

## Gilliam, Allen

---

**From:** Gilliam, Allen  
**Sent:** Monday, December 12, 2011 3:28 PM  
**To:** tim.barry@st-ji.com  
**Cc:** heber springs  
**Subject:** AR0022381\_Saint Jean (ARP001050) November 2011 semi annual Pretreatment Report Reply\_20111212

Tim,

Your November 2011 Semi-Annual Pretreatment Report was received, reviewed and deemed compliant with the National Pretreatment Regulations in 40 CFR 403.

As per the compliance assurance visit on 11/8/11 and subsequent correspondence it was discovered Saint Jean discharges regulated (aluminum forming heat treat quench water under 40 CFR 467.46) wastewater approximately every 7 to 10 years from its dedicated cooling tower system.

Your signed certification statement, "There has been no regulated wastewater discharged to the City's sewer system during this 6 month reporting period" on this semi-annual report will be considered a complete report.

Please keep this office apprised of any change in process water discharge practices. It is strongly advised to stay in close communications with your maintenance supervisor to ascertain well in advance of regulated wastewater to be discharged from the heat treatment quench tank's recycled cooling tower system. A week's notice should be given to you for procuring proper sample bottles from an ADEQ certified lab. Four (4) equally time-spaced grab samples over that discharge period of time should be taken and analyzed to show compliance with the Aluminum Forming Pretreatment Standards in 40 CFR 467.46.

Total wastewater discharged and million pounds of aluminum quenched will also have to be reported over that "7 to 10 year" period.

Please keep this correspondence in your "Pretreatment File" for future use for others to follow.

If you have any questions or concerns, please feel free to contact this office.

Sincerely,

Allen Gilliam  
ADEQ State Pretreatment Coordinator  
501.682.0625

cc: Donald Knight/General Manager/Heber Springs Wastewater