

Gage, Hannah

From: Gilliam, Allen
Sent: Monday, December 05, 2016 10:24 AM
To: 'MCDUGAL Mandie'; SWARTWOOD Matt; WOZNY Tim
Cc: Gage, Hannah; Yates, Adam; heber springs Kent Latch
Subject: AR0022381_St Jean ARP001050 Nov 2016 reply to questions Semi annual No Discharge Pretreatment report_20161205

Thank you Mandie,

Allen Gilliam
ADEQ State Pretreatment Coordinator
501.682.0625

[E/NPDES/NPDES/Pretreatment/Reports](#)

From: MCDUGAL Mandie [<mailto:mandie.mcdougal@st-ji.com>]
Sent: Friday, December 02, 2016 10:10 AM
To: Gilliam, Allen; SWARTWOOD Matt; WOZNY Tim
Cc: Gage, Hannah; Yates, Adam; heber springs Kent Latch
Subject: RE: AR0022381_St Jean ARP001050 Nov 2016 Semi annual No Discharge Pretreatment report_20161201

Mr. Gilliam,

We have two closed loops systems. Building one is for cooling parts, building two is for cooling the building. For building 1, up until 2012, we had an environmental service (Crystal Clean) which came with a large filtration system and tanker to draw the water out, filter it, and replace it. We haven't had that service since then, but are scheduling it for near the end of this month. Any water lost from that system is left in Crystal Clean's vac tank. Building 2 gets an additive to keep the water at an acceptable level and has never been discharged. We have no current expectation of completely replacing either system. If anything should change we will update all pertinent people, including ADEQ and Kent Latch, immediately.

Tim Wozny is the maintenance manager for building 1, though should not be a regular contact. He was filling in for certain aspects of EHS during the layoff. Matt Swartwood is the Quality Manager. I report to him and include him on emails for his information.

If you have any further questions, please do not hesitate to contact me.

Best,

Mandie MCDUGAL

Environmental, Health , & Safety Coordinator

Saint Jean Industries Inc
Innovative Solutions.
424 Industrial Park Road
72543 Heber Springs
Tel : +1 (501) 362-9536

