

Torrence, Rufus

From: Torrence, Rufus
Sent: Wednesday, March 30, 2011 9:00 AM
To: 'ken@pbwastewater.com'
Cc: Vincent Miles (Vincent@pbwastewater.com)
Subject: AFIN 35-00149 AR0033316 City of Pine Bluff 2010 Annual Report



March 30, 2011

Mr. Ken Johnson
Pine Bluff Wastewater Utility
1520 S. Ohio Street
Pine Bluff, Arkansas 71601-6055

Re: City of Pine Bluff 2010 Pretreatment Annual Report
(Permit No. AR0033316, AFIN 34-00149)

Dear Mr. Johnson:


The Department has reviewed the City's 2010 Annual Report and the report has been deemed "complete". Nonetheless, the Department has an additional request.

In reference to the City's NPDES permit, the City is required to test for Table III parameters which do not include Molybdenum. EPA recently requested all pretreatment cities to include Molybdenum as a pollutant-of-concern when developing local limits. The Department requests that the City test for Molybdenum for all future annual reports.

The Department appreciates the City's continued efforts in annual reporting. The City will not be required to submit additional information at this time.

If you have any questions or concerns, please contact the Department at (501) 682-0626 or by email at torrence@adeq.state.ar.us.

Sincerely,



Rufus Torrence, Pretreatment Engineer
Water Division

CC: Vincent Miles, Environmental Compliance Supervisor

ARKANSAS DEPARTMENT OF ENVIRONMENTAL QUALITY
5301 NORTHSHORE DRIVE / NORTH LITTLE ROCK / ARKANSAS 72118-5317 / TELEPHONE 501-682-0744 / FAX 501-682-0745
www.adeq.state.ar.us