

Torrence, Rufus

From: Torrence, Rufus
Sent: Friday, February 25, 2011 8:30 AM
To: Sal Pappalardo (sal@jwwu.com)
Subject: AFIN 60-00543 AR0041335 City of Jacksonville 2010 Annual Report
Attachments: JKVL TBLL2008.xls; AR0041335_City of Jacksonville Maximum Allowable Headworks Loadings and Water Quality Levels not to be Exceeded Guidance_20080603.pdf; JKVL Inf Eff Chart.doc



February 25, 2011

Sal Pappalardo, Pretreatment Coordinator
City of Jacksonville
248 Cloverdale Road
Jacksonville, Arkansas 72076

Re: City of Jacksonville 2010 Annual Pretreatment Report
(Permit No. AR0041335, AFIN 60-00543)

Dear Mr. Pappalardo:

The Department has reviewed the City's 2010 Annual Report. The report is complete. However, the City did not list the Maximum Allowable Headworks Concentrations (MAHCs) and Water Quality Limits on the influent-effluent chart in the report.


In a letter dated June 3, 2008 the Department recommended that the City used the MAHCs developed by ADEQ. For expediency, the Department recommends that the City list the MAHCs shown on the Local Limits worksheet in the attached TBLL workbook. For the City's convenience, the Department has attached a chart with these MAHCs listed.

Please note that the effluent values for Copper and Zinc are approaching the applicable Water Quality Standards (WQS). The WQS for Copper is only 9.24 ug/l (the city reported a concentration of 8.3 ug/l in the effluent). The WQS for Zinc is only 85.53 ug/l (the city reported 52 ug/l). The City may want to research the potential source of these metals prior to re-issuance of the NPDES permit.

The Department appreciates the City's continued efforts in annual reporting and the City will not be required to submit any additional information for the 2010 annual report.

If you have any questions or concerns, please contact the Department at (501) 682-0626 or by email at torrence@adeq.state.ar.us .

Sincerely,



Rufus Torrence, Pretreatment Engineer
Water Division

ARKANSAS DEPARTMENT OF ENVIRONMENTAL QUALITY
9301 NORTHSHORE DRIVE / NORTH LITTLE ROCK / ARKANSAS 72115-5317 / TELEPHONE 501-682-0244 / FAX 501-687-1111
www.adeq.state.ar.us