

August 9, 2011

Alton Yancey, Manager Marianna Water and Sewer Commission P.O. Box 737 Marianna, Arkansas 72360

RE: Pond B Sanitary Sewer Collection System

AFIN: 39-00034 NPDES Permit No.: AR0034142

Dear Mr. Yancey:

On August 3, 2011, I conducted a Sanitary Sewer Overflow Inspection of the above referenced facility in accordance with the provisions of the Federal Clean Water Act, the Arkansas Water and Air Pollution Control Act, and the regulations promulgated thereunder. At the time of inspection, the system appeared to be in compliance with the applicable regulations.

If I can be of any assistance, please contact me at (870) 247-5155.

L. Honderson

Sincerely,

Steven L. Henderson District 6 Inspector Water Division

cc: Water Division Enforcement Branch

Water Division Permits Branch

ADEQ Water NPDES Inspection	AFIN: 39-00034	Permit #: AR0034142

3	E P A													Form Approved OMB No. 2040-0003			
UNITED STATES ENVIRONMENTAL PROTECTION AGENCY																	
NPDES Compliance Inspection Report																	
			<u>_</u>	-													
	Section A: National Data System Coding Transaction Code NPDES Yr/Mo/Day Inspec. Type Inspector Fac. Type																
1	1 N 2 5 3 A R 0 0 3 4 1 4 2 11 12 1 1 0 8 0 3 17 18							18	V 19 S 20 1								
	Inspection Work Days]	•	Evaluation R	Rating	E	3I 	(QA		 I	 I	F	Reserved			
	67 69		70	N		71	N 7	72	N 73		74	75		80			
						ection B		ity l					1				
incli	ne and Location of Facility Inspected adde POTW name and NPDES permi of Marianna WWTP – Pond	t num		al users disc	charging to	POTW	, also		Entry Time/Da 9:00 a.m. 8/3					Permit Effective Date February 1, 2010			
North of Hwy. 79 and approximately ¼ mile West of Marianna Section 13, Township 2 North, Range 3 East Lee County, Arkansas Exit Time/Date 11:45 a.m. 8/3/2011							Permit Expiration Date January 31, 2015										
Alton Yancey, Manager (870) 295-2115						ner Facility Data											
Nan	David Moneymaker, Class I Operator (870) 295-2115 PDS# 060516 Name, Address of Responsible Official/Title/Phone and Fax Number PDS# 060516							W 000210									
Alton Yancey, Manager (870) 295-2115 Marianna Water and Sewer Commission Contacted																	
P.O. Box 737 Marianna, Arkansas 72360 Yes No																	
									ring Inspection								
S		N			•	ırginal, l			sfactory, N = No			Τ,	N	a			
S	Permit Records/Reports	N		Measureme Ionitoring I		-		•	erations & Mai dge Handling/I			_					
S	Facility Site Review	N		liance Sche	_	-	<u> </u>		ige Handing/L treatment	Disposa	11	-	.,				
N	Effluent/Receiving Waters	N	Labor		uuics	ŀ	N.T		rm Water			1	N Other:				
	Emucing Receiving Waters	Se		•	ry of Findings/Comments (Attach additional sheets if necessary)				Other.								
A routine SSO inspection was conducted to determine compliance status with the Arkansas Water and Air Pollution Control Act, the Federal Clean Water Act and the regulations promulgated thereunder. At the time of inspection, the facility appeared to be in compliance with the applicable regulations.																	
_	ne(s) and Signature(s) of Inspector(s) Steven L. H.		son		Agency/ ADEQ/				Fax 247-5155/ (870) 247-5	5185			Date August 8, 2011			
Sign	nature of Reviewer				Agency/	/Office/	Phone a	and	Fax Numbers					Date			

ADEQ Water NPDES Inspection	AFIN: 39-00034	Permit #: AR0034142

COLLECTION SYSTEM INSPECTION AND OVER	RALL RATING	Øs	□м	□u	□NA	□NE	
PROVIDE A BRIEF DESCRIPTION OF THE COLLECTION SYSTEM:							
Gravity Flow > 5 Pump Stations > WWTP POPULATION SERVED/NUMBER OF RESIDENTIAL AND (COMMERCIAL CONNECTIONS	S:					
Population= 4119 Residential= 504 Commercial= 76							
FEET OF SEWER SYSTEM: Unknown							
AGE OF SYSTEM: Unknown							
DOES THE SYSTEM EXPERIENCE PROBLEMS DURING DESCRIPTION (EXPLAIN): Infiltration during heavy rainfall events	DRY OR WET WEATHER		ØY	□N	□NA	□NE	
IS THERE A SYSTEM IN PLACE FOR REPORTING SSOS Contact ADEQ via phone or e-mail within 24 hours, mont			ØY	□и	□NA	□NE	
ARE ALL SSOs REPORTED REGARDLESS OF SIZE:		ØY	□N	□NA	□NE		
HAVE SSOs REACHED "WATERS OF THE U. S." (LIST DA):	□Y	ØN	□NA	□NE		
		l .					
PUMP STATIONS		□s	□м	□u	□NA	□NE	
NUMBER OF PUMP STATIONS IN SYSTEM: 5 NUMBER WITH BACKUP POWER: 5							
HOW OFTEN ARE PUMP STATIONS INSPECTED/MONITORED: Daily							
ARE MAINTENANCE RECORDS AND/OR OPERATOR LOGS KEPT: Yes							
ADEQUATE INVENTORY OF SPARE PARTS: Yes							
TYPE OF REMOTE ELECTRONIC MONITORING USED (I.E. SCADA OR AUTO DIALERS): None							
BRIEF SUMMARY OF EMERGENCY PROCEDURES: contact operator							
NUMBER OF PUMP STATIONS VISITED DURING INSPECTION (SEE ATTACHED CHECKLISTS FOR EACH): 1							
SATELLITE SYSTEMS		□s	□м	□u	ØNA	□NE	
DOES THE COLLECTION SYSTEM RECEIVE FLOW FROM SATELLITE SYSTEMS:							
TYPE(S) OF WASTE WATER RECEIVED:_ □RESIDENTIAL □COMMERCIAL □INDUSTRIAL □OTHER:							
BRIEFLY DESCRIBE THE SATELLITE SYSTEM:							
ANY KNOWN PROBLEMS WITH SATELLITE SYSTEM:							
NAME, ADDRESS AND PHONE NUMBER OF PERSON RESPONSIBLE FOR SATELLITE SYSTEM:							

ADEQ Water NPDES Inspection	AFIN: 39-00034	Permit #: AR0034142

PUMP STATION VISIT (COMPLETE A SEPARATE CHECKLIST FOR EACH PUMP STATION VISITED)					
GENERAL INFORMATION AND OVERALL EVAL	☑S □M □U □NA				
NAME AND/OR LOCATION OF PUMP STATION: Underground Pump Station, Hwy. 1					
TYPE(S) OF WASTE WATER RECEIVED: ZRESIDENTIAL	☑COMMERCIAL □INDUSTRIA	AL DOTHER:			
NUMBER OF PUMPS: 2					
NUMBER AND SIZE OF PUMPS APPEARS ADEQUATE:		☑S □M □U □NA □NE			
EVIDENCE OF RECENT OVERFLOWS OR HIGH LEVELS:		□Y ØN □NA □NE			
GENERAL OPERATION AND MAINTENANCE		☑S □M □U □NA			
CLEAN AND WELL MAINTAINED WITH MINIMAL STORAG EQUIPMENT:		⊠S □M □U □NA □NE			
GATES/DOORS/HATCHES/LIDS/ETC. LOCKED TO PREVE ACCESS AND/OR TAMPERING:	⊠S □M □U □NA □NE				
WET WELLS, SUMPS AND PITS ADEQUATELY COVERED PROTECTED:	⊠S □M □U □NA □NE				
ELECTRICAL CONTROLS COVERS CONDUIT AND EQUIP INSTALLED AND MAINTAINED:	⊠S □M □U □NA □NE				
GUARDS AND SHIELDS IN PLACE AROUND MOVING EQUENCES HAFTS, ETC.):	⊠S □M □U □NA □NE				
ADEQUATE VENTILATION TO PREVENT EXCESSIVE CONGASES AND FUMES:	⊠S □M □U □NA □NE				
ADEQUATE LIGHTING FOR ROUTINE INSPECTION/MAIN	☑S □M □U □NA □NE				
SEALS, VALVES AND PACKING ADEQUATELY MAINTAIN	☑S □M □U □NA □NE				
MINIMAL ACCUMULATION OF GREASE AND SOLIDS IN V	☑S □M □U □NA □NE				
BACKUP POWER AND ALARMS		⊠S □M □U □NA			
PROVISIONS FOR GENERATOR AND/OR EMERGENCY T	RANSFER PUMP:	⊠S □M □U □NA □NE			
AUDIBLE/VISUAL ALARM WITH EMERGENCY CONTACT I	☑S □M □U □NA □NE				
SCADA SYSTEM (LIST PARAMETERS MONITORED):	□Y □N ☑NA □NE				