

Permit No. 263-A was issued on November 22, 1974 to Arkansas Power and Light Company (AP&L) for the construction and operation of the White Bluff coal fired steam electric station. The electrostatic precipitators (EP) were installed upstream of the air preheaters (hot-side) and, are, therefore exposed to relatively high temperatures of approximately 800° F. AP&L proposes to reroute the ducting such that the air entering the EP's would first be cooled in the preheaters (cold-side) and thus extend the life of the EP's while improving the operation and maintenance.

The Commission hereby approves the amendment of Permit No. 263-A to reflect the aforementioned modification.

COMMISSIONERS

SW
JTB
[Signature]
[Signature]
[Signature]
[Signature]
[Signature]
[Signature]

John P. Saxton
CHAIRMAN

SUBMITTED BY Wilson Tolefree DATE PASSED July 23, 1982