

The Commission approves the below listed modification to the latest addition of the "Recommended Standards for Sewage Works" published by the Great Lakes-Upper Mississippi Board of State Sanitary Engineers. Use of the listed modification will only be approved by the Department when fully justified. This Minute Order supplements Minute Order No. 80-21 passed on April 4, 1980 which adopted, with modifications, the "Recommended Standards for Sewage Works" as basic criteria for wastewater treatment works in the State of Arkansas.

Chapter 20 - Design Of Sewers
Section 25 - Manholes
Subsection 25.1 - Locations

Cleanouts may be substituted for manholes under the following conditions:

1. The line shall be a dead end line serving no more than 4 services without the possibility of future extensions.
2. The cleanout shall terminate at the ground's surface in a concrete pad a minimum 24 inches square.
3. The cleanout pipe diameter shall be the same nominal diameter as the diameter of the line it serves.
4. The cleanout shall not be placed more than 150 feet past the last manhole.
5. Approval of the limited use of cleanouts in lieu of manholes is subject to the discretion and concurrence of the particular wastewater utility involved.

COMMISSIONERS

[Signature]

4210

[Signature]

[Signature]

[Signature]

[Signature]

[Signature]

[Signature]

[Signature]

SUBMITTED BY: TONIE PATTERSON DATE PASSED: 2/24/92