

**ARKANSAS DEPARTMENT OF ENVIRONMENTAL QUALITY
P. O. BOX 8913, LITTLE ROCK, AR 72219-8913**

COMPLAINT REPORT

LOCATION: Hwy 66 West at PD Builder's Supply in Mountain View	AFIN#: 69-00011	PERMIT#: AR0020117
DATE RECEIVED: 4-13-09	COUNTY: Stone	
COMPLAINANT NAME: anonymous	COMPLAINT AGAINST: City of Mountain View	
ADDRESS: n/a	ADDRESS: P.O. Drawer 360 Mountain View, AR 72560	
PHONE: n/a Fax: n/a	PHONE: 870 269-3293	FAX: n/a

PERSON RECEIVING REPORT: Tony Morris	DATE: 4-13-09	SUPERVISOR REFERRAL:	DATE:
INSPECTOR REFERRED:	DATE:	MEDIA SUPERVISOR REFERRAL:	DATE:
PHONE REFERRAL CONTACT:	DATE:	RECEIVING INSPECTOR: Bruce Kirkpatrick	DATE: 4-13-09

DESCRIPTION (IN DETAIL)

Manhole overflow

LOCATION (IN DETAIL)

Hwy 66 West at PD Builder's Supply

PREVIOUS COMPLAINT? ___ YES NO **DATES:**

DISCHARGE TO STREAM? YES ___ NO **NAME OF STREAM:** Hughes Creek

HOW COMPLAINT WAS RECEIVED: PHONE ___ LETTER ___ VERBAL ___ FAX ___ E-MAIL

FOLLOW UP ON COMPLAINT

COMPLAINT #: *n/a*

AFIN #: *69-00011*

INSPECTOR: *Bruce Kirkpatrick*

DATE: *4-27-09*

ACTION TAKEN: *Site investigation*

PHOTOS TAKEN: *yes*

A NPDES recon inspection was performed on 4-27-09. See the NPDES Inspection Report for findings. Pump failure during heavy rains resulted in a sewer overflow of about 5000 gallons on 4/12/09. Site was cleaned and disinfected. Pump was repaired. Overflow was reported as required by permit.

FURTHER ACTION TAKEN/TO BE TAKEN: *Letter will be sent to the City with no further action required at this time.*

A copy of all will be sent to the ADEQ files in Little Rock. A copy will be retained at the ADEQ Jasper Field Office.

INSPECTOR SIGNATURE:



DATE: *6/11/09*

HOURS WORKED: *4*