



Form Approved  
OMB No. 2040-0003  
Approval Expires 7-31-85

**UNITED STATES ENVIRONMENTAL PROTECTION AGENCY**  
**Washington, D.C. 20460**  
**NPDES Compliance Inspection Report**

**Section A: National Data System Coding**

Transaction Code	NPDES										yr/mo/day						Inspec. Type	Inspector	Fac Type	
1 N	2 5	3 A	R	0	0	0	1	2	1	0	11 0	12 6	0	7	0	6	17 R	19 S	20 2	
Remarks																				
0	2	-	0	0	0	1	3	A	s	h	l	e	y							
Inspection Work Days					Facility Evaluation Rating					BI	QA	-----Reserved-----								
67					70	3	71	N	72	N	73		74	75						80

**Section B: Facility Data**

Name and Location of Facility Inspected (For industrial users discharging to POTW, also include POTW name and NPDES permit number) Georgia Pacific Corporation d/b/a Georgia Pacific Crossett Paper Operation, 100 Papermill Road Crossett, AR	Entry Time /Date 13:51/ 06 July 2006	Permit Effective Date 01 September 2004
	Exit Time/Date 14:45/ 06 July 2006	Permit Expiration Date 31 August 2009
Name(s) of On-Site Representative(s)/Title(s)/Phone and Fax Number(s) James Cutbirth, Technical Service Manager/870567-8144 Fax 870-364-9076	Other Facility Data	
Name, Address of Responsible Official/Title/Phone and Fax Number Karen Dickinson, Vice President 870-567-5049 Georgia Pacific Corporation P.O. Box 3333 Crossett, AR 71635	Contacted Yes <input type="checkbox"/> No <input checked="" type="checkbox"/>	

**Section C: Areas Evaluated During Inspection**

(S = Satisfactory, M = Marginal, U = Unsatisfactory, N = Not Evaluated)

N	Permit	N	Flow Measurement	S	Operations & Maintenance	N	Sampling
N	Records/Reports	N	Self-Monitoring Program	N	Sludge Handling/Disposal	N	Pollution Prevention
N	Facility Site Review	N	Compliance Schedules	N	Pretreatment	N	Multimedia
N	Effluent/Receiving Waters	N	Laboratory	N	Storm Water		Other:

**Section D: Summary of Findings/Comments (Attach additional sheets if necessary)**

This inspection was performed in response to a complaint which alleged that the facility had plant effluent flowed through a residential neighborhood located on Pistol Street in Crossett. The complainant state that is had been sometime since this condition had been observed. However, the complainant also stated that the area smelled terrible and that the fumes off the plant effluent had corroded metal in the neighborhood.

On the date of the inspection, I visited Pistol Street located in Crossett. The main storm drain in this area was located around 500 Pistol Street. No evidence of plant effluent was observed in this storm drain and the appearance of said storm drain appeared normal with no flow, only standing water from the rain a few days earlier. The odor of the paper mill was detected in the neighborhood. I then proceeded to the bar screen area of the paper mill. The paper mill effluent is conveyed to the bar screen area by two sets of enclosed pipe sewers which end at the bar screen area. The end of the pipeline was 0.5 miles from Pistol Street. I traveled up the pipeline and no leaks in the pipeline were observed. It appeared that the elevation of the storm drain at Pistol Street was higher than the elevation of the plant effluent.

Name(s) and Signature(s) of Inspector(s) John Wesley Lamb	Agency/Office/Telephone/Fax ADEQ/EI Doraod/870-862-5941/870-862-3509	Date 01 August 2006
Patricia Willis	EPA Region 6/Dallas/214-665-8356/214-665-7446	
Signature of Reviewer	Agency/Office/Phone and Fax Numbers	Date