



UNITED STATES ENVIRONMENTAL PROTECTION AGENCY  
Washington, D.C. 20460

# NPDES Compliance Inspection Report

Form Approved  
OMB No. 2040-0003  
Approval Expires 7-31-85

## Section A: National Data System Coding

Transaction Code	NPDES	yr/mo/day	Inspec. Type	Inspector	Fac Type
1 <input type="checkbox"/> N <input type="checkbox"/> 2 <input type="checkbox"/> 5 <input type="checkbox"/> 3 <input type="checkbox"/> A <input type="checkbox"/> R <input type="checkbox"/> 0 <input type="checkbox"/> 0 <input type="checkbox"/> 2 <input type="checkbox"/> 1 <input type="checkbox"/> 7 <input type="checkbox"/> 9 <input type="checkbox"/> 2 <input type="checkbox"/> 11 <input type="checkbox"/> 12 <input type="checkbox"/> 0 <input type="checkbox"/> 6 <input type="checkbox"/> 1 <input type="checkbox"/> 1 <input type="checkbox"/> 0 <input type="checkbox"/> 8 <input type="checkbox"/> 17 <input type="checkbox"/> 18 <input type="checkbox"/> C <input type="checkbox"/> 19 <input type="checkbox"/> S <input type="checkbox"/> 20 <input type="checkbox"/> 1 <input type="checkbox"/>					
Remarks					
<input type="checkbox"/> A <input type="checkbox"/> F <input type="checkbox"/> I <input type="checkbox"/> N <input type="checkbox"/> 0 <input type="checkbox"/> 8 <input type="checkbox"/> - <input type="checkbox"/> 0 <input type="checkbox"/> 0 <input type="checkbox"/> 0 <input type="checkbox"/> 3 <input type="checkbox"/> 4 <input type="checkbox"/>					
Inspection Work Days	Facility Evaluation Rating	BI	QA	Reserved	
67 <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> 69	70 <input type="checkbox"/> 2 <input type="checkbox"/>	71 <input type="checkbox"/> N <input type="checkbox"/>	72 <input type="checkbox"/> N <input type="checkbox"/>	73 <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>	74 <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> 75 <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> 80

## Section B: Facility Data

Name and Location of Facility Inspected (For industrial users discharging to POTW, also include POTW name and NPDES permit number) City of Berryville 1000 W Cedarvale S26 T20N R25W in Carroll County	Entry Time /Date 1000/11-08-06	Permit Effective Date November 1, 2002
	Exit Time/Date 1605/11/08-06	Permit Expiration Date October 31, 2007
Name(s) of On-Site Representative(s)/Title(s)/Phone and Fax Number(s) Darrell Backs/Chief Operator/870-423-3749/No fax	Other Facility Data	
Name, Address of Responsible Official/Title/Phone and Fax Number Kirby Murray/Public Works Director/870-423-4074/870-423-4501 City of Berryville P.O. Box 227 Berryville, AR 72616	Contacted Yes <input type="checkbox"/> No <input checked="" type="checkbox"/>	GPS Coordinates of Outfall 001: N36.35640 W93.58091  GPS Coordinates at Gate: N36.35718 W93.57895

## Section C: Areas Evaluated During Inspection

(S = Satisfactory, M = Marginal, U = Unsatisfactory, N = Not Evaluated)

<input type="checkbox"/> S	Permit	<input type="checkbox"/> S	Flow Measurement	<input type="checkbox"/> M	Operations & Maintenance	<input type="checkbox"/> U	Sampling
<input type="checkbox"/> U	Records/Reports	<input type="checkbox"/> U	Self-Monitoring Program	<input type="checkbox"/> S	Sludge Handling/Disposal	<input type="checkbox"/> N	Pollution Prevention
<input type="checkbox"/> S	Facility Site Review	<input type="checkbox"/> N	Compliance Schedules	<input type="checkbox"/> N	Pretreatment	<input type="checkbox"/> N	Multimedia
<input type="checkbox"/> S	Effluent/Receiving Waters	<input type="checkbox"/> U	Laboratory	<input type="checkbox"/> U	Storm Water	<input type="checkbox"/> S	Other: Effluent Limits

## Section D: Summary of Findings/Comments (Attach additional sheets if necessary)

No Storm Water Pollution Prevention Plan has been submitted or implemented as required by the permit.

See Attachments 3, 4, and 5 for details of additional findings.

DMRs for the months of August and September of 2006 were reviewed during the inspection. The effluent was within permit limits for those months.

Name(s) and Signature(s) of Inspector(s) John Fazio	Agency/Office/Telephone/Fax Arkansas Dept. of Environmental Quality/ Fayetteville/(501)682-0744	Date November 29, 2006
Signature of Reviewer ddw	Agency/Office/Phone and Fax Numbers	Date

**SECTION A - PERMIT VERIFICATION**

PERMIT SATISFACTORILY ADDRESSES OBSERVATIONS DETAILS:  S  M  U  NA (FURTHER EXPLANATION ATTACHED No)

- 1. CORRECT NAME AND MAILING ADDRESS OF PERMITTEE  Y  N  NA
- 2. NOTIFICATION GIVEN TO EPA/STATE OF NEW DIFFERENT OR INCREASED DISCHARGES  Y  N  NA
- 3. NUMBER AND LOCATION OF DISCHARGE POINTS AS DESCRIBED IN PERMIT  Y  N  NA
- 4. ALL DISCHARGES ARE PERMITTED  Y  N  NA

**SECTION B - RECORDKEEPING AND REPORTING EVALUATION**

RECORDS AND REPORTS MAINTAINED AS REQUIRED BY PERMIT. DETAILS:  S  M  U  NA (FURTHER EXPLANATION ATTACHED Yes)

- 1. ANALYTICAL RESULTS CONSISTENT WITH DATA REPORTED ON DMRs.  Y  N  NA
- 2. SAMPLING AND ANALYSES DATA ADEQUATE AND INCLUDE.  S  M  U  NA
  - a) DATES, TIME(S) AND LOCATION(S) OF SAMPLING  Y  N  NA
  - b) NAME OF INDIVIDUAL PERFORMING SAMPLING  Y  N  NA
  - c) ANALYTICAL METHODS AND TECHNIQUES.  Y  N  NA
  - d) RESULTS OF ANALYSES AND CALIBRATIONS.  Y  N  NA
  - e) DATES AND TIMES OF ANALYSES.  Y  N  NA
  - f) NAME OF PERSON(S) PERFORMING ANALYSES.  Y  N  NA
- 3. LABORATORY EQUIPMENT CALIBRATION AND MAINTENANCE RECORDS ADEQUATE. **Contract Laboratory**  S  M  U  NA
- 4. PLANT RECORDS INCLUDE SCHEDULES, DATES OF EQUIPMENT MAINTENANCE AND REPAIR.  S  M  U  NE
- 5. EFFLUENT LOADINGS CALCULATED USING DAILY EFFLUENT FLOW AND DAILY ANALYTICAL DATA.  Y  N  NA

**SECTION C - OPERATIONS AND MAINTENANCE**

TREATMENT FACILITY PROPERLY OPERATED AND MAINTAINED. DETAILS:  S  M  U  NA (FURTHER EXPLANATION ATTACHED Yes)

- 1. TREATMENT UNITS PROPERLY OPERATED.  S  M  U  NA
- 2. TREATMENT UNITS PROPERLY MAINTAINED. Seal out on grit pump  S  M  U  NA
- 3. STANDBY POWER OR OTHER EQUIVALENT PROVIDED. Generator and telemetry phone  S  M  U  NA
- 4. ADEQUATE ALARM SYSTEM FOR POWER OR EQUIPMENT FAILURES AVAILABLE. Computer call out  S  M  U  NA
- 5. ALL NEEDED TREATMENT UNITS IN SERVICE.  S  M  U  NA
- 6. ADEQUATE NUMBER OF QUALIFIED OPERATORS PROVIDED. 3 Class IIs; 1 Class I; 1 operator in-training  S  M  U  NA
- 7. SPARE PARTS AND SUPPLIES INVENTORY MAINTAINED.  S  M  U  NE
- 8. OPERATION AND MAINTENANCE MANUAL AVAILABLE.  Y  N  NA
- STANDARD OPERATING PROCEDURES AND SCHEDULES ESTABLISHED.  Y  N  NA
- PROCEDURES FOR EMERGENCY TREATMENT CONTROL ESTABLISHED.  Y  N  NE

**SECTION C - OPERATIONS AND MAINTENANCE (CONT'D)**

9. HAVE BYPASSES/OVERFLOWS OCCURRED AT THE PLANT OR IN THE COLLECTION SYSTEM IN THE LAST YEAR?  Y  N  NA  
 IF SO, HAS THE REGULATORY AGENCY BEEN NOTIFIED?  Y  N  NA  
 HAS CORRECTIVE ACTION BEEN TAKEN TO PREVENT ADDITIONAL BYPASSES/OVERFLOWS?  Y  N  NA

10. HAVE ANY HYDRAULIC OVERLOADS OCCURRED AT THE TREATMENT PLANT?  Y  N  NA  
 IF SO, DID PERMIT VIOLATIONS OCCUR AS A RESULT?  Y  N  NA

**SECTION D - SAMPLING**

PERMITTEE Sampling MEETS PERMIT REQUIREMENTS.  S  M  U  NA (FURTHER EXPLANATION ATTACHED Yes ).  
 DETAILS:

1. SAMPLES TAKEN AT SITE(S) SPECIFIED IN PERMIT.  Y  N  NA

2. LOCATIONS ADEQUATE FOR REPRESENTATIVE SAMPLES.  Y  N  NA

3. FLOW PROPORTIONED SAMPLES OBTAINED WHEN REQUIRED BY PERMIT.  Y  N  NA

4. SAMPLING AND ANALYSES COMPLETED ON PARAMETERS SPECIFIED IN PERMIT.  Y  N  NA

5. SAMPLING AND ANALYSES PERFORMED AT FREQUENCY SPECIFIED IN PERMIT.  Y  N  NA

6. SAMPLE COLLECTION PROCEDURES ADEQUATE  Y  N  NA

a) SAMPLES REFRIGERATED DURING COMPOSITING.  Y  N  NA

b) PROPER PRESERVATION TECHNIQUES USED.  Y  N  NA

c) CONTAINERS AND SAMPLE HOLDING TIMES CONFORM TO 40 CFR 136  Y  N  NA

7. IF MONITORING AND ANALYSES ARE PERFORMED MORE OFTEN THAN REQUIRED BY PERMIT, ARE THE RESULTS REPORTED IN PERMITTEE'S SELF-MONITORING REPORT?  Y  N  NA

**SECTION E - FLOW MEASUREMENT**

PERMITTEE FLOW MEASUREMENT MEETS PERMIT REQUIREMENTS.  S  M  U  NA (FURTHER EXPLANATION ATTACHED ( No ) )  
 DETAILS:

1. PRIMARY FLOW MEASUREMENT DEVICE PROPERLY INSTALLED AND MAINTAINED.  Y  N  NA  
 TYPE OF DEVICE 18" Parshall Flume

2. FLOW MEASURED AT EACH OUTFALL AS REQUIRED.  Y  N  NA

3. SECONDARY INSTRUMENTS (TOTALIZERS, RECORDERS, ETC.) PROPERLY OPERATED AND MAINTAINED.  Y  N  NA

4. CALIBRATION FREQUENCY ADEQUATE. (DATE OF LAST CALIBRATION ( 8-2-06 )  
 RECORDS MAINTAINED OF CALIBRATION PROCEDURES.  Y  N  NA  
 CALIBRATION CHECKS DONE TO ASSURE CONTINUED COMPLIANCE.  Y  N  NA

5. FLOW ENTERING DEVICE WELL DISTRIBUTED ACROSS THE CHANNEL AND FREE OF TURBULENCE.  Y  N  NA

6. HEAD MEASURED AT PROPER LOCATION.  Y  N  NA

7. FLOW MEASUREMENT EQUIPMENT ADEQUATE TO HANDLE EXPECTED RANGE OF FLOW RATES.  Y  N  NA

**SECTION F - LABORATORY**

PERMITTEE LABORATORY PROCEDURES MEET PERMIT REQUIREMENTS.  S  M  U  NA (FURTHER EXPLANATION ATTACHED Yes )  
 DETAILS:

1. EPA APPROVED ANALYTICAL PROCEDURES USED (40 CFR 136.3 FOR LIQUIDS, 503.8(b) FOR SLUDGES)  Y  N  NA

**SECTION F - LABORATORY (CONT'D)**

- 2. IF ALTERNATIVE ANALYTICAL PROCEDURES ARE USED, PROPER APPROVAL HAS BEEN OBTAINED  Y  N  NA
- 3. SATISFACTORY CALIBRATION AND MAINTENANCE OF INSTRUMENTS AND EQUIPMENT.  S  M  U  NA
- 4. QUALITY CONTROL PROCEDURES ADEQUATE.  S  M  U  NA
- 5. DUPLICATE SAMPLES ARE ANALYZED, TRC, pH, DO 100% OF THE TIME City sample % known; contract labs % not provided.  Y  N  NA
- 6. SPIKED SAMPLES ARE ANALYZED, \_\_\_% OF THE TIME.  Y  N  NA
- 7. COMMERCIAL LABORATORY USED.  Y  N  NA

LAB NAME Environmental Testing Group Environmental Testing Consultants  
 LAB ADDRESS 1702 E. Central Ave., Bentonville, AR 72712 2790 Whitten Rd., Memphis, TN 38133  
 PARAMETERS PERFORMED BOD5, TSS, NH<sub>3</sub>-N, fecal coliform, sludge parameters Biomonitoring

**SECTION G – (EFFLUENT)/RECEIVING WATERS OBSERVATIONS.**  S  M  U  NA (FURTHER EXPLANATION ATTACHED No).

**Based on visual observations only.**

OUTFALL NO.	OIL SHEEN	GREASE	TURBIDITY	VISIBLE FOAM	FLOAT SOL.	COLOR	OTHER
001	None	None	None	None	None	Clear	

Comments:

**SECTION H - SLUDGE DISPOSAL**

- SLUDGE DISPOSAL MEETS PERMIT REQUIREMENTS.  S  M  U  NA (FURTHER EXPLANATION ATTACHED No).  
 DETAILS:
- 1. SLUDGE MANAGEMENT ADEQUATE TO MAINTAIN EFFLUENT QUALITY.  S  M  U  NA
  - 2. SLUDGE RECORDS MAINTAINED AS REQUIRED BY 40 CFR 503.  S  M  U  NA
  - 3. FOR LAND APPLIED SLUDGE, TYPE OF LAND APPLIED TO: Agricultural (e.g., FOREST, AGRICULTURAL, PUBLIC CONTACT SITE)

**SECTION I - SAMPLING INSPECTION PROCEDURES** (FURTHER EXPLANATION ATTACHED No)

- 1. SAMPLES OBTAINED THIS INSPECTION.  Y  N  NA
- 2. TYPE OF SAMPLE OBTAINED - N/A  
 GRAB \_\_\_\_\_ COMPOSITE SAMPLE \_\_\_\_\_ METHOD \_\_\_\_\_ FREQUENCY \_\_\_\_\_
- 3. SAMPLES PRESERVED.  Y  N  NA
- 4. FLOW PROPORTIONED SAMPLES OBTAINED.  Y  N  NA
- 5. SAMPLE OBTAINED FROM FACILITY'S SAMPLING DEVICE.  Y  N  NA
- 6. SAMPLE REPRESENTATIVE OF VOLUME AND NATURE OF DISCHARGE.  Y  N  NA
- 7. SAMPLE SPLIT WITH PERMITTEE.  Y  N  NA
- 8. CHAIN-OF-CUSTODY PROCEDURES EMPLOYED.  Y  N  NA
- 9. SAMPLES COLLECTED IN ACCORDANCE WITH PERMIT.  Y  N  NA

FLOW CALCULATION SHEET

Field Data: Date 11-08-06 Time 10:55 a.m.

Head in Inches 7.5" = 0.625 ft

Type & Size of Primary Flow Measurement Device

18" Parshall Flume

Name & Model of Secondary Flow Measurement Device

BIF DC Totalizer/Recorder Model 257

Recorded Flow at date & time listed above 1.72 MGD

Flows are calculated from flow charts taken from the ISCO Open Channel Flow Measurement Handbook-5th Edition

$$\frac{1.72-1.882}{1.882} = -0.086$$

$$\% \text{ error} = \frac{(\text{recorded value} - \text{calculated value})}{\text{calculated value}} \times 100$$

$$\% \text{ error} = \frac{-0.086}{1} \times 100$$

$$\% \text{ error} = \underline{-8.6\% \text{ error } (<10\%, \text{ OK})}$$



NPDES Compliance Inspection Report  
Further Explanation

Page 2 of 4

Section B

Detail 2c, 2d, 2e, 2f

Consulting lab is not providing the permittee with the following:

1. the analytical methods or techniques used to analyze biochemical oxygen demand (BOD), total suspended solids (TSS), ammonia-nitrogen, and fecal coliform;
2. the analysis dates and times for BOD, TSS, ammonia-nitrogen, and fecal coliform;
3. the name of the person performing the analysis for BOD, TSS, ammonia-nitrogen, and fecal coliform; and

The permittee has no record of the following:

1. calibration records for pH, dissolved oxygen (DO), and total residual chlorine (TRC) measurement equipment; and
2. sampling time for pH, DO, and TRC.

Page 2 of 4

Section B

Detail 3

Consulting lab is not providing permittee with lab equipment calibration and maintenance records.

Page 2 of 4

Section C

Detail 2

Seal out on grit pump.

Page 2 of 4

Section C

Detail 7

A spare parts and supplies inventory should be maintained.

NPDES Compliance Inspection Report  
Further Explanation

Page 3 of 4

Section D

Detail 3

6 hr. and 24 hr. composite samples are time-weighted rather than flow-weighted.

Page 3 of 4

Section D

Detail 6b, c

6b: Consulting lab did not provide permittee with all chain-of-custody records to accompany lab reports, therefore, it is unknown if proper preservation techniques were used for BOD, TSS, ammonia-nitrogen, and fecal coliform for those sampling events.

6c: Consulting lab did not provide permittee with analysis time on lab report, therefore, it is unknown if holding times for BOD, TSS, ammonia-nitrogen, and fecal coliform were met.

Permittee has no records of sampling time for DO, pH and TRC, therefore, it is unknown if holding times were met for those parameters.

Page 3 of 4

Section F

Detail 1

Consulting lab did not provide permittee with analytical methods used, therefore, it is unknown if approved methods were used for BOD, TSS, ammonia-nitrogen, and fecal coliform.

Page 4 of 4

Section F

Detail 3

Consulting lab did not provide permittee with documentation of calibration and maintenance of instruments and equipment on lab report. This requirement can be satisfied by the consulting lab providing a statement on the lab report that the instruments and equipment are properly maintained and calibrated.



**NPDES Compliance Inspection Report  
Further Explanation**

**Page 4 of 4**

**Section D**

**Detail 4, 5, 6**

**Consulting lab did not provide permittee with spiked sample and duplicate sample analysis on lab report. Therefore, it is unknown if quality control procedures are adequate, and at what frequency duplicate and spiked samples are analyzed.**

**Page 1 of 4**

**Section D**

**No Storm Water Pollution Prevention Plan has been submitted or implemented by the permittee as required by the permit. The permittee can contact the ADEQ NPDES Branch for specifics regarding “No Exposure Certification” for possible exclusion from the NPDES permitting requirement for storm water discharges from your facility.**

# ADEQ

ARKANSAS  
Department of Environmental Quality

December 7, 2006

Kirby Murray, Public Works Director  
City of Berryville  
P.O. Box 227  
Berryville, AR 72616

RE: AFIN: 08-00034

NPDES Permit No.: AR0021792

Dear Mr. Murray:

On November 08, 2006, Dale Washam, Inspector Supervisor, and I, performed a routine compliance inspection of the waste water treatment facility in accordance with the provisions of the federal Clean Water Act, the Arkansas Water and Air Pollution Control Act, and the regulations promulgated there under. This inspection revealed the following violations:

1. Consulting lab is not providing permittee with the analytical methods or techniques used for analysis of biological oxygen demand (BOD), total suspended solids (TSS), ammonia-nitrogen, and fecal coliform; lab equipment calibration and maintenance records; chain-of-custody reports to accompany each of the lab analysis reports to document that proper preservation methods were used for BOD, TSS, ammonia-nitrogen, and fecal coliform; the analysis times on the lab analysis reports to document that holding times were met for BOD, TSS, ammonia-nitrogen, and fecal coliform; and spiked sample and duplicate sample analyses to document whether quality control procedures are adequate and at what frequency duplicate and spiked samples are analyzed. Additionally, the permittee has no calibration records for pH, dissolved oxygen (DO), and total residual chlorine (TRC); and has no records of analysis times for DO, pH, and TRC to document that holding times were met for these parameters. These items are in violation of Part II.C.3 of the permit and records of these items need to be maintained at the treatment facility.
2. Permittee has no record of the sampling times for DO, pH, and TRC. This is in violation of Part II.C.8.a of the permit.
3. Consulting lab is not providing permittee with the analysis date and time for BOD, TSS, ammonia-nitrogen, and fecal coliform. This is in violation of Part II.C.8.c of the permit.
4. Consulting lab is not providing permittee with the name of the individual performing the analysis for BOD, TSS, ammonia-nitrogen and fecal coliform. This is in violation of Part II.C.8.d of the permit.

WATER DIVISION

Kirby Murray  
December 7, 2006  
Page Two

5. Consulting lab is not providing permittee with the analytical methods or techniques used for analysis of BOD, TSS, ammonia-nitrogen, and fecal coliform. This is in violation of Part II.C.8.e of the permit.
6. 6-hour composite samples for BOD, TSS, ammonia-nitrogen, and fecal coliform are time-weighted rather than flow-weighted. This is in violation by definition in Part IV of the permit.
7. 24-hour composite samples for toxicity testing are time-weighted rather than flow-weighted. This is in violation of Part III.10.2.d.i of the permit.
8. An adequate spare parts and supplies inventory is not being maintained. Additionally, a seal is out on the grit pump. These items are in violation of Part II.B.1.a of the permit.
9. A Storm Water Pollution Prevention Plan has not been submitted or implemented by the permittee in accordance with the requirements of Part III, item 12 of the permit.

The above items require your immediate attention. Please submit a written response to these findings to the NPDES Enforcement Section of this Department when the violations have been corrected. This response should contain documentation describing the course of action taken to correct the items noted. This corrective action should be completed as soon as possible, and the written response is due by **December 21, 2006**.

If I can be any assistance, please contact me at 501-682-0744.

Sincerely,

A handwritten signature in black ink, appearing to read "John Fazio". The signature is stylized and cursive.

John Fazio  
District Field Inspector  
Water Division

cc: NPDES Enforcement Branch  
NPDES Permits Branch

## **503 SLUDGE INSPECTION CHECKLIST - LAND APPLICATION**

**FACILITY:** City of Berryville

**PERMIT #:** AR0021792

**INSPECTION DATE:** November 08, 2006

1. What is the quantity of sludge land applied per year (dry weight basis)?  
225 metric tons
2. What is the required frequency of monitoring for pollutants, pathogen densities, and vector attraction reduction? (See table 2-7, p. 43) Once per quarter as required by permit
3. Is monitoring being conducted at the required frequency? Yes
4. Which set of metals limits is being met? (pollutant concentration limits or ceiling concentration limits - See Table 2-1, p. 29) Ceiling and cumulative concentration limits
5. Which Pathogen Reduction Requirement alternative is being used? (See Table 2-5., p. 37) Class B – Alternative 2  
Are the requirements for the alternative being met? Yes
6. Which Vector Attraction Reduction option is being used? (See Table 2-6, p. 37) Option 2 – anaerobic digestion  
Are the requirements for the selected option being met? Yes

### **GO TO FLOW CHART, DETERMINE SLUDGE TYPE, RESULTING REQUIREMENTS**

7. What is the sludge type? (EQ, PC, CPLR, or APLR) PC Class B
8. Are site restrictions required? Yes  
Are they being met? (See Fig. 2-4, p. 38) Yes
9. Are management practices required? Yes  
Yes  
Are they being met? (See Fig. 2-9, p. 45)
10. Do the general requirements apply? Yes  
Are they being met? (See Fig. 2-8, p. 44) Yes
11. Is the facility subject to loading rate limits? Yes; by permit  
Yes  
Are they being met? (See Table 2-1, p. 29) Yes

**NOTE: TABLES AND PAGE NUMBERS REFERENCED ABOVE ARE FROM EPA'S A PLAIN ENGLISH GUIDE TO THE EPA PART 503 BIOSOLIDS RULE, September 1994.**