≎EPA

Form Approved OMB No. 2040-0003 Approval Expires 7-31-85

	UNITED STATES ENVIRONMENTAL PROTECTION AGENCY Washington, D.C. 20460														Approval Expires 7 31 03													
	NPDES Compliance Inspection Report																											
	Section A: National Data System Coding																											
1	Transaction Code N 2 5 3 A R	0 1 11 12 0													Inspec. Type Inspector Fac Type 18 V 19 S 20 1													
L	Inspection Work Days 67 69]		y Evalu	1	Ratir	ng		71	BI N	rks 72	QA L N	73				 74	75	<u> </u>	Resei	rved-					80		
							5	Sec	tion	B: Fa	cility	y Data																
inclu Jone	Name and Location of Facility Inspected (For industrial users discharging to POTW, also include POTW name and NPDES permit number) [Onesboro City Water and Light – East Treatment Plant]												Entry Time/Date 02/02/2007 1555									Permit Effective Date December 1, 2006						
5205 Ingles Rd. Jonesboro, AR Craighead County												Exit Time/Date 02/02/2007 1615								Permit Expiration Date November 30, 2011								
Name(s) of On-Site Representative(s)/Title(s)/Phone and Fax Number(s) Brett Tate/Supervisor – on site Jake Rice/General Operations Dir./870-930-3395 & Susan Merideth/Treatment Superintendent/870-930-3387 via phone													ther Facility Data															
Ron City P.O.	Name, Address of Responsible Official/Title/Phone and Fax Number Ronald Bowen/Manager/870-930-3300 City Water and Light of Jonesboro P.O. Box 1289 Jonesboro, AR 72403										Yes	Yes X No																
	Section C: Areas Evaluated During Inspection (S = Satisfactory, M = Marginal, U = Unsatisfactory, N = Not Evaluated)																											
N	Permit	N	Flov	w Mea	suren	ient				N	0	peratio	rations & Maintenance S								CSO/SSO							
N	Records/Reports	ds/Reports N Self-Monitoring						Program N Sl						adge Handling/Disposal S								Pollution Prevention						
N	Facility Site Review	⊢ '								N	Pı	retreatment N								Multimedia								
N Effluent/Receiving Waters N Laboratory N											St	orm Water N									Other:							
Section D: Summary of Findings/Comments (Attach additional sheets if necessary) This inspection was conducted in response to an anonymous complaint alleging an overflow from a cleanout at an apartment complex on Lakewood Dr. The overflow was the result of a blockage in the CWL collection system. CWL personnel removed the blockage on the previous day however they were not aware the cap had been removed from the cleanout at the apartment complex thus allowing wastes to be discharged onto the surface of the ground. Upon being informed of the overflow, CWL personnel quickly removed the discharged wastes and disinfected the affected area with lime. A 24-hr report of the SSO was submitted and a record of the overflow was added to the tabular report for submission with the February 2007 DMR. No further action is required at this time.																												
Name(s) and Signature(s) of Inspector(s) Brent L. Walker Brest L Walker								sas	Dep		Envi	onmer	Fax nmental Quality/Jonesboro/								Date							
Brer	at L. Walker	(8	(870) 935-7221 ext. 12/(870) 935-4715											February 21, 2007														
Signature of Reviewer								y/C	Office	e/Pho	ne an	d Fax 1	Fax Numbers									Date						



February 20, 2007

Ronald Bowen, Manager City Water & Light of Jonesboro P.O. Box 1289 Jonesboro, AR 72403

RE: Jonesboro CWL East Treatment Plant Sanitary Sewer Overflow Complaint

AFIN: 16-00152 NPDES Permit No.: AR0043401

Dear Mr. Bowen:

On February 2, 2007, I performed an investigation of Sanitary Sewer Overflow (SSO) at 3606 Lakewood Dr., in accordance with the provisions of the Federal Clean Water Act, the Arkansas Water and Air Pollution Control Act and the regulations promulgated thereunder. This inspection revealed

The permittee shall report all overflows with the Discharge Monitoring report (DMR) submittal. These reports shall be summarized and reported in tabular format. The summaries shall include: the date, time, duration, location, estimated volume, and cause of overflow; observed environmental impacts from the overflow; action taken to address the overflow; and ultimate discharge location if not contained (e.g., storm sewer system, ditch, tributary.)

Overflows which endanger health or the environment shall be orally reported to this department (Enforcement Section of Water Division), within 24 hours from the time the permittee becomes aware of the circumstance. A written report of overflows which endanger health or the environment shall be provided within 5 days of the time the permittee becomes aware of the circumstance.

If I can be of any assistance, please contact me at 870-935-7221 ext.-12.

Sincerely,

Brent L. Walker

District 3 Field Inspector

rest 2 Walton

Water Division

cc: NPDES Enforcement Branch

NPDES Permits Branch