



UNITED STATES ENVIRONMENTAL PROTECTION AGENCY
Washington, D.C. 20460

Form Approved
OMB No. 2040-0003
Approval Expires 7-31-85

NPDES Compliance Inspection Report

Section A: National Data System Coding

Transaction Code	NPDES	yr/mo/day	Inspec. Type	Inspector	Fac Type
1 N 2 5 3 A R 0 0 3 3 8 8 0 11 12 0 7 0 3 2 7 17 18 V 19 S 20 1					
Remarks					
A F I N # 2 6 - 0 0 1 4 5 G A R L A N D C O .					
Inspection Work Days	Facility Evaluation Rating	BI	QA	-----Reserved-----	
67 1 69	70 N	71 N	72 N	73	74 75 80

Section B: Facility Data

Name and Location of Facility Inspected (For industrial users discharging to POTW, also include POTW name and NPDES permit number)	Entry Time /Date 10:30 A.M. 3/27/07	Permit Effective Date 1 Jan. 2002
City of Hot Springs Pump Station at 117 Caroline Acres Road and Mount Carmel Road Hot Springs, AR	Exit Time/Date 11:50 A.M. 3/27/07	Permit Expiration Date 31 Dec. 2007
Name(s) of On-Site Representative(s)/Title(s)/Phone and Fax Number(s)	Other Facility Data	
Craig Stevens, Pump Station Supv., 501-627-6453, fax 501-262-0339		
Name, Address of Responsible Official/Title/Phone and Fax Number Kent Myers, City Manager, 501-321-6810 320 Davidson Drive Hot Springs, Arkansas 71901	Contacted Yes <input type="checkbox"/> No <input checked="" type="checkbox"/>	

Section C: Areas Evaluated During Inspection (S = Satisfactory, M = Marginal, U = Unsatisfactory, N = Not Evaluated)

-	Permit	-	Flow Measurement	-	Operations & Maintenance	-	Sampling
-	Records/Reports	-	Self-Monitoring Program	-	Sludge Handling/Disposal	-	Pollution Prevention
-	Facility Site Review	-	Compliance Schedules	-	Pretreatment	-	Multimedia
-	Effluent/Receiving Waters	-	Laboratory	-	Storm Water	S	CSO-SSO

Section D: Summary of Findings/Comments (Attach additional sheets if necessary)

An SSO inspection was performed on this pump station in response to a citizen's complaint. The investigation was performed on March 27, 2007. I did notice an odor coming from this particular pump station. I contacted Craig Stevens (City of Hot Springs) to discuss this complaint. He stated that the pump station collected wastewater from all of the grinders on Carline Acres Road, and that there would be odor coming from the station from time to time. I asked if there was something the city could do to correct this. He stated that an enzyme filter system could be place there to minimize the odor. I asked if he would consider installing one on this station since there was a nearby condominium. He stated that he would.

Name(s) and Signature(s) of Inspector(s) Jim McSwain	Agency/Office/Telephone/Fax ADEQ / Hot Springs, AR / 501-520-0541	Date 3/27/07
Signature of Management QA Reviewer	Agency/Office/Phone and Fax Numbers	Date

ADEQ

ARKANSAS
Department of Environmental Quality

March 27, 2007

Steve Mallett, Utilities Director
City of Hot Springs
P.O. Box 700
Hot Springs, Arkansas

Re: AFIN No.: 26-00145


NPDES Permit No.: AR0033880

Dear Mr. Mallett:

On March 27, 2007, I performed a routine SSO inspection of the city's wastewater collection system, in accordance with the provisions of the federal Clean Water ACT, the Arkansas Water and Air Pollution Control Act, and the regulations promulgated there under. Specifically the pump station located on the corner of Caroline Acres Road and Mount Carmel Road was inspected in response to a citizen's complaint. This inspection revealed that you were in compliance with the terms of your permit.

If I can be any assistance, please contact me at 501-520-0541.

Sincerely,



Jim McSwain
District Field Inspector
Water Division

cc: NPDES Branch