≎EPA

UNITED STATES ENVIRONMENTAL PROTECTION AGENCY
Washington, D.C. 20460

Form Approved OMB No. 2040-0003 Approval Expires 7-31-85

NPDES Compliand						
Section A: National Data System Coding						
Transaction Code NPDES yr/mo/day Inspect. Type Inspector Fac Type N 2 5 3 A R 0 0 2 1 8 0 6 11 12 0 7 0 4 1 0 17 18 C 19 S 20 1						
A F I N 6 0 - 0 0 4	Remarks 0 9 P U	L A S K I	C O U N T Y			
Inspection Work Days Facility Evaluation I 67 69 70 5	ı ı i	N 73 74 75	Reserved			
	Section B: Facility I	Data				
Name and Location of Facility Inspected (For industrial users also include POTW name and NPDES permit number)	discharging to POTW,	Entry Time /Date 0830 on 04/10/07	Permit Effective Date 01/01/07			
Little Rock Wastewater Utility – Adams Field Plant 1001 Temple Little Rock, AR		Exit Time/Date 1130 on 04/10/07	Permit Expiration Date 12/31/11			
Name(s) of On-Site Representative(s)/Title(s)/Phone and Fax N Perry Thornton / Plant Superintendent / 501-688-1526	Number(s)		Other Facility Data Major mun.			
Name, Address of Responsible Official/Title/Phone and Fax N Reggie Corbitt, C.E.O 221 E. Capitol Little Rock, AR 72202	umber	Yes No X	PL 92-500			
	ction C: Areas Evaluated Du y, M = Marginal, U = Unsati	ring Inspection sfactory, N = Not Evaluated)				
S Permit M Flow Measureme	ent S Ope	erations & Maintenance	S Sampling			
S Records/Reports S Self-Monitoring	g Program S Slu	dge Handling/Disposal	N Pollution Prevention			
Facility Site Review N Compliance Sch	edules N Pr	etreatment	N Multimedia			
S Effluent/Receiving Waters S Laboratory	N Sto	rm Water	Other:			
<u> </u>		ach additional sheets if necessar	y)			
The facility's effluent flow meter was found to be out of the 10% allowable error. During this inspection it was also found that the plant has changed their process operation of their aeration basins from a complete mix and aeration to a plugged flow and partial aeration to create an anoxic zone at the head of the basins and to increase detention time. Also the facility is now maintaining a two foot sludge blanket in their final clarifiers, where in previous years they have maintained virtually no blanket.						
Name(s) and Signature(s) of Inspector(s)						
Zachary Watson	Agency/Office/Telephone ADEQ / Little Rock / (501		Date 04/10/07			
Zachary Watson						

	Permit No. AR0021806					
SECTION A - PERMIT VERIFICATION						
PERMIT SATISFACTORILY ADDRESSES OBSERVATIONS DETAILS: S M U NA (FURTHER EXPLANATION ATTAINMENT)	ACHED <u>no</u>)					
1. CORRECT NAME AND MAILING ADDRESS OF PERMITTEE	■ Y □ N □ NA					
2. NOTIFICATION GIVEN TO EPA/STATE OF NEW DIFFERENT OR INCREASED DISCHARGES	□ y □ N ■ NA					
3. NUMBER AND LOCATION OF DISCHARGE POINTS AS DESCRIBED IN PERMIT	■ Y □ N □ NA					
4. ALL DISCHARGES ARE PERMITTED	□ Y ■ N □ NA					
SECTION B - RECORDKEEPING AND REPORTING EVALUATION						
RECORDS AND REPORTS MAINTAINED AS REQUIRED BY PERMIT. S M U NA (FURTHER EXPLANATION ATT DETAILS:	ACHED <u>no</u>)					
1. ANALYTICAL RESULTS CONSISTENT WITH DATA REPORTED ON DMRs.	■ y □ n □ na					
2. SAMPLING AND ANALYSES DATA ADEQUATE AND INCLUDE.						
a) DATES, TIME(S) AND LOCATION(S) OF SAMPLING	■ Y □ N □ NA					
b) NAME OF INDIVIDUAL PERFORMING SAMPLING	■ Y □ N □ NA					
c) ANALYTICAL METHODS AND TECHNIQUES.	■ Y □ N □ NA					
d) RESULTS OF ANALYSES AND CALIBRATIONS.	■ Y □ N □ NA					
e) DATES AND TIMES OF ANALYSES.	■ Y □ N □ NA					
f) NAME OF PERSON(S) PERFORMING ANALYSES.	■ Y □ N □ NA					
3. LABORATORY EQUIPMENT CALIBRATION AND MAINTENANCE RECORDS ADEQUATE.						
4. PLANT RECORDS INCLUDE SCHEDULES, DATES OF EQUIPMENT MAINTENANCE AND REPAIR.						
5. EFFLUENT LOADINGS CALCULATED USING DAILY EFFLUENT FLOW AND DAILY ANALYTICAL DATA.	■ Y □ N □ NA					
SECTION C - OPERATIONS AND MAINTENANCE						
TREATMENT FACILITY PROPERLY OPERATED AND MAINTAINED. S M U NA (FURTHER EXPLANATION ATTACHED yes) DETAILS:						
1. TREATMENT UNITS PROPERLY OPERATED.	□ M □ U □ NA					
2. TREATMENT UNITS PROPERLY MAINTAINED.	□м □u □NA					
3. STANDBY POWER OR OTHER EQUIVALENT PROVIDED.	□м □u □NA					
4. ADEQUATE ALARM SYSTEM FOR POWER OR EQUIPMENT FAILURES AVAILABLE.	□м □u □NA					
5. ALL NEEDED TREATMENT UNITS IN SERVICE.	□ M □ U □ NA					
6. ADEQUATE NUMBER OF QUALIFIED OPERATORS PROVIDED.	□м □u □NA					
7. SPARE PARTS AND SUPPLIES INVENTORY MAINTAINED.	□м □u □NA					
8. OPERATION AND MAINTENANCE MANUAL AVAILABLE.	■ Y □ N □ NA					
STANDARD OPERATING PROCEDURES AND SCHEDULES ESTABLISHED.	\blacksquare Y \square N \square NA					
PROCEDURES FOR EMERGENCY TREATMENT CONTROL ESTABLISHED.	\blacksquare Y \square N \square NA					

		PERMIT NO. AR0021806			
SECTION C - OPERATIONS AND MAINTENANCE (CONT'D)					
IF SO, HAS THE REGULATORY AGENCY BEEN NOTIFIED?	1	Y □ N □ NA Y □ N □ NA Y □ N □ NA			
		Y □ N □ NA Y ■ N □ NA			
SECTION D - SELF-MONITORING					
PERMITTEE SELF-MONITORING MEETS PERMIT REQUIREMENTS. ■ S □ M □ U □ NA (FURTHER EXPLANATION ATTACHDETAILS:	ŒD	<u>no</u>).			
1. SAMPLES TAKEN AT SITE(S) SPECIFIED IN PERMIT.	-	Y □ N □ NA			
2. LOCATIONS ADEQUATE FOR REPRESENTATIVE SAMPLES.	-	Y □ N □ NA			
3. FLOW PROPORTIONED SAMPLES OBTAINED WHEN REQUIRED BY PERMIT.	-	y □ n □ na			
4. SAMPLING AND ANALYSES COMPLETED ON PARAMETERS SPECIFIED IN PERMIT.	= '	Y □ N □ NA			
5. SAMPLING AND ANALYSES PERFORMED AT FREQUENCY SPECIFIED IN PERMIT.	1	Y □ N □ NA			
6. SAMPLE COLLECTION PROCEDURES ADEQUATE	_	Y □ N □ NA			
a) SAMPLES REFRIGERATED DURING COMPOSITING.	_ ·	Y □ N □ NA			
b) PROPER PRESERVATION TECHNIQUES USED.	,	Y □ N □ NA			
c) CONTAINERS AND SAMPLE HOLDING TIMES CONFORM TO 40 CFR 136.3.		Y □ N □ NA			
7. IF MONITORING AND ANALYSES ARE PERFORMED MORE OFTEN THAN REQUIRED BY PERMIT, ARE THE RESULTS REPORTED IN PERMITTEE'S SELF-MONITORING REPORT?		Y □ N ■ NA			
SECTION E - FLOW MEASUREMENT					
PERMITTEE FLOW MEASUREMENT MEETS PERMIT REQUIREMENTS. S M U NA (FURTHER EXPLANATION ATTACHEDno) DETAILS: Flow calibration check was out of the +/-10% range of error					
1. PRIMARY FLOW MEASUREMENT DEVICE PROPERLY INSTALLED AND MAINTAINED. TYPE OF DEVICE weir	.	Y □ N □ NA			
2. FLOW MEASURED AT EACH OUTFALL AS REQUIRED.	-	Y □ N □ NA			
3. SECONDARY INSTRUMENTS (TOTALIZERS, RECORDERS, ETC.) PROPERLY OPERATED AND MAINTAINED.	<u> </u>	y ■ n □ na			
RECORDS MAINTAINED OF CALIBRATION PROCEDURES.	Y	Y □ N □ NA Y □ N □ NA Y □ N □ NA			
5. FLOW ENTERING DEVICE WELL DISTRIBUTED ACROSS THE CHANNEL AND FREE OF TURBULENCE.		Y □ N □ NA			
6. HEAD MEASURED AT PROPER LOCATION.		y □ n □ na			
		Y □ N □ NA			
SECTION F - LABORATORY					
PERMITTEE LABORATORY PROCEDURES MEET PERMIT REQUIREMENTS. ■ S □ M □ U □ NA (FURTHER EXPLANATION.) DETAILS:	/ AT :	TACHED <u>no</u>			
1. EPA APPROVED ANALYTICAL PROCEDURES USED (40 CFR 136.3 FOR LIQUIDS, 503.8(b) FOR SLUDGES)		y □ n □ na			

						Permit N	No. AR0021806
SECTION F - LABORATO	RY (CONT'D)						
2. IF ALTERNATIVE ANALYT	TICAL PROCEDURES A	ARE USED, PROPER A	PPROVAL HAS BEEN	OBTAINED	□y□n	■ NA	
3. SATISFACTORY CALIBRA	TION AND MAINTENA	NCE OF INSTRUMEN	TS AND EQUIPMENT.		■ S □ M □ U	□ NA	
4. QUALITY CONTROL PROC	CEDURES ADEQUATE.				■ s □ m □ u	□ NA	
5. DUPLICATE SAMPLES ARE	E ANALYZED. <u>>10</u> %	OF THE TIME.			■ y □ n	□ NA	
6. SPIKED SAMPLES ARE AN	ALYZED. <u>>10</u> % OF	THE TIME.			\blacksquare Y \square N	□ NA	
7. COMMERCIAL LABORATO	ORY USED.				\blacksquare Y \square N	□ NA	
LAB NAME In House Lab LAB ADDRESS 9500 Birdwo PARAMETERS PERFORME		RC, & pH					
SECTION G - EFFLUENT	T/RECEIVING WAT	ERS OBSERVATIO	N ■s □ m □ u [☐ NA (FURTHER EXPLA	ANATION ATTACHED <u>no</u>).	
OUTFALL NO.	OIL SHEEN	GREASE	TURBIDITY	VISIBLE FOAM	FLOAT SOL.	COLOR	OTHER
001	none	none	none	none	none	clear	NA
							_
RECEIVING WATER OBSER	RVATIONS <u>could not</u>	observe due to airport a	ccess restrictions.				
SECTION H - SLUDGE I	DISPOSAL						
SLUDGE DISPOSAL MEETS DETAILS:	S PERMIT REQUIREM	ENTS.	■ s □ m □ u □	NA (FURTHER EXPLAI	NATION ATTACHED <u>no</u>).	
1. SLUDGE MANAGEMENT ADEQUATE TO MAINTAIN EFFLUENT QUALITY. ■ S □ M □ U □ NA							
2. SLUDGE RECORDS MAINTAINED AS REQUIRED BY 40 CFR 503.					J □ NA		
3. FOR LAND APPLIED SLU	JDGE, TYPE OF LAND	APPLIED TO:agric	ultural (e.g., FORES	T, AGRICULTURAL, P	UBLIC CONTACT SIT	TE)	
SECTION I - SAMPLING	INSPECTION PRO	CEDURES (FURTH	ER EXPLANATION ATTAC	THED <u>N/A</u>).			
1. SAMPLES OBTAINED THIS INSPECTION. □ Y ■ N □ NA							
2. TYPE OF SAMPLE OBTA	INED NA						
GRAB	COMPOSITE	SAMPLE METHO	D FREQUEN	NCY			
3. SAMPLES PRESERVED. □ Y □ N ■ NA							
4. FLOW PROPORTIONED	SAMPLES OBTAINED.				□ Y □	N NA	
5. SAMPLE OBTAINED FRO	OM FACILITY'S SAMP	LING DEVICE.			□у□	N NA	
6. SAMPLE REPRESENTATIVE OF VOLUME AND MATURE OF DISCHARGE. □ Y □ N ■ NA							
7. SAMPLE SPLIT WITH PE	7. SAMPLE SPLIT WITH PERMITTEE. □ Y □ N ■ NA						
8. CHAIN-OF-CUSTODY PROCEDURES EMPLOYED.							
9. SAMPLES COLLECTED I	9. SAMPLES COLLECTED IN ACCORDANCE WITH PERMIT. □ Y □ N ■ NA						

Attachment # 1 NPDES Permit No. AR0021806

Outfall 001

DMR Calculation Check

Reporting Period: from	2007	Jan.	01	to	2007	Jan.	<u>31</u>
	Year	Month	Day		Year	Month	Day

Parameter Checked: TSS

	<u>Quantity</u>					
	Monthly Mass Avg. (lbs/day)	Monthly Avg.(mg/l)	7-Day Avg.(mg/l)			
Reported Value:	2930	9.0	10.5			
Calculated Value:	1556	9.0	10.5			
Permit Value:	9010.00	30.00	45.00			

If calculated value does not equal reported value, explain:

VALUES EQUAL / OK

Attachment # 2 NPDES Permit No. AR0021806

Outfall 001

Flow Calculation Sheet

Field Data: Date <u>4-10-07</u> Time <u>1045</u> hrs.

Head 4.0 Inches

Type & Size of Flow Monitoring Device 36 ft. rectangular weir without end contractions

Name & Model of Flow Monitoring Device Inventron 9140 P

Recorded Flow at date & time listed above 11.84 MGD

Formula: 4.0"/12" = .334 Head feet

MGD $Q=2.152 LH^{1.5}$

Calculations: $Q = 2.152 \times 36 \times .334^{1.5}$

=2.152 x 36 x .237 =18.36 MGD

% error = $\underline{\text{Recorded value - calculated value}}$ (100) calculated value

$$=\frac{11.84-14.91}{14.95}$$
 (100) $=\frac{-3.07}{14.95}$ (100) $=$.2059 (100) $=$ 20.59 % error

The flow calibration check revealed an error of 20.59 %, which is outside the + or - 10 % error of actual flow requirement.



April 19, 2007

Reggie Corbitt, C.E.O. Little Rock Wastewater Utility 221 East Capitol Little Rock, AR 72202

Re: AFIN: 60-00409 NPDES Permit No. AR0021806 AR0040177

Dear Mr. Corbitt:

On April 10 and 17, 2007, I performed a routine compliance inspection of your facilities in accordance with the provisions of the federal Clean Water Act, the Arkansas Water and Air Pollution Control Act and the regulations promulgated thereunder. This inspection revealed the following violation:

The effluent flow meter at the Adams Field Plant's outfall 001 was found to be operating outside of the allowable 10 % error range.

Please submit a written response to this finding to the Enforcement Branch of this Department. This response should contain documentation describing the course of action taken to correct the item noted. This corrective action should be completed as soon as possible, and the written response is due by **May 10, 2007.**

If I can be of any assistance, please contact me at (501)-682-0658.

Sincerely,

Zachary Watson
District Field Inspector

Water Division

cc: Enforcement Branch Permits Branch