



Form Approved
OMB No. 2040-0003
Approval Expires 7-31-85

UNITED STATES ENVIRONMENTAL PROTECTION AGENCY
Washington, D.C. 20460
NPDES Compliance Inspection Report

Section A: National Data System Coding

Transaction Code	NPDES											yr/mo/day					Inspec. Type	Inspector	Fac Type								
1 N 2 5 3 A R 0 0 0 0 7 5 2 11 12 0 7 0 4 1 7 17 18 R 19 S 20 2																											
Remarks																											
U n i o n																											
Inspection Work Days	Facility Evaluation Rating											BI	QA	-----Reserved-----													
67 69	70 4											71 N	72 N	73	74 75	80											

Section B: Facility Data

Name and Location of Facility Inspected (For industrial users discharging to POTW, also include POTW name and NPDES permit number) El Dorado Chemical Company Northwest Ave EL Dorado, AR	Entry Time /Date 9:02/04/17/07	Permit Effective Date 01 July 2002
	Exit Time/Date 10:21/04/18/07	Permit Expiration Date 30 June 2007
Name(s) of On-Site Representative(s)/Title(s)/Phone and Fax Number(s) David Sartan/Environmental Technician /(870)-863-1484 Brent Parker/Environmental Technician	Other Facility Data	
Name, Address of Responsible Official/Title/Phone and Fax Number Greg Withrow, General Manager/870-863-1400 EDCC P.O. Box 231, El Dorado, AR 71731	Contacted Yes <input type="checkbox"/> No <input checked="" type="checkbox"/>	

Section C: Areas Evaluated During Inspection

(S = Satisfactory, M = Marginal, U = Unsatisfactory, N = Not Evaluated)

S	Permit	S	Flow Measurement	S	Operations & Maintenance	S	Sampling
S	Records/Reports	S	Self-Monitoring Program	N	Sludge Handling/Disposal	N	Pollution Prevention
S	Facility Site Review	N	Compliance Schedules	N	Pretreatment	N	Multimedia
S	Effluent/Receiving Waters	S	Laboratory	N	Storm Water	N	Other:

Section D: Summary of Findings/Comments (Attach additional sheets if necessary)

The facility is still working under the interim limits of the permit until June 2007. Samples of Outfall 001 revealed that the facility was meeting the interim permit limits on the day of sampling.

Name(s) and Signature(s) of Inspector(s) John Wesley Lamb 	Agency/Office/Telephone/Fax ADEQ/El Dorado/870862-5941/870-862-3509	Date June 20, 2007
Signature of Reviewer	Agency/Office/Phone and Fax Numbers	Date

- CERTIFICATE OF ANALYSIS – AR0000752

Attn:

Phone:

Ext:

Our Lab#: 2007-1250

FAX:

Your Sample ID: El Dorado Chem Outfall 001

Sample Type:

Report Date: 08-May-07

Anions				
	Bromide	2.58	mg/L	4/17/2007
	Chloride	26.7	mg/L	4/17/2007
	Fluoride	0.16	mg/L	4/17/2007
	Sulfate	38.8	mg/L	4/17/2007
FIELD				
	Dissolved oxygen	11.2	mg/L	4/18/2007
	Field pH	7.96	SU	4/18/2007
	Water temperature	16.7	°C	4/18/2007
ICP/MS-T				
	Aluminum	335	µg/L	4/24/2007
	Antimony	< 100	µg/L	4/24/2007
	Arsenic	< 25.0	µg/L	4/24/2007
	Barium	< 100	µg/L	4/24/2007
	Beryllium	< 5.00	µg/L	4/24/2007
	Boron	< 250	µg/L	4/24/2007
	Cadmium	< 10.0	µg/L	4/24/2007
	Calcium	13.9	mg/L	4/24/2007
	Chromium	< 10.0	µg/L	4/24/2007
	Cobalt	< 25.0	µg/L	4/24/2007
	Copper	< 25.0	µg/L	4/24/2007
	Iron	< 1000	µg/L	4/24/2007
	Lead	< 10.0	µg/L	4/24/2007
	Magnesium	4.22	mg/L	4/24/2007
	Manganese	60.1	µg/L	4/24/2007

- CERTIFICATE OF ANALYSIS - AR0000752

Attn:

Phone:

Ext:

Our Lab#: 2007-1250

FAX:

Your Sample ID: El Dorado Chem Outfall 001

Sample Type:

Report Date: 08-May-07

Nickel	<	25.0	µg/L	4/24/2007
Potassium		3.20	mg/L	4/24/2007
Selenium	<	50.0	µg/L	4/24/2007
Silicon Dioxide		6.38	mg/L	4/24/2007
Silver	<	50.0	µg/L	4/24/2007
Sodium		29.5	mg/L	4/24/2007
Thallium	<	25.0	µg/L	4/24/2007
Vanadium	<	25.0	µg/L	4/24/2007
Zinc	<	50.0	µg/L	4/24/2007
NH3-N-ISE				
Ammonia as nitrogen		9.53	mg/L	4/23/2007
TSS				
Total suspended solids		4.75	mg/L	4/17/2007
NH3/PO4/NO3				
Ammonia as nitrogen		9.57	mg/L	4/18/2007
Orthophosphate as phosphorus	<	0.005	mg/L	4/18/2007
Nitrite+Nitrate-N		12.0	mg/L	4/18/2007

Mr. Greg Withrow, General Manager
El Dorado Chemical Corporation
P.O. Box 231
El Dorado, AR 71731

ADEQ

ARKANSAS
Department of Environmental Quality

June 20, 2007

Mr. Greg Withrow, General Manager
El Dorado Chemical Corporation
P.O. Box 231
El Dorado, AR 71731


NPDES Permit No. AR0000752

Dear Mr. Withrow:

On April 17 and 18, 2007, I performed a reconnaissance sampling inspection of the EDCC Facility in accordance with the provisions of the federal Clean Water Act, the Arkansas Water and Air Pollution Control Act and the regulations promulgated thereunder. The inspection with sample results are attached.

If I can be of any assistance, please contact me at 870-862-0680.

Sincerely,



John W. Lamb
District Field Inspector
Water Division

cc: NPDES Enforcement Branch
NPDES Permits Branch

WATER DIVISION