

# ADEQ

ARKANSAS  
Department of Environmental Quality

December 3, 2007

Tom McAlister, Utility Manager  
Rogers Water Utilities  
P.O. Drawer 338  
Rogers, AR 72757-0338

RE: City of Rogers

AFIN: 04-00155


NPDES Permit No.: AR0043397

Dear Mr. McAlister:

On November 30, 2007, John Fazio, District Field Inspector, and I performed a routine compliance inspection of the waste water treatment facility in accordance with the provisions of the Federal Clean Water Act, the Arkansas Water and Air Pollution Control Act, and the regulations promulgated thereunder. This inspection revealed that you are in compliance with the terms of your permit.

If I can be of any assistance, please contact me at 479-267-0811 ext 12(west@adeq.state.ar.us).

Sincerely,



Alison West  
District 1 Field Inspector  
Water Division

cc: Water Division Enforcement Branch  
Water Division Permits Branch



UNITED STATES ENVIRONMENTAL PROTECTION AGENCY  
Washington, D.C. 20460

## NPDES Compliance Inspection Report

Form Approved  
OMB No. 2040-0003

### Section A: National Data System Coding

Transaction Code	NPDES	Yr/Mo/Day	Inspec. Type	Inspector	Fac. Type
1 <b>N</b> 2 <b>5</b> 3 <b>A R 0 0 4 3 3 9 7</b> 11 12 <b>0 7 1 1 3 0</b> 17 18 <b>C</b> 19 <b>S</b> 20 <b>1</b>					
Remarks					
Inspection Work Days		Facility Evaluation Rating		BI QA -----Reserved-----	
67		69	70 <b>4</b>	71 <b>N</b> 72 <b>N</b> 73	74 75 80

### Section B: Facility Data

Name and Location of Facility Inspected ( <i>For industrial users discharging to POTW, also include POTW name and NPDES permit number</i> ) <b>City of Rogers</b> <b>4300 S. Rainbow</b> <b>Rogers, AR</b>	Entry Time/Date <b>9:00 a.m./11-30-07</b>	Permit Effective Date <b>November 1, 2006</b>
	Exit Time/Date <b>2:45 p.m./11-30-07</b>	Permit Expiration Date <b>February 28, 2011</b>
Name(s) of On-Site Representative(s)/Title(s)/Phone and Fax Number(s) <b>Mike Lawrence/Plant Manager/479-273-7378/479-273-7627</b> <b>Robert Moore/O &amp; M Supervisor/479-273-7378/479-273-7627</b>	Other Facility Data <b>Effluent Parshall Flume GPS:</b>  <b>N36-17-59.8</b> <b>W094-12-51.9</b>	
Name, Address of Responsible Official/Title/Phone and Fax Number <b>Tom McAlister/Utility Manager/479-273-7378/479-273-7627</b> <b>City of Rogers</b> <b>P.O. Box 338</b> <b>Rogers, AR 72757</b>	Contacted Yes <input type="checkbox"/> No <input checked="" type="checkbox"/>	

### Section C: Areas Evaluated During Inspection

(S = Satisfactory, M = Marginal, U = Unsatisfactory, N = Not Evaluated)

S Permit	S Flow Measurement	S Operations & Maintenance	S Sampling
S Records/Reports	S Self-Monitoring Program	S Sludge Handling/Disposal	N Pollution Prevention
S Facility Site Review	S Compliance Schedules	N Pretreatment	N Multimedia
S Effluent/Receiving Waters	S Laboratory	N Storm Water	N Other:

### Section D: Summary of Findings/Comments (Attach additional sheets if necessary)

Discharge monitoring reports were reviewed for April, May, and June 2007. Related data was reviewed for May 2007. No excursions of permit limits were noted.

Name(s) and Signature(s) of Inspector(s)  Alison West	Agency/Office/Telephone/Fax <b>AR Dept. of Environmental Quality-Fayetteville</b> <b>479-267-0811 ext 12/479-267-0819</b>	Date <b>December 3, 2007</b>
John Fazio	<b>AR Dept. of Environmental Quality-Fayetteville</b> <b>479-267-0811 ext 16/479-267-0819</b>	
Signature of Reviewer	Agency/Office/Phone and Fax Numbers	Date

**SECTION A: PERMIT VERIFICATION**

PERMIT SATISFACTORILY ADDRESSES OBSERVATIONS

S M U NA NE

## DETAILS:

- |  |  |
|--|--|
| 1. CORRECT NAME AND MAILING ADDRESS OF PERMITTEE:                            | <input checked="" type="checkbox"/> Y <input type="checkbox"/> N <input type="checkbox"/> NA <input type="checkbox"/> NE |
| 2. NOTIFICATION GIVEN TO EPA/STATE OF NEW DIFFERENT OR INCREASED DISCHARGES: | <input type="checkbox"/> Y <input type="checkbox"/> N <input checked="" type="checkbox"/> NA <input type="checkbox"/> NE |
| 3. NUMBER AND LOCATION OF DISCHARGE POINTS AS DESCRIBED IN PERMIT:           | <input checked="" type="checkbox"/> Y <input type="checkbox"/> N <input type="checkbox"/> NA <input type="checkbox"/> NE |
| 4. ALL DISCHARGES ARE PERMITTED:   | <input checked="" type="checkbox"/> Y <input type="checkbox"/> N <input type="checkbox"/> NA <input type="checkbox"/> NE |

**SECTION B: RECORDKEEPING AND REPORTING EVALUATION**

RECORDS AND REPORTS MAINTAINED AS REQUIRED BY PERMIT

S M U NA NE

## DETAILS:

- |  |   |
|--|---|
| 1. ANALYTICAL RESULTS CONSISTENT WITH DATA REPORTED ON DMRS:                         | <input checked="" type="checkbox"/> Y <input type="checkbox"/> N <input type="checkbox"/> NA <input type="checkbox"/> NE                            |
| 2. SAMPLING AND ANALYSES DATA ADEQUATE AND INCLUDE:                                  | <input checked="" type="checkbox"/> S <input type="checkbox"/> M <input type="checkbox"/> U <input type="checkbox"/> NA <input type="checkbox"/> NE |
| a. DATES AND TIME(S) OF SAMPLING:  | <input checked="" type="checkbox"/> Y <input type="checkbox"/> N <input type="checkbox"/> NA <input type="checkbox"/> NE                            |
| b. EXACT LOCATION(S) OF SAMPLING:  | <input checked="" type="checkbox"/> Y <input type="checkbox"/> N <input type="checkbox"/> NA <input type="checkbox"/> NE                            |
| c. NAME OF INDIVIDUAL PERFORMING SAMPLING:   | <input checked="" type="checkbox"/> Y <input type="checkbox"/> N <input type="checkbox"/> NA <input type="checkbox"/> NE                            |
| d. ANALYTICAL METHODS AND TECHNIQUES:  | <input checked="" type="checkbox"/> Y <input type="checkbox"/> N <input type="checkbox"/> NA <input type="checkbox"/> NE                            |
| e. RESULTS OF CALIBRATIONS:  | <input checked="" type="checkbox"/> Y <input type="checkbox"/> N <input type="checkbox"/> NA <input type="checkbox"/> NE                            |
| f. RESULTS OF ANALYSES:  | <input checked="" type="checkbox"/> Y <input type="checkbox"/> N <input type="checkbox"/> NA <input type="checkbox"/> NE                            |
| g. DATES AND TIMES OF ANALYSES:  | <input checked="" type="checkbox"/> Y <input type="checkbox"/> N <input type="checkbox"/> NA <input type="checkbox"/> NE                            |
| h. NAME OF PERSON(S) PERFORMING ANALYSES:  | <input checked="" type="checkbox"/> Y <input type="checkbox"/> N <input type="checkbox"/> NA <input type="checkbox"/> NE                            |
| 3. LABORATORY EQUIPMENT CALIBRATION AND MAINTENANCE RECORDS ADEQUATE:                | <input checked="" type="checkbox"/> S <input type="checkbox"/> M <input type="checkbox"/> U <input type="checkbox"/> NA <input type="checkbox"/> NE |
| 4. PLANT RECORDS INCLUDE SCHEDULES, DATES OF EQUIPMENT MAINTENANCE AND REPAIR:       | <input checked="" type="checkbox"/> S <input type="checkbox"/> M <input type="checkbox"/> U <input type="checkbox"/> NA <input type="checkbox"/> NE |
| 5. EFFLUENT LOADINGS CALCULATED USING DAILY EFFLUENT FLOW AND DAILY ANALYTICAL DATA: | <input checked="" type="checkbox"/> Y <input type="checkbox"/> N <input type="checkbox"/> NA <input type="checkbox"/> NE                            |

**SECTION C: OPERATIONS AND MAINTENANCE**

TREATMENT FACILITY PROPERLY OPERATED AND MAINTAINED

S M U NA NE

## DETAILS:

- |  |   |
|--|---|
| 1. TREATMENT UNITS PROPERLY OPERATED:  | <input checked="" type="checkbox"/> S <input type="checkbox"/> M <input type="checkbox"/> U <input type="checkbox"/> NA <input type="checkbox"/> NE |
| 2. TREATMENT UNITS PROPERLY MAINTAINED:  | <input checked="" type="checkbox"/> S <input type="checkbox"/> M <input type="checkbox"/> U <input type="checkbox"/> NA <input type="checkbox"/> NE |
| 3. STANDBY POWER OR OTHER EQUIVALENT PROVIDED: <u>2 Generators, 3 EQ Basins</u>                    | <input checked="" type="checkbox"/> S <input type="checkbox"/> M <input type="checkbox"/> U <input type="checkbox"/> NA <input type="checkbox"/> NE |
| 4. ADEQUATE ALARM SYSTEM FOR POWER OR EQUIPMENT FAILURES AVAILABLE: <u>Wonderware/SCADA System</u> | <input checked="" type="checkbox"/> S <input type="checkbox"/> M <input type="checkbox"/> U <input type="checkbox"/> NA <input type="checkbox"/> NE |
| 5. ALL NEEDED TREATMENT UNITS IN SERVICE:  | <input checked="" type="checkbox"/> S <input type="checkbox"/> M <input type="checkbox"/> U <input type="checkbox"/> NA <input type="checkbox"/> NE |
| 6. ADEQUATE NUMBER OF QUALIFIED OPERATORS PROVIDED:  | <input checked="" type="checkbox"/> S <input type="checkbox"/> M <input type="checkbox"/> U <input type="checkbox"/> NA <input type="checkbox"/> NE |
| 7. SPARE PARTS AND SUPPLIES INVENTORY MAINTAINED:  | <input checked="" type="checkbox"/> S <input type="checkbox"/> M <input type="checkbox"/> U <input type="checkbox"/> NA <input type="checkbox"/> NE |
| 8. OPERATION AND MAINTENANCE MANUAL AVAILABLE:   | <input checked="" type="checkbox"/> Y <input type="checkbox"/> N <input type="checkbox"/> NA <input type="checkbox"/> NE                            |
| 9. STANDARD OPERATING PROCEDURES AND SCHEDULES ESTABLISHED:  | <input checked="" type="checkbox"/> Y <input type="checkbox"/> N <input type="checkbox"/> NA <input type="checkbox"/> NE                            |
| 10. PROCEDURES FOR EMERGENCY TREATMENT CONTROL ESTABLISHED:  | <input type="checkbox"/> Y <input type="checkbox"/> N <input checked="" type="checkbox"/> NA <input type="checkbox"/> NE                            |
| 11. HAVE BYPASSES/OVERFLOWS OCCURRED AT THE PLANT OR IN THE COLLECTION SYSTEM IN THE LAST YEAR:    | <input checked="" type="checkbox"/> Y <input type="checkbox"/> N <input type="checkbox"/> NA <input type="checkbox"/> NE                            |
| 12. IF SO, HAS THE REGULATORY AGENCY BEEN NOTIFIED:  | <input checked="" type="checkbox"/> Y <input type="checkbox"/> N <input type="checkbox"/> NA <input type="checkbox"/> NE                            |
| 13. HAS CORRECTIVE ACTION BEEN TAKEN TO PREVENT ADDITIONAL BYPASSES/OVERFLOWS:                     | <input checked="" type="checkbox"/> Y <input type="checkbox"/> N <input type="checkbox"/> NA <input type="checkbox"/> NE                            |
| 14. HAVE ANY HYDRAULIC OVERLOADS OCCURRED AT THE TREATMENT PLANT:                                  | <input checked="" type="checkbox"/> Y <input type="checkbox"/> N <input type="checkbox"/> NA <input type="checkbox"/> NE                            |
| 15. IF SO, DID PERMIT VIOLATIONS OCCUR AS A RESULT:  | <input checked="" type="checkbox"/> Y <input type="checkbox"/> N <input type="checkbox"/> NA <input type="checkbox"/> NE                            |

**SECTION D: SAMPLING**

PERMITTEE SAMPLING MEETS PERMIT REQUIREMENTS

S M U NA NE

## DETAILS:

- |   |  |
|---|--|
| 1. SAMPLES TAKEN AT SITE(S) SPECIFIED IN PERMIT:  | <input checked="" type="checkbox"/> Y <input type="checkbox"/> N <input type="checkbox"/> NA <input type="checkbox"/> NE |
| 2. LOCATIONS ADEQUATE FOR REPRESENTATIVE SAMPLES:                                       | <input checked="" type="checkbox"/> Y <input type="checkbox"/> N <input type="checkbox"/> NA <input type="checkbox"/> NE |
| 3. FLOW PROPORTIONED SAMPLES OBTAINED WHEN REQUIRED BY PERMIT:                          | <input checked="" type="checkbox"/> Y <input type="checkbox"/> N <input type="checkbox"/> NA <input type="checkbox"/> NE |
| 4. SAMPLING AND ANALYSES COMPLETED ON PARAMETERS SPECIFIED IN PERMIT:                   | <input checked="" type="checkbox"/> Y <input type="checkbox"/> N <input type="checkbox"/> NA <input type="checkbox"/> NE |
| 5. SAMPLING AND ANALYSES PERFORMED AT FREQUENCY SPECIFIED IN PERMIT:                    | <input checked="" type="checkbox"/> Y <input type="checkbox"/> N <input type="checkbox"/> NA <input type="checkbox"/> NE |
| 6. SAMPLE COLLECTION PROCEDURES ADEQUATE:   | <input checked="" type="checkbox"/> Y <input type="checkbox"/> N <input type="checkbox"/> NA <input type="checkbox"/> NE |
| a. SAMPLES REFRIGERATED DURING COMPOSITING:   | <input checked="" type="checkbox"/> Y <input type="checkbox"/> N <input type="checkbox"/> NA <input type="checkbox"/> NE |
| b. PROPER PRESERVATION TECHNIQUES USED:   | <input checked="" type="checkbox"/> Y <input type="checkbox"/> N <input type="checkbox"/> NA <input type="checkbox"/> NE |
| c. CONTAINERS AND SAMPLE HOLDING TIMES CONFORM TO 40 CFR 136:                           | <input checked="" type="checkbox"/> Y <input type="checkbox"/> N <input type="checkbox"/> NA <input type="checkbox"/> NE |
| 7. IF MONITORING IS PERFORMED MORE OFTEN THAN REQUIRED ARE RESULTS REPORTED ON THE DMR: | <input checked="" type="checkbox"/> Y <input type="checkbox"/> N <input type="checkbox"/> NA <input type="checkbox"/> NE |

**SECTION E: FLOW MEASUREMENT**

PERMITTEE FLOW MEASUREMENT MEETS PERMIT REQUIREMENTS

S M U NA NEDETAILS: **Outfall 001-2 Foot Parshall Flume; Outfall 002-No manual flow device.**

- |  |  |
|--|--|
| 1. PRIMARY FLOW MEASUREMENT DEVICE PROPERLY INSTALLED AND MAINTAINED: __ TYPE OF DEVICE: | <input checked="" type="checkbox"/> Y <input type="checkbox"/> N <input type="checkbox"/> NA <input type="checkbox"/> NE |
| 2. FLOW MEASURED AT EACH OUTFALL AS REQUIRED:  | <input checked="" type="checkbox"/> Y <input type="checkbox"/> N <input type="checkbox"/> NA <input type="checkbox"/> NE |
| 3. SECONDARY INSTRUMENTS (TOTALIZERS, RECORDERS, ETC.) PROPERLY OPERATED AND MAINTAINED: | <input checked="" type="checkbox"/> Y <input type="checkbox"/> N <input type="checkbox"/> NA <input type="checkbox"/> NE |
| 4. CALIBRATION FREQUENCY ADEQUATE:   | <input checked="" type="checkbox"/> Y <input type="checkbox"/> N <input type="checkbox"/> NA <input type="checkbox"/> NE |
| 5. RECORDS MAINTAINED OF CALIBRATION PROCEDURES:   | <input checked="" type="checkbox"/> Y <input type="checkbox"/> N <input type="checkbox"/> NA <input type="checkbox"/> NE |
| 6. CALIBRATION CHECKS DONE TO ASSURE CONTINUED COMPLIANCE:                               | <input checked="" type="checkbox"/> Y <input type="checkbox"/> N <input type="checkbox"/> NA <input type="checkbox"/> NE |
| 7. FLOW ENTERING DEVICE WELL DISTRIBUTED ACROSS THE CHANNEL AND FREE OF TURBULENCE:      | <input checked="" type="checkbox"/> Y <input type="checkbox"/> N <input type="checkbox"/> NA <input type="checkbox"/> NE |
| 8. FLOW MEASUREMENT EQUIPMENT ADEQUATE TO HANDLE EXPECTED RANGE OF FLOW RATES:           | <input checked="" type="checkbox"/> Y <input type="checkbox"/> N <input type="checkbox"/> NA <input type="checkbox"/> NE |
| 9. HEAD MEASURED AT PROPER LOCATION:   | <input checked="" type="checkbox"/> Y <input type="checkbox"/> N <input type="checkbox"/> NA <input type="checkbox"/> NE |

**SECTION F: LABORATORY**

PERMITTEE LABORATORY PROCEDURES MEET PERMIT REQUIREMENTS

S M U NA NE

## DETAILS:

- |   |  |
|---|--|
| 1. EPA APPROVED ANALYTICAL PROCEDURES USED (40 CFR 136.3 FOR LIQUIDS, 503.8(B) FOR SLUDGES) : | <input checked="" type="checkbox"/> Y <input type="checkbox"/> N <input type="checkbox"/> NA <input type="checkbox"/> NE |
| 2. IF ALTERNATIVE ANALYTICAL PROCEDURES ARE USED, PROPER APPROVAL HAS BEEN OBTAINED:          | <input checked="" type="checkbox"/> Y <input type="checkbox"/> N <input type="checkbox"/> NA <input type="checkbox"/> NE |
| 3. SATISFACTORY CALIBRATION AND MAINTENANCE OF INSTRUMENTS AND EQUIPMENT:                     | <input checked="" type="checkbox"/> Y <input type="checkbox"/> N <input type="checkbox"/> NA <input type="checkbox"/> NE |
| 4. QUALITY CONTROL PROCEDURES ADEQUATE:   | <input checked="" type="checkbox"/> Y <input type="checkbox"/> N <input type="checkbox"/> NA <input type="checkbox"/> NE |
| 5. DUPLICATE SAMPLES ARE ANALYZED $\geq$ 10% OF THE TIME:                                     | <input checked="" type="checkbox"/> Y <input type="checkbox"/> N <input type="checkbox"/> NA <input type="checkbox"/> NE |
| 6. SPIKED SAMPLES ARE ANALYZED $\geq$ 10% OF THE TIME:  | <input checked="" type="checkbox"/> Y <input type="checkbox"/> N <input type="checkbox"/> NA <input type="checkbox"/> NE |
| 7. COMMERCIAL LABORATORY USED:  | <input checked="" type="checkbox"/> Y <input type="checkbox"/> N <input type="checkbox"/> NA <input type="checkbox"/> NE |
| a. LAB NAME: <u>Arkansas Analytical</u>   |  |
| b. LAB ADDRESS: <u>11701 I30, Bldg 1, Ste. 115, Little Rock, AR 72209</u>                     |  |
| c. PARAMETERS PERFORMED: <u>Biomonitoring, Sludge metals</u>                                  |  |
| 8. BIOMONITORING PROCEDURES ADEQUATE:   | <input checked="" type="checkbox"/> Y <input type="checkbox"/> N <input type="checkbox"/> NA <input type="checkbox"/> NE |
| a. PROPER ORGANISMS USED:   | <input checked="" type="checkbox"/> Y <input type="checkbox"/> N <input type="checkbox"/> NA <input type="checkbox"/> NE |
| b. PROPER DILUTION SERIES FOLLOWED:   | <input checked="" type="checkbox"/> Y <input type="checkbox"/> N <input type="checkbox"/> NA <input type="checkbox"/> NE |
| c. PROPER TEST METHODS AND DURATION:  | <input checked="" type="checkbox"/> Y <input type="checkbox"/> N <input type="checkbox"/> NA <input type="checkbox"/> NE |
| d. RETESTS AND/OR TRE PERFORMED AS REQUIRED:  | <input checked="" type="checkbox"/> Y <input type="checkbox"/> N <input type="checkbox"/> NA <input type="checkbox"/> NE |

**SECTION G: EFFLUENT/RECEIVING WATERS OBSERVATIONS**

BASED ON VISUAL OBSERVATIONS ONLY S M U NA NE

DETAILS:

OUTFALL #:	OIL SHEEN	GREASE	TURBIDITY	VISIBLE FOAM	FLOATING SOLIDS	COLOR	OTHER
001	None	None	None	Trace	None	Clear	
002	No discharge at time of inspection						

**SECTION H: SLUDGE DISPOSAL**

SLUDGE DISPOSAL MEETS PERMIT REQUIREMENTS S M U NA NE

DETAILS: Sludge is transported to a landfill in Shawnee, Oklahoma.

- |   |   |
|---|---|
| 1. SLUDGE MANAGEMENT ADEQUATE TO MAINTAIN EFFLUENT QUALITY:   | <input checked="" type="checkbox"/> S <input type="checkbox"/> M <input type="checkbox"/> U <input type="checkbox"/> NA <input type="checkbox"/> NE |
| 2. SLUDGE RECORDS MAINTAINED AS REQUIRED BY 40 CFR 503:   | <input checked="" type="checkbox"/> S <input type="checkbox"/> M <input type="checkbox"/> U <input type="checkbox"/> NA <input type="checkbox"/> NE |
| 3. FOR LAND APPLIED SLUDGE, TYPE OF LAND APPLIED TO: (E.G., FOREST, AGRICULTURAL, PUBLIC CONTACT SITE): |   |

**SECTION I: SAMPLING INSPECTION PROCEDURES**

SAMPLE RESULTS WITHIN PERMIT REQUIREMENTS S M U NA NE

- DETAILS:
- |  |  |
|--|--|
| 1. SAMPLES OBTAINED THIS INSPECTION:   | <input type="checkbox"/> Y <input type="checkbox"/> N <input type="checkbox"/> NA <input checked="" type="checkbox"/> NE |
| 2. TYPE OF SAMPLE: <input type="checkbox"/> GRAB:___ <input type="checkbox"/> COMPOSITE:___ METHOD:___ FREQUENCY:___ |  |
| 3. SAMPLES PRESERVED:  | <input type="checkbox"/> Y <input type="checkbox"/> N <input type="checkbox"/> NA <input checked="" type="checkbox"/> NE |
| 4. FLOW PROPORTIONED SAMPLES OBTAINED:   | <input type="checkbox"/> Y <input type="checkbox"/> N <input type="checkbox"/> NA <input checked="" type="checkbox"/> NE |
| 5. SAMPLE OBTAINED FROM FACILITY'S SAMPLING DEVICE:  | <input type="checkbox"/> Y <input type="checkbox"/> N <input type="checkbox"/> NA <input checked="" type="checkbox"/> NE |
| 6. SAMPLE REPRESENTATIVE OF VOLUME AND NATURE OF DISCHARGE:  | <input type="checkbox"/> Y <input type="checkbox"/> N <input type="checkbox"/> NA <input checked="" type="checkbox"/> NE |
| 7. SAMPLE SPLIT WITH PERMITTEE:  | <input type="checkbox"/> Y <input type="checkbox"/> N <input type="checkbox"/> NA <input checked="" type="checkbox"/> NE |
| 8. CHAIN-OF-CUSTODY PROCEDURES EMPLOYED:   | <input type="checkbox"/> Y <input type="checkbox"/> N <input type="checkbox"/> NA <input checked="" type="checkbox"/> NE |
| 9. SAMPLES COLLECTED IN ACCORDANCE WITH PERMIT:  | <input type="checkbox"/> Y <input type="checkbox"/> N <input type="checkbox"/> NA <input checked="" type="checkbox"/> NE |

**SECTION J: STORM WATER POLLUTION PREVENTION PLAN**

STORM WATER MANAGEMENT MEETS PERMIT REQUIREMENTS S M U NA NE

DETAILS: Facility has a no exposure storm water permit.

- |  |  |
|--|--|
| 1. SWPPP UPDATED AS NEEDED:___ DATE OF LAST UPDATE:___   | <input type="checkbox"/> Y <input type="checkbox"/> N <input checked="" type="checkbox"/> NA <input type="checkbox"/> NE |
| 2. SITE MAP INCLUDING ALL DISCHARGES AND SURFACE WATERS: | <input type="checkbox"/> Y <input type="checkbox"/> N <input checked="" type="checkbox"/> NA <input type="checkbox"/> NE |
| 3. POLLUTION PREVENTION TEAM IDENTIFIED:                 | <input type="checkbox"/> Y <input type="checkbox"/> N <input checked="" type="checkbox"/> NA <input type="checkbox"/> NE |
| 4. POLLUTION PREVENTION TEAM PROPERLY TRAINED:           | <input type="checkbox"/> Y <input type="checkbox"/> N <input checked="" type="checkbox"/> NA <input type="checkbox"/> NE |
| 5. LIST OF POTENTIAL POLLUTANT SOURCES:                  | <input type="checkbox"/> Y <input type="checkbox"/> N <input checked="" type="checkbox"/> NA <input type="checkbox"/> NE |
| 6. LIST OF POTENTIAL SOURCES AND PAST SPILLS AND LEAKS:  | <input type="checkbox"/> Y <input type="checkbox"/> N <input checked="" type="checkbox"/> NA <input type="checkbox"/> NE |
| 7. ALL NON-STORM WATER DISCHARGES ARE AUTHORIZED:        | <input type="checkbox"/> Y <input type="checkbox"/> N <input checked="" type="checkbox"/> NA <input type="checkbox"/> NE |
| 8. LIST OF STRUCTURAL BMPS:                              | <input type="checkbox"/> Y <input type="checkbox"/> N <input checked="" type="checkbox"/> NA <input type="checkbox"/> NE |
| 9. LIST OF NON-STRUCTURAL BMPS:                          | <input type="checkbox"/> Y <input type="checkbox"/> N <input checked="" type="checkbox"/> NA <input type="checkbox"/> NE |
| 10. BMPS PROPERLY OPERATED AND MAINTAINED:               | <input type="checkbox"/> Y <input type="checkbox"/> N <input checked="" type="checkbox"/> NA <input type="checkbox"/> NE |
| 11. INSPECTIONS CONDUCTED AS REQUIRED:                   | <input type="checkbox"/> Y <input type="checkbox"/> N <input checked="" type="checkbox"/> NA <input type="checkbox"/> NE |

## FLOW CALCULATION SHEET

Date:	<b>11-30-07</b>	Time:	<b>9:45 a.m.</b>	
-------	-----------------	-------	------------------	--

Head in Inches:	<b>14"</b>	Feet:	<b>1.17</b>	
-----------------	------------	-------	-------------	--

Type & Size of Primary Flow Measurement Device: **2 Foot Parshall Flume**

Name & Model of Secondary Flow Measurement Device:	<b>Ultra Sonic Transducer</b>
--	-------------------------------

Date of last Calibration of Secondary Flow Device: **5-18-07**

Recorded Flow at Date & Time Listed Above:	<b>6.46</b>	(Facility Flow Meter)
--	-------------	-----------------------

Calculated Flow at Date & Time Listed Above:	<b>6.594</b>	
--	--------------	--

(Flow is calculated using flow charts in: ISCO Open Channel Flow Measurement Handbook-5<sup>th</sup> Edition)

% Error =	Recorded Value	-	Calculated Value	X 100	
	Calculated Value				

% Error =	6.46	-	6.594	X 100	
	6.594				

% Error =	-.0203		X 100		
-----------	--------	--	-------	--	--

% Error =			X 100		
-----------	--	--	-------	--	--

% Error =	<b>-2.03</b>	%			
-----------	--------------	---	--	--	--

Comments:	<b>OK</b>
-----------	-----------

**DMR Calculation Check**

**Reporting Period:** From 07 05 01 To 07 05 31  
 Year Month Day Year Month Day

**Parameter Checked:** TSS

**Loading  
Mass**

**Mo. Avg. - lbs/day**

**Concentration  
Monthly**

**Mo. Avg. - mg/l**

**7-day Avg. - mg/l**

**Reported Value:** 195.6

3.8

4.6

**Calculated Value:** 195.6

3.8

4.6

**Permit Value:** 838.2

15

23

**If calculated value does not equal reported value, explain:**