

January 11, 2008

Mr. Hugh W. Harrison, III General Manager Clarksville Light and Water Company P.O. Box 1807 Clarksville, AR 72830

Re: AFIN: 36-00038; NPDES Permit No. AR0022187

Dear Mr. Harrison:

On December 13, 2007, I performed a compliance evaluation inspection of your facility in accordance with the provisions of the federal Clean Water Act, the Arkansas Water and Air Pollution Control Act and the regulations promulgated there under. This inspection revealed that you are in compliance with the terms of your permit.

If I can be of any assistance, please contact me at 870-446-6170.

Sincerely,

Bruce Kirkpatrick

District Field Inspector

Water Division

cc: Water Division Enforcement Branch

Water Division Permits Branch

	ADEQ Water NPDES Ins	pec	tion	AFIN: 36-0003 8	3			Р	ermit :	#: AR0	0221	87
3	EPA .	UNITI	ED STATES ENVIRO	ONMENTAL PROTECTI	ION AGEN	ЛСY						Form Approved OMB No. 2040-0003
	NPDES Compliance Inspection Report											
	Section A: National Data System Coding											
Transaction Code NPDES 1 N 2 5 3 A R 0 0 2 2 1 1				1 1 1	1 12	0	7 1 1	Mo/Day 2 1	1	17	Insp 18	cec. Type Inspector Fac. Type C 19 S 20 1
	A F I N 3 6 Inspection Work Days 67 69		0 0 acility Evaluatio 70 5	0 3 8 nn Rating	Remari BI N	Q. 72	A N 73	<u> </u> 	74	75]	Reserved
					ı B: Fac	ility D	ata			,		
incl	ne and Location of Facility Inspected (ude POTW name and NPDES permit n ksville Light and Water Pollution Cor	ıumb	er)				Entry Time 0 722 / Dec		13, 200	7		Permit Effective Date January 1, 2004
	ated on South Crawford Highway one ownship 9 North, Range 23 West, in J				ections 7		Exit Time/ 1430 / Dec		13, 200	7		Permit Expiration Date December 31, 2008
	ne(s) of On-Site Representative(s)/Titl Gregg Rainey / Pollution Control Fac				929 / Fa	x: 479-	754-6885				Out	er Facility Data fall OO1 sample point located at atitude N 35-26-38.8
Mr. Clai P.O	ne, Address of Responsible Official/T Hugh W. Harrison, III, General Mana ksville Light and Water Co. Box 1807 ksville, AR 72830 / Phone 479-754	ger	I				Yes		ed o 🗹		Lo Out La	fall 002 sample point located at atitude N 35-26-44.3 ongitude W 93-28-24.8
				Section C: Areas I ctory, M = Margina					aluate	i)		
s s	Permit Records/Reports Facility Site Review	S S N	Flow Measurer Self-Monitorin Compliance So	ng Program	S S N	Operations & Maintenance S Sludge Handling/Disposal N Pretreatment N			Sampling Pollution Prevention Multimedia			
S	Effluent/Receiving Waters	S	Laboratory		S		n Water			-	N	Other:
A review of 2007 discharge monitoring reports revealed one numeric effluent limit violation. For the June 2007 reporting period, the facility reported 7-day average fecal coliform bacteria concentration of 547 colonies per 100 milliliter which exceeded the permit limit of 400. A non-compliance report was submitted to the Department. No further action is necessary. No other violations were reported. The facility reported a Lethal/Sublethal Effects Biomonitoring test failure in February 2007. Test failure was attributed to cold water pathogenic fungus. The ADEQ Water Division did not require a retest. The plant was found to be operated and maintained well.												
	Name(s) and Signature(s) of Inspector(s) Bruce Kirkpatrick Agency/Office/Telephone/Fax AR Dept. of Environmental Quality-Jasper PHONE# (870) 446-6170 / FAX# (870) 446-2181 December 17, 2007											

Agency/Office/Phone and Fax Numbers

Signature of Reviewer

Date

ADEQ Water NPDES Inspection	AFIN: 36-00038	Permit #: AR0022187

SECTION A: PERMIT VERIFICATION	
PERMIT SATISFACTORILY ADDRESSES OBSERVATIONS	☑S □M □U □NA □NE
DETAILS:	
CORRECT NAME AND MAILING ADDRESS OF PERMITTEE:	✓Y □N □NA □NE
NOTIFICATION GIVEN TO EPA/STATE OF NEW DIFFERENT OR INCREASED DISCHARGES:	
NUMBER AND LOCATION OF DISCHARGE POINTS AS DESCRIBED IN PERMIT:	✓ ✓ ✓ ✓ ✓ ✓ ✓ ✓ ✓ ✓ ✓ ✓ ✓ ✓ ✓ ✓ ✓ ✓ ✓
4. ALL DISCHARGES ARE PERMITTED:	ØY □N □NA □NE
4. ALL DIOCHAROLO ARE I ERWITTED.	
SECTION B: RECORDKEEPING AND REPORTING EVALUATION	
RECORDS AND REPORTS MAINTAINED AS REQUIRED BY PERMIT	☑S □M □U □NA □NE
DETAILS:	ES LIM LO LINA LINE
ANALYTICAL RESULTS CONSISTENT WITH DATA REPORTED ON DMRS:	✓Y □N □NA □NE
SAMPLING AND ANALYSES DATA ADEQUATE AND INCLUDE:	Øs □m □u □na □ne
	MY □N □NA □NE
a. DATES AND TIME(S) OF SAMPLING:	☑Y ☐N ☐NA ☐NE
b. EXACT LOCATION(S) OF SAMPLING:	
C. NAME OF INDIVIDUAL PERFORMING SAMPLING:	ØY □N □NA □NE
d. ANALYTICAL METHODS AND TECHNIQUES:	ØY □N □NA □NE
e. RESULTS OF CALIBRATIONS:	ØY □N □NA □NE
f. RESULTS OF ANALYSES:	ØY □N □NA □NE
g. DATES AND TIMES OF ANALYSES:	ØY □N □NA □NE
h. NAME OF PERSON(S) PERFORMING ANALYSES:	ØY □N □NA □NE
3. LABORATORY EQUIPMENT CALIBRATION AND MAINTENANCE RECORDS ADEQUATE:	Øs Om Ou Ona One
4. PLANT RECORDS INCLUDE SCHEDULES, DATES OF EQUIPMENT MAINTENANCE AND REPAIR:	Øs Om Ou Ona One
5. EFFLUENT LOADINGS CALCULATED USING DAILY EFFLUENT FLOW AND DAILY ANALYTICAL DATA:	⊠y □n □na □ne
SECTION C. OPERATIONS AND MAINTENANCE	
TREATMENT FACILITY PROPERLY OPERATED AND MAINTAINED	
DETAILS:	✓S □M □U □NA □NE
1. TREATMENT UNITS PROPERLY OPERATED:	Øs □m □u □na □ne
TREATMENT UNITS PROPERLY MAINTAINED:	ØS □M □U □NA □NE
	ØS □M □U □NA □NE
3. STANDBY POWER OR OTHER EQUIVALENT PROVIDED:	☑S ☐M ☐U ☐NA ☐NE
4. ADEQUATE ALARM SYSTEM FOR POWER OR EQUIPMENT FAILURES AVAILABLE:	
5. ALL NEEDED TREATMENT UNITS IN SERVICE:	MS OM OU ONA ONE
6. ADEQUATE NUMBER OF QUALIFIED OPERATORS PROVIDED:	MS OM OU ONA ONE
7. SPARE PARTS AND SUPPLIES INVENTORY MAINTAINED:	ØS □M □U □NA □NE
8. OPERATION AND MAINTENANCE MANUAL AVAILABLE:	ØY □N □NA □NE
9. STANDARD OPERATING PROCEDURES AND SCHEDULES ESTABLISHED:	ØY □N □NA □NE
10. PROCEDURES FOR EMERGENCY TREATMENT CONTROL ESTABLISHED:	✓ ✓ ✓ ✓ ✓ ✓ ✓ ✓ ✓ ✓ ✓ ✓ ✓ ✓ ✓ ✓ ✓ ✓ ✓
11. HAVE BYPASSES/OVERFLOWS OCCURRED AT THE PLANT OR IN THE COLLECTION SYSTEM IN THE LAST YEAR:	ØY □N □NA □NE
12. IF SO, HAS THE REGULATORY AGENCY BEEN NOTIFIED:	ØY □N □NA □NE
13. HAS CORRECTIVE ACTION BEEN TAKEN TO PREVENT ADDITIONAL BYPASSES/OVERFLOWS:	ØY □N □NA □NE
14. HAVE ANY HYDRAULIC OVERLOADS OCCURRED AT THE TREATMENT PLANT:	OY ON ONE ONE
15. IF SO, DID PERMIT VIOLATIONS OCCUR AS A RESULT:	□Y □N ☑NA □NE

ADEQ Water NPDES Inspection	AFIN: 36-00038	Permit #: AR0022187

SI	ECTION D: SAMPLING	
	ERMITTEE SAMPLING MEETS PERMIT REQUIREMENTS	☑S □M □U □NA □NE
	ETAILS:	
1.	SAMPLES TAKEN AT SITE(S) SPECIFIED IN PERMIT:	⊠y □n □na □ne
2.	LOCATIONS ADEQUATE FOR REPRESENTATIVE SAMPLES:	⊠y □n □na □ne
3.	FLOW PROPORTIONED SAMPLES OBTAINED WHEN REQUIRED BY PERMIT:	⊠y □n □na □ne
4.	SAMPLING AND ANALYSES COMPLETED ON PARAMETERS SPECIFIED IN PERMIT:	⊠y □n □na □ne
5.	SAMPLING AND ANALYSES PERFORMED AT FREQUENCY SPECIFIED IN PERMIT:	Øy □n □na □ne
6.	SAMPLE COLLECTION PROCEDURES ADEQUATE:	Øy □n □na □ne
a	a. SAMPLES REFRIGERATED DURING COMPOSITING:	⊠y □n □na □ne
t	D. PROPER PRESERVATION TECHNIQUES USED:	⊠y □n □na □ne
(c. CONTAINERS AND SAMPLE HOLDING TIMES CONFORM TO 40 CFR 136:	⊠y □n □na □ne
7.	IF MONITORING IS PERFORMED MORE OFTEN THAN REQUIRED ARE RESULTS REPORTED ON THE DMR:	□Y ØN □NA □NE
SI	ECTION E: FLOW MEASUREMENT	
	ERMITTEE FLOW MEASUREMENT MEETS PERMIT REQUIREMENTS	ØS OM OU ONA ONE
	ETAILS:	
1.	PRIMARY FLOW MEASUREMENT DEVICE PROPERLY INSTALLED AND MAINTAINED: TYPE OF DEVICE: ultrasonic meter	on 001
2.	FLOW MEASURED AT EACH OUTFALL AS REQUIRED:	✓Y □N □NA □NE
3.	SECONDARY INSTRUMENTS (TOTALIZERS, RECORDERS, ETC.) PROPERLY OPERATED AND MAINTAINED:	Øy □n □na □ne
4.	CALIBRATION FREQUENCY ADEQUATE:	☑Y □N □NA □NE
5.	RECORDS MAINTAINED OF CALIBRATION PROCEDURES:	Øy □n □na □ne
6.	CALIBRATION CHECKS DONE TO ASSURE CONTINUED COMPLIANCE:	☑Y □N □NA □NE
7.	FLOW ENTERING DEVICE WELL DISTRIBUTED ACROSS THE CHANNEL AND FREE OF TURBULENCE:	□Y □N □NA ☑NE
8.	FLOW MEASUREMENT EQUIPMENT ADEQUATE TO HANDLE EXPECTED RANGE OF FLOW RATES:	☑Y □N □NA □NE
9.	HEAD MEASURED AT PROPER LOCATION:	□Y □N ☑NA □NE
SI	ECTION F: LABORATORY	
	ERMITTEE LABORATORY PROCEDURES MEET PERMIT REQUIREMENTS	ØS OM OU ONA ONE
	TAILS:	
1.	EPA APPROVED ANALYTICAL PROCEDURES USED (40 CFR 136.3 FOR LIQUIDS, 503.8(B) FOR SLUDGES) :	⊠y □n □na □ne
2.	IF ALTERNATIVE ANALYTICAL PROCEDURES ARE USED, PROPER APPROVAL HAS BEEN OBTAINED:	Øy □n □na □ne
3.	SATISFACTORY CALIBRATION AND MAINTENANCE OF INSTRUMENTS AND EQUIPMENT:	✓Y □N □NA □NE
4.	QUALITY CONTROL PROCEDURES ADEQUATE:	⊠y □n □na □ne
5.	DUPLICATE SAMPLES ARE ANALYZED ≥10% OF THE TIME:	⊠y □n □na □ne
6.	SPIKED SAMPLES ARE ANALYZED >10% OF THE TIME:	⊠Y □N □NA □NE
7.	COMMERCIAL LABORATORY USED:	⊠y □n □na □ne
a	a. LAB NAME: Huther and Associates	
t	D. LAB ADDRESS: 1156 North Bonnie, Denton TX 76202	
(:. PARAMETERS PERFORMED: Biomonitoring	
8.	BIOMONITORING PROCEDURES ADEQUATE:	⊠y □n □na □ne
-	a. PROPER ORGANISMS USED:	✓Y □N □NA □NE
t	D. PROPER DILUTION SERIES FOLLOWED:	✓Y □N □NA □NE
	proper test methods and duration:	✓Y □N □NA □NE
	I. RETESTS AND/OR TRE PERFORMED AS REQUIRED:	□Y □N ☑NA □NE

ADEQ Water NPDES Inspection	AFIN: 36-00038	Permit #: AR0022187

SECTION	G: EFFLUEI	NT/RECEIVIN	IG WATERS	OBSERVATION	ONS			
	N VISUAL OBS			OBOLIVIA		⊠s □м □	U □NA □NE	
	DETAILS: No discharge at Outfall 002.							
OUTFALL #:	COLOR	OTHER						
001	none	none	none	none	FLOATING SOLIDS	clear		
					1		1	
SECTION	H: SLUDGE	DISPOSAL						
SLUDGE D	DISPOSAL ME	ETS PERMIT F	REQUIREMEN'	TS		⊠s □m □	U □NA □NE	
DETAILS:					•			
1. SLUDGE M	IANAGEMENT ADEQU	ATE TO MAINTAIN EF	FLUENT QUALITY:			⊠s □m	□U □NA □NE	
2. SLUDGE R	ECORDS MAINTAINED	O AS REQUIRED BY 40	O CFR 503:			⊠s □m	□U □NA □NE	
3. FOR LAND	APPLIED SLUDGE, TY	PE OF LAND APPLIE	D TO: agricultural (E.0	G., FOREST, AGRICUL	TURAL, PUBLIC CONTAC	CT SITE):		
SECTION	I: SAMPLIN	G INSPECTION	ON PROCEDI	URES				
	RESULTS WITH	HIN PERMIT R	EQUIREMENT	S			U ⊠NA □NE	
DETAILS:								
	SAMPLES OBTAINED THIS INSPECTION:							
	SAMPLE: GRAB:	COMPOSITE: N	METHOD: FREQUE	ENCY:				
	PORTIONED SAMPLE						□N ☑NA □NE	
	BTAINED FROM FACIL						□N ☑NA □NE	
	EPRESENTATIVE OF		E OF DISCHARGE:				□N ☑NA □NE	
	PLIT WITH PERMITTER						□N ☑NA □NE	
9. SAMPLES	COLLECTED IN ACCO	RDANCE WITH PERIVI	11:			<u>L1</u>		
SECTION	J: STORM V	NATED DOLL	LITION DDE	VENTION DI	۸NI			
	ATER MANAG					Де □м □	U DNA DNE	
	No exposure ce				,		O LINA LINE	
_	PDATED AS NEEDED:			<u>o. </u>		ПП	□n □na ☑ne	
	INCLUDING ALL DISCH						□N □NA ☑NE	
	N PREVENTION TEAM	IDENTIFIED:					□N □NA ☑NE	
5. LIST OF PO								
6. LIST OF PO	OTENTIAL SOURCES A	AND PAST SPILLS ANI	D LEAKS:				□N □NA ☑NE	
7. ALL NON-S	STORM WATER DISCH	ARGES ARE AUTHOR	RIZED:				□N □NA ☑NE	
8. LIST OF ST	B. LIST OF STRUCTURAL BMPS:							
9. LIST OF NO	ON-STRUCTURAL BMF	PS:				ΠY	□n □na ☑ne	
10. BMPS PRO	D. BMPS PROPERLY OPERATED AND MAINTAINED:							
11. INSPECTIO	ONS CONDUCTED AS I	REQUIRED:				□Υ	□n □na ☑ne	
İ								

	FLOW CALCULATION SHEET							
Date: 12/	13/07	Time: 130	3					
		1	'					
Head in Inc	Head in Inches: n/a Feet:							
T 9 C:	of Deimone, Ele	N. 1	ant Davisas	ا د اد د د د د ا		o O4 in ala min a		
Type & Size	e of Primary Flo	ow Measurem	ient Device.	ultrasonici	meter ii	1 24 inch pipe		
Name & Mo	del of Seconda	ary Flow Mea	surement De	vice: BIF	Model	0259-21		
Data of last	Calibration of	Cocondon, El	ov Dovice:	luna F. 20	07			
Date of last	Calibration of	Secondary Fi	ow Device	June 5, 20	07			
Recorded F	low at Date &	Time Listed A	bove: 0.7 r	ngd		(Facility Flow Meter)		
			<u>'</u>	U	ļ.	,, <u>,</u>		
	Flow at Date &				th _			
(Flow is calculat	ed using flow charts	in: ISCO Open Ch	annel Flow Meas	urement Handl	<u>000k-5[™] E</u>	<u>dition</u>)		
0/	Recorded Va	lue - Calc	ulated Value	V 400				
% Error =	Ca	alculated Valu	X 100					
		<u> </u>			1			
% Error =		-		X 100				
0/		V 400						
% Error =		X 100						
% Error =		X 100						
% Error =	n/a	%						
Comments:		and location	n of flow me	ter, no flo	w calib	ration check was		
	performed.							

DMR Calculation Check

Reporting Period: From 07 02 01 To 07 02 28

Year Month Day Year Month Day

Parameter Checked: CBOD5

	Loading Mass	Concentration Monthly			
	Mo. Avg lbs/day	Mo. Avg mg/l	7-day Avg mg/l		
Reported Value:	33.16	3.54	5.23		
Calculated Value:	33.2	3.54	5.23		
Permit Value:	167	10	15		

If calculated value does not equal reported value, explain: <u>Values equal</u>