

October 14, 2008

Mary Timmons, Water Utilities Manager City of Mena 701 Mena St. Mena, AR 71953

RE: NPDES Compliance sampling / SSO inspection

AFIN: 57-00042

NPDES Permit No.: AR0036692

Dear Ms. Timmons:

On September 23 and 24, 2008, I performed a compliance sampling inspection of the waste water treatment facility and a sanitary sewer overflow inspection in accordance with the provisions of the Federal Clean Water Act, the Arkansas Water and Air Pollution Control Act, and the regulations promulgated thereunder. This inspection revealed the following violation:

1. A transcribing error resulted in a miscalculation or TSS mass loadings for the month of July, 2008. The July 29<sup>th</sup> lbs/day figure should be 8.9. The lab sheets show 89.

The above item requires your immediate attention. Please submit a written response to this finding to the Water Division Enforcement Section of this Department at the following address:

Water Division Enforcement Section Arkansas Department of Environmental Quality 5301 Northshore Drive North Little Rock, AR 72118-5317

This response should contain detailed documentation describing the course of action taken to correct the item noted. This corrective action should be completed as soon as possible, and the written response is due by November 4, 2008.

For additional information you may contact the enforcement section by telephone at 501-682-0639 or by fax at 501-682-0910.

City of Mena October 14, 2008 Page 2

If I can be of any assistance, please contact me at (870) 389-6970.

Sincerely,

Shan Synch

Shan Lynch District 12 Field Inspector Water Division

cc: Water Division Enforcement Branch Water Division Permits Branch

⇔EPA							Form Approved OMB No. 2040-0003			
UNITED STATES ENVIRONMENTAL PROTECTION AGENCY										
Washington, D.C. 20460 NPDES Compliance Inspection Report										
	Section A: National Data System Coding									
1	Transaction Code     NPDES     Yr/Mo/Day     Insp       1     N     2     5     3     A     R     0     0     3     6     6     9     2     11     12     0     8     0     9     2     3     17     18						pec. TypeInspectorFac. TypeC19S201			
					Remark					
	Inspection Work Days     67     69	1	Facility Evaluation R 70 4	rating 71	BI N	72	N         73         74         75		Reserved 80	
				Section 1	B: Faci	ility 1	Data		1	
	ne and Location of Facility Inspected ude POTW name and NPDES permi			charging to POTW	V, also		Entry Time/Date		Permit Effective Date	
	of Mena WWTP						0747 / 9-23-2008		July 1, 2006	
•	Polk County Rd. 53, north off of I	Hwy 8	8, east of Mena				Exit Time/Date		Permit Expiration Date	
							0822 / 9-24-2008	1	June 30, 2011	
	Name(s) of On-Site Representative(s)/Title(s)/Phone and Fax Number(s)       Other Facility Data         Jeff Flannigan / Wastewater Plant Operator / (479) 394-1239       Other Facility Data									
Nan	ne, Address of Responsible Official/	Title/l	Phone and Fax Num	ber				1	Major mun.	
701	Mary Timmons / Mena Water Utilities Manager / (479) 394-1132 701 Mena St. Mena, AR 71953					Contacted Yes No		CSI		
Section C: Areas Evaluated During Inspection										
a		G			г		sfactory, $N = Not Evaluated$ )	a		
S	Permit	S	Flow Measureme		S	•	erations & Maintenance	S		
M S	Records/Reports	S N	Self-Monitoring I	0	N N		dge Handling/Disposal	N N	T onution Trevention	
s	Facility Site Review Effluent/Receiving Waters	S	Compliance Sche Laboratory	edules	N		treatment rm Water	N	Multimedia Other: CSI	
	Enden/Acceiving Waters	Se	-	of Findings/Com	ments		ach additional sheets if necessary	y)		
Sec. B,1 – A transcribing error resulted in a miscalculation or TSS mass loadings for the month of July, 2008. The July 29 <sup>th</sup> lbs/day figure should be 8.9. The lab sheets show 89. * The lab results should be more consistent, by rounding all numbers and reporting all numbers to the nearest tenth or hundredth, where applicable.										
Nar	ne(s) and Signature(s) of Inspector(s			Agency/Office/Telephone					Date	
Sha	n Lynch Shan Synch			AR Dept. of E	nviron	ment	tal Quality / Dist. 12 / (870) 389-6	<b>5970</b>	October 10, 2008	
				ļ						
Signature of Reviewer				Agency/Office/Phone and Fax Numbers				Date		

ADEQ Water NPDES Inspection
-----------------------------

Г

AFIN: 57-00042

Permit #: AR0036692

SECTION A: PERMIT VERIFICATION	
PERMIT SATISFACTORILY ADDRESSES OBSERVATIONS	Øs 🗆 m 🗇 🛛 🗠 🗠 ne
DETAILS:	
1. CORRECT NAME AND MAILING ADDRESS OF PERMITTEE:	🗹 Y 🗆 N 🗆 NA 🗆 NE
2. NOTIFICATION GIVEN TO EPA/STATE OF NEW DIFFERENT OR INCREASED DISCHARGES:	DY DN ØNA DNE
3. NUMBER AND LOCATION OF DISCHARGE POINTS AS DESCRIBED IN PERMIT:	
4. ALL DISCHARGES ARE PERMITTED:	
SECTION B: RECORDKEEPING AND REPORTING EVALUATION	
RECORDS AND REPORTS MAINTAINED AS REQUIRED BY PERMIT	
DETAILS:	
1. ANALYTICAL RESULTS CONSISTENT WITH DATA REPORTED ON DMRS:	DY 🗹 N DNA DNE
2. SAMPLING AND ANALYSES DATA ADEQUATE AND INCLUDE:	🗹 s 🗆 m 🗇 u 🖾 na 🖾 ne
a. DATES AND TIME(S) OF SAMPLING:	
b. EXACT LOCATION(S) OF SAMPLING:	
c. NAME OF INDIVIDUAL PERFORMING SAMPLING:	
d. ANALYTICAL METHODS AND TECHNIQUES:	
e. RESULTS OF CALIBRATIONS:	
f. RESULTS OF ANALYSES:	
g. DATES AND TIMES OF ANALYSES:	
h. NAME OF PERSON(S) PERFORMING ANALYSES:	
3. LABORATORY EQUIPMENT CALIBRATION AND MAINTENANCE RECORDS ADEQUATE:	🗹 s 🗆 m 🗇 u 🖾 na 🖾 ne
4. PLANT RECORDS INCLUDE SCHEDULES, DATES OF EQUIPMENT MAINTENANCE AND REPAIR:	Øs 🗆m 🗇u 🖾na 🖾ne
5. EFFLUENT LOADINGS CALCULATED USING DAILY EFFLUENT FLOW AND DAILY ANALYTICAL DATA:	
SECTION C: OPERATIONS AND MAINTENANCE	
TREATMENT FACILITY PROPERLY OPERATED AND MAINTAINED	
DETAILS:	
1. TREATMENT UNITS PROPERLY OPERATED:	Øs 🗆m 🗇u 🖾na 🖾ne
2. TREATMENT UNITS PROPERLY MAINTAINED:	Øs 🗆m 🗇u 🖾na 🖾ne
3. STANDBY POWER OR OTHER EQUIVALENT PROVIDED:	
4. ADEQUATE ALARM SYSTEM FOR POWER OR EQUIPMENT FAILURES AVAILABLE:	
5. ALL NEEDED TREATMENT UNITS IN SERVICE:	Øs 🗆m 🗇u 🖾na 🖾ne
6. ADEQUATE NUMBER OF QUALIFIED OPERATORS PROVIDED:	Øs 🗆m 🗇u 🖾na 🖾ne
7. SPARE PARTS AND SUPPLIES INVENTORY MAINTAINED:	OS OM OU ONA ØNE
8. OPERATION AND MAINTENANCE MANUAL AVAILABLE:	
9. STANDARD OPERATING PROCEDURES AND SCHEDULES ESTABLISHED:	
10. PROCEDURES FOR EMERGENCY TREATMENT CONTROL ESTABLISHED:	
11. HAVE BYPASSES/OVERFLOWS OCCURRED AT THE PLANT OR IN THE COLLECTION SYSTEM IN THE LAST YEAR:	
12. IF SO, HAS THE REGULATORY AGENCY BEEN NOTIFIED:	
13. HAS CORRECTIVE ACTION BEEN TAKEN TO PREVENT ADDITIONAL BYPASSES/OVERFLOWS:	
14. HAVE ANY HYDRAULIC OVERLOADS OCCURRED AT THE TREATMENT PLANT:	
15. IF SO, DID PERMIT VIOLATIONS OCCUR AS A RESULT:	

Permit #: AR0036692

SECTION D: SAMPLING							
PERMITTEE SAMPLING MEETS PERMIT REQUIREMENTS	ØS □M □U □NA □NE						
DETAILS:							
1. SAMPLES TAKEN AT SITE(S) SPECIFIED IN PERMIT:							
2. LOCATIONS ADEQUATE FOR REPRESENTATIVE SAMPLES:							
3. FLOW PROPORTIONED SAMPLES OBTAINED WHEN REQUIRED BY PERMIT:							
4. SAMPLING AND ANALYSES COMPLETED ON PARAMETERS SPECIFIED IN PERMIT:							
5. SAMPLING AND ANALYSES PERFORMED AT FREQUENCY SPECIFIED IN PERMIT:	⊠y ⊡n ⊡na ⊡ne						
6. SAMPLE COLLECTION PROCEDURES ADEQUATE:							
a. SAMPLES REFRIGERATED DURING COMPOSITING:							
b. PROPER PRESERVATION TECHNIQUES USED:							
c. CONTAINERS AND SAMPLE HOLDING TIMES CONFORM TO 40 CFR 136:							
7. IF MONITORING IS PERFORMED MORE OFTEN THAN REQUIRED ARE RESULTS REPORTED ON THE DMR:							
SECTION E: FLOW MEASUREMENT							
PERMITTEE FLOW MEASUREMENT MEETS PERMIT REQUIREMENTS	ØS OM OU ONA ONE						
DETAILS:							
1. PRIMARY FLOW MEASUREMENT DEVICE PROPERLY INSTALLED AND MAINTAINED: TYPE OF DEVICE: weir							
2. FLOW MEASURED AT EACH OUTFALL AS REQUIRED:							
3. SECONDARY INSTRUMENTS (TOTALIZERS, RECORDERS, ETC.) PROPERLY OPERATED AND MAINTAINED:							
4. CALIBRATION FREQUENCY ADEQUATE: <u>4-25-2008</u>							
5. RECORDS MAINTAINED OF CALIBRATION PROCEDURES:							
6. CALIBRATION CHECKS DONE TO ASSURE CONTINUED COMPLIANCE:							
7. FLOW ENTERING DEVICE WELL DISTRIBUTED ACROSS THE CHANNEL AND FREE OF TURBULENCE:							
8. FLOW MEASUREMENT EQUIPMENT ADEQUATE TO HANDLE EXPECTED RANGE OF FLOW RATES:							
9. HEAD MEASURED AT PROPER LOCATION:	Øy 🛛n 🖾na 🖾ne						
SECTION F: LABORATORY							
PERMITTEE LABORATORY PROCEDURES MEET PERMIT REQUIREMENTS	Øs 🗆 m 🗇 u 🖾 na 🗇 ne						
1. EPA APPROVED ANALYTICAL PROCEDURES USED (40 CFR 136.3 FOR LIQUIDS, 503.8(B) FOR SLUDGES) :							
2. IF ALTERNATIVE ANALYTICAL PROCEDURES ARE USED, PROPER APPROVAL HAS BEEN OBTAINED:							
3. SATISFACTORY CALIBRATION AND MAINTENANCE OF INSTRUMENTS AND EQUIPMENT:							
4. QUALITY CONTROL PROCEDURES ADEQUATE:							
5. DUPLICATE SAMPLES ARE ANALYZED ≥10% OF THE TIME:							
6. SPIKED SAMPLES ARE ANALYZED ≥10% OF THE TIME:							
7. COMMERCIAL LABORATORY USED:	Øy 🛛 n 🗆 na 🖾 ne						
a. LAB NAME:     Data Testing     American Interplex       b. LAB ADDRESS:     3434 Country Club; Ft. Smith, AR, 72903     8600 Kanis Rd.; Little Rock, AR 72204							
b. LAB ADDRESS: <u>3434 Country Club; Ft. Smith, AR, 72903</u> <u>8600 Kanis Rd.; Little Rock, AR 72204</u> c. PARAMETERS PERFORMED: CBOD, NH3-N biomonitoring							
8. BIOMONITORING PROCEDURES ADEQUATE:							
a. PROPER ORGANISMS USED:							
b. PROPER DILUTION SERIES FOLLOWED:							
c. PROPER TEST METHODS AND DURATION:							
d. RETESTS AND/OR TRE PERFORMED AS REQUIRED:							

ADEQ Water NPDES Inspection
ADED Water NPDES Inspection

Permit #: AR0036692

SECTION G: EFFLUENT/RECEIVING WATERS OBSERVATIONS										
BASED ON VISUAL OBSERVATIONS ONLY										
DETAILS:										
OUTFALL #:	OIL SHEEN	GREASE	TURBIDITY	VISIBLE FOAM	FLOATING SOLIDS	COLOR	OTHER			
001	none	none	none	slight	none	clear	NA			
				•						
SECTION H: SLUDGE DISPOSAL										
SLUDGE DISPOSAL MEETS PERMIT REQUIREMENTS										
DETAILS:										
1. SLUDGE M	ANAGEMENT ADEQU	ATE TO MAINTAIN EF	FLUENT QUALITY:			□s	🗆 m 🗇 v 🗹 na 🗆 ne			
2. SLUDGE R	ECORDS MAINTAINED	D AS REQUIRED BY 40	) CFR 503:			□s	🗆 m 🗇 v 🗹 na 🗆 ne			
3. FOR LAND	APPLIED SLUDGE, TY	YPE OF LAND APPLIEI	D TO: (E.G., FOREST,	AGRICULTURAL, PUE	BLIC CONTACT SITE):	NA				
SECTION	I: SAMPLIN	<b>G INSPECTIO</b>	ON PROCEDI	JRES						
SAMPLE R	<b>RESULTS WITH</b>	HIN PERMIT R	EQUIREMENT	S		⊠s ⊡m				
DETAILS:					L. L					
1. SAMPLES	OBTAINED THIS INSPI	ECTION:					🗹 y 🗆 n 🗆 na 🗆 ne			
2. TYPE OF S	AMPLE: 🗹 GRAB:		IETHOD: FREQUE	NCY:						
3. SAMPLES	PRESERVED:						🗹 y 🗆 n 🗆 na 🗆 ne			
4. FLOW PRC	PORTIONED SAMPLE	S OBTAINED:					🗹 y 🗆 n 🗆 na 🗆 ne			
5. SAMPLE O	5. SAMPLE OBTAINED FROM FACILITY'S SAMPLING DEVICE:									
6. SAMPLE R	EPRESENTATIVE OF	VOLUME AND NATUR	E OF DISCHARGE:				🗹 y 🗆 n 🗆 na 🗆 ne			
7. SAMPLE SI	PLIT WITH PERMITTEI	E:					🗹 y 🗆 n 🗆 na 🗆 ne			
8. CHAIN-OF-	CUSTODY PROCEDU	RES EMPLOYED:					🗹 y 🗆 n 🗆 na 🗆 ne			
9. SAMPLES	9. SAMPLES COLLECTED IN ACCORDANCE WITH PERMIT:									
SECTION	J: STORM W	<b>WATER POLL</b>	UTION PREV	<b>VENTION PL</b>	AN					
STORM W	ATER MANAG	EMENT MEET	S PERMIT RE	QUIREMENTS	5	□s □m	□u Øna □ne			
DETAILS:										
1. SWPPP UP	DATED AS NEEDED:	DATE OF LAST UP	DATE:				🛛 Y 🖾 N 🖾 NA 🗆 NE			
2. SITE MAP I	NCLUDING ALL DISCH	HARGES AND SURFAC	CE WATERS:				□y □n Øna □ne			
3. POLLUTIO	N PREVENTION TEAM	I IDENTIFIED:					□y □n Øna □ne			
4. POLLUTIO	. POLLUTION PREVENTION TEAM PROPERLY TRAINED:									
5. LIST OF PC	5. LIST OF POTENTIAL POLLUTANT SOURCES:									
6. LIST OF PC	DTENTIAL SOURCES A	AND PAST SPILLS AND	D LEAKS:				Dy On Øna One			
7. ALL NON-S	TORM WATER DISCH	IARGES ARE AUTHOR	IZED:				□y □n Øna □ne			
8. LIST OF ST	RUCTURAL BMPS:						□y □n Øna □ne			
9. LIST OF NO	ON-STRUCTURAL BMF	PS:					□y □n Øna □ne			
10. BMPS PRO	PERLY OPERATED A	ND MAINTAINED:					🛛 Y 🖾 N 🖾 NA 🖾 NE			
11. INSPECTIC	ONS CONDUCTED AS	REQUIRED:					🛛 Y 🗖 N 🖉 NA 🗍 NE			

ADEQ Water NPDES	ADEQ Water NPDES Inspection AFIN: 57				Pe	ermit #: AR003	6692		
	tion Che	ck							
<b>Reporting Period:</b>	From	08	07	01	То	08	07	31	
		Year	Month	Day		Year	Month	Day	
Parameter Checked: <u>TSS</u> Loading			_			Concer	ntration		
Mass					Monthly				
	Mo. A	Avg lbs/	/day	Mo. A	vg	mg/l	7-day Avg	g mg/l	
<b>Reported Value:</b>	ie: <u>27.7</u>			4.66			7		
Calculated Value:	21.66			4.66		7			
Permit Value: 388				15		22.	5		

If calculated value does not equal reported value, explain:

<u>A transcription error for the loading on July 29 caused a miscalculation for July 2008. The</u> <u>result should read 8.9 instead of the 89 shown.</u>

Permit #: AR0036692

FLOW CALCULATION SHEET									
Date: 9-2	3-2008	Time:	0832						
			1						
Head in Inc	Head in Inches:   13   Feet:   1.08								
<b>T</b> 0.0:					<u> </u>				
Type & Size	e of Primary	Flow Measu	irement De	evice: 90	J degree	V-notch weir			
Name & Mo	odel of Seco	ndary Flow N	Jeasureme	ent Dev	ice <sup>.</sup> Mill	tronics HydroRange	r		
			nououronn			a chied rigarentarige	•		
Date of last	Calibration	of Secondar	y Flow Dev	vice: 4	-25-2008				
Recorded F	Flow at Date	& Time Liste	ed Above:	1335	gpm	(Facility Flow Mete	er)		
		e & Time List			) gpm				
(Flow is calcula	ted using flow ch	arts in: ISCO Ope	en Channel Flo	w Measure	ement Handl	<u>book-5<sup>m</sup> Edition</u> )			
	Descular			\/_l	I				
% Error =	Recorded		Calculated	X 100					
		Calculated	value						
	4000		4000						
% Error =	1335		1360		X 100				
		1360							
	-25								
% Error =		X 10	00						
1360									
% Error =	-0.01	8 X 10							
	-0.01								
% Error =	-1.8	%							
Comments	:								

## **Compliance Sampling Inspection Results**

	lbs / day	other units	s specified
Parameter	Monthly average	Monthly average	Daily max
CBOD	14.37	0.87 mg/l	0.87 mg/l
TSS	90.82	5.5 mg/l	5.5 mg/l
NH3-N	1.65	0.10 mg/l	0.10 mg/l
Fecal coliform	NA	< 3 col/100 ml	< 3 col/100 ml

TRC	0.01 mg/l
DO	8.03 mg/l
pН	6.01
Flow	1.98 mgd