

June 1, 2009

Mr. James Boston, Public Works Director City of Decatur P.O. Box 247 Decatur, Arkansas 72722

RE: Sanitary Sewer Overflow Reporting

AFIN: 04-00052 NPDES Permit No.: AR0022292

Dear Mr. Boston:

On May 8, 2009, I performed a reconnaissance inspection of the wastewater treatment facility collection system in accordance with the provisions of the Federal Clean Water Act, the Arkansas Water and Air Pollution Control Act, and the regulations promulgated thereunder. Two sanitary sewer overflows were observed. An overflow was observed at a manhole adjacent to 2<sup>nd</sup> St. (south of W. Roller Ave.), and another was observed at a manhole on a resident's property northwest of the intersection of Spring St. and Hall St. At each location, it was evident that the sewage from the collection system had discharged into the stream adjacent to the manholes. This inspection revealed the following violation:

Discharge of raw sewage from your collection system causing pollution to the waters of the State. This is in violation of the Arkansas Water and Air Pollution Control Act, Ark. Code Ann. §8-4-217(a)(1). Sewage from the manholes referenced above had entered Colombia Hollow Creek, a tributary to Spavinaw Creek.

Although you reported a sanitary sewer overflow of approximately 200 gallons to the Department on May 8, 2009, you did not specify the location of the overflow, nor did you report that the overflow had entered Columbia Hollow Creek (see attached photos). It is necessary that you provide this information to the Department in accordance with the reporting requirements of your permit.

According to Mr. James Beemer, a resident we spoke with while at the Spring St. overflow location, overflows occur at this manhole each time there is significant rainfall. Mr. Beemer stated that an overflow occurred at this location within two weeks prior to our visit. Mr. Beemer stated that he has reported many overflows from this manhole to the City of Decatur; however, Departmental records indicate that overflows from this manhole were reported to the Department on March 19, 2008, and June 9, 2008 only. You reported the June 9, 2008 overflow to the Department after we informed you that it was occurring.

James Boston, City of Decatur June 1, 2009 Page 2

The above items require your immediate attention. Please submit a written response to these findings to Cindy Garner, Water Division Enforcement Branch Manager. This response should be mailed to the address below. This response should contain documentation describing the course of action taken to correct each item noted. This corrective action should be completed as soon as possible, and the written response is due by June 11, 2009.

For additional information you may contact the Enforcement Branch by telephone at 501-682-0639 or by fax at 501-682-0910. If I can be of any assistance, please contact me at 479-267-0811, ext. 16.

Sincerely,

John Fazio


District 1 Field Inspector

Water Division

cc: Water Division Enforcement Branch

Water Division Permits Branch

	ADEQ Water NPDES I	nsped	tion AFIN	: 04-00052		Permit #:	AR0022	292	
								Form Approved	
<b>⊕</b>	E <b>P</b> A							OMB No. 2040-0003	
		UNIT	ED STATES ENVIRONMENT	'AL PROTECTION	N AGENCY				
	NDDE		Washington, D.	C. 20460		Danaut			
	NPDE	<u> </u>	Compliance			<del>-</del>			
				tion A: Natior	ial Data S	System Coding			
1	Transaction Code  N 2 5 3 A R	0	NPDES 0 2 2 2 9	2 11	12 <b>0</b>	Yr/Mo/Day  9 0 5 0 8	17 18	pec. Type Inspector Fac. Type  R 19 S 20 1	
				F	Remarks				
-	Inspection Work Days	J	Facility Evaluation Ratir	ng l	BI	QA		Reserved	
67 69 70 N 71 N 72 N 73							75	80	
				Section I	•	1			
inclı	ne and Location of Facility Inspected and POTW name and NPDES permit of Decatur POTW			ging to POTW	/, also	Entry Time/Date 1340 / 05-08-09		Permit Effective Date 06-01-09	
	Austin St. atur Arkansas					Exit Time/Date 1440 / 05-08-09		Permit Expiration Date 05-31-14	
	ne(s) of On-Site Representative(s)/T nes Boston, Public Works Director					her Facility Data 20' 37", -94 28' 24"			
	ne, Address of Responsible Official/ nes Boston, Public Works Director		Phone and Fax Number					20 37 ,-94 20 24	
City	of Decatur Box 247					Contacted			
Dec	atur, Arkansas 72722					Yes No V			
479-752-3912, 479-752-8336  Section C: Areas Evaluated During Inspection (S = Satisfactory, M = Marginal, U = Unsatisfactory, N = Not Evaluated)									
S	Permit	N	Flow Measurement		N O	perations & Maintenance	N	Sampling	
N	Records/Reports	Records/Reports N Self-Monitorin		gram	_	udge Handling/Disposal	U	<b>Pollution Prevention</b>	
N	<b>Facility Site Review</b>	N	Compliance Schedule	es		retreatment	N	Multimedia	
N	Effluent/Receiving Waters	t/Receiving Waters N Laboratory N Section D: Summary of Findings/Comments (A			torm Water	U	Other: SSO		
		36	cuon D. Summary of F	munigs/Com	ments (A	ttach additional sheets if fiece	ssaiy)		
The following violation was noted:									
1. Discharge of untreated sewage from your collection system causing pollution to the waters of the State.									
Nar	ne(s) and Signature(s) of Inspector(s	s)		e/Fax		Date			
	John Fay?			AR Dept. of Environmental Quality - Fayetteville 479-267-0811, ext. 16; 479-267-0819				06-01-09	
John Fazio									
Signature of Reviewer Agence					Phone an	d Fax Numbers	Date		



Water Division NPDES Photographic Evidence Sheet									
Location:	Dec	atur S	SO locati	ons					
Photographo	er:	John F	azio		Witness:		Alison West		
Photo #	3	Of	3		Date:		05/08/09	Time:	1415
Description:	: 5	Spring	St. sanitar	y sewer overflowed from ma	nhole into C	olu	mbia Hollow C	Creek (in bac	kground).
						(1) (1) (1) (1) (1) (1) (1) (1) (1) (1)			
Dhataguanh	om.				Witness		None		
Photographo Photo #	er:	Of	I		Witness: Date:		None	Time:	
Description:	. I	OI			Date:			Time:	
Description.	•								

ADEQ Water NPDES Inspection	AFIN: <b>04-00052</b>	Permit #: AR0022292



Phone: (479) 752-3912

June 9, 2009

Cindy Garner
Water Division Enforcement Branch Manager
5301 Northshore Drive
North Little Rock AR 72118-5317

RE: Sanitary Sewer Overflow Follow up report Permit No. AR0022292

Dear Ms Garner,

I am following up on the letter dated June 1<sup>st</sup> 2009 sent to me by Mr. Fazio concerning the slight overflow we had at the intersection of Second Street and Pool Street. After looking at the form I filled out on the day of the overflow I did not put the address of the overflow or the location on the form, I went through the form and thought I was filling it out completely but with everything going on that day I did not put the location and Creek it would have went into if it would have reached the creek. This was also a different form than I have used on your website in the past. I do apologize for not filling out the form completely; I did not purposely leave the address off the form. The water did not reach the creek at that location but did get the road wet.

It does appear that the water did overflow from the other manhole that Mr. Fazio photographed that we did not know about. We noticed the leak starting to happen at the 2<sup>nd</sup> and Pool Street location and immediately went to get the rodding machine to get rid of the blockage by debris that we had. This manhole is in front and in the street by Simmons Foods which I know would have been reported to us if they had observed the overflow. The other manhole that Mr. Fazio observed is upstream of the manhole that we cleared debris from.

To ensure this problem does not happen again, if the manhole at 2<sup>nd</sup> and Pool happens to overflow in the future we will also check the upstream manholes back to Spring street to make sure they have not also overflowed and report them if they have. As for Mr. Fazio's contact with Mr. Beemer, I believe there have been issues between Mr. Beemer and the City long before I went to work for the City and I am sure that he had a great opportunity to make the City look bad by talking to Mr. Fazio. Every water leak or manhole overflow is looked into immediately when reported. I would like to say that the manhole photographed on that day was not reported to us by Mr. Beemer or Mr. Fazio to my knowledge.

The line that had the blockage is a very busy sewer line. Our new WWTP comes on line in the next few weeks and this should eliminate a problem this line has always had and

that is being slightly surcharged during high water usage or rainfall. When opening up the new line into the new WWTP this problem should be eliminated.

If you have any questions or concerns please call me at 479-752-3912.

Sincerely,

James Boston

Public Works Manager

City of Decatur

P.O. Box 247 • 310 Maple Ave.
Decatur, Arkansas 72722

\* \* \* PB8776693 3230 \$ 00.610 JUN 10 09 5993 MAILED FROM DECATUR, AR 72722

ADEQ 5301 Northshore Drive North Little Rock AR 72118-5317

+5317

Hadaladhadhadhadhadhadhadhadh