

June 10, 2009

Ms. Belva Plumlee, Wastewater Utility Manager Bentonville Wastewater Treatment Plant 1901 N.E. A Street Bentonville, Arkansas 72712

**RE: NPDES Permit Compliance Inspection** 

AFIN: 04-00154 NPDES Permit No.: AR0022403

Dear Ms. Plumlee:

On June 4, 2009, I performed a routine permit compliance evaluation inspection of the wastewater treatment facility in accordance with the provisions of the Federal Clean Water Act, the Arkansas Water and Air Pollution Control Act, and the regulations promulgated thereunder. This inspection revealed that you are in compliance with the terms of your permit.

If I can be of any assistance, please contact me at 479-267-0811, ext. 16.

Sincerely,

John Fazio District 1 Field Inspector Water Division

cc: Water Division Enforcement Branch Water Division Permits Branch

≎EPA									Form Approved OMB No. 2040-0003		
UNITED STATES ENVIRONMENTAL PROTECTION AGENCY											
Washington, D.C. 20460											
	NPDES Compliance Inspection Report										
Section A: National Data System Coding											
1	N   2   5   3   A   R	0	NPDES           0         2         2         4	<b>0 3</b> 11	L	0	Yr/Mo/Day 9 0 6 0 4 17	Ins 18	pec. Type   Inspector   Fac. Type     C   19   S   20   1		
	Remarks         Inspection Work Days       Facility Evaluation Rating       BL       OA										
									Reserved		
	67     69     70     5     71     N     72     N     73     74     75     80										
				Section I		ity ]			1		
Name and Location of Facility Inspected (For industrial users discharging to POTW, also include POTW name and NPDES permit number)       Entry Time/Date 0945 / 06-04-09       Permit Effective Date March 1, 2009         City of Bentonville Wastewater Treatment Plant       March 1, 2009       March 1, 2009											
	1901 N.E. A Street Bentonville, Arkansas 72712Exit Time/Date 1515 / 06-04-09Permit Expiration Date February 28, 2014										
Name(s) of On-Site Representative(s)/Title(s)/Phone and Fax Number(s)       Other Facility Data         Belva Plumlee, Wastewater Utility Manager, 479-271-3160, 479-271-3167 (fax)       Outfall 001: 36 23 32.4, -94 12 12.6											
Name, Address of Responsible Official/Title/Phone and Fax Number       Belva Plumlee, Wastewater Utility Manager       Entrance: 36 23 27.4, -94 12 14.4         City of Bentonville       Contacted       Entrance: 36 23 27.4, -94 12 14.4											
115 W. Central     Yes     No       Bentonville, Arkansas 72712     Yes     No											
Section C: Areas Evaluated During Inspection (S = Satisfactory, M = Marginal, U = Unsatisfactory, N = Not Evaluated)											
						Sampling					
S							Ν	Pollution Prevention			
S							Multimedia				
S	Diffuent/receiving (fuers)							Other:			
Section D: Summary of Findings/Comments (Attach additional sheets if necessary)											
Records obtained for review include DMRs and DMR calculating spreadsheets (monthly reports) for March, April and May of 2009, and the 1 <sup>st</sup> Quarter Biomonitoring Report. One pH excursion was noted in April 2009.											
30-average percent removal for TSS in May 2009 was 98 percent. 30-average percent removal for CBOD5 in May 2009 was 98 percent.											
This inspection revealed no evidence of permit violations.											
	Name(s) and Signature(s) of Inspector(s)     Agency/Office/Telephone/Fax     Date       AR Dept. of Environmental Quality-Fayetteville     June 10, 2009       John Fazio     479-267-0811, ext. 16; 479-267-0819 (fax)										
3011	II I'ALIU *** * #					.,					
Sig	Signature of Reviewer     Agency/Office/Phone and Fax Numbers     Date										

ADEQ Water NPDES Inspection
-----------------------------

Permit #: AR0022403

SECTION A: PERMIT VERIFICATION	
PERMIT SATISFACTORILY ADDRESSES OBSERVATIONS	🗹 s 🗆 m 🗇 u 🖾 na 🗇 ne
DETAILS:	
1. CORRECT NAME AND MAILING ADDRESS OF PERMITTEE:	Øy 🗆n 🗆na 🗆ne
2. NOTIFICATION GIVEN TO EPA/STATE OF NEW DIFFERENT OR INCREASED DISCHARGES:	
3. NUMBER AND LOCATION OF DISCHARGE POINTS AS DESCRIBED IN PERMIT:	
4. ALL DISCHARGES ARE PERMITTED:	Øy 🗆n 🗆na 🗇ne
SECTION B: RECORDKEEPING AND REPORTING EVALUATION	
RECORDS AND REPORTS MAINTAINED AS REQUIRED BY PERMIT	🗹 S 🗆 M 🗇 U 🗆 NA 🗆 NE
DETAILS:	
1. ANALYTICAL RESULTS CONSISTENT WITH DATA REPORTED ON DMRS:	Øy 🗆n 🗆na 🗆ne
2. SAMPLING AND ANALYSES DATA ADEQUATE AND INCLUDE:	Øs 🗆m 🗇u 🖾na 🖾ne
a. DATES AND TIME(S) OF SAMPLING:	Øy 🗆n 🗆na 🗇ne
b. EXACT LOCATION(S) OF SAMPLING:	Øy 🗆n 🗆na 🗇ne
c. NAME OF INDIVIDUAL PERFORMING SAMPLING:	🗹 Y 🗆 N 🗆 NA 🗆 NE
d. ANALYTICAL METHODS AND TECHNIQUES:	Øy 🗆n 🗆na 🗆ne
e. RESULTS OF CALIBRATIONS:	Øy 🗆n 🗆na 🗇ne
f. RESULTS OF ANALYSES:	🗹 y 🗆 n 🗆 na 🗆 ne
g. DATES AND TIMES OF ANALYSES:	Øy 🗆n 🗆na 🗇ne
h. NAME OF PERSON(S) PERFORMING ANALYSES:	Øy 🗆n 🗆na 🗆ne
3. LABORATORY EQUIPMENT CALIBRATION AND MAINTENANCE RECORDS ADEQUATE:	🗹 s 🗆 m 🗇 u 🗆 na 🗠 ne
4. PLANT RECORDS INCLUDE SCHEDULES, DATES OF EQUIPMENT MAINTENANCE AND REPAIR:	Øs 🗆m 🗇u 🖾na 🖾ne
5. EFFLUENT LOADINGS CALCULATED USING DAILY EFFLUENT FLOW AND DAILY ANALYTICAL DATA:	Øy 🗆n 🗆na 🗇ne
SECTION C: OPERATIONS AND MAINTENANCE	
TREATMENT FACILITY PROPERLY OPERATED AND MAINTAINED	
DETAILS:	
1. TREATMENT UNITS PROPERLY OPERATED:	Øs 🗆m 🗇u 🖾na 🖾ne
2. TREATMENT UNITS PROPERLY MAINTAINED:	Øs 🗆m 🗇u 🖾na 🖾ne
3. STANDBY POWER OR OTHER EQUIVALENT PROVIDED: City has provided dual feed for power	Øs 🗆m 🗇u 🖾na 🖾ne
4. ADEQUATE ALARM SYSTEM FOR POWER OR EQUIPMENT FAILURES AVAILABLE: SCADA – battery backup	Øs 🗆m 🗇u 🖾na 🖾ne
5. ALL NEEDED TREATMENT UNITS IN SERVICE:	
6. ADEQUATE NUMBER OF QUALIFIED OPERATORS PROVIDED: Includes 3 Class IV Operators	Øs 🗆m 🗇u 🖾na 🖾ne
7. SPARE PARTS AND SUPPLIES INVENTORY MAINTAINED:	Øs 🗆m 🗇u 🖾na 🖾ne
8. OPERATION AND MAINTENANCE MANUAL AVAILABLE:	
9. STANDARD OPERATING PROCEDURES AND SCHEDULES ESTABLISHED:	
10. PROCEDURES FOR EMERGENCY TREATMENT CONTROL ESTABLISHED:	
11. HAVE BYPASSES/ <u>OVERFLOWS</u> OCCURRED AT THE PLANT OR IN THE COLLECTION SYSTEM IN THE LAST YEAR: <u>Overflo</u> collection system	w <u>s in</u> 🛛 🖉 Y 🗆 N 🗆 NA 🗆 NE
12. IF SO, HAS THE REGULATORY AGENCY BEEN NOTIFIED:	
13. HAS CORRECTIVE ACTION BEEN TAKEN TO PREVENT ADDITIONAL BYPASSES/OVERFLOWS: Bypasses N/A; Overflows Y	<u>/es</u> ØY  ON  ONA  ONE
14. HAVE ANY HYDRAULIC OVERLOADS OCCURRED AT THE TREATMENT PLANT:	Dy Øn Ona One
15. IF SO, DID PERMIT VIOLATIONS OCCUR AS A RESULT:	

Permit #: AR0022403

SECTION D: SAMPLING	
PERMITTEE SAMPLING MEETS PERMIT REQUIREMENTS	
DETAILS:	
1. SAMPLES TAKEN AT SITE(S) SPECIFIED IN PERMIT:	
2. LOCATIONS ADEQUATE FOR REPRESENTATIVE SAMPLES:	🗹 y 🗆 n 🗆 na 🗆 ne
3. FLOW PROPORTIONED SAMPLES OBTAINED WHEN REQUIRED BY PERMIT:	🗹 y 🗆 n 🗆 na 🗆 ne
4. SAMPLING AND ANALYSES COMPLETED ON PARAMETERS SPECIFIED IN PERMIT:	
5. SAMPLING AND ANALYSES PERFORMED AT FREQUENCY SPECIFIED IN PERMIT:	🗹 y 🗆 n 🗆 na 🗆 ne
6. SAMPLE COLLECTION PROCEDURES ADEQUATE:	
a. SAMPLES REFRIGERATED DURING COMPOSITING:	
b. PROPER PRESERVATION TECHNIQUES USED:	
c. CONTAINERS AND SAMPLE HOLDING TIMES CONFORM TO 40 CFR 136:	
7. IF MONITORING IS PERFORMED MORE OFTEN THAN REQUIRED, RESULTS ARE REPORTED ON THE DMR:	
SECTION E: FLOW MEASUREMENT	
PERMITTEE FLOW MEASUREMENT MEETS PERMIT REQUIREMENTS	I ØS □M □U □NA □NE
DETAILS:	
1. PRIMARY FLOW MEASUREMENT DEVICE PROPERLY INSTALLED AND MAINTAINED: TYPE OF DEVICE: ISCO 3010 UI	
2. FLOW MEASURED AT EACH OUTFALL AS REQUIRED:	
3. SECONDARY INSTRUMENTS (TOTALIZERS, RECORDERS, ETC.) PROPERLY OPERATED AND MAINTAINED:	
4. CALIBRATION FREQUENCY ADEQUATE: Calibrated 06/09/09	
5. RECORDS MAINTAINED OF CALIBRATION PROCEDURES:	Øy 🛛 n 🖓 na 🖓 ne
6. CALIBRATION CHECKS DONE TO ASSURE CONTINUED COMPLIANCE:	
<ol> <li>FLOW ENTERING DEVICE WELL DISTRIBUTED ACROSS THE CHANNEL AND FREE OF TURBULENCE: Effluent aerator tu at time of measurement to prevent turbulence.</li> </ol>	
8. FLOW MEASUREMENT EQUIPMENT ADEQUATE TO HANDLE EXPECTED RANGE OF FLOW RATES:	Øy 🛛 n 🖓 na 🖓 ne
9. HEAD MEASURED AT PROPER LOCATION:	🗹 Y 🗆 N 🗆 NA 🗆 NE
SECTION F: LABORATORY	
PERMITTEE LABORATORY PROCEDURES MEET PERMIT REQUIREMENTS	
DETAILS:	
1. EPA APPROVED ANALYTICAL PROCEDURES USED (40 CFR 136.3 FOR LIQUIDS, 503.8(B) FOR SLUDGES) :	
2. IF ALTERNATIVE ANALYTICAL PROCEDURES ARE USED, PROPER APPROVAL HAS BEEN OBTAINED:	
3. SATISFACTORY CALIBRATION AND MAINTENANCE OF INSTRUMENTS AND EQUIPMENT:	
4. QUALITY CONTROL PROCEDURES ADEQUATE:	🗹 y 🗆 n 🗆 na 🗆 ne
5. DUPLICATE SAMPLES ARE ANALYZED ≥10% OF THE TIME:	
6. SPIKED SAMPLES ARE ANALYZED $\geq$ 10% OF THE TIME:	
7. COMMERCIAL LABORATORY USED:	
a. LAB NAME: American Interplex Bio-Analytical Lab	
b. LAB ADDRESS: 8600 Kanis Rd., Little Rock, Arkansas 72204 3240 Spurgin Rd., Doyline, LA 71023	
c. PARAMETERS PERFORMED: Table II Organics, Table III Metals, TCLP, PCB Biomonitoring	
8. BIOMONITORING PROCEDURES ADEQUATE:	
a. PROPER ORGANISMS USED:	
b. PROPER DILUTION SERIES FOLLOWED:	
c. PROPER TEST METHODS AND DURATION:	
d. RETESTS AND/OR TRE PERFORMED AS REQUIRED:	

ADEQ Water NPDES Inspection
-----------------------------

Permit #: AR0022403

SECTION G: EFFLUENT/RECEIVING WATERS OBSERVATIONS												
BASED ON VISUAL OBSERVATIONS ONLY												
DETAILS:												
OUTFAL	L #: OIL SHEEN	GREASE	TURBIDITY	VISIBLE FOAM	FLOATING SOLIDS	TING SOLIDS COLOR OTHER						
001	None	None	None	None	None	Clear Some a						
SECTION H: SLUDGE DISPOSAL												
SLUDO	GE DISPOSAL MEI	ETS PERMIT F	REQUIREMEN	TS		⊠s ⊡n						
DETAI	DETAILS:											
1. SLUI												
2. SLUI												
3. FOR												
SECTION I: SAMPLING INSPECTION PROCEDURES												
SAMPLE RESULTS WITHIN PERMIT REQUIREMENTS												
DETAILS:												
1. SAMPLES OBTAINED THIS INSPECTION:												
2. TYPE	OF SAMPLE:		IETHOD: FREQUE	NCY:								
	PLES PRESERVED:			-								
4. FLO\	W PROPORTIONED SAMPLE	S OBTAINED:										
5. SAM	PLE OBTAINED FROM FACI	LITY'S SAMPLING DE	/ICE:									
6. SAMPLE REPRESENTATIVE OF VOLUME AND NATURE OF DISCHARGE:												
7.     SAMPLE SPLIT WITH PERMITTEE:     □Y □N □NA ☑NE												
8. CHAIN-OF-CUSTODY PROCEDURES EMPLOYED:												
9. SAMPLES COLLECTED IN ACCORDANCE WITH PERMIT:												
SECTION J: STORMWATER POLLUTION PREVENTION PLAN												
STORMWATER MANAGEMENT MEETS PERMIT REQUIREMENTS												
	LS: (Have No Expo				pection)							
	PP UPDATED AS NEEDED:						Dy On Øna One					
2. SITE	MAP INCLUDING ALL DISCH	HARGES AND SURFA	CE WATERS:									
3. POLI												
4. POLI												
5. LIST												
	NON-STORMWATER DISCH											
8. LIST												
	OF NON-STRUCTURAL BMF	PS:										
	S PROPERLY OPERATED A											
	ECTIONS CONDUCTED AS											

	ADEQ Water NPDES Inspe	ction
--	------------------------	-------

Permit #: AR0022403

FLOW CALCULATION SHEET									
Date: June 4, 2009 Time: 1112									
Head in Inc	ches: <b>13.25</b>	Feet: <b>1.1</b>	04						
Type & Size of Primary Flow Measurement Device: 24" Parshall Flume									
					_				
Name & Mo	odel of Secondary	Flow Measure	ement Dev	vice:   ISC	O 3010 Ultrasonic				
Date of last	t Calibration of Se	condary Flow	Device: 0	5/2008					
Recorded F	Recorded Flow at Date & Time Listed Above: 4250 gpm (Facility Flow Meter)								
Calculated	Calculated Flow at Date & Time Listed Above: 4162 gpm								
Calculated Flow at Date & Time Listed Above:       4162 gpm         (Flow is calculated using flow charts in:       ISCO Open Channel Flow Measurement Handbook-5 <sup>th</sup> Edition)									
Recorded Value - Calculated Value v 400									
% Error =	Recorded Value		- X 100 -						
	Calculated Value								
% Error =	4250	- 4	162	X 100					
		4162	X 100						
	88								
% Error =	4162	- X 100							
% Error =	0.0211	X 100							
% Error =	2.11	0/							
% EII0I =	2.11	%							
Comments	:								
	I								

ADEQ Water NPDES Inspection			AFIN: 04-00154			Permit #: AR0022403			
	DN	AR Calculat	tion Che	ck					
<b>Reporting Period:</b>		09 Tear	05 Month	01 Day	_ To	09 Year	05 Month	<u>31</u> Day	
Parameter Checked	: <u>CBC</u>	)D5	_						
		nding lass		Concentration Monthly					
	Mo. Avg	lbs/	/day	Mo. A	vg	mg/l	7-day Avg	g mg/l	
<b>Reported Value:</b>	2	241			4.1		6.2		
Calculated Value:	241			4.1			6.2		
Permit Value: <u>333.6</u>			10 1			15			

If calculated value does not equal reported value, explain: