

June 17, 2009

Carl W. Johnson, Mayor Mayor of Cave City P.O. Box 69 Cave City, AR 72521

AFIN: 68-00015 NPDES Permit No.: AR0022110

Dear Mayor Johnson:

On May 28, 2009, I performed a routine compliance inspection of the waste water treatment facility in accordance with the provisions of the Federal Clean Water Act, the Arkansas Water and Air Pollution Control Act, and the regulations promulgated thereunder. This inspection revealed that you are in compliance with the terms of your permit.

If I can be of any assistance, please contact me at 870-793-5819.

Sincerely,

Mile Kennedy

District 11, Field Inspector

Water Division

cc: Water Division Enforcement Branch

Water Division Permits Branch

	ас. Туре		
NPDES Compliance Inspection Report   Section A: National Data System Coding   Transaction Code   NPDES   NPDES   Yr/Mo/Day   Inspector   Fa   N   2   5   3   A   R   0   0   2   2   1   1   0   11   12   0   9   0   5   2   8   17   18   C   19   S   20   Remarks   Remarks	c. Type		
Section A: National Data System Coding   Transaction Code	c. Type		
1 N 2 5 3 A R 0 0 2 2 1 1 0 11 12 0 9 0 5 2 8 17 18 C 1 19 S 20 Remarks	c. Type		
Remarks	J PC		
	1		
A   F   I   N     0   0   -   0   0   0   I   3	ı		
Inspection Work Days Facility Evaluation Rating BI QAReserved			
	30		
Section B: Facility Data			
Name and Location of Facility Inspected (For industrial users discharging to POTW, also include POTW name and NPDES permit number)  Cave City WWTP  Entry Time/Date 1000 / May 28, 2009  July 1, 2008			
201 Foley Drive Cave City, AR  Exit Time/Date 1215 / May 28, 2009  Permit Expiration Date June 30, 2013			
Name(s) of On-Site Representative(s)/Title(s)/Phone and Fax Number(s)  Jim Smith / Wastewater Superintendent / 870-283-5190 / Cell 870-613-0003  Other Facility Data N35°56′12.49″ W91°32'08.90″			
Name, Address of Responsible Official/Title/Phone and Fax Number Carl W. Johnson / Mayor / 870-283-5103 Contacted			
Yes No V			
Section C: Areas Evaluated During Inspection			
(S = Satisfactory, M = Marginal, U = Unsatisfactory, N = Not Evaluated)			
S Permit S Flow Measurement S Operations & Maintenance S Sampling			
S     Records/Reports     S     Self-Monitoring Program     N     Sludge Handling/Disposal     N     Pollution Prevention       S     Facility Site Review     S     Compliance Schedules     N     Pretreatment     N     Multimedia			
S     Facility Site Review     S     Compliance Schedules     N     Pretreatment     N     Multimedia       S     Effluent/Receiving Waters     S     Laboratory     N     Storm Water     N     Other:			
Section D: Summary of Findings/Comments (Attach additional sheets if necessary)			
DMR's were reviewed for February, March and April 2009 during the inspection.			
The effluent appeared to be within permit limits.			
Name(s) and Signature(s) of Inspector(s)  Agency/Office/Telephone/Fax  Date			
ADEQ / Batesville / 870-793-5819 / 870-793-5814  June 17, 2009			
Mike Kennedy			
Signature of Reviewer Agency/Office/Phone and Fax Numbers Date			

ADEQ Water NPDES Inspection	AFIN: 68-00015	Permit #: AR0022110

SECTION A: PERMIT VERIFICATION	
PERMIT SATISFACTORILY ADDRESSES OBSERVATIONS	☑S ☐M ☐U ☐NA ☐NE
DETAILS:	
1. CORRECT NAME AND MAILING ADDRESS OF PERMITTEE:	☑Y □N □NA □NE
2. NOTIFICATION GIVEN TO EPA/STATE OF NEW DIFFERENT OR INCREASED DISCHARGES:	□y □n ☑na □ne
3. NUMBER AND LOCATION OF DISCHARGE POINTS AS DESCRIBED IN PERMIT:	☑Y □N □NA □NE
4. ALL DISCHARGES ARE PERMITTED:	☑y □n □na □ne
SECTION B: RECORDKEEPING AND REPORTING EVALUATION	
RECORDS AND REPORTS MAINTAINED AS REQUIRED BY PERMIT	☑S ☐M ☐U ☐NA ☐NE
DETAILS:	
1. ANALYTICAL RESULTS CONSISTENT WITH DATA REPORTED ON DMRS:	☑Y □N □NA □NE
2. SAMPLING AND ANALYSES DATA ADEQUATE AND INCLUDE:	⊠s □m □u □na □ne
a. DATES AND TIME(S) OF SAMPLING:	☑Y □N □NA □NE
b. EXACT LOCATION(S) OF SAMPLING:	☑y □n □na □ne
c. NAME OF INDIVIDUAL PERFORMING SAMPLING:	☑Y □N □NA □NE
d. ANALYTICAL METHODS AND TECHNIQUES:	☑Y □N □NA □NE
e. RESULTS OF CALIBRATIONS:	☑Y □N □NA □NE
f. RESULTS OF ANALYSES:	☑Y □N □NA □NE
g. DATES AND TIMES OF ANALYSES:	☑Y □N □NA □NE
h. NAME OF PERSON(S) PERFORMING ANALYSES:	☑Y □N □NA □NE
3. LABORATORY EQUIPMENT CALIBRATION AND MAINTENANCE RECORDS ADEQUATE: Contract Laboratory	□s □m □u ☑na □ne
4. PLANT RECORDS INCLUDE SCHEDULES, DATES OF EQUIPMENT MAINTENANCE AND REPAIR:	⊠s □m □u □na □ne
5. EFFLUENT LOADINGS CALCULATED USING DAILY EFFLUENT FLOW AND DAILY ANALYTICAL DATA:	☑Y □N □NA □NE
SECTION C: OPERATIONS AND MAINTENANCE	
TREATMENT FACILITY PROPERLY OPERATED AND MAINTAINED	☑S □M □U □NA □NE
DETAILS:	
1. TREATMENT UNITS PROPERLY OPERATED:	⊠s □m □u □na □ne
2. TREATMENT UNITS PROPERLY MAINTAINED:	⊠s □m □u □na □ne
3. STANDBY POWER OR OTHER EQUIVALENT PROVIDED: Generator	⊠s □m □u □na □ne
4. ADEQUATE ALARM SYSTEM FOR POWER OR EQUIPMENT FAILURES AVAILABLE: Alarms and lights at lift stations	⊠s □m □u □na □ne
5. ALL NEEDED TREATMENT UNITS IN SERVICE:	⊠s □m □u □na □ne
6. ADEQUATE NUMBER OF QUALIFIED OPERATORS PROVIDED: (1-Class III, 1-Class II)	⊠s □m □u □na □ne
7. SPARE PARTS AND SUPPLIES INVENTORY MAINTAINED:	Øs □m □u □na □ne
8. OPERATION AND MAINTENANCE MANUAL AVAILABLE:	☑Y ☐N ☐NA ☐NE
9. STANDARD OPERATING PROCEDURES AND SCHEDULES ESTABLISHED:	☑Y □N □NA □NE
10. PROCEDURES FOR EMERGENCY TREATMENT CONTROL ESTABLISHED:	□y □n □na ☑ne
11. HAVE BYPASSES/OVERFLOWS OCCURRED AT THE PLANT OR IN THE COLLECTION SYSTEM IN THE LAST YEAR:	□y Øn □na □ne
12. IF SO, HAS THE REGULATORY AGENCY BEEN NOTIFIED:	□y □n ☑na □ne
13. HAS CORRECTIVE ACTION BEEN TAKEN TO PREVENT ADDITIONAL BYPASSES/OVERFLOWS:	□y □n ☑na □ne
14. HAVE ANY HYDRAULIC OVERLOADS OCCURRED AT THE TREATMENT PLANT:	□y Øn □na □ne
15. IF SO, DID PERMIT VIOLATIONS OCCUR AS A RESULT:	□y □n ☑na □ne

ADEQ Water NPDES Inspection	AFIN: 68-00015	Permit #: AR0022110

SECTION D: SAMPLING	
PERMITTEE SAMPLING MEETS PERMIT REQUIREMENTS	☑S ☐M ☐U ☐NA ☐NE
DETAILS:	
1. SAMPLES TAKEN AT SITE(S) SPECIFIED IN PERMIT:	☑Y □N □NA □NE
2. LOCATIONS ADEQUATE FOR REPRESENTATIVE SAMPLES:	☑Y □N □NA □NE
3. FLOW PROPORTIONED SAMPLES OBTAINED WHEN REQUIRED BY PERMIT:	□y □n ☑na □ne
4. SAMPLING AND ANALYSES COMPLETED ON PARAMETERS SPECIFIED IN PERMIT:	☑Y □N □NA □NE
5. SAMPLING AND ANALYSES PERFORMED AT FREQUENCY SPECIFIED IN PERMIT:	Øy □n □na □ne
6. SAMPLE COLLECTION PROCEDURES ADEQUATE:	☑Y □N □NA □NE
a. SAMPLES REFRIGERATED DURING COMPOSITING:	□y □n ☑na □ne
b. PROPER PRESERVATION TECHNIQUES USED:	☑Y □N □NA □NE
c. CONTAINERS AND SAMPLE HOLDING TIMES CONFORM TO 40 CFR 136:	☑Y □N □NA □NE
7. IF MONITORING IS PERFORMED MORE OFTEN THAN REQUIRED ARE RESULTS REPORTED ON THE DMR:	□Y □N ☑NA □NE
SECTION E: FLOW MEASUREMENT	
PERMITTEE FLOW MEASUREMENT MEETS PERMIT REQUIREMENTS	☑S □M □U □NA □NE
DETAILS:	
1. PRIMARY FLOW MEASUREMENT DEVICE PROPERLY INSTALLED AND MAINTAINED: TYPE OF DEVICE: 6 inch Parshal	I Flume
2. FLOW MEASURED AT EACH OUTFALL AS REQUIRED:	☑Y □N □NA □NE
3. SECONDARY INSTRUMENTS (TOTALIZERS, RECORDERS, ETC.) PROPERLY OPERATED AND MAINTAINED:	☑Y □N □NA □NE
4. CALIBRATION FREQUENCY ADEQUATE: Last calibration 10-28-08	Øy □n □na □ne
5. RECORDS MAINTAINED OF CALIBRATION PROCEDURES:	Øy □n □na □ne
6. CALIBRATION CHECKS DONE TO ASSURE CONTINUED COMPLIANCE:	Øy □n □na □ne
7. FLOW ENTERING DEVICE WELL DISTRIBUTED ACROSS THE CHANNEL AND FREE OF TURBULENCE:	☑Y □N □NA □NE
8. FLOW MEASUREMENT EQUIPMENT ADEQUATE TO HANDLE EXPECTED RANGE OF FLOW RATES:	☑Y □N □NA □NE
9. HEAD MEASURED AT PROPER LOCATION:	Øy □n □na □ne
SECTION F: LABORATORY	
PERMITTEE LABORATORY PROCEDURES MEET PERMIT REQUIREMENTS	☑S □M □U □NA □NE
DETAILS:	
1. EPA APPROVED ANALYTICAL PROCEDURES USED (40 CFR 136.3 FOR LIQUIDS, 503.8(B) FOR SLUDGES) :	☑Y □N □NA □NE
2. IF ALTERNATIVE ANALYTICAL PROCEDURES ARE USED, PROPER APPROVAL HAS BEEN OBTAINED:	□Y □N ☑NA □NE
3. SATISFACTORY CALIBRATION AND MAINTENANCE OF INSTRUMENTS AND EQUIPMENT:	☑Y □N □NA □NE
4. QUALITY CONTROL PROCEDURES ADEQUATE:	Øy □n □na □ne
5. DUPLICATE SAMPLES ARE ANALYZED ≥10% OF THE TIME:	☑Y □N □NA □NE
6. SPIKED SAMPLES ARE ANALYZED ≥10% OF THE TIME:	☑Y □N □NA □NE
7. COMMERCIAL LABORATORY USED:	☑Y □N □NA □NE
a. LAB NAME: Arkansas Testing Laboratories	
b. LAB ADDRESS: 3301 Langley Drive, Searcy, AR 72143 Phone 501-268-6431	
c. PARAMETERS PERFORMED: Flow, CBOD, TSS, Ammonia Nitrogen, Fecal Coliform, pH, DO & Chlorine Residual	
8. BIOMONITORING PROCEDURES ADEQUATE:	□Y □N ☑NA □NE
a. PROPER ORGANISMS USED:	□Y □N ☑NA □NE
b. PROPER DILUTION SERIES FOLLOWED:	□Y □N ☑NA □NE
c. PROPER TEST METHODS AND DURATION:	□Y □N ☑NA □NE
d. RETESTS AND/OR TRE PERFORMED AS REQUIRED:	□y □n ☑na □ne

ADEQ Water NPDES Inspection	AFIN: 68-00015	Permit #: AR0022110

SECTION G: EFFLUENT/RECEIVING WATERS OBSERVATIONS							
BASED ON VISUAL OBSERVATIONS ONLY						⊠s □m □	U □NA □NE
DETAILS:							
OUTFALL #:	OIL SHEEN	GREASE	TURBIDITY	VISIBLE FOAM	FLOATING SOLIDS	COLOR	OTHER
001	None	None	Trace	None	None	Light Green	
SECTION	H: SLUDGE	DISPOSAL					
SLUDGE D	DISPOSAL ME	ETS PERMIT R	REQUIREMEN	ΓS		⊠s □m □	U □NA □NE
DETAILS:	No sludge need	ed to be remov	ed for Fiscal Ye	ear 2008	1		
1. SLUDGE M	IANAGEMENT ADEQU	ATE TO MAINTAIN EF	FLUENT QUALITY:			□s □м	□u ☑na □ne
2. SLUDGE R	ECORDS MAINTAINED	AS REQUIRED BY 40	) CFR 503:			□s □м	□u ☑na □ne
3. FOR LAND	APPLIED SLUDGE, TY	PE OF LAND APPLIE	O TO: (E.G., FOREST,	AGRICULTURAL, PUE	BLIC CONTACT SITE):		
SECTION	I: SAMPLIN	G INSPECTION	N PROCEDI	JRES			
SAMPLE F	RESULTS WITH	IIN PERMIT R	EQUIREMENT	S		□s □m □	U ⊠NA □NE
DETAILS:							
1. SAMPLES	OBTAINED THIS INSPE	ECTION:				□Y	☑N □NA □NE
2. TYPE OF S	AMPLE: GRAB:	COMPOSITE:_ N	METHOD: FREQUE	NCY:			
3. SAMPLES PRESERVED:							□n ☑na □ne
4. FLOW PRO	PORTIONED SAMPLE	S OBTAINED:				□Y	□n ☑na □ne
5. SAMPLE OBTAINED FROM FACILITY'S SAMPLING DEVICE:						□n ☑na □ne	
6. SAMPLE REPRESENTATIVE OF VOLUME AND NATURE OF DISCHARGE:						□Y	□n ☑na □ne
7. SAMPLE SPLIT WITH PERMITTEE:						□Y	□n ☑na □ne
8. CHAIN-OF-CUSTODY PROCEDURES EMPLOYED:						□Y	□n ☑na □ne
9. SAMPLES COLLECTED IN ACCORDANCE WITH PERMIT:						□Y	□N ☑NA □NE
SECTION	J: STORM V	<b>VATER POLL</b>	.UTION PRE	/ENTION PL/	AN		
STORM W	ATER MANAG	EMENT MEET	S PERMIT RE	QUIREMENTS		□s □m □	U ⊠NA □NE
DETAILS:							
1. SWPPP UF	PDATED AS NEEDED:_	_ DATE OF LAST UP	DATE:			□Y	□N ☑NA □NE
2. SITE MAP INCLUDING ALL DISCHARGES AND SURFACE WATERS:						□N ☑NA □NE	
3. POLLUTION PREVENTION TEAM IDENTIFIED:						□N ☑NA □NE	
4. POLLUTION PREVENTION TEAM PROPERLY TRAINED:						□n ☑na □ne	
5. LIST OF POTENTIAL POLLUTANT SOURCES:						□N ☑NA □NE	
6. LIST OF PO	6. LIST OF POTENTIAL SOURCES AND PAST SPILLS AND LEAKS:					□Y	□n ☑na □ne
7. ALL NON-STORM WATER DISCHARGES ARE AUTHORIZED:						□Y	□n ☑na □ne
8. LIST OF ST	RUCTURAL BMPS:					□Y	□n ☑na □ne
9. LIST OF NO	ON-STRUCTURAL BMF	PS:				□Y	□n Øna □ne
10. BMPS PRC	PERLY OPERATED A	ND MAINTAINED:				□Y	□n Øna □ne
11. INSPECTIO	11. INSPECTIONS CONDUCTED AS REQUIRED:						□N ☑NA □NE

FLOW CALCULATION SHEET							
Date: May	<sup>7</sup> 28, 2009 T	ime: 11:	50				
'	·	<u> </u>	•				
Head in Inc	hes: <b>5.25</b>	Feet:	0.4375				
Type & Size	e of Primary Flow	Measurem	nent Device:	6 inch Par	shall Flume		
1 1 1 1 2 2 2 2 2 2 2 2 2 2 2	or i illiary i low	<u> </u>	ioni Bovioo.	o intorni ar	Ondir i idirio		
Nama & Ma	dal of Sacandary	Flow Moo	curomont Do	vico: Mo	asure Tech SCM		
Name & MC	del of Secondary	i iow ivica	Surement De	evice.   ivie	asule recir scivi		
Data at last	0-11		D	0-1-10	0.0000		
Date of last	Calibration of Sec	condary Fi	ow Device:	October 2	8, 2008		
Recorded F	low at Date & Tim	ne Listed A	Above: <b>252</b>	GPM	(Facility Flow I	Meter)	
	Flow at Date & Tir			9 GPM			
(Flow is calculated	ed using flow charts in: <b>T</b>	able 13.4, ISC	CO 5 <sup>th</sup> Edition				
% Error =	252	-	249	X 100	0.0120		
70 21101 -		249		/ 100			
					<del>,</del>		
% Error =	Recorded	-   C	Calculated	Y 100			
/6 LIIOI =	Ca	alculated	ited		X 100		
				•			
0/		V 400					
% Error =		X 100					
% Error =	0.00120	X 100	1.20%				
70 21101	0.00.120	71 100	112070				
% Error =		%					
/0 E1101 =		/0					
Comments:	ОК						
Comments.							

## **DMR Calculation Check**

Reporting Period: From 2009 April 1 To 2009 April 30
Year Month Day Year Month Day

**Parameter Checked:** Fecal Coliform

	Loading Mass	Concentration Monthly		
	Mo. Avg lbs/day	Mo. Avg mg/l	7-day Avg mg/l	
Reported Value:	N/A	23	129	
Calculated Value:	N/A	22.72	129	
Permit Value:	N/A	1000	2000	

If calculated value does not equal reported value, explain: The difference is probably due to rounding off.

ADEQ Water NPDES Inspection	AFIN: 68-00015	Permit #: AR0022110