

February 16, 2010

Alma Clark, Director of Water and Waste Water City of Mountain Home 720 South Hickory Mountain Home, AR 72653

RE: Waste Water Treatment Plant Permit Compliance Inspection

AFIN: 03-00039 NPDES Permit No.: AR0021211

Dear Ms. Clark:

On February 11, 2010, I performed a routine compliance inspection of the Mountain Home Waste Water Treatment Plant in accordance with the provisions of the Federal Clean Water Act, the Arkansas Water and Air Pollution Control Act, and the regulations promulgated thereunder. This inspection revealed that the facility is in compliance with the terms of the permit.

During my Permit Compliance Inspection I found the plant to be well maintained and consistently producing high quality effluent. I appreciate the courtesy extended to me during this site visit and if I can be of any assistance, please contact me at 870-446-2770 or by e-mail at morris@adeq.state.ar.us.

Sincerely,

Tony L. Morris

District 2 Field Inspector **ADEQ Water Division**

Vory L morris

Water Division Enforcement Branch cc: Water Division Permits Branch

9	EPA										Form Approved OMB No. 2040-0003	
		UNIT	ED STATES ENVIRONM	ENTAL PROTECTION	N AGENC	Y						
	NPDE	S (Complianc	e Inspec	tion	F	Report					
			S	Section A: Nation	nal Data	ı Sy	stem Coding					
1	Transaction Code N 2 5 3 A R	pec. Type										
	0 3 - 0 0 0											
	Inspection Work Days		Reserved									
	67 69		70 5	71	N 7	72	N 73		74 75		80	
				Section I		ity I	Data					
incl	ne and Location of Facility Inspected ade POTW name and NPDES permit of Mountain Home Waste Water	num	ber)	charging to POTV	V, also		Entry Time/Da 10:00 Februar		010		Permit Effective Date May 1, 2005	
537	Hicks Road, ¼ mile east of Hwy 2 intain Home, Baxter County					Ì	Exit Time/Date	e			Permit Expiration Date	
WIO	intain frome, Baxter County						12:45 Februar	ry 11, 2	010		April 30, 2010	
Terry Sanders / Plant Supervisor / 870-425-6510									ner Facility Data 36.3012 92.3815			
	ne, Address of Responsible Official/			per						┪"	72,5015	
Ms.	Alma Clark / Water and Waste Wood Mountain Home						Con	itacted				
720	South Hickory						Yes	$_{ m No} \square$	7			
Mo	untain Home, AR 72653					ŀ	165	110	_			
				tion C: Areas Ev y, M = Marginal,					ated)			
S	Permit	S	Flow Measuremen		С		rations & Mair			S	Sampling	
S	Records/Reports	S	Self-Monitoring F	Program	S	- Sluc	lge Handling/D	isposal		N	Pollution Prevention	
S	Facility Site Review	S	Compliance Sche	dules	N 1	Pre	treatment	-		N	N Multimedia	
S	Effluent/Receiving Waters	S	Laboratory		N	Stoi	m Water			S	Other: Effluent Limits	
	-	Se	ction D: Summary	of Findings/Com	ments (Att	ach additional	sheets i	f necessar	y)		
	 The plant was found to be clean, orderly and well operated. The treated discharge to Hicks Creek was clear with no detectable foam or odor. Discharge monitoring reports for November 2009, December 2009 and January 2010 were reviewed during this inspection. All water quality parameters were below permit limits. The plant has a design maximum hydraulic capacity of 12 mgd and a maximum treatment capacity of 5 mgd. The plant was running at approximately 4.1 mgd at the time of this site visit. 											
Naı	ne(s) and Signature(s) of Inspector(s			Agency/Office/ AR Dept. of E1				er Fiel	d Office		Date	
Ton	y L. Morris Vong L ?	rov	т	870-446-2770/							February 12, 2010	
Sig	nature of Reviewer	_		Agency/Office/Phone and Fax Numbers					Date			

ADEQ Water NPDES Inspection	AFIN: 03-00039	Permit #: AR0021211

SECTION A: PERMIT VERIFICATION	
PERMIT SATISFACTORILY ADDRESSES OBSERVATIONS	☑S □M □U □NA □NE
DETAILS:	
CORRECT NAME AND MAILING ADDRESS OF PERMITTEE:	✓Y □N □NA □NE
NOTIFICATION GIVEN TO EPA/STATE OF NEW DIFFERENT OR INCREASED DISCHARGES:	
NUMBER AND LOCATION OF DISCHARGE POINTS AS DESCRIBED IN PERMIT:	✓Y □N □NA □NE
4. ALL DISCHARGES ARE PERMITTED:	ØY □N □NA □NE
4. ALE DIOCHARGES ARE I ERWITTED.	ET UN UNA UNE
SECTION B: RECORDKEEPING AND REPORTING EVALUATION	
RECORDS AND REPORTS MAINTAINED AS REQUIRED BY PERMIT	☑S □M □U □NA □NE
DETAILS:	
ANALYTICAL RESULTS CONSISTENT WITH DATA REPORTED ON DMRS:	✓Y □N □NA □NE
SAMPLING AND ANALYSES DATA ADEQUATE AND INCLUDE:	☑S □M □U □NA □NE
	Øy □n □na □ne
a. DATES AND TIME(S) OF SAMPLING:	✓ ✓ ✓ ✓ ✓ ✓ ✓ ✓ ✓ ✓ ✓ ✓ ✓ ✓ ✓ ✓ ✓ ✓ ✓
b. EXACT LOCATION(S) OF SAMPLING:	
C. NAME OF INDIVIDUAL PERFORMING SAMPLING:	ØY □N □NA □NE
d. ANALYTICAL METHODS AND TECHNIQUES:	ØY □N □NA □NE
e. RESULTS OF CALIBRATIONS:	ØY □N □NA □NE
f. RESULTS OF ANALYSES:	ØY □N □NA □NE
g. DATES AND TIMES OF ANALYSES:	ØY □N □NA □NE
h. NAME OF PERSON(S) PERFORMING ANALYSES:	ØY □N □NA □NE
3. LABORATORY EQUIPMENT CALIBRATION AND MAINTENANCE RECORDS ADEQUATE:	Øs □m □u □na □ne
4. PLANT RECORDS INCLUDE SCHEDULES, DATES OF EQUIPMENT MAINTENANCE AND REPAIR:	Øs □m □u □na □ne
5. EFFLUENT LOADINGS CALCULATED USING DAILY EFFLUENT FLOW AND DAILY ANALYTICAL DATA:	Øy □n □na □ne
CECTION C. OPERATIONS AND MAINTENANCE	
SECTION C: OPERATIONS AND MAINTENANCE	
TREATMENT FACILITY PROPERLY OPERATED AND MAINTAINED	☑S ☐M ☐U ☐NA ☐NE
DETAILS:	
1. TREATMENT UNITS PROPERLY OPERATED:	Øs Om Ou Ona One
2. TREATMENT UNITS PROPERLY MAINTAINED:	Øs OM OU ONA ONE
3. STANDBY POWER OR OTHER EQUIVALENT PROVIDED: 60 KW Generator	Øs □M □U □NA □NE
4. ADEQUATE ALARM SYSTEM FOR POWER OR EQUIPMENT FAILURES AVAILABLE:	Øs Om Ou Ona One
5. ALL NEEDED TREATMENT UNITS IN SERVICE:	Øs Om Ou Ona One
6. ADEQUATE NUMBER OF QUALIFIED OPERATORS PROVIDED: 10 Licensed Operators	Øs Om Ou Ona One
7. SPARE PARTS AND SUPPLIES INVENTORY MAINTAINED:	ØS OM OU ONA ONE
8. OPERATION AND MAINTENANCE MANUAL AVAILABLE:	MY ON ONA ONE
9. STANDARD OPERATING PROCEDURES AND SCHEDULES ESTABLISHED:	MY ON ONA ONE
10. PROCEDURES FOR EMERGENCY TREATMENT CONTROL ESTABLISHED:	MY ON ONA ONE
11. HAVE BYPASSES/OVERFLOWS OCCURRED AT THE PLANT OR IN THE COLLECTION SYSTEM IN THE LAST YEAR:	MY ON ONA ONE
12. IF SO, HAS THE REGULATORY AGENCY BEEN NOTIFIED:	MY ON ONA ONE
13. HAS CORRECTIVE ACTION BEEN TAKEN TO PREVENT ADDITIONAL BYPASSES/OVERFLOWS:	MY ON ONA ONE
14. HAVE ANY HYDRAULIC OVERLOADS OCCURRED AT THE TREATMENT PLANT:	OY ØN ONA ONE
15. IF SO, DID PERMIT VIOLATIONS OCCUR AS A RESULT:	□y □n ☑na □ne

ADEQ Water NPDES Inspection	AFIN: 03-00039	Permit #: AR0021211

SECTION D: SAMPLING	
PERMITTEE SAMPLING MEETS PERMIT REQUIREMENTS	☑S □M □U □NA □NE
DETAILS:	•
1. SAMPLES TAKEN AT SITE(S) SPECIFIED IN PERMIT:	☑Y □N □NA □NE
2. LOCATIONS ADEQUATE FOR REPRESENTATIVE SAMPLES:	☑Y □N □NA □NE
3. FLOW PROPORTIONED SAMPLES OBTAINED WHEN REQUIRED BY PERMIT:	☑Y □N □NA □NE
4. SAMPLING AND ANALYSES COMPLETED ON PARAMETERS SPECIFIED IN PERMIT:	☑Y □N □NA □NE
5. SAMPLING AND ANALYSES PERFORMED AT FREQUENCY SPECIFIED IN PERMIT:	☑Y □N □NA □NE
6. SAMPLE COLLECTION PROCEDURES ADEQUATE:	☑Y □N □NA □NE
a. SAMPLES REFRIGERATED DURING COMPOSITING:	☑Y □N □NA □NE
b. PROPER PRESERVATION TECHNIQUES USED:	☑Y □N □NA □NE
c. CONTAINERS AND SAMPLE HOLDING TIMES CONFORM TO 40 CFR 136:	☑Y □N □NA □NE
7. IF MONITORING IS PERFORMED MORE OFTEN THAN REQUIRED ARE RESULTS REPORTED ON THE DMR:	□Y □N ☑NA □NE
SECTION E: FLOW MEASUREMENT	
PERMITTEE FLOW MEASUREMENT MEETS PERMIT REQUIREMENTS	☑S □M □U □NA □NE
DETAILS:	•
1. PRIMARY FLOW MEASUREMENT DEVICE PROPERLY INSTALLED AND MAINTAINED: TYPE OF DEVICE: 2 Foot Parsha	all Flume
2. FLOW MEASURED AT EACH OUTFALL AS REQUIRED:	☑Y □N □NA □NE
3. SECONDARY INSTRUMENTS (TOTALIZERS, RECORDERS, ETC.) PROPERLY OPERATED AND MAINTAINED:	☑Y □N □NA □NE
4. CALIBRATION FREQUENCY ADEQUATE:	☑Y □N □NA □NE
5. RECORDS MAINTAINED OF CALIBRATION PROCEDURES:	Øy □n □na □ne
6. CALIBRATION CHECKS DONE TO ASSURE CONTINUED COMPLIANCE:	Øy □n □na □ne
7. FLOW ENTERING DEVICE WELL DISTRIBUTED ACROSS THE CHANNEL AND FREE OF TURBULENCE:	☑Y □N □NA □NE
8. FLOW MEASUREMENT EQUIPMENT ADEQUATE TO HANDLE EXPECTED RANGE OF FLOW RATES:	☑Y □N □NA □NE
9. HEAD MEASURED AT PROPER LOCATION:	☑Y □N □NA □NE
SECTION F: LABORATORY	
PERMITTEE LABORATORY PROCEDURES MEET PERMIT REQUIREMENTS	☑S □M □U □NA □NE
DETAILS:	
1. EPA APPROVED ANALYTICAL PROCEDURES USED (40 CFR 136.3 FOR LIQUIDS, 503.8(B) FOR SLUDGES) :	☑Y □N □NA □NE
2. IF ALTERNATIVE ANALYTICAL PROCEDURES ARE USED, PROPER APPROVAL HAS BEEN OBTAINED:	□Y □N ☑NA □NE
3. SATISFACTORY CALIBRATION AND MAINTENANCE OF INSTRUMENTS AND EQUIPMENT:	☑Y □N □NA □NE
4. QUALITY CONTROL PROCEDURES ADEQUATE:	☑Y □N □NA □NE
5. DUPLICATE SAMPLES ARE ANALYZED ≥10% OF THE TIME:	☑y □n □na □ne
6. SPIKED SAMPLES ARE ANALYZED ≥10% OF THE TIME:	☑Y □N □NA □NE
7. COMMERCIAL LABORATORY USED: For Biominitoring and Sludge Analysis	☑Y □N □NA □NE
a. LAB NAME: ETC of Memphis	
b. LAB ADDRESS: 2790 Whitter Rd. Memphis, Tn 38133	
c. PARAMETERS PERFORMED: Biomonitoring, Sludge analysis for TCLP, Paint Filter LiquidTest, copper	
8. BIOMONITORING PROCEDURES ADEQUATE:	□Y □N □NA ☑NE
a. PROPER ORGANISMS USED:	□Y □N □NA ☑NE
b. PROPER DILUTION SERIES FOLLOWED:	□Y □N □NA ☑NE
c. PROPER TEST METHODS AND DURATION:	□Y □N □NA ☑NE
d. RETESTS AND/OR TRE PERFORMED AS REQUIRED:	□y □n □na ☑ne

ADEQ Water NPDES Inspection	AFIN: 03-00039	Permit #: AR0021211

SECTIO	N G: EFFLUE	NT/RECEIVIN	IG WATERS	OBSERVATION	ONS					
	ON VISUAL OBS					⊠s □m □	lu □na □ne			
	: The discharge				L.					
OUTFALL #:	<u></u>	GREASE	TURBIDITY	VISIBLE FOAM	FLOATING SOLIDS	COLOR	OTHER			
	None	None	None	None	None	Clear	- Cinan			
			110110		110110					
		l	<u> </u>		<u> </u>		<u> </u>			
SECTIO	N H: SLUDGE	DISPOSAL								
	DISPOSAL MEI		REQUIREMEN	TS		⊠s □m □	lu □na □ne			
DETAILS				<u></u>	L_					
	MANAGEMENT ADEQU	IATE TO MAINTAIN EF	FLUENT QUALITY:			⊠s □w	I DU DNA DNE			
2. SLUDGE	RECORDS MAINTAINE	D AS REQUIRED BY 4	0 CFR 503:			□s□w	I □U ☑NA □NE			
3. FOR LAI	ND APPLIED SLUDGE, T	YPE OF LAND APPLIE	D TO: (E.G., FOREST	, AGRICULTURAL, PUI	BLIC CONTACT SITE):_S	ludge is landfilled at	Neighbors LF			
SECTIO	N I: SAMPLIN	G INSPECTION	ON PROCED	URES						
SAMPLE	RESULTS WITH	HIN PERMIT R	EQUIREMENT	S		□s □m □	U ØNA □NE			
DETAILS	:				1					
1. SAMPLE	1. SAMPLES OBTAINED THIS INSPECTION:									
2. TYPE O	SAMPLE: GRAB:_	□COMPOSITE: N	METHOD: FREQUE	ENCY:						
3. SAMPLE	S PRESERVED:					Πλ	′ □n □na ☑ne			
4. FLOW P	ROPORTIONED SAMPLE	S OBTAINED:				Π	′ □N □NA ☑NE			
5. SAMPLE	OBTAINED FROM FACIL	LITY'S SAMPLING DE	VICE:			Y	′ □N □NA ☑NE			
6. SAMPLE	REPRESENTATIVE OF	VOLUME AND NATUR	E OF DISCHARGE:			Y	′ □N □NA ☑NE			
7. SAMPLE	SPLIT WITH PERMITTE	E:					′ □N □NA ☑NE			
8. CHAIN-C	F-CUSTODY PROCEDU	RES EMPLOYED:					′ □n □na ☑ne			
9. SAMPLE	S COLLECTED IN ACCO	RDANCE WITH PERM	IIT:				′ □N □NA ☑NE			
SECTIO	N J: STORM V	NATER POLI	LUTION PRE	VENTION PLA	AN					
STORM	WATER MANAG	EMENT MEET	S PERMIT RE	QUIREMENTS	3	□s □m □	IU ⊠NA □NE			
DETAILS	:									
1. SWPPP	UPDATED AS NEEDED:_	_ DATE OF LAST UP	PDATE:				′ □N □NA ☑NE			
2. SITE MA	P INCLUDING ALL DISC	HARGES AND SURFA	CE WATERS:				' □N □NA ☑NE			
3. POLLUT	ION PREVENTION TEAM	I IDENTIFIED:					' □N □NA ☑NE			
4. POLLUT	ION PREVENTION TEAM	PROPERLY TRAINED	D:				' □N □NA ☑NE			
5. LIST OF	POTENTIAL POLLUTAN	T SOURCES:					' □n □na ☑ne			
6. LIST OF	POTENTIAL SOURCES A	AND PAST SPILLS AN	D LEAKS:				' □N □NA ☑NE			
7. ALL NO	N-STORM WATER DISCH	HARGES ARE AUTHOR	RIZED:				' □N □NA ☑NE			
	STRUCTURAL BMPS:						' □N □NA ☑NE			
	NON-STRUCTURAL BMF						' □N □NA ☑NE			
	ROPERLY OPERATED A						' □N □NA ☑NE			
11. INSPEC	TIONS CONDUCTED AS	REQUIRED:				<u> </u>	['] □N □NA ☑NE			

FLOW CALCULATION SHEET									
D-1 004	4440	Tina a	00						
Date: 02/	11/10	Time: 11:	29						
Head in Inc	hes: 11.37	Feet:	0.94						
	e of Primary Fl shall Flume	ow Measuren	nent D	evice:					
2 FUUL Par	Silali Fiullie								
Name & Mo	odel of Second	lary Flow Mea	surem	ent D	evice:				
Isco Bubb	e Flow meter								
Date of last	: Calibration of	Secondary F	low De	wico:					
2/11/10	. Calibration of	Secondary I	iow De	vice.					
	Flow at Date &	Time Listed A	Above:	4.2	mgd		(Facility Flow Meter)		
	Flow at Date & ted using flow charts				6 mgd surement Handb	ook-5 th	Edition)		
	·								
% Error =	Recorded Va		culated	l Valu	X 100				
	C	alculated Val	ue						
0/ Error —	4.2	-	4.6		X 100				
% Error =		4.6			X 100				
	.4								
% Error =	4.6	X 100							
% Error =	0.086	X 100							
% Error =	8.6	%							
70 LIIOI —	0.0	70							
Comments	Difference	is acceptable	<u>e</u>						

DMR Calculation Check

Reporting Period: From 2010 1 01 To 2010 1 31

Year Month Day Year Month Day

Parameter Checked: CBOD

Loading **Concentration** Mass **Monthly** Mo. Avg. - lbs/day 7-day Avg. - mg/l Mo. Avg. - mg/l **Reported Value:** 58.3 2.77 3.17 58.14 2.77 **Calculated Value:** 3.17 417 **Permit Value:** 15 **10**

If calculated value does not equal reported value, explain: <u>Values are equal</u>

DMR Calculation Check

Reporting Period: From 2010 1 01 To 2010 12 31

Year Month Day Year Month Day

Parameter Checked: TSS

Loading **Concentration** Mass **Monthly** Mo. Avg. - lbs/day Mo. Avg. - mg/l 7-day Avg. - mg/l **Reported Value:** 6.88 143 9.90 **6.8** 9.9 **Calculated Value:** 142.6 23 **Permit Value:** 625.5 **15**

If calculated value does not equal reported value, explain: <u>Values are equal</u>

	Water Division NPDES Photographic Evidence Sheet										
Location:	Location: Mountain Home POTW										
Photographer: Tony L Morris Witness: Terry Sanders											
Photo # 1 Of 4 Date: 02/11/10 Time: 11:26							11:26				
Description:	Description: The har screen in the head works of the plant										



Photograph	er:	Tony L	. Morris	Witness:	Terry Sande	Terry Sanders	
Photo #	2	Of	4	Date:	02/11/10	Time:	11:27

Description: Anoxic tank prior to discharge to oxidation basin.



	Water Division NPDES Photographic Evidence Sheet										
Location:	Location: Mountain Home POTW										
Photograph	Photographer: Tony L. Morris					Terry Sander	Terry Sanders				
Photo #	Photo # 3 Of 4 Date: 02/11/10 Time: 11:53							11:53			
Description: Sludge press building with sludge being discharge						o roll of contain	er to be lan	dfilled.			



Photograph	ner:	Tony L	. Morris	Witness:	Terry Sanders		
Photo #	4	Of	4	Date:	02/11/10	Time:	11:42

Description: Hicks Creek immediately downstream of the plant outfall with clear water.

