

ADEQ

ARKANSAS
Department of Environmental Quality

May 13, 2010

Mr. A.J. Henry, Chairman
City of Walnut Ridge
216 Southwest 4th Street
Walnut Ridge, AR 72476

RE: Recon Inspection

AFIN: 38-00040 NPDES Permit No.: AR0046566

Dear Mr. Henry:

On April 14, 2010, I performed a Recon Inspection of the waste water treatment facility in accordance with the provisions of the Federal Clean Water Act, the Arkansas Water and Air Pollution Control Act, and the regulations promulgated thereunder. This inspection revealed that the facility was out of compliance with the permit. Specifically, I found the following violation:

A review of the Discharge Monitoring Report for February 2010 revealed that the facility exceeded the permit limit for Ammonia Nitrogen (NH₃-N). The Permit limit for Mass Monthly Average for Ammonia Nitrogen is 60 lbs/day. The facility DMR revealed a reading of 70.25 lbs/day. This out of compliance item was reported to the Department in March 2010. The out of compliance item was corrected. There is no need for a further response to the Department concerning this item.

If I can be of any assistance, please contact me at 870-793-5819.

Sincerely,



Mike Kennedy
District 11
Water Division

cc: Water Division Enforcement Branch
 Water Division Permits Branch

