



UNITED STATES ENVIRONMENTAL PROTECTION AGENCY  
Washington, D.C. 20460

# NPDES Compliance Inspection Report

Form Approved  
OMB No. 2040-0003

## Section A: National Data System Coding

Transaction Code	NPDES	Yr/Mo/Day	Inspec. Type	Inspector	Fac. Type
1   N   2   5   3   A   R   0   0   2   0   0   1   0   11   12   1   0   0   8   2   0   17   18   R   19   S   20   1					
Remarks					
Inspection Work Days	Facility Evaluation Rating	BI	QA	-----Reserved-----	
67           69	70   N	71   N	72   N	73           74   75                   80	

## Section B: Facility Data

Name and Location of Facility Inspected ( <i>For industrial users discharging to POTW, also include POTW name and NPDES permit number</i> ) <b>Elkins Water &amp; Sewer Department (discharges to City of Fayetteville POTW)</b> <b>1874 Stokenbury Road</b> <b>Elkins, Arkansas 72727</b> <b>479-643-3131 / 479-879-5869 (cell) / 479-643-3368</b>	Entry Time/Date <b>1:25 p.m./ 8-20-2010</b>	Permit Effective Date <b>June 1, 2006</b>
	Exit Time/Date <b>2:30 p.m./ 8-20-2010</b>	Permit Expiration Date <b>May 31, 2011</b>
Name(s) of On-Site Representative(s)/Title(s)/Phone and Fax Number(s) <b>Jack Ladyman/Mayor of Elkins/479-643-3131</b>	Other Facility Data	
Name, Address of Responsible Official/Title/Phone and Fax Number <b>David Jurgens, P.E., Utilities Department Director</b> <b>City of Fayetteville</b> <b>113 W. Mountain</b> <b>Fayetteville, AR 72701</b>	Contacted Yes <input type="checkbox"/> No <input checked="" type="checkbox"/>	

## Section C: Areas Evaluated During Inspection

(S = Satisfactory, M = Marginal, U = Unsatisfactory, N = Not Evaluated)

N	Permit	N	Flow Measurement	N	Operations & Maintenance	N	Sampling
N	Records/Reports	N	Self-Monitoring Program	N	Sludge Handling/Disposal	N	Pollution Prevention
N	Facility Site Review	N	Compliance Schedules	N	Pretreatment	N	Multimedia
N	Effluent/Receiving Waters	N	Laboratory	N	Storm Water	U	Other: SSO from satellite system

## Section D: Summary of Findings/Comments (Attach additional sheets if necessary)

The City of Elkins has a waste collection system that discharges untreated sewage/waste to the City of Fayetteville POTW and is responsible for the operation and maintenance of the collection system. On August 17, 2010, I received a complaint concerning an overflow from a collection system manhole near Pump Station #2 north of the tributary to the White River. On August 17, 2010, I spoke with Honorable Ladyman in regards to the sanitary sewer overflow. Honorable Ladyman was not aware of the sanitary sewer overflow. I informed Honorable Ladyman raw sewage was entering a tributary of the White River. I informed Honorable Ladyman the area around the manhole and the waste in the tributary need to be properly cleaned up and disposed, the sanitary sewer overflow needs to be reported to the Department and the City of Fayetteville, and I would need a sanitary sewer overflow report. On August 20, 2010, John Fazio, District Field Inspector, and I conducted a follow-up reconnaissance inspection. This inspection revealed that the remediation of the SSO had not been completed. Mr. Fazio and I met with Honorable Ladyman on August 20, 2010, to inform him that the remediation of the SSO had not been completed.

Photographs taken during this inspection are included in the August 17, 2010, inspection. The overflow report from David Turner, Elkins Water and Sewer Superintendent, is attached with this inspection.

Name(s) and Signature(s) of Inspector(s) <b>Alison West/</b>	Agency/Office/Telephone/Fax <b>AR Dept. of Environmental Quality-Fayetteville</b> <b>479-267-0811, ext. 12; 479-267-0819 (fax)</b>	Date <b>October 29, 2010</b>
Signature of Reviewer	Agency/Office/Phone and Fax Numbers	Date

Allison West

Fax 267-0819

On Monday Aug. 16 we came to work and found Pump Station #1 overflowing. On Friday Aug 13 the pump station was working fine. As soon as we found the problem we went to work. We found the control panel did not have no electric. We got our electrician here, he found, in the control panel wires had been pulled and disconnected. We fixed the problem and now we are working on cleanup. We will remove all solids + spread lime in the area. # of gallons 2000

On Tuesday Aug 17, we were told that Pump station #2 had a problem. I was in a workshop with Martin Nett when I got the call. We found the control panel tampered with. The alarm was turned off as well as the pumps. We fixed the problem got the pumps running again. We will pump the water out of the creek back into our system, lime and chadonate the entire area. We have changed locks on all gates, leading into the stations. This should solve the problem. # of gallons 5000

# ADEQ

ARKANSAS  
Department of Environmental Quality

December 16, 2010

David Jurgens, P.E., Utilities Department Director  
City of Fayetteville  
113 West Mountain  
Fayetteville, Arkansas 72701

Re: NPDES Permit No.: AR0020010      AFIN: 72-00781  
Response to SSO Inspection

Dear Mr. Jurgens:

The Department has received your response to the August 17, 20, and 24, 2010 complaint investigation inspections of the above mentioned waste water collection system by our District Field Inspector, Alison West. Your letter appears to adequately address the discrepancies identified during the visits. The Department assumes the corrective actions taken will be maintained to ensure consistent compliance with the requirements of the permit. Acceptance of this response by the Department does not preclude any future enforcement action deemed necessary at this site or any other site.

The Department will keep the inspection and response on file. If future violations occur that require enforcement action, the Department will consider the inspection and response as required by the Pollution Control and Ecology Commission Regulation No. 7, Civil Penalties. This regulation requires the Department to consider the past history of your site and how expeditiously the violations were addressed in determining any civil penalty that may be necessary for any future violations.

If we need further information concerning this matter, we will contact you. Thank you for your attention to this matter. Should you have any questions, feel free to contact me at 501-682-0649 or you may e-mail me at [sawyer@adeq.state.ar.us](mailto:sawyer@adeq.state.ar.us).

Sincerely,



Sam Sawyer  
Enforcement Coordinator  
Water Division Enforcement Branch