

March 2, 2011

Mike Sims, Wastewater Superintendent City of DeQueen P.O. Box 730 DeQueen, AR 71832

AFIN: 67-00023

NPDES Permit No.: AR0021733

Dear Mr. Sims:

On February 16th and 17th, 2011, I performed a routine compliance inspection and a pretreatment compliance inspection of the waste water treatment facility in accordance with the provisions of the Federal Clean Water Act, the Arkansas Water and Air Pollution Control Act, and the regulations promulgated thereunder. This inspection revealed the following violations:

AR0021733

- 1. The laboratory thermometers have not been checked against an NIST thermometer to establish correction values. This needs to be done at least yearly to ensure that temperature sensitive lab equipment is at the temperatures required.
- 2. The TSS oven temperature was noted to be at 107 degrees. This unit should be at 103 degrees.

Pretreatment

No violations of the pretreatment portion of the permit were found during this inspection.

The above items require your immediate attention. Please submit a written response to these findings to Cindy Garner, Water Division Enforcement Branch Manager, of this Department. This response should be mailed to the address below. This response should contain documentation describing the course of action taken to correct each item noted. This corrective action should be completed as soon as possible, and the written response is due by March 12, 2011.

For additional information you may contact the enforcement section by telephone at 501-682-0639 or by fax at 501-682-0910.

City of DeQueen March 2, 2011 Page 2

If I can be of any assistance, please contact me at (870) 389-6970.

Sincerely,

Shan Synch

Shan Lynch District 12 Field Inspector Water Division

cc: Water Division Enforcement Branch Water Division Permits Branch

0)	EPA	Form Approved OMB No. 2040-0003									
	Washington, D.C. 20460 NPDES Compliance Inspection Report										
			-	-		ata System Coding					
1	Transaction Code NPDES Yr/Mo/Day Inspec. Type Inspector Fac. Type 1 N 2 5 3 A R 0 0 2 1 7 3 3 11 12 1 1 0 2 1 6 17 18 C 19 S 20 1										
	Inspection Work Days 67 69	Reserved 80									
						cility Data					
	ne and Location of Facility Inspected and POTW name and NPDES permit			charging to POTW	V, also	o Entry Time/Date	Permit Effective Date				
Cit	y of DeQueen WWTP					0851 / 2-16-2011	March 1, 2008				
at th	ne end of South 9 th St.					Exit Time/Date	Permit Expiration Date				
						1123 / 2-16-2011	February 28, 2013				
	ne(s) of On-Site Representative(s)/T te Sims / Wastewater Superintende			iber(s)		(ther Facility Data				
Nar	ne, Address of Responsible Official/	Title/	Phone and Fax Numb	ber			Major mun.				
Mił	e Sims / Wastewater Superintend	ent / (870) 642-5231			Contacted					
РО	Box 730 Queen, AR 71832					Yes No					
						ted During Inspection Unsatisfactory, N = Not Evaluated)					
S	Permit	S	Flow Measuremen				Sampling				
S	Records/Reports	S	Self-Monitoring F	Program	Ν	Sludge Handling/Disposal N	Pollution Prevention				
S	Facility Site Review	Ν	Compliance Sche	dules	N	Pretreatment N	Multimedia				
S	Effluent/Receiving Waters	M	Laboratory	- f F : 1:/C	S	Storm Water N	Other:				
		Se	cuon D: Summary	of Findings/Com	iments	ts (Attach additional sheets if necessary)					
Sec. F – The laboratory thermometers have not been checked against an NIST thermometer to establish correction values. This needs to be done at least yearly to ensure that temperature sensitive lab equipment is at the temperatures required. Sec. F – The TSS oven temperature was noted to be at 107 degrees. This unit should be at 103 degrees.											
Nai	ne(s) and Signature(s) of Inspector(s	.)		Agency/Office/	Telepł	bhone	Date				
Shan Lynch Shan Lynch				ADEQ / Dist. 7 / (870) 389-6970			February 18, 2011				
Signature of Reviewer Agency/Office/Phone and Fax Numbers Date											

SECTION A: PERMIT VERIFICATION	
PERMIT SATISFACTORILY ADDRESSES OBSERVATIONS	🗹 S 🗆 M 🗇 U 🗆 NA 🗆 NE
DETAILS:	
1. CORRECT NAME AND MAILING ADDRESS OF PERMITTEE:	
2. NOTIFICATION GIVEN TO EPA/STATE OF NEW DIFFERENT OR INCREASED DISCHARGES:	Dy Dn Øna Dne
3. NUMBER AND LOCATION OF DISCHARGE POINTS AS DESCRIBED IN PERMIT:	
4. ALL DISCHARGES ARE PERMITTED:	
SECTION B: RECORDKEEPING AND REPORTING EVALUATION	
RECORDS AND REPORTS MAINTAINED AS REQUIRED BY PERMIT	ØS ØM □U □NA □NE
DETAILS:	
1. ANALYTICAL RESULTS CONSISTENT WITH DATA REPORTED ON DMRS:	
2. SAMPLING AND ANALYSES DATA ADEQUATE AND INCLUDE:	Øs 🗆m 🗇u 🖾na 🖾ne
a. DATES AND TIME(S) OF SAMPLING:	
b. EXACT LOCATION(S) OF SAMPLING:	
c. NAME OF INDIVIDUAL PERFORMING SAMPLING:	
d. ANALYTICAL METHODS AND TECHNIQUES:	
e. RESULTS OF CALIBRATIONS:	
f. RESULTS OF ANALYSES:	
g. DATES AND TIMES OF ANALYSES:	
h. NAME OF PERSON(S) PERFORMING ANALYSES:	
3. LABORATORY EQUIPMENT CALIBRATION AND MAINTENANCE RECORDS ADEQUATE:	Øs 🗆m 🗇u 🖾na 🖾ne
4. PLANT RECORDS INCLUDE SCHEDULES, DATES OF EQUIPMENT MAINTENANCE AND REPAIR:	Øs 🗆m 🗇u 🖾na 🖾ne
5. EFFLUENT LOADINGS CALCULATED USING DAILY EFFLUENT FLOW AND DAILY ANALYTICAL DATA:	
SECTION C: OPERATIONS AND MAINTENANCE	
TREATMENT FACILITY PROPERLY OPERATED AND MAINTAINED	ØS 🗆 M 🗇 🖓 NA 🗆 NE
DETAILS:	
1. TREATMENT UNITS PROPERLY OPERATED:	🗹 s 🗆 m 🗇 u 🖾 na 🖾 ne
2. TREATMENT UNITS PROPERLY MAINTAINED:	🗹 s 🗆 m 🗇 u 🖾 na 🖾 ne
3. STANDBY POWER OR OTHER EQUIVALENT PROVIDED:	🗹 s 🗆 m 🗇 u 🖾 na 🖾 ne
4. ADEQUATE ALARM SYSTEM FOR POWER OR EQUIPMENT FAILURES AVAILABLE:	🗹 s 🗆 m 🗇 u 🖾 na 🖾 ne
5. ALL NEEDED TREATMENT UNITS IN SERVICE:	🗹 s 🗆 m 🗇 u 🖾 na 🖾 ne
6. ADEQUATE NUMBER OF QUALIFIED OPERATORS PROVIDED:	🗹 s 🗆 m 🗇 u 🖾 na 🖾 ne
7. SPARE PARTS AND SUPPLIES INVENTORY MAINTAINED:	Os Om Ou Øna One
8. OPERATION AND MAINTENANCE MANUAL AVAILABLE:	
9. STANDARD OPERATING PROCEDURES AND SCHEDULES ESTABLISHED:	
10. PROCEDURES FOR EMERGENCY TREATMENT CONTROL ESTABLISHED:	
11. HAVE BYPASSES/OVERFLOWS OCCURRED AT THE PLANT OR IN THE COLLECTION SYSTEM IN THE LAST YEAR:	
12. IF SO, HAS THE REGULATORY AGENCY BEEN NOTIFIED:	
13. HAS CORRECTIVE ACTION BEEN TAKEN TO PREVENT ADDITIONAL BYPASSES/OVERFLOWS:	
14. HAVE ANY HYDRAULIC OVERLOADS OCCURRED AT THE TREATMENT PLANT:	
15. IF SO, DID PERMIT VIOLATIONS OCCUR AS A RESULT:	

SECTION D: SAMPLING								
PERMITTEE SAMPLING MEETS PERMIT REQUIREMENTS								
DETAILS:								
1. SAMPLES TAKEN AT SITE(S) SPECIFIED IN PERMIT:	Øy 🗆n 🗆na 🗇ne							
2. LOCATIONS ADEQUATE FOR REPRESENTATIVE SAMPLES:	Øy 🗆n 🗆na 🗇ne							
3. FLOW PROPORTIONED SAMPLES OBTAINED WHEN REQUIRED BY PERMIT:	Øy 🗆n 🗆na 🗇ne							
4. SAMPLING AND ANALYSES COMPLETED ON PARAMETERS SPECIFIED IN PERMIT:	Øy 🗆n 🗆na 🗆ne							
5. SAMPLING AND ANALYSES PERFORMED AT FREQUENCY SPECIFIED IN PERMIT:	Øy 🗆n 🗆na 🗆ne							
6. SAMPLE COLLECTION PROCEDURES ADEQUATE:	Øy 🛛n 🖾na 🖾ne							
a. SAMPLES REFRIGERATED DURING COMPOSITING:	🗹 y 🗆 n 🗆 na 🗆 ne							
b. PROPER PRESERVATION TECHNIQUES USED:	🗹 y 🗆 n 🗆 na 🗆 ne							
c. CONTAINERS AND SAMPLE HOLDING TIMES CONFORM TO 40 CFR 136:	Øy 🗆n 🗆na 🗆ne							
7. IF MONITORING IS PERFORMED MORE OFTEN THAN REQUIRED ARE RESULTS REPORTED ON THE DMR:								
SECTION E: FLOW MEASUREMENT								
PERMITTEE FLOW MEASUREMENT MEETS PERMIT REQUIREMENTS								
DETAILS:								
1. PRIMARY FLOW MEASUREMENT DEVICE PROPERLY INSTALLED AND MAINTAINED: TYPE OF DEVICE: parshall flume								
2. FLOW MEASURED AT EACH OUTFALL AS REQUIRED:								
3. SECONDARY INSTRUMENTS (TOTALIZERS, RECORDERS, ETC.) PROPERLY OPERATED AND MAINTAINED:								
4. CALIBRATION FREQUENCY ADEQUATE: November 5, 2008								
5. RECORDS MAINTAINED OF CALIBRATION PROCEDURES:								
6. CALIBRATION CHECKS DONE TO ASSURE CONTINUED COMPLIANCE:								
7. FLOW ENTERING DEVICE WELL DISTRIBUTED ACROSS THE CHANNEL AND FREE OF TURBULENCE:								
8. FLOW MEASUREMENT EQUIPMENT ADEQUATE TO HANDLE EXPECTED RANGE OF FLOW RATES:								
9. HEAD MEASURED AT PROPER LOCATION:	Øy 🛛n 🖓na 🖓ne							
SECTION F: LABORATORY								
PERMITTEE LABORATORY PROCEDURES MEET PERMIT REQUIREMENTS	OS ØM OU ONA ONE							
DETAILS:								
1. EPA APPROVED ANALYTICAL PROCEDURES USED (40 CFR 136.3 FOR LIQUIDS, 503.8(B) FOR SLUDGES) :	Øy 🛛n 🖓na 🖓ne							
2. IF ALTERNATIVE ANALYTICAL PROCEDURES ARE USED, PROPER APPROVAL HAS BEEN OBTAINED:								
3. SATISFACTORY CALIBRATION AND MAINTENANCE OF INSTRUMENTS AND EQUIPMENT:								
4. QUALITY CONTROL PROCEDURES ADEQUATE:	Øy 🛛n 🖓na 🖓ne							
5. DUPLICATE SAMPLES ARE ANALYZED >10% OF THE TIME:	Øy 🛛n 🖓na 🖓ne							
6. SPIKED SAMPLES ARE ANALYZED >10% OF THE TIME:								
7. COMMERCIAL LABORATORY USED:								
a. LAB NAME: <u>Arkansas Analytical, Inc.</u>								
b. LAB ADDRESS: <u>11701 I-30; Building 1, Ste. 115; Little Rock, AR 72209</u>								
c. PARAMETERS PERFORMED: <u>NH3-N, Phosphorus, biomonitoring</u>								
8. BIOMONITORING PROCEDURES ADEQUATE:								
a. PROPER ORGANISMS USED:								
b. PROPER DILUTION SERIES FOLLOWED:								
c. PROPER TEST METHODS AND DURATION:								
d. RETESTS AND/OR TRE PERFORMED AS REQUIRED:								

ADEQ Water NPDES Inspection

SECTION G: EFFLUENT/RECEIVING WATERS OBSERVATIONS														
BASED ON VISUAL OBSERVATIONS ONLY														
DE	DETAILS:													
OU	TFALL #:	OIL SHEEN	DIL SHEEN GREASE TURBIDITY VISIBLE FOAM FLOATING SOLIDS COLD						OTHER					
	001	none	none	none	none	none	clea	ır	NA					
SECTION H: SLUDGE DISPOSAL														
SLUDGE DISPOSAL MEETS PERMIT REQUIREMENTS														
DE														
1.	SLUDGE M	ANAGEMENT ADEQU	ATE TO MAINTAIN EF	FLUENT QUALITY:				ls □m	DU 🗹 NA DNE					
2.	SLUDGE R	ECORDS MAINTAINED	D AS REQUIRED BY 40) CFR 503:				ls □m						
3.	FOR LAND	APPLIED SLUDGE, TY	YPE OF LAND APPLIEI	D TO: (E.G., FOREST,	AGRICULTURAL, PUE	BLIC CONTACT SITE):								
SE	CTION	I: SAMPLIN	G INSPECTIO	ON PROCEDI	JRES									
SA	MPLE R	ESULTS WITH	HIN PERMIT R	EQUIREMENT	S]M □(J ⊠NA □NE					
DE	TAILS:													
1.	SAMPLES	OBTAINED THIS INSPI	ECTION:					ΠY	□n Øna □ne					
2.	TYPE OF S	AMPLE: GRAB:		IETHOD: FREQUE	NCY:									
3.	SAMPLES F	PRESERVED:						ΠY	□n Øna □ne					
4.	FLOW PRO	PORTIONED SAMPLE	S OBTAINED:					ΠY	□n Øna □ne					
5.														
6.	SAMPLE R	EPRESENTATIVE OF	VOLUME AND NATUR	E OF DISCHARGE:				ΠY	□n Øna □ne					
7.	SAMPLE SP	PLIT WITH PERMITTEI	E:					ΠY	🗆 n 🗹 na 🗆 ne					
8.	CHAIN-OF-	CUSTODY PROCEDU	RES EMPLOYED:					ΠY	□n Øna □ne					
9.														
SE	CTION	J: STORM W	WATER POLL	UTION PREV	VENTION PL	AN								
ST	ORM W	ATER MANAG	EMENT MEET	S PERMIT RE	QUIREMENTS	5	🗆 s 🗆]M 🗆 (J ⊠NA □NE					
DE	TAILS:	* No Exposure	Certification let	ter from ADEQ	at facility									
1.	SWPPP UP	DATED AS NEEDED:	DATE OF LAST UP	DATE:				ΠY	🗆 n 🗹 na 🗆 ne					
2.	SITE MAP I	NCLUDING ALL DISCH	HARGES AND SURFAC	CE WATERS:				ΠY	🗆 n 🗹 na 🗆 ne					
3.	B. POLLUTION PREVENTION TEAM IDENTIFIED:													
4.	I. POLLUTION PREVENTION TEAM PROPERLY TRAINED:													
5.	5. LIST OF POTENTIAL POLLUTANT SOURCES:													
6.	6. LIST OF POTENTIAL SOURCES AND PAST SPILLS AND LEAKS:													
7. ALL NON-STORM WATER DISCHARGES ARE AUTHORIZED:									⊡n Øna ⊡ne					
8.	8. LIST OF STRUCTURAL BMPS:													
9.	LIST OF NO	ON-STRUCTURAL BMF	PS:					ΠY						
10.	BMPS PRO	PERLY OPERATED AI	ND MAINTAINED:					ΠY	□n Øna □ne					
11.	INSPECTIC	NS CONDUCTED AS	REQUIRED:					ΠY	⊡n Øna ⊡ne					

FLOW CALCULATION SHEET											
Date: 2-16-2011 Time: 1014											
Head in Inches: 13 Feet: 1.08											
Type & Siz	e of Primary Flow	v Measurer	nent Devid	ce: 12" par	shall flu	ıme					
Name & M	odel of Secondar		suramant		Indross	& Hauser					
		y i low wice									
Date of last	Calibration of Se	econdary F	low Devic	e: Novemb	oer 5, 20	11					
						Ι					
Recorded F	Flow at Date & Ti	me Listed /	Above: 2	.81 mgd		(Facility Flow Meter)					
Calculated	Flow at Date & T	imo Listod	Above:	2.906 mgd							
	ted using flow charts in:					Edition)					
``	¥										
% Error =	Recorded Valu		culated Va	alue X 10	0						
/0 21101 =	Calo	culated Val	ue		•						
	2.81		2.906								
% Error =	2.01	2.906	2.900	— X 10	0						
		2.000									
0/ Error	-0.096	V 100									
% Error =	2.906	X 100									
% Error =	-0.033	X 100									
% Error =	-3.3	%									
Comments:											

ADEQ Water NPDES	AFI	AFIN: 67-00023 Permit #: AR0021733								
DMR Calculation Check										
Reporting Period:	From	10	11	01	То	10	11	30		
		Year	Month	Day		Year	Month	Day		
Parameter Checked	:	TSS	_							
Loading Mass					Concentration Monthly					
Mo. Avg lbs/day					Mo. Avg mg/l 7-day Av			g mg/l		
Reported Value:		92.7			5.8		8.3			
Calculated Value:	:92.7			5.8		8.3				
Permit Value:	500.4			15		22.:	5			

If calculated value does not equal reported value, explain: <u>same</u>

Arkansas Department of Environmental Quality 5301 Northshore Drive North Little Rock, AR 72118

March 9, 2011

WATER DIVISION NPDES Enforcement Section Cindy Garner

RE: City of De Queen Wastewater Plant, NPDES Permit, AR0021733

Michael Sims City of De Queen Wastewater Superintendent PO Box 730 De Queen AR 71832



March 2, 2011

Mike Sims, Wastewater Superintendent City of DeQueen P.O. Box 730 DeQueen, AR 71832

AFIN: 67-00023

NPDES Permit No.: AR0021733

Dear Mr. Sims:

On February 16th and 17th, 2011, I performed a routine compliance inspection and a pretreatment compliance inspection of the waste water treatment facility in accordance with the provisions of the Federal Clean Water Act, the Arkansas Water and Air Pollution Control Act, and the regulations promulgated thereunder. This inspection revealed the following violations:

AR0021733

- 1. The laboratory thermometers have not been checked against an NIST thermometer to establish correction values. This needs to be done at least yearly to ensure that temperature sensitive lab equipment is at the temperatures required.
- 2. The TSS oven temperature was noted to be at 107 degrees. This unit should be at 103 degrees.

Pretreatment

No violations of the pretreatment portion of the permit were found during this inspection.

The above items require your immediate attention. Please submit a written response to these findings to Cindy Garner, Water Division Enforcement Branch Manager, of this Department. This response should be mailed to the address below. This response should contain documentation describing the course of action taken to correct each item noted. This corrective action should be completed as soon as possible, and the written response is due by March 12, 2011.

For additional information you may contact the enforcement section by telephone at 501-682-0639 or by fax at 501-682-0910.

City of DeQueen March 2, 2011 Page 2

If I can be of any assistance, please contact me at (870) 389-6970.

Sincerely,

Shan Synih

Shan Lynch District 12 Field Inspector Water Division

cc: Water Division Enforcement Branch Water Division Permits Branch



BILLY RAY McKELVY MAYOR DONNA J. JONES CITY CLERK/TREASURE

CITY OF DE QUEEN (870) 584-3445

March 9, 2011

Cindy Garner Water Division Enforcement Branch Manager ADEQ 5301 Northshore Dr. Little Rock Ar. 72118-5317

RE: NPDES No. AR0021733 City of De Queen compliance inspection Feb. 16-17 2011 violation response.

Dear Mrs. Garner:

The laboratory thermometers used at the De Queen Wastewater Plant were checked with a NIST thermometer on Feb. 18 2011 and will be set up on an annual workorder hereafter.

The TSS oven was turned down to 103 degrees on Feb 18 2011.


If you have any questions please call me at 870-642-5231.

Sincerely;

Mhal Sna

Michael Sims City of De Queen Wastewater Manager PO Box 730 De Queen AR 71832

P.O. BOX 730 • DE QUEEN, ARKANSAS 71832 • PHONE (870) 584-3445 • FAX (870) 642-3117 • E MAIL bmckelvy@dequeen-ar.us





FP NPDES Enforcement Section 5301 North shore Dr. North Little Roch Ap. 72118-5317