



A R K A N S A S  
Department of Environmental Quality

June 22, 2011

James Sanders, Mayor  
City of Blytheville  
P.O. Box 1784  
Blytheville, AR 72315

RE: Pretreatment Compliance Inspection

RE: AFIN: 47-00544

NPDES Permit No.: AR0022560

Dear Mr. Sanders:

On May 26, 2011, fellow inspector Michael Greenway and I performed a routine pretreatment compliance inspection of the waste water treatment facility in accordance with the provisions of the Federal Clean Water Act, the Arkansas Water and Air Pollution Control Act, and the regulations promulgated thereunder. This inspection revealed the following violations:

1. During the course of the PCI, it was discovered that the City of Blytheville does not have adequate data or **BMRs** for Aviation Repair Technologies which has the potential to cause a significant impact **and/or** damage to the collection system and POTW. The City of Blytheville should review current procedures for updating the Industrial User Survey and make appropriate modifications to ensure that adequate information is collected and maintained on all new and existing **IUs**.
2. Kagome Creative Foods has removed previously installed **O&G** (oil and grease) removal equipment, yet is continuing to operate at least two **production/packaging** lines.
3. **Omnium** was not sampled for **O&G**, Total Cyanide, TSS, pH, & **BOD5** as required by their permit.
4. Kagome Creative Foods has not been published in the newspaper as a Significant Violator for their discharge of peanut butter to the West WWTP (**O&G** Violations).


James Sanders, Pretreatment Inspection  
June 22, 2011  
Page 2

The above items require your immediate attention. Please submit a written response to these findings to Water Division Enforcement Branch of this Department. This response should be mailed to the address below and should contain documentation describing the course of action taken to correct each item noted. This corrective action should be completed as soon as possible, and the written response is due by **July 2, 2011**.

For additional information you may contact the Enforcement Branch by telephone at 501-682-0639 or by fax at 501-682-0910.

If I can be of any assistance, please contact me at [walker@adeq.state.ar.us](mailto:walker@adeq.state.ar.us) or 870-935-7221 ext.-12.

Sincerely,



Brent L. Walker  
District 3 Field Inspector  
Water Division

cc: Water Division Enforcement Branch  
Water Division Permits Branch



Form Approved  
OMB No. 2040-0003

UNITED STATES ENVIRONMENTAL PROTECTION AGENCY  
Washington, D.C. 20460

## NPDES Compliance Inspection Report

### Section A: National Data System Coding

Transaction Code			NPDES										Yr/Mo/Day				Inspec. Type		Inspector		Fac. Type								
1	N	2	5	3	A	R	0	0	2	2	5	6	0	11	12	1	1	0	5	2	6	17	18	I	19	S	20	2	
Remarks																													
0						0						5						C											
Inspection Work Days						Facility Evaluation Rating						BI		QA		-----Reserved-----													
67						70						N		71		N		72		N		73		74		75		80	

### Section B: Facility Data

Name and Location of Facility Inspected ( <i>For industrial users discharging to POTW, also include POTW name and NPDES permit number</i> ) <b>Advance Industries IU of Blytheville – AR0022560</b> <b>1000 N. Broadway</b> <b>Blytheville, AR</b> <b>Mississippi Co.</b>	Entry Time/Date <b>1400 5/26/2011</b>	Permit Effective Date <b>December 1, 2005</b>
	Exit Time/Date <b>1410 5/26/2011</b>	Permit Expiration Date <b>November 30, 2010</b>
Name(s) of On-Site Representative(s)/Title(s)/Phone and Fax Number(s) <b>None</b>	Other Facility Data	
Name, Address of Responsible Official/Title/Phone and Fax Number <b>Gordon Caffey/Owner/870-763-4343</b> <b>Advance Industries</b> <b>P.O. Box 922</b> <b>Blytheville, AR 72315</b>	Contacted Yes <input type="checkbox"/> No <input checked="" type="checkbox"/>	

### Section C: Areas Evaluated During Inspection

(S = Satisfactory, M = Marginal, U = Unsatisfactory, N = Not Evaluated)

Permit	Flow Measurement	Operations & Maintenance	Sampling
Records/Reports	Self-Monitoring Program	Sludge Handling/Disposal	Pollution Prevention
Facility Site Review	Compliance Schedules	Pretreatment	Multimedia
Effluent/Receiving Waters	Laboratory	Storm Water	Other:

### Section D: Summary of Findings/Comments (Attach additional sheets if necessary)

\*\*\*See the attached IU Site Visit form and the PCI Inspection Report from this date for additional information\*\*\*

Name(s) and Signature(s) of Inspector(s) <b>Brent L. Walker</b> <i>Brent L. Walker</i> <b>Michael B. Greenway</b>	Agency/Office/Telephone/Fax <b>AR Dept. of Environmental Quality-Jonesboro</b> <b>(870) 935-7221 ext. 12/(870) 935-4715 (Fax)</b>	Date <b>May 27, 2011</b>
Signature of Reviewer	Agency/Office/Phone and Fax Numbers	Date

**Industrial User Site Visit**

Name of Industry: Advance Industries

Industry Contacts: Gerald Lloyd – Maintenance (Not contacted this visit)

Type of Industry: Industrial Laundry

Date of Visit: May 26, 2011

- |   |            |     |            |    |            |     |
|---|------------|-----|------------|----|------------|-----|
| 1. Significant industrial user?                       | <u> X </u> | Yes | <u> </u>   | No | <u> </u>   | N/A |
| 2. Pretreatment equipment or procedures?              | <u> X </u> | Yes | <u> </u>   | No | <u> </u>   | N/A |
| 3. Pretreatment equipment maintained and operational? | <u> X </u> | Yes | <u> </u>   | No | <u> </u>   | N/A |
| 4. Hazardous waste generated or stored?               | <u> </u>   | Yes | <u> X </u> | No | <u> </u>   | N/A |
| 5. Proper solid waste disposal?                       | <u> X </u> | Yes | <u> </u>   | No | <u> </u>   | N/A |
| 6. Solvent management/TTO control?                    | <u> </u>   | Yes | <u> </u>   | No | <u> X </u> | N/A |
| 7. Suitable sampling location?                        | <u> X </u> | Yes | <u> </u>   | No | <u> </u>   | N/A |
| 8. Appropriate self-monitoring procedures/equipment?  | <u> </u>   | Yes | <u> </u>   | No | <u> X </u> | N/A |
| 9. Adequate spill prevention?                         | <u> X </u> | Yes | <u> </u>   | No | <u> </u>   | N/A |
| 10. Industry familiar with limits and requirements?   | <u> X </u> | Yes | <u> </u>   | No | <u> </u>   | N/A |

**Additional Comments:**

IU visit was conducted to verify that pretreatment equipment was being properly maintained. Facility has a history of equipment being out of service. At the time of this visit it appeared that the pretreatment equipment was operational – it was not in use at the time of the visit as laundry was not being done on this day. There was a large amount of lint on the surface of the ground under an exhaust vent.

Visit Conducted by: Brent L. Walker *Brent L. Walker* & Michael B. Greenway Date: 5/27/2011