

June 7, 2013

Ms. Kathryn Catlin, Plant Superintendent City of Harrison Wastewater Treatment Facility P.O. Box 1715 Harrison, AR 72602

RE: City of Harrison Wastewater Treatment Facility (Boone Co)
AFIN: 05-00054 NPDES Permit No. AR0034321

Dear Ms. Catlin:

On April 26, 2013, I performed a Compliance Evaluation Inspection (CEI) and a Sanitary Sewer Overflow (SSO) Inspection of the above referenced facility in accordance with the provisions of the Federal Clean Water Act, the Arkansas Water and Air Pollution Control Act, and the regulations promulgated thereunder. These inspections revealed that you were in compliance with the terms of the referenced permit.

If I can be of any assistance, please contact me at (870) 446-6170 or by e-mail at Kirkpatrick@adeq.state.ar.us.

Sincerely,

Bruce Kirkpatrick, P.E. District 2 Field Inspector

Buce Repaired

Water Division

<b>⊕</b> EPA	Form Approved OMB No. 2040-0003							
INITED STATES ENVIRONM								
Washingto	MENTAL PROTECTION AGENCY on, D.C. 20460	D 4						
NPDES Compliand	e Inspection	Report						
· · · · · · · · · · · · · · · · · · ·	Section A: National Data S		Inspec. Type Inspector Fac. Type					
1 N 2 5 3 A R 0 0 3 4 3	Transaction Code							
A F I N 0 5 - 0 0 0	Remarks 5 4	<u> </u>						
Inspection Work Days Facility Evaluation I	1 1	QA I I I I I	Reserved					
67 69 70 5	71 <b>N</b> 72	N 73 74 75	80					
	Section B: Facility	Data						
Name and Location of Facility Inspected (For industrial users dis include POTW name and NPDES permit number)	charging to POTW, also	Entry Time/Date <b>0755 / 4-26-2013</b>	Permit Effective Date October 1, 2007					
City of Harrison Wastewater Treatment Plant 1508 Silver Valley Road Harrison, Arkansas Section 2, T18N, R20W	in Boone County	Exit Time/Date 1102 / 4-26-2013	Permit Expiration Date September 30, 2012 (extended)					
Name(s) of On-Site Representative(s)/Title(s)/Phone and Fax Num Mr. Mike Crow / Plant Foreman / Phone 870-741-2528			Other Facility Data					
Ms. Kathryn Catlin / Wastewater Superintendent / Phone: 8	70-741-5527	T						
Name, Address of Responsible Official/Title/Phone and Fax Num Ms. Kathryn Catlin / Wastewater Superintendent / Phone: 8 City of Harrison P.O. Box 1715 Harrison, AR 72602		Contacted Yes ✓ No □						
Yes L. No L.								
	ction C: Areas Evaluated D ry, M = Marginal, U = Unsat	uring Inspection isfactory, N = Not Evaluated)						
S Permit S Flow Measureme	ent S Op	erations & Maintenance	S Sampling					
S Records/Reports S Self-Monitoring	Program S Sh	dge Handling/Disposal	N Pollution Prevention					
S Facility Site Review S Compliance Scho	<del>                                     </del>	etreatment	N Multimedia					
S Effluent/Receiving Waters S Laboratory		orm Water tach additional sheets if necessary	N Other: SSO					
During the course of the inspection, Discharge Monitoring Reports for the most recent twelve months were reviewed. No permit effluent violations were reported during this period. Overall, the facility was found to be clean, well-maintained and in good working condition at the time of inspection. Facility is now sampling and analyzing effluent for Sulfates, TDS and Chlorides at the request of the ADEQ.								
Name(s) and Signature(s) of Inspector(s)  Agency/Office/Telephone/Fax  Date								
Bruce Kirkpatrick Cauc Republic	tal Quality-Jasper / FAX# (870) 446-2181	June 5, 2013						
ътисе кігкрантіск	1 11ONE# (0/0) 440-01/0	/ ΕΑΑπ (0/0) <del>11</del> 0-2101	June 3, 2013					
Signature of Reviewer  Kerri McCabe  Kerri McCabe	Date <b>June 6, 2013</b>							

ADEQ Water NPDES Inspection AFIN: <b>05-00054</b> Permit #: <b>A</b>	AR0034321
SECTION A: PERMIT VERIFICATION	
PERMIT SATISFACTORILY ADDRESSES OBSERVATIONS	⊠s □m □u □na □n
DETAILS:	
1. CORRECT NAME AND MAILING ADDRESS OF PERMITTEE:	Øy □n □na □n
2. NOTIFICATION GIVEN TO EPA/STATE OF NEW DIFFERENT OR INCREASED DISCHARGES:	□Y ØN □NA □N
3. NUMBER AND LOCATION OF DISCHARGE POINTS AS DESCRIBED IN PERMIT:	☑Y □N □NA □N
4. ALL DISCHARGES ARE PERMITTED:	☑y □n □na □n
SECTION B: RECORDKEEPING AND REPORTING EVALUATION	
RECORDS AND REPORTS MAINTAINED AS REQUIRED BY PERMIT	☐ ☑S ☐M ☐U ☐NA ☐N
DETAILS:	
1. ANALYTICAL RESULTS CONSISTENT WITH DATA REPORTED ON DMRS:	☑Y □N □NA □N
2. SAMPLING AND ANALYSES DATA ADEQUATE AND INCLUDE:	⊠s □m □u □na □n
a. DATES AND TIME(S) OF SAMPLING:	☑Y □N □NA □N
b. EXACT LOCATION(S) OF SAMPLING:	☑Y □N □NA □N
c. NAME OF INDIVIDUAL PERFORMING SAMPLING:	☑Y □N □NA □N
d. ANALYTICAL METHODS AND TECHNIQUES:	☑Y □N □NA □N
e. RESULTS OF CALIBRATIONS:	☑Y □N □NA □N
f. RESULTS OF ANALYSES:	☑y □n □na □n
g. DATES AND TIMES OF ANALYSES:	☑Y □N □NA □N
h. NAME OF PERSON(S) PERFORMING ANALYSES:	☑Y □N □NA □N
3. LABORATORY EQUIPMENT CALIBRATION AND MAINTENANCE RECORDS ADEQUATE:	Øs □m □u □na □n
4. PLANT RECORDS INCLUDE SCHEDULES, DATES OF EQUIPMENT MAINTENANCE AND REPAIR:	⊠S □M □U □NA □N
5. EFFLUENT LOADINGS CALCULATED USING DAILY EFFLUENT FLOW AND DAILY ANALYTICAL DATA:	☑Y □N □NA □N
SECTION C: OPERATIONS AND MAINTENANCE	
TREATMENT FACILITY PROPERLY OPERATED AND MAINTAINED	☑S □M □U □NA □N
DETAILS: Anticipated bypass for four hours which did not violate effluent limits occur	
outage required for digester construction activities. Generator used to operate UV d	
1. TREATMENT UNITS PROPERLY OPERATED:	ØS OM OU ONA ON
2. TREATMENT UNITS PROPERLY MAINTAINED:	
3. STANDBY POWER OR OTHER EQUIVALENT PROVIDED:	Øs □m □u □na □n
4. ADEQUATE ALARM SYSTEM FOR POWER OR EQUIPMENT FAILURES AVAILABLE:	ØS □M □U □NA □N
5. ALL NEEDED TREATMENT UNITS IN SERVICE:	ØS □M □U □NA □N
6. ADEQUATE NUMBER OF QUALIFIED OPERATORS PROVIDED:	⊠S □M □U □NA □N
7. SPARE PARTS AND SUPPLIES INVENTORY MAINTAINED:	Øs □m □u □na □n
8. OPERATION AND MAINTENANCE MANUAL AVAILABLE:	☑Y □N □NA □N
9. STANDARD OPERATING PROCEDURES AND SCHEDULES ESTABLISHED:	☑y □n □na □n
10. PROCEDURES FOR EMERGENCY TREATMENT CONTROL ESTABLISHED:	☑Y □N □NA □N
11. HAVE BYPASSES/OVERFLOWS OCCURRED AT THE PLANT OR IN THE COLLECTION SYSTEM IN THE LAST YEAR:	☑Y □N □NA □N
12. IF SO, HAS THE REGULATORY AGENCY BEEN NOTIFIED:	☑Y □N □NA □N
13. HAS CORRECTIVE ACTION BEEN TAKEN TO PREVENT ADDITIONAL BYPASSES/OVERFLOWS:	☑Y □N □NA □N

14. HAVE ANY HYDRAULIC OVERLOADS OCCURRED AT THE TREATMENT PLANT:

15. IF SO, DID PERMIT VIOLATIONS OCCUR AS A RESULT:

□Y ☑N □NA □NE

□Y □N ☑NA □NE

ADEQ Water NPDES Inspection	AFIN: <b>05-00054</b>	Permit #: AR0034321

SECTION D: SAMPLING	
PERMITTEE SAMPLING MEETS PERMIT REQUIREMENTS	☑S □M □U □NA □NE
DETAILS:	·
SAMPLES TAKEN AT SITE(S) SPECIFIED IN PERMIT:	☑Y □N □NA □NE
2. LOCATIONS ADEQUATE FOR REPRESENTATIVE SAMPLES:	☑Y □N □NA □NE
3. FLOW PROPORTIONED SAMPLES OBTAINED WHEN REQUIRED BY PERMIT:	☑Y □N □NA □NE
4. SAMPLING AND ANALYSES COMPLETED ON PARAMETERS SPECIFIED IN PERMIT:	☑Y □N □NA □NE
5. SAMPLING AND ANALYSES PERFORMED AT FREQUENCY SPECIFIED IN PERMIT:	☑Y □N □NA □NE
6. SAMPLE COLLECTION PROCEDURES ADEQUATE:	☑Y □N □NA □NE
a. SAMPLES REFRIGERATED DURING COMPOSITING:	☑Y □N □NA □NE
b. PROPER PRESERVATION TECHNIQUES USED:	☑Y □N □NA □NE
c. CONTAINERS AND SAMPLE HOLDING TIMES CONFORM TO 40 CFR 136:	☑Y □N □NA □NE
7. IF MONITORING IS PERFORMED MORE OFTEN THAN REQUIRED ARE RESULTS REPORTED ON THE DMR:	□y □n ☑na □ne
SECTION E: FLOW MEASUREMENT	
PERMITTEE FLOW MEASUREMENT MEETS PERMIT REQUIREMENTS	☑S ☐M ☐U ☐NA ☐NE
DETAILS:	
1. PRIMARY FLOW MEASUREMENT DEVICE PROPERLY INSTALLED AND MAINTAINED: TYPE OF DEVICE: 18" PARSHAI	LL FLUME Y N NA NE
2. FLOW MEASURED AT EACH OUTFALL AS REQUIRED:	☑Y □N □NA □NE
3. SECONDARY INSTRUMENTS (TOTALIZERS, RECORDERS, ETC.) PROPERLY OPERATED AND MAINTAINED:	☑Y □N □NA □NE
4. CALIBRATION FREQUENCY ADEQUATE:	☑Y □N □NA □NE
5. RECORDS MAINTAINED OF CALIBRATION PROCEDURES:	☑Y □N □NA □NE
6. CALIBRATION CHECKS DONE TO ASSURE CONTINUED COMPLIANCE:	☑Y ☐N ☐NA ☐NE
7. FLOW ENTERING DEVICE WELL DISTRIBUTED ACROSS THE CHANNEL AND FREE OF TURBULENCE:	☑Y □N □NA □NE
8. FLOW MEASUREMENT EQUIPMENT ADEQUATE TO HANDLE EXPECTED RANGE OF FLOW RATES:	☑Y □N □NA □NE
9. HEAD MEASURED AT PROPER LOCATION:	☑Y □N □NA □NE
SECTION F: LABORATORY	
PERMITTEE LABORATORY PROCEDURES MEET PERMIT REQUIREMENTS	☑S ☐M ☐U ☐NA ☐NE
DETAILS:	
1. EPA APPROVED ANALYTICAL PROCEDURES USED (40 CFR 136.3 FOR LIQUIDS, 503.8(B) FOR SLUDGES) :	☑Y □N □NA □NE
2. IF ALTERNATIVE ANALYTICAL PROCEDURES ARE USED, PROPER APPROVAL HAS BEEN OBTAINED:	□y □n ☑na □ne
3. SATISFACTORY CALIBRATION AND MAINTENANCE OF INSTRUMENTS AND EQUIPMENT:	Øy □n □na □ne
4. QUALITY CONTROL PROCEDURES ADEQUATE:	☑Y □N □NA □NE
5. DUPLICATE SAMPLES ARE ANALYZED ≥10% OF THE TIME:	☑Y □N □NA □NE
6. SPIKED SAMPLES ARE ANALYZED ≥10% OF THE TIME:	☑Y □N □NA □NE
7. COMMERCIAL LABORATORY USED:	☑Y □N □NA □NE
a. LAB NAME: <u>ETC</u>	
b. LAB ADDRESS: 2924 Walnut Grove Road, Memphis, TN 38111	
c. PARAMETERS PERFORMED: biomonitoring	
8. BIOMONITORING PROCEDURES ADEQUATE:	□Y □N □NA ☑NE
a. PROPER ORGANISMS USED:	□Y □N □NA ☑NE
b. PROPER DILUTION SERIES FOLLOWED:	□y □n □na ☑ne
c. PROPER TEST METHODS AND DURATION:	□Y □N □NA ☑NE
d. RETESTS AND/OR TRE PERFORMED AS REQUIRED:	□Y □N □NA ☑NE

Α	DEQ Water NPDES Inspection	AFIN: <b>05-00054</b>	Permit #: AR0034321

SECTION G: EFFLUENT/RECEIVING WATERS OBSERVATIONS									
BASED ON VISUAL OBSERVATIONS ONLY									
DETAILS: Foam was observed at Outfall 001 in Crooked Creek but was not persistent downstream.									
OUTFALL #:									
001	none	none	none	slight	none	clear			
				3					
					1	1			
SECTION	H: SLUDGE	DISPOSAL							
	DISPOSAL ME		REQUIREMEN	TS		<b>М</b> ѕ □м □	lu □na □ne		
DETAILS:				<u>.                                      </u>					
	MANAGEMENT ADEQU	ATE TO MAINTAIN EF	FLUENT QUALITY:			⊠s□w	I DU DNA DNE		
2. SLUDGE R	ECORDS MAINTAINED	O AS REQUIRED BY 40	) CFR 503:				I □U □NA ☑NE		
3. FOR LAND	APPLIED SLUDGE, TY	PE OF LAND APPLIE	D TO: Agricultural (E.	G., FOREST, AGRICU	LTURAL, PUBLIC CONTA				
			<del>_</del>			·			
SECTION	II: SAMPLIN	G INSPECTION	ON PROCEDI	JRES					
	RESULTS WITH				T	□ѕ□м□	U ⊠NA □NE		
DETAILS:					L				
	OBTAINED THIS INSPI	ECTION:					∕ □N ØNA □NE		
2. TYPE OF S	SAMPLE: GRAB:_	COMPOSITE:_ N	METHOD: FREQUE	NCY:					
	PRESERVED:		<del></del>				∕ □N ØNA □NE		
4. FLOW PRO	OPORTIONED SAMPLE	S OBTAINED:					∕ □N ☑NA □NE		
5. SAMPLE C	BTAINED FROM FACIL	LITY'S SAMPLING DEV	/ICE:				∕ □N ☑NA □NE		
6. SAMPLE R	EPRESENTATIVE OF	VOLUME AND NATUR	E OF DISCHARGE:				∕ □n ☑na □ne		
7. SAMPLE S	PLIT WITH PERMITTE	E:					∕ □N ☑NA □NE		
8. CHAIN-OF	-CUSTODY PROCEDU	RES EMPLOYED:					∕ □N ☑NA □NE		
9. SAMPLES	COLLECTED IN ACCO	RDANCE WITH PERM	IT:				∕ □N ☑NA □NE		
SECTION	J: STORM V	<b>VATER POLL</b>	UTION PREV	VENTION PL	AN				
STORM W	ATER MANAG	EMENT MEET	S PERMIT RE	QUIREMENTS	3	Øs □m □	lu □na □ne		
DETAILS:	No-exposure co	ertification on f	ile.						
1. SWPPP UPDATED AS NEEDED: DATE OF LAST UPDATE:							∕ □N ☑NA □NE		
							∕ □N ☑NA □NE		
3. POLLUTION PREVENTION TEAM IDENTIFIED:							∕ □N ☑NA □NE		
4. POLLUTIO	POLLUTION PREVENTION TEAM PROPERLY TRAINED:								
5. LIST OF POTENTIAL POLLUTANT SOURCES:									
6. LIST OF P	6. LIST OF POTENTIAL SOURCES AND PAST SPILLS AND LEAKS:								
7. ALL NON-STORM WATER DISCHARGES ARE AUTHORIZED:							/ □N ☑NA □NE		
8. LIST OF STRUCTURAL BMPS:							∕ □N ☑NA □NE		
9. LIST OF N	ON-STRUCTURAL BMF	PS:					∕ □N ☑NA □NE		
10. BMPS PRO	10. BMPS PROPERLY OPERATED AND MAINTAINED:								
11. INSPECTION	11. INSPECTIONS CONDUCTED AS REQUIRED:								

FLOW CALCULATION SHEET													
Date:	201	3/04/2	26	Tin	ne:	080 hrs	_						
Head in	n Incl	nes:	10.0		F	eet:	0.833	3					
Type &	Size	of Pr	rimary F	low M	eas	uren	nent D	evice	: 1	8 inch	Parsha	all Flume	
Name 8	& Mo	del of	Secon	dary F	low	Mea	surem	ent D	)evi	ce: B	IF Mod	el 257	
Date of	last	Calib	ration o	f Seco	nda	ry Fl	low De	vice:	2-	<u> 28-201:</u>	3		
								T				T	
Record	ed F	low a	t Date 8	k Time	List	ted A	Above:	3.0	) m	gd		(Facility Flow Mete	r)
Calcula										mgd	th		
(Flow is ca	alculate	ed using	flow char	ts in: <u>ISC</u>	CO Op	oen Cr	nannel Fl	ow Mea	asure	ement Han	dbook-5"	<u>Edition</u> )	
		Poc	orded V	alua	_	Calc	culated	l Valı	10				
% Erro	r =  -	Nec		Calcula				ı vaic	16	X 100			
				Jaicuid	aleu	vait	ue						
			3.0				2.93	<u> </u>					
	_		3.0		2.93		2.00	,		X100			
					2.33								
	_												
% Erro	r =		2.4		%								
Comme	ents:	Cal	ibratio	n was	< 10	0%.	OK						
					4 1	_ / -							

## **DMR Calculation Check**

Reporting Period: From 13 01 01 To 13 01 31 Year Month Day Year Month Day

Parameter Checked: CBOD5

	Loading Mass	Concentration Monthly				
	Mo. Avg lbs/day	Mo. Avg mg/l	7-day Avg mg/l			
Reported Value:	27.2	2.5	3.1			
Calculated Value:	27	2.5	3.1			
Permit Value:	217	10	15			

If calculated value does not equal reported value, explain: Values are equal.



Post-aeration cascade for Outfall 001



**Outfall 001 into Crooked Creek**