

 A R K A N S A S Department of Environmental Quality		WATER DIVISION INSPECTION REPORT				
		AFIN: 32-00044		PERMIT #: AR0020702		DATE: 5/12/2014
		COUNTY: 32 Independence			PDS #: 077879	MEDIA: WN
		GPS LAT: 35.77175 LONG: -91.658972 LOCATION: General Area				
FACILITY INFORMATION			INSPECTION INFORMATION			
NAME: Batesville WWTP LOCATION: 500 River Banks Rd. CITY: Batesville, AR. 72501			FACILITY TYPE: 1 - Municipal INSPECTOR ID#: 71153 S - State FACILITY EVALUATION RATING: 3 - Satisfactory INSPECTION TYPE: Reconnaissance			
RESPONSIBLE OFFICIAL			DATE(S): ENTRY TIME: EXIT TIME: PERMIT EFFECTIVE DATE: 5/12/2014 12:30 14:00 5/1/2011 PERMIT EXPIRATION DATE: 4/30/2016			
NAME / TITLE: Rick Elumbaugh / Mayor COMPANY: City of Batesville MAILING ADDRESS: 500 E. Main St. CITY, STATE, ZIP: Batesville AR 72501 PHONE & EXT. / FAX: 870-698-2400 / EMAIL:			FAYETTEVILLE SHALE RELATED: N FAYETTEVILLE SHALE VIOLATIONS: N			
CONTACTED DURING INSPECTION: No			INSPECTION PARTICIPANTS			
			NAME/TITLE/PHONE/FAX/EMAIL/ETC.: Wesley Davis, Construction Superintendent, 870-698-2447			
AREA EVALUATIONS						
(S=Satisfactory, M=Marginal, U=Unsatisfactory, N=Not Applicable/Evaluated)						
N	PERMIT	N	FLOW MEASUREMENT	N	STORMWATER	
S	RECORDS/REPORTS	N	LABORATORY	N	FACILITY SITE REVIEW	
S	OPERATION & MAINTENANCE	N	EFFLUENT/RECEIVING WATER	N	SELF-MONITORING PROGRAM	
N	SAMPLING	N	SLUDGE HANDLING/DISPOSAL	N	PRETREATMENT	
S	OTHER: SSO					
SUMMARY OF FINDINGS						
No violations were noted at this time.						
GENERAL COMMENTS						
A copy of the work order for the site dated 4/28/2014, the Sanitary Sewer Overflow Monthly Report for April, and the last 24-hour Sanitary Sewer Overflow Report for the site is attached.						
INSPECTOR'S SIGNATURE: 			Sean Saunders		DATE: 5/13/2014	
SUPERVISOR'S SIGNATURE: 			Kerri McCabe		DATE: 5/19/2014	

Water Division Photographic Evidence Sheet

Location:	Batesville WWTP, 401 W. Charles ST.				
Photographer:	Sean Saunders	Date:	5/12/2014	Time:	13:25
Witness:	Wesley Davis	Photo #:	1		
Description:	Manhole with no recent evidence of overflow.				



Mini 1000

1-114

**BATESVILLE WATER UTILITY
COLLECTION SYSTEM OBSTRUCTION FORM**

CREW LEADER: M. Patrick DATE: 4-28-14 TIME NOTIFIED: 2:00pm
TIME RESPONDED: 2:15pm ADDRESS/LOCATION: Charles & Elsie

DESCRIPTION: [] MANHOLE OVERFLOW [] BACKUP IN HOUSE [] OVERFLOW IN HOUSE

EQUIPMENT NEEDED: pickup

PERSONNEL REQUIRED: 1 PRIORITY: [] EMERGENCY [] MAINTENANCE

TIME REQUIRED: 1/2 hr DISCHARGED TO WATERS OF THE STATE: [] YES [] NO

ESTIMATE HOW LONG MANHOLE OVERFLOWED: _____

APPROXIMATELY HOW MANY GALLONS: _____

REMARKS: Called because lid was PARTIALLY OFF
PUT lid BACK ON.

24-HOUR SANITARY SEWER OVERFLOW REPORT

Facility Permit Number: AR0020702 Facility Name: BATESVILLE WATER UTILITIES
 Start Date: 4-14-14 Time: 10:00am End Date: 4-14-14 Time: 1:00pm
 Address/Location: 401 W. CHARLES
 Estimated Volume (in gallons): 2000 GALLONS Manhole #: 1-114

<u>DESCRIPTION</u>	<u>COMMENTS</u>
Manhole Overflow	<u>X</u>
Lift Station Overflow	_____
Main Line Overflow	_____
Service Line Overflow	_____
Other - Describe:	_____

CAUSE(S) OF SSO

Construction	_____	Debris	_____
Equipment Failure	<u>X main pump st.</u>	Grease	_____
Hydro Clean	_____	Line Failure/Break	_____
Rainfall - I & I	<u>X</u>	Roots & Grease	_____
Roots	_____	Vandalism	_____
Power Failure	_____	Other - Describe:	<u>X</u>

ENVIRONMENTAL IMPACT

No Evidence of Adverse Health/Environmental Impact	<u>X</u>
Observed or Evidence of Environmental Impact	_____
Observed or Evidence of Human Contact	_____
Evidence of Fish Kill	_____

ACTION(S) TAKEN TO ADDRESS SSO

(Short term and long term action, including clean-up and any plans to remediate I & I)

Work Order	<u>X</u>	Machine Rodded	_____
Environmental Cleanup	_____	Jet-Vac	_____
Hydro Cleaned	_____	Used Generator to Power	_____
Hand Rodded	_____	Pumps/Equipment	_____
Referred to Engineering	_____	Disinfected & Deodorized	<u>X</u>
Public Notification	_____	Spread Lime on Affected Area	<u>X</u>
Other: Describe:	_____		_____

ULTIMATE DISCHARGE LOCATION

Creek/Stream/River	_____	Ground Surface	_____
Ditch	_____	Paved Area	<u>X</u>
Drop Inlet	_____	Contained in Building	_____

Crew Leader: M. PATRICK Date: 4-14-14

CONFIRMATION NUMBER

BCB38DE9-9126-40F9-96E1-7305368BF4FE

(NOTE: You will need this number should you ever need to contact ADEQ concerning this report)

The following information has been sent.

[Close this window](#) [Print this page](#)

24-Hour Sanitary Sewer Overflow Report

SSO ID#: BCB38DE9-9126-40F9-96E1-7305368BF4FE

Date Sent: 4/14/2014

SSO Bypass Upset

Facility Permit Number: **AR0020702**

Facility name:

Batesville Water Utility

Date Overflow Began: **4/14/14**

Time:

10:00 am

Date Overflow Ended: **4/14/14**

Time:

1:00 pm

Location:

401 W. Charles st. MH 1-114 on paved area.

(Give address, manhole number-if numbered. Include where the overflow went-yard, ditch, stream, storm sewer, building, other.)

Type of Overflow

- Manhole Overflow
- Lift Station Overflow
- Main Line Overflow
- Service Line Overflow
- Other Overflow Type:

(Enter overflow type if not listed)

Volume:

2000

(Give an estimate in gallons)

Impact of SSO Event:

SSO Reached Public Land Only (ground)

Cause of Overflow

- I & I - Rainfall
- Roots
- Grease
- Debris
- Equipment Failure
- Construction
- Vandallism
- Power Failure
- Line Failure/Break
- Other Cause:

Action Taken - Check all that apply

(Short term and long-term action, including clean-up and any plans to remediate I & I).

- Machine rodded
- Disinfected and Deodorized
- Jet-Vac
- Hydro Cleaned
- Hand rodded
- Spread Lime on Affected Area
- Used Generator To Power Pumps/Equipment
- Public Notification
- Other: Describe

Environmental Damage

- OEHC - Observed or Evidence of Human Contact
- NEAH - No Evidence of Adverse Health/Environmental Impact
- OEEI - Observed or Evidence of Environmental Impact
- EFK - Evidence of Fish Kill

Reported By **Michael Patrick** Title **Crew Leader** Telephone Number **(870) 698-2447**

Additional Comments if Needed:


Main pumpstation had mechanical problems that was fixed and during this time we had a 3 rainfall.

Sanitary Sewer Overflow Monthly Report

Facility Name: Batesville Water Utilities Permit Number: AR0020702 Reporting Period(Month/Year): April 2014

No Sanitary Sewer Overflows This Monitoring Period

Cause(s) of SSO	SSO Impact			Action(s) Taken		Ultimate Discharge Location	
	SSO Impact	SSO Impact	SSO Impact	Action(s) Taken	Action(s) Taken to Address SSO		
CO-Corruption	D-Debris	NEAH-No Evidence of Adverse Environmental Impact	WC-Work Order	CR-Creek/Stream/River (please specify)			
E-Equipment Failure	G-Grease	OE/IC-Cleaned or Evidence of Human Contact	EC-Environmental Cleanup	DL-Drain			
IC-Illegal Clean	LF-Lime	EFK-Evidence of Fish Kill	HC-Hygro Cleaned	SR-Down Hilt			
R-Rainfall	RG-Ranks & Grasse		IR-Hand Rotted	GR-Ground Surface			
RC-Rocks	V-Vandalism		EN-Returned to Engineering	FA-Failed Area			
			PA-Public Notification	CE-Contained in Building			
Location	Manhole #	Start Date of SSO	End Date of SSO	Estimated Volume (in gallons)	Cause of SSO	Environmental Impact	Ultimate Discharge Location
1950 Maple st.	4-87A	4/1/2014	4/1/2014	10	G	NEAH	PA,GR
Beggs st.	6-9	4/14/2014	4/14/2014	2500	RE	NEAH	GR,CR
451 W. Charles	1-114	4/14/2014	4/14/2014	2000	RE	NEAH	PA,GR
1590 . . .	6-11	4/14/2014	4/14/2014	3000	RE	NEAH	GR,CR
Fairway & Oulfer	6-32	4/14/2014	4/14/2014	3000	RE	NEAH	GR,CR
2110 S.W.M	6-82	4/17/2014	4/17/2014	unknown	H	NEAH	GR
2325 N.W. Hwy st.	5-29	4/24/2014	4/24/2014	100	R	NEAH	GR
817 Bates	2-175	4/28/2014	4/28/2014	unknown	R	NEAH	DI

Signature of Organizer or Rating Official:  Date: 5-6-14

"I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and analyze the information submitted. Based on my inquiry of the person or persons who prepare the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations."