



ARKANSAS
Department of Environmental Quality

April 23, 2015

Kirby Murray, Public Works Director
City of Berryville
PO Box 227
Berryville, AR 72616

RE: Berryville Wastewater Facility Inspection (Carroll Co)
AFIN: 08-00034 NPDES Permit No.: AR0021792 (EXPIRED)

Dear Mr. Murray:

On March 17, 2015, I performed a Compliance Evaluation Inspection of the above referenced facility in accordance with the provisions of the Federal Clean Water Act, the Arkansas Water and Air Pollution Control Act, and the regulations promulgated thereunder. A copy of the inspection report is enclosed for your records.

No violations were noted at the time of the inspection. Please refer to the attached inspection report for any comments.

If I can be of any assistance, please contact me at kirkpatrick@adeq.state.ar.us or (870) 446-6170.

Sincerely,

Bruce Kirkpatrick, P.E.
District 2 Field Inspector
Water Division




 A R K A N S A S Department of Environmental Quality		WATER DIVISION INSPECTION REPORT			
		AFIN: 08-00034		PERMIT #: AR0021792	
COUNTY: 08 Carroll		PDS #: 083618		MEDIA: WN	
GPS LAT: 36.357208 LONG: -93.57875 LOCATION: General Area					
FACILITY INFORMATION			INSPECTION INFORMATION		
NAME: Berryville Wastewater Facility LOCATION: 1000 W. Cedarvale CITY: Berryville, AR			FACILITY TYPE: 1 - Municipal INSPECTOR ID#: 25955 S - State FACILITY EVALUATION RATING: N INSPECTION TYPE: Compliance Evaluation		
RESPONSIBLE OFFICIAL			DATE(S): 3/17/2015 ENTRY TIME: 10:52 EXIT TIME: 11:55 PERMIT EFFECTIVE DATE: 12/1/2007 PERMIT EXPIRATION DATE: 11/30/2012		
			NAME / TITLE: Kirby Murray / Public Works Director COMPANY: City of Berryville MAILING ADDRESS: PO Box 227 CITY, STATE, ZIP: Berryville AR 72616 PHONE & EXT. / FAX: 870-423-4074 / EMAIL:		
CONTACTED DURING INSPECTION: No					
AREA EVALUATIONS					
(S=Satisfactory, M=Marginal, U=Unsatisfactory, N=Not Applicable/Evaluated)					
S	PERMIT	N	FLOW MEASUREMENT	S	STORMWATER
N	RECORDS/REPORTS	N	LABORATORY	S	FACILITY SITE REVIEW
N	OPERATION & MAINTENANCE	S	EFFLUENT/RECEIVING WATER	N	SELF-MONITORING PROGRAM
N	SAMPLING	N	SLUDGE HANDLING/DISPOSAL	N	PRETREATMENT
N	OTHER:				
SUMMARY OF FINDINGS					
No violations were noted at the time of the inspection.					
GENERAL COMMENTS					
The facility is classified by EPA as a NPDES Municipal Major; and therefore, subject to the NPDES general Industrial Stormwater regulatory requirements. The facility was doing an excellent job of complying with the referenced permit's stormwater conditions. Permit has been extended past the expiration date according to NPDES permitting rules. The Pollution Prevention Plan was updated on 5/15/2014 and complete. Records were maintained of all inspection and training activities. The inspection did not reveal any exposure to stormwater as described in NPDES Stormwater rules. Facility has been advised of the No-Exposure Certification option, but has opted to continue to comply with the existing permit conditions.					
INSPECTOR'S SIGNATURE: 				DATE: 4/10/2015	
SUPERVISOR'S SIGNATURE: 				DATE: 4/21/2015	

Figure 1. Google Earth image dated April 24, 2014 of the site.

