

 <b>A R K A N S A S</b> Department of Environmental Quality		<b>WATER DIVISION INSPECTION REPORT</b>				
		AFIN: 61-00055		PERMIT #: AR0034835		DATE: 2/12/2015
		COUNTY: 61 Randolph		PDS #: 084156		MEDIA: WN
		GPS LAT: 36.240997 LONG: -90.97981 LOCATION: Entrance				
<b>FACILITY INFORMATION</b>			<b>INSPECTION INFORMATION</b>			
NAME: <b>City of Pocahontas WWTP</b> LOCATION: <b>0.4 mi. S of Swan Cove intersection w/ Black River</b> CITY: <b>Pocahontas</b>			FACILITY TYPE: <b>1 - Municipal</b>	INSPECTOR ID#: <b>52138 S - State</b>		
			FACILITY EVALUATION RATING: <b>N</b>	INSPECTION TYPE: <b>Compliance Assistance</b>		
			DATE(S): <b>2/12/2015</b>	ENTRY TIME: <b>09:30</b>	EXIT TIME: <b>10:30</b>	PERMIT EFFECTIVE DATE: <b>3/1/2014</b> PERMIT EXPIRATION DATE: <b>2/28/2019</b>
<b>RESPONSIBLE OFFICIAL</b>						
NAME / TITLE: <b>Bill Daniel / Manager</b> COMPANY: <b>Pocahontas Water and Sewer System</b> MAILING ADDRESS: <b>207 Hwy. 67 South</b> CITY, STATE, ZIP: <b>Pocahontas AR 72455</b> PHONE & EXT. / FAX: <b>870-892-3222 /</b> EMAIL:			FAYETTEVILLE SHALE RELATED: <b>N</b> FAYETTEVILLE SHALE VIOLATIONS: <b>N</b>			
CONTACTED DURING INSPECTION: <b>Yes</b>			<b>INSPECTION PARTICIPANTS</b>			
			NAME/TITLE/PHONE/FAX/EMAIL/ETC.: <b>Bill Daniel/Manager</b> <b>Lloyd Lewallen/City Inspector/Code Enforcement</b> <b>Jay Matheny/Parks and Recreation Director</b> <b>Kary Story/Mayor</b>			
<b>AREA EVALUATIONS</b>						
(S=Satisfactory, M=Marginal, U=Unsatisfactory, N=Not Applicable/Evaluated)						
<b>S</b>	PERMIT	<b>N</b>	FLOW MEASUREMENT	<b>N</b>	STORMWATER	
<b>N</b>	RECORDS/REPORTS	<b>N</b>	LABORATORY	<b>N</b>	FACILITY SITE REVIEW	
<b>N</b>	OPERATION & MAINTENANCE	<b>N</b>	EFFLUENT/RECEIVING WATER	<b>N</b>	SELF-MONITORING PROGRAM	
<b>N</b>	SAMPLING	<b>N</b>	SLUDGE HANDLING/DISPOSAL	<b>N</b>	PRETREATMENT	
<b>N</b>	OTHER:					
<b>SUMMARY OF FINDINGS</b>						
<p>This compliance assistance inspection was conducted at the request of the City/Permittee to discuss potential impacts to the WWTP caused by swimming pool filter backwash from the new aquatic center currently under construction. After reviewing the projected backwash volumes and treatment processes, it was determined that the discharge of backwash water to the POTW is not likely to cause any adverse effects in the treatment process. Additionally, we discussed the need for evaluating the receiving sewer main and subsequent pump station to ensure that the maximum flow rate is not exceeded thus resulting in an overflow from the collection system.</p>						
<b>GENERAL COMMENTS</b>						
None						
INSPECTOR'S SIGNATURE:  Brent L. Walker				DATE: 5/15/2015		
SUPERVISOR'S SIGNATURE:  Jason Bolenbaugh				DATE: 5/21/2015		