

 A R K A N S A S Department of Environmental Quality		WATER DIVISION INSPECTION REPORT					
		AFIN: 36.00038		PERMIT #: AR0022187		DATE: 10/1/2015	
		COUNTY: 36 Johnson			PDS #: 087438		MEDIA: WN
		GPS LAT:		LONG:		LOCATION: N/A	
FACILITY INFORMATION				INSPECTION INFORMATION			
NAME: Bright Harvest LOCATION: 501 Taylor Rd. CITY: Clarksville, AR				FACILITY TYPE: 2 - Industrial		INSPECTOR ID#: 26588 S - State	
RESPONSIBLE OFFICIAL NAME / TITLE: John Lester / General Manager COMPANY: Clarksville Light & Water Co MAILING ADDRESS: P.O. Box 1807 CITY, STATE, ZIP: Clarksville AR 72830 PHONE & EXT. / FAX: / EMAIL:				FACILITY EVALUATION RATING: N		INSPECTION TYPE: Industrial User	
				DATE(S): 10/1/2015		ENTRY TIME: 13:30	
CONTACTED DURING INSPECTION: ***				PERMIT EFFECTIVE DATE: 10/1/2014			
				PERMIT EXPIRATION DATE: 9/30/2019			
				FAYETTEVILLE SHALE RELATED: N			
				FAYETTEVILLE SHALE VIOLATIONS: N			
				INSPECTION PARTICIPANTS			
				NAME/TITLE/PHONE/FAX/EMAIL/ETC.: Gregg Rainey / Pollution Control Facility Superintendent / 479-979-5509 Pam Smith / Lab Superintendent & Pretreatment Coordinator / 479-754-7229 Johnny Finn / Bright Harvest Pretreatment Specialist / 479-754-6313			
AREA EVALUATIONS							
(S=Satisfactory, M=Marginal, U=Unsatisfactory, N=Not Applicable/Evaluated)							
N	PERMIT	N	FLOW MEASUREMENT	N	STORMWATER	N	RECORDS/REPORTS
N	OPERATION & MAINTENANCE	N	LABORATORY	N	FACILITY SITE REVIEW	N	OPERATION & MAINTENANCE
N	SAMPLING	N	EFFLUENT/RECEIVING WATER	N	SELF-MONITORING PROGRAM	N	SAMPLING
N	OTHER:	N	SLUDGE HANDLING/DISPOSAL	S	PRETREATMENT	S	OTHER:
**							
SUMMARY OF FINDINGS							
No permit violations were noted during this inspection.							
GENERAL COMMENTS							
The settling basins are allowed to accumulate solids for up to a year before removal and land application. The organic material within the basins becomes septic and emits an intensely foul odor. The odor could be greatly reduced by removing the accumulated solids more frequently. The plant routinely meets the pretreatment discharge limits.							
INSPECTOR'S SIGNATURE: 				Tony L. Morris		DATE: 10/7/2015	
SUPERVISOR'S SIGNATURE: 				Kerri McCabe		DATE: 10/30/2015	

PRETREATMENT COMPLIANCE INSPECTION

IU SITE VISIT FORM

Name of Industry: **Bright Harvest**

POTW Name: **Clarksville POTW**

Industry Contacts: **Jeff Hannon, Johnny Finn**

Date and Time of Visit: **10/1/2015, 13:20**

Description of Manufacturing Process:
Sweet potato processing

Sources of Process Wastewater:
Washing potatoes prior to processing; cleaning processing equipment.

Categorical Industry? **No**

Basis for Limits: **40CFR403.8 individual permits with effluent limits**

Point of Application: **NE**

Description of Pretreatment Equipment and Procedures:
Two settling basins in series which drain to two aerated serpentine lagoons in series. Solids from settling basins hauled by TRS and land applied.

Spill Prevention and Solvent Management Procedures:
A concrete catchment basin and drain has been constructed to contain spills and divert to settling basins. No solvents used.

Sampling Location and Equipment:
Samples collected from "Blue Sample Hut" after discharge from aerated lagoon.

Water Division Photographic Evidence Sheet

Location:	Bright Harvest		
Photographer:	Google Earth	Date:	10/24/2012
Witness:		Time:	
		Photo #:	1
Description:	Bright Harvest pretreatment plant with settling basins south of oxidation.		

