

 A R K A N S A S Department of Environmental Quality		WATER DIVISION INSPECTION REPORT				
		AFIN: 36.00038		PERMIT #: AR0022187		DATE: 10/1/2015
		COUNTY: 36 Johnson			PDS #: 087439	MEDIA: WN
		GPS LAT:	LONG:	LOCATION: N/A		
FACILITY INFORMATION			INSPECTION INFORMATION			
NAME: Greenville Tube LOCATION: 501 South Montgomery CITY: Clarksville, AR			FACILITY TYPE: 2 - Industrial		INSPECTOR ID#: 26588 S - State	
RESPONSIBLE OFFICIAL NAME / TITLE: John Lester / General Manager COMPANY: Clarksville Light & Water Co MAILING ADDRESS: P.O. Box 1807 CITY, STATE, ZIP: Clarksville AR 72830 PHONE & EXT. / FAX: / EMAIL:			FACILITY EVALUATION RATING: N		INSPECTION TYPE: Industrial User	
			DATE(S): 10/1/2015	ENTRY TIME: 13:00	EXIT TIME: 13:20	PERMIT EFFECTIVE DATE: 10/1/2014 PERMIT EXPIRATION DATE: 9/30/2019
CONTACTED DURING INSPECTION: ***			FAYETTEVILLE SHALE RELATED: N			
			FAYETTEVILLE SHALE VIOLATIONS: N			
INSPECTION PARTICIPANTS						
NAME/TITLE/PHONE/FAX/EMAIL/ETC.: Gregg Rainey / Pollution Control Facility Superintendent / 479-979-5509 Pam Smith / Lab Superintendent & Pretreatment Coordinator / 479-754-7229 Jim Roberts / EH&S / 479-754-6500						
AREA EVALUATIONS						
(S=Satisfactory, M=Marginal, U=Unsatisfactory, N=Not Applicable/Evaluated)						
N	PERMIT	N	FLOW MEASUREMENT	N	STORMWATER	
N	RECORDS/REPORTS	N	LABORATORY	N	FACILITY SITE REVIEW	
N	OPERATION & MAINTENANCE	N	EFFLUENT/RECEIVING WATER	N	SELF-MONITORING PROGRAM	
N	SAMPLING	N	SLUDGE HANDLING/DISPOSAL	S	PRETREATMENT	
**	OTHER:					
SUMMARY OF FINDINGS						
No permit violations were noted during this inspection.						
GENERAL COMMENTS						
INSPECTOR'S SIGNATURE: 				DATE: 10/8/2015		
SUPERVISOR'S SIGNATURE: 				DATE: 10/30/2015		

PRETREATMENT COMPLIANCE INSPECTION

IU SITE VISIT FORM

Name of Industry: **Greenville Tube**

POTW Name: **Clarksville POTW**

Industry Contacts: **Jim Roberts**

Date and Time of Visit: **10/1/2015, 12:43**

Description of Manufacturing Process:
Metal finishing

Sources of Process Wastewater:
Citric acid passivation of stainless steel tubing.

Categorical Industry? **Yes**

Basis for Limits: **40CFR403.8 individual permits with effluent limits**

Point of Application: **NE**

Description of Pretreatment Equipment and Procedures:
pH adjustment with soda ash in tank.

Spill Prevention and Solvent Management Procedures:
Above floor tanks are in visually monitored for spills.
No solvents in use.

Sampling Location and Equipment:
Sample collected at south end of rinse tank.

Water Division Photographic Evidence Sheet

Location:	Greenville Tube		
Photographer:	Google Earth	Date:	10/24/2012
Witness:		Time:	
		Photo #:	1
Description:	Greenville Tube Plant; pretreatment units are within plant.		

