

May 23, 2016

Mike Spencer, Wastewater Supervisor City of Mena 323 Polk 53 Mena, AR 71953

RE: City of Mena Wastewater Plant Inspections (Polk Co)

AFIN: 57-00423 Permit No.: AR0036692

ARR000145 AR0036692C ARR150000

57-00290 5207-W

Dear Mr. Spencer:

On April 5-6 and 25, 2016, I performed a Compliance Evaluation Inspection, a Compliance Sampling Inspection, a Collection System Inspection, an Industrial Stormwater Inspection, a State WWTP Construction Inspection, a Small Construction Site Inspection, and a Land Application Inspection of the above-referenced facility in accordance with the provisions of the Federal Clean Water Act, the Arkansas Water and Air Pollution Control Act, and the regulations promulgated thereunder. Copies of the inspection reports are enclosed for your records.

Please refer to the "Summary of Findings" section of each of the attached inspection reports and provide a written response for each violation that was noted. This response should be mailed to the attention of the Water Division Inspection Branch at the address at the bottom of this letter or e-mailed to Water-Inspection-Report@adeq.state.ar.us. This response should contain documentation describing the course of action taken to correct each item noted. This corrective action should be completed as soon as possible, and the written response with all necessary documentation (i.e., photos) is due by June 6, 2016.

If I can be of any assistance, please contact me at mccabe@adeq.state.ar.us or (501) 682-0642.

Sincerely,

Kerri McCabe Inspector Supervisor

Kerri M'Caly

Water Division

ADFO			WATER	DIVISION I	NSF	PECTION	N RE	PORT
AULQ			IN: 57-00423 PI	ERMIT #: AR003 6	6692		DATE: 5	5/6/2016
Δ	RKANSAS	CC	DUNTY: 57 Polk		PDS	#: 090883		MEDIA: WN
De	partment of Environmental Quality	GF	S LAT: 34.55620	8 LONG: -94.188	032 L	OCATION: E	ntrance	9
	FACILITY INFORMAT	ION		IN	SPEC	TION INFOR	MATION	V
	E: ena Wastewater Plant stion:			FACILITY TYPE: 1 - Municipal	8402	TOR ID#: 22 S - State		
	3 Polk 53			FACILITY EVALUATION RATIN 2 - Marginal	G:		on type: pliance	Evaluation
	ena, AR			(-)	TRY TIME: 9:30	EXIT TIME: 13:45		FFECTIVE DATE:
	RESPONSIBLE OFFIC	CIAL		4/0/2010	3.30	13.43	3/1/20 PERMIT EX)12 (PIRATION DATE:
	E / TITLE	icor					2/28/2	2017
	ke Spencer / Wastewater Superv	1501		FAYETTEVILLE SHALE RELATED: N				
	y of Mena			FAYETTEVILLE SHALE VIOLATIONS: N				
	ING ADDRESS: 3 Polk 53			INSPECTION PARTICIPANTS				
CITY,	STATE, ZIP:			NAME/TITLE/PHONE/FAX/EMAIL/ETC.:				
	ena AR 71953 NE & EXT: / FAX:			Mike Spencer (Lic# 007917)/WW Supervisor/(479) 234- 2592/menawwtp@gmail.com				
	9-234-2592 /							
EMAI	L:							
	enawwtp@gmail.com							
CC	INTACTED DURING INSPECTION:	Yes						
	(S=Si	atisfac	AREA EVA tory, M=Marginal, U=Unsati		/Evaluated	(k		
S	PERMIT	S	FLOW MEASUR		S	STORMWA	ATER	
M	RECORDS/REPORTS	S	LABORATORY		S	FACILITY S		
M	OPERATION & MAINTENANCE	S		CEIVING WATER				G PROGRAM
M	SAMPLING	S	SLUDGE HAND	LING/DISPOSAL	S	PRETREAT	TMENT	
**	OTHER:							
			SUMMARY C	F FINDINGS				

The following violations were noted during the inspection:

- 1.) Facility failed to collect/analyze samples during discharge from Outfall 001 for Oct 2015. Records indicate that a discharge from Outfall 001 was occurring on Oct 1, Oct 2, and Oct 20-23; however, effluent samples were not collected/analyzed. This is a violation of Part I, Section A of the permit.
- 2.) Bypasses of treatment from Lagoon #2 to the former outfall structure downstream of the permitted Outfall 001 occurred in Oct 2015. There is no record of these bypasses being reported to the ADEQ. Flow records for Oct 2015 indicate no flow from the permitted Outfall 001 for several days in Oct 2015. Bypasses at the WWTP were reported on the online SSO Report for May 24-25, 2015; May 28-29, 2015; and Dec 27-29, 2015. This is a violation of Part III, Section B, 4, B. of the permit. Bypasses exceeding effluent limits must be reported to the Department. This is demonstrated by collecting/analyzing bypass discharge.
- 3.) Flow records for Oct 2015 were handwritten in a notebook and only contained the date and totalized flow. This is a violation of Part III, Section C, 8 of the permit. Records should contain all items listed in Part III, Sec C, 8, A-F of the permit. Operator has a flow recording spreadsheet that contains all the required information and this form needs to be used for recording flow.
- 4.) Several bypasses occurred at the WWTP in 2015. Three of these bypasses were reported on the online SSO Report form (May and Dec 2015) and two other bypasses were not reported (Oct 2015). A bypass is not a sanitary sewer overflow, and instances of bypass require specific reporting procedures. This is a violation of Part III, Section D, 6, A-B of the permit.

GENERAL COMMENTS

On Wednesday, April 6, 2016 a compliance inspection was conducted with the above-mentioned inspection participants. The inspection consisted of a site assessment and a records review.

Site assessment:

Treatment consists of automatic bar screen, main lift station, primary aerated (fine bubble diffusion) stabilization pond (25 acres), secondary aerated (fine bubble diffusion) stabilization pond (30 acres), polymer/coagulant addition, four (4) upflow continuous backwash rapid sand filters, chlorine gas disinfection, post-aeration via two (2) gravity static aerators, and discharge. Per a flow diagram submitted with the permit renewal application (March 2016), the facility has two bypass options: from the main lift station to Lagoon #2 and from Lagoon #2 to the receiving stream. The facility discharged via Lagoon #2 in Oct 2015 due to substantial precipitation (bypassed filtration and disinfection; not reported to Enforcement Branch).

The City has recently completed the construction of the geotube staging area for the dewatering of sludge, which will be land applied under State No-Discharge permit 5207-W.

Overall, the site was well-maintained. However, the City-operated animal control facility has constructed a waste pit for animal waste. This waste pit overflows, commingles with stormwater, and discharges downstream of the permitted outfall (upstream of the bypass outfall). Additionally, personnel from the animal control facility have stored materials outside at the adjacent WWTP property.

The in-house laboratory is clean and well-organized.

Records review:

The City samples/analyzes the following permit parameters: flow, TSS, DO, FCB, TRC, and pH. The City participates in the DMR Quality Assurance (DMR-QA) Study 36 program (results provided). There was no bench sheet documenting flow for Oct 2015. The Operator requires staff to perform daily flow accuracy checks and totalized flow is documented in a notebook, but it does not contain all info required by Part III, Sec C, 8. A-F. of the permit. Operator does have a spreadsheet for recording flow and needs to use this form for recording flow.

DMR check was conducted for April and Oct 2015. The Oct 2015 data indicate that samples were not collected for two weeks in Oct even though there was a discharge from Outfall 001. The Operator stated that a bypass had occurred in Oct 2015 from Lagoon #2 directly to the receiving stream. The monthly SSO Report for Oct 2015 indicates no overflows of the collection system. Excessive I&I of the collection system would indicate that a bypass was necessary to prevent levee failure of Lagoon #2. Per Gina Porter, Enforcement Analyst, no report for a bypass in Oct 2015 is documented for the City of Mena.

Kerri Mª Caly		
INSPECTOR'S SIGNATURE:	Kerri McCabe	DATE: 5/23/2016
SUPERVISOR'S SIGNATURE: Jan Rolling Jas	son Bolenbaugh	DATE: 5/23/2016

SECTION A: PERMIT VERIFICATION	
PERMIT SATISFACTORILY ADDRESSES OBSERVATIONS	☑S □M □U □NA □NE
DETAILS:	
1. CORRECT NAME AND MAILING ADDRESS OF PERMITTEE:	☑Y □N □NA □NE
2. NOTIFICATION GIVEN TO EPA/STATE OF NEW DIFFERENT OR INCREASED DISCHARGES:	□Y □N ØNA □NE
3. NUMBER AND LOCATION OF DISCHARGE POINTS AS DESCRIBED IN PERMIT: Old outfall structure utilized for bypass when	needed. ✓Y □N □NA □NE
4. ALL DISCHARGES ARE PERMITTED:	☑Y □N □NA □NE
SECTION B: RECORDKEEPING AND REPORTING EVALUATION	
RECORDS AND REPORTS MAINTAINED AS REQUIRED BY PERMIT	□S ☑M □U □NA □NE
DETAILS: Oct 2015 flow records recorded in notebook; need to use spreadsheet with req	uired information.
1. ANALYTICAL RESULTS CONSISTENT WITH DATA REPORTED ON DMRS:	☑Y □N □NA □NE
2. SAMPLING AND ANALYSES DATA ADEQUATE AND INCLUDE:	⊠s □m □u □na □ne
a. DATES AND TIME(S) OF SAMPLING:	☑Y □N □NA □NE
b. EXACT LOCATION(S) OF SAMPLING:	☑Y □N □NA □NE
c. NAME OF INDIVIDUAL PERFORMING SAMPLING:	☑Y □N □NA □NE
d. ANALYTICAL METHODS AND TECHNIQUES:	☑Y □N □NA □NE
e. RESULTS OF CALIBRATIONS:	☑Y □N □NA □NE
f. RESULTS OF ANALYSES:	☑Y □N □NA □NE
g. DATES AND TIMES OF ANALYSES:	☑Y □N □NA □NE
h. NAME OF PERSON(S) PERFORMING ANALYSES:	☑Y □N □NA □NE
3. LABORATORY EQUIPMENT CALIBRATION AND MAINTENANCE RECORDS ADEQUATE:	⊠S □M □U □NA □NE
4. PLANT RECORDS INCLUDE SCHEDULES, DATES OF EQUIPMENT MAINTENANCE AND REPAIR:	□S □M □U □NA ☑NE
5. EFFLUENT LOADINGS CALCULATED USING DAILY EFFLUENT FLOW AND DAILY ANALYTICAL DATA:	☑Y □N □NA □NE
SECTION C: OPERATIONS AND MAINTENANCE	
TREATMENT FACILITY PROPERLY OPERATED AND MAINTAINED	☐S ØM ☐U ☐NA ☐NE
DETAILS:	
1. TREATMENT UNITS PROPERLY OPERATED:	Øs □m □u □na □ne
2. TREATMENT UNITS PROPERLY MAINTAINED:	ØS □M □U □NA □NE
3. STANDBY POWER OR OTHER EQUIVALENT PROVIDED: Onsite generator (200hp).	Øs □m □u □na □ne
4. ADEQUATE ALARM SYSTEM FOR POWER OR EQUIPMENT FAILURES AVAILABLE:	Øs □m □u □na □ne
5. ALL NEEDED TREATMENT UNITS IN SERVICE:	Øs □m □u □na □ne
6. ADEQUATE NUMBER OF QUALIFIED OPERATORS PROVIDED: One (1) Class III/Adv. Industrial and one (1) Class I.	Øs □m □u □na □ne
7. SPARE PARTS AND SUPPLIES INVENTORY MAINTAINED:	ØS □M □U □NA □NE
8. OPERATION AND MAINTENANCE MANUAL AVAILABLE:	OY ON ONA MINE
9. STANDARD OPERATING PROCEDURES AND SCHEDULES ESTABLISHED:	OY ON ONA MINE
10. PROCEDURES FOR EMERGENCY TREATMENT CONTROL ESTABLISHED: Retain in lagoons; no EQ. 11. HAVE BYPASSES/OVERFLOWS OCCURRED AT THE PLANT OR IN THE COLLECTION SYSTEM IN THE LAST YEAR: Bypass	OY MN ONA ONE
Lagoon #2 to receiving stream in May 2015, Oct 2015, and Dec 2015.	
12. IF SO, HAS THE REGULATORY AGENCY BEEN NOTIFIED: Submitted online SSO Report for May and Dec 2015 bypasses; deport Oct 2015 bypasses to Enforcement Branch.	id not □Y ☑N □NA □NE
13. HAS CORRECTIVE ACTION BEEN TAKEN TO PREVENT ADDITIONAL BYPASSES/OVERFLOWS: Bypasses due to I&I of collisions and excessive precipitation in 2015; Corrective Action Plan (CAP) scheduled for June 2016.	ection ☐Y ☑N ☐NA ☐NE
14. HAVE ANY HYDRAULIC OVERLOADS OCCURRED AT THE TREATMENT PLANT:	□Y ØN □NA □NE
15. IF SO, DID PERMIT VIOLATIONS OCCUR AS A RESULT:	□Y □N ☑NA □NE

SECTION D: SAMPLING	
PERMITTEE SAMPLING MEETS PERMIT REQUIREMENTS	□S ☑M □U □NA □NE
DETAILS: Operator samples/analyzes flow, TSS, DO, FCB, TRC, and pH; all other param	eters contracted.
SAMPLES TAKEN AT SITE(S) SPECIFIED IN PERMIT:	Øy □n □na □ne
2. LOCATIONS ADEQUATE FOR REPRESENTATIVE SAMPLES:	☑Y □N □NA □NE
3. FLOW PROPORTIONED SAMPLES OBTAINED WHEN REQUIRED BY PERMIT:	☑Y □N □NA □NE
4. SAMPLING AND ANALYSES COMPLETED ON PARAMETERS SPECIFIED IN PERMIT:	☑Y □N □NA □NE
5. SAMPLING AND ANALYSES PERFORMED AT FREQUENCY SPECIFIED IN PERMIT: <u>Discharge from Outfall 001 was not</u> for two weeks in Oct 2015.	sampled ☐Y ☑N ☐NA ☐NE
6. SAMPLE COLLECTION PROCEDURES ADEQUATE:	Øy □n □na □ne
a. SAMPLES REFRIGERATED DURING COMPOSITING:	Øy □n □na □ne
b. PROPER PRESERVATION TECHNIQUES USED:	Øy □n □na □ne
c. CONTAINERS AND SAMPLE HOLDING TIMES CONFORM TO 40 CFR 136:	☑Y □N □NA □NE
7. IF MONITORING IS PERFORMED MORE OFTEN THAN REQUIRED ARE RESULTS REPORTED ON THE DMR: Process of	Ontrol □Y □N ☑NA □NE
sampling does not have to be reported.	
SECTION E: FLOW MEASUREMENT	
PERMITTEE FLOW MEASUREMENT MEETS PERMIT REQUIREMENTS	☑S □M □U □NA □NE
DETAILS:	
1. PRIMARY FLOW MEASUREMENT DEVICE PROPERLY INSTALLED AND MAINTAINED: YES TYPE OF DEVICE: 90deg N	/-notch
2. FLOW MEASURED AT EACH OUTFALL AS REQUIRED:	☑Y □N □NA □NE
SECONDARY INSTRUMENTS (TOTALIZERS, RECORDERS, ETC.) PROPERLY OPERATED AND MAINTAINED: Milltronics	
HydroRanger (totalizer)	
CALIBRATION FREQUENCY ADEQUATE: Last calibrated May 1, 2015. RECORDS MAINTAINED OF CALIBRATION PROCEDURES:	
	✓Y □N □NA □NE
CALIBRATION CHECKS DONE TO ASSURE CONTINUED COMPLIANCE: Operator has staff conduct accuracy checks da FLOW ENTERING DEVICE WELL DISTRIBUTED ACROSS THE CHANNEL AND FREE OF TURBULENCE:	illy.
FLOW BENTERING DEVICE WELL DISTRIBUTED ACROSS THE CHANNEL AND FREE OF TORBULENCE. FLOW MEASUREMENT EQUIPMENT ADEQUATE TO HANDLE EXPECTED RANGE OF FLOW RATES:	MY ON ONA ONE
9. HEAD MEASURED AT PROPER LOCATION: 9. HEAD MEASURED AT PROPER LOCATION:	MY ON ONA ONE
9. FILAD MILASURED AT PROPER ECCATION.	ET LIN LINA LINE
SECTION F: LABORATORY	
PERMITTEE LABORATORY PROCEDURES MEET PERMIT REQUIREMENTS	☑S □M □U □NA □NE
DETAILS: Operator samples/analyzes flow, TSS, DO, FCB, TRC, and pH; all other para	
EPA APPROVED ANALYTICAL PROCEDURES USED (40 CFR 136.3 FOR LIQUIDS, 503.8(B) FOR SLUDGES):	MY □N □NA □NE
2. IF ALTERNATIVE ANALYTICAL PROCEDURES ARE USED, PROPER APPROVAL HAS BEEN OBTAINED: 2. IF ALTERNATIVE ANALYTICAL PROCEDURES ARE USED, PROPER APPROVAL HAS BEEN OBTAINED:	
SATISFACTORY CALIBRATION AND MAINTENANCE OF INSTRUMENTS AND EQUIPMENT:	✓Y □N □NA □NE
QUALITY CONTROL PROCEDURES ADEQUATE: DMR-QA results provided.	✓Y □N □NA □NE
5. DUPLICATE SAMPLES ARE ANALYZED ≥10% OF THE TIME:	☑Y □N □NA □NE
6. SPIKED SAMPLES ARE ANALYZED ≥10% OF THE TIME:	☑Y □N □NA □NE
7. COMMERCIAL LABORATORY USED:	⊠y □n □na □ne
a. LAB NAME: Data Testing, Inc. American Interplex Corp	
b. LAB ADDRESS: 3434 Country Club, Fort Smith AR, 72903 8600 Kanis Rd, Little Rock, AR 72204	
c. PARAMETERS PERFORMED: CBOD5, NH3-N, TP, and NO3+NO2-N; Total Recoverable Cu	
8. BIOMONITORING PROCEDURES ADEQUATE: Huther & Associates, Inc., 1156 N Bonnie Brae, Denton, TX 76201	☑Y □N □NA □NE
a. PROPER ORGANISMS USED:	☑Y □N □NA □NE
b. PROPER DILUTION SERIES FOLLOWED:	⊠y □n □na □ne
c. PROPER TEST METHODS AND DURATION:	☑Y □N □NA □NE
d. RETESTS AND/OR TRE PERFORMED AS REQUIRED:	□Y □N ☑NA □NE

Inspection Report: Mena Wastewater Plant, AFIN: 57-00423, Permit #: AR0036692									
SECTION G: EFFLUENT/RECEIVING WATERS OBSERVATIONS									
BASED ON VISUAL OBSERVATIONS ONLY									
DETAILS: Observed at sample location and receiving stream.									
OUTFALL #:	OIL SHEEN	GREASE	TURBIDITY	VISIBLE FOAM	FLOATING SOLIDS	COLOR	OTHER		
001	NO	NO	NO	NO	Algae	Greenish	N/A		
	L			L	l.	L	L		
SECTION H	: SLUDGE DIS	POSAL							
	DISPOSAL ME		REQUIREMENT	rs		MS DM D	U □NA □NE		
			•		ater removed s				
	n (5027-W).	on dottod otdgr		<u></u>		<u></u>	10.10		
	IANAGEMENT ADEQU	ATE TO MAINTAIN EF	FLUENT QUALITY:			⊠s □m	□U □NA □NE		
2. SLUDGE R		O AS REQUIRED BY 40	CFR 503: Scheduled	to land apply in 2016	3-2017; last removed in		□U ☑NA □NE		
2 FOR LAND	2004.	/DE OF LAND ADDITE	2.TO: /F.C. FOREST	ACDICULTUDAL DUI	BLIC CONTACT SITE): A		LO ENA LINE		
3. FOR LAND	APPLIED SLUDGE, IT	TPE OF LAND APPLIED	J 10: (E.G., FOREST,	AGRICULTURAL, PUI	SLIC CONTACT SITE): A	<u>gricuiturai</u>			
SECTION I	SAMPLING IN	CDECTION DDC	CEDURES						
							UL MAIA MAIE		
	RESULTS WITH						U ⊠NA □NE		
	See separate		two days of s	ampling.					
	OBTAINED THIS INSPI					ЦΥ	□N ☑NA □NE		
	AMPLE: ☐GRAB:	☐COMPOSITE: N	METHOD: FREQUE	NCY:					
	PRESERVED:						□N ☑NA □NE		
4. FLOW PRO	PORTIONED SAMPLE	S OBTAINED:					□N ØNA □NE		
5. SAMPLE O	BTAINED FROM FACIL	LITY'S SAMPLING DEV	/ICE:				□N ☑NA □NE		
6. SAMPLE R	EPRESENTATIVE OF \	VOLUME AND NATUR	E OF DISCHARGE:				□N ☑NA □NE		
7. SAMPLE S	PLIT WITH PERMITTER	E:				□Y	□N ☑NA □NE		
8. CHAIN-OF-	CUSTODY PROCEDUI	RES EMPLOYED:				□Y	□N ☑NA □NE		
9. SAMPLES	COLLECTED IN ACCO	RDANCE WITH PERM	IT:			□Y	□n ☑na □ne		
SECTION J	: STORM WATI	ER POLLUTION	PREVENTION	PLAN					
STORM W	ATER MANAG	EMENT MEET	S PERMIT RE	QUIREMENTS	5		IU ⊠NA □NE		
DETAILS:	Part II, Condit	tion #7 require	s BMPs; insp	ected under IC	SP ARR000145;	see comment	s regarding		
run-on fro	<u>m animal cont</u>	rol facility.							
1. SWPPP UF	PDATED AS NEEDED:	_ DATE OF LAST UP	DATE:			□Y	□n ☑na □ne		
2. SITE MAP	INCLUDING ALL DISCH	HARGES AND SURFAC	CE WATERS:			□Y	□N ☑NA □NE		
3. POLLUTIO	N PREVENTION TEAM	IDENTIFIED:				□Y	□N ☑NA □NE		
4. POLLUTIO									
5. LIST OF PO									
6. LIST OF PO									
7. ALL NON-S									
8. LIST OF ST	RUCTURAL BMPS:					□Y	□n ☑na □ne		
9. LIST OF NO	ON-STRUCTURAL BMF	PS:				□Y	□n ☑na □ne		
10. BMPS PRO	PERLY OPERATED A	ND MAINTAINED:					□N ØNA □NE		
11. INSPECTIO	10. BMPS PROPERLY OPERATED AND MAINTAINED: □Y □N ☑NA □NE 11. INSPECTIONS CONDUCTED AS REQUIRED: □Y □N ☑NA □NE								

FLOW CALCULATION SHEET							
Date: Ap	ril 6, 2016 Ti	ime: 1146					
Head in Inc	hes:	Feet: 0.91 '					
Type & Size	e of Primary Flow N	Measurement De	evice: <u>90d</u>	<u>leg V-notcl</u>	n weir		
Name & Mo	odel of Secondary I	Flow Measurem	ent Device	e: Milltron (totalize	ics HydroRanger er)		
Date of last	Calibration of Sec	ondary Flow De	vice: Ma	ay 1, 201 <u>5</u>			
Recorded F	Tlow at Date & Time	e Listed Above:	<u>882.4 gr</u>	<u>pm</u>	(Facility Flow Meter)		
	Flow at Date & Timed using flow charts in: IS				th Edition)		
% Error =	Recorded Value Calcu	- Calculated lated Value	Value >	X 100			
% Error =	882.4	- 886.3	}	X 100			
% Error =	-3.9 886.3	X 100					
% Error =	-0.004	X 100					
% Error =	-0.4	%					
Comments:	Acceptable (rep	porting under);	within +/-	- 10% rang	e <u>.</u>		
İ							

DMR Calculation Check

Reporting Period:	From	2015	10	01	_ To	2015	10	31
		Year	Month	Day		Year	Month	Day
Parameter Checked:		NH3-N	_					
	Ma	Loading	y)			Concer		
		Mo. Avg.		Mo	o. Avg		7-Day	Avg.
Reported Value:		1.76			0.22		0.3	7
Calculated Value:		1.7			0.22		0.3	7
Permit Value:		55			2.1		4.5	5

If calculated value does not equal reported value, explain:

Bypass from Lagoon #2 to old outfall structure occurred in

Oct 2015; only three (3) weeks of data were sampled for

Outfall 001.

Values are similar; inconsistent flow recording on daily lab bench sheet and monthly spreadsheet (see Figure 3 for calculations).

DMR Calculation Check

Reporting Period: From 2015 04 01 To 2015 04 30

Year Month Day Year Month Day

Cu, Total Parameter Checked: Recoverable

Loading Concentration Mass (lbs/day) $(\mu g/I)$ Mo. Avg. Mo. Avg. 7-Day Avg. **Reported Value:** 0.04 2.3 2.3 **Calculated Value:** 0.04 2.3 2.3 **Permit Value:** 0.3 10.5 21

If calculated value does not equal reported value, explain: Values are the same; $(0.0023 \times 2.2 \times 8.34 = 0.04 \text{ lbs/day})$

DMR Calculation Check

Reporting Period:	From	2015	4	01	_ To _	2015	4	30
		Year	Month	Day		Year	Month	Day
Parameter Checked:		TSS	_					
	Ma	Loading	νλ			Concer		
		Mo. Avg.	y)	Мо	o. Avg		7-Day	Avg.
Reported Value:		160			7.2		9	
Calculated Value:		<mark>156</mark>			7.2		9	
Permit Value:		388			15		22.	5

If calculated value does not equal reported value, explain:

<u>Values are similar; inconsistent flow recording on daily lab bench sheet and monthly spreadsheet (see Figure 4 for calculations).</u>

Water Division Photographic Evidence Sheet Location: Mena Wastewater Plant Photographer: Kerri McCabe Date: April 6, 2016 Time: 1142 Witness: Mike Spencer Photo #: 1



Photographer:Kerri McCabeDate:April 6, 2016Time:1050Witness:Mike SpencerPhoto #:2






Water Division Photographic Evidence Sheet Location: Mena Wastewater Plant Photographer: Kerri McCabe Date: April 6, 2016 Time: 1102 Witness: Mike Spencer Photo #: 3 Description: Lagoon #2 at intake with baffles and fine bubble diffusers.



Photograph	ner: Kerri McCabe	Date: April 6, 2016	Time:	1107
Witness: N	Mike Spencer		Photo #:	4

Description: Old preliminary components now used to keep fishes from entering rapid sand filters.





Inspection Report: Mena Wastewater Plant, AFIN: 57-00423, Permit #: AR0036692

Water Division Photographic Evidence Sheet								
Location:	Men	a Wastewater Plant						
Photograph	ner:	Kerri McCabe	Date:	April 6, 2016	Time:	1133		
Witness: N	Witness: Mike Spencer Photo #: 7							


Description: Effluent at 90deg V-notch weir and after chlorine disinfection.




Photographer: Kerri McCabe Date: April 6, 2016 Time: 1134
Witness: Mike Spencer Photo #: 8


Description: Two static gravity aerators for post-aeration; effluent sampled in corner.







Photographer:Kerri McCabeDate:April 6, 2016Time:1108Witness:Mike SpencerPhoto #:10





Inspection Report: Mena Wastewater Plant, AFIN: 57-00423, Permit #: AR0036692

Water Division Photographic Evidence Sheet

Location: Mena Wastewater Plant

Photographer: Kerri McCabe

Date: April 6, 2016

Time: 1108

Witness: Mike Spencer

Photo #: 11

Description: Discharge pipe for bypass structure at Lagoon #2; downstream of Outfall 001.

Figure 1. Google Earth image dated Nov 6, 2016 showing overview of the City of Mena POTW and major structures.



Figure 2. Google Earth image dated Nov 6, 2016 showing close-up of the City of Mena POTW and major structures.



Inspection Report: Mena Wastewater Plant, AFIN: 57-00423, Permit #: AR0036692 Figure 3. NH3-N calculations for Oct 2015 for Outfall 001 (used flow from daily lab sheet).

Date	Concentration (mg/l)	7-day Average (mg/l)	Daily Flow (MGD)	Mass (lbs/day)
8	0.14	0.155	0.73	0.852348
9	0.17		0.8	1.13424
12	0.13	0.135	0.79	0.856518
13	0.14		0.78	0.910728
27	0.37	0.37	1.1	3.39438
28	0.37		1	3.0858
MAX	0.37		MAX	3.39438
MIN	0.13		MIN	0.852348
Average	0.22		Average	1.705669

Figure 4. TSS calculations for April 2015 for Outfall 001 (used flow from daily lab sheet).

Date	Concentration	7-day Average	Daily Flow	Mass
	(mg/l)	(mg/l)	(MGD)	(lbs/day)
1	4	7	2.21	73.7256
2	10		2.15	179.31
8	5	6.5	1.57	65.469
9	8		1.62	108.0864
14	8	9	2.64	176.1408
15	10		3.77	314.418
21	8	8.5	3.4	226.848
22	9		2.31	173.3886
28	7	5	2.98	173.9724
29	3		2.9	72.558
MAX	10		MAX	314.418
MIN	3		MIN	65.469
Average	<mark>7.2</mark>		Average	156.39168



CERTIFIED MAIL: 91 7199 9991 7035 3562 2104

July 21, 2016

Mike Spencer, Wastewater Supervisor City of Mena 323 Polk 53 Mena, AR 71953

Re: Failure to Respond to Inspections (Polk Co)

AFIN: 57-00423 NPDES Permit No.: AR0036692

AR0036692C ARR150000

Dear Mr. Spencer:

A letter dated May 23, 2016 was sent by the ADEQ to the City of Mena. The letter outlined the findings of my April 6, 2016 inspections of the above-referenced facility and associated permits. The letter requested that a written response be submitted to the Water Division Inspection Branch of this Department by June 6, 2016. To date, no response has been received for the Compliance Evaluation Inspection for AR0036692 or the Construction Stormwater Inspection for ARR150000. The consulting engineer did provide an adequate response to the State WWTP Construction inspection, and no further response is required regarding this inspection.

Please submit a written response by <u>August 4, 2016</u>. Copies of the applicable inspection reports have been included for your convenience.

Thank you for your attention to this matter. Should you have any questions, feel free to contact me at (501) 682-0642 or you may e-mail me at mccabe@adeq.state.ar.us.

Sincerely,

Kerri McCabe Inspector Supervisor

Kerri Mª Cale

Water Division

From: <u>Mike Spencer</u>

To: <u>Water-Inspection-Report</u>

Subject: Ar0036692

Date: Monday, July 25, 2016 6:45:41 AM

With reference to inspection summary of findings

Page 2. 1) Logs reveal that plant was not online during time frame listed in October 2015 and that is why samples not collected.

Page 2. 2) Bypasses have been reported via online server and phone calls and follow up letter. The City is experiencing extremely high rate I and I up to 650%. All bypasses will be reported via proper channels and City is developing a plan to try to drop the I and I rate coming to plant.

Page 2.3) All flows are being recorded via notebook and also daily computer excel spreadsheet, since inspector was on site.

Page 2.4) All bypasses in future will be reported as per permit requirements.

Storm water permit, with reference to dog pound loose items, have all been moved across fence to a secure area to prevent from being washed away.

Respectfully

Mike Spencer WWTP Supervisor



July 25, 2016

Mike Spencer, Wastewater Supervisor City of Mena 323 Polk 53 Mena, AR 71953

Re: Response to Inspections (Polk Co)

AFIN: 57-00423 NPDES Permit No.: AR0036392

ARR150000

Dear Mr. Spencer:

I have reviewed your response pertaining to my April 6, 2016 inspections of your wastewater treatment facility and the Small Construction Site associated with the geotube staging area. However, the information provided does not sufficiently addresses the violations referenced in my inspection reports.

AR0036692

Please review the copies of the flow records included with this letter. The plant discharged the third week (Oct 19-23) of Oct 2015. The plant may have been offline during normal sample collection, which is conducted on Mondays - Wednesdays; however, if a discharge occurs from the permitted outfall, samples are to be collected per Part I, Section A of the permit and regardless of sample regime. Additionally, to demonstrate that bypass is not violating permit parameters, the bypass is to be sampled. During the 2017 permit renewal, the old outfall structure associated with the plant must be included with the flow diagram for the facility. Otherwise, discharges from this structure will be considered unpermitted discharges that do not meet criteria of the definition of "bypass" and will be subject to enforcement action.

ARR150000

Your response references the City's No-Exposure permit (ARR000145). This is not the inspection that requires a response. The City modified the NPDES permit to construct a geotube staging area (AR0036392C). The disturbed area exceeded one acre (Condition #7), which requires the City to comply with the Construction General Permit (CGP; ARR150000). The City has not supplied a response for this inspection, which was provided with the Failure to Respond letter sent to the City on July 21, 2016.

Please provide the ADEQ Water Division Inspection Branch a response to these findings. Please provide the response no later than **August 8, 2016**.

Thank you for your attention to this matter. Should you have any questions, feel free to contact me at (501) 682-0642 or you may e-mail me at mccabe@adeq.state.ar.us.

Sincerely,

Kerri Mc Cole

Kerri McCabe Inspector Supervisor Water Division

McCabe, Kerri

From: Mike Spencer <menawwtp@gmail.com>

Sent: Thursday, July 28, 2016 12:52 PM


To: Water-Inspection-Report

Cc: McCabe, Kerri **Subject:** ar0039992

Attachments: IMG_20160728_0002.pdf

Kerri, I am not sure on the discrepancies' with the 2017 inspection comments. It was on the diagram submitted with permit renewal, but anyway the attached drawing shows old existing structure prior to 1986 filter installation. The inlet valve to the flume is locked shut and only opened when severe rain event to bypass plant and prevent levee breach. Our I and I is so severe that it has been open during these events in past.

Upon further investigation on October 2015, it appears inspector is correct and lab was not conducted on the two days required that week. I reviewed calendar for last year and I(Supervisor) was on vacation that week and its is obvious lead operator did not conduct lab as part of his duties. Even so some days we did not discharge, I returned and reviewed lab bench sheets and lab was not done and I failed to review effluent log and just assumed was shut down the entire week and lab would not be required. This is only time lab/sampling has not been conducted in the 14 years I have been Supervisor and will not happen again.



McCabe, Kerri

From: Mike Spencer <menawwtp@gmail.com>

Sent: Thursday, July 28, 2016 1:11 PM

To:Reiber, LorettaCc:McCabe, KerriSubject:FW: ar0039992

Loretta, If you will read Kerri's email we have in the past had to utilized our bypass in the event of a levee breach and bypass out of the old partial flume. We as you know are rated at 3.1 MGD and in rain events our flow is up at 4.5 MGD and usually stays that high 3 to 4 days after the rain stops. We maintain low freeboard to accept the hydraulic overload and try to keep water in lagoons, but it gets too high to contain we must bypass. Our formula has us at 600% percent I and I. We have reported bypasses in past but some were reported electronically and on SSO page and ADEQ may/or may not have seen them. I have been instructed to report these via normal channels and follow up with letter. As Kerri has stated this might need addressed in new permit.

From: McCabe, Kerri [mailto:MCCABE@adeq.state.ar.us]

Sent: Thursday, July 28, 2016 12:58 PM

To: Mike Spencer

Subject: RE: ar0039992

Mike,

I saw your flow diagram during a review of the renewal permit. Be sure that Shane puts some comment that allows to use this structure during severe weather; it will be a permission to bypass. It will probably need to have "optional" reported with it. Without that documentation, these releases to protect levee integrity are unpermitted. ADEQ has made cities remove structures of this type, but I see the value in them (particularly lagoon systems). I just want to make sure the City of Mena is covered in their permit.

Kerri McCabe

Inspector Supervisor

ADEQ – Water Division

Field Services – Inspection Branch

Office – (501) 682-0642 Work Cell – (501) 352-5641 Fax – (501) 682-0880 5301 Northshore Drive North Little Rock, AR 72118-5317



From: Mike Spencer [mailto:menawwtp@gmail.com]

Sent: Thursday, July 28, 2016 12:52 PM

To: Water-Inspection-Report

Cc: McCabe, Kerri Subject: ar0039992

Kerri, I am not sure on the discrepancies' with the 2017 inspection comments. It was on the diagram submitted with permit renewal, but anyway the attached drawing shows old existing structure prior to 1986 filter installation. The inlet valve to the flume is locked shut and only opened when severe rain event to bypass plant and prevent levee breach. Our I and I is so severe that it has been open during these events in past.

Upon further investigation on October 2015, it appears inspector is correct and lab was not conducted on the two days required that week. I reviewed calendar for last year and I(Supervisor) was on vacation that week and its is obvious lead operator did not conduct lab as part of his duties. Even so some days we did not discharge, I returned and reviewed lab bench sheets and lab was not done and I failed to review effluent log and just assumed was shut down the entire week and lab would not be required. This is only time lab/sampling has not been conducted in the 14 years I have been Supervisor and will not happen again.



October 13, 2016

Mike Spencer, Wastewater Supervisor City of Mena 323 Polk 53 Mena, AR 71953

Re: Response to Inspections – City of Mena (Polk Co)

AFIN: 57-00423 NPDES Permit No.: AR0036392

ARR150000

Dear Mr. Spencer:

I have reviewed the response pertaining to my April 6, 2016 inspections of your wastewater treatment facility and the Small Construction Site associated with the geotube staging area. The information provided sufficiently addresses the violations referenced in my inspection report. Please be advised that any future construction work at the plant that disturbs over one acre of soil requires the Construction General Permit (CGP; ARR150000). The contractor for the City addressed concerns associated with the AR0036392C permit, which authorizes modification to the treatment system only. The Small Construction site inspection violations were never addressed; however, the site was in final stabilization during the time of the inspection. At this time, the Department has no further comment concerning this particular inspection. Acceptance of this response by the Department does not preclude any future enforcement action deemed necessary at this site or any other site.

If we need further information concerning this matter, we will contact you. Thank you for your attention to this matter. Should you have any questions, feel free to contact me at (501) 682-0642 or you may e-mail me at mccabe@adeq.state.ar.us.

Sincerely,

Kerri McCabe Inspector Supervisor Compliance Branch

Kerri McCaly

Office of Water Quality