

September 22, 2016

Michael L. Hohnadel, Vice Pres. of Manufacturing Georgia Pacific, LLC Crossett Operations P.O. Box 3333 Crossett, AR 71635

RE: Georgia Pacific, LLC-Crossett Inspection (Ashley Co)

AFIN: 02-00013 NPDES Permit No.: AR0001210

Dear Mr. Hohnadel:

On September 7, 2016, I performed a Compliance Evaluation Inspection of the above-referenced facility in accordance with the provisions of the Federal Clean Water Act, the Arkansas Water and Air Pollution Control Act, and the regulations promulgated thereunder. A copy of the inspection report is enclosed for your records.

Please refer to the "Summary of Findings" section of the attached inspection report and provide a written response for each violation that was noted. This response should be mailed to the attention of the Water Division Inspection Branch at the address at the bottom of this letter or e-mailed to Water-Inspection-Report@adeq.state.ar.us. This response should contain documentation describing the course of action taken to correct each item noted. This corrective action should be completed as soon as possible, and the written response with all necessary documentation (i.e., photos) is due by October 6, 2016.

If I can be of any assistance, please contact me at youngm@adeq.state.ar.us or (501) 837-2073.

Sincerely,

Michael Young

District 8 Field Inspector

Mindy

Water Division

	· · · · · · · · · · · · · · · · · · ·		•						
	VDEO		WATER I	DIVISION INSPECTION REPORT					
	ADLU	AF	IN: 02-00013 PI	ERMIT #: AR000 1	210		DATE: 9/7/2016		
Δ	RKANSAS	CC	UNTY: 02 Ashle	y	PDS	#: 092853		MEDIA: WN	
Dep	partment of Environmental Quality	GP	S LAT: 33.13639	3 LONG: -91.967	238	LOCATION: E	Entrance	9	
	FACILITY INFORMAT	ION		IN	SPEC	CTION INFOR	MATION	N	
	orgia Pacific, LLC-Crossett			FACILITY TYPE: 2 - Industrial	-	ctor id#: 531 S - State)		
100 CITY:	Mill Supply Road			FACILITY EVALUATION RATING 4 - Satisfactory	G:		rion TYPE: ipliance	Evaluation	
	ossett, AR			(-)	ITRY TIME 9:02	: EXIT TIME: 17:02		FECTIVE DATE:	
	RESPONSIBLE OFFIC	CIAL		3/1/2010 0	3.02	17.02	9/30/2	2010 (PIRATION DATE:	
	: / TITLE						10/31/		
COM	chael L. Hohnadel / Vice Pres. of	ivia	nutacturing	FAYETTEVILLE SHALE RELATED: N					
	orgia Pacific, LLC			FAYETTEVILLE SHALE VIOLATIONS: N					
	NG ADDRESS:			INSPECTION PARTICIPANTS					
	ossett Operations P.O. Box 3333			NAME/TITLE/PHONE/FAX/EMAIL/ETC.:					
. ,	ossett AR 71635			Rachel Johnson/ Environmental Engineer/870-567-					
	IE & EXT: / FAX:			8170					
870	0-567-8144 /			Sarah Ross/Environmental Manager/870-567-8170					
EMAII		Tobin Fulmer/ADE		DEQ	District 8 Wa	ater Insp	ector		
CC	NTACTED DURING INSPECTION:	No							
AREA EVALUATIONS (S=Satisfactory, M=Marginal, U=Unsatisfactory, N=Not Applicable/Evaluated)					ed)				
S	PERMIT	M	FLOW MEASUR	REMENT	S	STORMWA	ATER		
S	RECORDS/REPORTS	S	LABORATORY		S	FACILITY	SITE RE	VIEW	
S	OPERATION & MAINTENANCE	S	EFFLUENT/REC	CEIVING WATER	S	SELF-MON	NITORIN	G PROGRAM	
M	SAMPLING	S	SLUDGE HAND	LING/DISPOSAL	S	PRETREA	TMENT		
**	OTHER:								

1.) Samples collected at Outfall 001 are transported to the laboratory without being maintained at 6°C for the entirety of transport. This is a violation of 40 CFR 136 Table II Footnote 2. SEE SAMPLE PRESERVATION COMMENTS.

SUMMARY OF FINDINGS

2.) Flow is being reported as a calculated flow for Internal Outfalls 101, 102, and 103. The permitted same type for these outfalls is instantaneous. This is a violation of permit condition Part III. (C.) (2.). SEE FLOW REPORTING COMMENTS.

GENERAL COMMENTS

On September 7, 2016 I performed a Compliance Evaluation Inspection at Georgia-Pacific (G-P) Crossett with Tobin Fulmer, ADEQ District 8 Water Inspector. I completed the inspection with Sarah Ross, G-P Environmental Manager, and Rachel Johnson, G-P Environmental Engineer.

SAMPLE PRESERVATION COMMENTS:

During the inspection; the collection, preservation, and analysis of samples at G-P Crossett was thoroughly discussed. The samples from Outfall 001 are collected by a composite sampler into a glass jug that collects a 24-hour composite sample that is composited according to flow. The samples are then transported to the G-P lab ~6 miles away from the outfall. During the transport, the samples cannot be ensured that they are maintaining ≤6°C because they are not being transported on ice or under refrigerated conditions. The regulation that samples maintain ≤6°C can be found in 40 CFR 136 Table 2. Also, be aware that samples requiring preservation using an additive (i.e., sulfuric acid, nitric acid, etc.) is quoted from Footnote 2 as follows, "Add the preservative to the sample container prior to sample collection when the preservative will not compromise the integrity of a grab sample, a composite sample, or an aliquot split from a composite sample; otherwise, preserve the grab sample, composite sample, or aliquot split from a composite sample within 15 minutes of collection." Additionally, I recommended that the laboratory log the temperature of samples when they arrive at the lab and prior to being refrigerated for analysis or packaged for shipping.

FLOW REPORTING COMMENTS:

There are three internal outfalls at G-P Crossett that are monitored under permit AR0001210. According to the permit, the sample type at these outfalls for flow is an instantaneous measurement. On the DMRs submitted, the facility indicates TOTALIZED flow as the sample type with a notation that "[...] totalized means a 24-hour average daily flow based on multiple totalized and estimated flows." Reporting of this flow was demonstrated to be based on a calculation and according to permit condition Part III. (C.) (2.), "Appropriate flow measurement devices and methods consistent with accepted scientific practices shall be selected and used to ensure the accuracy and reliability of measurements of the volume of monitored discharges." The facility needs to change the sample type for the internal outfalls to calculated and submit the formulation for calculation to ADEQ Water Division Permits Branch.

CITY OF CROSSETT CONTRACT COMMENTS:

Georgia-Pacific Crossett and the City of Crossett have an agreement that G-P will receive treated effluent from the city. The treated wastewater from the City of Crossett is then discharged through Outfall 001 and SMS 002 and sampled according to the G-P permit. The agreement has TSS and CBOD5 limits that the city must meet and requirements for sampling and reporting results to G-P. During the inspection, Sarah Ross, Rachel Johnson, Tobin Fulmer, and I visited the City of Crossett and met with Jeff Harrison, City of Crossett Public Works Director. I inspected the documentation maintained by the City of Crossett and the facility that is used to treat wastewater. The City of Crossett maintains a collection system that contains nine (9) lift stations. The wastewater in Crossett is gravity fed to the lift stations, enters force mains, and is then discharged to the main lift station at the City's wastewater treatment lagoons (see Figure 1). The city maintains a two-cell lagoon system with baffle curtains in both lagoon cells (see Figure 1). During the inspection, the ponds were in operation and the levees had no deterioration that was observed. Flow is measured at a location prior to being gravity fed to the G-P effluent stream (see Figure 1). Flow is being measured using an improper secondary device (see Photos 1-3). Flow at this facility during the month of August 2016 ranged from flows of 0.12 MGD to 3.80 MGD. The design of this treatment system is stated to be 1 MGD. High flows of 3+ MGD are in association with rainfall recorded by the facility. Infiltration and inflow (I&I) issues may be causing the variations in flow, and a collection system inspection may be needed in the future to determine if sanitary sewer overflows (SSOs) are frequent and whether the system is able to operate efficiently during high flow events and storm events. There is no reporting requirement for SSOs in the City of Crossett or with the G-P permit.

Mille		
INSPECTOR'S SIGNATURE:	Michael Young	DATE: 9/21/2016
Kerr	i Ms Coly	
SUPERVISOR'S SIGNATURE:	Kerri McCabe	DATE: 9/22/2016

SECTION A: PERMIT VERIFICATION	
PERMIT SATISFACTORILY ADDRESSES OBSERVATIONS	☑S □M □U □NA □NE
DETAILS:	
1. CORRECT NAME AND MAILING ADDRESS OF PERMITTEE:	☑y □n □na □ne
2. NOTIFICATION GIVEN TO EPA/STATE OF NEW DIFFERENT OR INCREASED DISCHARGES:	□Y □N ☑NA □NE
3. NUMBER AND LOCATION OF DISCHARGE POINTS AS DESCRIBED IN PERMIT:	☑Y □N □NA □NE
4. ALL DISCHARGES ARE PERMITTED:	☑Y □N □NA □NE
SECTION B: RECORDKEEPING AND REPORTING EVALUATION	
RECORDS AND REPORTS MAINTAINED AS REQUIRED BY PERMIT	ØS □M □U □NA □NE
DETAILS:	
1. ANALYTICAL RESULTS CONSISTENT WITH DATA REPORTED ON DMRS:	☑Y □N □NA □NE
2. SAMPLING AND ANALYSES DATA ADEQUATE AND INCLUDE:	Øs □m □u □na □ne
a. DATES AND TIME(S) OF SAMPLING:	ØY □N □NA □NE
b. EXACT LOCATION(S) OF SAMPLING:	ØY □N □NA □NE
c. NAME OF INDIVIDUAL PERFORMING SAMPLING:	ØY □N □NA □NE
d. ANALYTICAL METHODS AND TECHNIQUES:	ØY □N □NA □NE
e. RESULTS OF CALIBRATIONS:	Øy □n □na □ne
f. RESULTS OF ANALYSES:	Øy □n □na □ne
g. DATES AND TIMES OF ANALYSES:	☑Y □N □NA □NE
h. NAME OF PERSON(S) PERFORMING ANALYSES:	☑Y □N □NA □NE
3. LABORATORY EQUIPMENT CALIBRATION AND MAINTENANCE RECORDS ADEQUATE:	ØS □M □U □NA □NE
4. PLANT RECORDS INCLUDE SCHEDULES, DATES OF EQUIPMENT MAINTENANCE AND REPAIR:	ØS □M □U □NA □NE
5. EFFLUENT LOADINGS CALCULATED USING DAILY EFFLUENT FLOW AND DAILY ANALYTICAL DATA:	Øy □n □na □ne
SECTION C: OPERATIONS AND MAINTENANCE	
TREATMENT FACILITY PROPERLY OPERATED AND MAINTAINED	☑S □M □U □NA □NE
DETAILS:	
TREATMENT UNITS PROPERLY OPERATED:	⊠s □m □u □na □ne
2. TREATMENT UNITS PROPERLY MAINTAINED:	⊠S □M □U □NA □NE
3. STANDBY POWER OR OTHER EQUIVALENT PROVIDED:	⊠S □M □U □NA □NE
4. ADEQUATE ALARM SYSTEM FOR POWER OR EQUIPMENT FAILURES AVAILABLE:	ØS □M □U □NA □NE
5. ALL NEEDED TREATMENT UNITS IN SERVICE:	ØS □M □U □NA □NE
6. ADEQUATE NUMBER OF QUALIFIED OPERATORS PROVIDED:	Øs □m □u □na □ne
7. SPARE PARTS AND SUPPLIES INVENTORY MAINTAINED:	⊠S □M □U □NA □NE
8. OPERATION AND MAINTENANCE MANUAL AVAILABLE:	☑Y □N □NA □NE
9. STANDARD OPERATING PROCEDURES AND SCHEDULES ESTABLISHED:	☑Y □N □NA □NE
10. PROCEDURES FOR EMERGENCY TREATMENT CONTROL ESTABLISHED:	☑Y □N □NA □NE
11. HAVE BYPASSES/OVERFLOWS OCCURRED AT THE PLANT OR IN THE COLLECTION SYSTEM IN THE LAST YEAR: March event	flood ☑Y □N □NA □NE
12. IF SO, HAS THE REGULATORY AGENCY BEEN NOTIFIED:	Øy □n □na □ne
13. HAS CORRECTIVE ACTION BEEN TAKEN TO PREVENT ADDITIONAL BYPASSES/OVERFLOWS:	Øy □n □na □ne
14. HAVE ANY HYDRAULIC OVERLOADS OCCURRED AT THE TREATMENT PLANT:	Øy □n □na □ne
15. IF SO, DID PERMIT VIOLATIONS OCCUR AS A RESULT:	Øy □n □na □ne

SECTION D: SAMPLING	
PERMITTEE SAMPLING MEETS PERMIT REQUIREMENTS	□S ☑M □U □NA □NE
DETAILS:	
SAMPLES TAKEN AT SITE(S) SPECIFIED IN PERMIT:	☑Y □N □NA □NE
LOCATIONS ADEQUATE FOR REPRESENTATIVE SAMPLES:	✓Y □N □NA □NE
FLOW PROPORTIONED SAMPLES OBTAINED WHEN REQUIRED BY PERMIT:	MY ON ONA ONE
SAMPLING AND ANALYSES COMPLETED ON PARAMETERS SPECIFIED IN PERMIT:	✓Y □N □NA □NE
SAMPLING AND ANALYSES PERFORMED AT FREQUENCY SPECIFIED IN PERMIT:	☑Y □N □NA □NE
SAMPLE COLLECTION PROCEDURES ADEQUATE:	☑Y □N □NA □NE
a. SAMPLES REFRIGERATED DURING COMPOSITING:	MY ON ONA ONE
b. PROPER PRESERVATION TECHNIQUES USED: Transport samples from Outfall 001 on ice.	□Y ØN □NA □NE
c. CONTAINERS AND SAMPLE HOLDING TIMES CONFORM TO 40 CFR 136:	MY ON ONA ONE
7. IF MONITORING IS PERFORMED MORE OFTEN THAN REQUIRED ARE RESULTS REPORTED ON THE DMR:	□Y □N ØNA □NE
SECTION E: FLOW MEASUREMENT	
PERMITTEE FLOW MEASUREMENT MEETS PERMIT REQUIREMENTS	☑S □M □U □NA □NE
DETAILS: Outfall 001	
1. PRIMARY FLOW MEASUREMENT DEVICE PROPERLY INSTALLED AND MAINTAINED: TYPE OF DEVICE: Parshall flume	☑Y □N □NA □NE
2. FLOW MEASURED AT EACH OUTFALL AS REQUIRED:	Øy □n □na □ne
3. SECONDARY INSTRUMENTS (TOTALIZERS, RECORDERS, ETC.) PROPERLY OPERATED AND MAINTAINED: Totalizer	☑Y □N □NA □NE
4. CALIBRATION FREQUENCY ADEQUATE:	☑Y □N □NA □NE
5. RECORDS MAINTAINED OF CALIBRATION PROCEDURES:	☑Y □N □NA □NE
6. CALIBRATION CHECKS DONE TO ASSURE CONTINUED COMPLIANCE:	Øy □n □na □ne
7. FLOW ENTERING DEVICE WELL DISTRIBUTED ACROSS THE CHANNEL AND FREE OF TURBULENCE:	☑Y □N □NA □NE
8. FLOW MEASUREMENT EQUIPMENT ADEQUATE TO HANDLE EXPECTED RANGE OF FLOW RATES:	☑Y □N □NA □NE
9. HEAD MEASURED AT PROPER LOCATION:	☑Y □N □NA □NE
SECTION E: FLOW MEASUREMENT	
PERMITTEE FLOW MEASUREMENT MEETS PERMIT REQUIREMENTS	□S □M □U □NA ☑NE
DETAILS: SMS 002; monitoring station was in flood stage (+62') and not being mon	nitored.
10. PRIMARY FLOW MEASUREMENT DEVICE PROPERLY INSTALLED AND MAINTAINED: TYPE OF DEVICE:	□y □n □na ☑ne
11. FLOW MEASURED AT EACH OUTFALL AS REQUIRED:	□Y □N □NA ☑NE
12. SECONDARY INSTRUMENTS (TOTALIZERS, RECORDERS, ETC.) PROPERLY OPERATED AND MAINTAINED:	□y □n □na ☑ne
13. CALIBRATION FREQUENCY ADEQUATE:	□y □n □na ☑ne
14. RECORDS MAINTAINED OF CALIBRATION PROCEDURES:	□y □n □na ☑ne
15. CALIBRATION CHECKS DONE TO ASSURE CONTINUED COMPLIANCE:	□y □n □na ☑ne
16. FLOW ENTERING DEVICE WELL DISTRIBUTED ACROSS THE CHANNEL AND FREE OF TURBULENCE:	□Y □N □NA ☑NE
17. FLOW MEASUREMENT EQUIPMENT ADEQUATE TO HANDLE EXPECTED RANGE OF FLOW RATES:	□y □n □na ☑ne
18. HEAD MEASURED AT PROPER LOCATION:	□Y □N □NA ☑NE
SECTION E: FLOW MEASUREMENT	
PERMITTEE FLOW MEASUREMENT MEETS PERMIT REQUIREMENTS	□S □M ☑U □NA □NE
DETAILS: Internal Outfalls 101, 102, and 103.	
19. PRIMARY FLOW MEASUREMENT DEVICE PROPERLY INSTALLED AND MAINTAINED: TYPE OF DEVICE: Flow is calculated estimated	ed and Y VN DNA DNE
20. FLOW MEASURED AT EACH OUTFALL AS REQUIRED:	☑Y □N □NA □NE
21. SECONDARY INSTRUMENTS (TOTALIZERS, RECORDERS, ETC.) PROPERLY OPERATED AND MAINTAINED:	□Y □N ☑NA □NE
22. CALIBRATION FREQUENCY ADEQUATE:	
<u> </u>	□Y □N ☑NA □NE
23. RECORDS MAINTAINED OF CALIBRATION PROCEDURES:	□Y □N ☑NA □NE
23. RECORDS MAINTAINED OF CALIBRATION PROCEDURES: 24. CALIBRATION CHECKS DONE TO ASSURE CONTINUED COMPLIANCE:	
	□Y □N ØNA □NE
24. CALIBRATION CHECKS DONE TO ASSURE CONTINUED COMPLIANCE:	□Y □N ☑NA □NE
24. CALIBRATION CHECKS DONE TO ASSURE CONTINUED COMPLIANCE: 25. FLOW ENTERING DEVICE WELL DISTRIBUTED ACROSS THE CHANNEL AND FREE OF TURBULENCE: Closed pipe	OY ON MA ONE OY ON ONA MAE

SECTION F: LABORATORY	
PERMITTEE LABORATORY PROCEDURES MEET PERMIT REQUIREMENTS	⊠S □M □U □NA □NE
DETAILS: G-P Lab analyzes BOD5, TSS, pH, and TRC for WET Testing	
1. EPA APPROVED ANALYTICAL PROCEDURES USED (40 CFR 136.3 FOR LIQUIDS, 503.8(B) FOR SLUDGES):	☑y □n □na □ne
2. IF ALTERNATIVE ANALYTICAL PROCEDURES ARE USED, PROPER APPROVAL HAS BEEN OBTAINED:	☑Y ☐N ☐NA ☐NE
3. SATISFACTORY CALIBRATION AND MAINTENANCE OF INSTRUMENTS AND EQUIPMENT:	☑Y ☐N ☐NA ☐NE
4. QUALITY CONTROL PROCEDURES ADEQUATE:	☑Y □N □NA □NE
5. DUPLICATE SAMPLES ARE ANALYZED ≥10% OF THE TIME:	☑y □n □na □ne
6. SPIKED SAMPLES ARE ANALYZED ≥10% OF THE TIME:	☑y □n □na □ne
7. COMMERCIAL LABORATORY USED:	☑Y ☐N ☐NA ☐NE
a. LAB NAME: Summit Environmental Technologies/Environ/American Interplex/Test America	
b. LAB ADDRESS: 3310 Win Street Cuyahoga Falls, OH 44223/Brentwood, TN/Savannah, GA	
c. PARAMETERS PERFORMED: AOX, Dioxin, Chloroform, Chlorinated Phenolics/WET Testing/Metals, Nutrients, Pesticides/Color	
8. BIOMONITORING PROCEDURES ADEQUATE:	☑y □n □na □ne
a. PROPER ORGANISMS USED:	☑Y □N □NA □NE
b. PROPER DILUTION SERIES FOLLOWED:	☑Y □N □NA □NE
c. PROPER TEST METHODS AND DURATION:	☑Y □N □NA □NE
d. RETESTS AND/OR TRE PERFORMED AS REQUIRED:	☑Y □N □NA □NE

	inspection Report. Georgia Pacific, LLC-Crossett, AFIN. 02-00013, Permit #. AR0001210									
	SECTION G: EFFLUENT/RECEIVING WATERS OBSERVATIONS									
BASED ON VISUAL OBSERVATIONS ONLY										
DETAILS:										
OUT	FALL #:	OIL SHEEN	GREASE	TURBIDITY	VISIBLE FOAM	FLOATING SOLIDS	COLOR	OTHER		
	001	N	N	N	N	N	Dark/Tannic			
SI	MS 002	NE	NE	NE	NE	NE	NE	Flood Stage		
	rnal 101, and 103	NE	NE	NE	NE	NE	NE	Hazardous observation		
102	una 100							observation		
						<u> </u>	<u> </u>			
SEC	CTION H	: SLUDGE DIS	POSAL							
SLI	JDGE D	ISPOSAL ME	ETS PERMIT R	EQUIREMENT	ΓS		ØS DM D	U □NA □NE		
DE.	TAILS:									
		ANAGEMENT ADEQU	ATE TO MAINTAIN EFF	FLUENT QUALITY:			⊠s □m	□u □na □ne		
2.	SLUDGE RI	ECORDS MAINTAINED	O AS REQUIRED BY 40	CFR 503:			⊠s □m	□U □NA □NE		
3.	FOR LAND	APPLIED SLUDGE, TY	PE OF LAND APPLIED	TO: (E.G., FOREST,	AGRICULTURAL, PUE	BLIC CONTACT SITE):				
SEC	CTION I:	SAMPLING IN	SPECTION PRO	CEDURES						
SAI	MPLE R	ESULTS WITH	HIN PERMIT RI	EQUIREMENT	S			U ⊠NA □NE		
DE.	TAILS:					1				
1.	SAMPLES (OBTAINED THIS INSPI	ECTION:				□Y	□n Øna □ne		
2.	TYPE OF S	AMPLE: ☐GRAB:	□COMPOSITE: M	IETHOD: FREQUE	NCY:					
3.	SAMPLES F	PRESERVED:					□Y	□n Øna □ne		
4.	FLOW PRO	PORTIONED SAMPLE	S OBTAINED:				□Y	□n Øna □ne		
5.	SAMPLE O	BTAINED FROM FACIL	LITY'S SAMPLING DEV	ICE:			□Y	□n ☑na □ne		
6.	SAMPLE RI	EPRESENTATIVE OF	VOLUME AND NATURE	OF DISCHARGE:			□Y	□n ☑na □ne		
7.	SAMPLE SE	PLIT WITH PERMITTE	E:				□Y	□n ☑na □ne		
8.	CHAIN-OF-	CUSTODY PROCEDUI	RES EMPLOYED:				□Y	□n ☑na □ne		
9.	SAMPLES (COLLECTED IN ACCO	RDANCE WITH PERMI	T:			□Y	□n ☑na □ne		
SEC	CTION J	: STORM WATI	ER POLLUTION	PREVENTION	PLAN					
STO	ORM W	ATER MANAG	EMENT MEET	S PERMIT RE	QUIREMENTS		⊠S □M □	U □NA □NE		
DE.	TAILS:									
1.	SWPPP UP	DATED AS NEEDED:_	_ DATE OF LAST UP	DATE: June 2016			✓Y	□N □NA □NE		
2.	SITE MAP I	NCLUDING ALL DISCH	HARGES AND SURFAC	CE WATERS:			✓Y	□N □NA □NE		
3.	. POLLUTION PREVENTION TEAM IDENTIFIED:									
4.	POLLUTION PREVENTION TEAM PROPERLY TRAINED:									
5.	i. LIST OF POTENTIAL POLLUTANT SOURCES: ☑Y □N □NA □NE									
6.	LIST OF PC	TENTIAL SOURCES A	AND PAST SPILLS AND) LEAKS:			✓Y	□N □NA □NE		
7.	ALL NON-S	TORM WATER DISCH	ARGES ARE AUTHOR	IZED:			✓Y	□N □NA □NE		
8.	LIST OF ST	RUCTURAL BMPS:					✓Y	□N □NA □NE		
9.	LIST OF NO	ON-STRUCTURAL BMF	PS:				✓Y	□N □NA □NE		
10.	BMPS PRO	PERLY OPERATED A	ND MAINTAINED:				✓Y	□N □NA □NE		
11.	INSPECTIO	NS CONDUCTED AS I	REQUIRED:				✓Y	□N □NA □NE		

	F	FLOW CALCULAT	**					
Date: 09/07/2016 Time: 15:22								
Head in Inches: 19.75 Feet: 1.64								
Type & Size	e of Primary Flow N	Measurement Dev	rice: 8 foc	t Parsha	II flume			
Name & Mo	odel of Secondary F	Flow Measuremer	nt Device:	Milltro	nics OCM II			
Date of last	Calibration of Sec	ondary Flow Devi	ce: Mo	nthly/Dai	ily			
Recorded F	low at Date & Time	e Listed Above:	43.88		(Facility Flow Meter)			
Calculated	Flow at Date & Tim	ne Listed Above:	45.79					
Flow is calculat	ed using flow charts in: IS	CO Open Channel Flow	Measureme	nt Handbook-	5 th Edition)			
% Error =	Recorded Value	- Calculated Value	/alue X	100				
	Calcul	lateu value						
% Error =	43.88	- 45.79 45.79	x	100				
	•	+5.7 9						
% Error =	-1.91 45.79	X 100						
% Error =	0.04	X 100						
	<u> </u>							
% Error =	4	%						
Comments: Within 10%								

DMR Calculation Check

Reporting Period:	From	2016	06	01	_ To	2016	06	30
		Year	Month	Day		Year	Month	Day

	Loading Mass	Concentration Monthly			
	Mo. Avg Ibs/day	Mo. Avg mg/l	7-day Avg mg/l		
Reported Value:	6320	15	27		
Calculated Value:	6320	15	27		
Permit Value:	37720	119.6	222.4		

If calculated value does not equal reported value, explain:

<u>Equal</u>

DMR Calculation Check

Reporting Period:	From	2016	03	01	То	2016	03	31
		Year	Month	Day		Year	Month	Day

Phosphorus as P **Parameter Checked:**

	Loading Mass		entration onthly
	Mo. Avg Ibs/day	Mo. Avg mg/l	7-day Avg mg/l
Reported Value:	326.0	0.78	0.97
Calculated Value:	326.0	0.78	0.97
Permit Value:	Req. Monthly	Req. Monthly	Req. Monthly

If calculated value does not equal reported value, explain:

<u>Equal</u>

Water Division Photographic Evidence Sheet								
Location: (Location: Georgia Pacific, LLC-Crossett							
Photograph	Photographer: Michael Young Date: 09/07/2016 Time: 1							
Witness: T	Witness: Tobin Fulmer; Sarah Ross; Rachel Johnson; Jeff Harrison Photo #: 1							
Description:	Description: Secondary device designed by the facility to provide a reading from primary device							



 Photographer:
 Michael Young
 Date:
 09/07/2016
 Time:
 14:30

 Witness:
 Tobin Fulmer; Sarah Ross; Rachel Johnson; Jeff Harrison
 Photo #:
 2

 Description:
 White PVC is a "stilling well" where secondary flow measurements are achieved.






Figure 1. City of Crossett wastewater lagoons. Cell 1 has a baffle curtain installed throughout the entirety of the lagoon. Cell 2 has baffle curtains that separate the water into four (4) sections. Flow is

measured prior to being discharged to G-P effluent stream.



From: Johnson, Rachel M. (Crossett)

To: Water-Inspection-Report

Cc: Young, Michael

Subject: Georgia - Pacific Crossett LLC - NPDES Permit #AR0001210

Date: Thursday, October 06, 2016 4:47:04 PM
Attachments: Response to Inspection Findings - Oct 2016.pdf

Please accept the attached letter from Georgia-Pacific Crossett LLC (NPDES Permit #AR0001210) in response to the inspection report dated September 22, 2016. Feel free to contact me if there are any questions or concerns regarding this submittal.

Sincerely, Rachel M. Johnson Environmental Engineer Crossett Paper Operation (870) 567-8170



Georgia-Pacific Crossett LLC Consumer Products

Crossett Paper Operations 100 Mill Supply Road P.O. Box 3333 Crossett, AR 71635 (870) 567-8000 (870) 364-9076 (fax) www.gp.com

October 6, 2016

Water Division – Inspection Branch Arkansas Department of Environmental Quality 5301 Northshore Drive North Little Rock, AR 72118-5317

Reference:

Georgia-Pacific Crossett LLC NPDES Permit # AR0001210

Dear Sir or Madam:

On September 7, 2016, Michael Young, District 8 Field Inspector, performed an inspection of the Georgia-Pacific Crossett Paper Operations' - NPDES Permit # **AR0001210**. Two findings were noted during the inspection and were included in the written report dated September 22, 2016. Please see below for a response to each finding.

Finding 1. Samples collected at Outfall 001 are transported to the laboratory without being maintained at 6°C for the entirety of transport. This is a violation of 40 CFR 136 Table II footnote 2.

Response to Finding 1. Coolers of ice have been utilized in transporting samples back to the lab since the date of the inspection. Sampling procedures have been updated to include the transportation of samples on ice for all samples collected at Outfall 001. This will ensure that samples are maintained at 6°C or less.

Finding 2. Flow is being reported as a calculated flow for Internal Outfalls 101, 102, and 103. The permitted sample type for these outfalls is instantaneous. This is a violation of permit condition Part III. (C.) (2.).

Response to Finding 2. This item had already been identified by the facility and has been addressed in the NPDES permit renewal process. A request was submitted to Loretta Reiber as part of our comments on the Pre-Draft Permit dated May 6, 2016 to allow calculated flow measurements from the Internal Outfalls 101, 102 and 103 in the renewal permit. Based on discussions with Ms. Reiber, the permit language will be revised to accommodate this request.

If you have any questions or need additional information, please feel free to contact Sarah Ross at (870) 567-8670 or by email at sarah.ross@gapac.com.

Sincerely,

Michael L. Hohnadel

Vice President of Manufacturing

Crossett Paper Operations

cc: Michael Young



October 14, 2016

Michael L. Hohnadel, Vice Pres. of Manufacturing Georgia Pacific, LLC Crossett Operations P.O. Box 3333 Crossett, AR 71635

RE: Response to Inspection (Ashley Co)

AFIN: 02-00013 NPDES Permit No.: AR0001210

Dear Mr. Hohnadel:

I have reviewed the response pertaining to my September 7, 2016 inspection of the Georgia-Pacific facility in Crossett, AR. The information provided sufficiently addresses the violations referenced in my inspection report. At this time, the Department has no further comment concerning this particular inspection. Acceptance of this response by the Department does not preclude any future enforcement action deemed necessary at this site or any other site.

If we need further information concerning this matter, we will contact you. Thank you for your attention to this matter. Should you have any questions, feel free to contact me at (501) 837-2073 or you may e-mail me at youngm@adeq.state.ar.us.

Sincerely,

Michael Young

District 8 Field Inspector

Water Division