



ARKANSAS
Department of Environmental Quality

December 27, 2016

Ken Nelson, Complex Manager
Tyson Poultry - Waldron Process
442 Plant Street
Waldron, AR 72958

RE: Tyson Poultry - Waldron Inspections (Scott Co)
AFIN: 64-00001 **NPDES Permit No.: AR0038482**
ARR00A080

Dear Mr. Nelson:

On November 21, 2016, I performed a Compliance Evaluation Inspection and an Industrial Stormwater Inspection of the above-referenced facility in accordance with the provisions of the Federal Clean Water Act, the Arkansas Water and Air Pollution Control Act, and the regulations promulgated thereunder. A copy of each of these inspection reports is enclosed for your records.


Please refer to the "Summary of Findings" section of each of the attached inspection reports and provide a written response for each violation that was noted. This response should be mailed to the attention of the Office of Water Quality, Compliance Branch at the address at the bottom of this letter or e-mailed to Water-Inspection-Report@adeq.state.ar.us. This response should contain documentation describing the course of action taken to correct each item noted. This corrective action should be completed as soon as possible, and the written response with all necessary documentation (i.e., photos) is due by **January 10, 2017**.

If I can be of any assistance, please contact me at grayd@adeq.state.ar.us or (479) 424-0333.

Sincerely,

A handwritten signature in purple ink that reads "Dannielle Gray". The signature is written in a cursive style with a horizontal line at the end.

Dannielle Gray
District 4 Field Inspector
Office of Water Quality

 A R K A N S A S Department of Environmental Quality		WATER DIVISION INSPECTION REPORT							
		AFIN: 64-00001		PERMIT #: AR0038482		DATE: 11/21/2016			
		COUNTY: 64 Scott			PDS #: 094538		MEDIA: WN		
		GPS LAT: 34.902936 LONG: -94.101168 LOCATION: Entrance							
FACILITY INFORMATION				INSPECTION INFORMATION					
NAME: Tyson Poultry - Waldron LOCATION: 442 Plant Street CITY: Waldron				FACILITY TYPE: 2 - Industrial		INSPECTOR ID#: 71330 S - State			
				FACILITY EVALUATION RATING: 3 - Satisfactory		INSPECTION TYPE: Compliance Evaluation			
				DATE(S): 11/21/2016		ENTRY TIME: 10:00		EXIT TIME: 16:00	
								PERMIT EFFECTIVE DATE: 10/30/2010	
RESPONSIBLE OFFICIAL NAME: / TITLE Ken Nelson / Complex Manager COMPANY: Tyson Poultry - Waldron Process MAILING ADDRESS: 442 Plant Street CITY, STATE, ZIP: Waldron AR 72958 PHONE & EXT: / FAX: 479-637-5712 / EMAIL: janice.mitchell@tyson.com CONTACTED DURING INSPECTION: Yes						PERMIT EXPIRATION DATE: 9/30/2015			
				FAYETTEVILLE SHALE RELATED: N					
				FAYETTEVILLE SHALE VIOLATIONS: N					
				INSPECTION PARTICIPANTS					
				NAME/TITLE/PHONE/FAX/EMAIL/ETC.: Janice Mitchell/Environmental Manager/479-637-5712/janice.mitchell@tyson.com Terry Nix/Wastewater Supervisor/terry.nix@tyson.com Kenneth Nelson/Complex Manager/ken.jones@tyson.com Eddie Jones/Plant Manager					
AREA EVALUATIONS									
(S=Satisfactory, M=Marginal, U=Unsatisfactory, N=Not Applicable/Evaluated)									
S	PERMIT	S	FLOW MEASUREMENT	S	STORMWATER				
U	RECORDS/REPORTS	S	LABORATORY	S	FACILITY SITE REVIEW				
S	OPERATION & MAINTENANCE	M	EFFLUENT/RECEIVING WATER	S	SELF-MONITORING PROGRAM				
S	SAMPLING	S	SLUDGE HANDLING/DISPOSAL	**	PRETREATMENT				
**	OTHER:								
SUMMARY OF FINDINGS									
The following violations were noted during inspection: <ol style="list-style-type: none"> 1. Foam was observed in the effluent at the outfall. This is a violation of Part 1A of the permit. 2. COC does not indicate that samples are being properly preserved during transit. Specifically, there is no indication as to the type of container the samples are stored in or whether or not the samples are being preserved with ice. This is a violation of Part III, Section C.8.a of the permit. 3. Discrepancies were noted between lab analysis reports and data reported on DMRs (see General Comments below). This is a violation of Part 1A and Part III Section C.5 of the permit. Specifically, the following items must be addressed: <ol style="list-style-type: none"> a) Lab analysis sheets were unclear and contradictory. Reports indicated two separate results for samples. Following inspection, the facility clarified these reports with their lab (see General Comments below) and submitted an explanation to ADEQ via email. No further action for this sub-finding required. b) Lab results are not always being reported in the appropriate line item on DMRs. For example, effluent samples collected in March 2016 resulted in a BOD result of 2.97 mg/l and a CBOD5 Daily Maximum result of 3.44 mg/l. However, BOD results of 2.97 mg/l were reported as CBOD5 results. c) DO and pH maximums and minimums are not being consistently accurately reported (see General Comments below). 									

GENERAL COMMENTS

I inspected this facility with the above-referenced inspection participants on November 21, 2016. Ms. Mitchell and Mr. Nix accompanied me on the entire inspection. Mr. Nelson and Mr. Jones joined us for the closing conference. Inspection consisted of a facility assessment, a records audit, and an Industrial Stormwater Inspection.



Facility assessment included a tour of the facility starting at the influent house and following the path of the wastewater through the plant to the effluent outfall. The facility was clean and well-maintained. Nothing of concern was noted throughout the assessment of treatment plant components. However, persistent foam was observed at the outfall. Foaming in the oxidation ditch was consistent with typical activated sludge treatment and showed no obvious signs of oxidation ditch malfunction. Persistent foaming was not observed in the effluent box. Foam was only observed after post-aeration at the outfall and in the receiving stream. Persistent foam is a violation of the permit and can be an indicator of unseen operational issues in the treatment plant. Identifying the source of the foam and taking corrective action to cease foam discharge are required. Monitoring following any corrective actions taken to ensure that foam has ceased is advised.

Records audit revealed inconsistencies in lab analysis reports and data reported on DMRs. Upon further investigation, it was determined that there were two major contributors to the inconsistencies: unclear lab analysis reports and lack of attention to detail.

Lab analysis reports were unclear; and therefore, determining which results were effluent results and which results were process control results was difficult. Numbers included on the "DMR Calculation Check" sheets below were taken from these lab reports. As noted on the check sheets, my interpretation of the results and the Operator's interpretation of the results were different. Therefore, clarification of data on these reports is necessary.

Following inspection, the Operator submitted an explanation of the report indicating that he had spoken to the lab and understood the information provided on the report. As per his explanation, the lab provides two reports for samples collected at the outfall. The "certified report" states actual lab results of the samples. The "process control report" rounds the data results for operational use and treatment plant troubleshooting. As per the operator, process control reports will be removed from DMR files to avoid confusion. No further action required for this finding.

The other contributor to DMR inconsistencies identified during inspection was lack of attention to detail. As noted in the "Summary of Findings" above, records reviewed for the March 2016 reporting period revealed that BOD was being reported as CBOD on the DMR. DO and pH maximums and minimums were also misreported in some cases, but not all. On some DMRs, the facility reported the second to lowest DO or the second to lowest minimum (or second highest) pH instead of the true minimum or maximum. Records audited revealed that all values for the months audited were within effluent limits and reporting the true minimum and maximum would not have resulted in an effluent violation. Therefore, incorrect reporting was determined to be a result of lack of attention to detail when reporting effluent data on DMRs. Attention to detail must be exercised when reviewing these results and reporting the data on DMRs.

INSPECTOR'S SIGNATURE:  Dannielle Gray	DATE: 12/8/2016
SUPERVISOR'S SIGNATURE:  Kerri McCabe	DATE: 12/22/2016

SECTION A: PERMIT VERIFICATION

PERMIT SATISFACTORILY ADDRESSES OBSERVATIONS

☒S ☐M ☐U ☐NA ☐NE

DETAILS:

- | | |
|--|--|
| 1. CORRECT NAME AND MAILING ADDRESS OF PERMITTEE: | <input checked="" type="checkbox"/> Y <input type="checkbox"/> N <input type="checkbox"/> NA <input type="checkbox"/> NE |
| 2. NOTIFICATION GIVEN TO EPA/STATE OF NEW DIFFERENT OR INCREASED DISCHARGES: | <input type="checkbox"/> Y <input type="checkbox"/> N <input checked="" type="checkbox"/> NA <input type="checkbox"/> NE |
| 3. NUMBER AND LOCATION OF DISCHARGE POINTS AS DESCRIBED IN PERMIT: | <input checked="" type="checkbox"/> Y <input type="checkbox"/> N <input type="checkbox"/> NA <input type="checkbox"/> NE |
| 4. ALL DISCHARGES ARE PERMITTED: | <input checked="" type="checkbox"/> Y <input type="checkbox"/> N <input type="checkbox"/> NA <input type="checkbox"/> NE |

SECTION B: RECORDKEEPING AND REPORTING EVALUATION

RECORDS AND REPORTS MAINTAINED AS REQUIRED BY PERMIT

☒S ☐M ☐U ☐NA ☐NE

DETAILS:

- | | |
|--|---|
| 1. ANALYTICAL RESULTS CONSISTENT WITH DATA REPORTED ON DMRS: | <input type="checkbox"/> Y <input checked="" type="checkbox"/> N <input type="checkbox"/> NA <input type="checkbox"/> NE |
| 2. SAMPLING AND ANALYSES DATA ADEQUATE AND INCLUDE: | <input checked="" type="checkbox"/> S <input type="checkbox"/> M <input type="checkbox"/> U <input type="checkbox"/> NA <input type="checkbox"/> NE |
| a. DATES AND TIME(S) OF SAMPLING: | <input checked="" type="checkbox"/> Y <input type="checkbox"/> N <input type="checkbox"/> NA <input type="checkbox"/> NE |
| b. EXACT LOCATION(S) OF SAMPLING: | <input checked="" type="checkbox"/> Y <input type="checkbox"/> N <input type="checkbox"/> NA <input type="checkbox"/> NE |
| c. NAME OF INDIVIDUAL PERFORMING SAMPLING: | <input checked="" type="checkbox"/> Y <input type="checkbox"/> N <input type="checkbox"/> NA <input type="checkbox"/> NE |
| d. ANALYTICAL METHODS AND TECHNIQUES: | <input checked="" type="checkbox"/> Y <input type="checkbox"/> N <input type="checkbox"/> NA <input type="checkbox"/> NE |
| e. RESULTS OF CALIBRATIONS: | <input checked="" type="checkbox"/> Y <input type="checkbox"/> N <input type="checkbox"/> NA <input type="checkbox"/> NE |
| f. RESULTS OF ANALYSES: | <input checked="" type="checkbox"/> Y <input type="checkbox"/> N <input type="checkbox"/> NA <input type="checkbox"/> NE |
| g. DATES AND TIMES OF ANALYSES: | <input checked="" type="checkbox"/> Y <input type="checkbox"/> N <input type="checkbox"/> NA <input type="checkbox"/> NE |
| h. NAME OF PERSON(S) PERFORMING ANALYSES: | <input checked="" type="checkbox"/> Y <input type="checkbox"/> N <input type="checkbox"/> NA <input type="checkbox"/> NE |
| 3. LABORATORY EQUIPMENT CALIBRATION AND MAINTENANCE RECORDS ADEQUATE: | <input checked="" type="checkbox"/> S <input type="checkbox"/> M <input type="checkbox"/> U <input type="checkbox"/> NA <input type="checkbox"/> NE |
| 4. PLANT RECORDS INCLUDE SCHEDULES, DATES OF EQUIPMENT MAINTENANCE AND REPAIR: | <input checked="" type="checkbox"/> S <input type="checkbox"/> M <input type="checkbox"/> U <input type="checkbox"/> NA <input type="checkbox"/> NE |
| 5. EFFLUENT LOADINGS CALCULATED USING DAILY EFFLUENT FLOW AND DAILY ANALYTICAL DATA: | <input checked="" type="checkbox"/> Y <input type="checkbox"/> N <input type="checkbox"/> NA <input type="checkbox"/> NE |

SECTION C: OPERATIONS AND MAINTENANCE

TREATMENT FACILITY PROPERLY OPERATED AND MAINTAINED

☒S ☐M ☐U ☐NA ☐NE

DETAILS:

- | | |
|---|---|
| 1. TREATMENT UNITS PROPERLY OPERATED: | <input checked="" type="checkbox"/> S <input type="checkbox"/> M <input type="checkbox"/> U <input type="checkbox"/> NA <input type="checkbox"/> NE |
| 2. TREATMENT UNITS PROPERLY MAINTAINED: | <input checked="" type="checkbox"/> S <input type="checkbox"/> M <input type="checkbox"/> U <input type="checkbox"/> NA <input type="checkbox"/> NE |
| 3. STANDBY POWER OR OTHER EQUIVALENT PROVIDED: | <input checked="" type="checkbox"/> S <input type="checkbox"/> M <input type="checkbox"/> U <input type="checkbox"/> NA <input type="checkbox"/> NE |
| 4. ADEQUATE ALARM SYSTEM FOR POWER OR EQUIPMENT FAILURES AVAILABLE: | <input checked="" type="checkbox"/> S <input type="checkbox"/> M <input type="checkbox"/> U <input type="checkbox"/> NA <input type="checkbox"/> NE |
| 5. ALL NEEDED TREATMENT UNITS IN SERVICE: | <input checked="" type="checkbox"/> S <input type="checkbox"/> M <input type="checkbox"/> U <input type="checkbox"/> NA <input type="checkbox"/> NE |
| 6. ADEQUATE NUMBER OF QUALIFIED OPERATORS PROVIDED: | <input checked="" type="checkbox"/> S <input type="checkbox"/> M <input type="checkbox"/> U <input type="checkbox"/> NA <input type="checkbox"/> NE |
| 7. SPARE PARTS AND SUPPLIES INVENTORY MAINTAINED: | <input checked="" type="checkbox"/> S <input type="checkbox"/> M <input type="checkbox"/> U <input type="checkbox"/> NA <input type="checkbox"/> NE |
| 8. OPERATION AND MAINTENANCE MANUAL AVAILABLE: | <input checked="" type="checkbox"/> Y <input type="checkbox"/> N <input type="checkbox"/> NA <input type="checkbox"/> NE |
| 9. STANDARD OPERATING PROCEDURES AND SCHEDULES ESTABLISHED: | <input checked="" type="checkbox"/> Y <input type="checkbox"/> N <input type="checkbox"/> NA <input type="checkbox"/> NE |
| 10. PROCEDURES FOR EMERGENCY TREATMENT CONTROL ESTABLISHED: | <input checked="" type="checkbox"/> Y <input type="checkbox"/> N <input type="checkbox"/> NA <input type="checkbox"/> NE |
| 11. HAVE BYPASSES/OVERFLOWS OCCURRED AT THE PLANT OR IN THE COLLECTION SYSTEM IN THE LAST YEAR: | <input type="checkbox"/> Y <input type="checkbox"/> N <input checked="" type="checkbox"/> NA <input type="checkbox"/> NE |
| 12. IF SO, HAS THE REGULATORY AGENCY BEEN NOTIFIED: | <input type="checkbox"/> Y <input type="checkbox"/> N <input checked="" type="checkbox"/> NA <input type="checkbox"/> NE |
| 13. HAS CORRECTIVE ACTION BEEN TAKEN TO PREVENT ADDITIONAL BYPASSES/OVERFLOWS: | <input type="checkbox"/> Y <input type="checkbox"/> N <input checked="" type="checkbox"/> NA <input type="checkbox"/> NE |
| 14. HAVE ANY HYDRAULIC OVERLOADS OCCURRED AT THE TREATMENT PLANT: | <input type="checkbox"/> Y <input type="checkbox"/> N <input checked="" type="checkbox"/> NA <input type="checkbox"/> NE |
| 15. IF SO, DID PERMIT VIOLATIONS OCCUR AS A RESULT: | <input type="checkbox"/> Y <input type="checkbox"/> N <input checked="" type="checkbox"/> NA <input type="checkbox"/> NE |

SECTION D: SAMPLING	
PERMITTEE SAMPLING MEETS PERMIT REQUIREMENTS	<input type="checkbox"/> S <input checked="" type="checkbox"/> M <input type="checkbox"/> U <input type="checkbox"/> NA <input type="checkbox"/> NE
DETAILS:	
1. SAMPLES TAKEN AT SITE(S) SPECIFIED IN PERMIT:	<input checked="" type="checkbox"/> Y <input type="checkbox"/> N <input type="checkbox"/> NA <input type="checkbox"/> NE
2. LOCATIONS ADEQUATE FOR REPRESENTATIVE SAMPLES:	<input checked="" type="checkbox"/> Y <input type="checkbox"/> N <input type="checkbox"/> NA <input type="checkbox"/> NE
3. FLOW PROPORTIONED SAMPLES OBTAINED WHEN REQUIRED BY PERMIT:	<input type="checkbox"/> Y <input type="checkbox"/> N <input checked="" type="checkbox"/> NA <input type="checkbox"/> NE
4. SAMPLING AND ANALYSES COMPLETED ON PARAMETERS SPECIFIED IN PERMIT:	<input checked="" type="checkbox"/> Y <input type="checkbox"/> N <input type="checkbox"/> NA <input type="checkbox"/> NE
5. SAMPLING AND ANALYSES PERFORMED AT FREQUENCY SPECIFIED IN PERMIT:	<input checked="" type="checkbox"/> Y <input type="checkbox"/> N <input type="checkbox"/> NA <input type="checkbox"/> NE
6. SAMPLE COLLECTION PROCEDURES ADEQUATE:	<input checked="" type="checkbox"/> Y <input type="checkbox"/> N <input type="checkbox"/> NA <input type="checkbox"/> NE
a. SAMPLES REFRIGERATED DURING COMPOSITING:	<input type="checkbox"/> Y <input type="checkbox"/> N <input checked="" type="checkbox"/> NA <input type="checkbox"/> NE
b. PROPER PRESERVATION TECHNIQUES USED:	<input checked="" type="checkbox"/> Y <input type="checkbox"/> N <input type="checkbox"/> NA <input type="checkbox"/> NE
c. CONTAINERS AND SAMPLE HOLDING TIMES CONFORM TO 40 CFR 136:	<input type="checkbox"/> Y <input checked="" type="checkbox"/> N <input type="checkbox"/> NA <input type="checkbox"/> NE
7. IF MONITORING IS PERFORMED MORE OFTEN THAN REQUIRED ARE RESULTS REPORTED ON THE DMR:	<input type="checkbox"/> Y <input type="checkbox"/> N <input checked="" type="checkbox"/> NA <input type="checkbox"/> NE
SECTION E: FLOW MEASUREMENT	
PERMITTEE FLOW MEASUREMENT MEETS PERMIT REQUIREMENTS	<input checked="" type="checkbox"/> S <input type="checkbox"/> M <input type="checkbox"/> U <input type="checkbox"/> NA <input type="checkbox"/> NE
DETAILS:	
1. PRIMARY FLOW MEASUREMENT DEVICE PROPERLY INSTALLED AND MAINTAINED:___ TYPE OF DEVICE:	<input checked="" type="checkbox"/> Y <input type="checkbox"/> N <input type="checkbox"/> NA <input type="checkbox"/> NE
2. FLOW MEASURED AT EACH OUTFALL AS REQUIRED:	<input checked="" type="checkbox"/> Y <input type="checkbox"/> N <input type="checkbox"/> NA <input type="checkbox"/> NE
3. SECONDARY INSTRUMENTS (TOTALIZERS, RECORDERS, ETC.) PROPERLY OPERATED AND MAINTAINED:	<input checked="" type="checkbox"/> Y <input type="checkbox"/> N <input type="checkbox"/> NA <input type="checkbox"/> NE
4. CALIBRATION FREQUENCY ADEQUATE:	<input checked="" type="checkbox"/> Y <input type="checkbox"/> N <input type="checkbox"/> NA <input type="checkbox"/> NE
5. RECORDS MAINTAINED OF CALIBRATION PROCEDURES:	<input checked="" type="checkbox"/> Y <input type="checkbox"/> N <input type="checkbox"/> NA <input type="checkbox"/> NE
6. CALIBRATION CHECKS DONE TO ASSURE CONTINUED COMPLIANCE:	<input checked="" type="checkbox"/> Y <input type="checkbox"/> N <input type="checkbox"/> NA <input type="checkbox"/> NE
7. FLOW ENTERING DEVICE WELL DISTRIBUTED ACROSS THE CHANNEL AND FREE OF TURBULENCE:	<input checked="" type="checkbox"/> Y <input type="checkbox"/> N <input type="checkbox"/> NA <input type="checkbox"/> NE
8. FLOW MEASUREMENT EQUIPMENT ADEQUATE TO HANDLE EXPECTED RANGE OF FLOW RATES:	<input checked="" type="checkbox"/> Y <input type="checkbox"/> N <input type="checkbox"/> NA <input type="checkbox"/> NE
9. HEAD MEASURED AT PROPER LOCATION:	<input checked="" type="checkbox"/> Y <input type="checkbox"/> N <input type="checkbox"/> NA <input type="checkbox"/> NE
SECTION F: LABORATORY	
PERMITTEE LABORATORY PROCEDURES MEET PERMIT REQUIREMENTS	<input checked="" type="checkbox"/> S <input type="checkbox"/> M <input type="checkbox"/> U <input type="checkbox"/> NA <input type="checkbox"/> NE
DETAILS:	
1. EPA APPROVED ANALYTICAL PROCEDURES USED (40 CFR 136.3 FOR LIQUIDS, 503.8(B) FOR SLUDGES) :	<input checked="" type="checkbox"/> Y <input type="checkbox"/> N <input type="checkbox"/> NA <input type="checkbox"/> NE
2. IF ALTERNATIVE ANALYTICAL PROCEDURES ARE USED, PROPER APPROVAL HAS BEEN OBTAINED:	<input type="checkbox"/> Y <input type="checkbox"/> N <input checked="" type="checkbox"/> NA <input type="checkbox"/> NE
3. SATISFACTORY CALIBRATION AND MAINTENANCE OF INSTRUMENTS AND EQUIPMENT:	<input checked="" type="checkbox"/> Y <input type="checkbox"/> N <input type="checkbox"/> NA <input type="checkbox"/> NE
4. QUALITY CONTROL PROCEDURES ADEQUATE:	<input checked="" type="checkbox"/> Y <input type="checkbox"/> N <input type="checkbox"/> NA <input type="checkbox"/> NE
5. DUPLICATE SAMPLES ARE ANALYZED $\geq 10\%$ OF THE TIME:	<input checked="" type="checkbox"/> Y <input type="checkbox"/> N <input type="checkbox"/> NA <input type="checkbox"/> NE
6. SPIKED SAMPLES ARE ANALYZED $\geq 10\%$ OF THE TIME:	<input checked="" type="checkbox"/> Y <input type="checkbox"/> N <input type="checkbox"/> NA <input type="checkbox"/> NE
7. COMMERCIAL LABORATORY USED:	<input checked="" type="checkbox"/> Y <input type="checkbox"/> N <input type="checkbox"/> NA <input type="checkbox"/> NE
a. LAB NAME: <u>Tyson River Valley Regional Lab</u>	
b. LAB ADDRESS: <u>PO. Box 376, Scranton, AR</u>	
c. PARAMETERS PERFORMED: <u>All with DO & pH (analyzed in-house) and Total Cu & Total Zn analyzed by Arkansas Analytical</u>	
8. BIOMONITORING PROCEDURES ADEQUATE:	<input checked="" type="checkbox"/> Y <input type="checkbox"/> N <input type="checkbox"/> NA <input type="checkbox"/> NE
a. PROPER ORGANISMS USED:	<input checked="" type="checkbox"/> Y <input type="checkbox"/> N <input type="checkbox"/> NA <input type="checkbox"/> NE
b. PROPER DILUTION SERIES FOLLOWED:	<input checked="" type="checkbox"/> Y <input type="checkbox"/> N <input type="checkbox"/> NA <input type="checkbox"/> NE
c. PROPER TEST METHODS AND DURATION:	<input checked="" type="checkbox"/> Y <input type="checkbox"/> N <input type="checkbox"/> NA <input type="checkbox"/> NE
d. RETESTS AND/OR TRE PERFORMED AS REQUIRED:	<input type="checkbox"/> Y <input type="checkbox"/> N <input checked="" type="checkbox"/> NA <input type="checkbox"/> NE

SECTION G: EFFLUENT/RECEIVING WATERS OBSERVATIONS							
BASED ON VISUAL OBSERVATIONS ONLY						<input type="checkbox"/> S <input checked="" type="checkbox"/> M <input type="checkbox"/> U <input type="checkbox"/> NA <input type="checkbox"/> NE	
DETAILS:							
OUTFALL #:	OIL SHEEN	GREASE	TURBIDITY	VISIBLE FOAM	FLOATING SOLIDS	COLOR	OTHER
001	No	No	No	YES	No	clear	--
SECTION H: SLUDGE DISPOSAL							
SLUDGE DISPOSAL MEETS PERMIT REQUIREMENTS						<input checked="" type="checkbox"/> S <input type="checkbox"/> M <input type="checkbox"/> U <input type="checkbox"/> NA <input type="checkbox"/> NE	
DETAILS:							
1. SLUDGE MANAGEMENT ADEQUATE TO MAINTAIN EFFLUENT QUALITY:						<input checked="" type="checkbox"/> S <input type="checkbox"/> M <input type="checkbox"/> U <input type="checkbox"/> NA <input type="checkbox"/> NE	
2. SLUDGE RECORDS MAINTAINED AS REQUIRED BY 40 CFR 503:						<input checked="" type="checkbox"/> S <input type="checkbox"/> M <input type="checkbox"/> U <input type="checkbox"/> NA <input type="checkbox"/> NE	
3. FOR LAND APPLIED SLUDGE, TYPE OF LAND APPLIED TO: (E.G., FOREST, AGRICULTURAL, PUBLIC CONTACT SITE): <u>N/A</u>							
SECTION I: SAMPLING INSPECTION PROCEDURES							
SAMPLE RESULTS WITHIN PERMIT REQUIREMENTS						<input type="checkbox"/> S <input type="checkbox"/> M <input type="checkbox"/> U <input checked="" type="checkbox"/> NA <input type="checkbox"/> NE	
DETAILS:							
1. SAMPLES OBTAINED THIS INSPECTION:						<input type="checkbox"/> Y <input type="checkbox"/> N <input checked="" type="checkbox"/> NA <input type="checkbox"/> NE	
2. TYPE OF SAMPLE: <input type="checkbox"/> GRAB:___ <input type="checkbox"/> COMPOSITE:___ METHOD:___ FREQUENCY:___							
3. SAMPLES PRESERVED:						<input type="checkbox"/> Y <input type="checkbox"/> N <input checked="" type="checkbox"/> NA <input type="checkbox"/> NE	
4. FLOW PROPORTIONED SAMPLES OBTAINED:						<input type="checkbox"/> Y <input type="checkbox"/> N <input checked="" type="checkbox"/> NA <input type="checkbox"/> NE	
5. SAMPLE OBTAINED FROM FACILITY'S SAMPLING DEVICE:						<input type="checkbox"/> Y <input type="checkbox"/> N <input checked="" type="checkbox"/> NA <input type="checkbox"/> NE	
6. SAMPLE REPRESENTATIVE OF VOLUME AND NATURE OF DISCHARGE:						<input type="checkbox"/> Y <input type="checkbox"/> N <input checked="" type="checkbox"/> NA <input type="checkbox"/> NE	
7. SAMPLE SPLIT WITH PERMITTEE:						<input type="checkbox"/> Y <input type="checkbox"/> N <input checked="" type="checkbox"/> NA <input type="checkbox"/> NE	
8. CHAIN-OF-CUSTODY PROCEDURES EMPLOYED:						<input type="checkbox"/> Y <input type="checkbox"/> N <input checked="" type="checkbox"/> NA <input type="checkbox"/> NE	
9. SAMPLES COLLECTED IN ACCORDANCE WITH PERMIT:						<input type="checkbox"/> Y <input type="checkbox"/> N <input checked="" type="checkbox"/> NA <input type="checkbox"/> NE	
SECTION J: STORM WATER POLLUTION PREVENTION PLAN							
STORM WATER MANAGEMENT MEETS PERMIT REQUIREMENTS						<input type="checkbox"/> S <input type="checkbox"/> M <input type="checkbox"/> U <input checked="" type="checkbox"/> NA <input type="checkbox"/> NE	
DETAILS:							
1. SWPPP UPDATED AS NEEDED:___ DATE OF LAST UPDATE:___						<input type="checkbox"/> Y <input type="checkbox"/> N <input checked="" type="checkbox"/> NA <input type="checkbox"/> NE	
2. SITE MAP INCLUDING ALL DISCHARGES AND SURFACE WATERS:						<input type="checkbox"/> Y <input type="checkbox"/> N <input checked="" type="checkbox"/> NA <input type="checkbox"/> NE	
3. POLLUTION PREVENTION TEAM IDENTIFIED:						<input type="checkbox"/> Y <input type="checkbox"/> N <input checked="" type="checkbox"/> NA <input type="checkbox"/> NE	
4. POLLUTION PREVENTION TEAM PROPERLY TRAINED:						<input type="checkbox"/> Y <input type="checkbox"/> N <input checked="" type="checkbox"/> NA <input type="checkbox"/> NE	
5. LIST OF POTENTIAL POLLUTANT SOURCES:						<input type="checkbox"/> Y <input type="checkbox"/> N <input checked="" type="checkbox"/> NA <input type="checkbox"/> NE	
6. LIST OF POTENTIAL SOURCES AND PAST SPILLS AND LEAKS:						<input type="checkbox"/> Y <input type="checkbox"/> N <input checked="" type="checkbox"/> NA <input type="checkbox"/> NE	
7. ALL NON-STORM WATER DISCHARGES ARE AUTHORIZED:						<input type="checkbox"/> Y <input type="checkbox"/> N <input checked="" type="checkbox"/> NA <input type="checkbox"/> NE	
8. LIST OF STRUCTURAL BMPS:						<input type="checkbox"/> Y <input type="checkbox"/> N <input checked="" type="checkbox"/> NA <input type="checkbox"/> NE	
9. LIST OF NON-STRUCTURAL BMPS:						<input type="checkbox"/> Y <input type="checkbox"/> N <input checked="" type="checkbox"/> NA <input type="checkbox"/> NE	
10. BMPS PROPERLY OPERATED AND MAINTAINED:						<input type="checkbox"/> Y <input type="checkbox"/> N <input checked="" type="checkbox"/> NA <input type="checkbox"/> NE	
11. INSPECTIONS CONDUCTED AS REQUIRED:						<input type="checkbox"/> Y <input type="checkbox"/> N <input checked="" type="checkbox"/> NA <input type="checkbox"/> NE	

FLOW CALCULATION SHEET

Date:	11/21/2016	Time:	1112		
Head in Inches:	4.2"	Feet:			
Type & Size of Primary Flow Measurement Device: <u>2' rectangular weir with end contractions</u>					
Name & Model of Secondary Flow Measurement Device:				<u>ISCO Teledyne Signature flowmeter</u>	
Date of last Calibration of Secondary Flow Device:				<u>May 27, 2016</u>	
Recorded Flow at Date & Time Listed Above:				593 gpm	(Facility Flow Meter)
Calculated Flow at Date & Time Listed Above:				597.4 gpm	
(Flow is calculated using flow charts in: <u>ISCO Open Channel Flow Measurement Handbook-5th Edition</u>)					
% Error =	Recorded Value	-	Calculated Value	X 100	
	Calculated Value				
% Error =	593	-	597.4	X 100	
	597.4				
% Error =	-4.4	X 100			
	597.4				
% Error =	-0.007365	X 100			
% Error =	-0.737	%			
Comments:	<u>same</u>				

Parameter Checked:	Total Nitrogen
--------------------	----------------

Water Division Photographic Evidence Sheet			
--	--	--	--

Location:	Tyson Poultry - Waldron		
Photographer:	Dannielle Gray	Date:	11/21/2016
Witness:	Janice Mitchell & Terry Nix	Time:	1032
		Photo #:	1
Description:	Influent pumps		



Photographer:	Dannielle Gray	Date:	11/21/2016
Witness:	Janice Mitchell & Terry Nix	Time:	1033
		Photo #:	2
Description:	Sludge Pond 1 W		



Water Division Photographic Evidence Sheet					
Location:	Tyson Poultry - Waldron				
Photographer:	Dannielle Gray	Date:	11/21/2016	Time:	1043
Witness:	Janice Mitchell & Terry Nix			Photo #:	3
Description:	Waste Pond 2				
 <p style="text-align: right; color: orange; font-weight: bold;">11.21.2016 10:43</p>					
Photographer:	Dannielle Gray	Date:	11/21/2016	Time:	1044
Witness:	Janice Mitchell & Terry Nix			Photo #:	4
Description:	Waste Pond 1				
 <p style="text-align: right; color: orange; font-weight: bold;">11.21.2016 10:44</p>					

Water Division Photographic Evidence Sheet

Location:	Tyson Poultry - Waldron		
Photographer:	Dannielle Gray	Date:	11/21/2016
Witness:	Janice Mitchell & Terry Nix	Time:	1055
		Photo #:	5
Description:	Oxidation ditch		



Photographer:	Dannielle Gray	Date:	11/21/2016
Witness:	Janice Mitchell & Terry Nix	Time:	1050
		Photo #:	6
Description:	Activated sludge in treatment track		



Water Division Photographic Evidence Sheet

Location:	Tyson Poultry - Waldron		
Photographer:	Dannielle Gray	Date:	11/21/2016
Witness:	Janice Mitchell & Terry Nix	Time:	1051
		Photo #:	7
Description:	Treatment plant overview		



Photographer:	Dannielle Gray	Date:	11/21/2016
Witness:	Janice Mitchell & Terry Nix	Time:	1100
		Photo #:	8
Description:	Clarifier (note white mass in photo is a reflection of the clouds above the clarifier)		



Water Division Photographic Evidence Sheet

Location:	Tyson Poultry - Waldron		
Photographer:	Dannielle Gray	Date:	11/21/2016
Witness:	Janice Mitchell & Terry Nix	Time:	1106
		Photo #:	9
Description:	UV disinfection		



Photographer:	Dannielle Gray	Date:	11/21/2016
Witness:	Janice Mitchell & Terry Nix	Time:	1109
		Photo #:	10
Description:	Primary flow device (2' rectangular weir with end contractions)		



Water Division Photographic Evidence Sheet


Location:	Tyson Poultry - Waldron		
Photographer:	Dannielle Gray	Date:	11/21/2016
Witness:	Janice Mitchell & Terry Nix	Time:	1115
Description:	Post-aeration	Photo #:	11



Photographer:	Dannielle Gray	Date:	11/21/2016
Witness:	Janice Mitchell & Terry Nix	Time:	1117
Description:	Outfall 001 – note orange arrows identify persistent foam on surface.		



Figure 1. Google Earth image dated March 20, 2016 showing facility overview and major treatment components.



From: [Nix, Terry](#)
To: [Gray, Dannielle](#)
Subject: RE: waldron visit
Date: Wednesday, December 07, 2016 4:06:49 PM

Good afternoon,

These samples were collected at our outfall, the results are reported on a certified lab report and they also show up on our process control report. When the data is reported on the process control sheet it rounds some results to whole numbers. The certified report for October 2015, Total Nitrogen was 16.81 mg/l and our process control report was 17 mg/l. We have been keeping all these reports along with the DMR's in one file. In the future we will separate these files so only reportable sample results from our outfall will be kept with the DMR's. I hope this answers your question, please let me know if you need more information.

Thank You
Terry Nix
Wastewater Supervisor
Tyson, Waldron

From: Gray, Dannielle [mailto:grayd@adeq.state.ar.us]
Sent: Wednesday, December 07, 2016 3:33 PM
To: Nix, Terry <Terry.Nix@tyson.com>
Cc: Mitchell, Janice <janice.mitchell@tyson.com>
Subject: RE: waldron visit

Good afternoon Mr. Nix,

I have a quick question to clarify:

As I recall, the information that I reviewed stated that the samples were collected at the outfall location. What I'm hearing in this response is that these samples were for process control. Can you clarify for me? Were the samples collected at the effluent location, or were they taken in other areas of the treatment plant? (As a reference, the data we looked at was for October 2015, specifically Total Nitrogen.)

I just want to be sure that I understand before I finalize the report.

Dannielle Gray
ADEQ Water Inspector, District 4
(479) 424-0333

From: Nix, Terry [mailto:Terry.Nix@tyson.com]
Sent: Monday, November 21, 2016 4:28 PM
To: Gray, Dannielle

Cc: Mitchell, Janice
Subject: waldron visit

During your recent visit to the Tyson Waldron Wastewater Facility you pointed out some discrepancies in the lab reports that we had in our DMR files. I talked with the lab manager at the Tyson River Valley Regional Lab and she explained that the "Wastewater Certification Report" contains the actual raw numbers at time of testing. The other reports that we looked at were meant for process control purposes only and do not exactly reflect what the certified report contains. In the future we will keep all reportable data along with the DMR's in a separate file from the process control data. This should eliminate any confusion between the reports in the future.

Thank You,
Terry Nix
Wastewater Supervisor
Tyson Waldron

This email and any files transmitted with it are confidential and intended solely for the use of the addressee. If you are not the intended addressee, then you have received this email in error and any use, dissemination, forwarding, printing, or copying of this email is strictly prohibited. Please notify us immediately of your unintended receipt by reply and then delete this email and your reply. Tyson Foods, Inc. and its subsidiaries and affiliates will not be held liable to any person resulting from the unintended or unauthorized use of any information contained in this email or as a result of any additions or deletions of information originally contained in this email.

This email and any files transmitted with it are confidential and intended solely for the use of the addressee. If you are not the intended addressee, then you have received this email in error and any use, dissemination, forwarding, printing, or copying of this email is strictly prohibited. Please notify us immediately of your unintended receipt by reply and then delete this email and your reply. Tyson Foods, Inc. and its subsidiaries and affiliates will not be held liable to any person resulting from the unintended or unauthorized use of any information contained in this email or as a result of any additions or deletions of information originally contained in this email.

From: [Nix, Terry](#)
To: [Gray, Danielle](#)
Cc: [Mitchell, Janice](#)
Subject: waldron visit
Date: Monday, November 21, 2016 4:30:13 PM

During your recent visit to the Tyson Waldron Wastewater Facility you pointed out some discrepancies in the lab reports that we had in our DMR files. I talked with the lab manager at the Tyson River Valley Regional Lab and she explained that the " Wastewater Certification Report" contains the actual raw numbers at time of testing. The other reports that we looked at were meant for process control purposes only and do not exactly reflect what the certified report contains. In the future we will keep all reportable data along with the DMR's in a separate file from the process control data. This should eliminate any confusion between the reports in the future.

Thank You,

Terry Nix

Wastewater Supervisor

Tyson Waldron

This email and any files transmitted with it are confidential and intended solely for the use of the addressee. If you are not the intended addressee, then you have received this email in error and any use, dissemination, forwarding, printing, or copying of this email is strictly prohibited. Please notify us immediately of your unintended receipt by reply and then delete this email and your reply. Tyson Foods, Inc. and its subsidiaries and affiliates will not be held liable to any person resulting from the unintended or unauthorized use of any information contained in this email or as a result of any additions or deletions of information originally contained in this email.



Tyson Foods, Inc.

December 29, 2016

ADEQ

Kerri McCabe - Supervisor

Arkansas Department of Environmental Management

5301 Northshore Drive

North Little Rock, AR 72118-5317

RE: NPDES Permit Tracking Number AR0038482 AFIN: 64-00001

Dear Kerri McCabe:

We received your letter by email on 12/22/16 for the Compliance Evaluation Inspection on the NPDES Permit No. AR0038482 and AR00A080 that was performed on November 21, 2016.

On the Summary of Findings:

1. Foam was observed in the effluent at the outfall. This is a violation of Part 1 A of the Permit.

Response:

Within the inspector notes, no foam was noticed in the effluent box of a persistent nature. However, foam was noticed in the tributary. The accumulation was due to levee maintenance performed by the City of Waldron on their lagoon system. Various limbs had been thrown into the unnamed tributary creating a situation where any surface solids would not flow downstream. The limbs were removed by the wastewater supervisor to restore a situation whereby accumulation of any foam cannot occur. Based on the citation and the facts around this "finding" Tyson disagrees with it being regulatory in nature and would request the "violation" be removed.

Corrective Action: Antifoam has been added to the Waste Water System after the UV light right directly after the effluent pipe on 12/12/16 to eliminate the foam from reoccurring. The effluent at the outfall will be monitored on a daily basis for foam and documentation will be performed on the findings.

2. The Chain of Custody (COC) does not indicate that samples are being properly preserved during transit. Specifically, there is no indication as to the type of container the samples are stored in or whether or not that samples are being preserved with ice. This is a violation of Part III, section C.5 of the permit.

Response:

The use of the section cited as a basis for issuance of this violation is vague. Tyson can find no guidance by the Arkansas Department of Environmental Quality (Department) or the Environmental Protection Agency (EPA) on exactly what is required on the COC. There are requirements on how samples must be preserved, handled, and verification for all of those items are maintained by our labs. Tyson uses

approved and certified labs and the COC are provided by those labs. If samples are received that do not comply with the temperature or preservation methods required, those samples are flagged and the testing not performed. If the Department has a recommendation on what needs to be placed on a COC, Tyson would modify the forms in conjunction with that recommendation. Based on the facts cited, Tyson requests that this "finding" be removed as a regulatory violation.

Corrective Action: On 11/21/16, on the Chain of Custody Analytical Form Request Form was revised. The revision included adding the bottle type code (G= glass, plastic, V=Septum, and A=amber) and two columns that document the container type and a column how the sample is preserved.

3. Discrepancies were noted between lab analysis reports and data reports on Discharge Monitoring Reports (DMRS).

a) Lab results are not always being reports in the appropriate line items on DMRS.

b) DO and pH maximums and minimums are not being consistently accurately reported.


Response:

Tyson acknowledges that there have been some transposing issues related to our DMRs. The process for validating DMR accuracy prior to the inspection was that the Wastewater Manager filled out and reviewed the data for accuracy. Thank you for clarifying in the Department's inspection report that none of these oversights resulted in a violation of a water quality standard.

Corrective Action: Starting with the DMR in January, the reports will be reviewed and filled out by the Wastewater manager and reviewed by Environmental Manager prior to submission.

Should you have any questions feel free to contact me at 479-637-5712 or email to janice.mitchell@tyson.com.

Sincerely,



Janice Mitchell
Complex Environmental Manager
479-637-5712

CERTIFIED MAIL™



Tyson Foods
442 Plant Str
Waldron, AR




7012 3050 0001 8249 0286

NORTHWEST AR F&DF

AR 72118-5317 NEOPOST

05 JAN 2017



\$005.12⁰


01/06/2017 ZIP 72958
042L14805799

US POSTAGE

Arkansas Dept. of Environmental Quality
Attn: Office of Water Quality, Compliance Branch
5301 North Shore Drive
North Little Rock, AR 72118-5317

R004 C059

721185317





March 7, 2017

Ken Nelson, Complex Manager
Tyson Poultry – Waldron
442 Plant Street
Waldron, AR 72958

RE: Response to Inspection (Scott Co)
AFIN: 64-00001

Permit No.: AR0038482

Dear Mr. Nelson:

I have reviewed the response pertaining to my November 21, 2016 inspection of the Tyson Poultry Wastewater Treatment Plant in Waldron, Arkansas. The information provided sufficiently addresses the violations referenced in my inspection report. At this time, the Department has no further comment concerning this particular inspection. Acceptance of this response by the Department does not preclude any future enforcement action deemed necessary at this site or any other site.

If we need additional information concerning this matter, we will contact you. Should you have any questions, feel free to contact me at (479) 424-0333 or you may e-mail me at grayd@adeq.state.ar.us.

Sincerely,

A handwritten signature in purple ink that reads "Dannielle Gray".

Dannielle Gray
District 4 Field Inspector
Office of Water Quality

cc: Janice Mitchell, Tyson Foods, Complex Environmental Manager,
janice.mitchell@tyson.com