FACILITY INFORMATION FACILITY INFORMATION FACILITY INFORMATION S200 Theatre Dr. RESPONSIBLE OFFICIAL David Stewart / Mayor City of Newport RESPONSIBLE OFFICIAL David Stewart / Mayor City of Newport Member 1		<u>VDEO</u>	WATER DIVISION INSPECTION REPORT							
PACILITY INFORMATION FACILITY INFORMATION City of Newport - Airport WWTP S200 Theatre Dr. RESPONSIBLE OFFICIAL David Stewart / Mayor Common College of Mayor College of Mayor Common College of Mayor Common College of Mayor Common College of Mayor Common College of Mayor C	AULU			IN: 34-00061 P	ERMIT #: AR0045225			[DATE: 8/16/2018	
Part	ARKANSAS		COUNTY: 34 Jacks		on	PDS	PDS #: 104642		MEDIA: WN	
TABLET TIPE City of Newport - Airport WWTP City of Newport	Dep		16 LONG: -91.247179 LOCATION: Entrance							
City of Newport RESPONSIBLE OFFICIAL NAME / THILE David Stewart / Mayor City of Newport RESPONSIBLE OFFICIAL NAME / THILE David Stewart / Mayor City of Newport RESPONSIBLE OFFICIAL NAME / THILE David Stewart / Mayor City of Newport RESPONSIBLE OFFICIAL NAME / THILE David Stewart / Mayor City of Newport RESPONSIBLE OFFICIAL NAME / THILE David Stewart / Mayor City of Newport RESPONSIBLE OFFICIAL NAME / THILE David Stewart / Mayor City of Newport RESPONSIBLE OFFICIAL NAME / THILE David Stewart / Mayor City of Newport RESPONSIBLE OFFICIAL NAME / THILE David Stewart / Mayor City of Newport RESPONSIBLE OFFICIAL NEW / THILE SHALE RELATED: N FAYETTEVILLE SHALE RELATED: N FAYETTEVILLE SHALE VIOLATIONS: N INSPECTION PARTICIPANTS INSPECTION PARTICIPANTS MARTIN Steward/Superintendent/870-523-5121 - via telephone only AREA EVALUATIONS SESSIONAL Addams/la. Loboratorory Martin Steward/Superintendent/870-523-5121 - via telephone only AREA EVALUATIONS SESSIONAL REVALUATIONS SESSIONAL REVALUATIONS SESSIONAL REVALUATIONS N SAMPLING S FLOW MASSUREMENT N STORMWATER S RECORDS/REPORTS N LABORATORY S FACILITY SITE REVIEW M OPERATION & MAINTENANCE N SET-MONIT REVIEW N OTHER: SUMMARY OF FINDINGS The facility does not have adequate backup power to prevent overflows/unpermitted discharges during powoutages as required by Part III, Section B, Item 1.A. of the permit. SUMMARY OF FINDINGS The facility does not have adequate backup power to prevent overflows/unpermitted discharges during powoutages as required by Part III, Section B, Item 1.A. of the permit. SUMMARY OF FINDINGS The facility does not have adequate backup power to prevent overflows/unpermitted discharges during powoutages as required by Part III, Section B, Item 1.A. of the permit. SUMMARY OF FINDINGS The facility does not have adequate backup power to prevent overflows/unpermitted discharges during powoutages as required by Part III, Section B, Item 1.A. of the permit. SUMMARY OF FINDINGS The facility of Newport Main			ION					IFORI	MATION	
SAUTH RESPONSIBLE OFFICIAL Newport RESPONSIBLE OFFICIAL NAME: / TITLE David Stewart / Mayor City of Newport RESPONSIBLE OFFICIAL NEWPORT AR 72112 PROBLE STATIFT IN THE STATE OF TH	Cit	y of Newport - Airport WWTP								
RESPONSIBLE OFFICIAL NAME / HTLE David Stewart / Mayor City of Newport MANUAL ADRESS 615 Third St. CITY STATE 299 Newport AR 72112 PROME SENT / MAY CONTACTED DURING INSPECTION: No AREA EVALUATIONS (Sessibleston), M-Marginul, Librasification, N-N-N-Applicabile/Evaluated) RECORDS/REPORTS N LABORATORY S PERMIT S PERMIT S RECORDS/REPORTS N LABORATORY S RECORDS/REPORTS N SAMPLING S S SUDGE HANDLING/DISPOSAL N OFFICE SUMMARY OF FINDINGS The facility does not have adequate backup power to prevent overflows/unpermitted discharges during powoutages as required by Part III, Section B, Item 1.A. of the permit. GENERAL COMMENTS At the time of the inspection, the facility was not discharging. Effluent was being diverted to the City of Newport Main WWTP (AR0037044). This facility's most recent discharge was in May 2017. Prior to that, the most recent discharge was July 2016. The majority of the influent is high BOD (-2,000 mg/l) low nutrient wastewater from Shearer's Snacks. This Compliance Evaluation Inspection was performed in conjunction with an SSO Inspection of this WWTF well as Compliance Evaluation, SSO, and Stormwater Inspections of the City of Newport Main WWTP AR0037044. Jason Bolenbaugh, ADEQ Compliance Branch Manager, Office of Water Quality also participated in this inspection.	820							Comp		
RESPONSIBLE OFFICIAL David Stewart / Mayor COUNTY OF Newport MUMAN JORRESS STATE JORN Newport AR 72112 PROMISE JORN JORN JORN JORN JORN JORN JORN JORN	-	wport								
David Stewart / Mayor City of Newport MANDA JONESS CITY STATE 2P. MONEY AR 72112 PROTES ART / FAX RYO-523-6568 / EMALL CONTACTED DURING INSPECTION: No RECORDS/REPORTS N LABORATORY S FAULUATIONS RECORDS/REPORTS N LABORATORY NAMA PRETENTION REPORTS RECORDS/REPORTS N LABORATORY S FAULUATION REPORTS RECORDS/REPORTS N LABORATORY S FAULU	NAME		CIAL	_	0/10/2010 00.33 13.13				PERMIT EXPIRATION DATE:	
FAYETTEVILLE SHALE VIOLATIONS: N MSPECTION PARTICIPANTS MATTER PARTICIPANTS MSPECTION PARTICIPANTS MSPECTION PA	Da	vid Stewart / Mayor			EAVETTE\/II I E QUAL E DEL ATED. I					
INSPECTION PARTICIPANTS INSPECTION PARTICIPANTS INSPECTION PARTICIPANTS INSPECTION PARTICIPANTS INSPECTION PARTICIPANTS India Adams/Laboratory Martin Steward/Superintendent/870-523-5121 - via telephone only	Cit	y of Newport								
Newport AR 72112 Newport AR 72112 Nowe aper; PAX 870-523-6568 / STUDEN SECTION: No AREA EVALUATIONS (Sastisfactory, MeMorglinal, U-dimantisfactory, Mentor Applicable/Evaluated) S PERMIT S FLOW MEASUREMENT N STORMWATER S RECORDS/REPORTS N LABORATORY S FACILITY SITE REVIEW M OPERATION & MAINTENANCE N EFFLUENT/RECEIVING WATER S SELF-MONITORING PROGR N SAMPLING S SLUDGE HANDLING/DISPOSAL N PRETREATMENT N OTHER: SUMMARY OF FINDINGS The facility does not have adequate backup power to prevent overflows/unpermitted discharges during pow outages as required by Part III, Section B, Item 1.A. of the permit. GENERAL COMMENTS At the time of the inspection, the facility was not discharging. Effluent was being diverted to the City of Newport Main WWTP (AR0037044). This facility's most recent discharge was in May 2017. Prior to that, the most recent discharge was July 2016. The majority of the influent is high BOD (-2,000 mg/l) low nutrient wastewater from Shearer's Snacks. This Compliance Evaluation Inspection was performed in conjunction with an SSO Inspection of this WWTF well as Compliance Evaluation, SSO, and Stormwater Inspections of the City of Newport Main WWTP AR0037044. Jason Bolenbaugh, ADEQ Compliance Branch Manager, Office of Water Quality also participated in this inspection.										
Linda Adams/Laboratory 870-523-6568 / 870-523-6568 / STATE OF THE PROOF OF THE P					NAME/TITLE/PHONE/FAX/EMAI	L/ETC.:		11110	MI AITIO	
### Martin Steward/Superintendent/870-523-5121 - via telephone only ### AREA EVALUATIONS Satisfactory, M=Marginal, U=Unsatisfactory, N=Not Applicable/Evaluated) Satisfactory, M=Marginal, U=Unsatisfactory, N=Not N=Not Applicable/Evaluated) Satisfactory, M=Marginal, U=Unsatisfactory, N=Not N							tory			
telephone only CONTACTED DURING INSPECTION: No AREA EVALUATIONS (S=Satisfactory, M=Marginal, U=Unsatisfactory, N=Not Applicable/Evaluated) S PERMIT S FLOW MEASUREMENT N STORMWATER S RECORDS/REPORTS N LABORATORY S FACILITY SITE REVIEW M OPERATION & MAINTENANCE N EFFLUENT/RECEIVING WATER S SELF-MONITORING PROGR N SAMPLING S SLUDGE HANDLING/DISPOSAL N PRETREATMENT N OTHER: SUMMARY OF FINDINGS The facility does not have adequate backup power to prevent overflows/unpermitted discharges during powoutages as required by Part III, Section B, Item 1.A. of the permit. GENERAL COMMENTS At the time of the inspection, the facility was not discharging. Effluent was being diverted to the City of Newport Main WWTP (AR0037044). This facility's most recent discharge was in May 2017. Prior to that, the most recent discharge was July 2016. The majority of the influent is high BOD (~2,000 mg/l) low nutrient wastewater from Shearer's Snacks. This Compliance Evaluation Inspection was performed in conjunction with an SSO Inspection of this WWTF well as Compliance Evaluation, SSO, and Stormwater Inspections of the City of Newport Main WWTP AR0037044. Jason Bolenbaugh, ADEQ Compliance Branch Manager, Office of Water Quality also participated in this inspection.								ent/87	'0-523-5121 - via	
AREA EVALUATIONS (S-Satisfactory, MeMarginal, U-Unsatisfactory, N-Not Applicable/Evaluated) S PERMIT S FLOW MEASUREMENT N STORMWATER S RECORDS/REPORTS N LABORATORY S FACILITY SITE REVIEW M OPERATION & MAINTENANCE N EFFLUENT/RECEIVING WATER S SELF-MONITORING PROGR N SAMPLING S SLUDGE HANDLING/DISPOSAL N PRETREATMENT N OTHER: SUMMARY OF FINDINGS The facility does not have adequate backup power to prevent overflows/unpermitted discharges during power outages as required by Part III, Section B, Item 1.A. of the permit. GENERAL COMMENTS At the time of the inspection, the facility was not discharging. Effluent was being diverted to the City of Newport Main WWTP (AR0037044). This facility's most recent discharge was in May 2017. Prior to that, the most recent discharge was July 2016. The majority of the influent is high BOD (~2,000 mg/l) low nutrient wastewater from Shearer's Snacks. This Compliance Evaluation Inspection was performed in conjunction with an SSO Inspection of this WWTF well as Compliance Evaluation, SSO, and Stormwater Inspections of the City of Newport Main WWTP AR0037044. Jason Bolenbaugh, ADEQ Compliance Branch Manager, Office of Water Quality also participated in this inspection.						Cup			0 0 2 0 1 2 1 1 1 1 1 1	
(S=Satisfactory, M=Marginal, U=Unsatisfactory, N=Not Applicable/Evaluated) S PERMIT S FLOW MEASUREMENT N STORMWATER S RECORDS/REPORTS N LABORATORY S FACILITY SITE REVIEW M OPERATION & MAINTENANCE N EFFLUENT/RECEIVING WATER S SELF-MONITORING PROGR N SAMPLING S SLUDGE HANDLING/DISPOSAL N PRETREATMENT N OTHER: SUMMARY OF FINDINGS The facility does not have adequate backup power to prevent overflows/unpermitted discharges during powoutages as required by Part III, Section B, Item 1.A. of the permit. GENERAL COMMENTS At the time of the inspection, the facility was not discharging. Effluent was being diverted to the City of Newport Main WWTP (AR0037044). This facility's most recent discharge was in May 2017. Prior to that, the most recent discharge was July 2016. The majority of the influent is high BOD (~2,000 mg/l) low nutrient wastewater from Shearer's Snacks. This Compliance Evaluation Inspection was performed in conjunction with an SSO Inspection of this WWTF well as Compliance Evaluation, SSO, and Stormwater Inspections of the City of Newport Main WWTP AR0037044. Jason Bolenbaugh, ADEQ Compliance Branch Manager, Office of Water Quality also participated in this inspection.	CO	NTACTED DURING INSPECTION	: No							
S PERMIT S FLOW MEASUREMENT N STORMWATER S RECORDS/REPORTS N LABORATORY S FACILITY SITE REVIEW M OPERATION & MAINTENANCE N EFFLUENT/RECEIVING WATER S SELF-MONITORING PROGR N SAMPLING S SLUDGE HANDLING/DISPOSAL N PRETREATMENT N OTHER: SUMMARY OF FINDINGS The facility does not have adequate backup power to prevent overflows/unpermitted discharges during powoutages as required by Part III, Section B, Item 1.A. of the permit. GENERAL COMMENTS At the time of the inspection, the facility was not discharging. Effluent was being diverted to the City of Newport Main WWTP (AR0037044). This facility's most recent discharge was in May 2017. Prior to that, the most recent discharge was July 2016. The majority of the influent is high BOD (~2,000 mg/l) low nutrient wastewater from Shearer's Snacks. This Compliance Evaluation Inspection was performed in conjunction with an SSO Inspection of this WWTF well as Compliance Evaluation, SSO, and Stormwater Inspections of the City of Newport Main WWTP AR0037044. Jason Bolenbaugh, ADEQ Compliance Branch Manager, Office of Water Quality also participated in this inspection.		(9-9	atisfac			/Evaluate	od)			
M OPERATION & MAINTENANCE N EFFLUENT/RECEIVING WATER S SELF-MONITORING PROGR N SAMPLING S SLUDGE HANDLING/DISPOSAL N PRETREATMENT N OTHER: SUMMARY OF FINDINGS The facility does not have adequate backup power to prevent overflows/unpermitted discharges during powoutages as required by Part III, Section B, Item 1.A. of the permit. GENERAL COMMENTS At the time of the inspection, the facility was not discharging. Effluent was being diverted to the City of Newport Main WWTP (AR0037044). This facility's most recent discharge was in May 2017. Prior to that, the most recent discharge was July 2016. The majority of the influent is high BOD (~2,000 mg/l) low nutrient wastewater from Shearer's Snacks. This Compliance Evaluation Inspection was performed in conjunction with an SSO Inspection of this WWTF well as Compliance Evaluation, SSO, and Stormwater Inspections of the City of Newport Main WWTP AR0037044. Jason Bolenbaugh, ADEQ Compliance Branch Manager, Office of Water Quality also participated in this inspection.	S							MWA	TER	
N SAMPLING N OTHER: SUMMARY OF FINDINGS The facility does not have adequate backup power to prevent overflows/unpermitted discharges during powoutages as required by Part III, Section B, Item 1.A. of the permit. GENERAL COMMENTS At the time of the inspection, the facility was not discharging. Effluent was being diverted to the City of Newport Main WWTP (AR0037044). This facility's most recent discharge was in May 2017. Prior to that, the most recent discharge was July 2016. The majority of the influent is high BOD (~2,000 mg/l) low nutrient wastewater from Shearer's Snacks. This Compliance Evaluation Inspection was performed in conjunction with an SSO Inspection of this WWTF well as Compliance Evaluation, SSO, and Stormwater Inspections of the City of Newport Main WWTP AR0037044. Jason Bolenbaugh, ADEQ Compliance Branch Manager, Office of Water Quality also participated in this inspection.	S	RECORDS/REPORTS	N	LABORATORY		S	FACIL	ITY S	ITE REVIEW	
SUMMARY OF FINDINGS The facility does not have adequate backup power to prevent overflows/unpermitted discharges during powoutages as required by Part III, Section B, Item 1.A. of the permit. GENERAL COMMENTS At the time of the inspection, the facility was not discharging. Effluent was being diverted to the City of Newport Main WWTP (AR0037044). This facility's most recent discharge was in May 2017. Prior to that, the most recent discharge was July 2016. The majority of the influent is high BOD (~2,000 mg/l) low nutrient wastewater from Shearer's Snacks. This Compliance Evaluation Inspection was performed in conjunction with an SSO Inspection of this WWTF well as Compliance Evaluation, SSO, and Stormwater Inspections of the City of Newport Main WWTP AR0037044. Jason Bolenbaugh, ADEQ Compliance Branch Manager, Office of Water Quality also participated in this inspection.	M							F-MONITORING PROGRAM		
SUMMARY OF FINDINGS The facility does not have adequate backup power to prevent overflows/unpermitted discharges during power outages as required by Part III, Section B, Item 1.A. of the permit. GENERAL COMMENTS At the time of the inspection, the facility was not discharging. Effluent was being diverted to the City of Newport Main WWTP (AR0037044). This facility's most recent discharge was in May 2017. Prior to that, the most recent discharge was July 2016. The majority of the influent is high BOD (~2,000 mg/l) low nutrient wastewater from Shearer's Snacks. This Compliance Evaluation Inspection was performed in conjunction with an SSO Inspection of this WWTF well as Compliance Evaluation, SSO, and Stormwater Inspections of the City of Newport Main WWTP AR0037044. Jason Bolenbaugh, ADEQ Compliance Branch Manager, Office of Water Quality also participated in this inspection.			S	SLUDGE HAND	LING/DISPOSAL	N	PRET	REAT	MENT	
The facility does not have adequate backup power to prevent overflows/unpermitted discharges during power outages as required by Part III, Section B, Item 1.A. of the permit. GENERAL COMMENTS At the time of the inspection, the facility was not discharging. Effluent was being diverted to the City of Newport Main WWTP (AR0037044). This facility's most recent discharge was in May 2017. Prior to that, the most recent discharge was July 2016. The majority of the influent is high BOD (~2,000 mg/l) low nutrient wastewater from Shearer's Snacks. This Compliance Evaluation Inspection was performed in conjunction with an SSO Inspection of this WWTF well as Compliance Evaluation, SSO, and Stormwater Inspections of the City of Newport Main WWTP AR0037044. Jason Bolenbaugh, ADEQ Compliance Branch Manager, Office of Water Quality also participated in this inspection.	N	OTHER:		SIIMMADV (OE EINDINGS					
outages as required by Part III, Section B, Item 1.A. of the permit. GENERAL COMMENTS At the time of the inspection, the facility was not discharging. Effluent was being diverted to the City of Newport Main WWTP (AR0037044). This facility's most recent discharge was in May 2017. Prior to that, the most recent discharge was July 2016. The majority of the influent is high BOD (~2,000 mg/l) low nutrient wastewater from Shearer's Snacks. This Compliance Evaluation Inspection was performed in conjunction with an SSO Inspection of this WWTF well as Compliance Evaluation, SSO, and Stormwater Inspections of the City of Newport Main WWTP AR0037044. Jason Bolenbaugh, ADEQ Compliance Branch Manager, Office of Water Quality also participated in this inspection.				SUIVINART	DE FINDINGS					
At the time of the inspection, the facility was not discharging. Effluent was being diverted to the City of Newport Main WWTP (AR0037044). This facility's most recent discharge was in May 2017. Prior to that, the most recent discharge was July 2016. The majority of the influent is high BOD (~2,000 mg/l) low nutrient wastewater from Shearer's Snacks. This Compliance Evaluation Inspection was performed in conjunction with an SSO Inspection of this WWTF well as Compliance Evaluation, SSO, and Stormwater Inspections of the City of Newport Main WWTP AR0037044. Jason Bolenbaugh, ADEQ Compliance Branch Manager, Office of Water Quality also participated in this inspection.	The facility does not have adequate backup power to prevent overflows/unpermitted discharges during power outages as required by Part III, Section B, Item 1.A. of the permit.									
Newport Main WWTP (AR0037044). This facility's most recent discharge was in May 2017. Prior to that, the most recent discharge was July 2016. The majority of the influent is high BOD (~2,000 mg/l) low nutrient wastewater from Shearer's Snacks. This Compliance Evaluation Inspection was performed in conjunction with an SSO Inspection of this WWTF well as Compliance Evaluation, SSO, and Stormwater Inspections of the City of Newport Main WWTP AR0037044. Jason Bolenbaugh, ADEQ Compliance Branch Manager, Office of Water Quality also participated in this inspection.				GENERAL (COMMENTS					
most recent discharge was July 2016. The majority of the influent is high BOD (~2,000 mg/l) low nutrient wastewater from Shearer's Snacks. This Compliance Evaluation Inspection was performed in conjunction with an SSO Inspection of this WWTF well as Compliance Evaluation, SSO, and Stormwater Inspections of the City of Newport Main WWTP AR0037044. Jason Bolenbaugh, ADEQ Compliance Branch Manager, Office of Water Quality also participated in this inspection.	At	the time of the inspection, the fac	ility	was not discha	rging. Effluent w	as b	eing dive	erted	to the City of	
wastewater from Shearer's Snacks. This Compliance Evaluation Inspection was performed in conjunction with an SSO Inspection of this WWTF well as Compliance Evaluation, SSO, and Stormwater Inspections of the City of Newport Main WWTP AR0037044. Jason Bolenbaugh, ADEQ Compliance Branch Manager, Office of Water Quality also participated in this inspection.	Ne	wport Main WWTP (AR0037044).	Thi	s facility's most	recent discharge	was	in May 2	2017.	Prior to that, the	
This Compliance Evaluation Inspection was performed in conjunction with an SSO Inspection of this WWTF well as Compliance Evaluation, SSO, and Stormwater Inspections of the City of Newport Main WWTP AR0037044. Jason Bolenbaugh, ADEQ Compliance Branch Manager, Office of Water Quality also participated in this inspection.	mo	st recent discharge was July 201	6. 7	Γhe majority of t	he influent is higl	h BO	D (~2,000	0 mg/	l) low nutrient	
well as Compliance Evaluation, SSO, and Stormwater Inspections of the City of Newport Main WWTP AR0037044. Jason Bolenbaugh, ADEQ Compliance Branch Manager, Office of Water Quality also participated in this inspection.	wa	stewater from Shearer's Snacks.								
AR0037044. Jason Bolenbaugh, ADEQ Compliance Branch Manager, Office of Water Quality also participated in this inspection.	This Compliance Evaluation Inspection was performed in conjunction with an SSO Inspection of this WWTP as									
Jason Bolenbaugh, ADEQ Compliance Branch Manager, Office of Water Quality also participated in this inspection.	we									
inspection.	AR	0037044.								
inspection.										
INSPECTOR'S SIGNATURE: Brest L Walker DATE: 0/20/2019										
INSPECTOR'S SIGNATURE: PLET L Walker DATE: 0/20/2019	D = I + I + I + I + I + I + I + I + I + I									
INOLLOTOR O OIGINATURE. TO DATE. 3/20/2016	INS	SPECTOR'S SIGNATURE: De	Brent L. Walker			DATE: 9/20/2018				
1 0000 -										
SUPERVISOR'S SIGNATURE: Jason Bolenbaugh DATE: 9/21/2018	SU	PERVISOR'S SIGNATURE:	in R	Malakan Jas	son Bolenbaugh				DATE: 9/21/2018	

SECTION A: PERMIT VERIFICATION	
PERMIT SATISFACTORILY ADDRESSES OBSERVATIONS	ØS □M □U □NA □NE
DETAILS:	
1. CORRECT NAME AND MAILING ADDRESS OF PERMITTEE:	☑Y □N □NA □NE
2. NOTIFICATION GIVEN TO EPA/STATE OF NEW DIFFERENT OR INCREASED DISCHARGES:	□Y □N ☑NA □NE
3. NUMBER AND LOCATION OF DISCHARGE POINTS AS DESCRIBED IN PERMIT:	☑Y □N □NA □NE
4. ALL DISCHARGES ARE PERMITTED:	ØY □N □NA □NE
SECTION B: RECORDKEEPING AND REPORTING EVALUATION	
RECORDS AND REPORTS MAINTAINED AS REQUIRED BY PERMIT	☑S □M □U □NA □NE
DETAILS: Facility last discharged in May 2017. Applicable records are maintained as red	quired.
ANALYTICAL RESULTS CONSISTENT WITH DATA REPORTED ON DMRS:	□Y □N □NA ☑NE
2. SAMPLING AND ANALYSES DATA ADEQUATE AND INCLUDE:	□S □M □U □NA ☑NE
a. DATES AND TIME(S) OF SAMPLING:	□Y □N □NA ☑NE
b. EXACT LOCATION(S) OF SAMPLING:	□Y □N □NA ☑NE
c. NAME OF INDIVIDUAL PERFORMING SAMPLING:	□Y □N □NA ☑NE
d. ANALYTICAL METHODS AND TECHNIQUES:	□Y □N □NA ☑NE
e. RESULTS OF CALIBRATIONS:	□Y □N □NA ☑NE
f. RESULTS OF ANALYSES:	□Y □N □NA ☑NE
g. DATES AND TIMES OF ANALYSES:	□Y □N □NA ☑NE
h. NAME OF PERSON(S) PERFORMING ANALYSES:	□y □n □na ☑ne
3. LABORATORY EQUIPMENT CALIBRATION AND MAINTENANCE RECORDS ADEQUATE:	□s □m □u □na ☑ne
4. PLANT RECORDS INCLUDE SCHEDULES, DATES OF EQUIPMENT MAINTENANCE AND REPAIR:	□S □M □U □NA ☑NE
5. EFFLUENT LOADINGS CALCULATED USING DAILY EFFLUENT FLOW AND DAILY ANALYTICAL DATA:	□Y □N □NA ☑NE
SECTION C: OPERATIONS AND MAINTENANCE	
TREATMENT FACILITY PROPERLY OPERATED AND MAINTAINED	☐S ☑M ☐U ☐NA ☐NE
DETAILS: Facility does not have adequate backup power and alarms.	
1. TREATMENT UNITS PROPERLY OPERATED:	☑s ☐m ☐u ☐na ☐ne
2. TREATMENT UNITS PROPERLY MAINTAINED:	⊠s □m □u □na □ne
3. STANDBY POWER OR OTHER EQUIVALENT PROVIDED:	□S □M ☑U □NA □NE
4. ADEQUATE ALARM SYSTEM FOR POWER OR EQUIPMENT FAILURES AVAILABLE:	□S □M ☑U □NA □NE
5. ALL NEEDED TREATMENT UNITS IN SERVICE:	⊠s □m □u □na □ne
6. ADEQUATE NUMBER OF QUALIFIED OPERATORS PROVIDED:	☑s ☐m ☐u ☐na ☐ne
7. SPARE PARTS AND SUPPLIES INVENTORY MAINTAINED:	☑S ☐M ☐U ☐NA ☐NE
8. OPERATION AND MAINTENANCE MANUAL AVAILABLE:	□Y □N □NA ☑NE
9. STANDARD OPERATING PROCEDURES AND SCHEDULES ESTABLISHED:	☑Y □N □NA □NE
10. PROCEDURES FOR EMERGENCY TREATMENT CONTROL ESTABLISHED:	☑Y □N □NA □NE
11. HAVE BYPASSES/OVERFLOWS OCCURRED AT THE PLANT OR IN THE COLLECTION SYSTEM IN THE LAST YEAR:	☑Y □N □NA □NE
12. IF SO, HAS THE REGULATORY AGENCY BEEN NOTIFIED:	☑Y □N □NA □NE
13. HAS CORRECTIVE ACTION BEEN TAKEN TO PREVENT ADDITIONAL BYPASSES/OVERFLOWS:	□y ☑n □na □ne
14. HAVE ANY HYDRAULIC OVERLOADS OCCURRED AT THE TREATMENT PLANT:	□Y ☑N □NA □NE
15. IF SO, DID PERMIT VIOLATIONS OCCUR AS A RESULT:	□y □n ☑na □ne

SECTION D: SAMPLING							
PERMITTEE SAMPLING MEETS PERMIT REQUIREMENTS	□S □M □U □NA ☑NE						
DETAILS: Last discharge was May 2017.							
SAMPLES TAKEN AT SITE(S) SPECIFIED IN PERMIT:	□Y □N □NA ☑NE						
2. LOCATIONS ADEQUATE FOR REPRESENTATIVE SAMPLES:	□Y □N □NA ☑NE						
3. FLOW PROPORTIONED SAMPLES OBTAINED WHEN REQUIRED BY PERMIT:							
4. SAMPLING AND ANALYSES COMPLETED ON PARAMETERS SPECIFIED IN PERMIT:	□Y □N □NA ☑NE						
5. SAMPLING AND ANALYSES PERFORMED AT FREQUENCY SPECIFIED IN PERMIT:	□Y □N □NA ☑NE						
6. SAMPLE COLLECTION PROCEDURES ADEQUATE:	□Y □N □NA ☑NE						
a. SAMPLES REFRIGERATED DURING COMPOSITING:	□Y □N □NA ☑NE						
b. PROPER PRESERVATION TECHNIQUES USED:	□Y □N □NA ☑NE						
c. CONTAINERS AND SAMPLE HOLDING TIMES CONFORM TO 40 CFR 136:	□Y □N □NA ☑NE						
7. IF MONITORING IS PERFORMED MORE OFTEN THAN REQUIRED ARE RESULTS REPORTED ON THE DMR:	□y □n □na ☑ne						
SECTION E: FLOW MEASUREMENT							
PERMITTEE FLOW MEASUREMENT MEETS PERMIT REQUIREMENTS	☑S □M □U □NA □NE						
DETAILS: No discharge at time of inspection - last discharge was May 2017.							
1. PRIMARY FLOW MEASUREMENT DEVICE PROPERLY INSTALLED AND MAINTAINED: Yes TYPE OF DEVICE: Parshall F	Flume ☑Y ☐N ☐NA ☐NE						
2. FLOW MEASURED AT EACH OUTFALL AS REQUIRED:	☑Y □N □NA □NE						
3. SECONDARY INSTRUMENTS (TOTALIZERS, RECORDERS, ETC.) PROPERLY OPERATED AND MAINTAINED:	□Y □N □NA ☑NE						
4. CALIBRATION FREQUENCY ADEQUATE:	□Y □N □NA ☑NE						
5. RECORDS MAINTAINED OF CALIBRATION PROCEDURES:	□y □n □na ☑ne						
6. CALIBRATION CHECKS DONE TO ASSURE CONTINUED COMPLIANCE:	□y □n □na ☑ne						
7. FLOW ENTERING DEVICE WELL DISTRIBUTED ACROSS THE CHANNEL AND FREE OF TURBULENCE:	□y □n □na ☑ne						
8. FLOW MEASUREMENT EQUIPMENT ADEQUATE TO HANDLE EXPECTED RANGE OF FLOW RATES:	□Y □N □NA ☑NE						
9. HEAD MEASURED AT PROPER LOCATION:	□y □n □na ☑ne						
SECTION F: LABORATORY							
PERMITTEE LABORATORY PROCEDURES MEET PERMIT REQUIREMENTS	☑S □M □U □NA □NE						
DETAILS: Both this facility and AR0037044 share an in-house laboratory.							
1. EPA APPROVED ANALYTICAL PROCEDURES USED (40 CFR 136.3 FOR LIQUIDS, 503.8(B) FOR SLUDGES) :	☑Y ☐N ☐NA ☐NE						
2. IF ALTERNATIVE ANALYTICAL PROCEDURES ARE USED, PROPER APPROVAL HAS BEEN OBTAINED:	□y □n ☑na □ne						
3. SATISFACTORY CALIBRATION AND MAINTENANCE OF INSTRUMENTS AND EQUIPMENT:	☑Y □N □NA □NE						
4. QUALITY CONTROL PROCEDURES ADEQUATE:	☑Y □N □NA □NE						
5. DUPLICATE SAMPLES ARE ANALYZED ≥10% OF THE TIME:	☑Y □N □NA □NE						
6. SPIKED SAMPLES ARE ANALYZED ≥10% OF THE TIME:	☑Y □N □NA □NE						
7. COMMERCIAL LABORATORY USED:	☑Y □N □NA □NE						
a. LAB NAME: Arkansas Testing							
b. LAB ADDRESS: <u>Searcy, AR</u>							
c. PARAMETERS PERFORMED: CBOD, NH3-N, O&G, TP, NO3+NO2-N							
8. BIOMONITORING PROCEDURES ADEQUATE:	□Y □N ☑NA □NE						
a. PROPER ORGANISMS USED:	□Y □N ☑NA □NE						
b. PROPER DILUTION SERIES FOLLOWED:	□Y □N ☑NA □NE						
c. PROPER TEST METHODS AND DURATION:	□Y □N ☑NA □NE						
d. RETESTS AND/OR TRE PERFORMED AS REQUIRED:	□Y □N ☑NA □NE						

SECTION G: EFFLUENT/RECEIVING WATERS OBSERVATIONS											
BASED ON VISUAL OBSERVATIONS ONLY											
DETAILS: Facility is currently not discharging to 001 and is instead routed to the city's other WWTP (AR0037044). OUTFALL #: OIL SHEEN GREASE TURBIDITY VISIBLE FOAM FLOATING SOLIDS COLOR OTHER											
001	N/A	N/A	N/A	N/A	N/A	N/A					
	1477	1471	1071	14/7	1471	14/7					
SECTION H	H: SLUDGE DIS	POSAL									
	DISPOSAL MEI		REQUIREMEN [®]	TS		⊠S □M ∣	□U □NA □NE				
	Sludge is sent				l .						
_	MANAGEMENT ADEQU			(2 1000 1			I □U ☑NA □NE				
2. SLUDGE R	ECORDS MAINTAINED	O AS REQUIRED BY 40	O CFR 503:				I □U ☑NA □NE				
3. FOR LAND	APPLIED SLUDGE, TY	PE OF LAND APPLIE	D TO: (E.G., FOREST,	, AGRICULTURAL, PUI	BLIC CONTACT SITE):						
SECTION I:	SAMPLING IN	SPECTION PRO	CEDURES								
SAMPLE F	RESULTS WITH	HIN PERMIT R	EQUIREMENT	S		□S □M ∣	□U ⊠NA □NE				
DETAILS:					•						
1. SAMPLES	OBTAINED THIS INSPI	ECTION:)	/ □N ☑NA □NE				
2. TYPE OF S	SAMPLE: GRAB:	□COMPOSITE: N	METHOD: FREQUE	NCY:							
3. SAMPLES	PRESERVED:					<u> </u>	/ □N ☑NA □NE				
4. FLOW PRO	4. FLOW PROPORTIONED SAMPLES OBTAINED:										
5. SAMPLE C	5. SAMPLE OBTAINED FROM FACILITY'S SAMPLING DEVICE:										
6. SAMPLE R	EPRESENTATIVE OF	VOLUME AND NATUR	E OF DISCHARGE:			<u> </u>	/ □N ☑NA □NE				
7. SAMPLE S	PLIT WITH PERMITTEI	E:				<u> </u>	/ □N ☑NA □NE				
8. CHAIN-OF-	-CUSTODY PROCEDU	RES EMPLOYED:					∕ □N ☑NA □NE				
9. SAMPLES COLLECTED IN ACCORDANCE WITH PERMIT:							∕ □N ØNA □NE				
SECTION J	: STORM WAT	ER POLLUTION	PREVENTION	PLAN							
STORM W	ATER MANAG	EMENT MEET	S PERMIT RE	QUIREMENTS	3		□U ☑NA □NE				
DETAILS:							r □n ☑na □ne				
1. SWPPP UF	I. SWPPP UPDATED AS NEEDED: DATE OF LAST UPDATE:										
2. SITE MAP	SITE MAP INCLUDING ALL DISCHARGES AND SURFACE WATERS:										
3. POLLUTIO	. POLLUTION PREVENTION TEAM IDENTIFIED:										
4. POLLUTIO	POLLUTION PREVENTION TEAM PROPERLY TRAINED:										
5. LIST OF PO	LIST OF POTENTIAL POLLUTANT SOURCES:										
6. LIST OF POTENTIAL SOURCES AND PAST SPILLS AND LEAKS:							/ □N ☑NA □NE				
7. ALL NON-STORM WATER DISCHARGES ARE AUTHORIZED:							/ □N ☑NA □NE				
8. LIST OF STRUCTURAL BMPS:							/ □N ☑NA □NE				
9. LIST OF NON-STRUCTURAL BMPS:							/ □N ☑NA □NE				
10. BMPS PROPERLY OPERATED AND MAINTAINED:							/ □N ☑NA □NE				
11. INSPECTION		/ □N ØNA □NE									

THE CITY OF NEWPORT WASTEWATER TREATMENT PLANT 615 THIRD STREET FACILITY LOCATION 121 HIGHWAY 17 SOUTH NEWPORT, ARKANSAS 72112

PHONE: (870) 523-8121 FAX: (870) 523-8214

1 October 2018

Mr. Brent Walker ADEQ Water Division Inspection Branch 5301 Northshore Drive North Little Rock, Arkansas 72118

Re:

NPDES Permit #AR0045225, AFIN 34-00061

Response to compliance inspection report from August 16, 2018 Inspection.

Dear Mr. Walker:

An automatic emergency power supply generator system will be submitted to the city council for approval in the 2019 budget. High level alarms will be installed during the winter of 2018-2019 at pumping stations.

Sincerely Math Skund

Martin Steward Superintendent, WWTP

cc: David Stewart, Mayor