

January 9, 2019

Jake Rice III, PE, Manager Jonesboro City Water and Light P.O. Box 1289 Jonesboro, AR 72403

RE: City Water and Light – East & West WWTPs Inspections

AFIN: 16-00936 Permit No.: AR0043401, ARR000154, 5142-WR-1, AR0043401C

16-00152 AR0037907, ARR000629, 5105-WR-1

Dear Mr. Rice:

On September 17 and 18, 2018, I performed Compliance Evaluation, Sanitary Sewer Overflow/Collection System, Industrial Stormwater, Land Application, and Wastewater Treatment Plant Construction Inspections of the above referenced facilities in accordance with the provisions of the Federal Clean Water Act, the Arkansas Water and Air Pollution Control Act, and the regulations promulgated thereunder. Copies of the inspection reports are enclosed for your records.

No violations were noted at the time of the inspections. Please refer to the attached inspection reports for any comments.

If I can be of any assistance, please contact me at walker@adeq.state.ar.us or 870-935-7221 ext.-12.

Sincerely,

Brent L. Walker

District 3 Field Inspector

Brest 2 Walter

Water Division

<b>VDEO</b>		WATER DIVISION INSPECTION REPORT						
		AFIN: <b>16-00936</b> PERMIT #: <b>AR0043401</b>				DATE: <b>9/18/2018</b>		
		COUNTY: 16 Craigh		nead	PDS	S #: <b>10</b> 6	026	MEDIA: WN
Dep	partment of Environmental Quality	GP	S LAT: <b>35.79147</b>	7 LONG: -90.633	382	LOCA	ΓΙΟΝ: <b>Ε</b> ι	ntrance
FACILITY INFORMATION							INFORM	MATION
City Water & Light - East WWTP				1 - Municipal INSPECTOR ID#: 52138 S - State				
<b>520</b> CITY:	95 Ingels Rd.			Facility evaluation rating: inspection type:  5 - Satisfactory Compliance Evaluation				
Joi	nesboro			1 /	TRY TIM 8:35		TTIME: ':20	PERMIT EFFECTIVE DATE: 9/1/2017
NAME	RESPONSIBLE OFFICE	CIAL			3:15		:05	PERMIT EXPIRATION DATE:
Jak	ce Rice III, PE / Manager			FAYETTEVILLE SHALE RELATED: <b>N</b>				
JOI	nesboro City Water and Light							
MAILI	NG ADDRESS:			FAYETTEVILLE				
	). Box 1289 STATE, ZIP:			NAME/TITLE/PHONE/FAX/EMA	L/ETC.:			PANTS
	nesboro AR 72403							eatment Dept. Sup.
	E & EXT: / FAX: )-935-5581 / 870-930-3301			Adam Saulsbur Myra Taylor/Lai				reatment Coord.
EMAIL				Jody Gibson/Pr	etre	atment	Specia	list
CO	e@jonesborocwl.org NTACTED DURING INSPECTION:	Yes	<u> </u>	Scott Maynard/	Wast	ewate	Treatm	nent Plant Foreman
	AREA EVALUATIONS							
s	PERMIT	S	FLOW MEASUR	sfactory, N=Not Applicable REMENT	Evalua		DRMWA	TER
S	RECORDS/REPORTS	S	LABORATORY		5			ITE REVIEW
S	OPERATION & MAINTENANCE					ITORING PROGRAM		
S N	SAMPLING OTHER:	S	SLUDGE HAND	LING/DISPOSAL		I PRE	TREAT	MENI
•	OTTEK.		SUMMARY C	F FINDINGS				
	No violations were noted at the time of the inspection.  The facility is well maintained and has a very knowledgeable and professional staff.							
			GENERAL C	COMMENTS				
In conjunction with this Compliance Evaluation Inspection, the following inspections of this facility were performed: Sanitary Sewer Overflow/Collection System, Industrial Stormwater, Land Application of Biosolids, and WWTP Construction.  The facility is currently in the process of adding two clarifiers, two sludge pumping stations, ultraviolet disinfection, and magnetic flow meters. This activity is covered under AR0043401C								
IN:	INSPECTOR'S SIGNATURE: Brest L. Walker DATE: 1/2/2019							
	NSPECTOR'S SIGNATURE: DIES J. Walker Brent L. Walker DATE: 1/2/2019  SUPERVISOR'S SIGNATURE: Jason Bolenbaugh DATE: 1/7/2019							

SECTION A: PERMIT VERIFICATION	
PERMIT SATISFACTORILY ADDRESSES OBSERVATIONS	⊠S □M □U □NA □NE
DETAILS:	
1. CORRECT NAME AND MAILING ADDRESS OF PERMITTEE:	☑Y □N □NA □NE
2. NOTIFICATION GIVEN TO EPA/STATE OF NEW DIFFERENT OR INCREASED DISCHARGES:	□Y □N ☑NA □NE
3. NUMBER AND LOCATION OF DISCHARGE POINTS AS DESCRIBED IN PERMIT:	MY □N □NA □NE
4. ALL DISCHARGES ARE PERMITTED:	☑Y □N □NA □NE
SECTION B: RECORDKEEPING AND REPORTING EVALUATION	
RECORDS AND REPORTS MAINTAINED AS REQUIRED BY PERMIT	⊠S □M □U □NA □NE
DETAILS:	
1. ANALYTICAL RESULTS CONSISTENT WITH DATA REPORTED ON DMRS:	☑Y □N □NA □NE
2. SAMPLING AND ANALYSES DATA ADEQUATE AND INCLUDE:	⊠s □m □u □na □ne
a. DATES AND TIME(S) OF SAMPLING:	⊠y □n □na □ne
b. EXACT LOCATION(S) OF SAMPLING:	☑Y □N □NA □NE
c. NAME OF INDIVIDUAL PERFORMING SAMPLING:	☑Y □N □NA □NE
d. ANALYTICAL METHODS AND TECHNIQUES:	☑Y □N □NA □NE
e. RESULTS OF CALIBRATIONS:	⊠y □n □na □ne
f. RESULTS OF ANALYSES:	Øy □n □na □ne
g. DATES AND TIMES OF ANALYSES:	☑Y □N □NA □NE
h. NAME OF PERSON(S) PERFORMING ANALYSES:	☑Y □N □NA □NE
3. LABORATORY EQUIPMENT CALIBRATION AND MAINTENANCE RECORDS ADEQUATE:	⊠S □M □U □NA □NE
4. PLANT RECORDS INCLUDE SCHEDULES, DATES OF EQUIPMENT MAINTENANCE AND REPAIR:	⊠S □M □U □NA □NE
5. EFFLUENT LOADINGS CALCULATED USING DAILY EFFLUENT FLOW AND DAILY ANALYTICAL DATA:	☑Y □N □NA □NE
SECTION C: OPERATIONS AND MAINTENANCE	1
TREATMENT FACILITY PROPERLY OPERATED AND MAINTAINED	☑S □M □U □NA □NE
DETAILS:	
1. TREATMENT UNITS PROPERLY OPERATED:	ØS OM OU ONA ONE
2. TREATMENT UNITS PROPERLY MAINTAINED:	ØS OM OU ONA ONE
3. STANDBY POWER OR OTHER EQUIVALENT PROVIDED:	ØS OM OU ONA ONE
4. ADEQUATE ALARM SYSTEM FOR POWER OR EQUIPMENT FAILURES AVAILABLE:	ØS OM OU ONA ONE
5. ALL NEEDED TREATMENT UNITS IN SERVICE:	☑S ☐M ☐U ☐NA ☐NE
6. ADEQUATE NUMBER OF QUALIFIED OPERATORS PROVIDED:	ØS OM OU ONA ONE
7. SPARE PARTS AND SUPPLIES INVENTORY MAINTAINED:	ØS □M □U □NA □NE
8. OPERATION AND MAINTENANCE MANUAL AVAILABLE:	□Y □N □NA ☑NE
9. STANDARD OPERATING PROCEDURES AND SCHEDULES ESTABLISHED:	MY ON ONA ONE
10. PROCEDURES FOR EMERGENCY TREATMENT CONTROL ESTABLISHED:	MY □N □NA □NE
11. HAVE BYPASSES/OVERFLOWS OCCURRED AT THE PLANT OR IN THE COLLECTION SYSTEM IN THE LAST YEAR:	MY □N □NA □NE
12. IF SO, HAS THE REGULATORY AGENCY BEEN NOTIFIED:	ØY □N □NA □NE
13. HAS CORRECTIVE ACTION BEEN TAKEN TO PREVENT ADDITIONAL BYPASSES/OVERFLOWS:	ØY □N □NA □NE
14. HAVE ANY HYDRAULIC OVERLOADS OCCURRED AT THE TREATMENT PLANT:	□Y ☑N □NA □NE
15. IF SO, DID PERMIT VIOLATIONS OCCUR AS A RESULT:	□Y □N ☑NA □NE

SE	CTION D: SAMPLING	
PE	ERMITTEE SAMPLING MEETS PERMIT REQUIREMENTS	☑S □M □U □NA □NE
	TAILS:	
1.	SAMPLES TAKEN AT SITE(S) SPECIFIED IN PERMIT:	⊠y □n □na □ne
2.	LOCATIONS ADEQUATE FOR REPRESENTATIVE SAMPLES:	⊠y □n □na □ne
3.	FLOW PROPORTIONED SAMPLES OBTAINED WHEN REQUIRED BY PERMIT:	⊠y □n □na □ne
4.	SAMPLING AND ANALYSES COMPLETED ON PARAMETERS SPECIFIED IN PERMIT:	Øy □n □na □ne
5.	SAMPLING AND ANALYSES PERFORMED AT FREQUENCY SPECIFIED IN PERMIT:	✓Y □N □NA □NE
6.	SAMPLE COLLECTION PROCEDURES ADEQUATE:	Øy □n □na □ne
a	. SAMPLES REFRIGERATED DURING COMPOSITING:	☑Y □N □NA □NE
b	PROPER PRESERVATION TECHNIQUES USED:	✓Y □N □NA □NE
	CONTAINERS AND SAMPLE HOLDING TIMES CONFORM TO 40 CFR 136:	ØY ON ONA ONE
7.	IF MONITORING IS PERFORMED MORE OFTEN THAN REQUIRED ARE RESULTS REPORTED ON THE DMR:	☑Y □N □NA □NE
SE	CTION E: FLOW MEASUREMENT	
	ERMITTEE FLOW MEASUREMENT MEETS PERMIT REQUIREMENTS	ØS DM DU DNA DNE
	ETAILS:	
1.	PRIMARY FLOW MEASUREMENT DEVICE PROPERLY INSTALLED AND MAINTAINED: TYPE OF DEVICE: 2 Parshall Flumi (Soon to be replaced with mag meters)	es Øy On Ona One
2.	FLOW MEASURED AT EACH OUTFALL AS REQUIRED:	☑Y □N □NA □NE
3.	SECONDARY INSTRUMENTS (TOTALIZERS, RECORDERS, ETC.) PROPERLY OPERATED AND MAINTAINED:	⊠y □n □na □ne
4.	CALIBRATION FREQUENCY ADEQUATE:	⊠y □n □na □ne
5.	RECORDS MAINTAINED OF CALIBRATION PROCEDURES:	☑Y □N □NA □NE
6.	CALIBRATION CHECKS DONE TO ASSURE CONTINUED COMPLIANCE:	⊠y □n □na □ne
7.	FLOW ENTERING DEVICE WELL DISTRIBUTED ACROSS THE CHANNEL AND FREE OF TURBULENCE:	Øy □n □na □ne
8.	FLOW MEASUREMENT EQUIPMENT ADEQUATE TO HANDLE EXPECTED RANGE OF FLOW RATES:	⊠y □n □na □ne
9.	HEAD MEASURED AT PROPER LOCATION:	⊠y □n □na □ne
SE	CTION F: LABORATORY	
PE	ERMITTEE LABORATORY PROCEDURES MEET PERMIT REQUIREMENTS	☑S □M □U □NA □NE
DE	ETAILS:	
1.	EPA APPROVED ANALYTICAL PROCEDURES USED (40 CFR 136.3 FOR LIQUIDS, 503.8(B) FOR SLUDGES) :	☑y □n □na □ne
2.	IF ALTERNATIVE ANALYTICAL PROCEDURES ARE USED, PROPER APPROVAL HAS BEEN OBTAINED:	□Y □N ☑NA □NE
3.	SATISFACTORY CALIBRATION AND MAINTENANCE OF INSTRUMENTS AND EQUIPMENT:	☑Y □N □NA □NE
4.	QUALITY CONTROL PROCEDURES ADEQUATE:	☑Y □N □NA □NE
5.	DUPLICATE SAMPLES ARE ANALYZED ≥10% OF THE TIME:	☑Y □N □NA □NE
6.	SPIKED SAMPLES ARE ANALYZED ≥10% OF THE TIME:	⊠y □n □na □ne
7.	COMMERCIAL LABORATORY USED:	☑Y □N □NA □NE
a	. LAB NAME: American Interplex & ASU Ecotoxicology Research Facility	
b	. LAB ADDRESS: Little Rock, AR / State University, AR	
C	PARAMETERS PERFORMED: Chronic Toxicity	
8.	BIOMONITORING PROCEDURES ADEQUATE:	Øy □n □na □ne
a	. PROPER ORGANISMS USED:	Øy □n □na □ne
b	. PROPER DILUTION SERIES FOLLOWED:	Øy □n □na □ne
C	. PROPER TEST METHODS AND DURATION: <u>Deviations in test durations by American Interplex are currently being reviewed</u> ADEQ Lab Certification Program	by the   Y  N  NA  NE
c	I. RETESTS AND/OR TRE PERFORMED AS REQUIRED:	✓Y □N □NA □NE

SECTION G	: EFFLUENT/R	<u> </u>		-	10-00330, 1 0111111	7.1.133 13 13 1					
BASED ON	BASED ON VISUAL OBSERVATIONS ONLY										
DETAILS:											
OUTFALL #: OIL SHEEN GREASE TURBIDITY VISIBLE FOAM FLOATING SOLIDS COLOR											
001	001 None None Very Low None None		None	Clear							
			-								
SECTION H: SLUDGE DISPOSAL											
SLUDGE [	SLUDGE DISPOSAL MEETS PERMIT REQUIREMENTS  ØS DM DU DNA DNE										
DETAILS:	Covered under	No Discharge	Permit 5142-WI	R-1	<u> </u>						
1. SLUDGE N	IANAGEMENT ADEQU	ATE TO MAINTAIN EF	FLUENT QUALITY:			⊠s □m	□U □NA □NE				
2. SLUDGE R	ECORDS MAINTAINED	AS REQUIRED BY 4	0 CFR 503:			⊠s □m	□U □NA □NE				
3. FOR LAND	APPLIED SLUDGE, TY	PE OF LAND APPLIE	D TO: (E.G., FOREST	, AGRICULTURAL, PU	BLIC CONTACT SITE): <u>A</u>	gricultural (Bermuda	Hay)				
	SAMPLING IN										
	RESULTS WITH	HIN PERMIT R	REQUIREMENT	ΓS			U ⊠NA □NE				
DETAILS:											
1. SAMPLES	OBTAINED THIS INSPE	ECTION:				□Y	□N ☑NA □NE				
2. TYPE OF S	AMPLE: ☐GRAB:	□COMPOSITE:	METHOD: FREQUE	ENCY:							
3. SAMPLES											
	PORTIONED SAMPLE						□N ☑NA □NE				
	BTAINED FROM FACIL						□N ØNA □NE				
	EPRESENTATIVE OF \		RE OF DISCHARGE:				□N ☑NA □NE				
	PLIT WITH PERMITTER						□N ØNA □NE				
	CUSTODY PROCEDUI						□N ☑NA □NE				
9. SAMPLES	COLLECTED IN ACCO	RDANCE WITH PERM	MIT:			□Y	□N ☑NA □NE				
OFOTION I	OTODA WAT	ED DOLL LITION	I DDEVENTION	DI ANI							
	STORM WATE				,		III MAIA MAIG				
				QUIREMENTS			IU ⊠NA □NE				
_	No Exposure E  PDATED AS NEEDED:		_	(RUUU154		ПУ	□n Øna □ne				
		A•									

## Inspection Report: City Water & Light - East WWTP, AFIN: 16-00936, Permit #: AR0043401 DMR Calculation Check

Reporting Period:	From	2018	03	01	_ To	2018	03	31	
		Year	Month	Day		Year	Month	Day	
Parameter Checked:		NH3-N	-						
		Loading		Concentration Monthly					
		Mass							
	Mo.	Avg Ibs/d	lay	Mo. A	vg ۱	mg/l	7-day Avg	յ mg/l	
Reported Value:		<11			<0.1		<0.2	2	
Calculated Value:		<11			<0.1		<0.2	2	

4.0

If calculated value does not equal reported value, explain: <u>Equal</u>

300

**Permit Value:** 

6.0

## Inspection Report: City Water & Light - East WWTP, AFIN: 16-00936, Permit #: AR0043401 DMR Calculation Check

Reporting Period:	From	2018	04	01	То	2018	04	30	
		Year	Month	Day		Year	Month	Day	
Parameter Checked:		CBOD5							

	Loading Mass	Concentration  Monthly				
	Mo. Avg Ibs/day	Mo. Avg mg/l	7-day Avg mg/l			
Reported Value:	<179	<2.7	3.1			
Calculated Value:	<179	<2.7	3.1			
Permit Value:	1501	20	30			

If calculated value does not equal reported value, explain: <u>Equal</u>