



ENVIRONMENTAL
QUALITY

OFFICE OF WATER QUALITY INSPECTION REPORT

AFIN: **04-00155** PERMIT #: **AR0043397** DATE: **9/14/2021**
 COUNTY: **04 Benton** PDS #: **118906** MEDIA: **WN**
 GPS LAT: **36.29794** LONG: **-94.21233** LOCATION: **General Area**

FACILITY INFORMATION

NAME:
Preformed Line Products
 LOCATION:
2740 South 1st Street
 CITY:
Rogers

RESPONSIBLE OFFICIAL

NAME: / TITLE
Brent R. Dobler / Utility Superintendent
 COMPANY:
City of Rogers
 MAILING ADDRESS:
4300 Rainbow Road
 CITY, STATE, ZIP:
Rogers AR 72758
 PHONE & EXT: / FAX:
479-273-7627 /
 EMAIL:
brentdobler@rwu.org
 CONTACTED DURING INSPECTION: **Yes**

INSPECTION INFORMATION

FACILITY TYPE: **2 - Industrial** INSPECTOR ID#: **104111 S - State**
 FACILITY EVALUATION RATING: **N** INSPECTION TYPE: **Industrial User**
 DATE(S): **9/14/2021** ENTRY TIME: **14:36** EXIT TIME: **15:30** PERMIT EFFECTIVE DATE: **1/31/2006**
 PERMIT EXPIRATION DATE: **2/28/2023**

FAYETTEVILLE SHALE RELATED: **N**

FAYETTEVILLE SHALE VIOLATIONS: **N**

INSPECTION PARTICIPANTS

NAME/TITLE/PHONE/FAX/EMAIL/ETC.:
Paul Burns, Pretreatment Coordinator, RWU;
Amber Owens, Pretreatment, RWU;
Brent Walker, Inspector Supervisor, DEQ;
Cole Southerland, Inspector, DEQ;
Garrett Grimes, Inspector, DEQ

AREA EVALUATIONS

(S=Satisfactory, M=Marginal, U=Unsatisfactory, N=Not Applicable/Evaluated)

N	PERMIT	N	FLOW MEASUREMENT	N	STORMWATER
N	RECORDS/REPORTS	N	LABORATORY	N	FACILITY SITE REVIEW
S	OPERATION & MAINTENANCE	N	EFFLUENT/RECEIVING WATER	N	SELF-MONITORING PROGRAM
N	SAMPLING	N	SLUDGE HANDLING/DISPOSAL	S	PRETREATMENT
N	OTHER:				

SUMMARY OF FINDINGS

Construction was occurring at the time of the site visit with the sample location being moved. Casing of the current location of the Parshall Flume was previously damaged by a vehicle, but was still functional. Facility personnel were helpful and knowledgeable of their process.

GENERAL COMMENTS

This industrial user visit was performed as part of a Pretreatment Compliance Inspection of the City of Rogers Pretreatment Program.

INSPECTOR'S SIGNATURE: *Garrett Grimes* **Garrett Grimes** DATE: **10/18/2021**
 SUPERVISOR'S SIGNATURE: *Brent L Walker* **Brent L. Walker** DATE: **1/31/2022**

Industrial Site Visit

Name of Industry: Preformed Line Products

Industry Contacts: Lloyd Brown, Lead Assessor and Compliance Technician

Type of Industry: Aluminum Forming

Date of Visit: 9/14/2021

- | | | | | |
|-----|--|---|-----------------------------|---|
| 1. | Significant industrial user: | <input checked="" type="checkbox"/> Yes | <input type="checkbox"/> No | <input type="checkbox"/> N/A |
| 2. | Pretreatment equipment or procedures? | <input checked="" type="checkbox"/> Yes | <input type="checkbox"/> No | <input type="checkbox"/> N/A |
| 3. | Pretreatment equipment maintained and operational? | <input checked="" type="checkbox"/> Yes | <input type="checkbox"/> No | <input type="checkbox"/> N/A |
| 4. | Hazardous waste generated or stored? | <input checked="" type="checkbox"/> Yes | <input type="checkbox"/> No | <input type="checkbox"/> N/A |
| 5. | Proper solid waste disposal? | <input checked="" type="checkbox"/> Yes | <input type="checkbox"/> No | <input type="checkbox"/> N/A |
| 6. | Solvent management/TTO control? | <input checked="" type="checkbox"/> Yes | <input type="checkbox"/> No | <input type="checkbox"/> N/A |
| 7. | Suitable sampling location? | <input type="checkbox"/> Yes | <input type="checkbox"/> No | <input checked="" type="checkbox"/> N/A |
| 8. | Appropriate self-monitoring procedures/equipment? | <input type="checkbox"/> Yes | <input type="checkbox"/> No | <input checked="" type="checkbox"/> N/A |
| 9. | Adequate spill prevention? | <input checked="" type="checkbox"/> Yes | <input type="checkbox"/> No | <input type="checkbox"/> N/A |
| 10. | Industry familiar with limits and requirements? | <input checked="" type="checkbox"/> Yes | <input type="checkbox"/> No | <input type="checkbox"/> N/A |

Additional Comments: Solvent management currently as hazardous waste, but plans in place to recycle. Sample location under construction at the time of the site visit.