



October 12, 2022

Blake Marotti, General Manager City of Wynne 121 East Merriman Avenue Wynne, AR 72396 Via email: <u>wynnewater1@yahoo.com</u>

RE: City of Wynne WWTP Inspection AFIN: 19-00071 Permit No.: AR0021903 and ARR000293

Dear Mr. Marotti:

On March 9, 2022, I performed a Compliance Evaluation Inspection and Industrial Stormwater Inspection of the above referenced facility in accordance with the provisions of the Federal Clean Water Act, the Arkansas Water and Air Pollution Control Act, and the regulations promulgated thereunder. Copies of the inspection reports are enclosed for your records.

Please refer to the "Summary of Findings" section of the inspection report and provide a written response for each item that was noted. This response should be mailed to the attention of the Office of Water Quality Compliance Branch at the address below my signature or emailed to <u>Water-Inspection-Report@adeq.state.ar.us</u>. This response should contain documentation describing the course of action taken to correct each item noted. The corrective action(s) should be completed as soon as possible and the written response with all necessary documentation (i.e. photos) is due by **November 3, 2022**.

If I can be of any assistance please contact me at <u>frasher@adeq.state.ar.us</u> or 870-735-7221 ext.-15.

Sincerely,

Sarah Frasher Inspector, Office of Water Quality 5301 Northshore Drive, North Little Rock, AR, 72118

4	AL OTTACTOR	OFFICE OF WATER QUALITY INSPECTION REPORT						
() - ARK4		AFIN: 19-00071 PERMIT #: AR0021903 DATE: 3/9/2022					3/9/2022	
MERGY			DUNTY: 19 Cross			PDS #: 123032		MEDIA: WN
				• 4 Long: -90.828			Entrance	
	FACILITY INFORMAT							
NAME	E:			FACILITY TYPE:	INSPEC	for ID#:		•
	y of Wynne WWTP			1 - Municipal	-	847 S - Sta		
54	5 Bowden Road			FACILITY EVALUATION RATIN 3 - Satisfactory		-	ECTION TYPE: mpliance	Evaluation
CITY:	nne			DATE(S): EN	0:12	EXIT TIME: 10:57	PERMIT E	FECTIVE DATE:
RESPONSIBLE OFFICIAL				3/9/2022 1	0:12	10:57	8/1/20)18 XPIRATION DATE:
	E: / TITLE		<u> </u>				7/31/2	
	ake Marotti / General Manager		FAYETTEVILLE SHALE RELATED: N					
Cit	y of Wynne			FAYETTEVILLE SHALE VIOLATIONS: N				
	ng address: 1 East Merriman Avenue			INSPECTION PARTICIPANTS				
	STATE, ZIP:			NAME/TITLE/PHONE/FAX/EMA	IL/ETC.:			
	nne AR 72396			Josh Weaver/ Wastewater Treatment Lab Supervisor				
PHON	ve & ext: / fax:							
EMAI	Ŀ							
	nnewater1@yahoo.com			-				
CC	INTACTED DURING INSPECTION:	NO						
	(S=S	atisfac		LUATIONS tisfactory, N=Not Applicable	/Evaluated)		
S	PERMIT	S	FLOW MEASUR		Ν	STORM		
Μ	RECORDS/REPORTS	S	LABORATORY		S		Y SITE RE	
S	OPERATION & MAINTENANCE	S		CEIVING WATER	S			IG PROGRAM
S	SAMPLING	S	SLUDGE HANDLING/DISPOSAL			PRETRE	ATMENT	
Ν	N OTHER:							
SUMMARY OF FINDINGS								
Th	The following violations were noted at the time of the inspection:							

1. The facility reported a FCB 30 day average of 8 colonies/100mL instead of <6 colonies/100mL. Differences were also reflected in the FCB Monthly average of 241 Mcol/day instead of <170 Mcol/day for the November 2021 DMR. See the attached DMR Calculation Check below for details.

2. The facility reported a CBOD Monthly Average of 4.17 mg/L instead of <4.17 mg/L for the January 2022 DMR. The facility must include the less than symbol "<" or greater than symbol ">" when any concentrations are reported as such within the laboratory results. See the attached DMR Calculation Check below for details.

The City is replacing aerators and working on the removal of paddle wheels in the racetrack aeration basin (Photos 3-4). The other paddle wheel will be removed and aerator replaced next year. The ultraviolet disinfection system will be replaced later this year (Photo 8).

An Industrial Stormwater Inspection for a No Exposure permit, ARR000293, was performed in conjunction with this inspection. Please view report for further details.

INSPECTOR'S SIGNATURE: Sarah Frasher	DATE: 8/2/2022
$D \rightarrow (1 - 1) h$	
SUPERVISOR'S SIGNATURE: Brent L. Walker	
SUPERVISOR'S SIGNATURE: Correction Brent L. Walker	DATE: 10/11/2022

Inspection Report: City of Wynne WWTP, AFIN: 19-00071, Permit #: AR0021903

SECTION A: PERMIT VERIFICATION	
PERMIT SATISFACTORILY ADDRESSES OBSERVATIONS	
DETAILS:	
1. CORRECT NAME AND MAILING ADDRESS OF PERMITTEE:	
2. NOTIFICATION GIVEN TO EPA/STATE OF NEW DIFFERENT OR INCREASED DISCHARGES:	
3. NUMBER AND LOCATION OF DISCHARGE POINTS AS DESCRIBED IN PERMIT:	
4. ALL DISCHARGES ARE PERMITTED:	
SECTION B: RECORDKEEPING AND REPORTING EVALUATION	
RECORDS AND REPORTS MAINTAINED AS REQUIRED BY PERMIT	
DETAILS:	·
1. ANALYTICAL RESULTS CONSISTENT WITH DATA REPORTED ON DMRS: <u>Incorrect reporting for FCB. Less than symbol ne</u> reported on DMRs.	
2. SAMPLING AND ANALYSES DATA ADEQUATE AND INCLUDE:	Øs 🖙 🗆 v 🗆 na 🗆 ne
a. DATES AND TIME(S) OF SAMPLING:	
b. EXACT LOCATION(S) OF SAMPLING:	
c. NAME OF INDIVIDUAL PERFORMING SAMPLING:	
d. ANALYTICAL METHODS AND TECHNIQUES:	
e. RESULTS OF CALIBRATIONS:	
f. RESULTS OF ANALYSES:	
g. DATES AND TIMES OF ANALYSES:	
h. NAME OF PERSON(S) PERFORMING ANALYSES:	
3. LABORATORY EQUIPMENT CALIBRATION AND MAINTENANCE RECORDS ADEQUATE:	Øs 🗆m 🗇u 🖾na 🖾ne
4. PLANT RECORDS INCLUDE SCHEDULES, DATES OF EQUIPMENT MAINTENANCE AND REPAIR:	Øs 🗆m 🗇u 🖾na 🖾ne
5. EFFLUENT LOADINGS CALCULATED USING DAILY EFFLUENT FLOW AND DAILY ANALYTICAL DATA:	Øy 🛛 n 🗆 na 🗇 ne
OFOTION OF OPERATIONS AND MAINTENANCE	
SECTION C: OPERATIONS AND MAINTENANCE	
TREATMENT FACILITY PROPERLY OPERATED AND MAINTAINED	ØS OM OU ONA ONE
TREATMENT FACILITY PROPERLY OPERATED AND MAINTAINED DETAILS:	
TREATMENT FACILITY PROPERLY OPERATED AND MAINTAINED DETAILS: 1. TREATMENT UNITS PROPERLY OPERATED:	
TREATMENT FACILITY PROPERLY OPERATED AND MAINTAINED DETAILS: 1. TREATMENT UNITS PROPERLY OPERATED: 2. TREATMENT UNITS PROPERLY MAINTAINED:	Øs Om Ou Ona One Øs Om Ou Ona One
TREATMENT FACILITY PROPERLY OPERATED AND MAINTAINED DETAILS: 1. TREATMENT UNITS PROPERLY OPERATED: 2. TREATMENT UNITS PROPERLY MAINTAINED: 3. STANDBY POWER OR OTHER EQUIVALENT PROVIDED:	Øs Om Ou Ona One Øs Om Ou Ona One Øs Om Ou Ona One
TREATMENT FACILITY PROPERLY OPERATED AND MAINTAINED DETAILS: 1. TREATMENT UNITS PROPERLY OPERATED: 2. TREATMENT UNITS PROPERLY MAINTAINED: 3. STANDBY POWER OR OTHER EQUIVALENT PROVIDED: 4. ADEQUATE ALARM SYSTEM FOR POWER OR EQUIPMENT FAILURES AVAILABLE:	Øs Im Iu Ina Ine
TREATMENT FACILITY PROPERLY OPERATED AND MAINTAINED DETAILS: 1. TREATMENT UNITS PROPERLY OPERATED: 2. TREATMENT UNITS PROPERLY MAINTAINED: 3. STANDBY POWER OR OTHER EQUIVALENT PROVIDED: 4. ADEQUATE ALARM SYSTEM FOR POWER OR EQUIPMENT FAILURES AVAILABLE: 5. ALL NEEDED TREATMENT UNITS IN SERVICE:	Øs Im Iu Ina Ine
TREATMENT FACILITY PROPERLY OPERATED AND MAINTAINED DETAILS: 1. TREATMENT UNITS PROPERLY OPERATED: 2. TREATMENT UNITS PROPERLY MAINTAINED: 3. STANDBY POWER OR OTHER EQUIVALENT PROVIDED: 4. ADEQUATE ALARM SYSTEM FOR POWER OR EQUIPMENT FAILURES AVAILABLE: 5. ALL NEEDED TREATMENT UNITS IN SERVICE: 6. ADEQUATE NUMBER OF QUALIFIED OPERATORS PROVIDED:	Øs Dm Du Dna Dne
TREATMENT FACILITY PROPERLY OPERATED AND MAINTAINED DETAILS: 1. TREATMENT UNITS PROPERLY OPERATED: 2. TREATMENT UNITS PROPERLY MAINTAINED: 3. STANDBY POWER OR OTHER EQUIVALENT PROVIDED: 4. ADEQUATE ALARM SYSTEM FOR POWER OR EQUIPMENT FAILURES AVAILABLE: 5. ALL NEEDED TREATMENT UNITS IN SERVICE: 6. ADEQUATE NUMBER OF QUALIFIED OPERATORS PROVIDED: 7. SPARE PARTS AND SUPPLIES INVENTORY MAINTAINED:	Øs m u na ne
TREATMENT FACILITY PROPERLY OPERATED AND MAINTAINED DETAILS: 1. TREATMENT UNITS PROPERLY OPERATED: 2. TREATMENT UNITS PROPERLY MAINTAINED: 3. STANDBY POWER OR OTHER EQUIVALENT PROVIDED: 4. ADEQUATE ALARM SYSTEM FOR POWER OR EQUIPMENT FAILURES AVAILABLE: 5. ALL NEEDED TREATMENT UNITS IN SERVICE: 6. ADEQUATE NUMBER OF QUALIFIED OPERATORS PROVIDED: 7. SPARE PARTS AND SUPPLIES INVENTORY MAINTAINED: 8. OPERATION AND MAINTENANCE MANUAL AVAILABLE:	Øs Im Iu Ina Ine
TREATMENT FACILITY PROPERLY OPERATED AND MAINTAINED DETAILS: 1. TREATMENT UNITS PROPERLY OPERATED: 2. TREATMENT UNITS PROPERLY MAINTAINED: 3. STANDBY POWER OR OTHER EQUIVALENT PROVIDED: 4. ADEQUATE ALARM SYSTEM FOR POWER OR EQUIPMENT FAILURES AVAILABLE: 5. ALL NEEDED TREATMENT UNITS IN SERVICE: 6. ADEQUATE NUMBER OF QUALIFIED OPERATORS PROVIDED: 7. SPARE PARTS AND SUPPLIES INVENTORY MAINTAINED: 8. OPERATION AND MAINTENANCE MANUAL AVAILABLE: 9. STANDARD OPERATING PROCEDURES AND SCHEDULES ESTABLISHED:	Øs Im Im Ima Ima Øs Im Im Ima Ima Øs Im Imm Imm Imm Øs Im Imm Imm Imm Øs Im Imm Imm Imm Øs Imm Imm Imm Imm <tr< td=""></tr<>
TREATMENT FACILITY PROPERLY OPERATED AND MAINTAINED DETAILS: 1. TREATMENT UNITS PROPERLY OPERATED: 2. TREATMENT UNITS PROPERLY MAINTAINED: 3. STANDBY POWER OR OTHER EQUIVALENT PROVIDED: 4. ADEQUATE ALARM SYSTEM FOR POWER OR EQUIPMENT FAILURES AVAILABLE: 5. ALL NEEDED TREATMENT UNITS IN SERVICE: 6. ADEQUATE NUMBER OF QUALIFIED OPERATORS PROVIDED: 7. SPARE PARTS AND SUPPLIES INVENTORY MAINTAINED: 8. OPERATION AND MAINTENANCE MANUAL AVAILABLE: 9. STANDARD OPERATING PROCEDURES AND SCHEDULES ESTABLISHED: 10. PROCEDURES FOR EMERGENCY TREATMENT CONTROL ESTABLISHED:	Øs m u na ne Øy n na ne
TREATMENT FACILITY PROPERLY OPERATED AND MAINTAINED DETAILS: 1. TREATMENT UNITS PROPERLY OPERATED: 2. TREATMENT UNITS PROPERLY MAINTAINED: 3. STANDBY POWER OR OTHER EQUIVALENT PROVIDED: 4. ADEQUATE ALARM SYSTEM FOR POWER OR EQUIPMENT FAILURES AVAILABLE: 5. ALL NEEDED TREATMENT UNITS IN SERVICE: 6. ADEQUATE NUMBER OF QUALIFIED OPERATORS PROVIDED: 7. SPARE PARTS AND SUPPLIES INVENTORY MAINTAINED: 8. OPERATION AND MAINTENANCE MANUAL AVAILABLE: 9. STANDARD OPERATING PROCEDURES AND SCHEDULES ESTABLISHED: 10. PROCEDURES FOR EMERGENCY TREATMENT CONTROL ESTABLISHED: 11. HAVE BYPASSES/OVERFLOWS OCCURRED AT THE PLANT OR IN THE COLLECTION SYSTEM IN THE LAST YEAR:	Øs Im Iu Ina Ine Øy In Ina Ine Øy In Ina Ine Øy Iu Iu Iu Iu
TREATMENT FACILITY PROPERLY OPERATED AND MAINTAINED DETAILS: 1. TREATMENT UNITS PROPERLY OPERATED: 2. TREATMENT UNITS PROPERLY MAINTAINED: 3. STANDBY POWER OR OTHER EQUIVALENT PROVIDED: 4. ADEQUATE ALARM SYSTEM FOR POWER OR EQUIPMENT FAILURES AVAILABLE: 5. ALL NEEDED TREATMENT UNITS IN SERVICE: 6. ADEQUATE NUMBER OF QUALIFIED OPERATORS PROVIDED: 7. SPARE PARTS AND SUPPLIES INVENTORY MAINTAINED: 8. OPERATION AND MAINTENANCE MANUAL AVAILABLE: 9. STANDARD OPERATING PROCEDURES AND SCHEDULES ESTABLISHED: 10. PROCEDURES FOR EMERGENCY TREATMENT CONTROL ESTABLISHED: 11. HAVE BYPASSES/OVERFLOWS OCCURRED AT THE PLANT OR IN THE COLLECTION SYSTEM IN THE LAST YEAR: 12. IF SO, HAS THE REGULATORY AGENCY BEEN NOTIFIED:	Image: Second
TREATMENT FACILITY PROPERLY OPERATED AND MAINTAINED DETAILS: 1. TREATMENT UNITS PROPERLY OPERATED: 2. TREATMENT UNITS PROPERLY MAINTAINED: 3. STANDBY POWER OR OTHER EQUIVALENT PROVIDED: 4. ADEQUATE ALARM SYSTEM FOR POWER OR EQUIPMENT FAILURES AVAILABLE: 5. ALL NEEDED TREATMENT UNITS IN SERVICE: 6. ADEQUATE NUMBER OF QUALIFIED OPERATORS PROVIDED: 7. SPARE PARTS AND SUPPLIES INVENTORY MAINTAINED: 8. OPERATION AND MAINTENANCE MANUAL AVAILABLE: 9. STANDARD OPERATING PROCEDURES AND SCHEDULES ESTABLISHED: 10. PROCEDURES FOR EMERGENCY TREATMENT CONTROL ESTABLISHED: 11. HAVE BYPASSES/OVERFLOWS OCCURRED AT THE PLANT OR IN THE COLLECTION SYSTEM IN THE LAST YEAR: 12. IF SO, HAS THE REGULATORY AGENCY BEEN NOTIFIED: 13. HAS CORRECTIVE ACTION BEEN TAKEN TO PREVENT ADDITIONAL BYPASSES/OVERFLOWS:	Image: Second state Image: Second state
TREATMENT FACILITY PROPERLY OPERATED AND MAINTAINED DETAILS: 1. TREATMENT UNITS PROPERLY OPERATED: 2. TREATMENT UNITS PROPERLY MAINTAINED: 3. STANDBY POWER OR OTHER EQUIVALENT PROVIDED: 4. ADEQUATE ALARM SYSTEM FOR POWER OR EQUIPMENT FAILURES AVAILABLE: 5. ALL NEEDED TREATMENT UNITS IN SERVICE: 6. ADEQUATE NUMBER OF QUALIFIED OPERATORS PROVIDED: 7. SPARE PARTS AND SUPPLIES INVENTORY MAINTAINED: 8. OPERATION AND MAINTENANCE MANUAL AVAILABLE: 9. STANDARD OPERATING PROCEDURES AND SCHEDULES ESTABLISHED: 10. PROCEDURES FOR EMERGENCY TREATMENT CONTROL ESTABLISHED: 11. HAVE BYPASSES/OVERFLOWS OCCURRED AT THE PLANT OR IN THE COLLECTION SYSTEM IN THE LAST YEAR: 12. IF SO, HAS THE REGULATORY AGENCY BEEN NOTIFIED:	Øs Im Iu Ina Ine Øy In Ina Ine Øy In Ina Ine Øy Iu Iu Iu Iu

Inspection Report. City of Wynne WWTF, AFIN. 19-00071, Fernit #. ARC	/021905
SECTION D: SAMPLING	
PERMITTEE SAMPLING MEETS PERMIT REQUIREMENTS	ØS OM OU ONA ONE
DETAILS:	
1. SAMPLES TAKEN AT SITE(S) SPECIFIED IN PERMIT:	
2. LOCATIONS ADEQUATE FOR REPRESENTATIVE SAMPLES:	
3. FLOW PROPORTIONED SAMPLES OBTAINED WHEN REQUIRED BY PERMIT:	
4. SAMPLING AND ANALYSES COMPLETED ON PARAMETERS SPECIFIED IN PERMIT:	
5. SAMPLING AND ANALYSES PERFORMED AT FREQUENCY SPECIFIED IN PERMIT:	🗹 y 🗆 n 🗆 na 🗆 ne
6. SAMPLE COLLECTION PROCEDURES ADEQUATE:	Øy 🛛 n 🖓 na 🖓 ne
a. SAMPLES REFRIGERATED DURING COMPOSITING:	
b. PROPER PRESERVATION TECHNIQUES USED:	
c. CONTAINERS AND SAMPLE HOLDING TIMES CONFORM TO 40 CFR 136:	Øy 🛛 n 🗆 na 🗆 ne
7. IF MONITORING IS PERFORMED MORE OFTEN THAN REQUIRED ARE RESULTS REPORTED ON THE DMR:	
SECTION E: FLOW MEASUREMENT	
PERMITTEE FLOW MEASUREMENT MEETS PERMIT REQUIREMENTS	🗹 S 🗆 M 🗇 U 🗆 NA 🗆 NE
DETAILS:	
 PRIMARY FLOW MEASUREMENT DEVICE PROPERLY INSTALLED AND MAINTAINED: Yes TYPE OF DEVICE: 9 in. Parsha flume 	
2. FLOW MEASURED AT EACH OUTFALL AS REQUIRED:	
3. SECONDARY INSTRUMENTS (TOTALIZERS, RECORDERS, ETC.) PROPERLY OPERATED AND MAINTAINED: HydroRanger	
4. CALIBRATION FREQUENCY ADEQUATE:	
5. RECORDS MAINTAINED OF CALIBRATION PROCEDURES:	Øy 🗆n 🗆na 🗇ne
6. CALIBRATION CHECKS DONE TO ASSURE CONTINUED COMPLIANCE:	Øy 🗆n 🗆na 🗇ne
7. FLOW ENTERING DEVICE WELL DISTRIBUTED ACROSS THE CHANNEL AND FREE OF TURBULENCE:	Øy 🗆n 🗆na 🗆ne
8. FLOW MEASUREMENT EQUIPMENT ADEQUATE TO HANDLE EXPECTED RANGE OF FLOW RATES:	Øy 🛛 n 🖾 na 🖾 ne
9. HEAD MEASURED AT PROPER LOCATION:	Øy 🗆n 🗆na 🗇ne
SECTION F: LABORATORY	
PERMITTEE LABORATORY PROCEDURES MEET PERMIT REQUIREMENTS	ØS OM OU ONA ONE
DETAILS:	
1. EPA APPROVED ANALYTICAL PROCEDURES USED (40 CFR 136.3 FOR LIQUIDS, 503.8(B) FOR SLUDGES) :	Øy 🗆n 🗆na 🗆ne
2. IF ALTERNATIVE ANALYTICAL PROCEDURES ARE USED, PROPER APPROVAL HAS BEEN OBTAINED:	Øy 🗆n 🗆na 🗆ne
3. SATISFACTORY CALIBRATION AND MAINTENANCE OF INSTRUMENTS AND EQUIPMENT:	Øy 🗆n 🗆na 🗇ne
4. QUALITY CONTROL PROCEDURES ADEQUATE:	
5. DUPLICATE SAMPLES ARE ANALYZED ≥10% OF THE TIME:	
6. SPIKED SAMPLES ARE ANALYZED >10% OF THE TIME:	
7. COMMERCIAL LABORATORY USED:	
a. LAB NAME: <u>Arkansas Analytical</u>	
b. LAB ADDRESS: Little Rock, AR	
c. PARAMETERS PERFORMED: CBOD, TSS, NH3-N, DO, FCB, Total Arsenic, Total Copper, Total Phosphorus, Nitrate + Nitrite	Nitrogen, Sulfates, pH, WET Testing
8. BIOMONITORING PROCEDURES ADEQUATE:	
a. PROPER ORGANISMS USED:	
b. PROPER DILUTION SERIES FOLLOWED:	
c. PROPER TEST METHODS AND DURATION:	
d. RETESTS AND/OR TRE PERFORMED AS REQUIRED:	

SECTION G: EFFLUENT/RECEIVING WATERS OBSERVATIONS											
BASED ON VISUAL OBSERVATIONS ONLY											
DETAILS:											
OUTFALL #:	OIL SHEEN	GREASE	TURBIDITY	VISIBLE FOAM	FLOATING SOLIDS	COLOR	OTHER				
001	None	None	Low	None	None	Clear					
SECTION H: SLUDGE DISPOSAL											
SLUDGE DISPOSAL MEETS PERMIT REQUIREMENTS 🛛 S DM DU DNA DNE											
DETAILS:											
1. SLUDGE M	IANAGEMENT ADEQU	ATE TO MAINTAIN EF	FLUENT QUALITY:			⊠s ⊡m					
2. SLUDGE R	ECORDS MAINTAINED	D AS REQUIRED BY 40) CFR 503:			⊠s ⊡m					
3. FOR LAND	APPLIED SLUDGE, TY	YPE OF LAND APPLIE	D TO: (E.G., FOREST,	AGRICULTURAL, PUE	BLIC CONTACT SITE):						
SECTION I:	SAMPLING IN	SPECTION PRC	CEDURES								
SAMPLE R	RESULTS WITH	HIN PERMIT R	EQUIREMENT	S			IU ⊠NA ⊡NE				
DETAILS:											
1. SAMPLES	OBTAINED THIS INSPI	ECTION:				ΠY	🗆 n 🗹 na 🗆 ne				
2. TYPE OF S	AMPLE: GRAB:		METHOD: FREQUE	NCY:							
3. SAMPLES I	PRESERVED:						□n Øna □ne				
4. FLOW PRC	PORTIONED SAMPLE	S OBTAINED:				ΠY	□n Øna □ne				
5. SAMPLE O	BTAINED FROM FACIL	LITY'S SAMPLING DEV	/ICE:				□n Øna □ne				
6. SAMPLE R	EPRESENTATIVE OF	VOLUME AND NATUR	E OF DISCHARGE:				🗆 n 🗹 na 🗆 ne				
7. SAMPLE SI	PLIT WITH PERMITTE	E:									
8. CHAIN-OF-	CUSTODY PROCEDU	RES EMPLOYED:									
9. SAMPLES	COLLECTED IN ACCO	RDANCE WITH PERM	IT:			ΠY	🗆 n 🗹 na 🗆 ne				
	: STORM WAT										
	ATER MANAG	EMENT MEET	S PERMIT RE	QUIREMENTS			IU ⊠NA ⊡NE				
DETAILS:											
	PDATED AS NEEDED:										
-			CE WATERS:								
	N PREVENTION TEAM										
	N PREVENTION TEAM		2								
	DTENTIAL SOURCES A										
		IARGES ARE AUTHOR									
	RUCTURAL BMPS:	20.									
	ON-STRUCTURAL BMF										
11. INSPECTIC	ONS CONDUCTED AS					ЦY	⊡n Øna ⊡ne				

Inspection Report: City of Wynne WWTP, AFIN: 19-00071, Permit #: AR0021903

FLOW CALCULATION SHEET

		. 2011 0/								
Date: 3/9	/2022	Time: 10:	36							
Head in Inc	hes: 6.75	Feet:	0.5625							
	0.75	1 661.	0.3023	<u> </u>						
Type & Size of Primary Flow Measurement Device: 9 in. Parshall flume										
Name & Model of Secondary Flow Measurement Device: Hydroranger Plus										
Data af la at	Calibration of Ca	a a sa al a m v 🗖		40/40/00	01					
Date of last	Calibration of Se	condary F	IOW Device:	10/13/20	21					
Recorded F	Flow at Date & Tir	ne Listed A	Above:	0.845	(Facility Flow Meter)					
Oslavilatad				0.074						
	Flow at Date & Ti ted using flow charts in:			0.871						
% Error =	Recorded Value	Recorded Value - Calculated Value X 100								
/0 21101 =	Calc	ulated Valu	Je							
	0.845		0.871							
% Error =	0.040	0.871	0.071	— X 100						
% Error =	-0.026	— X 100								
70 EITOI =	0.871	X 100								
% Error =	-0.0299	X 100								
	0.0200	7,100								
% Error =	-3	%								
Comments: Within ± 10%										

DMR Calculation Check

Reporting Period:	From	<u>2021</u> Year	<u>11</u> Month	01 Day	_ To _	2021 Year	<u>11</u> Month	<u>30</u> Day	
Parameter Checked:		FCB							
		Loading				Concen			
	Mass Mo. Avg. –			Mor Mo. Avg. –			7-day Avg. –		
		Mcol/day		coloni	ies/10	OmL	colonies/	100mL	
Reported Value:		241			8		36		
		470			.0		20		
Calculated Value:		<170			<6		36		
Permit Value:		104,500		1	,000, I		2,00	0	

Differences due to facility using a value of 2 for calculations when laboratory reports a value of 1 or <1. Calculations should be done with a value of 1 when reported as <1 and the less than symbol used for any results.

If calculated value does not equal reported value, explain:

DMR Calculation Check

Reporting Period:	From	2022 Year	01 Month	01 Day	_ To _	2022 Year	01 Month	<u>31</u> Day		
Parameter Checked:		CBOD	-							
		Loading Mass			Concentration Monthly					
	Mo.	Mo. Avg Ibs/day			vg r		7-day Avg	mg/l		
Reported Value:		47.514		4.17			10.2			
Calculated Value:		<47.5			<4.2		10.2	2		
Permit Value:		276		12			18			

Not reporting the less than symbol, "<", when results calculated using concentrations reported as "<".

If calculated value does not equal reported value, explain:











