



ARKANSAS

ENERGY & ENVIRONMENT

October 17, 2022

David Stewart, Mayor
City of Newport
615 Third St.
Newport, AR 72112
Via email: newportmayor@newportar.org

RE: City of Newport-Airport Ind. Park Inspection
AFIN: 34-00061 **Permit No.: AR0045225**

Dear Mr. Stewart:

On June 28, 2022, DEQ Inspector Wes Klasky performed a Reconnaissance Inspection of the above referenced facility in accordance with the provisions of the Federal Clean Water Act, the Arkansas Water and Air Pollution Control Act, and the regulations promulgated thereunder. A copy of the inspection report is enclosed for your records.




No violations were noted at the time of the inspection. Please review the attached inspection report for any comments.

If I can be of any assistance please contact me at brent.l.walker@adeq.state.ar.us or (870) 935-7221, extension 12.

Sincerely,

A handwritten signature in black ink that reads "Brent L. Walker".

Brent L. Walker
Inspector Supervisor, Office of Water Quality
5301 Northshore Drive, North Little Rock, AR, 72118

 ENVIRONMENTAL QUALITY	OFFICE OF WATER QUALITY				
	INSPECTION REPORT				
	AFIN: 34-00061	PERMIT #: AR0045225	DATE: 6/28/2022		
	COUNTY: 34 Jackson	PDS #: 123039	MEDIA: WN		
GPS LAT: 35.634896 LONG: -91.183896 LOCATION: General Area					
FACILITY INFORMATION		INSPECTION INFORMATION			
NAME: City of Newport-Airport Ind. P LOCATION: 8200 Theatre Dr. CITY: Newport		FACILITY TYPE: 1 - Municipal INSPECTOR ID#: 93162 S - State FACILITY EVALUATION RATING: N INSPECTION TYPE: Reconnaissance			
RESPONSIBLE OFFICIAL		DATE(S): 6/28/2022 ENTRY TIME: 10:25 EXIT TIME: 10:50 PERMIT EFFECTIVE DATE: 5/1/2022 PERMIT EXPIRATION DATE: 4/30/2027			
NAME: / TITLE David Stewart / Mayor COMPANY: City of Newport MAILING ADDRESS: 615 Third St. CITY, STATE, ZIP: Newport AR 72112 PHONE & EXT: / FAX: 870-523-8121 / EMAIL: newportmayor@newportar.org		FAYETTEVILLE SHALE RELATED: N FAYETTEVILLE SHALE VIOLATIONS: N			
CONTACTED DURING INSPECTION: No		INSPECTION PARTICIPANTS			
		NAME/TITLE/PHONE/FAX/EMAIL/ETC.: Billy Hall / Operator			
AREA EVALUATIONS					
(S=Satisfactory, M=Marginal, U=Unsatisfactory, N=Not Applicable/Evaluated)					
S	PERMIT	S	FLOW MEASUREMENT	N	STORMWATER
S	RECORDS/REPORTS	S	LABORATORY	N	FACILITY SITE REVIEW
M	OPERATION & MAINTENANCE	S	EFFLUENT/RECEIVING WATER	N	SELF-MONITORING PROGRAM
S	SAMPLING	S	SLUDGE HANDLING/DISPOSAL	N	PRETREATMENT
N	OTHER:				
SUMMARY OF FINDINGS					
None; see comments below.					
GENERAL COMMENTS					
No recent discharges had occurred from this facility. Wastewater from this plant was being routed to the City of Newport's main WWTP for further treatment and ultimate discharge.					
INSPECTOR'S SIGNATURE:  Wes Klasky				DATE: 7/18/2022	
SUPERVISOR'S SIGNATURE:  Brent L. Walker				DATE: 10/11/2022	

Office of Water Quality Photographic Evidence Sheet

Location:	City of Newport-Airport Ind. P		
Photographer:	Wes Klasky	Date:	6/28/2022
Time:	10:34	Witness:	None
Photo #:	1	Description: View of clarifier not currently receiving wastewater.	



Photographer:	Wes Klasky	Date:	6/28/2022
Time:	10:26	Witness:	None
Photo #:	2	Description: View of aeration pond.	



Office of Water Quality Photographic Evidence Sheet

Location:	City of Newport-Airport Ind. P		
Photographer:	Wes Klasky	Date:	6/28/2022
Time:	10:26	Witness:	None
Photo #:	3	Description:	
View of influent flow measurement meter.			



Photographer:	Wes Klasky	Date:	6/28/2022
Time:	10:27	Witness:	None
Photo #:	4	Description:	
View of influent entering the aeration pond.			



Office of Water Quality Photographic Evidence Sheet

Location:	City of Newport-Airport Ind. P		
Photographer:	Wes Klasky	Date:	6/28/2022
Time:	10:31	Witness:	None
Photo #:	5	Description:	
View of outlet area from aeration pond.			



Photographer:	Wes Klasky	Date:	6/28/2022
Time:	10:33	Witness:	None
Photo #:	6	Description:	
View of blower motors.			



Office of Water Quality Photographic Evidence Sheet

Location:	City of Newport-Airport Ind. P		
Photographer:	Wes Klasky	Date:	6/28/2022
Time:	10:33	Witness:	None
Photo #:	7	Description:	View of clarifier.



Photographer:	Wes Klasky	Date:	6/28/2022
Time:	10:36	Witness:	None
Photo #:	8	Description:	View of chlorine contact chamber. Not in use at time of inspection.



Office of Water Quality Photographic Evidence Sheet

Location:	City of Newport-Airport Ind. P				
Photographer:	Wes Klasky	Date:	6/28/2022	Time:	10:37
Witness:	None	Photo #:	9		
Description:	View of flow measurement area.				



Photographer:	Wes Klasky	Date:	6/28/2022	Time:	10:42
Witness:	None	Photo #:	10		
Description:	View of flow recording equipment.				

