



**DIVISION OF  
ENVIRONMENTAL  
QUALITY**

Sarah Huckabee Sanders  
GOVERNOR

Shane E. Khoury  
SECRETARY

September 25, 2023

Mr. David Langley, EHS Manager  
Intimidator Group  
1 Bad Boy Blvd.  
Batesville, AR 72501  
Email Address

RE: Intimidator Group - Industrial User Inspection  
AFIN: 32-00530 Permit No.: AR0020702 (Batesville Water Utilities)

Dear Mr. Langley:


On August 10, 2023, I performed an Industrial User Inspection of the above referenced facility in accordance with the provisions of the Federal Clean Water Act, the Arkansas Water and Air Pollution Control Act, and the regulations promulgated thereunder. A copy of the inspection report is enclosed for your records.

No violations were noted at the time of the inspection. Please refer to the inspection report for any comments. If I can be of any assistance please contact me at [Jason.Bolenbaugh@adeq.state.ar.us](mailto:Jason.Bolenbaugh@adeq.state.ar.us) or 501-682-0659.

Sincerely,

A handwritten signature in black ink, appearing to read 'Jason Bolenbaugh'.

Jason Bolenbaugh  
Compliance Branch Manager, Office of Water Quality

 <b>ENVIRONMENTAL QUALITY</b>		<b>OFFICE OF WATER QUALITY</b>				
		<b>INSPECTION REPORT</b>				
		AFIN: 32-00530		PERMIT #: AR0020702		DATE: 8/10/2023
		COUNTY: 32 Independence		PDS #: 127038		MEDIA: WN
		GPS LAT: 35.79741 LONG: -91.63580 LOCATION: General Area				
<b>FACILITY INFORMATION</b>			<b>INSPECTION INFORMATION</b>			
NAME: <b>Intimidator Group</b> LOCATION: <b>1 Bad Boy Blvd.</b> CITY: <b>Batesville</b>			FACILITY TYPE: <b>2 - Industrial</b>	INSPECTOR ID#: <b>83321 S - State</b>		
			FACILITY EVALUATION RATING: <b>4 - Satisfactory</b>	INSPECTION TYPE: <b>Industrial User</b>		
			DATE(S): <b>8/10/2023</b>	ENTRY TIME: <b>09:15</b>	EXIT TIME: <b>12:17</b>	
			PERMIT EFFECTIVE DATE:  PERMIT EXPIRATION DATE:			
<b>RESPONSIBLE OFFICIAL</b>						
NAME: / TITLE <b>Mr. David Langley / EHS Manager</b> COMPANY: <b>Intimidator Group</b> MAILING ADDRESS: <b>1 Bad Boy Blvd.</b> CITY, STATE, ZIP: <b>Batesville AR 72501</b> PHONE & EXT: / FAX: <b>870-569-5019 /</b> EMAIL: <b>david.langley@intimidatorutv.com</b>			FAYETTEVILLE SHALE RELATED: <b>N</b> FAYETTEVILLE SHALE VIOLATIONS: <b>N</b>			
CONTACTED DURING INSPECTION: <b>Yes</b>			<b>INSPECTION PARTICIPANTS</b>			
			NAME/TITLE/PHONE/FAX/EMAIL/ETC.: <b>Steven Smith, Paint Supervisor, Intimidator</b> <b>Colton Britt, Paint Lead, Intimidator</b> <b>Steve Bateman, Operations Manager</b>			
<b>AREA EVALUATIONS</b>						
(S=Satisfactory, M=Marginal, U=Unsatisfactory, N=Not Applicable/Evaluated)						
**	PERMIT	**	FLOW MEASUREMENT	**	STORMWATER	
**	RECORDS/REPORTS	**	LABORATORY	**	FACILITY SITE REVIEW	
**	OPERATION & MAINTENANCE	**	EFFLUENT/RECEIVING WATER	**	SELF-MONITORING PROGRAM	
**	SAMPLING	**	SLUDGE HANDLING/DISPOSAL	<b>S</b>	PRETREATMENT	
**	OTHER:					

<b>SUMMARY OF FINDINGS</b>
<p>Intimidator Group (Intimidator) is an industrial user that discharges pretreated process water to Batesville Water Utilities (BWU) wastewater treatment plant permitted under NPDES Permit AR0020702. Intimidator is monitored under Pretreatment Tracking Number ARP001058. No violations of pretreatment standards were noted during the inspection. The following are observations made during the inspection.</p> <p>No violations were noted during the inspection. The following was noted during the inspection.</p> <ul style="list-style-type: none"> <li>• Intimidator is issued a pretreatment permit through BWU. The permit was issued on January 1, 2021 and will expire on December 31, 2025. It was modified on June 20, 2023. The facility is required to sample effluent twice per year for the following pollutants: Cadmium, Total Chromium, Copper, Lead, Nickel, Silver, Zinc, Total Cyanide, Total Toxic Organics, Oil &amp; Grease, and pH.</li> <li>• Samples are collected according to 40 CFR 433.17 and local limits established by BWU's Pretreatment Ordinance 93-1-1. Samples are collected semi-annually.</li> <li>• Intimidator operates 3 shifts per day, five days per week. Production remains relatively constant so the facility does not exhibit seasonal increases/decreases in production. Typical shutdown periods are only on the weekends.</li> <li>• No changes in the production processes have occurred that need to be reported to the State or BWU. The nature of the process is phosphatizing for powder coating steel and aluminum for multi-terrain vehicles. There are five stages in which the products are rinsed with an acid rinse or water rinse. Each stage tank ranges in size from 673 gallons to 1,884 gallons (Stage 1). PH is adjusted throughout the</li> </ul>

process. Stage 1 the pH will typically be ~11-12 SU. The Stage 1 tank does have an audible alarm that can be heard throughout the production area in the event of an overflow. All chemicals are stored within secondary containment pallets.


- The facility will typically discharge approximately 20,000 gallons per day to the BWU wastewater treatment plant which consists of sanitary wastewater (~15,000 GPD) and process wastewater (~5,000 GPD). No floor drains within the production areas drain directly to the BWU wastewater treatment plant.
- All generated hazardous waste materials are hauled away by Clean Harbors. Most of the hazardous waste consists of oil and gasoline used in the testing of engines.
- The facility uses a large, 2,100 gallon holding tank to contain sludge until it can be hauled away. The holding tank is not within the production area and is outside adjacent to the sampling and discharge point. It was recommended the tank have a label on it to identify its use.
- All systems appeared to be properly operated and maintained and facility staff are knowledgeable about the pretreatment process and permitting requirements.
- In the event of any spill or slug load discharge the facility has contact information for BWU readily available. There have not been any slug loads sent to BWU.
- The facility was in compliance with all self-monitoring and sampling requirements.

Please confirm if the sludge generated from the facility is or is not a hazardous waste.

**GENERAL COMMENTS**

Intimidator Group has a Hazardous Waste Generator ID ARR000029926; Regulated Storage Tank Permit 32001679; and, a NPDES Industrial Stormwater General Permit (ARR001548) – No Exposure Exclusion. An inspection of the stormwater permit was conducted while on site. Please refer to the separate inspection report for further details.

Ms. Jamie Belcourt served as the Office of Water Quality (OWQ) Pretreatment Coordinator during this inspection however, she has recently vacated this position. If there are any questions regarding pretreatment requirements you may contact the OWQ Permits Branch or Jason Bolenbaugh, OWQ Compliance Branch Manager.

INSPECTOR'S SIGNATURE:	←Click text to left to add signature	-Inspector Name	DATE:
SUPERVISOR'S SIGNATURE:		Jason Bolenbaugh	DATE: 9/22/2023

**Industrial Site Visit**

**Industry Contacts: Mr. David Langley, Mr. Colton Britt**

**Type of Industry: Metal Finishing Point Source Category – 40 CFR 433.17**

- |     |  |      |     |     |    |     |     |
|-----|--|------|-----|-----|----|-----|-----|
| 1.  | Significant industrial user:                       | X___ | Yes | ___ | No | ___ | N/A |
| 2.  | Pretreatment equipment or procedures?              | X___ | Yes | ___ | No | ___ | N/A |
| 3.  | Pretreatment equipment maintained and operational? | X___ | Yes | ___ | No | ___ | N/A |
| 4.  | Hazardous waste generated or stored?               | X___ | Yes | ___ | No | ___ | N/A |
| 5.  | Proper solid waste disposal?                       | X___ | Yes | ___ | No | ___ | N/A |
| 6.  | Solvent management/TTO control?                    | X___ | Yes | ___ | No | ___ | N/A |
| 7.  | Suitable sampling location?                        | X___ | Yes | ___ | No | ___ | N/A |
| 8.  | Appropriate self-monitoring procedures/equipment?  | X___ | Yes | ___ | No | ___ | N/A |
| 9.  | Adequate spill prevention?                         | X___ | Yes | ___ | No | ___ | N/A |
| 10. | Industry familiar with limits and requirements?    | X___ | Yes | ___ | No | ___ | N/A |

**Additional Comments:**

Office of Water Quality Photographic Evidence Sheet

Location:	<b>Intimidator Group</b>		
Photographer:	<b>Jamie Belcourt</b>	Date:	<b>8/10/2023</b>
Time:	<b>11:00</b>	Witness:	
Photo #:	<b>1</b>	Description:	<b>Metals entrance to the coating stage.</b>



Photographer:	<b>Jamie Belcourt</b>	Date:	<b>8/10/2023</b>
Time:	<b>11:01</b>	Witness:	
Photo #:	<b>2</b>	Description:	<b>Acids used for metal cleaning located opposite of Photo #1. Acids are on secondary containment.</b>



Office of Water Quality Photographic Evidence Sheet

Location:	<b>Intimidator Group</b>		
Photographer:	<b>Jamie Belcourt</b>	Date:	<b>8/10/2023</b>
Time:	<b>11:04</b>		Photo #:
Witness:			<b>3</b>
Description:	<b>Stage 1 – Alkaline Rinse Tank</b>		



Photographer:	<b>Jamie Belcourt</b>	Date:	<b>8/10/2023</b>
Time:	<b>11:04</b>		Photo #:
Witness:			<b>4</b>
Description:	<b>Stage 2 – Water Rinse Tank</b>		



Office of Water Quality Photographic Evidence Sheet

Location:	<b>Intimidator Group</b>		
Photographer:	<b>Jamie Belcourt</b>	Date:	<b>8/10/2023</b>
Time:	<b>11:06</b>	Witness:	
Photo #:	<b>5</b>	Description:	<b>Stage 3 – Water Rinse Tank</b>



Photographer:	<b>Jamie Belcourt</b>	Date:	<b>8/10/2023</b>
Time:	<b>11:07</b>	Witness:	
Photo #:	<b>6</b>	Description:	<b>Stage 4 – Acid Rinse Tank</b>



Office of Water Quality Photographic Evidence Sheet

Location:	<b>Intimidator Group</b>				
Photographer:	<b>Jamie Belcourt</b>	Date:	<b>8/10/2023</b>	Time:	<b>11:09</b>
Witness:				Photo #:	<b>7</b>
Description:	<b>Stage 5 – Water Rinse Tank</b>				



Photographer:	<b>Jason Bolenbaugh</b>	Date:	<b>8/10/2023</b>	Time:	<b>11:06</b>
Witness:				Photo #:	<b>8</b>
Description:	<b>DSCN6251: Process wastewater sump within the pretreatment area.</b>				





Office of Water Quality Photographic Evidence Sheet

Location:	<b>Intimidator Group</b>		
Photographer:	<b>Jason Bolenbaugh</b>	Date:	<b>8/10/2023</b>
Time:	<b>11:08</b>	Witness:	
Photo #:	<b>9</b>	Description: <b>DSCN6252: Holding tank.</b>	



Photographer:	<b>Jason Bolenbaugh</b>	Date:	<b>8/10/2023</b>
Time:	<b>11:09</b>	Witness:	
Photo #:	<b>10</b>	Description: <b>DSCN6254: Discharge point to the BWU wastewater collection system.</b>	



Office of Water Quality Photographic Evidence Sheet

Location:	<b>Intimidator Group</b>		
Photographer:	<b>Jason Bolenbaugh</b>	Date:	<b>8/10/2023</b>
Time:	<b>11:08</b>		Photo #:
Witness:			<b>9</b>
Description:	<b>DSCN6261: Used oil and gasoline storage area.</b>		



Photographer:		Date:		Time:	
Witness:				Photo #:	
Description:					

PAGE INTENTIONALLY LEFT BLANK