 <p><b>ENVIRONMENTAL QUALITY</b></p>	<b>OFFICE OF WATER QUALITY</b>		
	<b>INSPECTION REPORT</b>		
	AFIN: 02-00013	PERMIT #: AR0001210	DATE: 10/17/2024
	COUNTY: 02 Ashley	PDS #: 127988	MEDIA: WN
GPS LAT: 33.135624 LONG: -91.966954 LOCATION: Entrance			

FACILITY INFORMATION	INSPECTION INFORMATION
NAME: <b>Georgia-Pacific Crossett LLC</b> LOCATION: <b>100 Mill Supply Road</b> CITY: <b>Crossett, AR 71635</b>	FACILITY TYPE: <b>2 - Industrial</b> INSPECTOR ID#: <b>101531 S - State</b> FACILITY EVALUATION RATING: <b>5 - Satisfactory</b> INSPECTION TYPE: <b>Compliance Sampling</b> DATE(S): <b>10/17/2024</b> ENTRY TIME: <b>06:28</b> EXIT TIME: <b>08:44</b> PERMIT EFFECTIVE DATE: <b>11/1/2010</b> PERMIT EXPIRATION DATE: <b>10/3/2015</b>
RESPONSIBLE OFFICIAL	FAYETTEVILLE SHALE RELATED: <b>N</b> FAYETTEVILLE SHALE VIOLATIONS: <b>N</b>
NAME / TITLE: <b>Deborah Coduto / Vice President of Manufacturing</b> COMPANY: <b>Georgia-Pacific Crossett, LLC</b> MAILING ADDRESS: <b>10 Mill Supply Road</b> CITY, STATE, ZIP: <b>Crossett AR 71635</b> PHONE & EXT. / FAX: <b>918-346-3573 /</b> EMAIL: <b>deborah.coduto@gapac.com</b>	INSPECTION PARTICIPANTS
CONTACTED DURING INSPECTION: <b>Yes</b>	NAME/TITLE/PHONE/FAX/EMAIL/ETC.: <b>Rachel Johnson/Environmental Compliance/870-415-6362/rachel.johnson2@gapac.com</b>

AREA EVALUATIONS					
(S=Satisfactory, M=Marginal, U=Unsatisfactory, N=Not Applicable/Evaluated)					
**	PERMIT	**	FLOW MEASUREMENT	**	STORMWATER
**	RECORDS/REPORTS	**	LABORATORY	**	FACILITY SITE REVIEW
**	OPERATION & MAINTENANCE	**	EFFLUENT/RECEIVING WATER	**	SELF-MONITORING PROGRAM
**	SAMPLING	**	SLUDGE HANDLING/DISPOSAL	**	PRETREATMENT
**	OTHER:				

**SUMMARY OF FINDINGS**

**No violations observed at the time of inspection.**

**GENERAL COMMENTS**

**I performed a Compliance Sampling Inspection (CSI) at Georgia Pacific Crossett LLC on October 17, 2023, with the above participants. This sampling was performed as a split sample and the results from Arkansas E&E DEQ Laboratory were compared with the results from GP-Crossett. The results were well within the range of the results that were provided to me by GP Crossett. There were no issues observed with the collected and analysis of samples at this facility.**



INSPECTOR'S SIGNATURE:  <b>Michael Young</b>	DATE: 11/05/2024
SUPERVISOR'S SIGNATURE:  <b>Jason Bolenbaugh</b>	DATE: 11/13/2024

Table 1. Results from GP-Crossett and DEQ Laboratory for October 17, 2023, sample event.

<b>Effluent Characteristics - Outfall 001</b>	<b>Discharge Limitations</b>		<b>Results from GP</b>		<b>Results from DEQ</b>	
	Concentration (mg/L)		Concentration (mg/L)		Concentration (mg/L)	
	Monthly Avg.	Daily Max	Monthly Avg.	Daily Max	Monthly Avg.	Daily Max
Biochemical Oxygen Demand (BOD5)	64.4	123.8		5.4		7.59
Total Suspended Solids (TSS)	119.6	222.4		15		14.8
2, 3, 7, 8 - TCDD	Report pg/l	Report pg/l		--		--
Absorbable Organic Halogens (AOX)	N/A	N/A		--		--
Diesldrin	0.00091	0.00284		--		--
Total Recoverable Copper	18.75	37.62		0.0012		<0.0050
Total Recoverable Zinc	194.58	390.41		<0.010		<0.0050
Total Phosphorus	Report	Report		0.15		0.14
Nitrates as Nitrogen	Report	Report		0.41		0.53
pH	6	9		7.12		7.05

<b>Effluent Characteristics</b>	<b>Discharge Limitations</b>		<b>Results from GP</b>		<b>Results from DEQ</b>	
	Concentration (mg/L)		Concentration (mg/L)		Concentration (mg/L)	
	Monthly Avg.	Daily Max	Monthly Avg.	Daily Max	Monthly Avg.	Daily Max
Biochemical Oxygen Demand (BOD5)	Report	Report		4.2		9.89
Total Suspended Solids (TSS)	Report	Report		12		10.5
2, 3, 7, 8 - TCDD	Report pg/l	Report pg/l		--		--
Absorbable Organic Halogens (AOX)	N/A	N/A		--		--
Diesldrin	0.00091	0.00284		--		--
Total Recoverable Copper	18.75	37.62		0.0011		0.000852
Total Recoverable Zinc	194.58	390.41		0.016		0.0179
Total Phosphorus	Report	Report		0.1		0.07
Nitrates as Nitrogen	Report	Report		<0.050		<0.05
pH	6	9		6.64		6.58

-- indicates results were not included because DEQ lab was unable to analyze.

# Analytical Results



ENVIRONMENTAL  
QUALITY

## Lab Contact Info:

DEQ OWQ Laboratory  
5301 Northshore Drive, North Little Rock, AR 72118  
www.adeq.state.ar.us

Lessie Redican  
Lessie.Redican@arkansas.gov  
501-682-0937

Collector: Young, Michael

Project: CSI

Project Description: Georgia Pacific split sample (AR0001210 AFIN 02-00013) 2023 2802-2803

Date and Time Received: 10/17/2023 11:43:00

Work Order Number: WO-231017-02

## Sample Receipt Conditions:

Condition	Response	Comment
Is the COC completed properly?	Yes	
Temperature on Receipt	1.3°C	
Received on Ice	Yes	
Containers are Correct	Yes	
Custody Seals	No	
COC/Labels Agree	Yes	

## Data Qualifiers

Qualifier Flag	Description
R	RPD value of field duplicates does not meet laboratory acceptance criteria

# Analytical Results



ENVIRONMENTAL  
QUALITY

This analytical report must be reproduced in its entirety

Laboratory Name: DEQ OWQ Laboratory  
 Contact Name: Young, Michael  
 Lab Address: 5301 Northshore Drive North Little Rock, AR 72118

Email: YoungM@adeq.state.ar.us  
 Phone: 501-837-2073  
 Fax:

Collector: Young, Michael Site: GP - Outfall 001

Work Order Number: WO-231017-02

Sample Classification: Routine Monitoring

Project: CSI

Matrix: Water

Collected: 10/17/2023 7:18

Sample Barcode: 

Sample Number: 2023-2802

## Nitrate +Nitrite as N

Method: SM 4500-NO3 F, 2011

Analyst: JR

Aliquot #: 2023-2802-1-01

Batch Number: AB-231018-023

Analyte(s)	Result	Units	Q	Reporting Limit	Dilution	Analysis Date and Time
Nitrite+Nitrate as Nitrogen	0.53	mg/L		0.05	1	10/17/2023 17:57

## pH

Method: SM 4500-H+ B, 2000

Analyst: MY

Aliquot #: 2023-2802-1-02

Batch Number: AB-231030-056

Analyte(s)	Result	Units	Q	Reporting Limit	Dilution	Analysis Date and Time
pH	7.05	None			1	10/17/2023 7:22

## Total Dissolved Solids

Method: SM 2540 C, 2011

Analyst: SD

Aliquot #: 2023-2802-1-03

Batch Number: AB-231023-005

Analyte(s)	Result	Units	Q	Reporting Limit	Dilution	Analysis Date and Time
Total Dissolved Solids	259	mg/L		5.00	1	10/18/2023 15:00

## Water Temperature

Method: SM 2550 B, 2000

Analyst: MY

Aliquot #: 2023-2802-1-04

Batch Number: AB-231030-057

Analyte(s)	Result	Units	Q	Reporting Limit	Dilution	Analysis Date and Time
Water Temperature	15.4	°C			1	10/17/2023 7:22

## Total Suspended Solids

Method: SM 2540 D, 2011

Analyst: SD

Aliquot #: 2023-2802-1-05

Batch Number: AB-231023-001

Analyte(s)	Result	Units	Q	Reporting Limit	Dilution	Analysis Date and Time
Total Suspended Solids	14.8	mg/L		2.00	1	10/18/2023 14:00

# Analytical Results



ENVIRONMENTAL  
QUALITY

This analytical report must be reproduced in its entirety

Collector: Young, Michael

Site: GP - Outfall 001

Work Order Number: WO-231017-02

Sample Classification: Routine Monitoring

Project: CSI

Matrix: Water

Collected: 10/17/2023 7:18

Sample Barcode: 

Sample Number: 2023-2802

## 5 day Biochemical Oxygen Demand

Method: SM 5210 B, 2011

Analyst: CAC

Aliquot #: 2023-2802-1-06

Batch Number: AB-231031-001

Analyte(s)	Result	Units	Q	Reporting Limit	Dilution	Analysis Date and Time
Biochemical Oxygen Demand	7.59	mg/L		0.20	1	10/18/2023 15:51

## Total Phosphorus as P

Method: SM 4500-P J, 2011

Analyst: JR

Aliquot #: 2023-2802-1-10

Batch Number: AB-231019-006

Analyte(s)	Result	Units	Q	Reporting Limit	Dilution	Analysis Date and Time
Total Phosphorus	0.14	mg/L		0.02	1	10/19/2023 10:42

## ICP/MS Metals (Total)

Method: EPA 200.8 (Rev. 5.4, 1994)

Analyst: PH

Aliquot #: 2023-2802-2-01

Batch Number: AB-231116-012

Analyte(s)	Result	Units	Q	Reporting Limit	Dilution	Analysis Date and Time
Antimony	<2.00	ug/L		2.00	1	11/16/2023 13:26
Arsenic	<1.00	ug/L		1.00	1	11/16/2023 13:26
Barium	94.4	ug/L		5.00	5	11/16/2023 13:26
Beryllium	<1.00	ug/L		1.00	1	11/16/2023 13:26
Cadmium	<0.300	ug/L		0.30	1	11/16/2023 13:26
Chromium	<1.00	ug/L		1.00	1	11/16/2023 13:26
Cobalt	0.178	ug/L		0.10	1	11/16/2023 13:26
Copper	<0.500	ug/L		0.50	1	11/16/2023 13:26
Lead	<0.500	ug/L		0.50	1	11/16/2023 13:26
Nickel	0.517	ug/L	R	0.50	1	11/16/2023 13:26
Selenium	<5.00	ug/L		5.00	1	11/16/2023 13:26
Silver	<0.100	ug/L		0.10	1	11/16/2023 13:26
Thallium	<0.500	ug/L		0.50	1	11/16/2023 13:26
Vanadium	0.686	ug/L	R	0.20	1	11/16/2023 13:26
Zinc	<5.00	ug/L		5.00	1	11/16/2023 13:26

# Analytical Results



ENVIRONMENTAL  
QUALITY

This analytical report must be reproduced in its entirety

Collector: Young, Michael

Site: GP - Outfall 001

Work Order Number: WO-231017-02

Sample Classification: Routine Monitoring

Project: CSI

Matrix: Water

Collected: 10/17/2023 7:18

Sample Barcode: 

Sample Number: 2023-2802

ICP/OES Metals (Total)

Method: EPA 200.7

Analyst: PH

Aliquot #: 2023-2802-2-13

Batch Number: AB-231201-007

Analyte(s)	Result	Units	Q	Reporting	Dilution	Analysis
				Limit		Date and Time
Aluminum	<0.100	mg/L		0.10	1	12/1/2023 11:43
Calcium	26.9	mg/L		1.00	1	12/1/2023 11:43
Iron	<0.100	mg/L		0.10	1	12/1/2023 11:43
Magnesium	3.10	mg/L		1.00	1	12/1/2023 11:43
Manganese	0.104	mg/L		0.02	1	12/1/2023 11:43
Potassium	3.72	mg/L		1.00	1	12/1/2023 11:43
Sodium	61.2	mg/L		5.00	5	12/1/2023 13:08
Phosphorus	<1.00	mg/L		1.00	1	12/1/2023 11:43

# Analytical Results



ENVIRONMENTAL  
QUALITY

This analytical report must be reproduced in its entirety

Collector: Young, Michael

Site: GP - SMS 002

Work Order Number: WO-231017-02

Sample Classification: Routine Monitoring

Project: CSI

Matrix: Water

Collected: 10/17/2023 7:56

Sample Barcode:



Sample Number: 2023-2803

## 5 day Biochemical Oxygen Demand

Method: SM 5210 B, 2011

Analyst: CAC

Aliquot #: 2023-2803-1-01

Batch Number: AB-231031-001

Analyte(s)	Result	Units	Q	Reporting Limit	Dilution	Analysis Date and Time
Biochemical Oxygen Demand	9.89	mg/L		0.20	1	10/18/2023 15:51

## pH

Method: SM 4500-H+ B, 2000

Analyst: MY

Aliquot #: 2023-2803-1-02

Batch Number: AB-231030-056

Analyte(s)	Result	Units	Q	Reporting Limit	Dilution	Analysis Date and Time
pH	6.58	None			1	10/17/2023 8:03

## Water Temperature

Method: SM 2550 B, 2000

Analyst: MY

Aliquot #: 2023-2803-1-03

Batch Number: AB-231030-057

Analyte(s)	Result	Units	Q	Reporting Limit	Dilution	Analysis Date and Time
Water Temperature	15.8	°C			1	10/17/2023 8:03

## Nitrate +Nitrite as N

Method: SM 4500-NO3 F, 2011

Analyst: JR

Aliquot #: 2023-2803-1-04

Batch Number: AB-231018-023

Analyte(s)	Result	Units	Q	Reporting Limit	Dilution	Analysis Date and Time
Nitrite+Nitrate as Nitrogen	<0.05	mg/L		0.05	1	10/17/2023 17:49

## Total Dissolved Solids

Method: SM 2540 C, 2011

Analyst: SD

Aliquot #: 2023-2803-1-05

Batch Number: AB-231023-005

Analyte(s)	Result	Units	Q	Reporting Limit	Dilution	Analysis Date and Time
Total Dissolved Solids	206	mg/L		5.00	1	10/18/2023 15:00

# Analytical Results



ENVIRONMENTAL  
QUALITY

This analytical report must be reproduced in its entirety

Collector: Young, Michael

Site: GP - SMS 002

Work Order Number: WO-231017-02

Sample Classification: Routine Monitoring

Project: CSI

Matrix: Water

Collected: 10/17/2023 7:56

Sample Barcode: 

Sample Number: 2023-2803

**Total Suspended Solids**

Method: SM 2540 D, 2011

Analyst: SD

Aliquot #: 2023-2803-1-06

Batch Number: AB-231023-001

Analyte(s)	Result	Units	Q	Reporting Limit	Dilution	Analysis Date and Time
Total Suspended Solids	10.5	mg/L		2.00	1	10/20/2023 14:00

**Total Phosphorus as P**

Method: SM 4500-P J, 2011

Analyst: JR

Aliquot #: 2023-2803-1-08

Batch Number: AB-231019-006

Analyte(s)	Result	Units	Q	Reporting Limit	Dilution	Analysis Date and Time
Total Phosphorus	0.07	mg/L		0.02	1	10/19/2023 10:44

**ICP/MS Metals (Total)**

Method: EPA 200.8 (Rev. 5.4, 1994)

Analyst: PH

Aliquot #: 2023-2803-2-02

Batch Number: AB-231116-012

Analyte(s)	Result	Units	Q	Reporting Limit	Dilution	Analysis Date and Time
Antimony	<2.00	ug/L		2.00	1	11/16/2023 13:40
Arsenic	1.06	ug/L		1.00	1	11/16/2023 13:40
Barium	62.1	ug/L		1.00	1	11/16/2023 13:40
Beryllium	<1.00	ug/L		1.00	1	11/16/2023 13:40
Cadmium	<0.300	ug/L		0.30	1	11/16/2023 13:40
Chromium	<1.00	ug/L		1.00	1	11/16/2023 13:40
Cobalt	0.433	ug/L		0.10	1	11/16/2023 13:40
Copper	0.852	ug/L		0.50	1	11/16/2023 13:40
Lead	0.502	ug/L		0.50	1	11/16/2023 13:40
Nickel	1.61	ug/L		0.50	1	11/16/2023 13:40
Selenium	<5.00	ug/L		5.00	1	11/16/2023 13:40
Silver	<0.100	ug/L		0.10	1	11/16/2023 13:40
Thallium	<0.500	ug/L		0.50	1	11/16/2023 13:40
Vanadium	3.28	ug/L		0.20	1	11/16/2023 13:40
Zinc	17.9	ug/L		5.00	1	11/16/2023 13:40

# Analytical Results



ENVIRONMENTAL  
QUALITY

This analytical report must be reproduced in its entirety

Collector: Young, Michael

Site: GP - SMS 002

Work Order Number: WO-231017-02

Sample Classification: Routine Monitoring

Project: CSI

Matrix: Water

Collected: 10/17/2023 7:56

Sample Barcode: 

Sample Number: 2023-2803

ICP/OES Metals (Total)

Method: EPA 200.7

Analyst: PH

Aliquot #: 2023-2803-2-05

Batch Number: AB-231201-007

Analyte(s)	Result	Units	Q	Reporting Limit	Dilution	Analysis Date and Time
Aluminum	0.158	mg/L		0.10	1	12/1/2023 11:50
Calcium	17.0	mg/L		1.00	1	12/1/2023 11:50
Iron	0.426	mg/L		0.10	1	12/1/2023 11:50
Magnesium	2.77	mg/L		1.00	1	12/1/2023 11:50
Manganese	0.176	mg/L		0.02	1	12/1/2023 11:50
Potassium	3.03	mg/L		1.00	1	12/1/2023 11:50
Sodium	47.3	mg/L		1.00	1	12/1/2023 11:50
Phosphorus	<1.00	mg/L		1.00	1	12/1/2023 11:50

This analytical report must be reproduced in its entirety

QUALITY CONTROL REPORT



ENVIRONMENTAL QUALITY

Project: Georgia Pacific split sample (AR0001210 AFIN 02-00013) 2023 2802-2803

Date and Time Received: 10/17/2023 11:43:00

Analyte	Units	Method Blank	Reporting Limit	% Recovery LCS/LCSD	Limits	% RPD	Lab Dup Result	Limits	% RPD	% Recovery MS/MSD	Limits	% RPD	Limits	Qualifiers
<b>Nitrate +Nitrite as N</b>		<b>SM 4500-NO3 F, 2011</b>				<b>Batch #:</b>		<b>AB-231018-023</b>		<b>Parent Sample:</b>		<b>2023-2795</b>		
	mg/L	<0.05	0.05	100.5 /	80-120		-			97.5 / 102.7	80-120	5.1	-	
<b>Total Phosphorus as P</b>		<b>SM 4500-P J, 2011</b>				<b>Batch #:</b>		<b>AB-231019-006</b>		<b>Parent Sample:</b>		<b>2023-2795</b>		
	mg/L	<0.02	0.02	95.5 /	80-120		-			87.2 / 86.2	80-120	0.8	-	
<b>Total Suspended Solids</b>		<b>SM 2540 D, 2011</b>				<b>Batch #:</b>		<b>AB-231023-001</b>		<b>Parent Sample:</b>		<b>2023-2795</b>		
	mg/L	<2.00	2.00	99.0 /	90-110		-			/	-	-	-	
<b>Total Dissolved Solids</b>		<b>SM 2540 C, 2011</b>				<b>Batch #:</b>		<b>AB-231023-005</b>		<b>Parent Sample:</b>		<b>2023-2795</b>		
	mg/L	<5.00	5.00	100.0 /	90-110		-			/	-	-	-	
<b>5 Day Biochemical Oxygen Demand</b>		<b>SM 5210 B, 2011</b>				<b>Batch #:</b>		<b>AB-231031-001</b>		<b>Parent Sample:</b>		<b>2023-2795</b>		
	mg/L	<0.20	0.20	94.7 /	85-115		-			/	-	-	-	
<b>ICP/MS Metals (Total)</b>		<b>EPA 200.8 (Rev. 5.4, 1994)</b>				<b>Batch #:</b>		<b>AB-231116-012</b>		<b>Parent Sample:</b>		<b>2023-2795</b>		
Ag	ug/L	<0.100	0.10	98.9 /	85-115		-			93.9 / 89.1	70-130	5.3	-	
As	ug/L	<1.00	1.00	100.5 /	85-115		-			108.7 / 103.4	70-130	4.9	-	
Ba	ug/L	<1.00	1.00	94.7 /	85-115		-			101.8 / 88.6	70-130	3.8	-	
Be	ug/L	<1.00	1.00	103.3 /	85-115		-			107.0 / 105.6	70-130	1.3	-	
Cd	ug/L	<0.300	0.30	103.9 /	85-115		-			106.5 / 101.7	70-130	4.7	-	
Co	ug/L	<0.100	0.10	99.2 /	85-115		-			95.0 / 89.5	70-130	5.3	-	
Cr	ug/L	<1.00	1.00	101.1 /	85-115		-			99.1 / 92.5	70-130	6.3	-	
Cu	ug/L	<0.500	0.50	93.9 /	85-115		-			85.9 / 82.3	70-130	4.1	-	
Ni	ug/L	<0.500	0.50	97.2 /	85-115		-			89.6 / 86.5	70-130	3.4	-	
Pb	ug/L	<0.500	0.50	110.0 /	85-115		-			114.5 / 108.0	70-130	5.0	-	
Sb	ug/L	<2.00	2.00	114.1 /	85-115		-			116.9 / 111.3	70-130	4.9	-	
Se	ug/L	<5.00	5.00	103.3 /	85-115		-			113.8 / 110.1	70-130	3.3	-	
Tl	ug/L	<0.500	0.50	105.0 /	85-115		-			109.5 / 102.4	70-130	6.7	-	
V	ug/L	<0.200	0.20	101.3 /	85-115		-			101.7 / 96.5	70-130	4.5	-	
Zn	ug/L	<5.00	5.00	101.6 /	85-115		-			101.6 / 96.3	70-130	4.8	-	
		<b>EPA 200.7</b>				<b>Batch #:</b>		<b>AB-231201-007</b>		<b>Parent Sample:</b>		<b>2023-2795</b>		
Al	mg/L	<0.100	0.10	107.8 /	85-115		-			113.8 / 113.3	70-130	0.3	-	
Ca	mg/L	<1.00	1.00	110.6 /	85-115		-			110.5 / 116.3	70-130	0.8	-	
Fe	mg/L	<0.100	0.10	111.3 /	85-115		-			111.1 / 110.4	70-130	0.5	-	
K	mg/L	<1.00	1.00	109.2 /	85-115		-			116.6 / 117.9	70-130	0.6	-	
Mg	mg/L	<1.00	1.00	111.6 /	85-115		-			109.9 / 112.2	70-130	0.7	-	
Analyte	Units	Method Blank	Reporting Limit	% Recovery LCS/LCSD	Limits	% RPD	Lab Dup Result	Limits	% RPD	% Recovery MS/MSD	Limits	% RPD	Limits	Qualifiers
Mn	mg/L	<0.0200	0.02	110.9 /	85-115		-			109.0 / 111.5	70-130	0.7	-	
Na	mg/L	<1.00	1.00	112.1 /	85-115		-			120.1 / 130.1	70-130	0.8	-	
P	mg/L	<1.00	1.00	112.8 /	85-115		-			118.6 / 118.5	70-130	0.0	-	

FIELD QUALITY CONTROL REPORT

This analytical report must be reproduced in its entirety



ENVIRONMENTAL QUALITY

Work Order #

WO-231017-02

Parent Sample

2023-2802

Analyte(s)	Parent Sample Result	Field Dup Result	Units	% RPD	Limits	Batch Number
<b>Aliquot #</b>	AB-231018-023 Dup - Field 3					<b>Parent Aliquot #</b> 2023-2802-1-01
Nitrite+Nitrate as Nitrogen		0.53	mg/L	0.38	0 - 20	AB-231018-023
<b>Aliquot #</b>	AB-231023-001 Dup - Field 3					<b>Parent Aliquot #</b> 2023-2802-1-05
Total Suspended Solids		14.2	mg/L	3.45	0 - 5	AB-231023-001
<b>Aliquot #</b>	AB-231023-005 Dup - Field 3					<b>Parent Aliquot #</b> 2023-2802-1-03
Total Dissolved Solids		262	mg/L	0.96	0 - 5	AB-231023-005
<b>Aliquot #</b>	AB-231030-056 Dup - Field 1					<b>Parent Aliquot #</b> 2023-2802-1-02
pH		7.08	units	0.42	0 - 20	AB-231030-056
<b>Aliquot #</b>	AB-231030-057 Dup - Field 1					<b>Parent Aliquot #</b> 2023-2802-1-04
Water Temperature		15.2	°C	1.31	0 - 20	AB-231030-057
<b>Aliquot #</b>	AB-231031-001 Dup - Field 1					<b>Parent Aliquot #</b> 2023-2802-1-06
Biochemical Oxygen Demand		7.97	mg/L	4.88	0 - 20	AB-231031-001
<b>Aliquot #</b>	AB-231201-007 Dup - Field 3					<b>Parent Aliquot #</b> 2023-2802-2-13
Aluminum		<0.100	mg/L	0.00	0 - 20	AB-231201-007
Calcium		28.5	mg/L	5.78	0 - 20	AB-231201-007
Iron		<0.100	mg/L	0.00	0 - 20	AB-231201-007
Magnesium		3.17	mg/L	2.10	0 - 20	AB-231201-007
Manganese		0.104	mg/L	0.19	0 - 20	AB-231201-007
Potassium		3.76	mg/L	1.02	0 - 20	AB-231201-007
Sodium		62.6	mg/L	2.29	0 - 20	AB-231201-007
Phosphorus		<1.00	mg/L	0.00	0 - 20	AB-231201-007
<b>Aliquot #</b>	PB-231019-002 Dup - Field 3					<b>Parent Aliquot #</b> 2023-2802-1-10
Total Phosphorus		0.14	mg/L	0.72	0 - 20	AB-231019-006
<b>Aliquot #</b>	PB-231116-002 Dup - Field 3					<b>Parent Aliquot #</b> 2023-2802-2-01
Antimony		<2.00	ug/L	0.00	0 - 20	AB-231116-012
Arsenic		<1.00	ug/L	0.00	0 - 20	AB-231116-012
Barium		96.1	ug/L	1.79	0 - 20	AB-231116-012
Beryllium		<1.00	ug/L	0.00	0 - 20	AB-231116-012
Cadmium		<0.300	ug/L	0.00	0 - 20	AB-231116-012
Chromium		<1.00	ug/L	0.00	0 - 20	AB-231116-012
Cobalt		0.176	ug/L	0.93	0 - 20	AB-231116-012
Copper		<0.500	ug/L	0.00	0 - 20	AB-231116-012
Lead		<0.500	ug/L	0.00	0 - 20	AB-231116-012
Nickel		0.683	ug/L	27.67	0 - 20	AB-231116-012
Selenium		<5.00	ug/L	0.00	0 - 20	AB-231116-012
Silver		<0.100	ug/L	0.00	0 - 20	AB-231116-012
Thallium		<0.500	ug/L	0.00	0 - 20	AB-231116-012
Vanadium		0.996	ug/L	36.78	0 - 20	AB-231116-012
Zinc		<5.00	ug/L	0.00	0 - 20	AB-231116-012



