

DIVISION OF ENVIRONMENTAL QUALITY

February 8, 2024

Honorable Jerry Jackson, Mayor City of Harrison P.O. Box 1715 Harrison, AR 72602 Email Address: <u>mayor@harrisonar.gov</u>

RE: Harrison WWTP Inspections – PDS# 128771 & 128772 AFIN: 05-00054 Permit No.: AR0034321

Dear Mayor Jackson:

On January 4, 2024, I performed a Compliance Evaluation Inspection and a Collection System Evaluation of the above referenced facility in accordance with the provisions of the Federal Clean Water Act, the Arkansas Water and Air Pollution Control Act, and the regulations promulgated thereunder. A copy of the inspection reports are enclosed for your records.

No violations were noted at the time of the inspection. Please refer to the inspection report for any comments. If I can be of any assistance please contact me at <u>amy.huneycutt@adeq.state.ar.us</u> or 501-837-2082.

Sincerely,

Himg Huneycutt

Amy Huneycutt Inspector, Office of Water Quality

			OFFICE OF WATER QUALITY							
ANTHON THE		INSPECTION REPORT								
		AFIN: 05-00054 PERMIT #: AR003432				321	21		DATE: 1/4/2024	
\$	AND ENVIRON	CC	UNTY: 05 Bod	one	)	PDS	6 #: <b>128</b>	771		MEDIA: WN
		GF	PS LAT: <b>36.236</b>	<b>99</b>	0 LONG: -93.076	433	LOCAT	ion: C	Seneral A	Area
	FACILITY INFORMAT	ION			IN	SPE		NFOR	MATION	1
	rrison WWTP				FACILITY TYPE: <b>1 - Municipal</b>	36	537 S -	State		
	08 Silver Valley Road		FACILITY EVALUATION RATING			Com	ION TYPE: <b>pliance</b>	Evaluation		
На	rrison		( )	ITRY TIM		TIME:		FECTIVE DATE:		
	RESPONSIBLE OFFIC						8/1/20 PERMIT EXI	Z1 PIRATION DATE:		
NAME: / TITLE Jerry Jackson / Mayor									7/31/2	026
COMF	PANY:			Ī	FAYETTEVILLE SHALE RELATED: N					
	y of Harrison			Ī	FAYETTEVILLE SHALE VIOLATIONS: N					
	D. Box 1715				INSPECTION PARTICIPANTS					
- /					NAME/TITLE/PHONE/FAX/EMAIL/ETC.: Kathryn Catlin, WW Systems Manager, 870-741-5527, kcatlin@harrisonar.gov ; Michael Crow WW Plant Asst. Manager, 870-741-2528,					
	rrison AR 72602 IE & EXT: / FAX:									
	)-741-5022 /									
EMAI	yor@harrisonar.gov				mcrow@harrisonar.gov;					
	NTACTED DURING INSPECTION	No			Jeremy Jennings, Pretreatment Coordinator, 870-741- 4426, jjennings@harrisonar.gov					
					4420, jjennings@namsonar.gov					
	(S=S	atisfac			LUATIONS sfactory, N=Not Applicable/	/Evaluat	ed)			
S	PERMIT	S	FLOW MEAS	SUR		Ν	I STO	RMWA		
S	RECORDS/REPORTS	S	LABORATOR			S	-		SITE RE	
S	OPERATION & MAINTENANCE	S			CEIVING WATER					G PROGRAM
S	SAMPLING	S	SLUDGE HAI	ND	LING/DISPOSAL	N	I   PRE	TREA	TMENT	
**	OTHER:									

# SUMMARY OF FINDINGS

No violations observed during this inspection.

#### GENERAL COMMENTS

I inspected this facility on January 4, 2024 with the above participants. The inspection consisted of facility assessment and record review.

#### Facility assessment:

The treatment system includes bar screen, grit chamber, primary clarifier, two parallel extended aeration oxidation ditches, two parallel secondary clarifiers, UV disinfection, and step aeration to Outfall 001. Solids from the clarifiers are sent to and aerobic digester and then a belt press. The biosolids are then land applied under permit 5158-WR-1. All treatment components are working properly and well-maintained.

During this inspection I observed some sediment erosion from the upslope side of the plant, near the primary clarifiers. The facility should monitor this area to ensure erosion does not become a problem. Additionally, flow calibration checks need to be documented. Mr. Crow stated calibration checks are performed but not recorded. During this inspection the flow meter was measuring within ±10% of the true flow.

#### Record review:

I reviewed DMR from January 2022 to the present for permit violations. There have been no reported permit violations during this period. I performed a detailed review for January 2023 effluent data and 2023 fourth quarter WET test. The January 2023 data is accurately reported. Records are complete and organized.

Army Huneycitt	
INSPECTOR'S SIGNATURE: O Amy Huneycutt	DATE: 1/23/2024
an Rellerbar	
SUPERVISOR'S SIGNATURE: Jason Bolenbaugh	DATE: 2/7/2024

PERMIT SATISFACTORILY ADDRESSES OBSERVATIONS	
DETAILS:	
1. CORRECT NAME AND MAILING ADDRESS OF PERMITTEE:	
2. NOTIFICATION GIVEN TO EPA/STATE OF NEW DIFFERENT OR INCREASED DISCHARGES:	
3. NUMBER AND LOCATION OF DISCHARGE POINTS AS DESCRIBED IN PERMIT:	
4. ALL DISCHARGES ARE PERMITTED:	
SECTION B: RECORDKEEPING AND REPORTING EVALUATION	
RECORDS AND REPORTS MAINTAINED AS REQUIRED BY PERMIT	
DETAILS:	
1. ANALYTICAL RESULTS CONSISTENT WITH DATA REPORTED ON DMRS:	
2. SAMPLING AND ANALYSES DATA ADEQUATE AND INCLUDE:	
a. DATES AND TIME(S) OF SAMPLING:	
b. EXACT LOCATION(S) OF SAMPLING:	
c. NAME OF INDIVIDUAL PERFORMING SAMPLING:	
d. ANALYTICAL METHODS AND TECHNIQUES:	
e. RESULTS OF CALIBRATIONS:	
f. RESULTS OF ANALYSES:	
g. DATES AND TIMES OF ANALYSES:	
h. NAME OF PERSON(S) PERFORMING ANALYSES:	
3. LABORATORY EQUIPMENT CALIBRATION AND MAINTENANCE RECORDS ADEQUATE:	
4. PLANT RECORDS INCLUDE SCHEDULES, DATES OF EQUIPMENT MAINTENANCE AND REPAIR:	
5. EFFLUENT LOADINGS CALCULATED USING DAILY EFFLUENT FLOW AND DAILY ANALYTICAL DATA:	
SECTION C: OPERATIONS AND MAINTENANCE	
TREATMENT FACILITY PROPERLY OPERATED AND MAINTAINED	
DETAILS:	
1. TREATMENT UNITS PROPERLY OPERATED:	
2. TREATMENT UNITS PROPERLY MAINTAINED:	Øs 🗆 m 🗇 u 🗆 na 🗇 n
3. STANDBY POWER OR OTHER EQUIVALENT PROVIDED:	
4. ADEQUATE ALARM SYSTEM FOR POWER OR EQUIPMENT FAILURES AVAILABLE:	
5. ALL NEEDED TREATMENT UNITS IN SERVICE:	
6. ADEQUATE NUMBER OF QUALIFIED OPERATORS PROVIDED:	
7. SPARE PARTS AND SUPPLIES INVENTORY MAINTAINED:	
8. OPERATION AND MAINTENANCE MANUAL AVAILABLE:	
9. STANDARD OPERATING PROCEDURES AND SCHEDULES ESTABLISHED:	
10. PROCEDURES FOR EMERGENCY TREATMENT CONTROL ESTABLISHED:	
11. HAVE BYPASSES/OVERFLOWS OCCURRED AT THE PLANT OR IN THE COLLECTION SYSTEM IN THE LAST YEAR:	
12. IF SO, HAS THE REGULATORY AGENCY BEEN NOTIFIED:	
13. HAS CORRECTIVE ACTION BEEN TAKEN TO PREVENT ADDITIONAL BYPASSES/OVERFLOWS:	
14. HAVE ANY HYDRAULIC OVERLOADS OCCURRED AT THE TREATMENT PLANT:	

SECTION D: SAMPLING	
PERMITTEE SAMPLING MEETS PERMIT REQUIREMENTS	
DETAILS:	
1. SAMPLES TAKEN AT SITE(S) SPECIFIED IN PERMIT:	
2. LOCATIONS ADEQUATE FOR REPRESENTATIVE SAMPLES:	
3. FLOW PROPORTIONED SAMPLES OBTAINED WHEN REQUIRED BY PERMIT:	
4. SAMPLING AND ANALYSES COMPLETED ON PARAMETERS SPECIFIED IN PERMIT:	
5. SAMPLING AND ANALYSES PERFORMED AT FREQUENCY SPECIFIED IN PERMIT:	
6. SAMPLE COLLECTION PROCEDURES ADEQUATE:	
a. SAMPLES REFRIGERATED DURING COMPOSITING:	
b. PROPER PRESERVATION TECHNIQUES USED:	
c. CONTAINERS AND SAMPLE HOLDING TIMES CONFORM TO 40 CFR 136:	
7. IF MONITORING IS PERFORMED MORE OFTEN THAN REQUIRED ARE RESULTS REPORTED ON THE DMR:	
SECTION E: FLOW MEASUREMENT	
PERMITTEE FLOW MEASUREMENT MEETS PERMIT REQUIREMENTS	
DETAILS:	·
1. PRIMARY FLOW MEASUREMENT DEVICE PROPERLY INSTALLED AND MAINTAINED: Yes TYPE OF DEVICE: 12" Parsh	
2. FLOW MEASURED AT EACH OUTFALL AS REQUIRED:	
3. SECONDARY INSTRUMENTS (TOTALIZERS, RECORDERS, ETC.) PROPERLY OPERATED AND MAINTAINED:	
4. CALIBRATION FREQUENCY ADEQUATE:	
5. RECORDS MAINTAINED OF CALIBRATION PROCEDURES:	
6. CALIBRATION CHECKS DONE TO ASSURE CONTINUED COMPLIANCE:	
7. FLOW ENTERING DEVICE WELL DISTRIBUTED ACROSS THE CHANNEL AND FREE OF TURBULENCE:	
8. FLOW MEASUREMENT EQUIPMENT ADEQUATE TO HANDLE EXPECTED RANGE OF FLOW RATES:	
9. HEAD MEASURED AT PROPER LOCATION:	
SECTION F: LABORATORY	
PERMITTEE LABORATORY PROCEDURES MEET PERMIT REQUIREMENTS	
DETAILS: Lab document request given to the facility.	
1. EPA APPROVED ANALYTICAL PROCEDURES USED (40 CFR 136.3 FOR LIQUIDS, 503.8(B) FOR SLUDGES) :	
2. IF ALTERNATIVE ANALYTICAL PROCEDURES ARE USED, PROPER APPROVAL HAS BEEN OBTAINED:	
3. SATISFACTORY CALIBRATION AND MAINTENANCE OF INSTRUMENTS AND EQUIPMENT:	
4. QUALITY CONTROL PROCEDURES ADEQUATE:	
5. DUPLICATE SAMPLES ARE ANALYZED ≥10% OF THE TIME:	
6. SPIKED SAMPLES ARE ANALYZED >10% OF THE TIME:	
7. COMMERCIAL LABORATORY USED:	
a. LAB NAME:	
b. LAB ADDRESS:	
c. PARAMETERS PERFORMED:	
8. BIOMONITORING PROCEDURES ADEQUATE:	
a. PROPER ORGANISMS USED:	
b. PROPER DILUTION SERIES FOLLOWED:	
c. PROPER TEST METHODS AND DURATION:	
d. RETESTS AND/OR TRE PERFORMED AS REQUIRED:	

# Inspection Report: Harrison WWTP, AFIN: 05-00054, Permit #: AR0034321

				ATIONS			
-	VISUAL OBSE		-				
	Crooked Creek			1	T		1
OUTFALL #:	OIL SHEEN	GREASE	TURBIDITY	VISIBLE FOAM	FLOATING SOLIDS	COLOR	OTHER
001	No	No	No	No	No	Clear	
	: SLUDGE DISF			<b>T</b> 0			
	DISPOSAL MEE	IS PERMIT	REQUIREMEN	15		⊠S ⊔M L	
DETAILS:						<b>.</b>	<u></u>
	ANAGEMENT ADEQUA	-					
	ECORDS MAINTAINED						
3. FOR LAND	APPLIED SLUDGE, TY	PE OF LAND APPLIE	ED TO: (E.G., FOREST	, AGRICULTURAL, PU	BLIC CONTACT SITE): Pe	rmitted land applica	tion fields.
OFOTION I							
				-0			
	ESULTS WITH			3			
DETAILS:	OBTAINED THIS INSPE	CTION					
				-1101/		ЦY	
	AMPLE: GRAB:	COMPOSITE:	METHOD: FREQUE				
	PRESERVED.						
	EPRESENTATIVE OF V		-				
			LE OF DISCHARGE.				
	CUSTODY PROCEDUR						
		-	ЛТ·				
J. ON WIT ELO						1	
SECTION J	: STORM WATE			ΡΙΔΝ			
	ATER MANAGE				3		
DETAILS:							
	DATED AS NEEDED:	DATE OF LAST U	PDATE:				
2. SITE MAP I	NCLUDING ALL DISCH	ARGES AND SURFA	ACE WATERS:				
3. POLLUTIO	N PREVENTION TEAM I	DENTIFIED:					
4. POLLUTIO	N PREVENTION TEAM I	PROPERLY TRAINE	D:				
5. LIST OF PO	TENTIAL POLLUTANT	SOURCES:					
6. LIST OF PO	DTENTIAL SOURCES A	ND PAST SPILLS AN	ID LEAKS:				
7. ALL NON-S	TORM WATER DISCHA	RGES ARE AUTHO	RIZED:				
8. LIST OF ST	RUCTURAL BMPS:						
9. LIST OF NO	ON-STRUCTURAL BMP	5:					
10. BMPS PRC	PERLY OPERATED AN	D MAINTAINED:					

# Inspection Report: Harrison WWTP, AFIN: 05-00054, Permit #: AR0034321

FLOW CALCULATION SHEET													
Date: (	01/04/20	24	Time:	132	25								
Head in	Inches:		Fe	eet:									
Type & Size of Primary Flow Measurement Device:													
12" Parshall Flume													
Name &	Model o	f Second	dary Flow	Mea	Isurem	ent D	)evi	ce: H	oneyv	vell			
Date of la	ast Calib	oration o	f Seconda	ry Fl	low De	vice:	C	6/07/2	023				
Recorde	d Flow a	t Date 8	Time List	ed A	bove:	2.3	S MC	SD		(F	acility Flow	/ Meter)	
-			& Time Lis s in: ISCO Op					IGD ment Han	dbook-5	<sup>th</sup> Edit	ion)		
											<u>1011)</u>		
% Error =	=	orded V (		- Calculated Value					X 100				
% Error =	=	2.3	-		2.2			X 100					
			2.2		1								
% Error =	=	0.1	X 1	00									
% Error =	=	0.045	X 1	00									
% Error =	=	4.5	%										
Commer	nts:												

## **DMR Calculation Check**

Reporting Period:	From	2023	01	01	_ То	2023	01	31	
		Year	Month	Day		Year	Month	Day	
Parameter Checked:		FCB							
		Loading				Concen	tration		
		Mass		Monthly					
		Mo. Avg.			. Avg. /100m		7-day A col/10	-	
Reported Value:		NA			12.0		51.0	0	
Calculated Value:		NA			12.0		51.0	0	
Permit Value:		NA			1000		200	0	


If calculated value does not equal reported value, explain:

## **DMR Calculation Check**

Reporting Period:	From	2023	01	01	_ То	2023	01	31	
		Year	Month	Day		Year	Month	Day	
Parameter Checked:		NH3-N	-						
		Loading Mass		Concentration Monthly					
	Mo.	Avg Ibs/c	lay	Mo. A	vg r		7-day Avg	mg/l	
Reported Value:		5.7		0.28			0.92		
Calculated Value:	5.7			0.28			0.92		
Permit Value:		6			6.4				


If calculated value does not equal reported value, explain:











## Inspection Report: Harrison WWTP, AFIN: 05-00054, Permit #: AR0034321

Figure 1. Google Earth image dated July 2022 showing the treatment plant and outfall.

