

DIVISION OF ENVIRONMENTAL QUALITY

February 10, 2025

Blake Marotti, General Manager Wynne Water Utilities 121 E. Merriman Wynne, AR 72396 Email Address: <u>bmarotti@wynnewater.com</u>

RE: Wynne Water Utilities Inspection -PDS# 131741 & 131934 (Cross Co.) AFIN: 19-00071 Permit No.: AR0021903

Dear Mr. Marotti:

On August 28, 2024, I performed a Compliance Evaluation Inspection of the above referenced facility in accordance with the provisions of the Federal Clean Water Act, the Arkansas Water and Air Pollution Control Act, and the regulations promulgated thereunder. A copy of the inspection report is enclosed for your records.

Please refer to the attached inspection reports for any comments regarding these inspections.

If I can be of any assistance, please contact me at <u>Sarah.Frasher@arkansas.gov</u> or 870-935-7221 ext.-15.

Sincerely,

Gel Fre

Sarah Frasher Inspector, Office of Water Quality

Cc: Richard Healey, E&E: DEQ, OWQ Enforcement Branch, <u>Richard.Healey@arkansas.gov</u>

Let a	ENVIRONMENTAL QUALITY	OFFICE OF WATER QUALITY INSPECTION REPORT							
V - ENE		AF	AFIN: 19-00071   PERMIT #: AR00219		903	3		DATE: 8/28/2024	
10×		COUNTY: 19 Cross		S	PDS #		#: 131741		MEDIA: WN
		GF	S LAT: 35.22412	21 LONG: -90.793967 LOCATION: Entrance					1
	FACILITY INFORMAT	ION		INSPECTION INFORMATION					
Wynne Water Utilities				FACILITY TYPE: <b>1 - Municipal</b>		ror ID#: 347 S - State			
TOCATION: 706 W. Martin Drive				FACILITY EVALUATION RATING: INSPECTION TYPE:   1 - Unsatisfactory Compliance Evaluation			Evaluation		
Wy	/nne			(-)	RY TIME:	EXIT TIME 10:39			
RESPONSIBLE OFFICIAL				0/20/2024 10:00 10:39 2/1/2024 PERMIT EXPIRATION DATE:					
	: / TITLE			1/31/2029				029	
Blake Marotti / General Manager				FAYETTEVILLE SHALE RELATED: N					
Wynne Water Utilities				FAYETTEVILLE SHALE VIOLATIONS: N					
	ING ADDRESS: 1 E. Merriman			INSPECTION PARTICIPANTS					
	STATE, ZIP:			NAME/TITLE/PHONE/FAX/EMAIL/ETC.:					
Wynne AR 72396				Josh Weaver/ Wastewater Treatment Supervisor					
PHON	NE & EXT: / FAX:								
l EMAIL:									
bmarotti@wynnewater.com				4					
CONTACTED DURING INSPECTION: No									
AREA EVALUATIONS (S=Satisfactory, M=Marginal, U=Unsatisfactory, N=Not Applicable/Evaluated)									
S	PERMIT	U FLOW MEASUREMENT N STORMWATER							
Ν	RECORDS/REPORTS	Ν	LABORATORY	,	Μ	FACILITY SITE REVIEW			
Μ	<b>OPERATION &amp; MAINTENANCE</b>	Μ	EFFLUENT/RE	CEIVING WATER	U	SELF-MONITORING PROGRAM			
Ν	SAMPLING	N SLUDGE HANDLING/DISPOSAL N PRETREATMENT							
Ν	OTHER:								

## SUMMARY OF FINDINGS

This facility received extensive damage during a severe weather event resulting in an EF3 tornado on March 31, 2023. The DEQ issued Emergency Order LIS 23-028 which allows the equalization basin to be used as a temporary treatment facility. On November 21, 2024, the DEQ executed Consent Administrative Order (CAO) LIS 24-162 which will become effective on January 7, 2025, and close the Emergency Order.

The following items were noted at the time of the inspection and must be corrected as soon as possible with a written update regarding the corrective action taken included in the first quarterly progress report required by CAO LIS 24-162:

- 1. The newly installed influent pipe is discharging onto the slope of the equalization basin levee (Photos 2-3). This has the potential to cause erosion and compromise the integrity of the levee.
- 2. The facility was not making any formal efforts to disinfect the wastewater prior to discharge as required by Item 2.d. of the Emergency Order. (Photos 9-10).
- 3. The facility was not making reasonable efforts to measure flow volume of the discharge as required by Item 2.f of the Emergency Order.

## GENERAL COMMENTS

Both the Emergency Order and the CAO require monthly reporting of the status of emergency treatment and sample results.

A Reconnaissance Inspection (PDS# 131934) was performed on 9/11/2024 in response to a complaint (PDS# 033381). Please see the separate report for details.

Walter Kincade, DEQ Inspector, also participated in this inspection.

C/ fd	
INSPECTOR'S SIGNATURE: Sarah Frasher	DATE: 12/6/2024
SUPERVISOR'S SIGNATURE: Brent L. Walker	DATE: <b>12/9/2024</b>

SECTION A: PERMIT VERIFICATION				
PERMIT SATISFACTORILY ADDRESSES OBSERVATIONS	ØS OM OU ONA ONE			
DETAILS:				
1. CORRECT NAME AND MAILING ADDRESS OF PERMITTEE:				
2. NOTIFICATION GIVEN TO EPA/STATE OF NEW DIFFERENT OR INCREASED DISCHARGES:				
3. NUMBER AND LOCATION OF DISCHARGE POINTS AS DESCRIBED IN PERMIT:				
4. ALL DISCHARGES ARE PERMITTED:				
SECTION B: RECORDKEEPING AND REPORTING EVALUATION				
RECORDS AND REPORTS MAINTAINED AS REQUIRED BY PERMIT	□S □M □U □NA ☑NE			
DETAILS: Laboratory results are sent to DEQ.				
1. ANALYTICAL RESULTS CONSISTENT WITH DATA REPORTED ON DMRS:	DY DN DNA ØNE			
2. SAMPLING AND ANALYSES DATA ADEQUATE AND INCLUDE:	Os Om Ou Ona Øne			
a. DATES AND TIME(S) OF SAMPLING:	DY DN DNA ØNE			
b. EXACT LOCATION(S) OF SAMPLING:				
c. NAME OF INDIVIDUAL PERFORMING SAMPLING:				
d. ANALYTICAL METHODS AND TECHNIQUES:	DY DN DNA ØNE			
e. RESULTS OF CALIBRATIONS:	DY DN DNA ØNE			
f. RESULTS OF ANALYSES:				
g. DATES AND TIMES OF ANALYSES:				
h. NAME OF PERSON(S) PERFORMING ANALYSES:				
3. LABORATORY EQUIPMENT CALIBRATION AND MAINTENANCE RECORDS ADEQUATE:	OS OM OU ONA ØNE			
4. PLANT RECORDS INCLUDE SCHEDULES, DATES OF EQUIPMENT MAINTENANCE AND REPAIR:	OS OM OU ONA ØNE			
5. EFFLUENT LOADINGS CALCULATED USING DAILY EFFLUENT FLOW AND DAILY ANALYTICAL DATA:				
SECTION C: OPERATIONS AND MAINTENANCE				
TREATMENT FACILITY PROPERLY OPERATED AND MAINTAINED	□S ØM □U □NA □NE			
DETAILS: Influent pipe discharges to slope of levee				
1. TREATMENT UNITS PROPERLY OPERATED:	OS 🗹 M 🗇 U 🗆 NA 🗆 NE			
2. TREATMENT UNITS PROPERLY MAINTAINED:	□s ∅m □u □na □ne			
3. STANDBY POWER OR OTHER EQUIVALENT PROVIDED:	□s □m □u Øna □ne			
4. ADEQUATE ALARM SYSTEM FOR POWER OR EQUIPMENT FAILURES AVAILABLE:	□s □m □u Øna □ne			
5. ALL NEEDED TREATMENT UNITS IN SERVICE:	🗹 s 🗆 m 🗇 u 🖾 na 🖾 ne			
6. ADEQUATE NUMBER OF QUALIFIED OPERATORS PROVIDED:	Øs 🗆m 🗇u 🖾na 🖾ne			
7. SPARE PARTS AND SUPPLIES INVENTORY MAINTAINED:	□s □m □u Øna □ne			
8. OPERATION AND MAINTENANCE MANUAL AVAILABLE:	DY DN ØNA DNE			
9. STANDARD OPERATING PROCEDURES AND SCHEDULES ESTABLISHED:				
10. PROCEDURES FOR EMERGENCY TREATMENT CONTROL ESTABLISHED:				
11. HAVE BYPASSES/OVERFLOWS OCCURRED AT THE PLANT OR IN THE COLLECTION SYSTEM IN THE LAST YEAR:				
12. IF SO, HAS THE REGULATORY AGENCY BEEN NOTIFIED:				
13. HAS CORRECTIVE ACTION BEEN TAKEN TO PREVENT ADDITIONAL BYPASSES/OVERFLOWS:				
14. HAVE ANY HYDRAULIC OVERLOADS OCCURRED AT THE TREATMENT PLANT:				
15. IF SO, DID PERMIT VIOLATIONS OCCUR AS A RESULT:				

SECTION D: SAMPLING					
PERMITTEE SAMPLING MEETS PERMIT REQUIREMENTS					
DETAILS: Laboratory results sent to DEQ.					
1. SAMPLES TAKEN AT SITE(S) SPECIFIED IN PERMIT:					
2. LOCATIONS ADEQUATE FOR REPRESENTATIVE SAMPLES:					
3. FLOW PROPORTIONED SAMPLES OBTAINED WHEN REQUIRED BY PERMIT:					
4. SAMPLING AND ANALYSES COMPLETED ON PARAMETERS SPECIFIED IN PERMIT:					
5. SAMPLING AND ANALYSES PERFORMED AT FREQUENCY SPECIFIED IN PERMIT:					
6. SAMPLE COLLECTION PROCEDURES ADEQUATE:	DY DN DNA ØNE				
a. SAMPLES REFRIGERATED DURING COMPOSITING:					
b. PROPER PRESERVATION TECHNIQUES USED:					
c. CONTAINERS AND SAMPLE HOLDING TIMES CONFORM TO 40 CFR 136:					
7. IF MONITORING IS PERFORMED MORE OFTEN THAN REQUIRED ARE RESULTS REPORTED ON THE DMR:					
SECTION E: FLOW MEASUREMENT					
PERMITTEE FLOW MEASUREMENT MEETS PERMIT REQUIREMENTS					
DETAILS: No flow measuring device available at this time.	•				
1. PRIMARY FLOW MEASUREMENT DEVICE PROPERLY INSTALLED AND MAINTAINED: TYPE OF DEVICE:					
2. FLOW MEASURED AT EACH OUTFALL AS REQUIRED:					
3. SECONDARY INSTRUMENTS (TOTALIZERS, RECORDERS, ETC.) PROPERLY OPERATED AND MAINTAINED:					
4. CALIBRATION FREQUENCY ADEQUATE:					
5. RECORDS MAINTAINED OF CALIBRATION PROCEDURES:					
6. CALIBRATION CHECKS DONE TO ASSURE CONTINUED COMPLIANCE:					
7. FLOW ENTERING DEVICE WELL DISTRIBUTED ACROSS THE CHANNEL AND FREE OF TURBULENCE:					
8. FLOW MEASUREMENT EQUIPMENT ADEQUATE TO HANDLE EXPECTED RANGE OF FLOW RATES:					
9. HEAD MEASURED AT PROPER LOCATION:					
SECTION F: LABORATORY					
PERMITTEE LABORATORY PROCEDURES MEET PERMIT REQUIREMENTS					
DETAILS: Laboratory results are sent to DEQ.	_				
1. EPA APPROVED ANALYTICAL PROCEDURES USED (40 CFR 136.3 FOR LIQUIDS, 503.8(B) FOR SLUDGES) :					
2. IF ALTERNATIVE ANALYTICAL PROCEDURES ARE USED, PROPER APPROVAL HAS BEEN OBTAINED:					
3. SATISFACTORY CALIBRATION AND MAINTENANCE OF INSTRUMENTS AND EQUIPMENT:					
4. QUALITY CONTROL PROCEDURES ADEQUATE:					
5. DUPLICATE SAMPLES ARE ANALYZED ≥10% OF THE TIME:					
6. SPIKED SAMPLES ARE ANALYZED ≥10% OF THE TIME:					
7. COMMERCIAL LABORATORY USED:					
a. LAB NAME:					
b. LAB ADDRESS:					
c. PARAMETERS PERFORMED:					
8. BIOMONITORING PROCEDURES ADEQUATE:					
a. PROPER ORGANISMS USED:					
b. PROPER DILUTION SERIES FOLLOWED:					
c. PROPER TEST METHODS AND DURATION:					
d. RETESTS AND/OR TRE PERFORMED AS REQUIRED:					

SECTION G: EFFLUENT/RECEIVING WATERS OBSERVATIONS								
BASED ON	BASED ON VISUAL OBSERVATIONS ONLY						U 🗆 NA 🗆 NE	
DETAILS:	Water is discha	arged from efflu	ent pipe direct	y to outfall with	no disinfection.			
OUTFALL #:	OIL SHEEN	GREASE	TURBIDITY	VISIBLE FOAM	FLOATING SOLIDS	COLOR	OTHER	
001	None	None	Low	None	None	Green		
SECTION H	: SLUDGE DIS	POSAL						
SLUDGE D	DISPOSAL ME	ETS PERMIT F	REQUIREMENT	ſS			U ⊠NA ⊡NE	
DETAILS:	Sludge stays in	<u>the lagoon.</u>						
1. SLUDGE M	ANAGEMENT ADEQU	ATE TO MAINTAIN EF	FLUENT QUALITY:			⊡s ⊡м		
2. SLUDGE R	ECORDS MAINTAINED	DAS REQUIRED BY 40	) CFR 503:			⊡s ⊡м	DU 🗹 NA DNE	
3. FOR LAND	APPLIED SLUDGE, TY	PE OF LAND APPLIE	D TO: (E.G., FOREST,	AGRICULTURAL, PUB	BLIC CONTACT SITE):			
SECTION I:	SAMPLING IN	SPECTION PRO	CEDURES					
SAMPLE F	RESULTS WITH	HIN PERMIT R	EQUIREMENT	S			U ⊠NA ⊡NE	
DETAILS:								
1. SAMPLES	OBTAINED THIS INSPE	ECTION:				ΠY	⊡n Øna ⊡ne	
2. TYPE OF S	AMPLE: GRAB:		IETHOD: FREQUE	NCY:				
3. SAMPLES	3. SAMPLES PRESERVED:						□n Øna □ne	
4. FLOW PROPORTIONED SAMPLES OBTAINED:					ΠY			
5. SAMPLE O	5. SAMPLE OBTAINED FROM FACILITY'S SAMPLING DEVICE:						□n Øna □ne	
6. SAMPLE REPRESENTATIVE OF VOLUME AND NATURE OF DISCHARGE:						⊡n Øna ⊡ne		
7. SAMPLE SPLIT WITH PERMITTEE:						⊡n Øna ⊡ne		
8. CHAIN-OF-CUSTODY PROCEDURES EMPLOYED:					ΠY			
9. SAMPLES COLLECTED IN ACCORDANCE WITH PERMIT:								
	: STORM WAT							
STORM WATER MANAGEMENT MEETS PERMIT REQUIREMENTS								
DETAILS:								
1. SWPPP UF	1. SWPPP UPDATED AS NEEDED: DATE OF LAST UPDATE:							
2. SITE MAP I	NCLUDING ALL DISCH	HARGES AND SURFAC	CE WATERS:			ΠY	□n Øna □ne	
3. POLLUTIO	POLLUTION PREVENTION TEAM IDENTIFIED:					□n Øna □ne		
4. POLLUTIO	. POLLUTION PREVENTION TEAM PROPERLY TRAINED:							
5. LIST OF PC	5. LIST OF POTENTIAL POLLUTANT SOURCES:					□n Øna □ne		
6. LIST OF PC	6. LIST OF POTENTIAL SOURCES AND PAST SPILLS AND LEAKS:							
7. ALL NON-STORM WATER DISCHARGES ARE AUTHORIZED: Image: Comparison of the second se					□n Øna □ne			
8. LIST OF ST	8. LIST OF STRUCTURAL BMPS:							
9. LIST OF NO	9. LIST OF NON-STRUCTURAL BMPS:							
10. BMPS PRC	). BMPS PROPERLY OPERATED AND MAINTAINED:							
11. INSPECTIO	. INSPECTIONS CONDUCTED AS REQUIRED:							
1								



Figure 1. Google Earth map of the Wynne Water Utilities lagoon for Emergency Treatment of wastewater. Labels are placed to highlight the different areas of treatment.











From:	Blake Marotti <bmarotti@wynnewater.com></bmarotti@wynnewater.com>
Sent:	Monday, February 10, 2025 10:54 AM
То:	Water-Inspection-Report@adeq.state.ar.us
Cc:	Brent Walker (adpce.ad); Richard Healey (adpce.ad)
Subject:	Wynne Water Utilities - Wastewater Inspections 131741 & 131934
Follow Up Flag:	Follow up
Flag Status:	Flagged

To Whom It May Concern,

I have received the inspection reports, from Ms. Marshall, for the Temporary Wastewater Lagoons. I am aware of the recent grab sample results, and we have been taking several measures to improve the fecal numbers during the cold weather months (i.e. running all of the aerators 24/7 and currently having a local fabrication shop build a custom riser gate at the effluent pipe to allow for additional holding time).

We are also currently in the process of building a temporary structure to house the hypochlorite tank and chem pump skid. It is important to get this equipment under roof and enclosed so that proper insulation measures can be taken so that the hypo does not freeze. I fully expect to have the chem feed pumps operational and disinfecting wastewater with the disinfection bay of the lagoons this month. Regarding the flow measurement, I have spoken with John Keckler of ISI and he will be installing a temporary battery powered flow measurement device at the outfall this week. Regarding the influent pipe, we will get the slope framed up and concrete poured for a "splash block" within the referenced area to eliminate the possibility of further erosion.

I apologize for these issues, and they will be remedied ASAP. Thank you for your time and If there's any further information that you need, please contact me at your convenience.

Thanks,

Blake Marotti General Manager (870) 238-2751 | <u>www.wynnewater.com</u>



550 N. Falls Blvd. | Wynne, AR 72396