



**DIVISION OF
ENVIRONMENTAL
QUALITY**

Sarah Huckabee Sanders
GOVERNOR

Shane E. Khoury
SECRETARY

July 8, 2025

Jonas Anderson, Mayor
City Hall
201 South Main Street
Cave City, AR 72521
Email Address: cityhall@cavecity.us

RE: Cave City WWTP Inspection
AFIN: 68-00015

PDS#: 133207 (Sharp Co.)
Permit No.: AR0022110

Dear Mr. Anderson:


On March 21, 2025, I performed a Reconnaissance Inspection of the above referenced facility in accordance with the provisions of the Federal Clean Water Act, the Arkansas Water and Air Pollution Control Act, and the regulations promulgated thereunder. A copy of the inspection report is enclosed for your records.

No violations were noted at the time of the inspection. Please refer to the inspection report for any comments. If I can be of any assistance, please contact me at Wayne.Reynolds@Arkansas.Gov or 501 837 6964.



Sincerely,

A handwritten signature in black ink, reading "Wayne Reynolds".

Wayne Reynolds
Inspector, Office of Water Quality

 ENVIRONMENTAL QUALITY	OFFICE OF WATER QUALITY INSPECTION REPORT		
	AFIN: 68-00015		PERMIT #: AR0022110
	COUNTY: 68 Sharp		PDS #: 133207
	GPS LAT: 35.937270 LONG: -91.536058 LOCATION: General Area		
FACILITY INFORMATION		INSPECTION INFORMATION	
NAME: Cave City WWTP LOCATION: 200 Foley Drive CITY: Cave City		FACILITY TYPE: 1 - Municipal INSPECTOR ID#: 123804 S - State	
		FACILITY EVALUATION RATING: N INSPECTION TYPE: Reconnaissance	
		DATE(S): 3/21/2025 ENTRY TIME: 12:33 EXIT TIME: 13:06	
		PERMIT EFFECTIVE DATE: 5/1/2024 PERMIT EXPIRATION DATE: 4/30/2029	
RESPONSIBLE OFFICIAL			
NAME: / TITLE Jonas Anderson / Mayor COMPANY: Cave City MAILING ADDRESS: 201 South Main Street CITY, STATE, ZIP: Cave City AR 72521 PHONE & EXT: / FAX: 8702835455 / EMAIL: cityhall@cavecity.us		FAYETTEVILLE SHALE RELATED: N FAYETTEVILLE SHALE VIOLATIONS: N	
CONTACTED DURING INSPECTION: Yes		INSPECTION PARTICIPANTS NAME/TITLE/PHONE/FAX/EMAIL/ETC.: Wayne Reynolds, Inspector Payton Wooldridge, Operator	
AREA EVALUATIONS			
(S=Satisfactory, M=Marginal, U=Unsatisfactory, N=Not Applicable/Evaluated)			
S	PERMIT	N	FLOW MEASUREMENT
N	RECORDS/REPORTS	N	LABORATORY
S	OPERATION & MAINTENANCE	S	EFFLUENT/RECEIVING WATER
N	SAMPLING	N	SLUDGE HANDLING/DISPOSAL
N	OTHER:	N	STORMWATER
			FACILITY SITE REVIEW
			SELF-MONITORING PROGRAM
			PRETREATMENT

SUMMARY OF FINDINGS
This inspection was to check on the operation of the WWTP after the tornado of March 15, 2025. No problems were observed and there was no interruption of service.
GENERAL COMMENTS
Treatment consists of a bar screen (one mechanical and one manual removal), oxidation ditch, clarifier boat, facultative lagoon, intermittent sand filter, post-aeration and discharge to outfall 001. There is no chlorine used in the chlorine contact chamber. The sand filters are alternated regularly and tilled prior to alternation.

INSPECTOR'S SIGNATURE: 	Wayne Reynolds	DATE: 3/24/2025
SUPERVISOR'S SIGNATURE: 	Brent L. Walker	DATE: 6/27/2025

Office of Water Quality Photographic Evidence Sheet

Location:	Cave City WWTP		
Photographer:	Wayne Reynolds	Date:	21 MAR 2025
Witness:		Time:	1245
		Photo #:	1
Description:	Manual and automatic bar screens operational.		



Photographer:	Wayne Reynolds	Date:	21 MAR 2025
Witness:		Time:	1243
		Photo #:	2
Description:	Influent Parshall Flume with some vegetative growth		

