

STATEMENT OF BASIS

For the issuance of Draft Air Permit # 0287-AOP-R19 AFIN: 41-00002

1. PERMITTING AUTHORITY:

Arkansas Department of Environmental Quality
5301 Northshore Drive
North Little Rock, Arkansas 72118-5317

2. APPLICANT:

Domtar A.W. LLC
285 Highway 71 South
Ashdown, Arkansas 71822

3. PERMIT WRITER:

Christopher Riley

4. NAICS DESCRIPTION AND CODE:

NAICS Description: Paper (except Newsprint) Mills
NAICS Code: 322121

5. SUBMITTALS:

Date of Application	Type of Application (New, Renewal, Modification, Deminimis/Minor Mod, or Administrative Amendment)	Short Description of Any Changes That Would Be Considered New or Modified Emissions
2/23/2017	Administrative Amendment	None

6. REVIEWER'S NOTES:

Domtar A.W. LLC. –Ashdown Mill (AFIN: 41-00002) operates a paper mill located at 285 Highway 71 South in Ashdown, Arkansas 71822. Domtar submitted an application, as an administrative amendment, to modify the permitted boiler fuels for SN-01 and SN-05 by removing fuels from the permit that are no longer combusted in the boilers. This modification did not change any operating conditions for the boilers. Furthermore, this will not cause any changes to the permitted emissions for the affected sources or the facility as a whole.

7. COMPLIANCE STATUS:

The following summarizes the current compliance of the facility including active/pending enforcement actions and recent compliance activities and issues.

The most recent inspection ended on March 1, 2016. The inspection report did not identify any compliance issues.

8. PSD APPLICABILITY:

a) Did the facility undergo PSD review in this permit (i.e., BACT, Modeling, etc.)? N

b) Is the facility categorized as a major source for PSD? Y

- *Single pollutant ≥ 100 tpy and on the list of 28 or single pollutant ≥ 250 tpy and not on list*

If yes, explain why this permit modification is not PSD.

This application is an Administrative Amendment that has no impact on emissions (no increases or decreases before netting)

9. SOURCE AND POLLUTANT SPECIFIC REGULATORY APPLICABILITY:

Source No.	Regulation	Description
Facility	40 CFR Part 63, Subpart S	NESHAPS for Hazardous Air Pollutants from the Pulp and Paper Industry
Facility	40 CFR Part 60, Subpart A	General Provisions
01	40 CFR Part 60, Subpart Db	Standards of Performance for Industrial-Commercial-Institutional Steam Generating Units
01	40 CFR 52, Subpart E	Prevention of Significant Deterioration
02	40 CFR Part 60, Subpart BB	Standards of performance for Kraft Pulp Mills
02	40 CFR Part 63, Subpart MM	NESHAPS for Chemical Recovery Combustion Sources at Kraft, Soda, Sulfite and Stand-Alone Semichemical Pulp Mills
02	40 CFR 52, Subpart E	Prevention of Significant Deterioration
05	40 CFR Part 60, Subpart BB	Standards of Performance for Kraft Pulp Mills
05	40 CFR Part 60, Subpart D	Standards of Performance for Fossil-Fuel-Fired Steam Generators for Which Construction Is Commenced after August 17, 1971
06	40 CFR Part 60, Subpart BB	Standards of Performance for Kraft Pulp Mills
06	40 CFR 52, Subpart E	Prevention of Significant Deterioration
06	40 CFR Part 63, Subpart MM	NESHAPS for Chemical Recovery Combustion Sources at Kraft, Soda, Sulfite and Stand-Alone Semichemical Pulp Mills
08	40 CFR Part 60, Subpart BB	Standards of Performance for Kraft Pulp Mills

Source No.	Regulation	Description
08	40 CFR §52.21	Prevention of Significant Deterioration
08	40 CFR Part 63, Subpart MM	NESHAPS for Chemical Recovery Combustion Sources at Kraft, Soda, Sulfite and Stand-Alone Semicheical Pulp Mills
09	40 CFR Part 60, Subpart BB	Standards of Performance for Kraft Pulp Mills
09	40 CFR Part 63, Subpart MM	NESHAPS for Chemical Recovery Combustion Sources at Kraft, Soda, Sulfite and Stand-Alone Semicheical Pulp Mills
12	40 CFR Part 60, Subpart Db	Standards of Performance for Industrial-Commercial-Institutional Steam Generating Units
14	40 CFR Part 60, Subpart BB	Standards of Performance for Kraft Pulp Mills
14	40 CFR 52, Subpart E	Prevention of Significant Deterioration
14	40 CFR Part 63, Subpart M	NESHAPS for Chemical Recovery Combustion Sources at Kraft, Soda, Sulfite and Stand-Alone Semicheical Pulp Mills
15	40 CFR Part 60, Subpart BB	Standards of Performance for Kraft Pulp Mills
50, 53, 54a, 54b, 57, 58, 59	40 CFR Part 63, Subpart ZZZZ	National Emissions Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines
38, 15	40 CFR 52, Subpart E	Prevention of Significant Deterioration

10. EMISSION CHANGES AND FEE CALCULATION:

See emission change and fee calculation spreadsheet in Appendix A.

11. AMBIENT AIR EVALUATIONS:

a) Reserved.

b) Non-Criteria Pollutants:

The non-criteria pollutants listed below were evaluated. Based on Department procedures for review of non-criteria pollutants, emissions of all other non-criteria pollutants are below thresholds of concern.

1st Tier Screening (PAER)

Estimated hourly emissions from the following sources were compared to the Presumptively Acceptable Emission Rate (PAER) for each compound. The Department has deemed the PAER to be the product, in lb/hr, of 0.11 and the Threshold Limit Value (mg/m³), as listed by the American Conference of Governmental Industrial Hygienists (ACGIH).

Pollutant	TLV (mg/m ³)	PAER (lb/hr) = 0.11 × TLV	Proposed lb/hr	Pass?
Acetaldehyde	45.0409	4.954499	15.3	N
Acrolein	0.229284	0.025221	0.895408	N
Ammonia	52.42945	5.767239	8.05	N
Arsenic	0.01	0.0011	0.019014	N
Beryllium	0.00005	5.5E-06	0.001629	N
Benzene	3.883436	0.427178	8.3	N
Cadmium	0.002	0.00022	0.008759	N
Chlorine	1.450102	0.159511	7.31	N
Chloroform	48.82618	5.370879	17.09	N
Chrome	0.5	0.055	0.039775	PASS
Chrome VI	0.05	0.0055	0.002705	PASS
Cobalt	0.02	0.0022	0.007593	N
Formaldehyde	0.368466	0.040531	10.3	N
Sulfuric Acid	0.2	0.022	7.42	N
HCl	2.983231	0.328155	144.87	N
Manganese	0.2	0.022	0.397179	N
Mercury	0.01	0.0011	0.011108	N
Methanol	262.0859	28.82945	466.32	N
Nickel	0.1	0.011	0.04425	N
Selenium	0.2	0.022	0.056821	N

2nd Tier Screening (PAIL)

AERMOD air dispersion modeling was performed on the estimated hourly emissions from the following sources, in order to predict ambient concentrations beyond the property boundary. The Presumptively Acceptable Impact Level (PAIL) for each compound has been deemed by the Department to be one one-hundredth of the Threshold Limit Value as listed by the ACGIH.

Pollutant	PAIL (µg/m ³) = 1/100 of Threshold Limit Value	Modeled Concentration (µg/m ³)	Pass?
Acetaldehyde	450.409	22.67892	Y
Acrolein	2.292843	0.4661	Y
Ammonia	524.2945	104.1325	Y
Arsenic	0.1	0.00286	Y
Beryllium	0.0005	0.00015	Y
C6h6	38.83436	0.88375	Y
Cadmium	0.02	0.00061	Y
Chlorine	14.50102	6.06006	Y
Chloroform	488.2618	16.40307	Y
Chrome	1032.515	0.00225	Y

Pollutant	PAIL ($\mu\text{g}/\text{m}^3$) = 1/100 of Threshold Limit Value	Modeled Concentration ($\mu\text{g}/\text{m}^3$)	Pass?
Chrome VI	1032.515	0.00106	Y
Cobalt	0.2	0.00072	Y
Formaldehyde	3.684663	2.71545	Y
Sulfuric Acid	2	0.14547	Y
HCl	29.83231	5.97147	Y
Manganese	2	0.0439	Y
Mercury	0.1	0.00087	Y
Methanol	2620.859	2564.18	Y
Nickel	1	0.00255	Y
Selenium	2	0.00902	Y

c) H₂S Modeling:

A.C.A. §8-3-103 requires hydrogen sulfide emissions to meet specific ambient standards. Many sources are exempt from this regulation, refer to the Arkansas Code for details.

Is the facility exempt from the H₂S Standards Y

The facility is subject to and complies with 40 CFR Part 60, Subpart BB and is exempt pursuant to A.C.A. § 8-3-103-(d)(2)(B)(ii).

12. CALCULATIONS:

Constituent	Emission Factor Source (AP-42, Testing, etc.)	Emission Factor and units (lb/ton, lb/hr, etc.)	Control Equipment Type (if any)	Control Equipment Efficiency	Comments (Emission factor controlled/uncontrolled, etc.)
Source SN-01 No. 3 Power Boiler					
PM/PM ₁₀	NSPS and PSD	0.025 lb/MMBtu	ESP	98	Controlled Lb/hr based on 790 MMBtu/hr
SO ₂	PSD BACT	0.1 lb/MMBtu (NSPS Limit)	N/A	-	PSD limit applied to unit with 620 MMBtu/hr of bark feed and 170 MMBtu/hr natural gas. (Permit 946-A)

Constituent	Emission Factor Source (AP-42, Testing, etc.)	Emission Factor and units (lb/ton, lb/hr, etc.)	Control Equipment Type (if any)	Control Equipment Efficiency	Comments (Emission factor controlled/uncontrolled, etc.)
VOC	PSD BACT	0.027 lb/MMBtu	N/A		PSD limit applied to unit with 790 MMBtu/hr of bark feed and natural gas at a steam production rate of 450,000 lb/hr. (Permit 946-A)
CO	PSD BACT	0.35 lb/MMBtu	N/A		PSD limit applied to unit with 790 MMBtu/hr of a combination of bark feed and natural gas at a steam production rate of 450,000 lb/hr. (Permit 946-A)
NO _x	PSD and NSPS Db	0.3 lb/MMBtu	N/A		PSD limit applied to unit with 790 MMBtu/hr of a combination of bark feed and natural gas at a steam production rate of 450,000 lb/hr. (Permit 946-A)
Lead	NCASI	5.04E-06 lb/MMBtu	ESP	N/A	790 MMBtu/hr Heat Input Design Capacity
Acetaldehyde	Stack Test	0.21 lb/hr	N/A		
Acrolein	NCASI	9.36E-05 lb/MMBtu	N/A		790 MMBtu/hr Heat Input Design Capacity
Benzene	NCASI	3.30E-03 lb/MMBtu	N/A		790 MMBtu/hr Heat Input Design Capacity
Formaldehyde	NCASI	1.56E-03 lb/MMBtu	N/A		790 MMBtu/hr Heat Input Design Capacity
Hydrogen Chloride	NCASI	8.04E-04 lb/MMBtu	N/A		790 MMBtu/hr Heat Input Design Capacity
Hexane	NCASI	1.8 lb/MMscf	N/A		790 MMBtu/hr Heat Input Design Capacity
Naphthalene	Stack Test	0.50 lb/hr	N/A		
Phenol	NCASI	1.4E-05 lb/MMBtu	N/A		790 MMBtu/hr Heat Input Design Capacity
Toluene	NCASI	3.48E-05 lb/MMBtu	N/A		790 MMBtu/hr Heat Input Design Capacity, No SF

Constituent	Emission Factor Source (AP-42, Testing, etc.)	Emission Factor and units (lb/ton, lb/hr, etc.)	Control Equipment Type (if any)	Control Equipment Efficiency	Comments (Emission factor controlled/uncontrolled, etc.)
Antimony	NCASI	5.04E-07 lb/MMBtu	N/A		790 MMBtu/hr Heat Input Design Capacity
Arsenic	NCASI	4.80E-07 lb/MMBtu	N/A		790 MMBtu/hr Heat Input Design Capacity
Beryllium	NCASI	4.80E-07 lb/MMBtu	N/A		790 MMBtu/hr Heat Input Design Capacity
Cadmium	NCASI	7.08E-07 lb/MMBtu	N/A		790 MMBtu/hr Heat Input Design Capacity
Chromium VI	NCASI	5.88E-07 lb/MMBtu	N/A		790 MMBtu/hr Heat Input Design Capacity
Chromium	NCASI	6.24E-07 lb/MMBtu	N/A		790 MMBtu/hr Heat Input Design Capacity
Cobalt	NCASI	2.28E-07 lb/MMBtu	N/A		790 MMBtu/hr Heat Input Design Capacity
Manganese	NCASI	6.84E-05 lb/MMBtu	N/A		790 MMBtu/hr Heat Input Design Capacity
Mercury	Stack Test	1.92E-3 lb/hr	N/A		
Nickel	NCASI	4.20E-06 lb/MMBtu	N/A		790 MMBtu/hr Heat Input Design Capacity
Selenium	NCASI	3.96E-06 lb/MMBtu	N/A		790 MMBtu/hr Heat Input Design Capacity
SN-02 No. 3 Lime Kiln					
PM ₁₀ /PM	NSPS BB	0.066 gr/dscf	ESP	98	Stack Test 8.6 lb PM ₁₀ /hr
SO ₂	PSD	0.727 lb/Ton CaO (13.3 lb/hr)			PSD limit applied to unit with 440 tons per day of lime (Permit 946-A) (0.727*440)/24= lb/hr tpy *8760
VOC	PSD	0.795 lb/ton of CaO			287-AR-7 cites AP-42, 4th Edition, current AP-42 does not have a factor. Calculation of lb/h and tpy same as SO ₂ . The permit has as PSD limit but 946-A did not have in PSD. Picked up as a PSD cite in 287-AR-7.

Constituent	Emission Factor Source (AP-42, Testing, etc.)	Emission Factor and units (lb/ton, lb/hr, etc.)	Control Equipment Type (if any)	Control Equipment Efficiency	Comments (Emission factor controlled/uncontrolled, etc.)
CO	PSD	3.0 lb/ton CaO			PSD limit applied to unit with 440 tons per day of lime (Permit 946-A) $(3.0*440)/24=$ lb/hr tpy *8760
NO _x	PSD	3.63 lb/ton CaO			PSD limit applied to unit with 440 tons per day of lime (Permit 946-A) $(3.63*440)/24=$ lb/hr tpy *8760
TRS	NSPS BB	8 ppm			1.34 lb/hr CEMS
Acetaldehyde	NCASI	5.1E-03 lb/ton CaO			
Benzene	Stack Test	0.24 lb/hr			
Formaldehyde	NCASI	6.12E-03 lb/ton CaO			
Methanol	Stack Test	1.31 lb/hr			
Toluene	NCASI	9.96E-03 lb/ton CaO			
Source SN-03 No. 1 Power Boiler					
PM ₁₀ /PM	Stack Test	340.6lb/hr	WESP	98%	Stack test 20% SF
SO ₂	Fuel Reporting	214 lb/hr			
VOC	Stack Test	43 lb/hr			
CO	Stack Test	164 lb/hr			Stack test 20% SF
NO _x	Stack Test	247.5 lb/hr			
Lead	Stack Test	0.059 lb/hr	WESP		
Acetaldehyde	NCASI Factor	0.84 lb/hr	N/A		
Acrolein	NCASI	9.36E-05 lb/MMBtu	N/A		580 MMBtu/hr Design Heat Input Capacity
Benzene	NCASI	3.30E-03 lb/MMBtu	N/A		580 MMBtu/hr Design Heat Input Capacity
Formaldehyde	NCASI	1.56E-03 lb/MMBtu	N/A		580 MMBtu/hr Design Heat Input Capacity

Constituent	Emission Factor Source (AP-42, Testing, etc.)	Emission Factor and units (lb/ton, lb/hr, etc.)	Control Equipment Type (if any)	Control Equipment Efficiency	Comments (Emission factor controlled/uncontrolled, etc.)
Hydrogen Chloride	Stack Test	52.2 lb/hr			
Hexane	NCASI	1.8 lb/MMscf	N/A		580 MMBtu/hr Design Heat Input Capacity
Phenol	NCASI	1.4E-05 lb/MMBtu	N/A		580 MMBtu/hr Design Heat Input Capacity
Toluene	NCASI	3.48E-05 lb/MMBtu	N/A		580 MMBtu/hr Design Heat Input Capacity
Antimony	NCASI	5.04E-07 lb/MMBtu	N/A		580 MMBtu/hr Design Heat Input Capacity
Arsenic	Stack Test	9.28E-03 lb/hr	N/A		
Beryllium	Stack Test	2.02E-03 lb/hr	N/A		
Cadmium	Stack Test	0.0746 lb/hr	N/A		
Chromium VI	NCASI	5.88E-07 lb/MMBtu	N/A		580 MMBtu/hr Design Heat Input Capacity
Chromium	NCASI	0.0242 lb/hr	N/A		580 MMBtu/hr Design Heat Input Capacity
Cobalt	NCASI	2.28E-07 lb/MMBtu	N/A		580 MMBtu/hr Design Heat Input Capacity
Manganese	Stack Test	4.76 lb/hr	N/A		
Mercury	NCASI	7.44E-07 lb/MMBtu			580 MMBtu/hr Design Heat Input Capacity
Nickel	Stack Test	0.0204			
Selenium	NCASI	3.96E-06 lb/MMBtu			580 MMBtu/hr Design Heat Input Capacity
Source SN-05 No. 2 Power Boiler					
PM ₁₀	BART	0.1 lb/MMBtu	Venturi Scrubber	98	820 MMBtu/hr Design Heat Input Capacity
SO ₂	BART	1.2 lb/MMBtu	Venturi Scrubber	98	820 MMBtu/hr Design Heat Input Capacity
VOC	Stack Test	92 lb/hr			
CO	AP-42	0.324 lb/MMBtu			820 MMBtu/hr Design Heat Input Capacity
NO _x	NSPS	0.7 lb/MMBtu			820 MMBtu/hr Design Heat Input Capacity

Constituent	Emission Factor Source (AP-42, Testing, etc.)	Emission Factor and units (lb/ton, lb/hr, etc.)	Control Equipment Type (if any)	Control Equipment Efficiency	Comments (Emission factor controlled/uncontrolled, etc.)
Lead	EPA Toxic Air Pollutant Factors, October 1988	0.03 lb/hr			
Acetaldehyde	Stack Test	0.21 lb/hr	N/A		
Acrolein	NCASI	7.8E-05 lb/MMBtu	N/A		820 MMBtu/hr Design Heat Input Capacity
Benzene	NCASI	3.3E-03 lb/MMBtu	N/A		820 MMBtu/hr Design Heat Input Capacity
HCl	Stack Test	5.75 lb/hr	N/A		
Hexane	NCASI	1.8 lb/MMscf	N/A		820 MMBtu/hr Design Heat Input Capacity
Naphthalene	Stack Test	0.50 lb/hr	N/A		
Phenol	NCASI	1.4E-05 lb/MMBtu	N/A		
Toluene	NCASI	2.9E-05 lb/MMBtu	N/A		
Antimony	NCASI	1.8E-05 lb/ton coal	Venturi Scrubber	98	800 tons coal/day
Arsenic	NCASI	4.1E-04 lb/ton coal	Venturi Scrubber	98	800 tons coal/day
Beryllium	NCASI	2.1E-05 lb/ton coal	Venturi Scrubber	98	800 tons coal/day
Cadmium	NCASI	5.1E-05 lb/ton coal	Venturi Scrubber	98	800 tons coal/day
Chromium VI	NCASI	6.1E-6 lb/MMBtu	Venturi Scrubber	98	820 MMBtu/hr Design Heat Input Capacity
Chromium	NCASI	2.6E-04 lb/ton coal	Venturi Scrubber	98	800 tons coal/day
Cobalt	NCASI	1.0E-04 lb/ton coal	Venturi Scrubber	98	800 tons coal/day
Manganese	NCASI	4.0E-05 lb/MMBtu	Venturi Scrubber	98	820 MMBtu/hr Design Heat Input Capacity
Mercury	NCASI	8.3E-05 lb/ton coal	Venturi Scrubber	98	800 tons coal/day
Nickel	NCASI	2.8E-04 lb/ton coal	Venturi Scrubber	98	800 tons coal/day

Constituent	Emission Factor Source (AP-42, Testing, etc.)	Emission Factor and units (lb/ton, lb/hr, etc.)	Control Equipment Type (if any)	Control Equipment Efficiency	Comments (Emission factor controlled/uncontrolled, etc.)
Selenium	NCASI	1.3E-03 lb/ton coal	Venturi Scrubber	98	800 tons coal/day
Source SN-06 No. 2 Recovery Boiler					
PM ₁₀	Stack Test	84.4	ESP	98	
SO ₂	PSD	286 lb/hr			PSD limit from 287-AR-3
VOC	Stack Test	46.7 lb/hr			
CO	PSD	980 lb/hr 16.8 lb/ADTP			
NO _x	PSD	309.2 lb/hr 5.3 lb/ADTP			
Acetaldehyde	NCASI	4.2E-04 lb/ton BLS			2160 tons BLS/day 788,400 tons BLS/yr
Benzene	NCASI	6.4E-04 lb/ton BLS			2160 tons BLS/day 788,400 tons BLS/yr
Formaldehyde	Stack Test	0.72 lb/hr			
Hydrogen Chloride	Stack Test	51.20 lb/hr			
Methanol	NCASI	0.045 lb/ton BLS			2160 tons BLS/day 788,400 tons BLS/yr
Styrene	Stack Test	3.22 lb/hr			
Sulfuric Acid	NCASI	3.024 lb/ton BLS			2160 tons BLS/day 788,400 tons BLS/yr
TRS	CEMS	7.4 lb/hr			NSPS BB 5PPMV
Source SN-08 - No. 2 Smelt Dissolving Tank					
PM ₁₀ / PM	NSPS BB	0.2 lb/ton BLS	Scrubber	80	PM is a PSD limit from 287-AR-3 2160 tons BLS/day 788,400 tons BLS/yr
SO ₂	PSD	10.6 lb/hr	Scrubber	80	SO ₂ is a PSD limit from 287-AR-3
VOC	NCASI	0.066 lb/ton BLS			2160 tons BLS/day 788,400 tons BLS/yr
Acetaldehyde	NCASI	1.6E-03 lb/ton BLS			2160 tons BLS/day 788,400 tons BLS/yr

Constituent	Emission Factor Source (AP-42, Testing, etc.)	Emission Factor and units (lb/ton, lb/hr, etc.)	Control Equipment Type (if any)	Control Equipment Efficiency	Comments (Emission factor controlled/uncontrolled, etc.)
Ammonia	NCASI	0.41E-03 lb/ton BLS			2160 tons BLS/day 788,400 tons BLS/yr
Formaldehyde	NCASI	3.5E-03 lb/ton BLS			2160 tons BLS/day 788,400 tons BLS/yr
Methanol	NCASI	0.023 lb/ton BLS			2160 tons BLS/day 788,400 tons BLS/yr
TRS	NSPS BB	0.033 lb/ton BLS	Scrubber	60	2160 tons BLS/day 788,400 tons BLS/yr
Source SN-09 No. 2 Lime Kiln					
PM/PM ₁₀	Stack Test NSPS	51.0 lb/hr 0.064 gr/dscf	Scrubber	85	PM is a PSD limit
SO ₂	Permit 946A	0.727 lb/ton CaO			Based on BACT for Lime Kiln No. 3 18.33 tons CaO/hr 160571 tons CaO/yr
VOC	AP-42, 4th edition, 1985	0.9353 lb/ton CaO			18.33 tons CaO/hr 160571 tons CaO/yr
CO	AP-42, 4th edition, 1985	3.0 lb/ton CaO			Based on BACT for Lime Kiln No. 3
NO _x	AP-42, 4th edition, 1985	3.7411 lb/ton CaO			18.33 tons CaO/hr 160571 tons CaO/yr
Acetaldehyde	NCASI	5.1E-03 lb/ton CaO			18.33 tons CaO/hr 160571 tons CaO/yr
Benzene	Stack Test	0.23			
Methanol	Stack Test	1.18			
Formaldehyde	NCASI	8.5E-03 lb/ton CaO			
Toluene	NCASI	8.3E-03 lb/ton CaO			
TRS	NSPS BB	8.00 ppmvd @10% O ₂	Scrubber	25	CEMS
Source SN-14 No. 3 Recovery Boiler					

Constituent	Emission Factor Source (AP-42, Testing, etc.)	Emission Factor and units (lb/ton, lb/hr, etc.)	Control Equipment Type (if any)	Control Equipment Efficiency	Comments (Emission factor controlled/uncontrolled, etc.)
PM ₁₀ /PM	PSD NSPS	93.5 lb/hr 0.044 gr/dscf	ESP	98	controlled
SO ₂	PSD	425.0 lb/hr 250 PPM			287-AR had a PSD avoidance limit of the firing rate of BLS. CEMS can show compliance now. 1861.5 tpy
VOC	AP-42 , 4th edition, 1985	0.8 lb/ADTP			INCOMPLETE Calculations
CO	CEMS	856 lb/hr			
NO _x	CEMS	270 lb/hr			PSD Limit
Acetaldehyde	NCASI	4.2E-04 lb/ton BLS			2,800 tons/day 1,022,000 tons/yr
Benzene	NCASI	6.4E-04 lb/ton BLS			2,800 tons/day 1,022,000 tons/yr
Formaldehyde	NCASI	6.6E-03 lb/ton BLS			2,800 tons/day 1,022,000 tons/yr
Hydrogen Chloride	Stack Test	54.50 lb/hr			
Methanol	NCASI	0.045 lb/ton BLS			2,800 tons/day 1,022,000 tons/yr
Styrene	NCASI	8.8E-04 lb/ton BLS			2,800 tons/day 1,022,000 tons/yr
Sulfuric Acid	Stack Test	4.20 lb/hr			
TRS	CEMS	6.6 lb/hr			PSD Limit
Source SN-15 - No. 3 Smelt Dissolving Tank					
PM ₁₀ /PM	PSD NSPS BB	18.7 lb/hr 0.1 g/kg BLS	Scrubber	90	
SO ₂	PSD		Scrubber	10	
VOC	NCASI ⁷	0.066 lb/ton BLS			2800 tons/day 1,022,000 tons/year
TRS	PSD NSPS BB	1.6 lb/hr 0.0168 g/kg BLS	Scrubber	25	
Acetaldehyde	NCASI	1.6E-04 lb/ton BLS			

Constituent	Emission Factor Source (AP-42, Testing, etc.)	Emission Factor and units (lb/ton, lb/hr, etc.)	Control Equipment Type (if any)	Control Equipment Efficiency	Comments (Emission factor controlled/uncontrolled, etc.)
Ammonia	NCASI	0.41 lb/ton BLS			
Formaldehyde	Stack Test	0.58 lb/hr			
Methanol	NCASI	0.023 lb/ton BLS			
Sources SN-16 – No. 1A Bleachplant Vents, SN-17 - No. 1B Bleachplant Vents and SN-18 - No. 2 Bleachplant Vents					
VOC	Stack Test	32.0 lb/hr			Bubbled Sources
CO	Stack Test	240.4 lb/hr			
Acetaldehyde	NCASI	2.3E-3 lb/ADTUBP			3,407 ADTUBP/day 1,234,555 ADTUBP/yr
Chlorine	Stack Test	6.00 lb/hr	Scrubber	99	
Chlorine Dioxide	Stack Test	4.00 lb/hr	Scrubber	99	
Chloroform	Stack Test	16.50 lb/hr			
Formaldehyde	NCASI	4.2E-4 lb/ADTUBP			3,407 ADTUBP/day 1,234,555 ADTUBP/yr
HCl	NCASI	0.022 lb/ADTUBP			3,407 ADTUBP/day 1,234,555 ADTUBP/yr
Methanol	NCASI	0.15 lb/ADTUBP			3,407 ADTUBP/day 1,234,555 ADTUBP/yr
TRS	NCASI	2.8E-3 lb/ADTUBP			3,407 ADTUBP/day 1,234,555 ADTUBP/yr
Source SN-20 - ERCO ClO2 Generator					
Chlorine	Stack Test	0.30 lb/hr			
Chlorine Dioxide	Stack Test	3.00 lb/hr			
Source SN-21 - Effluent Treatment Lagoons					
VOC	NCASI	248.9 lb/hr			Sum of methanol, formaldehyde, and chloroform estimates 75 Mgal/day effluent
Chloroform	NCASI	5E-03 lb/ADTUBP			3,770 ADTUBP/day 1,376,050 ADTUBP/yr
Formaldehyde	NCASI	0.76 ppmw			3,770 ADTUBP/day 1,376,050 ADTUBP/yr

Constituent	Emission Factor Source (AP-42, Testing, etc.)	Emission Factor and units (lb/ton, lb/hr, etc.)	Control Equipment Type (if any)	Control Equipment Efficiency	Comments (Emission factor controlled/uncontrolled, etc.)
Methanol	NCASI	4.9 ^A 21.4 ^B 0.25 ^C 0.25 ^D			3,770 ADTUBP/day 1,376,050 ADTUBP/yr Contributions from sources: A: Bleach Plant [lb/ADTUBP] B: Condensates [lb/ADTUBP] C: Clarifier Effluent [ppmw] D: Clarifier Fugitive [ppmw]
Source SN-22 - No. 1A and 1B Brownstock Washers					
VOC	stack test	1A 0.57 lb/ton pulp and No. 1B .06173 lb/ton pulp			59.2 lb/hr 259.3 tpy
Acetone	stack test	8.80 lb/hr			
Formaldehyde	stack test	1A 0.0109 lb/ton pulp			
Methanol	stack test	1A 0.01731 lb/ton pulp and No. 1B .001593 lb/ton pulp			
TRS	NCASI	0.23 lb/ADTUBP			1,152 ADTUBP/day 420,480 ADTUBP/yr
Source SN-23 - Storage Tank - Methanol Tank					
VOC	AP-42 Sec. 7.1.3.1	39.81 lb/hr			
Methanol	AP-42 Sec. 7.1.3.1	39.81 lb/hr			
SN-28 - Storage Tank					
VOC	AP-42 Sec. 7.1.3.1	6.62 lb/hr			
Formic Acid	AP-42 Sec. 7.1.3.1	6.62 lb/hr			
Source SN-29 - Reausticizer Vents					

Constituent	Emission Factor Source (AP-42, Testing, etc.)	Emission Factor and units (lb/ton, lb/hr, etc.)	Control Equipment Type (if any)	Control Equipment Efficiency	Comments (Emission factor controlled/uncontrolled, etc.)
PM/PM ₁₀	NCASI	0.031 lb/ton CaO			1,152 tons CaO/day 420,500 tons CaO/yr
VOC	NCASI	3.62 lb/hr			Sum of acetaldehyde and methanol
Acetaldehyde	NCASI	2.1E-2 lb/ton CaO			Emission factor is from the previous permit. Permittee requested to keep existing emission limit of 0.51 lb/hr.
Ammonia	NCASI	0.46 lb/ton CaO			1,152 tons CaO/day 420,500 tons CaO/yr
Methanol	NCASI	0.054 lb/ton CaO			1,152 tons CaO/day 420,500 tons CaO/yr
Sources SN-30A, SN-30B, SN-30C, SN-30D, SN-30E and SN-30E – PCC Carbonators Lime Silos					
PM ₁₀	Stack test	4.8 lb/hr			
SO ₂	Stack test	2.4 lb/hr			
VOC	Stack test	12.6 lb/hr			
CO	Stack test	54.6 lb/hr			
NO _x	Stack test	65.4 lb/hr			
TRS	Stack test	0.36 lb/hr			
Source SN-36 - Weak Black Liquor Tanks (Tanks #1 through #9)					
VOC	Stack test	7.3 lb/hr			
Methanol	Stack test	6.30 lb/hr			
TRS	Stack test	0.1 lb/hr			PSD limit
Source SN-36 – Weak Black Liquor Tank #10					
VOC	NCASI	0.68 lb/hr/tank			
Methanol	NCASI	0.62 lb/hr/tank			
TRS	NCASI	0.84 lb/hr/tank			
Source SN-37 - Pulp Dryer Hood and Vacuum Exhausts					

Constituent	Emission Factor Source (AP-42, Testing, etc.)	Emission Factor and units (lb/ton, lb/hr, etc.)	Control Equipment Type (if any)	Control Equipment Efficiency	Comments (Emission factor controlled/uncontrolled, etc.)
VOC	Stack test	4.7 lb/hr			R0 Application: production rate 37.5 tph finished pulp @7% moisture which is 34.875 tph bone dry pulp 900 air dried tons per day finished product Permitted 8,760 hours (328,500 ADTFP/yr)
Acetaldehyde	NCASI	0.033 lb/ADTFP			See comment for VOC. Permit limit includes 20% safety factor
Methanol	NCASI	0.071 lb/ADTFP			See comment for VOC. Permit limit includes 20% safety factor
Source SN-38 - No. 2 and No. 3 Wood Yards					
PM	AP-42 Section 13.2.4	6.67E-5 lb/ton bark 4.05E-5 lb/ton chips			
PM ₁₀	AP-42 Section 13.2.4	3.15E-5 lb/ton bark 1.91E-5 lb/ton chips			
VOC	NCASI	0.27 lb/Tdw Hardwood 2.12 lb/Tdw Softwood			Assumes 50% moisture, 74% softwood, and 26% hardwood PSD Limit
Source SN-39 – High Density Storage Tanks					
VOC	NCASI	0.151 lb/hr/tank			11 tanks Sum of acetaldehyde, chloroform, and methanol 20% SF
Acetaldehyde	NCASI	0.02 lb/hr/tank			11 tanks 20% SF
Chloroform	NCASI	0.011 lb/hr/tank			11 tanks 20% SF

Constituent	Emission Factor Source (AP-42, Testing, etc.)	Emission Factor and units (lb/ton, lb/hr, etc.)	Control Equipment Type (if any)	Control Equipment Efficiency	Comments (Emission factor controlled/uncontrolled, etc.)
Methanol	NCASI	0.12 lb/hr/tank			11 tanks 20% SF
TRS	NCASI	0.349 lb/hr/tank			11 tanks 20% SF
Acetone	NCASI	0.027 lb/hr/tank			11 tanks 20% SF
Source SN-40 - No. 1A and No. 1B Digester Chip Fill Exhausts					
VOC	Stack Test	10.0 lb/hr			Compliance demonstrated by limiting time between blows Sum of Methanol and Ethanol 2,304 ADTP/day 840,960 ADTP/yr
Methanol	Stack Test	0.33 lb/ADTP			Compliance demonstrated by limiting time between blows
TRS	NCASI	0.072 lb/ADTP			Compliance demonstrated by limiting time between blows 2,304 ADTP/day 840,960 ADTP/yr
Source SN-41 - Sludge Landfill					
PM	AP-42 Section 13.2.4	1.36E-3 lb/ton Sludge			344,000 yd ³ /yr 170 yd ³ /hr 947.7 lb/yd ³
PM ₁₀	AP-42 Section 13.2.4	6.5E-4 lb/ton Sludge			344,000 yd ³ /yr 170 yd ³ /hr 947.7 lb/yd ³
VOC (as NMOC)	LandGEM	63.15 lb/hr			
CO	LandGEM	4.8 lb/hr 1.8 tpy			
HAPS	LandGEM				See Permit For Emission Rates
Source SN-42 - No. 2 Decker					

Constituent	Emission Factor Source (AP-42, Testing, etc.)	Emission Factor and units (lb/ton, lb/hr, etc.)	Control Equipment Type (if any)	Control Equipment Efficiency	Comments (Emission factor controlled/uncontrolled, etc.)
VOC	Stack Test	5.6 lb/hr			Sum of acetaldehyde, formaldehyde, methanol, and terpenes (0.48 lb terpenes/ADTUBP)
Acetaldehyde	NCASI	5.9E-03 lb/ADTUBP			1,100 ADTUBP/day 401,500 ADTUBP/yr 20% SF
Acetone	Stack Test	7.52 lb/hr			
Formaldehyde	NCASI	3.3E-03 lb/ADTUBP			1,100 ADTUBP/day 401,500 ADTUBP/yr 20% SF
Methanol	Stack Test	3.3 lb/hr			
TRS	NCASI	0.044 lb/ADTUBP			1,100 ADTUBP/day 401,500 ADTUBP/yr 20% SF
Source SN-43 - Tub Grinder					
PM ₁₀ /PM	AP-42 Table 3.3-1	0.31 lb/MMBtu			4 MMBtu/hr 258,000 gallon/yr 0.13 MMBtu/gal
SO ₂	AP-42 Table 3.3-1	0.29 lb/MMBtu			4 MMBtu/hr 258,000 gallon/yr 0.13 MMBtu/gal
VOC	AP-42 Table 3.3-1	0.36 lb/MMBtu			4 MMBtu/hr 258,000 gallon/yr 0.13 MMBtu/gal
CO	AP-42 Table 3.3-1	0.95 lb/MMBtu			4 MMBtu/hr 258,000 gallon/yr 0.13 MMBtu/gal
NO _x	AP-42 Table 3.3-1	4.41 lb/MMBtu			4 MMBtu/hr 258,000 gallon/yr 0.13 MMBtu/gal
HAPs	AP-42 Table 3.3-2				4 MMBtu/hr 258,000 gallon/yr 0.13 MMBtu/gal
Sources SN-44a, SN-44b, SN-44c and SN-44d - Paper Machines					
VOC	Testing	44A: 2.0 44B: 4.7 44C: 5.6 44D: 10.3			Emission factors are in lb/hr by machine.

Constituent	Emission Factor Source (AP-42, Testing, etc.)	Emission Factor and units (lb/ton, lb/hr, etc.)	Control Equipment Type (if any)	Control Equipment Efficiency	Comments (Emission factor controlled/uncontrolled, etc.)
Acetaldehyde	NCASI	0.033 lb/ADTFP			<u>SN-44A</u> 19.1 ADTFP/hr 167,316 ADTFP/yr <u>SN-44B & C</u> 30.77 ADTFP/hr 269,553 ADTFP/yr <u>SN-44D</u> 79.92 ADTFP/hr 700,070 ADTFP/yr ADTFP – air dried tons of finished product 20% SF
Acrolein	NCASI	1.6E-3 lb/ADTFP			See Comments for Acetaldehyde 20% SF
Formaldehyde	NCASI	6.4E-3 lb/ADTFP			See Comments for Acetaldehyde 20% SF
Methanol	Testing	44A: 2.00 44B: 4.70 44C: 5.60 44D: 6.80			Limited by VOC and Methanol in shower water Emission factors are in lb/hr by machine.
Source SN-45 - Oxygen Delignification System					
VOC	Stack Test	9.1 lb/hr			1,100 ADTUBP/day
CO	Stack Test	16.5 lb/hr			1,100 ADTUBP/day
Acetaldehyde	NCASI	0.021 lb/ADTP			1,100 ADTUBP/day
Formaldehyde	NCASI	0.0017 lb/ADTP			1,100 ADTUBP/day
Methanol	Stack Test	9.11 lb/hr			1,100 ADTUBP/day
TRS	Stack Test	2 lb/hr			1,144 ADTUBP/day
SN-46 – Haul roads					

Constituent	Emission Factor Source (AP-42, Testing, etc.)	Emission Factor and units (lb/ton, lb/hr, etc.)	Control Equipment Type (if any)	Control Equipment Efficiency	Comments (Emission factor controlled/uncontrolled, etc.)
PM/PM ₁₀	Estimate	0.16 lb/VMT		Subject to road maintenance plan	Overall lb/VMT for both paved/undpaved with controls included
SN-50, SN-53, SN-54a, SN-54b, SN-57, SN-58, and SN-59 – Stationary RICE					
PM/PM ₁₀	AP-42 Table 3.3-1				
SO ₂	AP-42 Table 3.3-1				
VOC	AP-42 Table 3.3-1				
CO	AP-42 Table 3.3-1				
NO _x	AP-42 Table 3.3-1				
HAP	AP-42 Table 3.3-1				
SN-55 – Paper Additive Silos					
PM/PM ₁₀	Mass Balance	0.03 gr/dscfm	Fabric filter		
SN-56 – Dye Operation					
VOC	Mass Balance				Emission factor varies by MSDS for each product used.

13. TESTING REQUIREMENTS:

The permit requires testing of the following sources.

SN(s)	Pollutant	Test Method	Test Interval	Justification For Test Requirement
01	PM	5	Every 5 years	§19.702
01	PM ₁₀	201A or 5 and 202	Every 5 years	§19.702
01	VOC	Method 25A	Every 5 years	§19.702
01	Filterable PM	Multiple refer to Subpart DDDDD, Table 5	Annually	Boiler MACT
01	HCl	Multiple refer to Subpart DDDDD, Table 5	Annually	Boiler MACT

SN(s)	Pollutant	Test Method	Test Interval	Justification For Test Requirement
01	Mercury	Multiple refer to Subpart DDDDD, Table 5	Annually	Boiler MACT
02	PM/PM ₁₀	5 or 29	Initial test	§63.865
02	O ₂	3, 3A or 3B	Initial test	§63.865
02	PM	5	Every five years	§18.1002
02	PM ₁₀	201A or 5 and 202	Every five years	§19.702
02	VOC	25A	Every five years	§19.702
03	VOC	25A	Every five years	§19.705
03	PM	5 and 202	Every five years	§18.1002
03	PM ₁₀	201A or 5 and 202	Every five years	§19.705
03	CO	10B	Every five years	§19.705
03	NO _x	7E	Every five years	§19.705
05	PM	5	Every five years	§18.1002
05	PM ₁₀	201A or 5 and 202	Every five years	§19.705
05	VOC	25A	Every five years	§19.705
05	HCl	26A	Every five years	§18.1002
05	Filterable PM	Multiple refer to Subpart DDDDD, Table 5	Annually	Boiler MACT
058	HCl	Multiple refer to Subpart DDDDD, Table 5	Annually	Boiler MACT
05	Mercury	Multiple refer to Subpart DDDDD, Table 5	Annually	Boiler MACT
06	VOC	25A	Every five years	§19.705
06	PM	5 and 202	Every five years	§19.705
06	PM ₁₀	201A or 5 and 202	Every five years	§19.705
08	TRS	16	Every five years	§18.1002
08	VOC	25A	Every five years	§19.705
08	O ₂	3A or 3B	Once	§63.865
08	PM	5	Every five years	§19.705
08	PM ₁₀	201A or 5 and 202	Every five years	§19.705
09	PM	5 or 29	Once	§63.865
09	O ₂	3A or 3B	Once	§63.865
09	NO _x	7E	Annually	§19.705
14	PM ₁₀	201A or 5 and 202	Every five years	§19.702
14	VOC	25A	Every five years	§19.702
15	TRS	16	Annual	§19.804
15	Ammonia	206	Every five years	§19.703
15	PM	5 or 29	Initial	63.865
15	O ₂	3 or 3A	Initial	63.865
16, 17,18	Pressure differential	Pressure transmitter	Yearly	63.453(a)(1)

SN(s)	Pollutant	Test Method	Test Interval	Justification For Test Requirement
16, 17,18	Cl ₂ , ClO ₂	NCASI Special Report Number 91-07	Every five years	18.1002
16,17,18	CO	10B	Every five years	§19.703
16,17,18	VOC	25A	Every five years	§19.703
20	Cl ₂ , ClO ₂	NCASI Special Report Number 91-07	Every five years	18.1002
21	COD	Water Test	Daily	63.453(j)
21	Horsepower of Aerator units	Observation	Daily	63.453(j)
21	Inlet liquid flow	Flow Meter	Daily	63.453(j)
21	Liquid Temperature	Thermocouple	Daily	63.453(j)
21	BOD ₅ percent reduction	BOD ₅	Quarterly	63.453(j)
22	Methanol	25D	Yearly	§18.1003
22	Acetone	25D	Yearly	§18.1003
30	PM	5	Every five years	§19.702
30	PM/PM ₁₀	201A or 5 and 202	Every five years	§19.702
30	SO ₂	6C	Every five years	§19.702
30	VOC	25A	Every five years	§19.702
30	NO _x	7E	Every five years	§19.702
37	VOC	25D	Yearly	§19.702
42	Methanol	NCASI Method DI/MEOH-94-02, Methanol in Process liquids by GC/FID, August 1998, Methods Manual, NCASI, Research Triangle Park, NC	Yearly	§18.1002
42	Acetone		Yearly	§18.1002
44a	VOC	25D on shower water	Yearly	§19.703
44b, 44c, 44d	Methanol	NCASI Method DI/MEOH-94-02, Methanol in Process liquids by GC/FID, August 1998, Methods Manual, NCASI, Research Triangle Park, NC	Yearly	§18.1002
45	VOC	25A	Every 5 years	§19.705

SN(s)	Pollutant	Test Method	Test Interval	Justification For Test Requirement
45	CO	10	Every 5 years	\$19.705
54a	Formaldehyde	Method 320 or 323 of 40 CFR Part 63, App A	Initial	\$63.6620 One test per engine
54b	Formaldehyde	Method 320 or 323 of 40 CFR Part 63, App A	Initial	\$63.6620 One test per engine

14. MONITORING OR CEMS:

The permittee must monitor the following parameters with CEMS or other monitoring equipment (temperature, pressure differential, etc.)

SN(s)	Parameter or Pollutant to be Monitored	Method of Monitoring (CEM, Pressure Gauge, etc)	Frequency*	Report (Y/N)**
01	CO, NO _x	CEM	Every 15 minutes; Average once/ hour	N
01	Opacity	COM	Six-minute average	N
02	TRS	CEM	12-hour Average	N
02	CO, O ₂	CEM	Every 15 minutes; Average once/ hour	N
02	Opacity	COM	Six-minute average	N
03	Pressure Drop across Multi-clones	CPMS	Once per 8-hr shift	N
05	SO ₂ , CO, NO _x , O ₂	CEM	Every 15 minutes; Average once/ hour	N
05	Temperature Scrubbing Liquid Flow rate Pressure Drop of Gas Stream	CEM	Continuous	N
06	SO ₂ , CO, NO _x TRS, O ₂	CEM	Every 15 minutes; Average once/ hour	N

SN(s)	Parameter or Pollutant to be Monitored	Method of Monitoring (CEM, Pressure Gauge, etc)	Frequency*	Report (Y/N)**
06	Opacity	COM	Six-minute average	N
06	Floor Tube Temperature	CPMS	Continuous	N
08	Pressure Drop of gas stream Pressure of liquid supply Scrubbing liquor flow rate	CPMS	Continuous	Y
09	CO, TRS, O ₂	CEM	Every 15 minutes; Average once/hour	N
09	Scrubbing liquid flow rate Air pressure drop across scrubber Temperature of lime kiln	CPMS	Continuous	N
14	Opacity	COM	Six-minute average	N
14	CO, NO _x , TRS, O ₂	CEM	Every 15 minutes; Average once/hour	N
14	SO ₂	CEM	Every 15 minutes; Average once/hour	Y
14	Temperature	CPMS	Continuous	N
15	Scrubber gas pressure drop Scrubber Liquid Pressure	CPMS	Continuous	Y
15	Scrubbing liquid flow rate	CPMS	Every 8 hours – average the three daily readings	N
16	Inlet air flow rate Scrubbing liquid flow rate Inlet pH of Scrubber Liquid	CPMS	Continuous	N
17	Inlet air flow rate Scrubbing liquid flow rate Inlet pH of Scrubber Liquid	CPMS	Continuous	N

SN(s)	Parameter or Pollutant to be Monitored	Method of Monitoring (CEM, Pressure Gauge, etc)	Frequency*	Report (Y/N)**
18	Inlet air flow rate Scrubbing liquid flow rate Inlet pH of Scrubber Liquid	CPMS	Continuous	N
20	Absorption Water Temperature	Thermocouple	Once per shift	N
36	Temperature	CPMS	Continuous	N

15. RECORDKEEPING REQUIREMENTS:

The following are items (such as throughput, fuel usage, VOC content, etc.) that must be tracked and recorded.

SN	Recorded Item	Limit	Frequency	Report (Y/N)
01	Fuel Usage	Recording of pounds of fuel used	Daily	N
01	Fuel Usage	Recording of pounds of fuel used	Monthly Average	Y
01	Fuel Usage	Recording of pounds of fuel used	12-month Rolling Average	Y
01	Hourly NO _x Emission Rate	237 lb/hr	Hourly	Y
01	30-day average NO _x emission rates	0.3 lb/MMBtu	30-day rolling average	Y
01	30-day average CO emission rates	0.35 lb/MMBtu	30-day rolling average	Y
01	Moisture Content of Biomass Fuel	Must exceed 40% by weight on an as fired annual heat input basis	Monthly	Y
01	HCl and Mercury content per fuel analysis	No standard – Boiler MACT	Concurrently with performance testing, annually	Y
01	Type of fuel and amount during Startup/Shutdown	No standard – Boiler MACT	Per Event	Y
01	BTU Loading	790 MMBTU/hr	Daily	Y
02	TRS Concentration		Twelve-hour Average	Y
02	O ₂		Twelve-hour Average	N
02	Period pre-coat filter isolated	75% feed capacity for kiln		N

SN	Recorded Item	Limit	Frequency	Report (Y/N)
02	CO and NO _x	240.9 tpy CO 291.3 tpy NO _x	30-day rolling averages	N
02	%Solids of lime mud feed	65% 30-day rolling average	Daily	N
02	CaO Production	Ton/d	daily	Y
03	Fuel oil usage	2,700,000 gal/12 months	Monthly	Y
03	Pressure Drop across Multiclones	0.68 in. of H ₂ O	Every eight hours	N
05	Fuel Usage	tpd	daily	Y
05	Fuel Usage	tpd	Month	Y
05	Moisture Content of Biomass Fuel	Must exceed 40% by weight on an as fired annual heat input basis	Monthly	Y
05	HCl and Mercury content per fuel analysis	No standard – Boiler MACT	Concurrently with performance testing, annually	Y
05	Type of fuel and amount during Startup/Shutdown	No standard – Boiler MACT	Per Event	Y
05	Biomass heat input	Must be 10% or greater on an annual heat input basis	Monthly	Y
06	TRS emission	12-hour average	Daily	N
06	O ₂ Concentration	12-hour average	Daily	N
06	Hourly HCl Emissions	One-hour average	Hourly	N
06	Floor Tube Temperature	3-hour average	Hourly	Y
06	Floor Tube Temperature	monthly average	monthly	Y
06	Black Liquor Solids Rate	Daily feed	Daily	N
08	Pressure Drop of gas stream	Instantaneous	Once per shift	N
08	Pressure of liquid supply	Instantaneous	Once per shift	N
08	Scrubbing Liquor flow Rate	Flow Meter	Hourly	Y
08	Pressure Drop of gas stream	Pressure Drop	Once Every 15-minutes	Y
08	Scrubbing Liquor flow Rate	Flow Meter	Once Every 15-minutes	Y
09	TRS Concentration	CEMS	12-hour average	N
09	O ₂ Concentration	CEMS	12-hour average	N
09	Pressure Drop of gas stream	Instantaneous	Once per shift	N
09	Pressure of liquid supply	Instantaneous	Once per shift	N
09	Temperature	1-hour Rolling average	hourly	N
09	%Solids of lime mud feed	65% 30-day rolling average	Daily	N

SN	Recorded Item	Limit	Frequency	Report (Y/N)
09	CaO Production Rate	daily	daily	
09	Liquid Flow rate	Daily		N
09	Gas pressure drop	CEMs	Daily	N
12	Fuel Usage		Daily	Y
12	Fuel Usage		Monthly	Y
12	Hours of Operation		Hour	Y
12	Steam Loading		Hourly	N
14	TRS concentration		12-hour average	N
14	Black Liquor Firing Rate		Time below 1.5 MMlbs/day	N
14	HCl emissions	54.5 lb/hr and 238.71 tpy	Hourly	Y
14	BLS firing rate		Daily	Y
15	Scrubber Gas Pressure drop		Once per shift/ once every 15 minutes	Y
15	Scrubber Liquid Supply Pressure		Once per shift	Y
15	Scrubber Liquid flow Rate	175 gpm	Once per shift/ once every 15 minutes	Y
16	Fan Amperage	65 -105 amperes	Once per shift	Y
16	Scrubber Liquid flow Rate	300 gallons/minute	Once per shift	
17	Scrubber Liquid flow Rate	300 gallons/minute	Once per shift	
17	Fan Amperage	50 -105 amperes	Once per shift	Y
18	Scrubber Liquid flow Rate	350 gallons/minute	Once per shift	
18	350 gallons/minute	30 -80 amperes	Once per shift	Y
20	Scrubber Water Temperature		Once per shift	N
23	Tank Dimensions			N
23	Methanol Throughput	18,850,000 lbs/12 months	Monthly	Y
24	Ammonia Throughput	800,000 lbs/12 months	Monthly	Y
25	Phosphoric Acid throughput	1,500,000 lbs/12 months	Monthly	Y
26	Sulfuric Acid throughput	105,120,000 lbs/12 months	Monthly	Y
28	Formic Acid throughput	5,336,000 lbs/12 months	Monthly	Y
29	Lime processed	420,500 tons/12 months	Monthly	Y
36 Tank #10	Weak Black Liquor Throughput	2,018,304,000 gallon/12 months	Monthly	Y
37	Finished Product (Pulp)	328,000 tons of air dried pulp	Monthly	Y
38	Woodchips processed	4,320,000 tons/12 months	Monthly	Y
40	Time sample port is opened	Only when retrieving sample	Daily	N

SN	Recorded Item	Limit	Frequency	Report (Y/N)
40	Spacing of digester blows	Minimum of 25 minutes	Daily	N
41	Sludge put in landfill	163,000 tons/12 months	Monthly	Y
42	Unbleached Pulp	401,500 tons of air dried unbleached pulp	Monthly	Y
43	Fuel Consumption	258,000 gallons/12 months	Monthly	Y
44A	Finished Product	167,316 tons air dried paper/12 months	Monthly	Y
44B	Finished Product	269,553 tons air dried paper/12 months	Monthly	Y
44C	Finished Product	269,553 tons air dried paper/12 months	Monthly	Y
44D	Finished Product	700,070 tons air dried product/12 months	Monthly	Y
01,03,05	Tire derived fuel	220 tons/24-hours	Daily	Y
ALL	Units Operating at less than 25% capacity		Yearly	Y
RICE	Hours of Operation	500 hrs / 12 months	Per event	Y
56	Dye Usage	12.8 tons/12 months	Monthly	Y

16. OPACITY:

SN	Opacity %	Justification	Compliance Mechanism
01	20	Boiler fired with many different fuels	COMS - submittals in accordance with CEM standards
01	10	Boiler MACT	COMS operated according to Boiler MACT
02	20	This is a lime kiln. Particulate emissions are present which are not entirely caused by fuel combustion.	COMS - submittals in accordance with CEM standards
03	5	Fires only natural gas.	Fires only natural gas
05	20	This is a boiler which is fired with many different types of fuel.	Scrubber parameters - no submittal of records required.
06	20	Recovery boiler. The highest allowable under the NSPS is 35%. The boiler is limited to 20% because of Department regulations.	CEMS - submittals in accordance with CEM standards
08	20	Smelt tank with 18 lb/hr of particulate matter emissions.	Scrubber parameters - Submittal of records as required by 63 Subpart MM
09	20	This is a lime kiln which has particulate matter emissions from fuel combustion as well as from	Scrubber parameters - Submittal of records as required by 63 Subpart MM

SN	Opacity %	Justification	Compliance Mechanism
		proper operation of the kiln.	
11	5	Natural gas fired boiler. Department study has shown that natural gas fired sources should not have any visible emissions when operated properly.	Natural gas as the only fuel used to fire this source.
12	5	Natural gas fired boiler. Department study has shown that natural gas fired sources should not have any visible emissions when operated properly.	Natural gas as the only fuel used to fire this source.
14	20	Recovery boiler. The highest allowable under the NSPS is 35%. The boiler is limited to 20% because of Department regulations.	COMS - submittals in accordance with CEM standards
15	20	Smelt tank with PM emissions of 18.7 lb/hr.	Scrubber parameters - Submittal of records as required by 63 Subpart MM
43	5	Tub grinder fired with diesel fuel.	Weekly observations - no submittal of records required
RICE	20 - Diesel 5 - Propane	Regulation 19.501	Daily for events lasting more than 24 hours

17. DELETED CONDITIONS:

Former SC	Justification for removal
25, 26, 27, 40, 41, 83a.a, 83a.b, 83a.d, 83a.e, 103, 104, 105, 106, 134b.a, 134b.b, 134b.d, 134b.e,	Fuel oil combustion removed from permit for boilers and lime kilns.
39a	Boiler has limit of natural gas only.
42, 42a	Requirement to operate WESP was fuels other than natural gas. The boiler is limited to natural gas.

18. GROUP A INSIGNIFICANT ACTIVITIES:

Source Name	Group A Category	Emissions (tpy)					
		PM/PM ₁₀	SO ₂	VOC	CO	NO _x	HAPs

							Single	Total
250 gal lubricating/hydraulic oil tanks (5,000 gal site wide)	A2			5E-05				
Used Oil Storage Tank (10,000 gal)	A3			8E-05				
Woodyard Diesel Tank (9,425 gal)	A3			0.014				
Woodyard Hydraulic Oil Tank (9,425 gal)	A3			9E-05				
Medium Diesel Tanks (<10,000 gal site wide)	A3			0.014				
Small Diesel Tanks (<1,000 gal each)	A3			0.01				
Paper Machine Portable Tote Bins	A3			0.01				
Caustic Storage Tanks	A4							
Laboratory Hoods	A5			0.21				0.21
Mill Services (storeroom) gasoline tank (130,000 gal)	A13			1.65				
Brock Services Gasoline Tank (552 gal)	A13			0.27				
Coal Pile	A13	0.03						
Turpentine Storage Tank (18,612 gal)	A13			0.546				
Cooling Tower ^a #1	A13	0.05						
Cooling Tower ^a #2	A13	0.02						
Cooling Tower ^a #3	A13	0.03						
Cooling Tower ^a #4	A13	0.05						
Cooling Tower ^a #5	A13	0.11						
Cooling Tower ^a #6	A13	0.04						
Cooling Tower ^a #7	A13	0.005						
Cooling Tower ^a #8	A13	0.060						
Cooling Tower ^a #9	A13	0.008						
Cooling Tower ^a #10	A13	0.053						
Cooling Tower ^a #11	A13	0.025						
Cooling Tower ^a #12	A13	0.454						
Cooling Tower ^a #13	A13	0.329						

Source Name	Group A Category	Emissions (tpy)						
		PM/PM ₁₀	SO ₂	VOC	CO	NO _x	HAPs	
							Single	Total
Cooling Tower ^a #14	A13	0.350						
Cooling Tower ^a #15	A13	0.387						
Converting Area	A13			0.26				0.26

^a #1 #3 EVAP, #2 Water Plant North Tower, #3 Water Plant South Tower, #4 R-8 Tower ERCO, #5 SVP Tower, #6 No. 62 Tower, #7 BAC 3642 Tower 61 PM Converting, #8 61 PM Ground, #9 63 PM, #10 Pulp Mill MCC, #11 Admin, #12 No. 4 Turbine Generator Tower, #13 No. 64 Tower, #14 Vacuum Pump Tower, and #15 ECF Conversion Tower

19. VOIDED, SUPERSEDED, OR SUBSUMED PERMITS:

List all active permits voided/superseded/subsumed by the issuance of this permit.

Permit #
0287-AOP-R18

APPENDIX A – EMISSION CHANGES AND FEE CALCULATION

Fee Calculation for Major Source

Revised 03-11-16

Facility Name: Domtar A.W. LLC
 Permit Number: 287-AOP-R19
 AFIN: 41-00002

\$/ton factor	23.93	Annual Chargeable Emissions (tpy)	16011.46
Permit Type	AA	Permit Fee \$	0

Minor Modification Fee \$	500
Minimum Modification Fee \$	1000
Renewal with Minor Modification \$	500

Check if Facility Holds an Active Minor Source or Minor Source General Permit

If Hold Active Permit, Amt of Last Annual Air Permit Invoice \$ 0

Total Permit Fee Chargeable Emissions (tpy) 0

Initial Title V Permit Fee Chargeable Emissions (tpy)

HAPs not included in VOC or PM:

Chlorine, Hydrazine, HCl, HF, Methyl Chloroform, Methylene Chloride, Phosphine, Tetrachloroethylene, Titanium Tetrachloride

Air Contaminants:

All air contaminants are chargeable unless they are included in other totals (e.g., H2SO4 in condensible PM, H2S in TRS, etc.)

Pollutant (tpy)	Check if Chargeable Emission	Old Permit	New Permit	Change in Emissions	Permit Fee Chargeable Emissions	Annual Chargeable Emissions
PM		2456.9	2456.9	0	0	2456.9
PM ₁₀		1885.4	1885.4	0		
PM _{2.5}		0	0	0		
SO ₂		7889.7	7889.7	0	0	4000
VOC		5682	5682	0	0	4000
CO		12299.8	12299.8	0		
NO _x		7610	7610	0	0	4000
Lead	<input type="checkbox"/>	0.83	0.83	0		

Pollutant (tpy)	Check if Chargeable Emission	Old Permit	New Permit	Change in Emissions	Permit Fee Chargeable Emissions	Annual Chargeable Emissions
1,1,1- Trichloroethane	<input checked="" type="checkbox"/>	0.03	0.03	0	0	0.03
Acetone	<input checked="" type="checkbox"/>	73.2	73.2	0	0	73.2
Ammonia	<input checked="" type="checkbox"/>	493.24	493.24	0	0	493.24
Chlorine	<input checked="" type="checkbox"/>	27.59	27.59	0	0	27.59
Chlorine Diozide	<input checked="" type="checkbox"/>	30.66	30.66	0	0	30.66
Dichloromethane	<input checked="" type="checkbox"/>	0.56	0.56	0	0	0.56
H2S	<input checked="" type="checkbox"/>	0.55	0.55	0	0	0.55
HCl	<input checked="" type="checkbox"/>	634.55	634.55	0	0	634.55
Perchloroethylene	<input checked="" type="checkbox"/>	0.28	0.28	0	0	0.28
Sulfuric Acid	<input checked="" type="checkbox"/>	32.5	32.5	0	0	32.5
TRS	<input checked="" type="checkbox"/>	261.4	261.4	0	0	261.4