

## RESPONSE TO COMMENTS

### Entergy Arkansas, Inc. – Independence DRAFT PERMIT #0449-AOP-R7 AFIN: 32-00042

On July 9, 2010, the Director of the Arkansas Department of Environmental Quality gave notice of a draft permitting decision for the above referenced facility. During the comment period, written comments on the draft permitting decision were submitted by the facility and the public. The Department's response to these issues follows.

*Note: The following page numbers and condition numbers refer to the draft permit. These references may have changed in the final permit based on changes made during the comment period.*

#### **Comment I:**

##### Relevant Background Information

The Independence Station was required to obtain a prevention of significant deterioration (PSD) permit prior to construction of the facility. EPA issued a PSD permit for Independence in 1978. As discussed in the draft Title V permit for Independence Station, the PSD permit issued by EPA included these terms and limitations:

- a) A limit on the maximum SO<sub>2</sub> emission rate from the common stack of 15,510 lb/hr (or 7,755 lb/hr per unit).
- b) A limit on the maximum TSP emission rate of 611 lb/hr (or 305.5 lb/hr per unit).
- c) Use of coal with a heat content of 8,700 Btu/lb, a sulfur content of no more than 0.45% and an ash content of no more than 8%.
- d) The permit must require compliance with 40 C.F.R. Part 60, Subpart Y.

#### **Response to Comment I:**

These requirements and limits were in a permit issued by the EPA in 1978 for the construction of the Independence Steam plant.

#### **Comment II. A.:**

ADEQ unlawfully attempted to change PSD requirements applicable to Independence under the 1978 PSD permit issued by EPA without undergoing a PSD permit modification and complying with PSD permitting requirements.

Although ADEQ has attempted to modify some of the terms of the PSD permit in subsequent permit actions, EPA's 1978 PSD permit remains in effect unless rescinded or revoked. 40 C.F.R. §§ 52.21(q), (u), (w), 124.5(g)(2) ("PSD permits may be terminated only by rescission under

§52.21(w) or by automatic expiration under §52.21(r).”). There is no record that the EPA-issued PSD permit for Independence was rescinded.

The 1978 PSD permit’s terms must be included in the Title V permit for Independence Station. Title V permits must include all requirements applicable to a facility, and this includes all requirements of any applicable preconstruction permit. 40 C.F.R. § 70.2; APCEC Reg. 26, Chapter 2. Those terms include a limit on the maximum SO<sub>2</sub> emission rate from the common stack of 15,510 lb/hr (or 7,755 lb/hr per unit) and a limit on the maximum TSP emission rate of 611 lb/hr (or 305.5 lb/hr per unit).

In addition, the Title V permit must also include the conditions from the EPA-issued PSD permit requiring use of coal with a heat content of 8,700 Btu/lb, a sulfur content of no more than 0.45% and an ash content of no more than 8%. Last, the permit must require compliance with 40 C.F.R. Part 60, Subpart Y.

Permit 449-AR-1

Assuming operation at these hourly emission rates for the allowable hours of operation specified in Permit 449-AR-1 of 7,800 hours a year, these changes in permitted emission limits allowed for an increase in potential emissions of 2,621 tons per year (tpy) of SO<sub>2</sub> and 332 tpy of TSP. These increases in potential emissions are well in excess of the PSD significance levels of 40 tpy and 25 tpy, respectively.

ADEQ improperly authorized these emission increases. A permitting authority cannot change emission limitations and requirements of a PSD permit, especially not to increase emissions, without issuing a PSD permit modification that complies with all of the PSD permitting requirements. As part of the PSD permit modification when PSD limits are being increased, the permitting authority is required to evaluate best available control technology (BACT) based on currently available technologies and techniques... such a re-evaluation of BACT for SO<sub>2</sub> in 1991 would have required for installation of scrubbers for SO<sub>2</sub> control.

### **Response to Comment II. A.:**

The Arkansas state implementation plan (SIP) to incorporate the federal PSD regulations was originally approved by EPA on February 16, 1982. See 47 Fed. Reg. 2112 (January 14, 1982). That approval gave Arkansas the authority to carry out all the aspects of PSD reviewing and permitting. Arkansas acted within its authority and with the EPA’s approval when it issued permit 449-AR-1 for Independence Station in 1991. This permit unequivocally states in Specific Condition 6 that “all previous permits are hereby rescinded.” Thus, EPA’s PSD permit, PSD-AR-48, was superseded by permit 449-AR-1. Permit 449-AR-1 modified SO<sub>2</sub> and TSP emission rates. SO<sub>2</sub> increased from 15,510 lb/hr to 16,182 lb/hr (8,091 lb/hr for each unit) and TSP increased from 611 lb/hr to 696 lb/hr (348 lb/hr each unit.) This change was made twenty years ago, when ADEQ issued its permit to Independence Station in 1991.

The Arkansas Pollution Control and Ecology Pollution, Regulation 8, Administrative Procedures, provides both a mechanism and time frame for appealing the permit issued in 1991.

In 1991, the controlling section for appealing a draft permitting decision was section 2.7 of Regulation 8. Regulation 8 was then renumbered and thereafter, section 8.208 governed permitting decisions made by ADEQ.

Both provisions of Regulation 8, the former and the latter, provide the right to challenge a draft permitting decision to those persons who submit written comments, data, views, or arguments on the draft permitting decision. The procedures in both sections are almost identical. Each provided for a public comment period and a process for an appeal. In the current version of Regulation 8, the public comment period commence on the date the notice of the draft permitting decision is published and closes on the thirtieth (30<sup>th</sup>) calendar day after the publication of the notice, unless the period is extended by the Director.

An appeal under this regulatory scheme must be made by filing a Request for Hearing with the Commission Secretary within the thirty (30) days of the date of issuance of the Director's final permitting decision.

Public notice was issued regarding ADEQ's approval of permit 449-AR-1 on March 4, 1991. The Sierra Club was required to submit comments if it desired to appeal ADEQ's decision. The Sierra Club did not submit comments in response to the public notice. The Sierra's Club objection to the Title V permit renewal on the basis of the 1991 modification is untimely and may not be raised in this proceeding. *See* Acts of Arkansas 1949, No. 472 § 5 (as added by Acts of Arkansas 1965, No. 183, § 7) stating that ADEQ's final decision may not be questioned in another action or proceeding.

Numerous permits have been issued for Independence Steam Electric Station since 1991. Permit 449-AOP-RO was the first operating air permit that was issued under Regulation 26 (Title V). Since then, Permit 449-AOP-R1 was issued in the year 2000, and Permit 449-AOP-R2 was issued in 2001. The Sierra Club did not challenge these permitting decisions.

Subsequent permitting decisions, Permit 449-AO-R3 and Permit 449-AOP -R4, made after ADEQ had implemented its Title V regulations, gave EPA an opportunity to review and comments on these decisions. This gave the Sierra Club yet another opportunity to challenge the limits in the Independence Station permit. Section 505(b)(2) of the Clean Air Act provides:

If the Administrator does not object in writing to the issuance of a permit pursuant to paragraph(1) [of this section] any person may petition the Administrator within 60 days after the expiration of the 45-day review period specified in paragraph (1) to take such action.

42 U.S.C. § 7661d.

The Sierra Club did not petition the EPA to object to these subsequent permitting decisions.

The Sierra Club's claims of PSD violations and that ADEQ erred in not re-evaluating BACT in prior permitting decisions, are untimely under state law.

For the above stated reasons, the SO<sub>2</sub> and TSP (PM<sub>10</sub>) lb/hr emission rates, in the permit issued by the EPA will not be re-instated.

In regards to complying with 40 C.F.R. Part 60, Subpart Y, the draft permit already contains all the necessary requirements. These conditions were omitted in permit 0449-AR-1, but re-instated in this draft permit 0449-AOP-R7. No updates will be made to the final permit.

**Comment II. B.:**

Permits 449-AOP-R3 and 449-AOP-R4

Clearly, subbituminous coal from northeastern Wyoming was the coal planned to be used at the Independence Station, and EPA relied on those plans in evaluating whether the units met BACT for SO<sub>2</sub> and TSP and in evaluating ambient air impacts. The PSD permit terms are based on the information provided in the PSD permit application and all other submittals to EPA, and the PSD permit requires compliance with those submissions.

The EAB has interpreted BACT requirements as including the control technology upon which BACT is based. In the case of the Independence units, the SO<sub>2</sub> BACT determination was clearly based on the use of low sulfur subbituminous coal from the Powder River Basin in northeastern Wyoming, with a sulfur content no higher than 0.45%. The BACT determination for particulate matter was also based on use of coal with an ash content no higher than 8%. ADEQ cannot modify these BACT requirements without issuing a new PSD permit.

Those conditions to be included are a requirement to burn only subbituminous coal from northeastern Wyoming, a limit on sulfur content of the coal of no more than 0.45%, a limit on ash content of coal of no more than 8%, and use of coal with heat value of 8700 Btu/lb. Those conditions that must be deleted include all references allowing the burning of bituminous coal and Condition 30 (allowing for higher ash and sulfur content).

**Response to Comment II. B.:**

See response to Comment II A. above.

The facility was engineered and built for the use of subbituminous coal. As such it is a subbituminous fired coal plant; there is no restriction on the region that the facility may obtain its coal.

Permit 449-AOP-RO, the original Title V permit for Independence Station, contained no sulfur or ash limitations. This permit was renewed in 2005 as 449-AOP-R3 again without sulfur or ash limitations. To protect against PM increases, ADEQ added Condition 30 in permit 449-AOP-R4 which limited the fuel sulfur content to 0.66%, unless the PM compliance in that condition could be met. As noted in Response to Comment II. A., the Sierra Club did not raise any objections to these prior permitting decisions and is barred from doing so now.

Further, the CAA requires permitting authorities to regulate the release of air pollutants by establishing emissions limitations. It is those limitations that are enforceable. A permit must be a stand-alone document that fully sets out the applicable enforceable conditions and the means to measure compliance with those conditions. Thus, to be enforceable, an emission limitation must have two components: and numerical limit on emissions, and a method of measuring that limitation. *New Source Review Workshop Manual* at H.5-H.6 (Draft Oct. 1990). However, a numerical limit standing alone without a method of measuring compliance cannot be an enforceable condition. To be an enforceable condition, it should be written as clearly and directly as possible and state precisely what is expected of the source, should contain as few exceptions or conditional statements as possible, and should state *what* is to be measured, recorded, or reported; *what* the emission standards are, and *how* these standards are to be met. *Effective Permit Writing, Student Guidebook*, EPA-450/September 1986, Air Pollution Training Institute.

To predict the future impact of emissions from a source, a permit applicant must make a number of assumptions about unit operation. The permit issuer then must decide which of those operating parameters, assumed in the modeling, should be enforced through the emission limitations established in the permit. Those parameters that are part of the input, but which are not written in terms of enforceable conditions, are the descriptive limits.

In regards to the coal, the coal heat content, sulfur content, and ash content limits are descriptive limits in the PSD permit and will not be added back into the permit.

In regards to Specific Condition 30 of the draft permit, this condition is a method used to determine the amount of condensable particulate matter emitted from the main stack. No PSD limit has ever been established for condensable particulate matter at the facility, therefore this limit shall remain.

**Comment III:**

The permit modification authorizing the burning of bituminous coal should have been reviewed for applicability under PSD permitting requirements as a Major Modification and under the New Source Performance Standard Subpart Da Requirements.

**Response to Comment III:**

The operator of Independence Station has not faced the coal delivery problems that lead to the request to use bituminous coal and has requested to remove the bituminous fuel option from the EAI ISES Title V renewal permit application.

The bituminous coal burning option has been removed.

**Comment IV:**

The replacement of the economizers at Independence Units 1 and 2 should have been reviewed for PSD applicability as Major Modifications, and available information indicates that the Unit 2 economizer replacement should have triggered PSD applicability as Major Modification.

**Response to Comment IV:**

The commenter provides no evidence as to what “available information” was reviewed and how such information “indicated that there was, in fact, a strong possibility that a significant emissions increase would occur”. The statement, “it appears that the Unit 2 economizer replacement was definitely a major modification that triggered PSD” is in no way supported with any information.

There was no PSD modification requiring review. Statements about BACT and CO<sub>2</sub> are irrelevant.

**Comment V:**

EAI has replaced other major components of the Independence Units over the last few years that should have been evaluated for PSD applicability, specifically:

Unit 1:

- Replacement of the reheater between approximately March 2006 and March 2008.
- Replacement of the low temperature superheater between approximately March 2007 and March 2008.
- Replacement of the center water wall tubes in approximately March 2006.
- Replacement of worn high pressure turbine nozzle blocks in approximately March 2008.

Unit 2:

- A high pressure turbine upgrade in approximately November 2004.
- Replacement of center water wall in furnace in approximately November 2007.

**Response to Comment V:**

Entergy submitted an emission analysis that there would be no increase in emissions as a result of the high pressure turbine project. The high pressure turbine project was treated as a non-routine physical change, which the Department approved on May 7, 2004. Entergy provided the Department with annual emissions reports for 3 years following the completion of the turbine project. On March 18, 2008, the Department approved Entergy’s request to suspend submission of annual emission reports.

All of the remaining replacements specifically stated involve the replacement of a portion of the tubing in the reheater, low temperature superheater, and center water wall sections of the boiler.

These activities are considered routine maintenance, and are specifically excluded from PSD regulations.

**Comment VI:**

Title V requires ADEQ to have included a compliance schedule in the draft operating permit for prior PSD violations at Independence.

**Response to Comment VI:**

There were no violations noted during the review of the Title V Renewal application or recent inspections of the facility. Therefore, ADEQ is not required to include a compliance schedule to bring the facility back into compliance in the draft (or final) Operating Permit.

**Comment VII:**

It appears that the allowable hourly SO<sub>2</sub> And PM<sub>10</sub> emission rates at the Independence Plant do not ensure protection of the PSD increments for SO<sub>2</sub> and PM<sub>10</sub>.

**Response to Comment VII:**

The commenter is improperly attempting to compare the NAAQS analysis to an Increment analysis. Increment consumption is only examined during a PSD review. There was no PSD modification with the Title V Renewal application. Therefore, increment modeling is not required. Additionally, the original increment analysis was performed and examined with the original PSD application.

**Comment VIII:**

EAI has failed to adequately demonstrate that the Independence Plant will operate in compliance with the National Ambient Air Quality Standards (NAAQS). Specifically modeling results were not provided for two standards, PM<sub>2.5</sub> and the 1-hr NO<sub>2</sub>.

**Response to Comment VIII:**

PM<sub>2.5</sub> NAAQS are not yet implemented by the state of Arkansas. The state has 3 years from the date of the rule to incorporate the provisions into its regulations. In the interim and in accordance with EPA policy, PM<sub>10</sub> remains the regulated pollutant.

1-hr NO<sub>2</sub> New Source Regulations NAAQS are not yet implemented by the state of Arkansas. The state has 3 years from the date of the rule to incorporate the provisions into its regulations.

**Comment IX:**

Page 7, Regulations Table – Please add the text below since SN-21 the Emergency Diesel Fire Pump will have requirements associated with this subpart beginning May 3, 2013.

40 CFR Part 63, Subpart ZZZZ – *National Emissions Standards for Hazardous Air Pollutants for Reciprocating Internal Combustion Engines (effective date May 3, 2013)*

**Response to Comment IX:**

The change was made.

**Comment X:**

Page 23, Specific Condition 8- Please revise as follows.

The permittee shall test SN-01 and SN-02 for CO while operating under Scenario I: Coal Firing. This testing shall be conducted within 180 days of permit issuance of permit 449-AOP-R3 (June 3, 2005) and every five years thereafter. These tests shall be performed using EPA Reference Method 10, and shall be conducted in accordance with Plantwide Condition #3. This testing shall be conducted while operating at 90% or greater capacity and consist of three, one hour test periods averaged to demonstrate compliance with Specific Condition # 7. [Regulation 19, §19.702 and 40 CFR Part 52, Subpart E]

**Response to Comment X:**

The change was made.

**Comment XI:**

Page 28, Specific Condition 29 - Please revise as follows.

The permittee shall test SN-01 and SN-02 for PM and PM<sub>10</sub> while operating under Scenario I: Coal Firing and while operating at 90% or greater capacity. Emission results shall be extrapolated to correlate with 100% of the permitted capacity to determine compliance. The PM test shall be performed using EPA Reference Methods 5 and 202. The PM<sub>10</sub> test shall be performed using EPA Reference Methods 201A and 202. These tests shall be conducted in accordance with Plantwide Condition # 3. This testing shall be conducted within 180 days of permit issuance of permit 449-AOP-R3 (June 3, 2005) and every five years thereafter. [Regulation 19, §19.702 and 40 CFR Part 52, Subpart E]

**Response to Comment XI:**

The change was made.

**Comment XII:**

Page 32, Specific Condition 37 – please make the following change to round up the H<sub>2</sub>SO<sub>4</sub> lb/hr emission limit.

37. The permittee shall not exceed the emission rates set forth in the following table when burning No. 2 fuel oil or Bio-diesel in the Auxiliary Boiler, SN-05. [Regulation 18, §18.801, and A.C.A. §8-4-203 as referenced by §8-4-304 and §8-4-311]

Source No.	Pollutant	lb/hr	tpy
SN-05	PM	4.5	19.4
	Arsenic	0.01	0.01
	Beryllium	0.01	0.01
	Cadmium	0.01	0.01
	Chromium	0.01	0.01
	Formaldehyde	0.07	0.29
	Manganese	0.01	0.01
	Mercury	0.01	0.01
	Nickel	0.01	0.01
	POM	0.01	0.02
	Selenium	0.01	0.02
	N <sub>2</sub> O	0.35	1.53
	H <sub>2</sub> SO <sub>4</sub>	1.60 1.62	7.10

**Response to Comment XII:**

The change was made.

**Comment XIII:**

Page 37, Specific Condition 56 – please make the change noted below. The paved and unpaved mileage submitted was for all ash truck hauling (bottom ash, fly ash, onsite and offsite sales). Additionally, 12,045 VMT was submitted for the unpaved portion.

56. The fly ash trucks ~~hauling ash for disposal in the on-site landfill~~ shall not exceed 61,320 vehicle miles traveled per consecutive twelve (12) month period on paved roads and ~~13,545~~ 12,045 vehicle miles traveled per consecutive twelve (12) month period on unpaved roads. [Regulation 19, §19.705, A.C.A. §8-4-203 as referenced by §8-4-304 and §8-4-311, and 40 CFR Part 70.6]

**Response to Comment XIII:**

The change was made.

**Comment XIV:**

Please add a new Specific Condition under SN-21 Emergency Diesel Fire Pump worded as follows:

The permittee shall comply with the following requirements for SN-21 Emergency Diesel Fire Pump beginning on May 3, 2013:

1. Minimize engine idle and limit startup to less than 30 minutes
2. Change oil and filter every 500 hours or annually, whichever comes first or use oil change analysis program to extend oil change frequencies per 40 CFR 63.6625(i).
3. Inspect air cleaner every 1000 hours or annually, whichever comes first
4. Inspect all hoses and belts every 500 hours or annually, whichever comes first
5. A Non-resettable hour meter must be installed
6. Non-emergency operation cannot exceed 50 hrs/yr
7. Maintenance checks/readiness testing cannot exceed 100 hrs/yr
8. The 50 hrs of non-emergency operation must count towards the 100 hrs of maintenance per/yr
9. Operate and maintain according to manufacturer's instructions or implement a maintenance plan
10. Maintain records to demonstrate compliance with the operating hour limitations listed above

**Response to Comment XIV:**

The emergency generator (SN-20) and the emergency diesel fire pump (SN-21) are both subject to 40 CFR Part 63, Subpart ZZZZ – *National Emissions Standards for Hazardous Air Pollutants for Reciprocating Internal Combustion Engines* with a compliance date of May 3, 2013. The applicable requirements have been added to the permit.

# ADEQ

ARKANSAS  
Department of Environmental Quality

April 22, 2011

Tracy Johnson  
Senior Environmentalist Specialist  
Entergy Arkansas, Inc. - Independence Plant  
PO Box 551  
Little Rock, AR 72203


Dear Mr. Johnson:

The enclosed Permit No. 0449-AOP-R7 is your authority to construct, operate, and maintain the equipment and/or control apparatus as set forth in your application initially received on 11/23/2009.

After considering the facts and requirements of A.C.A. §8-4-101 et seq., and implementing regulations, I have determined that Permit No. 0449-AOP-R7 for the construction, operation and maintenance of an air pollution control system for Entergy Arkansas, Inc. - Independence Plant to be issued and effective on the date specified in the permit, unless a Commission review has been properly requested under Arkansas Department of Pollution Control & Ecology Commission's Administrative Procedures, Regulation 8, within thirty (30) days after service of this decision.

The applicant or permittee and any other person submitting public comments on the record may request an adjudicatory hearing and Commission review of the final permitting decisions as provided under Chapter Six of Regulation No. 8, Administrative Procedures, Arkansas Pollution Control and Ecology Commission. Such a request shall be in the form and manner required by Regulation 8.603, including filing a written Request for Hearing with the APC&E Commission Secretary at 101 E. Capitol Ave., Suite 205, Little Rock, Arkansas 72201. If you have any questions about filing the request, please call the Commission at 501-682-7890.

Sincerely,



Mike Bates  
Chief, Air Division

# ADEQ OPERATING AIR PERMIT

Pursuant to the Regulations of the Arkansas Operating Air Permit Program, Regulation 26:

Permit No. : 0449-AOP-R7

IS ISSUED TO:

Entergy Arkansas, Inc. - Independence Plant  
555 Point Ferry Road  
Newark, AR 72562  
Independence County  
AFIN: 32-00042

THIS PERMIT AUTHORIZES THE ABOVE REFERENCED PERMITTEE TO INSTALL, OPERATE, AND MAINTAIN THE EQUIPMENT AND EMISSION UNITS DESCRIBED IN THE PERMIT APPLICATION AND ON THE FOLLOWING PAGES. THIS PERMIT IS VALID BETWEEN:


April 22, 2011

AND

April 21, 2016

THE PERMITTEE IS SUBJECT TO ALL LIMITS AND CONDITIONS CONTAINED HEREIN.

Signed:

  
Mike Bates  
Chief, Air Division

April 22, 2011  
Date

Table of Contents

SECTION I: FACILITY INFORMATION ..... 4

SECTION II: INTRODUCTION..... 5

    Summary of Permit Activity ..... 5

    Process Description..... 5

    Regulations ..... 7

    Emission Summary ..... 7

SECTION III: PERMIT HISTORY..... 15

SECTION IV: SPECIFIC CONDITIONS..... 18

    SN-01, SN-02, and SN-05 ..... 18

    SN-03, SN-06A, SN-06B, and SN-06C..... 33

    SN-04 ..... 39

    SN-07 ..... 41

    SN-12 and SN-13 ..... 42

    SN-16 and SN-17 ..... 44

    SN-18 ..... 46

    SN-19 ..... 48

    SN-20 ..... 49

    SN-21 ..... 52

SECTION V: COMPLIANCE PLAN AND SCHEDULE..... 58

SECTION VI: PLANTWIDE CONDITIONS..... 59

    Acid Rain (Title IV)..... 60

    Clean Air Interstate Rule (CAIR) ..... 60

    Title VI Provisions ..... 60

    Permit Shield..... 61

SECTION VII: INSIGNIFICANT ACTIVITIES..... 64

SECTION VIII: GENERAL PROVISIONS ..... 65

Appendix A – 40 CFR Part 60, Subpart D

Appendix B – Continuous Emission Monitoring Systems Conditions, Revised August 2004

Appendix C – Compliance Plan for SN-03, Maintenance Plan for SN-04, and Design  
 Specifications for SN-16 and SN-17

Appendix D – Acid Rain Permit Application

Appendix E – Clean Air Interstate Rule (CAIR) Permit Application

Appendix F – 40 CFR Part 60, Subpart Y

Appendix G – 40 CFR Part 63, Subpart ZZZZ

Entergy Arkansas, Inc. - Independence Plant  
Permit #: 0449-AOP-R7  
AFIN: 32-00042

List of Acronyms and Abbreviations

A.C.A.	Arkansas Code Annotated
AFIN	ADEQ Facility Identification Number
CFR	Code of Federal Regulations
CO	Carbon Monoxide
HAP	Hazardous Air Pollutant
lb/hr	Pound Per Hour
MVAC	Motor Vehicle Air Conditioner
No.	Number
NO <sub>x</sub>	Nitrogen Oxide
PM	Particulate Matter
PM <sub>10</sub>	Particulate Matter Smaller Than Ten Microns
SNAP	Significant New Alternatives Program (SNAP)
SO <sub>2</sub>	Sulfur Dioxide
SSM	Startup, Shutdown, and Malfunction Plan
Tpy	Tons Per Year
UTM	Universal Transverse Mercator
VOC	Volatile Organic Compound

Entergy Arkansas, Inc. - Independence Plant  
Permit #: 0449-AOP-R7  
AFIN: 32-00042

SECTION I: FACILITY INFORMATION

PERMITTEE: Entergy Arkansas, Inc. - Independence Plant

AFIN: 32-00042

PERMIT NUMBER: 0449-AOP-R7

FACILITY ADDRESS: 555 Point Ferry Road  
Newark, AR 72562

MAILING ADDRESS: PO Box 551  
Little Rock, AR 72203

COUNTY: Independence County

CONTACT NAME: Tracy Johnson

CONTACT POSITION: Senior Environmentalist Specialist

TELEPHONE NUMBER: 501-377-4033

REVIEWING ENGINEER: Joseph Hurt

UTM North South (Y): Zone 15: 3949363.54 m

UTM East West (X): Zone 15: 643704.53 m

Entergy Arkansas, Inc. - Independence Plant  
Permit #: 0449-AOP-R7  
AFIN: 32-00042

## SECTION II: INTRODUCTION

### Summary of Permit Activity

Entergy Arkansas, Inc. - Independence located in Independence, Arkansas is a two-unit electric generating station which generates electric energy for sale. This is the second Title V Renewal for the facility. With this modification, Entergy is moving the emergency diesel engine and the emergency diesel fire pump out of the Insignificant Activities list and listing them as permitted sources.

With this renewal, the total permitted emission changes include increases of 40.3 tpy of PM<sub>10</sub>, 5.7 tpy of SO<sub>2</sub>, 4.2 tpy of VOC, 11.5 tpy of CO, and 46.7 tpy of NO<sub>x</sub>.

### Process Description

Independence Steam Electric Station typically operates as a base-load facility. It has 2 identical coal-fired units (Units 1 and 2) with a total nominal capacity of 1,700 megawatts (MW). Electricity is produced using coal as the primary fuel and No. 2 fuel oil or bio-diesel as the start-up fuel in both boilers. The boilers produce steam which is used to drive turbines that turn the electric generators.

Operating Scenario 1 (AOS1) occurs when the boilers are firing coal, and Operating Scenario 2 (AOS2) occurs when the boilers are firing No. 2 fuel oil or bio-diesel.

Exhaust gases from both units are expelled through two 1,000-foot stacks within a common outer chimney shell. Waste heat dissipation is through two hyperbolic natural draft cooling towers (SN-16 and SN-17) which obtain makeup water from the White River and from the capture of site drainage. Unit 1 exhausts out of SN-01 and Unit 2 Boiler exhausts out of SN-02.

During both operating scenarios, emissions from the boilers include sulfur dioxide (SO<sub>2</sub>), nitrogen oxides (NO<sub>x</sub>), and particulate matter (PM). The emission levels for each of these are governed by federal and state emission and ambient air regulations. In-stack monitoring is designed to meet the requirements of Acid Rain (40 Code of Federal Regulation [CFR] 75) and New Source Performance Standards (NSPS) (40 CFR 60). Oxides of nitrogen (NO<sub>x</sub>) must meet NSPS and acid rain requirements. Additionally, emissions of SO<sub>2</sub> and PM are subject to controls and emission limits under the Prevention of Significant Deterioration (PSD) program under 40 CFR Part 52. These emissions are controlled by sulfur limitations in the fuel and an electrostatic precipitator, respectively.

In addition to the main boilers, an Auxiliary Boiler provides steam for unit start-up activities. The Auxiliary Boiler combusts No. 2 fuel oil or bio-diesel and exhausts out of SN-05.

Other major plant components include facilities for storage and handling of coal and disposal of ash, a switch-yard, sand blasting, water treatment, surge and other ponds, intake and discharge structures, and fuel storage tanks for gasoline, No. 2 fuel oil and bio-diesel.

Entergy Arkansas, Inc. - Independence Plant  
Permit #: 0449-AOP-R7  
AFIN: 32-00042

Other emissions-producing activities at the Independence Plant are all in support of the primary process at the facility, which is the production of electricity as described above. These other emissions-producing activities are necessary to maintain the power plant equipment and systems. These activities include, but are not limited to, painting, welding, boiler cleaning and the use of temporary combustion devices to drive equipment during outages. Many of these maintenance activities are conducted by outside contractors using equipment owned by the contractors. Furthermore, many of these maintenance activities are classified as insignificant activities and are listed in Section VII of this permit.

#### *Primary Operating Scenario*

In the primary operating scenario (AOS1), coal is combusted in the main boilers.

During AOS1, particulates are controlled to meet NSPS and PSD requirements by use of cold side electrostatic precipitators and sulfur oxide emissions meet NSPS, PSD and acid rain requirements by the combustion of low sulfur coal.

Sub-bituminous coal is delivered by rail. Each rail car is equipped with rotary couplings which enable the rotary car dumper (SN-03) to grasp one car at a time and empty it without removing the car from the train. The rotary car dumper is capable of emptying approximately 30 cars per hour. Transfer conveyors move the coal to a transfer tower.

From here the coal can be conveyed to three different areas including the plant to be pulverized and burned, the stacker/reclaimer, or the storage area. The stacker/reclaimer has the capability of either stacking coal out or reclaiming the coal from the storage area. The storage area is used for long term storage of coal and is managed by the use of bulldozers.

There are numerous transfer points, conveyors, towers, and connections associated with coal and its handling. Dust suppression is accomplished with chemical foam and water sprays.

#### *Alternative Operating Scenario*

In the alternative operating scenario (AOS2), No. 2 fuel oil or bio-diesel is combusted in the main boilers and the electrostatic precipitators are not employed.

Entergy Arkansas, Inc. - Independence Plant  
 Permit #: 0449-AOP-R7  
 AFIN: 32-00042

### Regulations

The following table contains the regulations applicable to this permit.

Regulations
Arkansas Air Pollution Control Code, Regulation 18, effective January 25, 2009
Regulations of the Arkansas Plan of Implementation for Air Pollution Control, Regulation 19, effective July 18, 2009
Regulations of the Arkansas Operating Air Permit Program, Regulation 26, effective January 25, 2009
40 CFR Part 60, Subpart D – <i>Standards of Performance for Fossil-Fuel-Fired Steam Generators for Which Construction is Commenced After August 17, 1971</i>
40 CFR Part 60, Subpart Y – <i>Standards of Performance for Coal Preparation Plants</i>
40 CFR Part 61, Subpart M – <i>National Emissions Standard for Asbestos</i>
40 CFR Part 63, Subpart ZZZZ – <i>National Emissions Standards for Hazardous Air Pollutants for Reciprocating Internal Combustion Engines (effective date May 3, 2013)</i>
40 CFR Part 72, Subpart A-D – <i>Permits Regulation (Acid Rain)</i>
40 CFR Part 73, Subpart B – <i>Sulfur Dioxide Allowance System</i>
40 CFR Part 75 – <i>Continuous Emission Monitoring</i>
40 CFR Part 76 – <i>Acid Rain Nitrogen Oxide Emission Reduction Program</i>
40 CFR Part 77 – <i>Excess Emissions</i>
40 CFR 52.21 – <i>Prevention of Significant Deterioration of Air Quality (PSD)</i>
40 CFR Part 64 – <i>Compliance Assurance Monitoring</i>
40 CFR Part 82 – <i>Protection of Stratospheric Ozone</i>
40 CFR Part 96 – <i>CAIR NO<sub>x</sub> Ozone Season Trading Program</i>

### Emission Summary

The following table is a summary of emissions from the facility. This table, in itself, is not an enforceable condition of the permit.

EMISSION SUMMARY				
Source Number	Description	Pollutant	Emission Rates	
			lb/hr	tpy
Total Allowable Emissions		PM	1,535.9	6,328.0
		PM <sub>10</sub>	1,392.7	6,005.8
		SO <sub>2</sub>	16,292.2	71,343.7

Entergy Arkansas, Inc. - Independence Plant  
 Permit #: 0449-AOP-R7  
 AFIN: 32-00042

EMISSION SUMMARY				
Source Number	Description	Pollutant	Emission Rates	
			lb/hr	tpy
		VOC	105.4	327.9
		CO	6,480.4	9,478.5
		NO <sub>x</sub>	12,250.6	53,536.0
		Lead*	0.7	2.1
	HAPs	Acenaphthene*	0.04	0.04
		Acenaphthylene*	0.04	0.04
		Acetaldehyde*	0.62	2.66
		Acrolein*	0.34	1.36
		Anthracene*	0.04	0.04
		Arsenic*	0.45	1.91
		Benzene*	1.40	6.00
		Benzyl Chloride*	0.74	3.22
		Beryllium*	0.07	0.25
		Cadmium*	0.07	0.25
		Carbon Disulfide*	0.14	0.60
		2-Chloroacetophenone*	0.02	0.04
		Chloroform*	0.08	0.28
		Chromium*	0.29	1.21
		Chromium VI*	0.10	0.38
		Cobalt*	0.12	0.46
		Cyanide*	2.64	11.50
		Dimethyl Sulfate*	0.06	0.24
		Ethylene Dichloride*	0.06	0.20
		Fluoranthene*	0.04	0.04
		Fluorene*	0.04	0.04
		Formaldehyde*	0.81	3.39
		Hydrogen Chloride	1260.00	5518.80
		Hydrogen Fluoride	157.50	689.86
		Isophorone*	0.62	2.68
		Manganese*	0.53	2.27
		Mercury*	0.11	0.41
		Methyl Chloride	0.56	2.44
		Methyl Hydrazine*	0.18	0.80
		Methylene Chloride*	0.32	1.34
		Nickel*	0.31	1.31
		Phenanthrene*	0.04	0.04
		Phenol*	0.02	0.08
	POM*	0.07	0.24	
	Propionaldehyde*	0.40	1.76	
	Pyrene*	0.04	0.04	

Entergy Arkansas, Inc. - Independence Plant  
 Permit #: 0449-AOP-R7  
 AFIN: 32-00042

EMISSION SUMMARY				
Source Number	Description	Pollutant	Emission Rates	
			lb/hr	tpy
		Selenium*	1.39	6.00
		Styrene*	0.04	0.12
		Toluene*	0.28	1.14
		2,3,7,8-TCDD*	0.02	0.02
	Air Contaminants **	N <sub>2</sub> O**	84.35	369.45
		H <sub>2</sub> SO <sub>4</sub> **	25.02	109.64
SN-01 (C1)	Unit 1 Boiler – Coal Fired	PM	662.0	2,899.6
		PM <sub>10</sub>	662.0	2,899.6
		SO <sub>2</sub>	8,091.0	35,438.6
		VOC	35.0	153.3
		CO	3,232.0	4,718.8
		NO <sub>x</sub>	6,090.0	26,674.2
		Lead*	0.3	1.0
		Acenaphthene*	0.01	0.01
		Acenaphthylene*	0.01	0.01
		Acetaldehyde*	0.30	1.32
		Acrolein*	0.16	0.67
		Anthracene*	0.01	0.01
		Arsenic*	0.22	0.95
		Benzene*	0.69	2.99
		Benzyl Chloride*	0.37	1.61
		Beryllium*	0.02	0.05
		Cadmium*	0.03	0.12
		Carbon Disulfide*	0.07	0.30
		2-Chloroacetophenone*	0.01	0.02
		Chloroform*	0.04	0.14
		Chromium*	0.14	0.60
		Chromium VI*	0.05	0.19
		Cobalt*	0.06	0.23
		Cyanide*	1.32	5.75
		Dimethyl Sulfate*	0.03	0.12
		Ethylene Dichloride*	0.03	0.10
		Fluoranthene*	0.01	0.01
		Fluorene*	0.01	0.01
		Formaldehyde*	0.13	0.56
		Hydrogen Chloride	630.00	2,759.40
		Hydrogen Fluoride	78.75	344.93
Isophorone*	0.31	1.34		
Manganese*	0.26	1.13		

EMISSION SUMMARY						
Source Number	Description	Pollutant	Emission Rates			
			lb/hr	tpy		
		Mercury*	0.05	0.20		
		Methyl Chloride	0.28	1.22		
		Methyl Hydrazine*	0.09	0.40		
		Methylene Chloride*	0.16	0.67		
		Nickel*	0.15	0.65		
		Phenanthrene*	0.01	0.01		
		Phenol*	0.01	0.04		
		POM*	0.03	0.10		
		Propionaldehyde*	0.20	0.88		
		Pyrene*	0.01	0.01		
		Selenium*	0.69	2.99		
		Styrene*	0.02	0.06		
		Toluene*	0.13	0.56		
		2,3,7,8-TCDD*	0.01	0.01		
		N <sub>2</sub> O**	42.00	183.96		
		H <sub>2</sub> SO <sub>4</sub> **	11.71	51.27		
		SN-02 (C2)	Unit 2 Boiler – Coal Fired	PM	662.0	2,899.6
				PM <sub>10</sub>	662.0	2,899.6
SO <sub>2</sub>	8,091.0			35,438.6		
VOC	35.0			153.3		
CO	3,232.0			4,718.8		
NO <sub>x</sub>	6,090.0			26,674.2		
Lead*	0.3			1.0		
Acenaphthene*	0.01			0.01		
Acenaphthylene*	0.01			0.01		
Acetaldehyde*	0.30			1.32		
Acrolein*	0.16			0.67		
Anthracene*	0.01			0.01		
Arsenic*	0.22			0.95		
Benzene*	0.69			2.99		
Benzyl Chloride*	0.37			1.61		
Beryllium*	0.02			0.05		
Cadmium*	0.03			0.12		
Carbon Disulfide*	0.07			0.30		
2-Chloroacetophenone*	0.01			0.02		
Chloroform*	0.04			0.14		
Chromium*	0.14			0.60		
Chromium VI*	0.05			0.19		
Cobalt*	0.06			0.23		

Entergy Arkansas, Inc. - Independence Plant  
 Permit #: 0449-AOP-R7  
 AFIN: 32-00042

EMISSION SUMMARY						
Source Number	Description	Pollutant	Emission Rates			
			lb/hr	tpy		
		Cyanide*	1.32	5.75		
		Dimethyl Sulfate*	0.03	0.12		
		Ethylene Dichloride*	0.03	0.10		
		Fluoranthene*	0.01	0.01		
		Fluorene*	0.01	0.01		
		Formaldehyde*	0.13	0.56		
		Hydrogen Chloride	630.00	2,759.40		
		Hydrogen Fluoride	78.75	344.93		
		Isophorone*	0.31	1.34		
		Manganese*	0.26	1.13		
		Mercury*	0.05	0.20		
		Methyl Chloride	0.28	1.22		
		Methyl Hydrazine*	0.09	0.40		
		Methylene Chloride*	0.16	0.67		
		Nickel*	0.15	0.65		
		Phenanthrene*	0.01	0.01		
		Phenol*	0.01	0.04		
		POM*	0.03	0.10		
		Propionaldehyde*	0.20	0.88		
		Pyrene*	0.01	0.01		
		Selenium*	0.69	2.99		
		Styrene*	0.02	0.06		
		Toluene*	0.13	0.56		
		2,3,7,8-TCDD*	0.01	0.01		
		N <sub>2</sub> O**	42.00	183.96		
		H <sub>2</sub> SO <sub>4</sub> **	11.71	51.27		
		SN-01 (C1)	Unit 1 Boiler – No. 2 Fuel Oil or Biodiesel Fired	PM	24.1	105.6
				PM <sub>10</sub>	16.8	73.6
SO <sub>2</sub>	573.0			2,509.8		
VOC	1.9			8.1		
CO	3,232.0			4,718.8		
NO <sub>x</sub>	175.2			767.4		
Lead*	0.1			0.4		
Arsenic*	0.04			0.16		
Beryllium*	0.03			0.12		
Cadmium*	0.03			0.12		
Chromium*	0.03			0.12		
Formaldehyde*	0.36			1.54		
Manganese*	0.06			0.23		

Entergy Arkansas, Inc. - Independence Plant  
 Permit #: 0449-AOP-R7  
 AFIN: 32-00042

EMISSION SUMMARY				
Source Number	Description	Pollutant	Emission Rates	
			lb/hr	tpy
		Mercury*	0.03	0.12
		Nickel*	0.03	0.12
		POM*	0.03	0.11
		Selenium*	0.14	0.58
		N <sub>2</sub> O**	1.90	8.32
		H <sub>2</sub> SO <sub>4</sub> **	7.61	33.33
SN-02 (C1)	Unit 2 Boiler – No. 2 Fuel Oil or Biodiesel Fired	PM	24.1	105.6
		PM <sub>10</sub>	16.8	73.6
		SO <sub>2</sub>	573.0	2,509.8
		VOC	1.9	8.1
		CO	3,232.0	4,718.8
		NO <sub>x</sub>	175.2	767.4
		Lead*	0.1	0.4
		Arsenic*	0.4	0.16
		Beryllium*	0.03	0.12
		Cadmium*	0.03	0.12
		Chromium*	0.03	0.12
		Formaldehyde*	0.36	1.54
		Manganese*	0.06	0.23
		Mercury*	0.03	0.12
		Nickel*	0.03	0.12
		POM*	0.03	0.11
		Selenium*	0.14	0.58
		N <sub>2</sub> O**	1.90	8.32
		H <sub>2</sub> SO <sub>4</sub> **	7.61	33.33
		SN-03 (M1)	Rail Car Rotary Dumper	PM
PM <sub>10</sub>	0.1			0.1
VOC	1.3			1.1
SN-04 (M30-31)	Fly Ash Silos (2) with Fabric Filters	PM	0.1	0.1
		PM <sub>10</sub>	0.1	0.1
SN-05 (C3)	Auxiliary Boiler	PM	4.5	19.4
		PM <sub>10</sub>	4.5	19.4
		SO <sub>2</sub>	105.2	460.8
		VOC	0.4	1.5
		CO	6.7	29.4
		NO <sub>x</sub>	32.2	140.9
		Lead*	0.1	0.1
		Arsenic*	0.01	0.01
Beryllium*	0.01	0.01		

Entergy Arkansas, Inc. - Independence Plant  
 Permit #: 0449-AOP-R7  
 AFIN: 32-00042

EMISSION SUMMARY				
Source Number	Description	Pollutant	Emission Rates	
			lb/hr	tpy
		Cadmium*	0.01	0.01
		Chromium*	0.01	0.01
		Formaldehyde*	0.07	0.29
		Manganese*	0.01	0.01
		Mercury*	0.01	0.01
		Nickel*	0.01	0.01
		POM*	0.01	0.02
		Selenium*	0.01	0.02
		N <sub>2</sub> O**	0.35	1.53
		H <sub>2</sub> SO <sub>4</sub> **	1.62	7.10
SN-06A	Handling / Conveying Emissions	PM	1.1	4.6
		PM <sub>10</sub>	0.5	2.2
		VOC	1.3	1.1
SN-06B	Stacker / Reclaimer Emissions	PM	1.0	4.3
		PM <sub>10</sub>	0.5	2.1
SN-06C	Storage Pile and Haul Road Emissions	PM	190.4	440.9
		PM <sub>10</sub>	49.4	128.2
SN-07 (T1)	Fuel Oil Storage Tank	VOC	2.2	3.1
SN-12 (T27)	UST Diesel Tank	VOC	0.1	0.1
SN-13 (T29)	UST Automotive Unleaded Gasoline Tank	VOC	19.8	0.1
SN-14 (T30)	Unleaded Gasoline Tank	Insignificant Activity		
SN-16 (X35)	Cooling Tower # 1	PM	5.7	24.9
		PM <sub>10</sub>	5.7	24.9
SN-17 (X36)	Cooling Tower # 2	PM	5.7	24.9
		PM <sub>10</sub>	5.7	24.9
SN-18	Degreasing Operations	VOC	8.5	12.0
SN-19 (X23)	Grit Blaster	PM	1.8	7.6
		PM <sub>10</sub>	0.7	2.7
SN-20 (C4)	Emergency Diesel Generator	PM	0.6	0.7
		PM <sub>10</sub>	0.6	0.7
		SO <sub>2</sub>	4.2	4.5
		VOC	0.8	0.8
		CO	7.0	7.6
		NO <sub>x</sub>	26.3	28.5

Entergy Arkansas, Inc. - Independence Plant  
 Permit #: 0449-AOP-R7  
 AFIN: 32-00042

EMISSION SUMMARY				
Source Number	Description	Pollutant	Emission Rates	
			lb/hr	tpy
		Acenaphthene*	0.01	0.01
		Acenaphthylene*	0.01	0.01
		Acetaldehyde*	0.01	0.01
		Acrolein*	0.01	0.01
		Anthracene*	0.01	0.01
		Benzene*	0.01	0.01
		Fluoranthene*	0.01	0.01
		Fluorene*	0.01	0.01
		Formaldehyde*	0.01	0.01
		Phenanthrene*	0.01	0.01
		Pyrene*	0.01	0.01
		Toluene*	0.01	0.01
		SN-21 (C5)	Emergency Diesel Fire Pump	PM
PM <sub>10</sub>	0.9			1.3
SO <sub>2</sub>	0.8			1.2
VOC	1.0			1.5
CO	2.7			3.9
NO <sub>x</sub>	12.1			18.2
Acenaphthene*	0.01			0.01
Acenaphthylene*	0.01			0.01
Acetaldehyde*	0.01			0.01
Acrolein*	0.01			0.01
Anthracene*	0.01			0.01
Benzene*	0.01			0.01
Fluoranthene*	0.01			0.01
Fluorene*	0.01			0.01
Formaldehyde*	0.01			0.01
Phenanthrene*	0.01			0.01
Pyrene*	0.01			0.01
Toluene*	0.01			0.01

\*HAPs included in the PM/VOC totals. Other HAPs are not included in any other totals unless specifically stated.  
 \*\*Air Contaminants such as ammonia, acetone, and certain halogenated solvents are not VOCs or HAPs.

Entergy Arkansas, Inc. - Independence Plant  
Permit #: 0449-AOP-R7  
AFIN: 32-00042

### SECTION III: PERMIT HISTORY

449-A was issued to Arkansas Power & Light Company on November 1, 1977. 449-A permitted the installation of the coal-fired steam electric station near Newark on the White River. The permit established the limit of the SO<sub>2</sub> emission rate at 0.93 lbs/MMBtu heat input. The maximum emission rate for TSP was limited to 611 lb/hr based on the use of coal with a heat content of 8700 Btu/lb and a maximum sulfur and ash content of 0.45 percent and 8 percent, respectively on an as received basis.

PSD-AR-48 was issued by the Environmental Protection Agency (EPA) to Arkansas Power and Light Company to construct the Independence Steam Electric Station on March 30, 1978. This PSD permit limited the emission rates from the common stack of the two 800 MW coal-fired units (Units 1 and 2) to 15,510 lb/hr SO<sub>2</sub> and 611 lb/hr TSP based on the use of coal with a heat content of 8,700 Btu/lb and a maximum sulfur of 0.45% and a maximum ash content of 8%. Limits of 0.04 lb/10<sup>6</sup> Btu TSP and 0.93 lb/10<sup>6</sup> Btu SO<sub>2</sub> were also included. The EPA determined that the facility met the Best Available Control Technology (BACT) requirements for SO<sub>2</sub> and TSP. (The actual technology requirements were not specified in the permit.) This source was also subject to the requirements of 40 CFR 60, Subpart D-*Standards of Performance for Fossil-Fuel-Fired Steam Generators for Which Construction is Commenced After August 17, 1971*, except that the maximum allowed emissions for TSP and SO<sub>2</sub> were 0.04 and 0.93 lb/10<sup>6</sup> Btu and 40 CFR 60, Subpart Y-*Standards of Performance for Coal Preparation Plants*.

449-AR-1 was issued to Arkansas Power & Light Company- Independence Steam Electric Station on April 9, 1991. In June, 1990, AP&L announced its intent to sell a percentage of power from Unit 2 to Entergy Power Incorporated (EPI). EPI is a subsidiary of Entergy Corporation. It was determined that a revised permit for the Independence facility was needed. The revised permit incorporated existing lb/10<sup>6</sup> Btu limits for particulate matter, and sulfur dioxide. The lb/hr limit for SO<sub>2</sub> was increased from 15,510 lb/hr to 16,182 lb/hr (8,091 lb/hr for each unit.) The lb/hr limit for TSP was increased from 611 lb/hr to 696 lb/hr (348 lb/hr for each unit.) The limits from 40 CFR 60, Subpart D-*Standards of Performance for Fossil-Fuel-Fired Steam Generators for Which Construction is Commenced After August 17, 1971*, were incorporated for oxides of nitrogen and opacity. It also identified emission sources that were not addressed in the original permit application (i.e. rotary car dumper, fly ash silos) and estimated pollutant emissions from fuel oil storage facilities and air toxic emissions. The restrictions of 40 CFR 60, Subpart Y-*Standards of Performance for Coal Preparation Plants* were removed from the permit because the facility commenced construction before the applicable date.

0449-AOP-R0 was the first operating air permit issued to Entergy-Arkansas, Inc.-Independence Steam Electric Station under Regulation 26 (Title V). There were no physical changes in the method of operation at the facility. Entergy-Arkansas, Inc. increased the CO limit for the Independence facility from 300 lb/hr (50 ppm) to 3232 lb/hr or 300 ppm hourly (100 ppm 24-hour average) to reflect the optimum range for unit operating efficiency. Modeling analysis at a 500 ppm emission rate was conducted and showed no significant impact to the NAAQS. In addition, a Best Achievable Control Technology review was conducted since the facility is currently subject to PSD.

Entergy Arkansas, Inc. - Independence Plant  
Permit #: 0449-AOP-R7  
AFIN: 32-00042

Permit #449-AOP-R1 was issued July 12, 2000. In this minor modification, storage tanks SN-10 and SN-11, and the Emergency Diesel Generator (SN-08), and the Fire Pump Emergency Diesel Generator (SN-09) were moved to the insignificant activities list. Storage tank SN-15 was removed from the permit because it was no longer in existence. The fuel throughput for storage tanks SN's 12, 13, and 14 was increased. The true vapor pressure for SN-13 and SN-14 was also increased.

Permit #449-AOP-R2 was issued November 8, 2001. In this minor modification, the facility replaced the control equipment associated with the rail car rotary dumper (SN-03) and the coal emission points (SN-06) with chemical foam spray. Emissions from the use of the chemical foam spray were permitted at 2.2 tpy VOC.

Permit #449-AOP-R3 was issued on June 3, 2005. In addition to renewing the facility's Title V air permit, this permitting action was necessary to permit emissions of hazardous air pollutants (HAPs); recalculate the permitted coal handling emission rates (SN-06); increase the diesel throughput of SN-12; move SN-14 to the insignificant activities list; increase the cooling tower circulating water flow rate (SN-16 and SN-17); increase the cooling tower total dissolved solids content (SN-16 and SN-17); permit the degreasers (SN-18) and grit blaster (SN-19) which were previously submitted as insignificant; correct the emission rate limits of SN-05 to reflect No. 2 fuel oil firing; correct the fly ash silos (SN-04) PM emission rates; specify the CO PSD limit and compliance demonstration (SN-01 and SN-02); correct the permitted annual CO emission rate (SN-01 and SN-02) to correspond with the PSD limit of 100 ppm (24-hr average); update the PM<sub>10</sub> emission rates (SN-01, SN-02, and SN-05) to include condensable particulate matter; and correct the permitted PM emission rates (SN-01 and SN-02) to correspond with the PSD limit of 0.04 lb/MMBtu. An administrative amendment was issued on August 8, 2005 to remove the words "from northeastern Wyoming" from the process description and to remove the "-88" from ASTM D4507-88 for the fuel oil sampling condition.

Permit # 0449-AOP-R4 was issued on May 8, 2006. The permitting actions included:

- Allowing for the use of bituminous coal;
- Increasing the coal sulfur and ash contents;
- Setting the PM<sub>10</sub> emission rate limits equal to the PM emission rate limits for SN-01 and SN-02;
- Adding Specific Condition #6;
- Revising Specific Condition #28;
- Adding Specific Condition #29;
- Adding 40 CFR Part 63, Subpart DDDDD – *National Emission Standards for Hazardous Air Pollutants for Industrial, Commercial, and Institutional Boilers and Process Heaters* as applicable to SN-05 (which includes the addition of Specific Condition #41); and
- Revising the opacity limit for SN-04.

The total permitted emission rate increases associated with the permitting actions included: 1,830.8 tons per year (tpy) PM and 4,599.0 tpy PM<sub>10</sub>. These increases did not require PSD review because there was no physical modification to the boilers (SN-01 and SN-02) and the

Entergy Arkansas, Inc. - Independence Plant  
Permit #: 0449-AOP-R7  
AFIN: 32-00042

original PM PSD limit had not changed with the modification. The PSD limit of 0.04 lb of filterable PM per MMBtu still applied to SN-01 and SN-02.

Permit # 0449-AOP-R5 was issued on December 7, 2007. With the modification, Entergy submitted the language necessary to incorporate Bio-diesel into the permit as fuel for SN-01 or SN-02. Entergy also submitted the necessary calculations to incorporate their sulfuric acid ( $H_2SO_4$ ) emissions from SN-01 and SN-02. Additionally, Entergy determined that Scenario 2 – Fuel Oil Firing, PM/ $PM_{10}$  emissions from SN-01 and SN-02 is more accurate if the control efficiency for the ESP is removed since the ESP is not in operation during startup when fuel oil is being used. Revised emissions reflecting this determination were submitted. Also, Entergy requested the increase of the permitted annual throughput for degreasing operations and submitted calculations supporting the increased throughput. The total annual permitted emission rate increases due to the permitting action included 13.4 tons per year PM, 13.2 tpy  $PM_{10}$ , 1.6 tpy VOC, and 102.54 tpy  $H_2SO_4$ .

Permit # 0449-AOP-R6 was issued on January 12, 2009. With the modification, Entergy updated the fuel oil  $N_2O$  emissions. The  $N_2O$  annual emissions for the fuel oil fired scenario increased by 11.12 tpy. The total annual permitted emission rate increases included 0.88 tpy of  $N_2O$ . The permit modification also incorporated the facility's Clean Air Interstate Rule (CAIR) permit application.

Entergy Arkansas, Inc. - Independence Plant  
Permit #: 0449-AOP-R7  
AFIN: 32-00042

## SECTION IV: SPECIFIC CONDITIONS

### SN-01, SN-02, and SN-05 Boilers

#### Source Description

SN-01 and SN-02 are 8700 million Btu per hour coal fired boilers. Both boilers were installed in 1978. Unit 1 (SN-01) was placed into operation in 1983 and Unit 2 (SN-02) was placed into operation in 1985. The boilers use sub-bituminous coal as their primary fuel and No. 2 fuel oil or Bio-diesel as the start-up fuel. The boilers are permitted to operate under alternating scenarios. Scenario I represents combustion from coal and Scenario II represents No. 2 fuel oil or Bio-diesel combustion. The boilers supply steam which feed turbine generators to produce electricity. Both units are subject to NSPS Subpart D, which regulates emissions of particulate matter, sulfur dioxide, and nitrogen oxides from fossil-fuel-fired steam generators. A PSD permit was issued by the EPA in 1978 for the Independence facility. The facility underwent PSD review for SO<sub>2</sub> and TSP. The limits of 0.04 lb/10<sup>6</sup> Btu TSP and 0.93 lb/10<sup>6</sup> Btu SO<sub>2</sub> are still in effect. A PSD permit for CO was issued by the Department in 1998. These limits are specified in the Specific Conditions section for these sources.

Particulate emissions from SN-01 and SN-02 are controlled with electrostatic precipitators. NSPS emissions standards for particulate matter are 0.1 lb/MMBtu and a maximum opacity of 20 percent. However, the more stringent PSD emission limitation of 0.04 lb/MMBtu is in effect for this facility. A continuous opacity monitor records opacity emissions.

Sulfur dioxide emissions from SN-01 and SN-02 are limited by the use of low-sulfur coal. The NSPS emission standard for sulfur dioxide is 1.2 lb/MMBtu. However, the more stringent PSD emission limitation of 0.93 lb/MMBtu is in effect for this facility. A continuous emissions monitoring system measures sulfur dioxide emissions. Continuous emissions monitoring systems also measure CO<sub>2</sub> emissions and NO<sub>x</sub> emissions under Acid Rain requirements (40 CFR 75).

SN-05 is a 183 million Btu per hour boiler. It was installed in 1978. This Auxiliary Boiler combusts No. 2 fuel or Bio-diesel in order to provide steam for unit start-up and shut-down activities. There are no control devices associated with this source. Emissions from this boiler are regulated under the State Implementation Plan (SIP), Regulation 19.

Specific Conditions

- The permittee shall not exceed the emission rates set forth in the following table, when operating under Scenario I: Coal Firing. [Regulation 19, §19.501 et seq., and 40 CFR Part 52, Subpart E]

SN	Description	Pollutant	lb/hr	tpy
SN-01 (C1)	Unit 1 Boiler – Coal Fired	PM <sub>10</sub>	662.0*	2,899.6
		SO <sub>2</sub>	8,091.0	35,438.6
		VOC	35.0	153.3
		CO	3,232.0	4,718.8**
		NO <sub>x</sub>	6,090.0	26,674.2
		Lead	0.3	1.0
SN-02 (C2)	Unit 2 Boiler – Coal Fired	PM <sub>10</sub>	662.0*	2,899.6
		SO <sub>2</sub>	8,091.0	35,438.6
		VOC	35.0	153.3
		CO	3,232.0	4,718.8**
		NO <sub>x</sub>	6,090.0	26,674.2
		Lead	0.3	1.0

\*Note: This lb/hr limit is based on 348 lb/hr filterable PM<sub>10</sub> and 314 lb/hr condensable PM<sub>10</sub>. See Specific Condition # 2.

\*\*Note: The CO tpy limit is based on the PSD limit of 100 ppm (24 hour average).

- The permittee shall not exceed the maximum PSD emission rates set forth in the following table, when operating under Scenario I: Coal Firing. [Regulation 19, §19.501 et seq., and 40 CFR Part 52, Subpart E]

SN	Description	Pollutant	lb/hr	tpy
SN-01 (C1)	Unit 1 Boiler – Coal Fired	PM	348.0**	1,524.3**
		SO <sub>2</sub>	8,091.0	35,438.6
		CO	3,232.0	4,718.8*
SN-02 (C2)	Unit 2 Boiler – Coal Fired	PM	348.0**	1,524.3**
		SO <sub>2</sub>	8,091.0	35,438.6
		CO	3,232.0	4,718.8*

\*Note: The CO tpy limit is based on the PSD limit of 100 ppm (24 hour average).

\*\*Filterable PM only as measured by US EPA Reference Method 5. See Specific Condition # 6.

Entergy Arkansas, Inc. - Independence Plant  
 Permit #: 0449-AOP-R7  
 AFIN: 32-00042

3. The permittee shall not exceed the emission rates set forth in the following table, when operating under Scenario I: Coal Firing. [Regulation 18, §18.801, and A.C.A. §8-4-203 as referenced by A.C.A. §8-4-304 and §8-4-311]

SN	Description	Pollutant	lb/hr	tpy
SN-01 (C1)	Unit 1 Boiler – Coal Fired	PM	662.0*	2,899.6
		Acenaphthene	0.01	0.01
		Acenaphthylene	0.01	0.01
		Acetaldehyde	0.30	1.32
		Acrolein	0.16	0.67
		Anthracene	0.01	0.01
		Arsenic	0.22	0.95
		Benzene	0.69	2.99
		Benzyl Chloride	0.37	1.61
		Beryllium	0.02	0.05
		Cadmium	0.03	0.12
		Carbon Disulfide	0.07	0.30
		2-Chloroacetophenone	0.01	0.02
		Chloroform	0.04	0.14
		Chromium	0.14	0.60
		Chromium VI	0.05	0.19
		Cobalt	0.06	0.23
		Cyanide	1.32	5.75
		Dimethyl Sulfate	0.03	0.12
		Ethylene Dichloride	0.03	0.10
		Fluoranthene	0.01	0.01
		Fluorene	0.01	0.01
		Formaldehyde	0.13	0.56
		Hydrogen Chloride	630.00	2,759.40
		Hydrogen Fluoride	78.75	344.93
		Isophorone	0.31	1.34
		Manganese	0.26	1.13
		Mercury	0.05	0.20
		Methyl Chloride	0.28	1.22
		Methyl Hydrazine	0.09	0.40
		Methylene Chloride	0.16	0.67
		Nickel	0.15	0.65
		Phenanthrene	0.01	0.01
Phenol	0.01	0.04		
POM	0.03	0.10		
Propionaldehyde	0.20	0.88		
Pyrene	0.01	0.01		
Selenium	0.69	2.99		

Entergy Arkansas, Inc. - Independence Plant

Permit #: 0449-AOP-R7

AFIN: 32-00042

SN	Description	Pollutant	lb/hr	tpy
		Styrene	0.02	0.06
		Toluene	0.13	0.56
		2,3,7,8-TCDD	0.01	0.01
		N <sub>2</sub> O	42.00	183.96
		H <sub>2</sub> SO <sub>4</sub>	11.71	51.27
		PM	662.0*	2,899.6
		Acenaphthene	0.01	0.01
		Acenaphthylene	0.01	0.01
		Acetaldehyde	0.30	1.32
		Acrolein	0.16	0.67
		Anthracene	0.01	0.01
		Arsenic	0.22	0.95
		Benzene	0.69	2.99
		Benzyl Chloride	0.37	1.61
		Beryllium	0.02	0.05
		Cadmium	0.03	0.12
		Carbon Disulfide	0.07	0.30
		2-Chloroacetophenone	0.01	0.02
		Chloroform	0.04	0.14
		Chromium	0.14	0.60
		Chromium VI	0.05	0.19
		Cobalt	0.06	0.23
		Cyanide	1.32	5.75
		Dimethyl Sulfate	0.03	0.12
		Ethylene Dichloride	0.03	0.10
		Fluoranthene	0.01	0.01
		Fluorene	0.01	0.01
		Formaldehyde	0.13	0.56
		Hydrogen Chloride	630.00	2,759.40
		Hydrogen Fluoride	78.75	344.93
		Isophorone	0.31	1.34
		Manganese	0.26	1.13
		Mercury	0.05	0.20
		Methyl Chloride	0.28	1.22
		Methyl Hydrazine	0.09	0.40
		Methylene Chloride	0.16	0.67
		Nickel	0.15	0.65
		Phenanthrene	0.01	0.01
		Phenol	0.01	0.04
		POM	0.03	0.10
		Propionaldehyde	0.20	0.88
		Pyrene	0.01	0.01

Entergy Arkansas, Inc. - Independence Plant  
 Permit #: 0449-AOP-R7  
 AFIN: 32-00042

SN	Description	Pollutant	lb/hr	tpy
		Selenium	0.69	2.99
		Styrene	0.02	0.06
		Toluene	0.13	0.56
		2,3,7,8-TCDD	0.01	0.01
		N <sub>2</sub> O	42.00	183.96
		H <sub>2</sub> SO <sub>4</sub>	11.71	51.27

\*Note: This lb/hr limit is based on 348 lb/hr filterable PM and 314 lb/hr condensable PM. See Specific Condition # 2.

4. SN-01 and SN-02 are subject to 40 CFR Part 60, Subpart D, Standards of Performance for fossil fuel-fired steam generators due to a heat input capacity of greater than 250 MMBtu/hr. A copy of Subpart D is provided in Appendix A. [Regulation 19, §19.304, and 40 CFR Part 60] Applicable provisions of Subpart D, include, but are not limited to:
  - a. PM emissions shall not exceed 0.1 lb/MMBtu.\* [40 CFR 60.42(a)(1)]
  - b. Opacity shall not exceed 20 percent except for one six-minute period per hour of not more than 27 percent opacity and except as provided by 40 CFR 60.8 and 60.11. [40 CFR 60.42(a)(2)]
  - c. SO<sub>2</sub> emissions shall not exceed 1.2 lb/MMBtu.\*\* [40 CFR 60.43(a)(2)]
  - d. NO<sub>x</sub> emissions shall not exceed 0.7 lb/MMBtu. [40 CFR 60.44(a)(3)]
  - e. The permittee shall install, calibrate, and maintain Continuous Emissions Monitoring Systems (CEMS) for NO<sub>x</sub>, SO<sub>2</sub>, CO<sub>2</sub>, and opacity. [40 CFR 60.45(a)]
  - f. Excess emission and monitoring system performance reports shall be submitted to the ADEQ for every calendar quarter. Quarterly reports shall be postmarked by the 30<sup>th</sup> day following the end of the calendar quarter. Excess emissions are defined in 60.45(g)(1), (2), and (3). [40 CFR 60.45(g)]
  - g. Excess opacity emissions are defined as any six-minute period during which the average opacity emissions exceed 20%, except for one 6-minute average per hour of up to 27% opacity. [40 CFR 60.45(g)(1)]
  - h. Excess SO<sub>2</sub> emissions are defined as any 3-hour period during which the average emissions (arithmetic average of three contiguous one-hour periods) of SO<sub>2</sub> as measured by a CEMS exceed the applicable standard under §60.43. [40 CFR 60.45(g)(2)]

Entergy Arkansas, Inc. - Independence Plant  
 Permit #: 0449-AOP-R7  
 AFIN: 32-00042

- i. Excess NO<sub>x</sub> emissions are defined as any 3-hour period during which the average emissions (arithmetic average of three contiguous one-hour periods) of NO<sub>x</sub> as measured by a CEMS exceed the applicable standard under §60.44. [40 CFR 60.45(g)(3)]

**Note these units are also subject to PSD Restrictions.**

\*A more stringent PSD limit of 0.04 lb PM/MMBtu is in effect for these units. (See Specific Condition # 5)

\*\*A more stringent PSD limit of 0.93 lb SO<sub>2</sub>/MMBtu is in effect for these units. (See Specific Condition # 5)

- 5. The emissions from SN-01 and SN-02 shall not exceed the PSD emission limits in the following table when burning coal or No. 2 fuel oil. [Regulation 19, §19.901 et seq., and 40 CFR Part 52, Subpart E]

Source No.	Pollutant	lb/MMBtu
SN-01	PM*	0.04
	SO <sub>2</sub>	0.93
SN-02	PM*	0.04
	SO <sub>2</sub>	0.93

\* Filterable PM only, as measured by US EPA Reference Method #5.  
 See Specific Condition # 6.

- 6. The PM emission limits of Specific Condition # 5 are for filterable PM as measured by US EPA Reference Method #5. [A.C.A. §8-4-203 as referenced by §8-4-304 and §8-4-311]
- 7. Carbon monoxide (CO) emissions shall not exceed the PSD limit of 100 ppm (24-hour average) per unit from SN-01 and SN-02 when burning coal, No. 2 fuel oil, or bio-diesel. [Regulation 19, §19.901, and 40 CFR Part 52, Subpart E]
- 8. The permittee shall test SN-01 and SN-02 for CO while operating under Scenario I: Coal Firing. This testing shall be conducted within 180 days of issuance of permit 0449-AOP-R3 (June 3, 2005) and every five years thereafter. These tests shall be performed using EPA Reference Method 10, and shall be conducted in accordance with Plantwide Condition #3. This testing shall be conducted while operating at 90% or greater capacity and consist of three, one hour test periods averaged to demonstrate compliance with Specific Condition # 7. [Regulation 19, §19.702 and 40 CFR Part 52, Subpart E]
- 9. The permittee shall maintain records which demonstrate compliance with the SO<sub>2</sub> emission limits set in Specific Conditions # 1, # 4, and # 5. These records may be used by the Department for enforcement purposes. For Specific Condition # 1, compliance shall be determined as the arithmetic average of three contiguous one-hour periods of

Entergy Arkansas, Inc. - Independence Plant  
Permit #: 0449-AOP-R7  
AFIN: 32-00042

SO<sub>2</sub> emissions as measured by the CEMS and converted to pounds per hour per 40 CFR Part 75. For Specific Conditions #4 and # 5, compliance shall be determined as the arithmetic average of three contiguous one-hour periods of SO<sub>2</sub> as measured by a CEMS and converted to pounds per MMBtu per 40 CFR Part 60. These records shall be kept on site and shall be provided to Department personnel upon request. Records shall be submitted in accordance with General Provisions # 7 and # 8. [Regulation 19, §19.705, and 40 CFR Part 52, Subpart E]

10. The permittee shall maintain records which demonstrate compliance with the NO<sub>x</sub> emission limits set in Specific Conditions # 1 and # 4. These records may be used by the Department for enforcement purposes. For Specific Condition # 1, compliance shall be determined as the arithmetic average of three contiguous one-hour periods of NO<sub>x</sub> emissions as measured by the CEMS and converted to pounds per hour per 40 CFR Part 75. For Specific Condition # 4, compliance shall be determined as the arithmetic average of three contiguous one-hour periods of NO<sub>x</sub> as measured by a CEMS and converted to pounds per MMBtu per 40 CFR Part 60. These records shall be kept on site and shall be provided to Department personnel upon request. Records shall be submitted in accordance with General Provisions # 7 and # 8. [Regulation 19, §19.705, and 40 CFR Part 52, Subpart E]
11. The permittee shall not cause to be discharged to the atmosphere from the boilers any emissions which exhibit an opacity greater than 20 percent when firing coal, No. 2 fuel oil, or bio-diesel. The opacity shall not exceed 20 percent (6-minute average), except for one 6-minute period per hour not to exceed 27 percent. Opacity exceedances shall be reported in accordance with Specific Condition # 12. [Regulation 19, §19.503, 40 CFR Part 52, Subpart E and 40 CFR 60.42(a)(2)]
12. The permittee shall install, calibrate, maintain, and operate a continuous emission monitoring system (CEMS) for measuring opacity of emissions and all SO<sub>2</sub>, NO<sub>x</sub> and CO<sub>2</sub> emissions discharged to the atmosphere from SN-01 and SN-02 and record the output of the system. This CEMS shall comply with the Air Division's "Continuous Emission Monitoring System Conditions". A copy is provided in Appendix B. The permittee shall report all excess emissions as defined by 40 CFR 60.45(g)(1), (2), and (3) and in accordance with 40 CFR 60.7(c).

Except for opacity, the permittee must report all excess emissions including those excess emissions caused by startups, shutdowns, and malfunctions. For opacity, all exceedances must be reported in the quarterly reports including those attributable to startup, shutdown, and malfunction. Only those opacity exceedances that are not attributable to startup, shutdown, and malfunction will be used for calculating the percentage of compliance with the NSPS opacity limit. Opacity exceedances would not be reported under §19.601 of Regulation 19 for startup, shutdown, and malfunction.

The number of startup and shutdown occurrences that occur at this facility have historically ranged from 12 to 24 per year. In general, startup begins when the ID and FD

Entergy Arkansas, Inc. - Independence Plant  
 Permit #: 0449-AOP-R7  
 AFIN: 32-00042

fans are started with the intent to fire the unit. Normally, startup ends when the unit achieves stable operation and the following operating parameters are met: (1) the electrostatic precipitator is placed in service, and (2) startup oil is no longer necessary to support combustion. Duct sweeps are usually considered a part of the startup operation. For these units, shutdown normally begins when the unit load or output is reduced with the intent of removing the unit from service, or when the unit trips as the result of a sudden or unforeseen failure or malfunction. Shutdown ends when the unit is no longer combusting fuel and fan operation is no longer required. [Regulation 19, §19.703 and §19.901, 40 CFR Part 52, Subpart E, A.C.A. §8- 4-203 as referenced by §8-4-304 and §8-4-311, and 40 CFR 60, Subpart D]

13. The permittee shall submit quarterly excess emissions and monitoring systems performance reports to the Department. The reports shall include the magnitude of excess emissions, date and time of commencement and completion of each period of excess emissions, process operating time during reporting period, date and time of each period during which the CEMS are inoperative, identification of each period of excess emissions that occurs during startup, shutdown, and malfunctions of the units, nature and cause of any malfunction (if known), and the corrective action or preventative measure adopted. Reports shall be sent to the following address [Regulation 19, §19.304, and 40 CFR 60, §60.7]:

Arkansas Department of Environmental Quality  
 Air Division  
 ATTN: Compliance Inspector Supervisor  
 5301 Northshore Drive  
 North Little Rock, AR 72118

14. The permittee shall ensure that all continuous emission and opacity monitoring systems are in operation and monitoring all unit emissions or opacity at all times that the affected unit combusts any fuel, except during periods of calibration, quality assurance, preventative maintenance or repair. [Regulation 19, §19.304, and 40 CFR 75, §75.10]
15. The permittee shall not exceed the emission rates, when operating under Scenario II: No. 2 Fuel Oil or Bio-diesel Firing, set forth in the following table.

SN	Description	Pollutant	lb/hr	tpy
SN-01 (C1)	Unit 1 Boiler – No. 2 Fuel Oil or Bio-diesel Fired	PM <sub>10</sub>	16.8	73.6
		SO <sub>2</sub>	573.0	2,509.8
		VOC	1.9	8.1
		CO	3,232.0	4,718.8
		NO <sub>x</sub>	175.2	767.4
		Lead	0.1	0.4
SN-02 (C2)	Unit 2 Boiler – No. 2 Fuel Oil or Bio-	PM <sub>10</sub>	16.8	73.6
		SO <sub>2</sub>	573.0	2,509.8

Entergy Arkansas, Inc. - Independence Plant  
 Permit #: 0449-AOP-R7  
 AFIN: 32-00042

SN	Description	Pollutant	lb/hr	tpy
	diesel Fired	VOC	1.9	8.1
		CO	3,232.0	4,718.8
		NO <sub>x</sub>	175.2	767.4
		Lead	0.1	0.4

16. The permittee shall not exceed the emission rates, when operating under Scenario II: No. 2 Fuel Oil or Bio-diesel Firing, set forth in the following table.

SN	Description	Pollutant	lb/hr	tpy
SN-01 (C1)	Unit 1 Boiler – No. 2 Fuel Oil or Bio-diesel Fired	PM	24.1	105.6
		Arsenic	0.04	0.16
		Beryllium	0.03	0.12
		Cadmium	0.03	0.12
		Chromium	0.03	0.12
		Formaldehyde	0.36	1.54
		Manganese	0.06	0.23
		Mercury	0.03	0.12
		Nickel	0.03	0.12
		POM	0.03	0.11
		Selenium	0.14	0.58
		N <sub>2</sub> O	1.90	8.32
		H <sub>2</sub> SO <sub>4</sub>	7.61	33.33
SN-02 (C2)	Unit 2 Boiler – No. 2 Fuel Oil or Bio-diesel Fired	PM	24.1	105.6
		Arsenic	0.04	0.16
		Beryllium	0.03	0.12
		Cadmium	0.03	0.12
		Chromium	0.03	0.12
		Formaldehyde	0.36	1.54
		Manganese	0.06	0.23
		Mercury	0.03	0.12
		Nickel	0.03	0.12
		POM	0.03	0.11
		Selenium	0.14	0.58
		N <sub>2</sub> O	1.90	8.32
		H <sub>2</sub> SO <sub>4</sub>	7.61	33.33

17. The permittee shall maintain records which demonstrate compliance with the SO<sub>2</sub> emission limits set in Specific Condition # 15 and may be used by the Department for enforcement purposes. For Specific Condition # 15, compliance shall be determined as the arithmetic average of three contiguous one-hour periods of SO<sub>2</sub> emissions as measured by the CEMS and converted to pounds per hour per 40 CFR Part 75. For

Specific Condition # 5, compliance shall be determined as the arithmetic average of three contiguous one-hour periods of SO<sub>2</sub> as measured by a CEMS and converted to pounds per MMBtu. These records shall be kept on site and shall be provided to Department personnel upon request. Records shall be submitted in accordance with General Provisions # 7 and # 8. [Regulation 19, §19.705, and 40 CFR Part 52, Subpart E]

18. The permittee shall maintain records which demonstrate compliance with the NO<sub>x</sub> emission limits set in Specific Condition # 15 and may be used by the Department for enforcement purposes. For Specific Condition # 15, compliance shall be determined as the arithmetic average of three contiguous one-hour periods of NO<sub>x</sub> emissions as measured by the CEMS and converted to pounds per hour per 40 CFR Part 75. These records shall be kept on site and shall be provided to Department personnel upon request. Records shall be submitted in accordance with General Provisions # 7 and # 8. [Regulation 19, §19.705, and 40 CFR Part 52, Subpart E]
19. The permittee may burn No. 2 Fuel Oil or Bio-diesel during startup, shutdown, and malfunction. For all other No. 2 Fuel Oil or Bio-diesel burning activities, the permittee shall submit a request to EPA for a determination regarding the applicability of NSPS Subpart D limits and testing requirements during the coal and fuel oil and fuel oil only firing scenarios. Within 30 days of permit issuance, this request shall be submitted to EPA and a copy shall be submitted to the Department. The facility submitted a request for determination on June 15, 2005. The permittee may burn No. 2 Fuel Oil or Bio-diesel until a determination is made by EPA. [A.C.A. §8-4-203 as referenced by §8-4-304 and §8-4-311]
20. The permittee shall, contemporaneously with making a change from one operating scenario to another, record in a log at the permitted facility a record of the scenario under which the facility or source is operating. [40 CFR 70.6(a)(9)(i), §26.7 of Regulation #26, and in accordance with General Provision #17]
21. The permittee shall not exceed the rates in the following table during any consecutive twelve month period from SN-01 and SN-02 when firing coal, No. 2 fuel oil, or Bio-diesel. [Regulation 19, §19.501, and 40 CFR Part 52, Subpart E]

Source No.	Pollutant	tpy
SN-01 and SN-02	SO <sub>2</sub>	70,877.2

22. The permittee shall maintain monthly records which demonstrate compliance with the limit set in Specific Condition # 21. These records may be used by the Department for enforcement purposes. These records shall be updated no later than the last day of the month following the month which the records represent. The records shall be kept on site, and shall be provided to Department personnel upon request. A twelve month rolling total and each individual month's data shall be submitted in accordance with General Provision # 7. [Regulation 19, §19.705, and 40 CFR Part 52, Subpart E]

Entergy Arkansas, Inc. - Independence Plant  
Permit #: 0449-AOP-R7  
AFIN: 32-00042

23. The permittee shall not exceed the rates in the following table during any consecutive twelve month period from SN-01 and SN-02 when firing coal, No. 2 fuel oil, or Bio-diesel. [Regulation 19, §19.501, and 40 CFR Part 52, Subpart E]

Source No.	Pollutant	tpy
SN-01 and SN-02	NO <sub>x</sub>	53,348.4

24. The permittee shall maintain monthly records which demonstrate compliance with the limit set in Specific Condition # 23. These records may be used by the Department for enforcement purposes. These records shall be updated no later than the last day of the month following the month which the records represent. The records shall be kept on site, and shall be provided to Department personnel upon request. A twelve month rolling total and each individual month's data shall be submitted in accordance with General Provision #7. [Regulation 19, §19.705, and 40 CFR Part 52, Subpart E]
25. SN-01 and SN-02 are subject to and shall comply with all applicable provisions of the Acid Rain Program. [Regulation 19, §19.304, and 40 CFR Parts 72, 73, 75, 76, and 77]
26. The permittee shall submit the required electronic data reports (EDRs) to EPA Headquarters. [Regulation 19, §19.304, and 40 CFR Part 75]
27. Relative Accuracy tests will be performed in accordance with 40 CFR, Part 75. This relative accuracy test will meet the requirements under 40 CFR, Part 60, Subpart D. [Regulation 19, §19.304, and 40 CFR 75]
28. The permittee shall determine and record the heat input to each affected unit (SN-01 and SN-02) for every hour or part of an hour any fuel is combusted following the procedures in Appendix F of 40 CFR Part 75. [Regulation 19, §19.304, and 40 CFR Part 75.10(c)]
29. The permittee shall test SN-01 and SN-02 for PM and PM<sub>10</sub> while operating under Scenario I: Coal Firing and while operating at 90% or greater capacity. Emission results shall be extrapolated to correlate with 100% of the permitted capacity to determine compliance. The PM test shall be performed using EPA Reference Methods 5 and 202. The PM<sub>10</sub> test shall be performed using EPA Reference Methods 201A and 202. These tests shall be conducted in accordance with Plantwide Condition # 3. This testing shall be conducted within 180 days of issuance of permit 0449-AOP-R3 (June 3, 2005) and every five years thereafter. [Regulation 19, §19.702 and 40 CFR Part 52, Subpart E]
30. The permittee shall monitor the opacity of SN-01 and SN-02 using a continuous opacity monitoring system. The permittee shall initiate corrective action when the measured opacity is greater than 20% for a one-hour average, and shall report any excursions where the opacity is 20% or greater on a three-hour average. Corrective action shall include ESP inspection, returning tripped ESP sections to service, ash removal system evaluation,

and load reduction, if necessary. During startup when the ESP is offline, the corrective actions referenced above will not be required but startup shall be minimized. The permittee shall maintain records of the measured opacity and any corrective actions taken. A monitoring report shall be submitted to the Department in accordance with General Provision #7 and shall include the following per 40 CFR §64.9(a)(2):

- a. The information required under 40 CFR §70.6(a)(3)(iii);
- b. Summary information on the number, duration and cause (including unknown cause, if applicable) of excursions or exceedances, as applicable, and the corrective actions taken;
- c. Summary information on the number, duration and cause (including unknown cause, if applicable) for monitor downtime incidents (other than downtime associated with zero and span or other daily calibration checks, if applicable); and
- d. A description of the actions taken to implement a QIP, if required, during the reporting period as specified in §64.8. Upon completion of a QIP, the owner or operator shall include in the next summary report documentation that the implementation of the plan has been completed and reduced the likelihood of similar levels of excursions or exceedances occurring. A QIP shall be required if the excess emissions for opacity, as reported on the Quarterly Excess Emissions Report, exceeds 5% of the unit operating time.

All opacity exceedances must be reported in the quarterly reports including those attributable to startup, shutdown, and malfunction. Opacity exceedances would not be reported under §19.601 of Regulation 19 for startup, shutdown, and malfunction. In accordance with §64.7(d)(2), a determination may be made by the Department regarding whether the permittee has used acceptable procedures in response to an excursion or an exceedance. [Regulation 19, §19.304, and 40 CFR Part 64]

31. The opacity for SN-01 and SN-02 shall not exceed 20% opacity except that emissions greater than 20% opacity but not exceeding 60% opacity will be allowed for not more than six (6) minutes in the aggregate in any consecutive 60-minute period, provided such emissions will not be permitted more than three (3) times during any 24-hour period. However, the opacity limits imposed by this condition will be held in abeyance provided that opacity does not exceed 20% except that emissions greater than 20% opacity but not exceeding 27% opacity will be allowed for not more than one 6-minute period per hour, provided such emissions will not be permitted more than ten (10) times per day. Violations of this condition may be allowed as a direct result of unavoidable upset conditions in the nature of the process, or unavoidable and unforeseeable breakdown of any air pollution control equipment or related operating equipment, or as a direct result of shutdown or start-up of the operating unit, provided the following requirements are met:

- a. Such occurrence, in the case of unavoidable upset in or breakdown of equipment, shall have been reported to the Department by means of a notification delivered by phone, fax, or email by the end of the next business day after the discovery of the occurrence.
- b. The facility shall submit to the Department, at its request, a full report of such occurrence, including a statement of all known causes and of the scheduling and nature of the actions to be taken to minimize or eliminate future occurrences, including, but not limited to, action to reduce the frequency of occurrence of such conditions, to minimize the amount by which said limits are exceeded, and to reduce the length of time for which said limits are exceeded.
- c. In the case of shutdown for necessary scheduled maintenance, the intent to shutdown shall be reported to the Department at least twenty-four (24) hours prior to the shutdown; provided, however, that the exception provided by this condition shall only apply in those cases where maximum reasonable effort has been made to accomplish such maintenance during periods of non operation of any related source operation or where it would be unreasonable or impossible to shut down the source operation during the maintenance period. Any information which is considered a trade secret under 8-4-308 shall be submitted with an affidavit containing the information of Regulation 18.1402(B).
- d. Demonstrates to the satisfaction of the Department that the emissions resulted from:
  - i. Equipment malfunction or upset and are not the result of negligence or improper maintenance;
  - ii. Physical constraints on the ability of a source to comply with the emission standard, limitation or rate during startup or shutdown;
  - iii. And that all reasonable measures have been taken to immediately minimize or eliminate the excess emissions.

Opacity exceedances shall be reported in accordance with Specific Condition # 12. [Regulation 18, §18.102(C), §18.501, and §18.1101, and A.C.A. §8-4-203 as referenced by §8-4-304 and §8-4-311]

32. The permittee shall sample and analyze each shipment of fuel oil or Bio-diesel to determine the sulfur content. The sulfur content shall not exceed 0.5 weight percent. Fuel oil or Bio-diesel sampling and analysis may be performed by the owner or operator of an affected unit, an outside laboratory, or a fuel supplier, provided that sampling is performed according to ASTM D4057. Each shipment shall be defined as a 5,000 or 10,000 barrel lot delivered to a pipeline and pumped to a loading rack. (*Note: Vendor testing would satisfy this requirement as long as the sampling is performed according to ASTM D4057 and the facility is able to meet the requirements of Specific Condition # 33.*) [Regulation 19, §19.703, 40 CFR Part 52, Subpart E, and A.C.A. §8- 4-203 as referenced by §8-4-304 and §8-4-311]

Entergy Arkansas, Inc. - Independence Plant  
 Permit #: 0449-AOP-R7  
 AFIN: 32-00042

33. The permittee shall maintain records of fuel oil or Bio-diesel sampling. These records shall be kept on site and made available to Department personnel upon request. These records may be used by the Department for enforcement purposes. [Regulation 19, §19.705, and 40 CFR Part 52, Subpart E]
34. No. 2 fuel oil or Bio-diesel is the only fuel permitted for use in the Auxiliary Boiler, SN-05. [Regulation 19, §19.705, A.C.A. §8-4-203 as referenced by §8-4-304 and §8-4-311, and 40 CFR 70.6]
35. The permittee shall not exceed the emission rates set forth in the following table when burning No. 2 fuel oil or Bio-diesel in the Auxiliary Boiler, SN-05. [Regulation 19, §19.501, and 40 CFR Part 52, Subpart E]

Source No.	Pollutant	lb/hr	tpy
SN-05	PM <sub>10</sub>	4.5	19.4
	SO <sub>2</sub>	105.2	460.8
	VOC	0.4	1.5
	CO	6.7	29.4
	NO <sub>x</sub>	32.2	140.9
	Lead	0.1	0.1

36. The permittee shall not exceed the emission rates set forth in the following table when burning No. 2 fuel oil or Bio-diesel in the Auxiliary Boiler, SN-05. [Regulation 18, §18.801, and A.C.A. §8-4-203 as referenced by §8-4-304 and §8-4-311]

Source No.	Pollutant	lb/hr	tpy
SN-05	PM	4.5	19.4
	Arsenic	0.01	0.01
	Beryllium	0.01	0.01
	Cadmium	0.01	0.01
	Chromium	0.01	0.01
	Formaldehyde	0.07	0.29
	Manganese	0.01	0.01
	Mercury	0.01	0.01
	Nickel	0.01	0.01
	POM	0.01	0.02
	Selenium	0.01	0.02
	N <sub>2</sub> O	0.35	1.53
	H <sub>2</sub> SO <sub>4</sub>	1.62	7.10

37. The opacity shall not exceed 20% from SN-05 as measured by EPA Reference Method 9. [Regulation 19, §19.503 and 40 CFR Part 52, Subpart E]

Entergy Arkansas, Inc. - Independence Plant  
Permit #: 0449-AOP-R7  
AFIN: 32-00042

38. Weekly observations of the opacity from SN-05 shall be conducted by personnel familiar with the permittee's visible emissions, when it operates more than one continuous hour. The permittee shall keep records of these observations. The permittee shall maintain personnel trained in (but not necessarily certified in) EPA Reference Method 9. If visible emissions are detected, then the permittee shall conduct a 6-minute opacity reading in accordance with EPA Reference Method 9. Records of the opacity observations shall be updated weekly, maintained on site, and made available to Department personnel upon request. [Regulation 19, §19.705 and 40 CFR Part 52, Subpart E]
39. The permittee shall maintain records of when SN-05 is operated. These records shall be maintained on site, and made available to Department personnel upon request. [Regulation 19, §19.705 and 40 CFR Part 52, Subpart E]

SN-03, SN-06A, SN-06B, and SN-06C  
 Rail Car Rotary Dumper and Handling / Conveying Emissions

Source Description

SN-03 - The coal for the Independence Steam Electric Station is received by rail. Each rail car is equipped with rotary couplings which enable the rail car rotary dumper to grasp one car at a time and empty it without removing the car from the train. The rail car rotary dumper, SN-03, is capable of emptying approximately 30 cars per hour. The rotoclone and water sprays previously used to control emissions from this process were replaced by chemical foam spray in 2001. Emissions from the rail car rotary dumper are regulated under the State Implementation Plan (SIP), Regulation 19.

SN-06 - Minor emission sources at the facility include coal handling/conveying operations. Dust emissions from the coal handling operations (SN-06) were previously controlled with AMERCLONES, rotoclones and wet sprays. Beginning in 2001, dust emissions are now controlled with water and a chemical foam spray. SN-06 is separated into three sources: SN-06A, SN-06B, and SN-06C. SN-06A, Handling and Conveying Emissions, includes emission points M2, M3, M5, M6, M7, M8, M9, M12, M13, M14, M15, M16, M24, M25, M26, M27, M28, M32, and M33. SN-06B, Stacker/Reclaimer Emissions, includes emission points M17, M18, M20, M21, M22, and M23. SN-06C, Storage Piles and Haul Road Emissions, includes emission points M11 and M34. Emissions are regulated under the State Implementation Plan (SIP), Regulation 19.

Specific Conditions

40. The permittee shall not exceed the emission rates set forth in the following table.  
 [Regulation 19, §19.501 et seq. and 40 CFR Part 52, Subpart E]

SN	Description	Pollutant	lb/hr	tpy
SN-03	Rail Car Rotary Dumper	PM <sub>10</sub>	0.1	0.1
		VOC	1.3	1.1
SN-06A	Handling / Conveying Emissions	PM <sub>10</sub>	0.5	2.2
		VOC	1.3	1.1
SN-06B	Stacker / Reclaimer Emissions	PM <sub>10</sub>	0.5	2.1
SN-06C	Storage Pile and Haul Road Emissions	PM <sub>10</sub>	49.4	128.2

41. The permittee shall not exceed the emission rates set forth in the following table.  
 [Regulation 18, §18.801, and A.C.A. §8-4-203 as referenced by A.C.A. §8-4-304 and §8-4-311]

SN	Description	Pollutant	lb/hr	tpy
SN-03	Rail Car Rotary Dumper	PM	0.1	0.1
SN-06A	Handling / Conveying Emissions	PM	1.1	4.6
SN-06B	Stacker / Reclaimer Emissions	PM	1.0	4.3
SN-06C	Storage Pile and Haul Road Emissions	PM	190.4	440.9

42. The permittee shall not use any chemical foam spray at SN-03 and SN-06 which contains HAPs. [Regulation 18, §18.1004 and A.C.A. §8-4-203 as referenced by §8-4-304 and §8-4-311]
43. Records shall be maintained to demonstrate compliance with Condition # 42. These records shall be updated no later than the last day of the month following the month which the records represent. Such records shall be submitted to the Department in accordance with General Provision #7. [Regulation 18, §18.1004 and A.C.A. §8-4-203 as referenced by §8-4-304 and §8-4-311]
44. The VOC content of the chemical foam spray used at SN-03 and SN-06 shall not exceed 1.42% by weight. [Regulation 19, §19.705, A.C.A. §8-4-203 as referenced by §8-4-304 and §8-4-311, and 40 CFR Part 70.6]
45. Records shall be maintained to demonstrate compliance with Specific Condition # 44. These records shall be updated no later than the last day of the month following the month which the records represent. Such records shall be submitted to the Department in accordance with General Provision #7. [Regulation 19, §19.705 and 40 CFR Part 52, Subpart E]
46. Usage of the chemical foam spray at SN-03 and SN-06 shall not exceed 300,000 pounds in any consecutive twelve month period. [Regulation 19, §19.705, A.C.A. §8-4-203 as referenced by §8-4-304 and §8-4-311, and 40 CFR Part 70.6]
47. The permittee shall maintain monthly records to demonstrate compliance with Specific Condition # 46. These records shall be updated no later than the last day of the month following the month which the records represent. The records shall be kept on site, and shall be provided to Department personnel upon request. A twelve month rolling total and each individual month's data shall be submitted in accordance with General Provision #7. [Regulation 19, §19.705 and 40 CFR Part 52, Subpart E]

Entergy Arkansas, Inc. - Independence Plant  
Permit #: 0449-AOP-R7  
AFIN: 32-00042

48. The permittee shall not cause to be discharged into the atmosphere any emissions which exhibit an opacity greater than or equal to 20% from the sources at SN-03, SN-06A, and SN-06B. The opacity shall be measured in accordance with EPA Reference Method 9. [Regulation 19, §19.503, 40 CFR Part 52, Subpart E, and 40 CFR §60.252(c)(2)]
49. Weekly observations of the opacity from sources SN-03 and SN-06A shall be conducted by personnel familiar with the permittee's visible emissions. The permittee shall maintain personnel trained in (but not necessarily certified in) EPA Reference Method 9. If visible emissions from any of the towers, enclosed conveyors, or silos are detected, the permittee shall take action to identify the cause of the visible emissions, implement corrective action, and document if visible emissions were present following the corrective action. If visible emissions are still present following the corrective action, the permittee shall document that visible emissions do not appear to be greater than or equal to 20% opacity and shall document that visible emissions did not cause a nuisance off-site. The permittee shall maintain records which contain the following items in order to demonstrate compliance with this condition:
- a. The date and time of the opacity observation and/or visual check.
  - b. If any visible emissions were detected.
  - c. If any visible emissions were detected, the permittee shall document the opacity, the cause of the visible emissions, the corrective action taken, any necessary repairs, and if any visible emissions were detected following the repairs.
  - d. The name of the person conducting the opacity observation and/or visual check.

These records shall be updated weekly, kept on site, and made available to Department personnel upon request. [Regulation 19, §19.705, 40 CFR Part 52, Subpart E, and 40 CFR Part 64]

50. The permittee shall conduct weekly observations of the opacity for source SN-06B. Weekly observations from source SN-06B shall be conducted by personnel familiar with the permittee's visible emissions. The permittee shall maintain personnel trained in (but not necessarily certified in) EPA Reference Method 9. If visible emissions from stackout, reclaiming, or any of the belts or transfer points are detected, the permittee shall take action to identify the cause of the visible emissions, implement corrective action, and document if visible emissions were present following the corrective action. If visible emissions are still present following the corrective action, the permittee shall document that visible emissions do not cause a nuisance beyond the property boundary. Under normal conditions, off-site opacity less than or equal to 5% shall not be considered a nuisance. The permittee shall maintain records which contain the following items in order to demonstrate compliance with this condition:
- a. The date and time of the opacity observation and/or visual check.
  - b. If any visible emissions were detected.

- c. If any visible emissions were detected, the permittee shall document the opacity, the cause of the visible emissions, the corrective action taken, any necessary repairs, and if any visible emissions were detected following the repairs.
- d. The name of the person conducting the opacity observation and/or visual check.

These records shall be updated weekly, kept on site, and made available to Department personnel upon request. [Regulation 19, §19.705, 40 CFR Part 52, Subpart E, and 40 CFR Part 64]

51. The permittee shall not operate in a manner such that fugitive emissions from the storage piles, pile operations (such as operation of mobile equipment upon the storage pile), and haul road (SN-06C) would cause a nuisance off-site. Under normal conditions, off-site opacity less than or equal to 5% shall not be considered a nuisance. The permittee shall use water sprays or other techniques as necessary to control fugitive emissions. [A.C.A. §8-4-203 as referenced by §8-4-304 and §8-4-311]
52. Dust suppression activities should be conducted in a manner and at a rate of application that will not cause runoff from the area being applied. Best Management Practices (40 CFR §122.44(k)) should be used around streams and waterbodies to prevent the dust suppression agent from entering Waters of the State. Except for potable water, no agent shall be applied within 100 feet of wetlands, lakes, ponds, springs, streams, or sinkholes. Failure to meet this condition may require the permittee to obtain a National Pollutant Discharge Elimination System (NPDES) permit in accordance with 40 CFR §122.1(b). [A.C.A. §8-4-203 as referenced by A.C.A. §8-4-304 and §8-4-311]
53. The permittee shall use the foam sprays while the dumper (SN-03) is in operation and at all times when the Transfer Points (SN-06) including Bins, Silos, etc., that are equipped with the foam spray controls are in use except when the ambient temperature is below 40 degrees F or while it is raining. [Regulation 19, §19.303 and A.C.A. §8-4-203 as referenced by §8-4-304 and §8-4-311]
54. The permittee shall comply with the maintenance plan submitted to the Department for the rotary car dumper, SN-03 (See Appendix C). The requirements include but are not limited to the following:
  - a. Inspect spray nozzles for pluggage,
  - b. Check air pressure and flow,
  - c. Check water pressure and water/dust foam flow, and
  - d. Check for adequate dust foam chemical additive.

The permittee may use equivalent or alternative plans for this source without undergoing a modification to this permit if the new maintenance plans have been reviewed and approved by the Department. The permittee is required to submit any new maintenance plan for this source to the Department and may not implement the maintenance plan until the facility receives approval from the Department. The permittee must submit the

Entergy Arkansas, Inc. - Independence Plant  
Permit #: 0449-AOP-R7  
AFIN: 32-00042

proposed maintenance plan(s) with a cover letter explaining any changes to the following address.

Arkansas Department of Environmental Quality  
Air Division  
ATTN: Compliance Inspector Supervisor  
5301 Northshore Drive  
North Little Rock, AR 72118

[Regulation 19, §19.304 and 40 CFR 70.6]

55. The ash trucks shall not exceed 61,320 vehicle miles traveled per consecutive twelve (12) month period on paved roads and 12,045 vehicle miles traveled per consecutive twelve (12) month period on unpaved roads. [Regulation 19, §19.705, A.C.A. §8-4-203 as referenced by §8-4-304 and §8-4-311, and 40 CFR Part 70.6]
56. The permittee shall maintain monthly records to demonstrate compliance with Specific Condition # 55. Compliance shall be demonstrated by recording the tons of fly ash disposed of in the on-site landfill and calculating the mileage based on the following calculations:

$$\text{Monthly Total Paved Miles Traveled} = \left( \frac{\text{Monthly tons disposed}}{26 \text{ tons per round trip}} \right) \times (\text{"Miles Paved" per round trip})$$

$$\text{Monthly Total Unpaved Miles Traveled} = \left( \frac{\text{Monthly tons disposed}}{26 \text{ tons per round trip}} \right) \times (\text{"Miles Unpaved" per round trip})$$

The round trip mileage to the on-site landfill will be checked annually to determine the number of miles on paved and unpaved road. This check will be completed prior to the end of the first quarter of the year. The results will be recorded and used in the calculation for the remainder of the year unless an additional check is performed. The total miles traveled records shall be updated no later than the last day of the month following the month which the records represent. The records shall be kept on site, and shall be provided to Department personnel upon request. A twelve month rolling total and each individual month's data shall be submitted in accordance with General Provision #7. [Regulation 19, §19.705 and 40 CFR Part 52, Subpart E]

57. The permittee shall not operate the Coal Yard Dozers more than a combined 9,000 hours per consecutive twelve (12) month period, and the water wagon shall not exceed 3,000 hours of operation per consecutive twelve (12) month period. Hours of operation do not include time spent idling while stationary. [Regulation 19, §19.705, A.C.A. §8-4-203 as referenced by §8-4-304 and §8-4-311, and 40 CFR Part 70.6]

Entergy Arkansas, Inc. - Independence Plant  
Permit #: 0449-AOP-R7  
AFIN: 32-00042

58. The permittee shall maintain monthly records to demonstrate compliance with Specific Condition # 57. These records shall be updated no later than the last day of the month following the month which the records represent. The records shall be kept on site, and shall be provided to Department personnel upon request. A twelve month rolling total and each individual month's data shall be submitted in accordance with General Provision #7. [Regulation 19, §19.705 and 40 CFR Part 52, Subpart E]

SN-04  
 Fly Ash Silos with Fabric Filters

Source Description

The Independence Plant is equipped with two (2) fly ash silos. Particulate emissions from the silos are controlled by fabric filters (SN-04) with control efficiency of 99.9% for PM and 99.8% for PM<sub>10</sub>. Emissions are regulated under the State Implementation Plan, (SIP), Regulation 19.

Specific Conditions

59. The permittee shall not exceed the emission rates set forth in the following table.  
 [Regulation 19, §19.501 et seq. and 40 CFR Part 52, Subpart E]

SN	Description	Pollutant	lb/hr	tpy
SN-04	Fly Ash Silos	PM <sub>10</sub>	0.1	0.1

60. The permittee shall not exceed the emission rates set forth in the following table.  
 [Regulation 18, §18.801, and A.C.A. §8-4-203 as referenced by A.C.A. §8-4-304 and §8-4-311]

SN	Description	Pollutant	lb/hr	tpy
SN-04	Fly Ash Silos	PM	0.1	0.1

61. The permittee shall not cause to be emitted from this source any emission which exhibit an opacity greater than 5 percent. The opacity shall be measured in accordance with EPA Reference Method 9. [Regulation 18, §18.501 and A.C.A. §8-4-203 as referenced by §8-4-304 and §8-4-311]
62. Plant personnel will perform a daily visual check, during daylight hours, to ensure the baghouse is functioning properly. Observations of the opacity from source SN-04 shall be conducted by personnel familiar with the permittee's visible emissions. These observations of opacity shall be conducted weekly and whenever visible emissions are detected during the daily visual checks. The permittee shall maintain personnel trained in (but not necessarily certified in) EPA Reference Method 9. If visible emissions are detected, the permittee shall identify the cause of the visible emissions and implement corrective action. The permittee shall maintain records which contain the following items in order to demonstrate compliance with this condition:
- a. The date and time of the opacity observation and/or visual check.
  - b. If any visible emissions were detected.

Entergy Arkansas, Inc. - Independence Plant  
Permit #: 0449-AOP-R7  
AFIN: 32-00042

- c. If any visible emissions were detected, the permittee shall document the opacity, the cause of the visible emissions, the corrective action taken, any necessary repairs, and if any visible emissions were detected following the repairs.
- d. The name of the person conducting the opacity observation and/or visual check.

These records shall be updated daily, kept on site, and made available to Department personnel upon request. The records shall be submitted to the Department in accordance with General Provision #7. [Regulation 19, §19.705, 40 CFR Part 52, Subpart E, and 40 CFR Part 64]

63. The permittee shall comply with the maintenance plan submitted to the Department for the fly ash silos (See Appendix C). Requirements include but are not limited to the following:
  - a. Check air leaks on pulsation system;
  - b. Check air operated valves;
  - c. Check piping and supports;
  - d. Check air cylinders;
  - e. Check baghouse doors and seals;
  - f. Check bags;
  - g. Check diffuser blower bearings for heat and vibration;
  - h. Check blower case for excessive heat buildup;
  - i. Check inlet filter and change as needed.

The permittee may use equivalent or alternative maintenance plans for this source without undergoing a modification to this permit. [Regulation 19, §19.303 and A.C.A. §8-4-203 as referenced by §8-4-304 and §8-4-311]

64. The permittee shall conduct semi-annual maintenance inspections on the baghouses at SN-04. These inspections shall include checking all of the requirements listed in Specific Condition # 63. The permittee shall maintain a record of these inspections. This record shall be kept on site and made available to Department personnel upon request. [Regulation 19, §19.705, 40 CFR Part 52, Subpart E, and 40 CFR Part 64]

Entergy Arkansas, Inc. - Independence Plant  
Permit #: 0449-AOP-R7  
AFIN: 32-00042

SN-07  
Fuel Oil Storage Tank

Source Description

No. 2 Fuel Oil or bio-diesel is stored in a storage tank on site. The tank has a capacity of 3,360,000 gallons or 80,000 barrels. The tank is cylindrical with a fixed roof. Emissions from the storage tank are 3.1 tons/year of volatile organic compounds (VOCs). Emissions are regulated under the State Implementation Plan (SIP), Regulation 19.

Specific Conditions

65. The permittee shall not exceed the emission rates set forth in the following table. The permittee shall demonstrate compliance with this condition by Specific Condition #66. [Regulation 19, §19.501 et seq. and 40 CFR Part 52, Subpart E]

SN	Description	Pollutant	lb/hr	tpy
SN-07	Fuel Oil Storage Tank	VOC	2.2	3.1

66. The permittee shall not exceed the annual throughput limit of 112,000,000 gallons of No. 2 fuel oil or bio-diesel at SN-07 during any consecutive 12-month period. [Regulation 19, §19.705, A.C.A. §8-4-203 as referenced by §8-4-304 and §8-4-311, and 40 CFR 70.6]
67. The permittee shall maintain monthly records to demonstrate compliance with Specific Condition # 66. The permittee shall update these records by the thirtieth day of the month following the month to which the records pertain. A twelve month rolling total and each individual month's data shall be maintained on-site, made available to Department personnel upon request and submitted in accordance with General Provision # 7. [Regulation 19, §19.705 and 40 CFR Part 52, Subpart E]

Entergy Arkansas, Inc. - Independence Plant  
Permit #: 0449-AOP-R7  
AFIN: 32-00042

SN-12 and SN-13  
Miscellaneous Storage Tanks

Source Description

SN-12 (T27) is a 15,000 gallon tank used to store diesel or bio-diesel.

SN-13 (T29) is a 2,500 gallon tank used to store gasoline.

Emissions from the tanks are volatile organic compounds (VOCs) which are regulated under the State Implementation Plan (SIP), Regulation 19.

Specific Conditions

68. The permittee shall not exceed the emission rates set forth in the following table. The permittee shall demonstrate compliance with this condition by Specific Conditions # 69 through # 72. [Regulation 19, §19.501 et seq. and 40 CFR Part 52, Subpart E]

SN	Description	Pollutant	lb/hr	tpy
SN-12 (T27)	UST Diesel Tank	VOC	0.1	0.1
SN-13 (T29)	UST Automotive Unleaded Gasoline Tank	VOC	19.8	0.1

69. The permittee shall store only diesel or bio-diesel in storage tank SN-12. Supporting documentation shall be maintained on site to demonstrate compliance with this specific condition. [Regulation 19, §19.705, A.C.A. §8-4-203 as referenced by §8-4-304 and §8-4-311, and 40 CFR 70.6]
70. The permittee shall store only gasoline in storage tank SN-13. Supporting documentation shall be maintained on site to demonstrate compliance with this specific condition. [Regulation 19, §19.705, A.C.A. §8-4-203 as referenced by §8-4-304 and §8-4-311, and 40 CFR 70.6]
71. The permittee shall not exceed an annual throughput limit of 200,000 gallons of diesel or bio-diesel at SN-12 during any consecutive twelve month period. [Regulation 19, §19.705, A.C.A. §8-4-203 as referenced by §8-4-304 and §8-4-311, and 40 CFR 70.6]
72. The permittee shall not exceed an annual throughput of 15,600 gallons of gasoline at SN-13 during any consecutive twelve month period. [Regulation 19, §19.705, A.C.A. §8-4-203 as referenced by §8-4-304 and §8-4-311, and 40 CFR 70.6]
73. The permittee shall maintain monthly records to demonstrate compliance with Specific Conditions # 71 and # 72. The permittee shall update these records by the thirtieth day of

Entergy Arkansas, Inc. - Independence Plant  
Permit #: 0449-AOP-R7  
AFIN: 32-00042

the month following the month to which the records pertain. A twelve month rolling total and each individual month's data shall be maintained on-site, made available to Department personnel upon request and submitted in accordance with General Provision # 7. [Regulation 19, §19.705 and 40 CFR Part 52, Subpart E]

SN-16 and SN-17  
 Cooling Towers

Source Description

The Independence Steam Electric Station operates two (2) cooling towers for waste heat dissipation. The cooling towers obtain makeup water from the White River and from the capture of site drainage. Emissions from the towers are particulate matter which are regulated under the State Implementation Plan, (SIP), Regulation 19.

Specific Conditions

74. The permittee shall not exceed the emission rates set forth in the following table. The permittee shall demonstrate compliance with this condition by Specific Conditions # 78 and # 80. [Regulation 19, §19.501 et seq. and 40 CFR Part 52, Subpart E]

SN	Description	Pollutant	lb/hr	tpy
SN-16 (X35)	Cooling Tower # 1	PM <sub>10</sub>	5.7	24.9
SN-17 (X36)	Cooling Tower # 2	PM <sub>10</sub>	5.7	24.9

75. The permittee shall not exceed the emission rates set forth in the following table. The permittee shall demonstrate compliance with this condition by Specific Conditions # 78 and # 80. [Regulation 18, §18.801, and A.C.A. §8-4-203 as referenced by A.C.A. §8-4-304 and §8-4-311]

SN	Description	Pollutant	lb/hr	tpy
SN-16 (X35)	Cooling Tower # 1	PM	5.7	24.9
SN-17 (X36)	Cooling Tower # 2	PM	5.7	24.9

76. The permittee shall not cause to be discharged to the atmosphere from this source any cooling tower drift emissions which exhibit an opacity greater than 5 percent. The opacity shall be measured in accordance with EPA Reference Method 9. [Regulation 18, §18.501, and A.C.A. §8-4-203 as referenced by §8-4-304 and §8-4-311]
77. The permittee shall operate the cooling towers within the design specifications listed in Appendix C. Compliance with the design specifications may demonstrate compliance with the limit specified in Specific Condition # 76. [A.C.A. §8-4-203 as referenced by §8-4-304 and §8-4-311]

Entergy Arkansas, Inc. - Independence Plant  
Permit #: 0449-AOP-R7  
AFIN: 32-00042

78. The total dissolved solids content shall not exceed 3,600 parts per million. [Regulation 19, §19.705, A.C.A. §8- 4-203 as referenced by §8-4-304 and §8-4-311, and 40 CFR 70.6]
79. The permittee shall monitor the total dissolved solids weekly when the unit is operating to demonstrate compliance with Specific Condition # 78. The permittee shall maintain records that demonstrate compliance with this specific condition. These records shall be updated weekly, kept on site, and made available to Department personnel upon request. [Regulation 19, §19.705 and 40 CFR Part 52, Subpart E]
80. The circulating water flow for SN-16 and SN-17 shall not exceed 21,600 kgal/hr per Tower. [Regulation 19, §19.705, A.C.A. §8-4-203 as referenced by §8-4-304 and §8-4-311, and 40 CFR 70.6]
81. The permittee shall test the circulating water flow annually to demonstrate compliance with this Specific Condition # 80. The permittee shall maintain records that demonstrate compliance with this specific condition. These records shall be updated annually, kept on site, and made available to Department personnel upon request. [Regulation 19, §19.705 and 40 CFR Part 52, Subpart E]

SN-18  
Degreasing Operations

Source Description

This source consists of ten (10) degreasers with a total capacity of 698 gallons. Four (4) of the degreasers are used during outage periods only. One of the degreasers, the turbine oil filter degreaser (16 gallon capacity), uses a different solvent than the other 9 degreasers.

Specific Conditions

82. The permittee shall not exceed the emission rates set forth in the following table. The permittee shall demonstrate compliance with this condition by Specific Conditions # 83 through # 86. [Regulation 19, §19.501 et seq. and 40 CFR Part 52, Subpart E]

SN	Description	Pollutant	lb/hr	tpy
SN-18	Degreasing Operations	VOC	8.5	12.0

83. The VOC content of the solvent used at the turbine oil filter degreaser shall not exceed 7.59 pounds of VOC per gallon of solvent. Material Safety Data Sheets shall be maintained on site to demonstrate compliance with this specific condition. [Regulation 19, §19.705, A.C.A. §8- 4-203 as referenced by §8-4-304 and §8-4-311, and 40 CFR 70.6]
84. The VOC content of the solvent used at all degreasers other than the turbine oil filter degreaser shall not exceed 6.8 pounds of VOC per gallon of solvent. Material Safety Data Sheets shall be maintained on site to demonstrate compliance with this specific condition. [Regulation 19, §19.705, A.C.A. §8- 4-203 as referenced by §8-4-304 and §8-4-311, and 40 CFR 70.6]
85. The throughput of the turbine oil filter degreaser shall not exceed 32 gallons of solvent per consecutive twelve-month period. [Regulation 19, §19.705, A.C.A. §8- 4-203 as referenced by §8-4-304 and §8-4-311, and 40 CFR 70.6]
86. The throughput of all degreasers excluding the turbine oil filter degreaser shall not exceed 3,480 gallons of solvent per consecutive twelve-month period. [Regulation 19, §19.705, A.C.A. §8- 4-203 as referenced by §8-4-304 and §8-4-311, and 40 CFR 70.6]
87. The permittee shall maintain monthly records to demonstrate compliance with Specific Conditions # 85 and # 86. The permittee shall update these records by the thirtieth day of the month following the month to which the records pertain. A twelve month rolling total and each individual month's data shall be maintained on-site, made available to

Entergy Arkansas, Inc. - Independence Plant  
Permit #: 0449-AOP-R7  
AFIN: 32-00042

Department personnel upon request and submitted in accordance with General Provision  
# 7. [Regulation 19, §19.705 and 40 CFR Part 52, Subpart E]

Entergy Arkansas, Inc. - Independence Plant  
Permit #: 0449-AOP-R7  
AFIN: 32-00042

SN-19  
Grit Blaster

Source Description

This source consists of a grit blaster used for small parts cleaning. The maximum hourly abrasive usage rate is 550 lb/hr. The emissions are controlled with a baghouse.

Specific Conditions

88. The permittee shall not exceed the emission rates set forth in the following table.  
[Regulation 19, §19.501 et seq. and 40 CFR Part 52, Subpart E]

SN	Description	Pollutant	lb/hr	tpy
SN-19 (X23)	Grit Blaster	PM <sub>10</sub>	0.7	2.7

89. The permittee shall not exceed the emission rates set forth in the following table.  
[Regulation 18, §18.801, and A.C.A. §8-4-203 as referenced by A.C.A. §8-4-304 and §8-4-311]

SN	Description	Pollutant	lb/hr	tpy
SN-19 (X23)	Grit Blaster	PM	1.8	7.6

90. The permittee shall not cause to be emitted from this source any emission which exhibit an opacity greater than 5 percent. The opacity shall be measured in accordance with EPA Reference Method 9. [Regulation 18, §18.501 and A.C.A. §8-4-203 as referenced by §8-4-304 and §8-4-311]
91. The permittee shall operate the baghouse according to the manufacturer's specifications. Compliance with this specific condition may demonstrate compliance with Specific Condition # 90. [Regulation 19, §19.303 and A.C.A. §8-4-203 as referenced by §8-4-304 and §8-4-311]

SN-20  
 Emergency Diesel Generator

Source Description

The Independence Plant is equipped with an 1100 Hp emergency diesel generator (SN-20).

Specific Conditions

92. The permittee shall not exceed the emission rates set forth in the following table. The permittee shall demonstrate compliance with this condition by Specific Conditions # 94 through # 96. [Regulation 19, §19.501 et seq. and 40 CFR Part 52, Subpart E]

SN	Description	Pollutant	lb/hr	tpy
SN-20 (C4)	Emergency Diesel Generator	PM <sub>10</sub>	0.6	0.7
		SO <sub>2</sub>	4.2	4.5
		VOC	0.8	0.8
		CO	7.0	7.6
		NO <sub>x</sub>	26.3	28.5

93. The permittee shall not exceed the emission rates set forth in the following table. The permittee shall demonstrate compliance with this condition by Specific Conditions # 94 through # 96, and # 99. [Regulation 18, §18.801, and A.C.A. §8-4-203 as referenced by A.C.A. §8-4-304 and §8-4-311]

SN	Description	Pollutant	lb/hr	tpy
SN-20 (C4)	Emergency Diesel Generator	PM	0.6	0.7
		Acenaphthene	0.01	0.01
		Acenaphthylene	0.01	0.01
		Acetaldehyde	0.01	0.01
		Acrolein	0.01	0.01
		Anthracene	0.01	0.01
		Benzene	0.01	0.01
		Fluoranthene	0.01	0.01
		Fluorene	0.01	0.01
		Formaldehyde	0.01	0.01
		Phenanthrene	0.01	0.01
		Pyrene	0.01	0.01
		Toluene	0.01	0.01

94. The permittee shall not exceed 20% opacity from SN-20 as measured by EPA Reference Method 9. Compliance with this Specific Condition shall be demonstrated by

compliance with Specific Condition # 98. [Regulation 19, §19.503, and A.C.A. §8-4-203 as referenced by §8-4-304 and §8-4-311, and 40 CFR Part 52, Subpart E]

95. The permittee shall not operate the emergency diesel generator (SN-20) in excess of 2,160 hours during any consecutive twelve-month period. [Regulation 19, §19.705 and A.C.A. §8-4-203 as referenced by §8-4-304 and §8-4-311]
96. The permittee shall only use diesel fuel, with a Sulfur content not greater than 0.5% by weight, to fire the emergency diesel generator (SN-20). Compliance with this Specific Condition shall be demonstrated by compliance with Specific Conditions # 32 and # 33. [Regulation 19, §19.705, A.C.A. §8-4-203 as referenced by A.C.A. §8-4-304 and §8-4-311, and 40 CFR 70.6]
97. The permittee shall maintain records of the hours of operation of the emergency diesel generator (SN-20) which demonstrate compliance with Specific Condition # 95. These records shall be updated on a monthly basis, shall be kept at the nearest manned site, and shall be provided to Department personnel upon request. An annual total and each individual month's data shall be submitted in accordance with General Provision # 7. [Regulation 19, §19.705 and A.C.A. §8-4-203 as referenced by §8-4-304 and §8-4-311]
98. The permittee shall conduct annual visible emissions observations as a method of compliance verification for the opacity limit assigned for SN-20. Observations shall be conducted by someone trained in EPA Reference Method 9. Whenever SN-20 is in operation for more than 24 consecutive hours, the permittee shall conduct daily visible emissions observations as a method of compliance verification for the opacity limit assigned for SN-20. If during the observations, visible emissions are detected which appear to be in excess of the permitted opacity limit, the permittee shall:
  - a. Take immediate action to identify the cause of the visible emissions,
  - b. Implement corrective action, and
  - c. If excessive visible emissions are still detected, an opacity reading shall be conducted in accordance with EPA Reference Method 9 for point sources and in accordance with EPA Method 22 for non-point sources. This reading shall be conducted by a person trained and certified in the reference method. If the opacity reading exceeds the permitted limit, further corrective measures shall be taken.
  - d. If no excessive visible emissions are detected, the incident shall be noted in the records as described below.

The permittee shall maintain records related to all visible emission observations and Method 9 readings. These records shall be updated on an as-performed basis. These records shall be kept on site and made available to Department personnel upon request. These records shall contain:

- e. The time and date of each observation/reading,

Entergy Arkansas, Inc. - Independence Plant  
Permit #: 0449-AOP-R7  
AFIN: 32-00042

- f. Any observance of visible emissions appearing to be above permitted limits or any Method 9 reading which indicates exceedance,
  - g. The cause of any observed exceedance of opacity limits, corrective actions taken, and results of the reassessment, and
  - h. The name of the person conducting the observation/reading.
99. SN-20 is subject to 40 CFR Part 63, Subpart ZZZZ. The permittee shall comply with all applicable provisions of 40 CFR Part 63, Subpart ZZZZ which includes, but is not limited to, Specific Condition # 100. [Regulation 19, §19.304 and 40 CFR Part 63, Subpart ZZZZ]
100. The permittee shall operate SN-20 according to the requirements in paragraphs (f)(2)(i) through (iii) of §63.6640. If the permittee does not operate the engine according to the requirements in paragraphs (f) (2) (i) through (iii) of §63.6640, the engine will not be considered an emergency engine under 40 CFR Part 63, Subpart ZZZZ and will need to meet all requirements for non-emergency engines.
- a. There is no time limit on the use of emergency stationary RICE in emergency situations.
  - b. The permittee may operate SN-20 for the purpose of maintenance checks and readiness testing, provided that the tests are recommended by the manufacturer, the vendor, or the insurance company associated with the engine. Required testing of such units should be minimized, but there is no time limit on the use of emergency stationary RICE in emergency situations and for routine testing and maintenance.
  - c. The permittee may operate SN-20 up to 50 hours per year in non-emergency situations, The 50 hours per year for non-emergency situations cannot be used for peak shaving or to generate income for a facility to supply power to an electric grid or otherwise supply power as part of a financial arrangement with another entity.

[Regulation 19, §19.304 and 40 CFR §63.6640(f)(2)]

SN-21  
 Emergency Diesel Fire Pump

Source Description

The Independence Plant is equipped with a 342 Hp emergency diesel fire pump engine (SN-21).

Specific Conditions

101. The permittee shall not exceed the emission rates set forth in the following table. The permittee shall demonstrate compliance with this condition by Specific Conditions # 103 through # 105. [Regulation 19, §19.501 et seq. and 40 CFR Part 52, Subpart E]

SN	Description	Pollutant	lb/hr	tpy
SN-21 (C5)	Emergency Diesel Fire Pump	PM <sub>10</sub>	0.9	1.3
		SO <sub>2</sub>	0.8	1.2
		VOC	1.0	1.5
		CO	2.7	3.9
		NO <sub>x</sub>	12.1	18.2

102. The permittee shall not exceed the emission rates set forth in the following table. The permittee shall demonstrate compliance with this condition by Specific Conditions # 103 through # 105, and # 108. [Regulation 18, §18.801, and A.C.A. §8-4-203 as referenced by A.C.A. §8-4-304 and §8-4-311]

SN	Description	Pollutant	lb/hr	tpy
SN-21 (C5)	Emergency Diesel Fire Pump	PM	0.9	1.3
		Acenaphthene	0.01	0.01
		Acenaphthylene	0.01	0.01
		Acetaldehyde	0.01	0.01
		Acrolein	0.01	0.01
		Anthracene	0.01	0.01
		Benzene	0.01	0.01
		Fluoranthene	0.01	0.01
		Fluorene	0.01	0.01
		Formaldehyde	0.01	0.01
		Phenanthrene	0.01	0.01
		Pyrene	0.01	0.01
		Toluene	0.01	0.01

103. The permittee shall not exceed 20% opacity from SN-21 as measured by EPA Reference Method 9. Compliance with this Specific Condition shall be demonstrated by

compliance with Specific Condition # 107. [Regulation 19, §19.503, A.C.A. §8-4-203 as referenced by §8-4-304 and §8-4-311, and 40 CFR Part 52, Subpart E]

104. The permittee shall not operate the emergency diesel fire pump (SN-21) in excess of 3,000 hours during any consecutive twelve-month period. [Regulation 19, §19.705 and A.C.A. §8-4-203 as referenced by §8-4-304 and §8-4-311]
105. The permittee shall only use diesel fuel, with a Sulfur content not greater than 0.5% by weight, to fire the emergency diesel fire pump (SN-21). Compliance with this Specific Condition shall be demonstrated by compliance with Specific Conditions # 32 and # 33. [Regulation 19, §19.705, A.C.A. §8-4-203 as referenced by A.C.A. §8-4-304 and §8-4-311, and 40 CFR 70.6]
106. The permittee shall maintain records of the hours of operation of the emergency diesel fire pump (SN-21) which demonstrate compliance with Specific Condition # 104. These records shall be updated on a monthly basis, shall be kept at the nearest manned site, and shall be provided to Department personnel upon request. An annual total and each individual month's data shall be submitted in accordance with General Provision # 7. [Regulation 19, §19.705 and A.C.A. §8-4-203 as referenced by §8-4-304 and §8-4-311]
107. The permittee shall conduct annual visible emissions observations as a method of compliance verification for the opacity limit assigned for SN-21. Observations shall be conducted by someone trained in EPA Reference Method 9. Whenever SN-21 is in operation for more than 24 consecutive hours, the permittee shall conduct daily visible emissions observations as a method of compliance verification for the opacity limit assigned for SN-21. If during the observations, visible emissions are detected which appear to be in excess of the permitted opacity limit, the permittee shall:
  - a. Take immediate action to identify the cause of the visible emissions,
  - b. Implement corrective action, and
  - c. If excessive visible emissions are still detected, an opacity reading shall be conducted in accordance with EPA Reference Method 9 for point sources and in accordance with EPA Method 22 for non-point sources. This reading shall be conducted by a person trained and certified in the reference method. If the opacity reading exceeds the permitted limit, further corrective measures shall be taken.
  - d. If no excessive visible emissions are detected, the incident shall be noted in the records as described below.

The permittee shall maintain records related to all visible emission observations and Method 9 readings. These records shall be updated on an as-performed basis. These records shall be kept on site and made available to Department personnel upon request. These records shall contain:

- e. The time and date of each observation/reading,

- f. Any observance of visible emissions appearing to be above permitted limits or any Method 9 reading which indicates exceedance,
  - g. The cause of any observed exceedance of opacity limits, corrective actions taken, and results of the reassessment, and
  - h. The name of the person conducting the observation/reading.
108. SN-21 is subject to 40 CFR Part 63, Subpart ZZZZ. The permittee shall comply with all applicable provisions of 40 CFR Part 63, Subpart ZZZZ which includes, but is not limited to, Specific Conditions # 109 through # 121. [Regulation 19, §19.304 and 40 CFR Part 63, Subpart ZZZZ]
109. The permittee shall be in compliance with the applicable emission limitations and operating limitations in 40 CFR Part 63, Subpart ZZZZ at all times. [Regulation 19, §19.304 and 40 CFR §63.6605(a)]
110. At all times the permittee shall operate and maintain any affected source, including associated air pollution control equipment and monitoring equipment, in a manner consistent with safety and good air pollution control practices for minimizing emissions. The general duty to minimize emissions does not require you to make any further efforts to reduce emissions if levels required by this standard have been achieved. Determination of whether such operation and maintenance procedures are being used will be based on information available to the Administrator which may include, but is not limited to, monitoring results, review of operation and maintenance procedures, review of operation and maintenance records, and inspection of the source. [Regulation 19, §19.304 and 40 CFR §63.6605(b)]
111. The permittee shall operate and maintain SN-21 according to the manufacturer's emission-related written instructions or develop your own maintenance plan which must provide to the extent practicable for the maintenance and operation of the engine in a manner consistent with good air pollution control practice for minimizing emissions. [Regulation 19, §19.304, and 40 CFR §63.6625(e)]
112. The permittee shall install a non-resettable hour meter at SN-21. [Regulation 19, §19.304 and 40 CFR §63.6625(f)]
113. The permittee shall minimize the engine's time spent at idle during startup and minimize the engine's startup time to a period needed for appropriate and safe loading of the engine, not to exceed 30 minutes. [Regulation 19, §19.304, and 40 CFR §63.6625(h)]
114. The permittee has the option of utilizing an oil analysis program at SN-21 in order to extend the specified oil change requirement in Table 2c to 40 CFR Part 63, Subpart ZZZZ. The oil analysis must be performed at the same frequency specified for changing the oil in Table 2c to 40 CFR Part 63, Subpart ZZZZ. The analysis program must at a minimum analyze the following three parameters: Total Base Number, viscosity, and percent water content. The condemning limits for these parameters are as follows: Total

Base Number is less than 30 percent of the Total Base Number of the oil when new; viscosity of the oil has changed by more than 20 percent from the viscosity of the oil when new; or percent water content (by volume) is greater than 0.5. If all of these condemning limits are not exceeded, the engine owner or operator is not required to change the oil. If any of the limits are exceeded, the engine owner or operator must change the oil within 2 days of receiving the results of the analysis; if the engine is not in operation when the results of the analysis are received, the engine owner or operator must change the oil within 2 days or before commencing operation, whichever is later. The owner or operator must keep records of the parameters that are analyzed as part of the program, the results of the analysis, and the oil changes for the engine. The analysis program must be part of the maintenance plan for the engine. [Regulation 19, §19.304 and 40 CFR §63.6625(i)]

115. As stated in §63.6602 and §63.6640, the permittee shall comply with the following requirements for existing stationary RICE located at area sources of HAP emissions:

For each	The permittee shall meet the following requirement, except during periods of startup	During periods of startup the permittee shall
SN-21 <sup>1</sup>	a. Change oil and filter every 500 hours of operation or annually, whichever comes first; <sup>2</sup> b. Inspect air cleaner every 1,000 hours of operation or annually, whichever comes first; and c. Inspect all hoses and belts every 500 hours of operation or annually, whichever comes first, and replace as necessary. <sup>3</sup>	Minimize the engine's time spent at idle and minimize the engine's startup time at startup to a period needed for appropriate and safe loading of the engine, not to exceed 30 minutes, after which time the non-startup emission limitations apply. <sup>3</sup>

1. If an emergency engine is operating during an emergency and it is not possible to shut down the engine in order to perform the work practice requirements on the schedule required in Table 2c of this subpart, or if performing the work practice on the required schedule would otherwise pose an unacceptable risk under Federal, State, or local law, the work practice can be delayed until the emergency is over or the unacceptable risk under Federal, State, or local law has abated. The work practice should be performed as soon as practicable after the emergency has ended or the unacceptable risk under Federal, State, or local law has abated. Sources must report any failure to perform the work practice on the schedule required and the Federal, State or local law under which the risk was deemed unacceptable.
2. Sources have the option to utilize an oil analysis program as described in §63.6625(i) in order to extend the specified oil change requirement in Table 2c of this subpart.
3. Sources can petition the Administrator pursuant to the requirements of 40 CFR 63.6(g) for alternative work practices.

[Regulation 19, §19.304, and 40 CFR §63.6602, §63.6640, and Table 2c]

116. The permittee shall report each instance in which the permittee did not meet each applicable emission limitation or operating limitation in Table 2c to 40 CFR Part 63, Subpart ZZZZ. These instances are deviations from the emission and operating limitations in 40 CFR Part 63, Subpart ZZZZ. These deviations must be reported

according to the requirements in §63.6650. If the permittee changes the catalyst, the permittee shall reestablish the values of the operating parameters measured during the initial performance test. When the permittee reestablishes the values of the operating parameters, the permittee shall also conduct performance test(s) to demonstrate that the permittee is meeting the required emission limitation applicable to the engine(s).  
[§19.304 of Regulation 19 and 40 CFR §63.6640(b)]

117. The permittee shall operate SN-21 according to the requirements in paragraphs (f) (1) (i) through (iii) of §63.6640. Any operation other than emergency operation, maintenance and testing, and operation in non-emergency situations for 50 hours per year, as described in paragraphs (f) (1) (i) through (iii) of §63.6640, is prohibited. If the permittee does not operate the engine according to the requirements in paragraphs (f) (1) (i) through (iii) of §63.6640, the engine will not be considered an emergency engine under 40 CFR Part 63, Subpart ZZZZ and will need to meet all requirements for non-emergency engines.
- a. There is no time limit on the use of emergency stationary RICE in emergency situations.
  - b. The permittee may operate SN-21 for the purpose of maintenance checks and readiness testing, provided that the tests are recommended by Federal, State or local government, the manufacturer, the vendor, or the insurance company associated with the engine. Maintenance checks and readiness testing of such units is limited to 100 hours per year. The owner or operator may petition the Administrator for approval of additional hours to be used for maintenance checks and readiness testing, but a petition is not required if the owner or operator maintains records indicating that Federal, State, or local standards require maintenance and testing of emergency RICE beyond 100 hours per year.
  - c. The permittee may operate SN-21 up to 50 hours per year in non-emergency situations, but those 50 hours are counted towards the 100 hours per year provided for maintenance and testing. The 50 hours per year for non-emergency situations cannot be used for peak shaving or to generate income for a facility to supply power to an electric grid or otherwise supply power as part of a financial arrangement with another entity; except that owners and operators may operate the emergency engine for a maximum of 15 hours per year as part of a demand response program if the regional transmission organization or equivalent balancing authority and transmission operator has determined there are emergency conditions that could lead to a potential electrical blackout, such as unusually low frequency, equipment overload, capacity or energy deficiency, or unacceptable voltage level. The engine may not be operated for more than 30 minutes prior to the time when the emergency condition is expected to occur, and the engine operation must be terminated immediately after the facility is notified that the emergency condition is no longer imminent. The 15 hours per year of demand response operation are counted as part of the 50 hours of operation per year provided for non-emergency situations. The supply of emergency power to another entity or entities pursuant to financial arrangement is not limited by this paragraph (f)(1)(iii), as long as the power provided by the financial arrangement is limited to emergency power.

[Regulation 19, §19.304 and 40 CFR §63.6640(f)(1)]

118. The permittee shall keep the records described in paragraphs (a) (1) through (a) (5), (b) (1) through (b) (3) and (c) of §63.6655.
- a. A copy of each notification and report that you submitted to comply with 40 CFR Part 63, Subpart ZZZZ, including all documentation supporting any Initial Notification or Notification of Compliance Status that you submitted, according to the requirement in §63.10(b)(2)(xiv).
  - b. Records of the occurrence and duration of each malfunction of operation (i.e., process equipment) or the air pollution control and monitoring equipment.
  - c. Records of performance tests and performance evaluations as required in §63.10(b) (2) (viii).
  - d. Records of all required maintenance performed on the air pollution control and monitoring equipment.
  - e. Records of actions taken during periods of malfunction to minimize emissions in accordance with §63.6605(b), including corrective actions to restore malfunctioning process and air pollution control and monitoring equipment to its normal or usual manner of operation.
  - f. For each CEMS or CPMS, the permittee shall keep the records listed in paragraphs (b) (1) through (3) of §63.6655.
  - g. Records described in §63.10(b) (2) (vi) through (xi).
  - h. Previous (i.e., superseded) versions of the performance evaluation plan as required in §63.8(d) (3).
  - i. Requests for alternatives to the relative accuracy test for CEMS or CPMS as required in §63.8(f) (6) (i), if applicable.

[Regulation 19, §19.304 and 40 CFR §63.6655(a) and (b)]

119. The permittee shall keep the records required in Table 6 of 40 CFR Part 63, Subpart ZZZZ to show continuous compliance with each applicable emission or operating limitation. [Regulation 19, §19.304 and 40 CFR §63.6655(d)]
120. The permittee shall keep records of the maintenance conducted on SN-21 in order to demonstrate that you operated and maintained the stationary RICE and after-treatment control device (if any) according to your own maintenance plan. [Regulation 19, §19.304 and 40 CFR §63.6655(e)]
121. The permittee shall keep records of the hours of operation of SN-21 that are recorded through the non-resettable hour meters. The permittee shall document how many hours are spent for emergency operation, including what classified the operation as emergency and how many hours are spent for non-emergency operation. If the engines are used for demand response operation, the permittee shall keep records of the notification of the emergency situation, and the time the engine was operated as part of demand response. [Regulation 19, §19.304 and 40 CFR §63.6655(f)]

Entergy Arkansas, Inc. - Independence Plant  
Permit #: 0449-AOP-R7  
AFIN: 32-00042

#### SECTION V: COMPLIANCE PLAN AND SCHEDULE

Entergy Arkansas, Inc. - Independence Plant will continue to operate in compliance with those identified regulatory provisions. The facility will examine and analyze future regulations that may apply and determine their applicability with any necessary action taken on a timely basis.

SECTION VI: PLANTWIDE CONDITIONS

1. The permittee shall notify the Director in writing within thirty (30) days after commencing construction, completing construction, first placing the equipment and/or facility in operation, and reaching the equipment and/or facility target production rate. [Regulation 19, §19.704, 40 CFR Part 52, Subpart E, and A.C.A. §8-4-203 as referenced by A.C.A. §8-4-304 and §8-4-311]
2. If the permittee fails to start construction within eighteen months or suspends construction for eighteen months or more, the Director may cancel all or part of this permit. [Regulation 19, §19.410(B) and 40 CFR Part 52, Subpart E]
3. The permittee must test any equipment scheduled for testing, unless otherwise stated in the Specific Conditions of this permit or by any federally regulated requirements, within the following time frames: (1) new equipment or newly modified equipment within sixty (60) days of achieving the maximum production rate, but no later than 180 days after initial start up of the permitted source or (2) operating equipment according to the time frames set forth by the Department or within 180 days of permit issuance if no date is specified. The permittee must notify the Department of the scheduled date of compliance testing at least fifteen (15) business days in advance of such test. The permittee shall submit the compliance test results to the Department within thirty (30) calendar days after completing the testing. [Regulation 19, §19.702 and/or Regulation 18 §18.1002 and A.C.A. §8-4-203 as referenced by A.C.A. §8-4-304 and §8-4-311]
4. The permittee must provide:
  - a. Sampling ports adequate for applicable test methods;
  - b. Safe sampling platforms;
  - c. Safe access to sampling platforms; and
  - d. Utilities for sampling and testing equipment.

[Regulation 19, §19.702 and/or Regulation 18, §18.1002 and A.C.A. §8-4-203 as referenced by A.C.A. §8-4-304 and §8-4-311]

5. The permittee must operate the equipment, control apparatus and emission monitoring equipment within the design limitations. The permittee shall maintain the equipment in good condition at all times. [Regulation 19, §19.303 and A.C.A. §8-4-203 as referenced by A.C.A. §8-4-304 and §8-4-311]
6. This permit subsumes and incorporates all previously issued air permits for this facility. [Regulation 26 and A.C.A. §8-4-203 as referenced by A.C.A. §8-4-304 and §8-4-311]

Entergy Arkansas, Inc. - Independence Plant  
Permit #: 0449-AOP-R7  
AFIN: 32-00042

#### Acid Rain (Title IV)

7. The Director prohibits the permittee to cause any emissions exceeding any allowances the source lawfully holds under Title IV of the Act or the regulations promulgated under the Act. No permit revision is required for increases in emissions allowed by allowances acquired pursuant to the acid rain program, if such increases do not require a permit revision under any other applicable requirement. This permit establishes no limit on the number of allowances held by the permittee. However, the source may not use allowances as a defense for noncompliance with any other applicable requirement of this permit or the Act. The permittee will account for any such allowance according to the procedures established in regulations promulgated under Title IV of the Act. A copy of the facility's Acid Rain Permit is attached in an appendix to this Title V permit. [Regulation 26, §26.701 and 40 CFR 70.6(a)(4)]

#### Clean Air Interstate Rule (CAIR)

8. The permittee shall comply with the monitoring, reporting, and recordkeeping requirements of subpart HHHH of 40 CFR part 96. The permittee shall comply with the NO<sub>x</sub> emission requirements established under CAIR. The Permittee shall report and maintain the records required by subpart HHHH of 40 CFR part 96. A copy of the CAIR permit is attached to this Title V permit. [Regulation No. 19 §19.1401 and 40 CFR Part 52, Subpart E]

#### Title VI Provisions

9. The permittee must comply with the standards for labeling of products using ozone-depleting substances. [40 CFR Part 82, Subpart E]
  - a. All containers containing a class I or class II substance stored or transported, all products containing a class I substance, and all products directly manufactured with a class I substance must bear the required warning statement if it is being introduced to interstate commerce pursuant to §82.106.
  - b. The placement of the required warning statement must comply with the requirements pursuant to §82.108.
  - c. The form of the label bearing the required warning must comply with the requirements pursuant to §82.110.
  - d. No person may modify, remove, or interfere with the required warning statement except as described in §82.112.
10. The permittee must comply with the standards for recycling and emissions reduction, except as provided for MVACs in Subpart B. [40 CFR Part 82, Subpart F]
  - a. Persons opening appliances for maintenance, service, repair, or disposal must comply with the required practices pursuant to §82.156.

- b. Equipment used during the maintenance, service, repair, or disposal of appliances must comply with the standards for recycling and recovery equipment pursuant to §82.158.
  - c. Persons performing maintenance, service repair, or disposal of appliances must be certified by an approved technician certification program pursuant to §82.161.
  - d. Persons disposing of small appliances, MVACs, and MVAC like appliances must comply with record keeping requirements pursuant to §82.166. (“MVAC like appliance” as defined at §82.152)
  - e. Persons owning commercial or industrial process refrigeration equipment must comply with leak repair requirements pursuant to §82.156.
  - f. Owners/operators of appliances normally containing 50 or more pounds of refrigerant must keep records of refrigerant purchased and added to such appliances pursuant to §82.166.
11. If the permittee manufactures, transforms, destroys, imports, or exports a class I or class II substance, the permittee is subject to all requirements as specified in 40 CFR Part 82, Subpart A, Production and Consumption Controls.
12. If the permittee performs a service on motor (fleet) vehicles when this service involves ozone depleting substance refrigerant (or regulated substitute substance) in the motor vehicle air conditioner (MVAC), the permittee is subject to all the applicable requirements as specified in 40 CFR part 82, Subpart B, Servicing of Motor Vehicle Air Conditioners.
- The term “motor vehicle” as used in Subpart B does not include a vehicle in which final assembly of the vehicle has not been completed. The term “MVAC” as used in Subpart B does not include the air tight sealed refrigeration system used as refrigerated cargo, or the system used on passenger buses using HCFC 22 refrigerant.
13. The permittee can switch from any ozone depleting substance to any alternative listed in the Significant New Alternatives Program (SNAP) promulgated pursuant to 40 CFR Part 82, Subpart G.

Permit Shield

14. Compliance with the conditions of this permit shall be deemed compliance with all applicable requirements, as of the date of permit issuance, included in and specifically identified in the following table of this condition. The permit specifically identifies the following as applicable requirements based upon the information submitted by the permittee in an application dated November 27, 2002.

Applicable Regulations

Regulation	Description	Basis
Regulations of the Arkansas	Regulation 26	Facility is defined as a major source.

Entergy Arkansas, Inc. - Independence Plant  
 Permit #: 0449-AOP-R7  
 AFIN: 32-00042

Regulation	Description	Basis
Operating Air Permit Program	Section 3	
State Implementation Plan, Prevention of Significant Deterioration Supplement	Regulation 19 §19.9	Facility is currently a major stationary source for the purpose of applicability.
New Source Performance Standards for Fossil-Fuel-Fired Steam Generators after August 17, 1978	40 CFR 60 Subpart D	Fossil-fuel fired steam generating units have heat input rate greater than 250 MMBtu/hr.
National Emission Standards for Hazardous Air Pollutants	40 CFR 61 Subpart M	Facility meets requirements for asbestos.
Acid Rain Permit Regulations	40 CFR 72 Subpart A-D	Units meet the definition of an affected source.
SO <sub>2</sub> Allowance Allocations	40 CFR 73 Subpart B	Facility is on list of Phase II Allowance Allocations.
Continuous Emission Monitoring	40 CFR 75 Subpart A-D, F, and G	Facility is subject to Acid Rain Requirements for the purpose of applicability.
NO <sub>x</sub> Emission Reduction Program	40 CFR 76	Facility is subject to Acid Rain Requirements for the purpose of applicability.
Excess Emissions	40 CFR 77	Facility is subject to Acid Rain Requirements for the purpose of applicability.
Prevention of Significant Deterioration of Air Quality (PSD)	40 CFR 52.21	Facility is subject to PSD requirements.
Compliance Assurance Monitoring (CAM)	40 CFR 64	Facility is subject to CAM requirements.
Protection of Stratospheric Ozone	40 CFR 82	Facility is subject to these requirements.

The permit specifically identifies the following as inapplicable based upon information submitted by the permittee in an application dated November 27, 2002.

#### Inapplicable Regulations

Source No.	Regulation	Description
N/A		

- The annual throughput of coal at the facility shall not exceed 9.2 million tons of coal per any consecutive twelve month period. [Regulation 19, §19.705, A.C.A. §8-4-203 as referenced by §8-4-304 and §8-4-311, and 40 CFR 70.6]

Entergy Arkansas, Inc. - Independence Plant  
Permit #: 0449-AOP-R7  
AFIN: 32-00042

16. The permittee shall maintain records which demonstrate compliance with the limit set in Plantwide Condition # 15. These records shall be updated on a monthly basis, shall be kept on site, shall be provided to Department personnel upon request, and shall be submitted in accordance with General Provision #7. [Regulation 19, §19.705, and 40 CFR Part 52, Subpart E]
17. The permittee shall submit a compliance certification with state-only enforceable terms and conditions contained in the permit, including emission limitations, standards, or work practices. This compliance certification shall be submitted annually to the Department. All compliance certifications required by this permit shall include the following:
  - a. The identification of each term or condition of the permit that is the basis of the certification;
  - b. The compliance status;
  - c. Whether compliance was continuous or intermittent;
  - d. The method(s) used for determining the compliance status of the source, currently and over the reporting period established by the monitoring requirements of this permit; and
  - e. Such other facts as the Department may require elsewhere in this permit.

This compliance certification may be in the same format as, and may be included with, the annual compliance certification required by General Provision 21. [Regulation 18, §18.1004]

SECTION VII: INSIGNIFICANT ACTIVITIES

The following sources are insignificant activities. Any activity that has a state or federal applicable requirement shall be considered a significant activity even if this activity meets the criteria of §26.304 of Regulation 26 or listed in the table below. Insignificant activity determinations rely upon the information submitted by the permittee in an application dated November 23, 2009.

Description	Category
Microwave Tower Propane Generator (C6), Kerosene Fired Space Heaters #1-#4 (C7-C10)	A-1
Storage tanks less than 250 gallons storing organic liquids having a true vapor pressure less than or equal to 3.5 psia, provided that the aggregate pollutant specific emissions from all such liquid storage tanks listed as insignificant do not exceed 5 tpy of any combination of HAPs and 10 tpy of any other pollutant. (T52, T63-T65)	A-2
Storage tanks less than 10,000 gallons storing organic liquids having a true vapor pressure less than or equal to 0.5 psia, provided that the aggregate pollutant specific emissions from all such liquid storage tanks listed as insignificant do not exceed 5 tpy of any combination of HAPs and 10 tpy of any other pollutant. (T3-T12, T14-T26, T28, T32-T33, T47-T48)	A-3
Caustic storage tank containing no VOCs. (T36B, T36C, T37)	A-4
Emissions from laboratory equipment/vents (V38 and V39)	A-5
Other activities for which the facility demonstrates that no enforceable permit conditions are necessary to insure compliance with any applicable law or regulation provided that the emissions are less than 5 tpy of any pollutant regulated under this regulation or less than 1 tpy of a single HAP or 2.5 tpy of any combination of HAPs. Unit 1 Turbine Lube Oil Storage Tank (T2), Unit 2 Lube Oil Storage Tank (T13), Unleaded Gasoline Storage Tank - 500 gal (T30), Oil/Water Separator (W5-W7), Oil/Waste Basin (W8), Turbine Area Sump (W9), Fuel Dispensing Stations (X1-X8), Welding Area (X10-X15), Transformers (X24-X28), Switchyard Oil Circuit Breaker (X29), Unit 1 and Unit 2 Battery Room (X30-X31), Common Battery Room (X32), Metalizer (X34), Aerosol Lubricant Fugitives (X57), Aerosol Degreaser Fugitives (X58), Aerosol Puncture Station, and Insecticide Fugitives (X59)	A-13
AC Chiller – Pressure Tanks (X38-X45 and X53-X56)	Pressure Tanks No Emissions

SECTION VIII: GENERAL PROVISIONS

1. Any terms or conditions included in this permit which specify and reference Arkansas Pollution Control & Ecology Commission Regulation 18 or the Arkansas Water and Air Pollution Control Act (A.C.A. §8-4-101 et seq.) as the sole origin of and authority for the terms or conditions are not required under the Clean Air Act or any of its applicable requirements, and are not federally enforceable under the Clean Air Act. Arkansas Pollution Control & Ecology Commission Regulation 18 was adopted pursuant to the Arkansas Water and Air Pollution Control Act (A.C.A. §8-4-101 et seq.). Any terms or conditions included in this permit which specify and reference Arkansas Pollution Control & Ecology Commission Regulation 18 or the Arkansas Water and Air Pollution Control Act (A.C.A. §8-4-101 et seq.) as the origin of and authority for the terms or conditions are enforceable under this Arkansas statute. [40 CFR 70.6(b)(2)]
2. This permit shall be valid for a period of five (5) years beginning on the date this permit becomes effective and ending five (5) years later. [40 CFR 70.6(a)(2) and §26.701(B) of the Regulations of the Arkansas Operating Air Permit Program (Regulation 26)]
3. The permittee must submit a complete application for permit renewal at least six (6) months before permit expiration. Permit expiration terminates the permittee's right to operate unless the permittee submitted a complete renewal application at least six (6) months before permit expiration. If the permittee submits a complete application, the existing permit will remain in effect until the Department takes final action on the renewal application. The Department will not necessarily notify the permittee when the permit renewal application is due. [Regulation 26, §26.406]
4. Where an applicable requirement of the Clean Air Act, as amended, 42 U.S.C. 7401, et seq. (Act) is more stringent than an applicable requirement of regulations promulgated under Title IV of the Act, the permit incorporates both provisions into the permit, and the Director or the Administrator can enforce both provisions. [40 CFR 70.6(a)(1)(ii) and Regulation 26, §26.701(A)(2)]
5. The permittee must maintain the following records of monitoring information as required by this permit.
  - a. The date, place as defined in this permit, and time of sampling or measurements;
  - b. The date(s) analyses performed;
  - c. The company or entity performing the analyses;
  - d. The analytical techniques or methods used;
  - e. The results of such analyses; and
  - f. The operating conditions existing at the time of sampling or measurement.

[40 CFR 70.6(a)(3)(ii)(A) and Regulation 26, §26.701(C)(2)]

Entergy Arkansas, Inc. - Independence Plant  
Permit #: 0449-AOP-R7  
AFIN: 32-00042

6. The permittee must retain the records of all required monitoring data and support information for at least five (5) years from the date of the monitoring sample, measurement, report, or application. Support information includes all calibration and maintenance records and all original strip chart recordings for continuous monitoring instrumentation, and copies of all reports required by this permit. [40 CFR 70.6(a)(3)(ii)(B) and Regulation 26, §26.701(C)(2)(b)]
7. The permittee must submit reports of all required monitoring every six (6) months. If permit establishes no other reporting period, the reporting period shall end on the last day of the anniversary month of the initial Title V permit. The report is due within thirty (30) days of the end of the reporting period. Although the reports are due every six months, each report shall contain a full year of data. The report must clearly identify all instances of deviations from permit requirements. A responsible official as defined in Regulation No. 26, §26.2 must certify all required reports. The permittee will send the reports to the address below:

Arkansas Department of Environmental Quality  
Air Division  
ATTN: Compliance Inspector Supervisor  
5301 Northshore Drive  
North Little Rock, AR 72118-5317

[40 C.F.R. 70.6(a)(3)(iii)(A) and Regulation 26, §26.701(C)(3)(a)]

8. The permittee shall report to the Department all deviations from permit requirements, including those attributable to upset conditions as defined in the permit.
  - a. For all upset conditions (as defined in Regulation 19, § 19.601), the permittee will make an initial report to the Department by the next business day after the discovery of the occurrence. The initial report may be made by telephone and shall include:
    - i. The facility name and location;
    - ii. The process unit or emission source deviating from the permit limit;
    - iii. The permit limit, including the identification of pollutants, from which deviation occurs;
    - iv. The date and time the deviation started;
    - v. The duration of the deviation;
    - vi. The average emissions during the deviation;
    - vii. The probable cause of such deviations;
    - viii. Any corrective actions or preventive measures taken or being taken to prevent such deviations in the future; and
    - ix. The name of the person submitting the report.

The permittee shall make a full report in writing to the Department within five (5) business days of discovery of the occurrence. The report must include, in addition to the information required by the initial report, a schedule of actions taken or planned to eliminate future occurrences and/or to minimize the amount the permit's limits were exceeded and to reduce the length of time the limits were exceeded. The permittee may submit a full report in writing (by facsimile, overnight courier, or other means) by the next business day after discovery of the occurrence, and the report will serve as both the initial report and full report.

- b. For all deviations, the permittee shall report such events in semi-annual reporting and annual certifications required in this permit. This includes all upset conditions reported in 8a above. The semi-annual report must include all the information as required by the initial and full reports required in 8a.

[Regulation 19, §19.601 and §19.602, Regulation 26, §26.701(C)(3)(b), and 40 CFR 70.6(a)(3)(iii)(B)]

9. If any provision of the permit or the application thereof to any person or circumstance is held invalid, such invalidity will not affect other provisions or applications hereof which can be given effect without the invalid provision or application, and to this end, provisions of this Regulation are declared to be separable and severable. [40 CFR 70.6(a)(5), Regulation 26, §26.701(E), and A.C.A. §8-4-203 as referenced by A.C.A. §8-4-304 and §8-4-311]
10. The permittee must comply with all conditions of this Part 70 permit. Any permit noncompliance with applicable requirements as defined in Regulation 26 constitutes a violation of the Clean Air Act, as amended, 42 U.S.C. §7401, et seq. and is grounds for enforcement action; for permit termination, revocation and reissuance, for permit modification; or for denial of a permit renewal application. [40 CFR 70.6(a)(6)(i) and Regulation 26, §26.701(F)(1)]
11. It shall not be a defense for a permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity to maintain compliance with the conditions of this permit. [40 CFR 70.6(a)(6)(ii) and Regulation 26, §26.701(F)(2)]
12. The Department may modify, revoke, reopen and reissue the permit or terminate the permit for cause. The filing of a request by the permittee for a permit modification, revocation and reissuance, termination, or of a notification of planned changes or anticipated noncompliance does not stay any permit condition. [40 CFR 70.6(a)(6)(iii) and Regulation 26, §26.701(F)(3)]
13. This permit does not convey any property rights of any sort, or any exclusive privilege. [40 CFR 70.6(a)(6)(iv) and Regulation 26, §26.701(F)(4)]

Entergy Arkansas, Inc. - Independence Plant  
Permit #: 0449-AOP-R7  
AFIN: 32-00042

14. The permittee must furnish to the Director, within the time specified by the Director, any information that the Director may request in writing to determine whether cause exists for modifying, revoking and reissuing, or terminating the permit or to determine compliance with the permit. Upon request, the permittee must also furnish to the Director copies of records required by the permit. For information the permittee claims confidentiality, the Department may require the permittee to furnish such records directly to the Director along with a claim of confidentiality. [40 CFR 70.6(a)(6)(v) and Regulation 26, §26.701(F)(5)]
15. The permittee must pay all permit fees in accordance with the procedures established in Regulation 9. [40 CFR 70.6(a)(7) and Regulation 26, §26.701(G)]
16. No permit revision shall be required, under any approved economic incentives, marketable permits, emissions trading and other similar programs or processes for changes provided for elsewhere in this permit. [40 CFR 70.6(a)(8) and Regulation 26, §26.701(H)]
17. If the permit allows different operating scenarios, the permittee shall, contemporaneously with making a change from one operating scenario to another, record in a log at the permitted facility a record of the operational scenario. [40 CFR 70.6(a)(9)(i) and Regulation 26, §26.701(I)(1)]
18. The Administrator and citizens may enforce under the Act all terms and conditions in this permit, including any provisions designed to limit a source's potential to emit, unless the Department specifically designates terms and conditions of the permit as being federally unenforceable under the Act or under any of its applicable requirements. [40 CFR 70.6(b) and Regulation 26, §26.702(A) and (B)]
19. Any document (including reports) required by this permit must contain a certification by a responsible official as defined in Regulation 26, §26.2. [40 CFR 70.6(c)(1) and Regulation 26, §26.703(A)]
20. The permittee must allow an authorized representative of the Department, upon presentation of credentials, to perform the following: [40 CFR 70.6(c)(2) and Regulation 26, §26.703(B)]
  - a. Enter upon the permittee's premises where the permitted source is located or emissions related activity is conducted, or where records must be kept under the conditions of this permit;
  - b. Have access to and copy, at reasonable times, any records required under the conditions of this permit;
  - c. Inspect at reasonable times any facilities, equipment (including monitoring and air pollution control equipment), practices, or operations regulated or required under this permit; and

Entergy Arkansas, Inc. - Independence Plant  
Permit #: 0449-AOP-R7  
AFIN: 32-00042

- d. As authorized by the Act, sample or monitor at reasonable times substances or parameters for assuring compliance with this permit or applicable requirements.
21. The permittee shall submit a compliance certification with the terms and conditions contained in the permit, including emission limitations, standards, or work practices. The permittee must submit the compliance certification annually within 30 days following the last day of the anniversary month of the initial Title V permit. The permittee must also submit the compliance certification to the Administrator as well as to the Department. All compliance certifications required by this permit must include the following: [40 CFR 70.6(c)(5) and Regulation 26, §26.703(E)(3)]
  - a. The identification of each term or condition of the permit that is the basis of the certification;
  - b. The compliance status;
  - c. Whether compliance was continuous or intermittent;
  - d. The method(s) used for determining the compliance status of the source, currently and over the reporting period established by the monitoring requirements of this permit; and
  - e. Such other facts as the Department may require elsewhere in this permit or by §114(a)(3) and §504(b) of the Act.
22. Nothing in this permit will alter or affect the following: [Regulation 26, §26.704(C)]
  - a. The provisions of Section 303 of the Act (emergency orders), including the authority of the Administrator under that section;
  - b. The liability of the permittee for any violation of applicable requirements prior to or at the time of permit issuance;
  - c. The applicable requirements of the acid rain program, consistent with §408(a) of the Act; or
  - d. The ability of EPA to obtain information from a source pursuant to §114 of the Act.
23. This permit authorizes only those pollutant emitting activities addressed in this permit. [A.C.A. §8-4-203 as referenced by A.C.A. §8-4-304 and §8-4-311]
24. The permittee may request in writing and at least 15 days in advance of the deadline, an extension to any testing, compliance or other dates in this permit. No such extensions are authorized until the permittee receives written Department approval. The Department may grant such a request, at its discretion in the following circumstances:
  - a. Such an extension does not violate a federal requirement;
  - b. The permittee demonstrates the need for the extension; and
  - c. The permittee documents that all reasonable measures have been taken to meet the current deadline and documents reasons it cannot be met.

Entergy Arkansas, Inc. - Independence Plant  
Permit #: 0449-AOP-R7  
AFIN: 32-00042

[Regulation 18, §18.314(A), Regulation 19, §19.416(A), Regulation 26, §26.1013(A), A.C.A. §8-4-203 as referenced by A.C.A. §8-4-304 and §8-4-311, and 40 CFR Part 52, Subpart E]

25. The permittee may request in writing and at least 30 days in advance, temporary emissions and/or testing that would otherwise exceed an emission rate, throughput requirement, or other limit in this permit. No such activities are authorized until the permittee receives written Department approval. Any such emissions shall be included in the facility's total emissions and reported as such. The Department may grant such a request, at its discretion under the following conditions:
- a. Such a request does not violate a federal requirement;
  - b. Such a request is temporary in nature;
  - c. Such a request will not result in a condition of air pollution;
  - d. The request contains such information necessary for the Department to evaluate the request, including but not limited to, quantification of such emissions and the date/time such emission will occur;
  - e. Such a request will result in increased emissions less than five tons of any individual criteria pollutant, one ton of any single HAP and 2.5 tons of total HAPs; and
  - f. The permittee maintains records of the dates and results of such temporary emissions/testing.

[Regulation 18, §18.314(B), Regulation 19, §19.416(B), Regulation 26, §26.1013(B), A.C.A. §8-4-203 as referenced by A.C.A. §8-4-304 and §8-4-311, and 40 CFR Part 52, Subpart E]

26. The permittee may request in writing and at least 30 days in advance, an alternative to the specified monitoring in this permit. No such alternatives are authorized until the permittee receives written Department approval. The Department may grant such a request, at its discretion under the following conditions:
- f. The request does not violate a federal requirement;
  - g. The request provides an equivalent or greater degree of actual monitoring to the current requirements; and
  - h. Any such request, if approved, is incorporated in the next permit modification application by the permittee.

[Regulation 18, §18.314(C), Regulation 19, §19.416(C), Regulation 26, §26.1013(C), A.C.A. §8-4-203 as referenced by A.C.A. §8-4-304 and §8-4-311, and 40 CFR Part 52, Subpart E]

APPENDIX A  
40 CFR Part 60 Subpart D  
*Standards of Performance for Fossil-Fuel-Fired Steam Generators for Which Construction Is  
Commenced After August 17, 1971*

## **Subpart D—Standards of Performance for Fossil-Fuel-Fired Steam Generators for Which Construction Is Commenced After August 17, 1971**

**Source:** 72 FR 32717, June 13, 2007, unless otherwise noted.

### **§ 60.40 Applicability and designation of affected facility.**

(a) The affected facilities to which the provisions of this subpart apply are:

(1) Each fossil-fuel-fired steam generating unit of more than 73 megawatts (MW) heat input rate (250 million British thermal units per hour (MMBtu/hr)).

(2) Each fossil-fuel and wood-residue-fired steam generating unit capable of firing fossil fuel at a heat input rate of more than 73 MW (250 MMBtu/hr).

(b) Any change to an existing fossil-fuel-fired steam generating unit to accommodate the use of combustible materials, other than fossil fuels as defined in this subpart, shall not bring that unit under the applicability of this subpart.

(c) Except as provided in paragraph (d) of this section, any facility under paragraph (a) of this section that commenced construction or modification after August 17, 1971, is subject to the requirements of this subpart.

(d) The requirements of §§60.44 (a)(4), (a)(5), (b) and (d), and 60.45(f)(4)(vi) are applicable to lignite-fired steam generating units that commenced construction or modification after December 22, 1976.

(e) Any facility covered under subpart Da is not covered under this subpart.

### **§ 60.41 Definitions.**

As used in this subpart, all terms not defined herein shall have the meaning given them in the Act, and in subpart A of this part.

*Boiler operating day* means a 24-hour period between 12 midnight and the following midnight during which any fuel is combusted at any time in the steam-generating unit. It is not necessary for fuel to be combusted the entire 24-hour period.

*Coal* means all solid fuels classified as anthracite, bituminous, subbituminous, or lignite by ASTM D388 (incorporated by reference, see §60.17).

*Coal refuse* means waste-products of coal mining, cleaning, and coal preparation operations (e.g. culm, gob, etc.) containing coal, matrix material, clay, and other organic and inorganic material.

*Fossil fuel* means natural gas, petroleum, coal, and any form of solid, liquid, or gaseous fuel derived from such materials for the purpose of creating useful heat.

*Fossil fuel and wood residue-fired steam generating unit* means a furnace or boiler used in the process of burning fossil fuel and wood residue for the purpose of producing steam by heat transfer.

*Fossil-fuel-fired steam generating unit* means a furnace or boiler used in the process of burning fossil fuel for the purpose of producing steam by heat transfer.

*Wood residue* means bark, sawdust, slabs, chips, shavings, mill trim, and other wood products derived from wood processing and forest management operations.

**§ 60.42 Standard for particulate matter (PM).**

[Link to an amendment published at 76 FR 3522, Jan. 20, 2011.](#)

(a) On and after the date on which the performance test required to be conducted by §60.8 is completed, no owner or operator subject to the provisions of this subpart shall cause to be discharged into the atmosphere from any affected facility any gases that:

(1) Contain PM in excess of 43 nanograms per joule (ng/J) heat input (0.10 lb/MMBtu) derived from fossil fuel or fossil fuel and wood residue.

(2) Exhibit greater than 20 percent opacity except for one six-minute period per hour of not more than 27 percent opacity.

(b)(1) On or after December 28, 1979, no owner or operator shall cause to be discharged into the atmosphere from the Southwestern Public Service Company's Harrington Station #1, in Amarillo, TX, any gases which exhibit greater than 35 percent opacity, except that a maximum of 42 percent opacity shall be permitted for not more than 6 minutes in any hour.

(2) Interstate Power Company shall not cause to be discharged into the atmosphere from its Lansing Station Unit No. 4 in Lansing, IA, any gases which exhibit greater than 32 percent opacity, except that a maximum of 39 percent opacity shall be permitted for not more than six minutes in any hour.

(c) As an alternate to meeting the requirements of paragraph (a) of this section, an owner or operator that elects to install, calibrate, maintain, and operate a continuous emissions monitoring systems (CEMS) for measuring PM emissions can petition the Administrator (in writing) to comply with §60.42Da(a) of subpart Da of this part. If the Administrator grants the petition, the source will from then on (unless the unit is modified or reconstructed in the future) have to comply with the requirements in §60.43Da(a) of subpart Da of this part.

[60 FR 65415, Dec. 19, 1995, as amended at 74 FR 5077, Jan. 28, 2009]

**§ 60.43 Standard for sulfur dioxide (SO<sub>2</sub>).**

(a) Except as provided under paragraph (d) of this section, on and after the date on which the performance test required to be conducted by §60.8 is completed, no owner or operator subject to the provisions of this subpart shall cause to be discharged into the atmosphere from any affected facility any gases that contain SO<sub>2</sub> in excess of:

(1) 340 ng/J heat input (0.80 lb/MMBtu) derived from liquid fossil fuel or liquid fossil fuel and wood residue.

(2) 520 ng/J heat input (1.2 lb/MMBtu) derived from solid fossil fuel or solid fossil fuel and wood residue, except as provided in paragraph (e) of this section.

(b) Except as provided under paragraph (d) of this section, when different fossil fuels are burned simultaneously in any combination, the applicable standard (in ng/J) shall be determined by proration using the following formula:

$$PS_{SO_2} = \frac{y(340) + z(520)}{(y + z)}$$

Where:

PS<sub>SO<sub>2</sub></sub>= Prorated standard for S<sub>O<sub>2</sub></sub>when burning different fuels simultaneously, in ng/J heat input derived from all fossil fuels or from all fossil fuels and wood residue fired;

y = Percentage of total heat input derived from liquid fossil fuel; and

z = Percentage of total heat input derived from solid fossil fuel.

(c) Compliance shall be based on the total heat input from all fossil fuels burned, including gaseous fuels.

(d) As an alternate to meeting the requirements of paragraphs (a) and (b) of this section, an owner or operator can petition the Administrator (in writing) to comply with §60.43Da(i)(3) of subpart Da of this part or comply with §60.42b(k)(4) of subpart Db of this part, as applicable to the affected source. If the Administrator grants the petition, the source will from then on (unless the unit is modified or reconstructed in the future) have to comply with the requirements in §60.43Da(i)(3) of subpart Da of this part or §60.42b(k)(4) of subpart Db of this part, as applicable to the affected source.

(e) Units 1 and 2 (as defined in appendix G of this part) at the Newton Power Station owned or operated by the Central Illinois Public Service Company will be in compliance with paragraph (a)(2) of this section if Unit 1 and Unit 2 individually comply with paragraph (a)(2) of this section or if the combined emission rate from Units 1 and 2 does not exceed 470 ng/J (1.1 lb/MMBtu) combined heat input to Units 1 and 2.

[60 FR 65415, Dec. 19, 1995, as amended at 74 FR 5077, Jan. 28, 2009]

#### § 60.44 Standard for nitrogen oxides (NO<sub>x</sub>).

(a) Except as provided under paragraph (e) of this section, on and after the date on which the performance test required to be conducted by §60.8 is completed, no owner or operator subject to the provisions of this subpart shall cause to be discharged into the atmosphere from any affected facility any gases that contain NO<sub>x</sub>, expressed as NO<sub>2</sub> in excess of:

(1) 86 ng/J heat input (0.20 lb/MMBtu) derived from gaseous fossil fuel.

(2) 129 ng/J heat input (0.30 lb/MMBtu) derived from liquid fossil fuel, liquid fossil fuel and wood residue, or gaseous fossil fuel and wood residue.

(3) 300 ng/J heat input (0.70 lb/MMBtu) derived from solid fossil fuel or solid fossil fuel and wood residue (except lignite or a solid fossil fuel containing 25 percent, by weight, or more of coal refuse).

(4) 260 ng/J heat input (0.60 lb MMBtu) derived from lignite or lignite and wood residue (except as provided under paragraph (a)(5) of this section).

(5) 340 ng/J heat input (0.80 lb MMBtu) derived from lignite which is mined in North Dakota, South Dakota, or Montana and which is burned in a cyclone-fired unit.

(b) Except as provided under paragraphs (c), (d), and (e) of this section, when different fossil fuels are burned simultaneously in any combination, the applicable standard (in ng/J) is determined by proration using the following formula:

$$PS_{NO_x} = \frac{w(260) + x(86) + y(300) + z(300)}{(w + x + y + z)}$$

Where:

PS<sub>NO<sub>x</sub></sub> = Prorated standard for NO<sub>x</sub> when burning different fuels simultaneously, in ng/J heat input derived from all fossil fuels fired or from all fossil fuels and wood residue fired;

w = Percentage of total heat input derived from lignite;

x = Percentage of total heat input derived from gaseous fossil fuel;

y = Percentage of total heat input derived from liquid fossil fuel; and

z = Percentage of total heat input derived from solid fossil fuel (except lignite).

(c) When a fossil fuel containing at least 25 percent, by weight, of coal refuse is burned in combination with gaseous, liquid, or other solid fossil fuel or wood residue, the standard for NO<sub>x</sub> does not apply.

(d) Except as provided under paragraph (e) of this section, cyclone-fired units which burn fuels containing at least 25 percent of lignite that is mined in North Dakota, South Dakota, or Montana remain subject to paragraph (a)(5) of this section regardless of the types of fuel combusted in combination with that lignite.

(e) As an alternate to meeting the requirements of paragraphs (a), (b), and (d) of this section, an owner or operator can petition the Administrator (in writing) to comply with §60.44Da(e)(3) of subpart Da of this part. If the Administrator grants the petition, the source will from then on (unless the unit is modified or reconstructed in the future) have to comply with the requirements in §60.44Da(e)(3) of subpart Da of this part.

#### **§ 60.45 Emissions and fuel monitoring.**

(a) Each owner or operator shall install, calibrate, maintain, and operate continuous opacity monitoring system (COMS) for measuring opacity and a CEMS for measuring SO<sub>2</sub> emissions, NO<sub>x</sub> emissions, and either oxygen (O<sub>2</sub>) or carbon dioxide (CO<sub>2</sub>) except as provided in paragraph (b) of this section.

(b) Certain of the CEMS requirements under paragraph (a) of this section do not apply to owners or operators under the following conditions:

(1) For a fossil-fuel-fired steam generator that burns only gaseous or liquid fossil fuel (excluding residual oil) with potential SO<sub>2</sub> emissions rates of 26 ng/J (0.060 lb/MMBtu) or less and that does not use post-combustion technology to reduce emissions of SO<sub>2</sub> or PM, CEMS for measuring the opacity of emissions and SO<sub>2</sub> emissions are not required if the owner or operator monitors SO<sub>2</sub> emissions by fuel sampling and analysis or fuel receipts.

(2) For a fossil-fuel-fired steam generator that does not use a flue gas desulfurization device, a CEMS for measuring SO<sub>2</sub> emissions is not required if the owner or operator monitors SO<sub>2</sub> emissions by fuel sampling and analysis.

(3) Notwithstanding §60.13(b), installation of a CEMS for NO<sub>x</sub> may be delayed until after the initial performance tests under §60.8 have been conducted. If the owner or operator demonstrates during the performance test that emissions of NO<sub>x</sub> are less than 70 percent of the applicable standards in §60.44, a CEMS for measuring NO<sub>x</sub> emissions is not required. If the initial performance test results show that NO<sub>x</sub> emissions are greater than 70 percent of the applicable standard, the owner or operator shall install a CEMS for NO<sub>x</sub> within one year after the date of the initial performance tests under §60.8 and comply with all other applicable monitoring requirements under this part.

(4) If an owner or operator does not install any CEMS for sulfur oxides and NO<sub>x</sub>, as provided under paragraphs (b)(1) and (b)(3) or paragraphs (b)(2) and (b)(3) of this section a CEMS for measuring either O<sub>2</sub> or CO<sub>2</sub> is not required.

(5) An owner or operator may petition the Administrator (in writing) to install a PM CEMS as an alternative to the CEMS for monitoring opacity emissions.

(6) A CEMS for measuring the opacity of emissions is not required for a fossil fuel-fired steam generator that does not use post-combustion technology (except a wet scrubber) for reducing PM, SO<sub>2</sub>, or carbon monoxide (CO) emissions, burns only gaseous fuels or fuel oils that contain less than or equal to 0.30 weight percent sulfur, and is operated such that emissions of CO to the atmosphere from the affected

source are maintained at levels less than or equal to 0.15 lb/MMBtu on a boiler operating day average basis. Owners and operators of affected sources electing to comply with this paragraph must demonstrate compliance according to the procedures specified in paragraphs (b)(6)(i) through (iv) of this section.

(i) You must monitor CO emissions using a CEMS according to the procedures specified in paragraphs (b)(6)(i)(A) through (D) of this section.

(A) The CO CEMS must be installed, certified, maintained, and operated according to the provisions in §60.58b(i)(3) of subpart Eb of this part.

(B) Each 1-hour CO emissions average is calculated using the data points generated by the CO CEMS expressed in parts per million by volume corrected to 3 percent oxygen (dry basis).

(C) At a minimum, valid 1-hour CO emissions averages must be obtained for at least 90 percent of the operating hours on a 30-day rolling average basis. The 1-hour averages are calculated using the data points required in §60.13(h)(2).

(D) Quarterly accuracy determinations and daily calibration drift tests for the CO CEMS must be performed in accordance with procedure 1 in appendix F of this part.

(ii) You must calculate the 1-hour average CO emissions levels for each boiler operating day by multiplying the average hourly CO output concentration measured by the CO CEMS times the corresponding average hourly flue gas flow rate and divided by the corresponding average hourly heat input to the affected source. The 24-hour average CO emission level is determined by calculating the arithmetic average of the hourly CO emission levels computed for each boiler operating day.

(iii) You must evaluate the preceding 24-hour average CO emission level each boiler operating day excluding periods of affected source startup, shutdown, or malfunction. If the 24-hour average CO emission level is greater than 0.15 lb/MMBtu, you must initiate investigation of the relevant equipment and control systems within 24 hours of the first discovery of the high emission incident and, take the appropriate corrective action as soon as practicable to adjust control settings or repair equipment to reduce the 24-hour average CO emission level to 0.15 lb/MMBtu or less.

(iv) You must record the CO measurements and calculations performed according to paragraph (b)(6) of this section and any corrective actions taken. The record of corrective action taken must include the date and time during which the 24-hour average CO emission level was greater than 0.15 lb/MMBtu, and the date, time, and description of the corrective action.

(7) An owner or operator of an affected facility subject to an opacity standard under §60.42 that elects to not use a COMS because the affected facility burns only fuels as specified under paragraph (b)(1) of this section, monitors PM emissions as specified under paragraph (b)(5) of this section, or monitors CO emissions as specified under paragraph (b)(6) of this section, shall conduct a performance test using Method 9 of appendix A-4 of this part and the procedures in §60.11 to demonstrate compliance with the applicable limit in §60.42 by April 29, 2011 or within 45 days after stopping use of an existing COMS, whichever is later, and shall comply with either paragraph (b)(7)(i), (b)(7)(ii), or (b)(7)(iii) of this section. The observation period for Method 9 of appendix A-4 of this part performance tests may be reduced from 3 hours to 60 minutes if all 6-minute averages are less than 10 percent and all individual 15-second observations are less than or equal to 20 percent during the initial 60 minutes of observation. The permitting authority may exempt owners or operators of affected facilities burning only natural gas from the opacity monitoring requirements.

(i) Except as provided in paragraph (b)(7)(ii) or (b)(7)(iii) of this section, the owner or operator shall conduct subsequent Method 9 of appendix A-4 of this part performance tests using the procedures in paragraph (b)(7) of this section according to the applicable schedule in paragraphs (b)(7)(i)(A) through (b)(7)(i)(D) of this section, as determined by the most recent Method 9 of appendix A-4 of this part performance test results.

(A) If no visible emissions are observed, a subsequent Method 9 of appendix A-4 of this part performance test must be completed within 12 calendar months from the date that the most recent performance test was conducted;

(B) If visible emissions are observed but the maximum 6-minute average opacity is less than or equal to 5 percent, a subsequent Method 9 of appendix A-4 of this part performance test must be completed within 6 calendar months from the date that the most recent performance test was conducted;

(C) If the maximum 6-minute average opacity is greater than 5 percent but less than or equal to 10 percent, a subsequent Method 9 of appendix A-4 of this part performance test must be completed within 3 calendar months from the date that the most recent performance test was conducted; or

(D) If the maximum 6-minute average opacity is greater than 10 percent, a subsequent Method 9 of appendix A-4 of this part performance test must be completed within 45 calendar days from the date that the most recent performance test was conducted.

(ii) If the maximum 6-minute opacity is less than 10 percent during the most recent Method 9 of appendix A-4 of this part performance test, the owner or operator may, as an alternative to performing subsequent Method 9 of appendix A-4 of this part performance test, elect to perform subsequent monitoring using Method 22 of appendix A-7 of this part according to the procedures specified in paragraphs (b)(7)(ii)(A) and (B) of this section.

(A) The owner or operator shall conduct 10 minute observations (during normal operation) each operating day the affected facility fires fuel for which an opacity standard is applicable using Method 22 of appendix A-7 of this part and demonstrate that the sum of the occurrences of any visible emissions is not in excess of 5 percent of the observation period ( *i.e.* , 30 seconds per 10 minute period). If the sum of the occurrence of any visible emissions is greater than 30 seconds during the initial 10 minute observation, immediately conduct a 30 minute observation. If the sum of the occurrence of visible emissions is greater than 5 percent of the observation period (*i.e.*, 90 seconds per 30 minute period), the owner or operator shall either document and adjust the operation of the facility and demonstrate within 24 hours that the sum of the occurrence of visible emissions is equal to or less than 5 percent during a 30 minute observation (*i.e.*, 90 seconds) or conduct a new Method 9 of appendix A-4 of this part performance test using the procedures in paragraph (b)(7) of this section within 45 calendar days according to the requirements in §60.46(b)(3).

(B) If no visible emissions are observed for 30 operating days during which an opacity standard is applicable, observations can be reduced to once every 7 operating days during which an opacity standard is applicable. If any visible emissions are observed, daily observations shall be resumed.

(iii) If the maximum 6-minute opacity is less than 10 percent during the most recent Method 9 of appendix A-4 of this part performance test, the owner or operator may, as an alternative to performing subsequent Method 9 of appendix A-4 performance tests, elect to perform subsequent monitoring using a digital opacity compliance system according to a site-specific monitoring plan approved by the Administrator. The observations shall be similar, but not necessarily identical, to the requirements in paragraph (b)(7)(ii) of this section. For reference purposes in preparing the monitoring plan, see OAQPS "Determination of Visible Emission Opacity from Stationary Sources Using Computer-Based Photographic Analysis Systems." This document is available from the U.S. Environmental Protection Agency (U.S. EPA); Office of Air Quality and Planning Standards; Sector Policies and Programs Division; Measurement Policy Group (D243-02), Research Triangle Park, NC 27711. This document is also available on the Technology Transfer Network (TTN) under Emission Measurement Center Preliminary Methods.

(c) For performance evaluations under §60.13(c) and calibration checks under §60.13(d), the following procedures shall be used:

(1) Methods 6, 7, and 3B of appendix A of this part, as applicable, shall be used for the performance evaluations of SO<sub>2</sub> and NO<sub>x</sub> continuous monitoring systems. Acceptable alternative methods for Methods 6, 7, and 3B of appendix A of this part are given in §60.46(d).

(2) Sulfur dioxide or nitric oxide, as applicable, shall be used for preparing calibration gas mixtures under Performance Specification 2 of appendix B to this part.

(3) For affected facilities burning fossil fuel(s), the span value for a continuous monitoring system measuring the opacity of emissions shall be 80, 90, or 100 percent. For a continuous monitoring system measuring sulfur oxides or NO<sub>x</sub> the span value shall be determined using one of the following procedures:

(i) Except as provided under paragraph (c)(3)(ii) of this section, SO<sub>2</sub> and NO<sub>x</sub> span values shall be determined as follows:

Fossil fuel	In parts per million	
	Span value for SO <sub>2</sub>	Span value for NO <sub>x</sub>
Gas	( <sup>1</sup> )	500.
Liquid	1,000	500.
Solid	1,500	1,000.
Combinations	1,000y + 1,500z	500 (x + y) + 1,000z.

<sup>1</sup>Not applicable.

Where:

x = Fraction of total heat input derived from gaseous fossil fuel;

y = Fraction of total heat input derived from liquid fossil fuel; and

z = Fraction of total heat input derived from solid fossil fuel.

(ii) As an alternative to meeting the requirements of paragraph (c)(3)(i) of this section, the owner or operator of an affected facility may elect to use the SO<sub>2</sub> and NO<sub>x</sub> span values determined according to sections 2.1.1 and 2.1.2 in appendix A to part 75 of this chapter.

(4) All span values computed under paragraph (c)(3)(i) of this section for burning combinations of fossil fuels shall be rounded to the nearest 500 ppm. Span values that are computed under paragraph (c)(3)(ii) of this section shall be rounded off according to the applicable procedures in section 2 of appendix A to part 75 of this chapter.

(5) For a fossil-fuel-fired steam generator that simultaneously burns fossil fuel and nonfossil fuel, the span value of all CEMS shall be subject to the Administrator's approval.

(d) [Reserved]

(e) For any CEMS installed under paragraph (a) of this section, the following conversion procedures shall be used to convert the continuous monitoring data into units of the applicable standards (ng/J, lb/MMBtu):

(1) When a CEMS for measuring O<sub>2</sub> is selected, the measurement of the pollutant concentration and O<sub>2</sub> concentration shall each be on a consistent basis (wet or dry). Alternative procedures approved by the Administrator shall be used when measurements are on a wet basis. When measurements are on a dry basis, the following conversion procedure shall be used:

$$E = CF \left( \frac{20.9}{(20.9 - \%O_2)} \right)$$

Where E, C, F, and %O<sub>2</sub> are determined under paragraph (f) of this section.

(2) When a CEMS for measuring CO<sub>2</sub> is selected, the measurement of the pollutant concentration and CO<sub>2</sub> concentration shall each be on a consistent basis (wet or dry) and the following conversion procedure shall be used:

$$E = CF_c \left( \frac{100}{\%CO_2} \right)$$

Where E, C, F<sub>c</sub> and %CO<sub>2</sub> are determined under paragraph (f) of this section.

(f) The values used in the equations under paragraphs (e)(1) and (2) of this section are derived as follows:

(1) E = pollutant emissions, ng/J (lb/MMBtu).

(2) C = pollutant concentration, ng/dscm (lb/dscf), determined by multiplying the average concentration (ppm) for each one-hour period by  $4.15 \times 10^4$  M ng/dscm per ppm ( $2.59 \times 10^{-9}$  M lb/dscf per ppm) where M = pollutant molecular weight, g/g-mole (lb/lb-mole). M = 64.07 for SO<sub>2</sub> and 46.01 for NO<sub>x</sub>.

(3) %O<sub>2</sub>, %CO<sub>2</sub> = O<sub>2</sub> or CO<sub>2</sub> volume (expressed as percent), determined with equipment specified under paragraph (a) of this section.

(4) F, F<sub>c</sub> = a factor representing a ratio of the volume of dry flue gases generated to the calorific value of the fuel combusted (F), and a factor representing a ratio of the volume of CO<sub>2</sub> generated to the calorific value of the fuel combusted (F<sub>c</sub>), respectively. Values of F and F<sub>c</sub> are given as follows:

(i) For anthracite coal as classified according to ASTM D388 (incorporated by reference, see §60.17), F =  $2.723 \times 10^{-7}$  dscm/J (10,140 dscf/MMBtu) and F<sub>c</sub> =  $0.532 \times 10^{-7}$  scm CO<sub>2</sub>/J (1,980 scf CO<sub>2</sub>/MMBtu).

(ii) For subbituminous and bituminous coal as classified according to ASTM D388 (incorporated by reference, see §60.17), F =  $2.637 \times 10^{-7}$  dscm/J (9,820 dscf/MMBtu) and F<sub>c</sub> =  $0.486 \times 10^{-7}$  scm CO<sub>2</sub>/J (1,810 scf CO<sub>2</sub>/MMBtu).

(iii) For liquid fossil fuels including crude, residual, and distillate oils, F =  $2.476 \times 10^{-7}$  dscm/J (9,220 dscf/MMBtu) and F<sub>c</sub> =  $0.384 \times 10^{-7}$  scm CO<sub>2</sub>/J (1,430 scf CO<sub>2</sub>/MMBtu).

(iv) For gaseous fossil fuels, F =  $2.347 \times 10^{-7}$  dscm/J (8,740 dscf/MMBtu). For natural gas, propane, and butane fuels, F<sub>c</sub> =  $0.279 \times 10^{-7}$  scm CO<sub>2</sub>/J (1,040 scf CO<sub>2</sub>/MMBtu) for natural gas,  $0.322 \times 10^{-7}$  scm CO<sub>2</sub>/J (1,200 scf CO<sub>2</sub>/MMBtu) for propane, and  $0.338 \times 10^{-7}$  scm CO<sub>2</sub>/J (1,260 scf CO<sub>2</sub>/MMBtu) for butane.

(v) For bark F =  $2.589 \times 10^{-7}$  dscm/J (9,640 dscf/MMBtu) and F<sub>c</sub> =  $0.500 \times 10^{-7}$  scm CO<sub>2</sub>/J (1,840 scf CO<sub>2</sub>/MMBtu). For wood residue other than bark F =  $2.492 \times 10^{-7}$  dscm/J (9,280 dscf/MMBtu) and F<sub>c</sub> =  $0.494 \times 10^{-7}$  scm CO<sub>2</sub>/J (1,860 scf CO<sub>2</sub>/MMBtu).

(vi) For lignite coal as classified according to ASTM D388 (incorporated by reference, see §60.17), F =  $2.659 \times 10^{-7}$  dscm/J (9,900 dscf/MMBtu) and F<sub>c</sub> =  $0.516 \times 10^{-7}$  scm CO<sub>2</sub>/J (1,920 scf CO<sub>2</sub>/MMBtu).

(5) The owner or operator may use the following equation to determine an F factor (dscm/J or dscf/MMBtu) on a dry basis (if it is desired to calculate F on a wet basis, consult the Administrator) or F<sub>c</sub> factor (scm CO<sub>2</sub>/J, or scf CO<sub>2</sub>/MMBtu) on either basis in lieu of the F or F<sub>c</sub> factors specified in paragraph (f)(4) of this section:

$$F = 10^{-1} \frac{[227.2 (\%H) + 95.5 (\%C) + 35.6 (\%S) + 8.7 (\%N) - 28.7 (\%O)]}{GCV}$$

$$F_c = \frac{2.0 \times 10^{-3} (\%C)}{GCV \text{ (SI units)}}$$

$$F = 10^{-1} \frac{[3.64 (\%H) + 1.53 (\%C) + 0.57 (\%S) + 0.14 (\%N) - 0.46 (\%O)]}{GCV \text{ (English units)}}$$

$$F_c = \frac{20.0 (\%C)}{GCV \text{ (SI units)}}$$

$$F_c = \frac{321 \times 10^3 (\%C)}{GCV \text{ (English units)}}$$

(i) %H, %C, %S, %N, and %O are content by weight of hydrogen, carbon, sulfur, nitrogen, and O<sub>2</sub> (expressed as percent), respectively, as determined on the same basis as GCV by ultimate analysis of the fuel fired, using ASTM D3178 or D3176 (solid fuels), or computed from results using ASTM D1137, D1945, or D1946 (gaseous fuels) as applicable. (These five methods are incorporated by reference, see §60.17.)

(ii) GCV is the gross calorific value (kJ/kg, Btu/lb) of the fuel combusted determined by the ASTM test methods D2015 or D5865 for solid fuels and D1826 for gaseous fuels as applicable. (These three methods are incorporated by reference, see §60.17.)

(iii) For affected facilities which fire both fossil fuels and nonfossil fuels, the F or F<sub>c</sub> value shall be subject to the Administrator's approval.

(6) For affected facilities firing combinations of fossil fuels or fossil fuels and wood residue, the F or F<sub>c</sub> factors determined by paragraphs (f)(4) or (f)(5) of this section shall be prorated in accordance with the applicable formula as follows:

$$F = \sum_{i=1}^n X_i F_i \quad \text{or} \quad F_c = \sum_{i=1}^n X_i (F_c)_i$$

Where:

X<sub>i</sub> = Fraction of total heat input derived from each type of fuel (e.g. natural gas, bituminous coal, wood residue, etc.);

F<sub>i</sub> or (F<sub>c</sub>)<sub>i</sub> = Applicable F or F<sub>c</sub> factor for each fuel type determined in accordance with paragraphs (f)(4) and (f)(5) of this section; and

n = Number of fuels being burned in combination.

(g) Excess emission and monitoring system performance reports shall be submitted to the Administrator semiannually for each six-month period in the calendar year. All semiannual reports shall be postmarked by the 30th day following the end of each six-month period. Each excess emission and MSP report shall include the information required in §60.7(c). Periods of excess emissions and monitoring systems (MS) downtime that shall be reported are defined as follows:

(1) *Opacity*. Excess emissions are defined as any six-minute period during which the average opacity of emissions exceeds 20 percent opacity, except that one six-minute average per hour of up to 27 percent opacity need not be reported.

(i) For sources subject to the opacity standard of §60.42(b)(1), excess emissions are defined as any six-minute period during which the average opacity of emissions exceeds 35 percent opacity, except that one six-minute average per hour of up to 42 percent opacity need not be reported.

(ii) For sources subject to the opacity standard of §60.42(b)(2), excess emissions are defined as any six-minute period during which the average opacity of emissions exceeds 32 percent opacity, except that one six-minute average per hour of up to 39 percent opacity need not be reported.

(2) *Sulfur dioxide*. Excess emissions for affected facilities are defined as:

(i) For affected facilities electing not to comply with §60.43(d), any three-hour period during which the average emissions (arithmetic average of three contiguous one-hour periods) of SO<sub>2</sub> as measured by a CEMS exceed the applicable standard in §60.43; or

(ii) For affected facilities electing to comply with §60.43(d), any 30 operating day period during which the average emissions (arithmetic average of all one-hour periods during the 30 operating days) of SO<sub>2</sub> as measured by a CEMS exceed the applicable standard in §60.43. Facilities complying with the 30-day SO<sub>2</sub> standard shall use the most current associated SO<sub>2</sub> compliance and monitoring requirements in §§60.48Da and 60.49Da of subpart Da of this part or §§60.45b and 60.47b of subpart Db of this part, as applicable.

(3) *Nitrogen oxides*. Excess emissions for affected facilities using a CEMS for measuring NO<sub>x</sub> are defined as:

(i) For affected facilities electing not to comply with §60.44(e), any three-hour period during which the average emissions (arithmetic average of three contiguous one-hour periods) exceed the applicable standards in §60.44; or

(ii) For affected facilities electing to comply with §60.44(e), any 30 operating day period during which the average emissions (arithmetic average of all one-hour periods during the 30 operating days) of NO<sub>x</sub> as measured by a CEMS exceed the applicable standard in §60.44. Facilities complying with the 30-day NO<sub>x</sub> standard shall use the most current associated NO<sub>x</sub> compliance and monitoring requirements in §§60.48Da and 60.49Da of subpart Da of this part.

(4) *Particulate matter*. Excess emissions for affected facilities using a CEMS for measuring PM are defined as any boiler operating day period during which the average emissions (arithmetic average of all operating one-hour periods) exceed the applicable standards in §60.42. Affected facilities using PM CEMS must follow the most current applicable compliance and monitoring provisions in §§60.48Da and 60.49Da of subpart Da of this part.

(h) The owner or operator of an affected facility subject to the opacity limits in §60.42 that elects to monitor emissions according to the requirements in §60.45(b)(7) shall maintain records according to the requirements specified in paragraphs (h)(1) through (3) of this section, as applicable to the visible emissions monitoring method used.

(1) For each performance test conducted using Method 9 of appendix A-4 of this part, the owner or operator shall keep the records including the information specified in paragraphs (h)(1)(i) through (iii) of this section.

(i) Dates and time intervals of all opacity observation periods;

(ii) Name, affiliation, and copy of current visible emission reading certification for each visible emission observer participating in the performance test; and

(iii) Copies of all visible emission observer opacity field data sheets;

(2) For each performance test conducted using Method 22 of appendix A-4 of this part, the owner or operator shall keep the records including the information specified in paragraphs (h)(2)(i) through (iv) of this section.

(i) Dates and time intervals of all visible emissions observation periods;

(ii) Name and affiliation for each visible emission observer participating in the performance test;

(iii) Copies of all visible emission observer opacity field data sheets; and

(iv) Documentation of any adjustments made and the time the adjustments were completed to the affected facility operation by the owner or operator to demonstrate compliance with the applicable monitoring requirements.

(3) For each digital opacity compliance system, the owner or operator shall maintain records and submit reports according to the requirements specified in the site-specific monitoring plan approved by the Administrator.

[60 FR 65415, Dec. 19, 1995, as amended at 74 FR 5077, Jan. 28, 2009; 76 FR 3522, Jan. 20, 2011]

#### **§ 60.46 Test methods and procedures.**

(a) In conducting the performance tests required in §60.8, and subsequent performance tests as requested by the EPA Administrator, the owner or operator shall use as reference methods and procedures the test methods in appendix A of this part or other methods and procedures as specified in this section, except as provided in §60.8(b). Acceptable alternative methods and procedures are given in paragraph (d) of this section.

(b) The owner or operator shall determine compliance with the PM, SO<sub>2</sub>, and NO<sub>x</sub> standards in §§60.42, 60.43, and 60.44 as follows:

(1) The emission rate (E) of PM, SO<sub>2</sub>, or NO<sub>x</sub> shall be computed for each run using the following equation:

$$E = CF_d \left( \frac{20.9}{(20.9 - \%O_2)} \right)$$

Where:

E = Emission rate of pollutant, ng/J (1b/million Btu);

C = Concentration of pollutant, ng/dscm (1b/dscf);

%O<sub>2</sub> = O<sub>2</sub> concentration, percent dry basis; and

F<sub>d</sub> = Factor as determined from Method 19 of appendix A of this part.

(2) Method 5 of appendix A of this part shall be used to determine the PM concentration (C) at affected facilities without wet flue-gas-desulfurization (FGD) systems and Method 5B of appendix A of this part shall be used to determine the PM concentration (C) after FGD systems.

(i) The sampling time and sample volume for each run shall be at least 60 minutes and 0.85 dscm (30 dscf). The probe and filter holder heating systems in the sampling train shall be set to provide an average gas temperature of 160±14 °C (320±25 °F).

(ii) The emission rate correction factor, integrated or grab sampling and analysis procedure of Method 3B of appendix A of this part shall be used to determine the O<sub>2</sub> concentration (%O<sub>2</sub>). The O<sub>2</sub> sample shall be obtained simultaneously with, and at the same traverse points as, the particulate sample. If the grab sampling procedure is used, the O<sub>2</sub> concentration for the run shall be the arithmetic mean of the sample O<sub>2</sub> concentrations at all traverse points.

(iii) If the particulate run has more than 12 traverse points, the O<sub>2</sub> traverse points may be reduced to 12 provided that Method 1 of appendix A of this part is used to locate the 12 O<sub>2</sub> traverse points.

(3) Method 9 of appendix A of this part and the procedures in §60.11 shall be used to determine opacity.

(4) Method 6 of appendix A of this part shall be used to determine the SO<sub>2</sub> concentration.

(i) The sampling site shall be the same as that selected for the particulate sample. The sampling location in the duct shall be at the centroid of the cross section or at a point no closer to the walls than 1 m (3.28 ft). The sampling time and sample volume for each sample run shall be at least 20 minutes and 0.020 dscm (0.71 dscf). Two samples shall be taken during a 1-hour period, with each sample taken within a 30-minute interval.

(ii) The emission rate correction factor, integrated sampling and analysis procedure of Method 3B of appendix A of this part shall be used to determine the O<sub>2</sub> concentration (%O<sub>2</sub>). The O<sub>2</sub> sample shall be taken simultaneously with, and at the same point as, the SO<sub>2</sub> sample. The SO<sub>2</sub> emission rate shall be computed for each pair of SO<sub>2</sub> and O<sub>2</sub> samples. The SO<sub>2</sub> emission rate (E) for each run shall be the arithmetic mean of the results of the two pairs of samples.

(5) Method 7 of appendix A of this part shall be used to determine the NO<sub>x</sub> concentration.

(i) The sampling site and location shall be the same as for the SO<sub>2</sub> sample. Each run shall consist of four grab samples, with each sample taken at about 15-minute intervals.

(ii) For each NO<sub>x</sub> sample, the emission rate correction factor, grab sampling and analysis procedure of Method 3B of appendix A of this part shall be used to determine the O<sub>2</sub> concentration (%O<sub>2</sub>). The sample shall be taken simultaneously with, and at the same point as, the NO<sub>x</sub> sample.

(iii) The NO<sub>x</sub> emission rate shall be computed for each pair of NO<sub>x</sub> and O<sub>2</sub> samples. The NO<sub>x</sub> emission rate (E) for each run shall be the arithmetic mean of the results of the four pairs of samples.

(c) When combinations of fossil fuels or fossil fuel and wood residue are fired, the owner or operator (in order to compute the prorated standard as shown in §§60.43(b) and 60.44(b)) shall determine the percentage (w, x, y, or z) of the total heat input derived from each type of fuel as follows:

(1) The heat input rate of each fuel shall be determined by multiplying the gross calorific value of each fuel fired by the rate of each fuel burned.

(2) ASTM Methods D2015, or D5865 (solid fuels), D240 (liquid fuels), or D1826 (gaseous fuels) (all of these methods are incorporated by reference, see §60.17) shall be used to determine the gross calorific values of the fuels. The method used to determine the calorific value of wood residue must be approved by the Administrator.

(3) Suitable methods shall be used to determine the rate of each fuel burned during each test period, and a material balance over the steam generating system shall be used to confirm the rate.

(d) The owner or operator may use the following as alternatives to the reference methods and procedures in this section or in other sections as specified:

(1) The emission rate (E) of PM, SO<sub>2</sub> and NO<sub>x</sub> may be determined by using the F<sub>c</sub> factor, provided that the following procedure is used:

(i) The emission rate (E) shall be computed using the following equation:

$$E = CF_c \left( \frac{100}{\%CO_2} \right)$$

Where:

E = Emission rate of pollutant, ng/J (lb/MMBtu);

C = Concentration of pollutant, ng/dscm (lb/dscf);

%CO<sub>2</sub> = CO<sub>2</sub> concentration, percent dry basis; and

F<sub>c</sub> = Factor as determined in appropriate sections of Method 19 of appendix A of this part.

(ii) If and only if the average F<sub>c</sub> factor in Method 19 of appendix A of this part is used to calculate E and either E is from 0.97 to 1.00 of the emission standard or the relative accuracy of a continuous emission monitoring system is from 17 to 20 percent, then three runs of Method 3B of appendix A of this part shall be used to determine the O<sub>2</sub> and CO<sub>2</sub> concentration according to the procedures in paragraph (b)(2)(ii), (4)(ii), or (5)(ii) of this section. Then if F<sub>o</sub> (average of three runs), as calculated from the equation in Method 3B of appendix A of this part, is more than ±3 percent than the average F<sub>o</sub> value, as determined from the average values of F<sub>o</sub> and F<sub>i</sub> in Method 19 of appendix A of this part, *i.e.*, F<sub>oa</sub> = 0.209 (F<sub>da</sub>/F<sub>ca</sub>), then the following procedure shall be followed:

(A) When F<sub>o</sub> is less than 0.97 F<sub>oa</sub>, then E shall be increased by that proportion under 0.97 F<sub>oa</sub>, *e.g.*, if F<sub>o</sub> is 0.95 F<sub>oa</sub>, E shall be increased by 2 percent. This recalculated value shall be used to determine compliance with the emission standard.

(B) When F<sub>o</sub> is less than 0.97 F<sub>oa</sub> and when the average difference (d) between the continuous monitor minus the reference methods is negative, then E shall be increased by that proportion under 0.97 F<sub>oa</sub>, *e.g.*, if F<sub>o</sub> is 0.95 F<sub>oa</sub>, E shall be increased by 2 percent. This recalculated value shall be used to determine compliance with the relative accuracy specification.

(C) When F<sub>o</sub> is greater than 1.03 F<sub>oa</sub> and when the average difference d is positive, then E shall be decreased by that proportion over 1.03 F<sub>oa</sub>, *e.g.*, if F<sub>o</sub> is 1.05 F<sub>oa</sub>, E shall be decreased by 2 percent. This recalculated value shall be used to determine compliance with the relative accuracy specification.

(2) For Method 5 or 5B of appendix A-3 of this part, Method 17 of appendix A-6 of this part may be used at facilities with or without wet FGD systems if the stack gas temperature at the sampling location does not exceed an average temperature of 160 °C (320 °F). The procedures of sections 8.1 and 11.1 of Method 5B of appendix A-3 of this part may be used with Method 17 of appendix A-6 of this part only if it is used after wet FGD systems. Method 17 of appendix A-6 of this part shall not be used after wet FGD systems if the effluent gas is saturated or laden with water droplets.

(3) Particulate matter and SO<sub>2</sub> may be determined simultaneously with the Method 5 of appendix A of this part train provided that the following changes are made:

(i) The filter and impinger apparatus in sections 2.1.5 and 2.1.6 of Method 8 of appendix A of this part is used in place of the condenser (section 2.1.7) of Method 5 of appendix A of this part.

(ii) All applicable procedures in Method 8 of appendix A of this part for the determination of SO<sub>2</sub> (including moisture) are used:

(4) For Method 6 of appendix A of this part, Method 6C of appendix A of this part may be used. Method 6A of appendix A of this part may also be used whenever Methods 6 and 3B of appendix A of this part data are specified to determine the SO<sub>2</sub> emission rate, under the conditions in paragraph (d)(1) of this section.

(5) For Method 7 of appendix A of this part, Method 7A, 7C, 7D, or 7E of appendix A of this part may be used. If Method 7C, 7D, or 7E of appendix A of this part is used, the sampling time for each run shall be at least 1 hour and the integrated sampling approach shall be used to determine the O<sub>2</sub> concentration (%O<sub>2</sub>) for the emission rate correction factor.

(6) For Method 3 of appendix A of this part, Method 3A or 3B of appendix A of this part may be used.

(7) For Method 3B of appendix A of this part, Method 3A of appendix A of this part may be used.

[60 FR 65415, Dec. 19, 1995, as amended at 74 FR 5078, Jan. 28, 2009]

**APPENDIX B**  
**Continuous Emission Monitoring Systems Conditions**

# Arkansas Department of Environmental Quality



## CONTINUOUS EMISSION MONITORING SYSTEMS CONDITIONS

Revised August 2004

## PREAMBLE

These conditions are intended to outline the requirements for facilities required to operate Continuous Emission Monitoring Systems/Continuous Opacity Monitoring Systems (CEMS/COMS). Generally there are three types of sources required to operate CEMS/COMS:

1. CEMS/COMS required by 40 CFR Part 60 or 63,
2. CEMS required by 40 CFR Part 75,
3. CEMS/COMS required by ADEQ permit for reasons other than Part 60, 63 or 75.

These CEMS/COMS conditions are not intended to supercede Part 60, 63 or 75 requirements.

- Only CEMS/COMS in the third category (those required by ADEQ permit for reasons other than Part 60, 63, or 75) shall comply with SECTION II, MONITORING REQUIREMENTS and SECTION IV, QUALITY ASSURANCE/QUALITY CONTROL.
- All CEMS/COMS shall comply with Section III, NOTIFICATION AND RECORDKEEPING.

## SECTION I

### DEFINITIONS

**Continuous Emission Monitoring System (CEMS)** - The total equipment required for the determination of a gas concentration and/or emission rate so as to include sampling, analysis and recording of emission data.

**Continuous Opacity Monitoring System (COMS)** - The total equipment required for the determination of opacity as to include sampling, analysis and recording of emission data.

**Calibration Drift (CD)** - The difference in the CEMS output reading from the established reference value after a stated period of operation during which no unscheduled maintenance, repair, or adjustments took place.

**Back-up CEMS (Secondary CEMS)** - A CEMS with the ability to sample, analyze and record stack pollutant to determine gas concentration and/or emission rate. This CEMS is to serve as a back-up to the primary CEMS to minimize monitor downtime.

**Excess Emissions** - Any period in which the emissions exceed the permit limits.

**Monitor Downtime** - Any period during which the CEMS/COMS is unable to sample, analyze and record a minimum of four evenly spaced data points over an hour, except during one daily zero-span check during which two data points per hour are sufficient.

**Out-of-Control Period** - Begins with the time corresponding to the completion of the fifth, consecutive, daily CD check with a CD in excess of two times the allowable limit, or the time corresponding to the completion of the daily CD check preceding the daily CD check that results in a CD in excess of four times the allowable limit and the time corresponding to the completion of the sampling for the RATA, RAA, or CGA which exceeds the limits outlined in Section IV. Out-of-Control Period ends with the time corresponding to the completion of the CD check following corrective action with the results being within the allowable CD limit or the completion of the sampling of the subsequent successful RATA, RAA, or CGA.

**Primary CEMS** - The main reporting CEMS with the ability to sample, analyze, and record stack pollutant to determine gas concentration and/or emission rate.

**Relative Accuracy (RA)** - The absolute mean difference between the gas concentration or emission rate determined by the CEMS and the value determined by the reference method plus the 2.5 percent error confidence coefficient of a series of tests divided by the mean of the reference method tests of the applicable emission limit.

**Span Value** - The upper limit of a gas concentration measurement range.

## SECTION II

### MONITORING REQUIREMENTS

- A. For new sources, the installation date for the CEMS/COMS shall be no later than thirty (30) days from the date of start-up of the source.
- B. For existing sources, the installation date for the CEMS/COMS shall be no later than sixty (60) days from the issuance of the permit unless the permit requires a specific date.
- C. Within sixty (60) days of installation of a CEMS/COMS, a performance specification test (PST) must be completed. PST's are defined in 40 CFR, Part 60, Appendix B, PS 1-9. The Department may accept alternate PST's for pollutants not covered by Appendix B on a case-by-case basis. Alternate PST's shall be approved, in writing, by the ADEQ CEM Coordinator prior to testing.
- D. Each CEMS/COMS shall have, as a minimum, a daily zero-span check. The zero-span shall be adjusted whenever the 24-hour zero or 24-hour span drift exceeds two times the limits in the applicable performance specification in 40 CFR, Part 60, Appendix B. Before any adjustments are made to either the zero or span drifts measured at the 24-hour interval the excess zero and span drifts measured must be quantified and recorded.
- E. All CEMS/COMS shall be in continuous operation and shall meet minimum frequency of operation requirements of 95% up-time for each quarter for each pollutant measured. Percent of monitor down-time is calculated by dividing the total minutes the monitor is not in operation by the total time in the calendar quarter and multiplying by one hundred. Failure to maintain operation time shall constitute a violation of the CEMS conditions.
- F. Percent of excess emissions are calculated by dividing the total minutes of excess emissions by the total time the source operated and multiplying by one hundred. Failure to maintain compliance may constitute a violation of the CEMS conditions.
- G. All CEMS measuring emissions shall complete a minimum of one cycle of operation (sampling, analyzing, and data recording) for each successive fifteen minute period unless more cycles are required by the permit. For each CEMS, one-hour averages shall be computed from four or more data points equally spaced over each one hour period unless more data points are required by the permit.
- H. All COMS shall complete a minimum of one cycle of sampling and analyzing for each successive 10-second period and one cycle of data recording for each successive 6-minute period.
- I. When the pollutant from a single affected facility is released through more than one point, a CEMS/COMS shall be installed on each point unless installation of fewer systems is approved, in writing, by the ADEQ CEM Coordinator. When more than one CEM/COM is used to monitor emissions from one affected facility the owner or operator shall report the results as required from each CEMS/COMS.

### SECTION III

#### NOTIFICATION AND RECORD KEEPING

- A. When requested to do so by an owner or operator, the ADEQ CEM Coordinator will review plans for installation or modification for the purpose of providing technical advice to the owner or operator.
- B. Each facility which operates a CEMS/COMS shall notify the ADEQ CEM Coordinator of the date for which the demonstration of the CEMS/COMS performance will commence (i.e. PST, RATA, RAA, CGA). Notification shall be received in writing no less than 15 days prior to testing. Performance test results shall be submitted to the Department within thirty days after completion of testing.
- C. Each facility which operates a CEMS/COMS shall maintain records of the occurrence and duration of start up/shut down, cleaning/soot blowing, process problems, fuel problems, or other malfunction in the operation of the affected facility which causes excess emissions. This includes any malfunction of the air pollution control equipment or any period during which a continuous monitoring device/system is inoperative.
- D. Except for Part 75 CEMs, each facility required to install a CEMS/COMS shall submit an excess emission and monitoring system performance report to the Department (Attention: Air Division, CEM Coordinator) at least quarterly, unless more frequent submittals are warranted to assess the compliance status of the facility. Quarterly reports shall be postmarked no later than the 30th day of the month following the end of each calendar quarter. Part 75 CEMs shall submit this information semi-annually and as part of Title V six (6) month reporting requirement if the facility is a Title V facility.
- E. All excess emissions shall be reported in terms of the applicable standard. Each report shall be submitted on ADEQ Quarterly Excess Emission Report Forms. Alternate forms may be used with prior written approval from the Department.
- F. Each facility which operates a CEMS/COMS must maintain on site a file of CEMS/COMS data including all raw data, corrected and adjusted, repair logs, calibration checks, adjustments, and test audits. This file must be retained for a period of at least five years, and is required to be maintained in such a condition that it can easily be audited by an inspector.
- G. Except for Part 75 CEMs, quarterly reports shall be used by the Department to determine compliance with the permit. For Part 75 CEMs, the semi-annual report shall be used.

## SECTION IV

### QUALITY ASSURANCE/QUALITY CONTROL

- A. For each CEMS/COMS a Quality Assurance/Quality Control (QA/QC) plan shall be submitted to the Department (Attn.: Air Division, CEM Coordinator). CEMS quality assurance procedures are defined in 40 CFR, Part 60, Appendix F. This plan shall be submitted within 180 days of the CEMS/COMS installation. A QA/QC plan shall consist of procedure and practices which assures acceptable level of monitor data accuracy, precision, representativeness, and availability.
- B. The submitted QA/QC plan for each CEMS/COMS shall not be considered as accepted until the facility receives a written notification of acceptance from the Department.
- C. Facilities responsible for one, or more, CEMS/COMS used for compliance monitoring shall meet these minimum requirements and are encouraged to develop and implement a more extensive QA/QC program, or to continue such programs where they already exist. Each QA/QC program must include written procedures which should describe in detail, complete, step-by-step procedures and operations for each of the following activities:
1. Calibration of CEMS/COMS
    - a. Daily calibrations (including the approximate time(s) that the daily zero and span drifts will be checked and the time required to perform these checks and return to stable operation)
  2. Calibration drift determination and adjustment of CEMS/COMS
    - a. Out-of-control period determination
    - b. Steps of corrective action
  3. Preventive maintenance of CEMS/COMS
    - a. CEMS/COMS information
      - 1) Manufacture
      - 2) Model number
      - 3) Serial number
    - b. Scheduled activities (check list)
    - c. Spare part inventory
  4. Data recording, calculations, and reporting
  5. Accuracy audit procedures including sampling and analysis methods
  6. Program of corrective action for malfunctioning CEMS/COMS
- D. A Relative Accuracy Test Audit (RATA), shall be conducted at least once every four calendar quarters. A Relative Accuracy Audit (RAA), or a Cylinder Gas Audit (CGA), may be conducted in the other three quarters but in no more than three quarters in succession. The RATA should be conducted in accordance with the applicable test procedure in 40 CFR Part 60 Appendix A and calculated in accordance with the applicable performance specification in 40 CFR Part 60 Appendix B. CGA's and RAA's should be conducted and the data calculated in accordance with the procedures outlined on 40 CFR Part 60 Appendix F.

If alternative testing procedures or methods of calculation are to be used in the RATA, RAA or CGA audits prior authorization must be obtained from the ADEQ CEM Coordinator.

E. Criteria for excessive audit inaccuracy.

**RATA**

All Pollutants except Carbon Monoxide	> 20% Relative Accuracy
Carbon Monoxide	> 10% Relative Accuracy
All Pollutants except Carbon Monoxide	> 10% of the Applicable Standard
Carbon Monoxide	> 5% of the Applicable Standard
Diluent (O <sub>2</sub> & CO <sub>2</sub> )	> 1.0 % O <sub>2</sub> or CO <sub>2</sub>
Flow	> 20% Relative Accuracy

**CGA**

Pollutant	> 15% of average audit value or 5 ppm difference
Diluent (O <sub>2</sub> & CO <sub>2</sub> )	> 15% of average audit value or 5 ppm difference

**RAA**

Pollutant	> 15% of the three run average or > 7.5 % of the applicable standard
Diluent (O <sub>2</sub> & CO <sub>2</sub> )	> 15% of the three run average or > 7.5 % of the applicable standard

- F. If either the zero or span drift results exceed two times the applicable drift specification in 40 CFR, Part 60, Appendix B for five consecutive, daily periods, the CEMS is out-of-control. If either the zero or span drift results exceed four times the applicable drift specification in Appendix B during a calibration drift check, the CEMS is out-of-control. If the CEMS exceeds the audit inaccuracies listed above, the CEMS is out-of-control. If a CEMS is out-of-control, the data from that out-of-control period is not counted towards meeting the minimum data availability as required and described in the applicable subpart. The end of the out-of-control period is the time corresponding to the completion of the successful daily zero or span drift or completion of the successful CGA, RAA or RATA.
- G. A back-up monitor may be placed on an emission source to minimize monitor downtime. This back-up CEMS is subject to the same QA/QC procedure and practices as the primary CEMS. The back-up CEMS shall be certified by a PST. Daily zero-span checks must be performed and recorded in accordance with standard practices. When the primary CEMS goes down, the back-up CEMS may then be engaged to sample, analyze and record the emission source pollutant until repairs are made and the primary unit is placed back in service. Records must be maintained on site when the back-up CEMS is placed in service, these records shall include at a minimum the reason the primary CEMS is out of service, the date and time the primary CEMS was out of service and the date and time the primary CEMS was placed back in service.

**APPENDIX C**  
**Compliance Plan for SN-03, Maintenance Plan for SN-04, and Design Specifications for SN-16  
and SN-17**



Entergy Services, Inc.  
425 West Capitol Avenue  
P. O. Box 551  
Little Rock, AR 72203  
Tel 501-377-4032  
Fax 501-377-5656

AR-01-068

May 30, 2001

State of Arkansas  
Department of Environmental Quality  
Air Division  
ATTN: Compliance Inspector Supervisor  
8001 National Drive  
Post Office Box 8913  
Little Rock, Arkansas 72219-8913

Dear Sirs,

**Subject: Independence Plant-Permit 449-AOP-R0**  
**Update compliance plan for the rotary car dumper (SN-03)**

In accordance with the Title V minor modification request approval received on May 17, 2001, Entergy is submitting the following revised compliance plan for the rotary car dumper for your review and approval. This plan will replace the previous compliance plan included in Appendix C of the permit. The change in the maintenance plan is necessary because the new dust suppression system is completely different from the old system. The old system was based on the use of rotoclones. The new system is based on the use of a foam spray.

Requirements include but are not limited to the following:

- a. Inspect spray nozzles for pluggage.
- b. Check air pressure and flow.
- c. Check water pressure and water/dustfoam flow.
- d. Check for adequate dustfoam chemical additive.

SPECIAL INSTRUCTIONS for PM #3641 (Printed: 6/10/03)

(M641)

AIR PERMIT requires this checklist be filed and retained. Return this checklist to the Environmental Specialist upon completion.

BAGHOUSE

CHECK AIR LEAKS ON PULSATION SYSTEM

CHECK AIR OPERATED VALVES

CHECK PIPING & SUPPORTS

CHECK AIR CYLINDERS

CHECK BAGHOUSE DOORS & SEALS

CHECK BAGS

CHECK PULSATION TUBES

CHECK DIFFUSER BLOWER BEARINGS FOR HEAT AND VIBRATION

CHECK BLOWER CASE FOR EXCESSIVE HEAT BUILDUP

CHECK INLET FILTER AND CHANGE AS NEEDED

\*\*\*\*WRITE WR AS NEEDED\*\*\*\*

PERFORMED BY \_\_\_\_\_ DATE \_\_\_\_\_  
FILE \_\_\_\_\_ NOT FILE \_\_\_\_\_

REVIEWED BY \_\_\_\_\_ DATE \_\_\_\_\_

REVIEWED \_\_\_\_\_ DATE \_\_\_\_\_

### Technical Design Data

Cooling Tower	
Manufacturer	Research-Cottrell Hamon Cooling Tower Division
Type	Natural Draft
Tower Construction	Hyperbolic
Water Flow @ 100%	360,000 gpm
Water Flow @ 50%	180,000 gpm
Fill	Asbestos Cement
Drift Eliminators	Asbestos Cement
Heat Load	$4.36 \times 10^9$ btu/hr
Range	28.1°F
Wet Bulb	78°F
Dry Bulb	94°F
Cold Water	95°F
Approach	17°F
Relative Humidity	50%
Evaporative Loss (Percent of circulating water flow)	2.46%
Drift Loss (Percent of circulating water flow)	.01%

**APPENDIX D**  
**Acid Rain Permit Application**



<b>Plant Name (from Step 1)</b> Independence
---

**Step 3**  
**Read the**  
**standard**  
**requirements**

### Permit Requirements

- (1) The designated representative of each affected source and each affected unit at the source shall:
- (i) Submit a complete Acid Rain permit application (including a compliance plan) under 40 CFR part 72 in accordance with the deadlines specified in 40 CFR 72.30; and
  - (ii) Submit in a timely manner any supplemental information that the permitting authority determines is necessary in order to review an Acid Rain permit application and issue or deny an Acid Rain permit;
- (2) The owners and operators of each affected source and each affected unit at the source shall:
- (i) Operate the unit in compliance with a complete Acid Rain permit application or superseding Acid Rain permit issued by the permitting authority; and
  - (ii) Have an Acid Rain Permit.

### Monitoring Requirements

- (1) The owners and operators and, to the extent applicable, designated representative of each affected source and each affected unit at the source shall comply with the monitoring requirements as provided in 40 CFR part 75.
- (2) The emissions measurements recorded and reported in accordance with 40 CFR part 75 shall be used to determine compliance by the unit with the Acid Rain emissions limitations and emissions reduction requirements for sulfur dioxide and nitrogen oxides under the Acid Rain Program.
- (3) The requirements of 40 CFR part 75 shall not affect the responsibility of the owners and operators to monitor emissions of other pollutants or other emissions characteristics at the unit under other applicable requirements of the Act and other provisions of the operating permit for the source.

### Sulfur Dioxide Requirements

- (1) The owners and operators of each source and each affected unit at the source shall:
- (i) Hold allowances, as of the allowance transfer deadline, in the unit's compliance sub account (after deductions under 40 CFR 73.34(c)), or in the compliance sub account of another affected unit at the same source to the extent provided in 40 CFR 73.35(b)(3), not less than the total annual emissions of sulfur dioxide for the previous calendar year from the unit; and
  - (ii) Comply with the applicable Acid Rain emissions limitations for sulfur dioxide.
- (2) Each ton of sulfur dioxide emitted in excess of the Acid Rain emissions limitations for sulfur dioxide shall constitute a separate violation of the Act.
- (3) An affected unit shall be subject to the requirements under paragraph (1) of the sulfur dioxide requirements as follows:
- (i) Starting January 1, 2000, an affected unit under 40 CFR 72.6(a)(2); or
  - i) Starting on the later of January 1, 2000 or the deadline for monitor certification under 40 CFR part 75, an affected unit under 40 CFR 72.6(a)(3).
- (4) Allowances shall be held in, deducted from, or transferred among Allowance Tracking System accounts in accordance with the Acid Rain Program.
- (5) An allowance shall not be deducted in order to comply with the requirements under paragraph (1) of the sulfur dioxide requirements prior to the calendar year for which the allowance was allocated.
- (6) An allowance allocated by the Administrator under the Acid Rain Program is a limited authorization to emit sulfur dioxide in accordance with the Acid Rain Program. No provision of the Acid Rain Program, the Acid Rain permit application, the Acid Rain permit, or an exemption under 40 CFR 72.7 or 72.8 and no provision of law shall be construed to limit the authority of the United States to terminate or limit such authorization.
- (7) An allowance allocated by the Administrator under the Acid Rain Program does not constitute a property right.

**Plant Name (from Step 1)**  
Independence

Step 3,  
Cont'd.

**Nitrogen Oxides Requirements** The owners and operators of the source and each attached unit at the source shall comply with the applicable Acid Rain emissions limitation for nitrogen oxides.

**Excess Emissions Requirements**

- (1) The designated representative of an affected unit that has excess emissions in any calendar year shall submit a proposed offset plan, as required under 40 CFR part 77.
- (2) The owners and operators of an affected unit that has excess emissions in any calendar year shall:
  - (i) Pay without demand the penalty required, and pay upon demand the interest on that penalty, as required by 40 CFR part 77; and
  - (ii) Comply with the terms of an approved offset plan, as required by 40 CFR part 77.

**Recordkeeping and Reporting Requirements**

- (1) Unless otherwise provided, the owners and operators of the source and each affected unit at the source shall keep on site at the source each of the following documents for a period of 5 years from the date the document is created. This period may be extended for cause, at any time prior to the end of 5 years, in writing by the Administrator or permitting authority:
  - (i) The certificate of representation for the designated representative for the source and each affected unit at the source and all documents that demonstrate the truth of the statements in the certificate of representation, in accordance with 40 CFR 72.24; provided that the certificate and documents shall be retained onsite at the source beyond such 5-year period until such documents are superseded because of the submission of a new certificate of representation changing the designated representative;
  - (ii) All emissions monitoring information, in accordance with 40 CFR part 75, provided that to the extent that 40 CFR part 75 provides for a 3-year period for record keeping, the 3-year period shall apply.
  - (iii) Copies of all reports, compliance certifications, and other submissions and all records made or required under the Acid Rain Program; and,
  - (iv) Copies of all documents used to complete an Acid Rain permit application and any other submission under the Acid Rain Program or to demonstrate compliance with the requirements of the Acid Rain Program.
- (2) The designated representative of an affected source and each affected unit at the source shall submit the reports and compliance certifications required under the Acid Rain Program, including those under 40 CFR part 72 subpart I and 40 CFR part 75.

**Liability**

- (1) Any person who knowingly violates any requirement or prohibition of the Acid Rain Program, a complete Acid Rain permit application, an Acid Rain permit, or an exemption under 40 CFR 72.7 or 72.8, including any requirement for the payment of any penalty owed to the United States, shall be subject to enforcement pursuant to section 113(c) of the Act.
- (2) Any person who knowingly makes a false, material statement in any record submission, or report under the Acid Rain Program shall be subject to criminal enforcement pursuant to section 113(c) of the Act and 18 U.S.C. 1001.
- (3) No permit revision shall excuse any violation of the requirements of the Acid Rain Program that occurs prior to the date that the revision takes effect.
- (4) Each affected source and each affected unit shall meet the requirements of the Acid Rain Program.

**Plant Name (from Step 1)**  
Independence

Liability, Cont'd.

**Step 3,  
Cont'd.**

- (5) Any provision of Acid Rain Program that applies to an affected source (including a provision applicable to the designated representative of an affected source) shall also apply to the owners and operators of such source and of the affected units at the source.
- (6) Any provision of the Acid Rain Program that applies to an affected unit (including a provision applicable to the designated representative of an affected unit) shall also apply to the owners and operators of such unit. Except as provided under 40 CFR 72.44 (Phase II repowering extension plans) and 40 CFR 76.11 (NO<sub>x</sub> averaging plans), and except with regard to the requirements applicable to units with a common stack under 40 CFR part 75 (including 40 CFR 75.16, 75.17, and 75.18), the owners and operators and the designated representative of one affected unit shall not be liable for any violation by any other affected unit of which they are not owners or operators or the designated representative and that is located at a source of which they are not owners or operators or the designated representative.
- (7) Each violation of a provision of 40 CFR parts 72, 73, 74, 75, 76, 77, and 78 by an affected source or affected unit, or by an owner or operator or designated representative of such source unit, shall be a separate violation of the Act.

Effect on Other Authorities

No provision of the Acid Rain Program, an Acid Rain permit application, an Acid Rain permit, or an exemption under 40 CFR 72.7 or 72.8 shall be construed as:


- (1) Except as expressly provided in title IV of the Act, exempting or excluding the owners and operators and, to the extent applicable, the designated representative of an affected source or affected unit from compliance with any other provision of the Act, including the provisions of title I of the Act relating to applicable National Ambient Air Quality Standards or State Implementation Plans;
- (2) Limiting the number of allowances a unit can hold; *provided*, that the number of allowances held by the unit shall not affect the source's obligation to comply with any other provisions of the Act;
- (3) Requiring a change of any kind in any State law regulating electric utility rates and charges, affecting any State law regarding such State regulation, or limiting such State regulation, including any prudence review requirements under such State law;
- (4) Modifying the Federal Power Act or affecting the authority of the Federal Energy Regulatory Commission under the Federal Power Act; or,
- (5) Interfering with or impairing any program for competitive bidding for power supply in a State in which such program is established.

Certification

**Step 4**

Read the Certification statement, sign, and date

I am authorized to make this submission on behalf of the owners and operators of the affected source or affected units for which the submission is made. I certify under penalty of law that I have personally examined, and am familiar with, the statements and information submitted in this document and all its attachments. Based on my inquiry of those individuals with primary responsibility for obtaining the information, I certify that the statements and information are to the best of my knowledge and belief true, accurate, and complete. I am aware that there are significant penalties for submitting false statements and information or omitting required statements and information, including the possibility of fine or imprisonment.

Name Etienne Senac	
Signature 	Date 6-15-04

**APPENDIX E**  
**Clean Air Interstate Rule (CAIR) Permit Application**

**TITLE V PERMIT  
SUPPLEMENTAL PACKAGE  
CLEAN AIR INTERSTATE RULE PERMIT APPLICATION**

<b>AFIN:</b>	32-00042	<b>Date:</b>	4/22/2008
<b>1. UNIT INFORMATION</b>			
Enter the Source ID and Description (as identified in your Arkansas Title V Permit).			
Source Number	Description		
SN-01	Unit 1 Boiler		
SN-02	Unit 2 Boiler		

**2. STANDARD REQUIREMENTS**

Read the standard requirements and the certification. Enter the name of the CAIR designated representative, and sign and date. Include the supplemental application along with a completed Arkansas Operating Permit (Major Source) General Information Forms (pages 1-6). The Department will process a modification to the facility's Title V permit to incorporate these CAIR requirements.

**NO<sub>x</sub> Ozone Season Emission Requirements**

**§ 96.306 Standard requirements**

(a) *Permit requirements.*

(1) The CAIR designated representative of each CAIR NO<sub>x</sub> Ozone Season source required to have a title V operating permit and each CAIR NO<sub>x</sub> Ozone Season unit required to have a title V operating permit at the source shall:

(i) Submit to the permitting authority a complete CAIR permit application under §96.322 in accordance with the deadlines specified in §96.321(a) and (b); and

(ii) Submit in a timely manner any supplemental information that the permitting authority determines is necessary in order to review a CAIR permit application and issue or deny a CAIR permit.

(2) The owners and operators of each CAIR NO<sub>x</sub> Ozone Season source required to have a title V operating permit and each CAIR NO<sub>x</sub> Ozone Season unit required to have a title V operating permit at the source shall have a CAIR permit issued by the permitting authority under subpart CCCC of 40 CFR part 96 for the source and operate the source and the unit in compliance with such CAIR permit.

(3) Except as provided in subpart IIII of 40 CFR part 96, the owners and operators of a CAIR NO<sub>x</sub> Ozone Season source that is not otherwise required to have a title V operating permit and each CAIR NO<sub>x</sub> Ozone Season unit that is not otherwise required to have a title V operating

permit are not required to submit a CAIR permit application, and to have a CAIR permit, under subpart CCCC of 40 CFR part 96 for such CAIR NO<sub>x</sub> Ozone Season source and such CAIR NO<sub>x</sub> Ozone Season unit.

*(b) Monitoring, reporting, and recordkeeping requirements.*

(1) The owners and operators, and the CAIR designated representative, of each CAIR NO<sub>x</sub> Ozone Season source and each CAIR NO<sub>x</sub> Ozone Season unit at the source shall comply with the monitoring, reporting, and recordkeeping requirements of subpart HHHH of 40 CFR part 96.

(2) The emissions measurements recorded and reported in accordance with subpart HHHH of 40 CFR part 96 shall be used to determine compliance by each CAIR NO<sub>x</sub> Ozone Season source with the CAIR NO<sub>x</sub> Ozone Season emissions limitation under paragraph (c) of this §96.306.

*(c) Nitrogen oxides ozone season emission requirements.*

(1) As of the allowance transfer deadline for a control period, the owners and operators of each CAIR NO<sub>x</sub> Ozone Season source and each CAIR NO<sub>x</sub> Ozone Season unit at the source shall hold, in the source's compliance account, CAIR NO<sub>x</sub> Ozone Season allowances available for compliance deductions for the control period under §96.354(a) in an amount not less than the tons of total nitrogen oxides emissions for the control period from all CAIR NO<sub>x</sub> Ozone Season units at the source, as determined in accordance with subpart HHHH of this part.

(2) A CAIR NO<sub>x</sub> Ozone Season unit shall be subject to the requirements under paragraph (c)(1) of this §96.306 starting on the later of May 1, 2009 or the deadline for meeting the unit's monitor certification requirements under §96.370(b)(1), (2), (3), or (7) and for each control period thereafter.

(3) A CAIR NO<sub>x</sub> Ozone Season allowance shall not be deducted, for compliance with the requirements under paragraph (c)(1) of §96.306, for a control period in a calendar year before the year for which the CAIR NO<sub>x</sub> Ozone Season allowance was allocated.

(4) CAIR NO<sub>x</sub> Ozone Season allowances shall be held in, deducted from, or transferred into or among CAIR NO<sub>x</sub> Ozone Season Allowance Tracking System accounts in accordance with subparts, FFFF, GGGG of 40 CFR part 96 and Chapter 14 of the Arkansas Pollution Control and Ecology Commission Regulation 19, Regulations of the Arkansas Plan of Implementation for Air Pollution Control.

(5) A CAIR NO<sub>x</sub> Ozone Season allowance is a limited authorization to emit one ton of nitrogen oxides in accordance with the CAIR NO<sub>x</sub> Ozone Season Trading Program. No provision of the CAIR NO<sub>x</sub> Ozone Season Trading Program, the CAIR permit application, the CAIR permit, or an exemption under §96.305 and no provision of law shall be construed to limit the authority of the State or the United States to terminate or limit such authorization.

(6) A CAIR NO<sub>x</sub> Ozone Season allowance does not constitute a property right.

(7) Upon recordation by the Administrator under subpart FFFF, GGGG of this part or Chapter 14 of the Arkansas Pollution Control and Ecology Commission Regulation 19, Regulations of the Arkansas Plan of Implementation for Air Pollution Control, every allocation, transfer, or deduction of a CAIR NO<sub>x</sub> Ozone Season allowance to or from a CAIR NO<sub>x</sub> Ozone Season source's compliance account is incorporated automatically in any CAIR permit of the source.

*(d) Excess emissions requirements.*

(1) If a CAIR NO<sub>x</sub> Ozone Season source emits nitrogen oxides during any control period in excess of the CAIR NO<sub>x</sub> Ozone Season emissions limitation, then:

- (i) The owners and operators of the source and each CAIR NO<sub>x</sub> Ozone Season unit at the source shall surrender the CAIR NO<sub>x</sub> Ozone Season allowances required for deduction under §96.354(d)(1) and pay any fine, penalty, or assessment or comply with any other remedy imposed, for the same violations, under the Clean Air Act or applicable State law; and
- (ii) Each ton of such excess emissions and each day of such control period shall constitute a separate violation of this subpart, the Clean Air Act, and applicable State law.

*(e) Recordkeeping and reporting requirements.*

(1) Unless otherwise provided, the owners and operators of the CAIR NO<sub>x</sub> Ozone Season source and each CAIR NO<sub>x</sub> Ozone Season unit at the source shall keep on site at the source each of the following documents for a period of 5 years from the date the document is created. This period may be extended for cause, at any time before the end of 5 years, in writing by the permitting authority or the Administrator.

(i) The certificate of representation under §96.313 for the CAIR designated representative for the source and each CAIR NO<sub>x</sub> Ozone Season unit at the source and all documents that demonstrate the truth of the statements in the certificate of representation; provided that the certificate and documents shall be retained on site at the source beyond such 5-year period until such documents are superseded because of the submission of a new certificate of representation under §96.313 changing the CAIR designated representative.

(ii) All emissions monitoring information, in accordance with subpart HHHH of 40 CFR part 96, provided that to the extent that subpart HHHH of 40 CFR part 96 provides for a 3-year period for recordkeeping, the 3-year period shall apply.

(iii) Copies of all reports, compliance certifications, and other submissions and all records made or required under the CAIR NO<sub>x</sub> Ozone Season Trading Program.

(iv) Copies of all documents used to complete a CAIR permit application and any other submission under the CAIR NO<sub>x</sub> Ozone Season Trading Program or to demonstrate compliance with the requirements of the CAIR NO<sub>x</sub> Ozone Season Trading Program.

(2) The CAIR designated representative of a CAIR NO<sub>x</sub> Ozone Season source and each CAIR NO<sub>x</sub> Ozone Season unit at the source shall submit the reports required under the CAIR NO<sub>x</sub> Ozone Season Trading Program, including those under subpart HHHH of 40 CFR part 96.

*(f) Liability.*

(1) Each CAIR NO<sub>x</sub> Ozone Season source and each CAIR NO<sub>x</sub> Ozone Season unit shall meet the requirements of the CAIR NO<sub>x</sub> Ozone Season Trading Program.

(2) Any provision of the CAIR NO<sub>x</sub> Ozone Season Trading Program that applies to a CAIR NO<sub>x</sub> Ozone Season source or the CAIR designated representative of a CAIR NO<sub>x</sub> Ozone Season source shall also apply to the owners and operators of such source and of the CAIR NO<sub>x</sub> Ozone Season units at the source.

(3) Any provision of the CAIR NO<sub>x</sub> Ozone Season Trading Program that applies to a CAIR NO<sub>x</sub> Ozone Season unit or the CAIR designated representative of a CAIR NO<sub>x</sub> Ozone Season unit shall also apply to the owners and operators of such unit.

*(g) Effect on other authorities.*

No provision of the CAIR NO<sub>x</sub> Ozone Season Trading Program, a CAIR permit application, a CAIR permit, or an exemption under §96.305 shall be construed as exempting or excluding the owners and operators, and the CAIR designated representative, of a CAIR NO<sub>x</sub> Ozone Season source or CAIR NO<sub>x</sub> Ozone Season unit from compliance with any other provision of the applicable, approved State implementation plan, a federally enforceable permit, or the Clean Air Act.

### 3. CERTIFICATION

I am authorized to make this submission on behalf of the owners and operators of the source or units for which the submission is made. I certify under penalty of law that I have personally examined, and am familiar with, the statements and information submitted in this document and all its attachments. Based on my inquiry of those individuals with primary responsibility for obtaining the information, I certify that the statements and information are to the best of my knowledge and belief true, accurate, and complete. I am aware that there are significant penalties for submitting false statements and information or omitting required statements and information, including the possibility of fine or imprisonment.

#### CAIR Designated Representative

Myra Glover	
Name (Print)	Myra H. Glover
Signature	Myra H. Glover
Date	4/28/08

APPENDIX F  
40 CFR Part 60, Subpart Y  
*Standards of Performance for Coal Preparation Plants*

## Subpart Y—Standards of Performance for Coal Preparation and Processing Plants

**Source:** 74 FR 51977, Oct. 8, 2009, unless otherwise noted.

### § 60.250 Applicability and designation of affected facility.

(a) The provisions of this subpart apply to affected facilities in coal preparation and processing plants that process more than 181 megagrams (Mg) (200 tons) of coal per day.

(b) The provisions in §60.251, §60.252(a), §60.253(a), §60.254(a), §60.255(a), and §60.256(a) of this subpart are applicable to any of the following affected facilities that commenced construction, reconstruction or modification after October 27, 1974, and on or before April 28, 2008: Thermal dryers, pneumatic coal-cleaning equipment (air tables), coal processing and conveying equipment (including breakers and crushers), and coal storage systems, transfer and loading systems.

(c) The provisions in §60.251, §60.252(b)(1) and (c), §60.253(b), §60.254(b), §60.255(b) through (h), §60.256(b) and (c), §60.257, and §60.258 of this subpart are applicable to any of the following affected facilities that commenced construction, reconstruction or modification after April 28, 2008, and on or before May 27, 2009: Thermal dryers, pneumatic coal-cleaning equipment (air tables), coal processing and conveying equipment (including breakers and crushers), and coal storage systems, transfer and loading systems.

(d) The provisions in §60.251, §60.252(b)(1) through (3), and (c), §60.253(b), §60.254(b) and (c), §60.255(b) through (h), §60.256(b) and (c), §60.257, and §60.258 of this subpart are applicable to any of the following affected facilities that commenced construction, reconstruction or modification after May 27, 2009: Thermal dryers, pneumatic coal-cleaning equipment (air tables), coal processing and conveying equipment (including breakers and crushers), coal storage systems, transfer and loading systems, and open storage piles.

### § 60.251 Definitions.

As used in this subpart, all terms not defined herein have the meaning given them in the Clean Air Act (Act) and in subpart A of this part.

(a) *Anthracite* means coal that is classified as anthracite according to the American Society of Testing and Materials in ASTM D388 (incorporated by reference, see §60.17).

(b) *Bag leak detection system* means a system that is capable of continuously monitoring relative particulate matter (dust loadings) in the exhaust of a fabric filter to detect bag leaks and other upset conditions. A bag leak detection system includes, but is not limited to, an instrument that operates on triboelectric, light scattering, light transmittance, or other effect to continuously monitor relative particulate matter loadings.

(c) *Bituminous coal* means solid fossil fuel classified as bituminous coal by ASTM D388 (incorporated by reference— see §60.17).

(d) *Coal* means:

(1) For units constructed, reconstructed, or modified on or before May 27, 2009, all solid fossil fuels classified as anthracite, bituminous, subbituminous, or lignite by ASTM D388 (incorporated by reference— see §60.17).

(2) For units constructed, reconstructed, or modified after May 27, 2009, all solid fossil fuels classified as anthracite, bituminous, subbituminous, or lignite by ASTM D388 (incorporated by reference— see §60.17), and coal refuse.

(e) *Coal preparation and processing plant* means any facility (excluding underground mining operations) which prepares coal by one or more of the following processes: breaking, crushing, screening, wet or dry cleaning, and thermal drying.

(f) *Coal processing and conveying equipment* means any machinery used to reduce the size of coal or to separate coal from refuse, and the equipment used to convey coal to or remove coal and refuse from the machinery. This includes, but is not limited to, breakers, crushers, screens, and conveyor belts. Equipment located at the mine face is not considered to be part of the coal preparation and processing plant.

(g) *Coal refuse* means waste products of coal mining, physical coal cleaning, and coal preparation operations ( e.g. culm, gob, etc. ) containing coal, matrix material, clay, and other organic and inorganic material.

(h) *Coal storage system* means any facility used to store coal except for open storage piles.

(i) *Design controlled potential PM emissions rate* means the theoretical particulate matter (PM) emissions (Mg) that would result from the operation of a control device at its design emissions rate (grams per dry standard cubic meter (g/dscm)), multiplied by the maximum design flow rate (dry standard cubic meter per minute (dscm/min)), multiplied by 60 (minutes per hour (min/hr)), multiplied by 8,760 (hours per year (hr/yr)), divided by 1,000,000 (megagrams per gram (Mg/g)).

(j) *Indirect thermal dryer* means a thermal dryer that reduces the moisture content of coal through indirect heating of the coal through contact with a heat transfer medium. If the source of heat (the source of combustion or furnace) is subject to another subpart of this part, then the furnace and the associated emissions are not part of the affected facility. However, if the source of heat is not subject to another subpart of this part, then the furnace and the associated emissions are part of the affected facility.

(k) *Lignite* means coal that is classified as lignite A or B according to the American Society of Testing and Materials in ASTM D388 (incorporated by reference, see §60.17).

(l) *Mechanical vent* means any vent that uses a powered mechanical drive (machine) to induce air flow.

(m) *Open storage pile* means any facility, including storage area, that is not enclosed that is used to store coal, including the equipment used in the loading, unloading, and conveying operations of the facility.

(n) *Operating day* means a 24-hour period between 12 midnight and the following midnight during which coal is prepared or processed at any time by the affected facility. It is not necessary that coal be prepared or processed the entire 24-hour period.

(o) *Pneumatic coal-cleaning equipment* means:

(1) For units constructed, reconstructed, or modified on or before May 27, 2009, any facility which classifies bituminous coal by size or separates bituminous coal from refuse by application of air stream(s).

(2) For units constructed, reconstructed, or modified after May 27, 2009, any facility which classifies coal by size or separates coal from refuse by application of air stream(s).

(p) *Potential combustion concentration* means the theoretical emissions (nanograms per joule (ng/J) or pounds per million British thermal units (lb/MMBtu) heat input) that would result from combustion of a fuel in an uncleaned state without emission control systems, as determined using Method 19 of appendix A-7 of this part.

(q) *Subbituminous coal* means coal that is classified as subbituminous A, B, or C according to the American Society of Testing and Materials in ASTM D388 (incorporated by reference, see §60.17).

(r) *Thermal dryer* means:

(1) For units constructed, reconstructed, or modified on or before May 27, 2009, any facility in which the moisture content of bituminous coal is reduced by contact with a heated gas stream which is exhausted to the atmosphere.

(2) For units constructed, reconstructed, or modified after May 27, 2009, any facility in which the moisture content of coal is reduced by either contact with a heated gas stream which is exhausted to the atmosphere or through indirect heating of the coal through contact with a heated heat transfer medium.

(s) *Transfer and loading system* means any facility used to transfer and load coal for shipment.

#### **§ 60.252 Standards for thermal dryers.**

(a) On and after the date on which the performance test is conducted or required to be completed under §60.8, whichever date comes first, an owner or operator of a thermal dryer constructed, reconstructed, or modified on or before April 28, 2008, subject to the provisions of this subpart must meet the requirements in paragraphs (a)(1) and (a)(2) of this section.

(1) The owner or operator shall not cause to be discharged into the atmosphere from the thermal dryer any gases which contain PM in excess of 0.070 g/dscm (0.031 grains per dry standard cubic feet (gr/dscf)); and

(2) The owner or operator shall not cause to be discharged into the atmosphere from the thermal dryer any gases which exhibit 20 percent opacity or greater.

(b) Except as provided in paragraph (c) of this section, on and after the date on which the performance test is conducted or required to be completed under §60.8, whichever date comes first, an owner or operator of a thermal dryer constructed, reconstructed, or modified after April 28, 2008, subject to the provisions of this subpart must meet the applicable standards for PM and opacity, as specified in paragraph (b)(1) of this section. In addition, and except as provided in paragraph (c) of this section, on and after the date on which the performance test is conducted or required to be completed under §60.8, whichever date comes first, an owner or operator of a thermal dryer constructed, reconstructed, or modified after May 29, 2009, subject to the provisions of this subpart must also meet the applicable standards for sulfur dioxide (SO<sub>2</sub>), and combined nitrogen oxides (NO<sub>x</sub>) and carbon monoxide (CO) as specified in paragraphs (b)(2) and (b)(3) of this section.

(1) The owner or operator must meet the requirements for PM emissions in paragraphs (b)(1)(i) through (iii) of this section, as applicable to the affected facility.

(i) For each thermal dryer constructed or reconstructed after April 28, 2008, the owner or operator must meet the requirements of (b)(1)(i)(A) and (b)(1)(i)(B).

(A) The owner or operator must not cause to be discharged into the atmosphere from the thermal dryer any gases that contain PM in excess of 0.023 g/dscm (0.010 grains per dry standard cubic feet (gr/dscf)); and

(B) The owner or operator must not cause to be discharged into the atmosphere from the thermal dryer any gases that exhibit 10 percent opacity or greater.

(ii) For each thermal dryer modified after April 28, 2008, the owner or operator must meet the requirements of paragraphs (b)(1)(ii)(A) and (b)(1)(ii)(B) of this section.

(A) The owner or operator must not cause to be discharged to the atmosphere from the affected facility any gases which contain PM in excess of 0.070 g/dscm (0.031 gr/dscf); and

(B) The owner or operator must not cause to be discharged into the atmosphere from the affected facility any gases which exhibit 20 percent opacity or greater.

(2) Except as provided in paragraph (b)(2)(iii) of this section, for each thermal dryer constructed, reconstructed, or modified after May 27, 2009, the owner or operator must meet the requirements for SO<sub>2</sub> emissions in either paragraph (b)(2)(i) or (b)(2)(ii) of this section.

(i) The owner or operator must not cause to be discharged into the atmosphere from the affected facility any gases that contain SO<sub>2</sub> in excess of 85 ng/J (0.20 lb/MMBtu) heat input; or

(ii) The owner or operator must not cause to be discharged into the atmosphere from the affected facility any gases that either contain SO<sub>2</sub> in excess of 520 ng/J (1.20 lb/MMBtu) heat input or contain SO<sub>2</sub> in excess of 10 percent of the potential combustion concentration ( *i.e.*, the facility must achieve at least a 90 percent reduction of the potential combustion concentration and may not exceed a maximum emissions rate of 1.2 lb/MMBtu (520 ng/J)).

(iii) Thermal dryers that receive all of their thermal input from a source other than coal or residual oil, that receive all of their thermal input from a source subject to an SO<sub>2</sub> limit under another subpart of this part, or that use waste heat or residual from the combustion of coal or residual oil as their only thermal input are not subject to the SO<sub>2</sub> limits of this section.

(3) Except as provided in paragraph (b)(3)(iii) of this section, the owner or operator must meet the requirements for combined NO<sub>x</sub> and CO emissions in paragraph (b)(3)(i) or (b)(3)(ii) of this section, as applicable to the affected facility.

(i) For each thermal dryer constructed after May 27, 2009, the owner or operator must not cause to be discharged into the atmosphere from the affected facility any gases which contain a combined concentration of NO<sub>x</sub> and CO in excess of 280 ng/J (0.65 lb/MMBtu) heat input.

(ii) For each thermal dryer reconstructed or modified after May 27, 2009, the owner or operator must not cause to be discharged into the atmosphere from the affected facility any gases which contain combined concentration of NO<sub>x</sub> and CO in excess of 430 ng/J (1.0 lb/MMBtu) heat input.

(iii) Thermal dryers that receive all of their thermal input from a source other than coal or residual oil, that receive all of their thermal input from a source subject to a NO<sub>x</sub> limit and/or CO limit under another subpart of this part, or that use waste heat or residual from the combustion of coal or residual oil as their only thermal input, are not subject to the combined NO<sub>x</sub> and CO limits of this section.

(c) Thermal dryers receiving all of their thermal input from an affected facility covered under another 40 CFR Part 60 subpart must meet the applicable requirements in that subpart but are not subject to the requirements in this subpart.

### **§ 60.253 Standards for pneumatic coal-cleaning equipment.**

(a) On and after the date on which the performance test is conducted or required to be completed under §60.8, whichever date comes first, an owner or operator of pneumatic coal-cleaning equipment constructed, reconstructed, or modified on or before April 28, 2008, must meet the requirements of paragraphs (a)(1) and (a)(2) of this section.

(1) The owner or operator must not cause to be discharged into the atmosphere from the pneumatic coal-cleaning equipment any gases that contain PM in excess of 0.040 g/dscm (0.017 gr/dscf); and

(2) The owner or operator must not cause to be discharged into the atmosphere from the pneumatic coal-cleaning equipment any gases that exhibit 10 percent opacity or greater.

(b) On and after the date on which the performance test is conducted or required to be completed under §60.8, whichever date comes first, an owner or operator of pneumatic coal-cleaning equipment constructed, reconstructed, or modified after April 28, 2008, must meet the requirements in paragraphs (b)(1) and (b)(2) of this section.

(1) The owner or operator must not cause to be discharged into the atmosphere from the pneumatic coal-cleaning equipment any gases that contain PM in excess of 0.023 g/dscm (0.010 gr/dscf); and

(2) The owner or operator must not cause to be discharged into the atmosphere from the pneumatic coal-cleaning equipment any gases that exhibit greater than 5 percent opacity.

**§ 60.254 Standards for coal processing and conveying equipment, coal storage systems, transfer and loading systems, and open storage piles.**

(a) On and after the date on which the performance test is conducted or required to be completed under §60.8, whichever date comes first, an owner or operator shall not cause to be discharged into the atmosphere from any coal processing and conveying equipment, coal storage system, or coal transfer and loading system processing coal constructed, reconstructed, or modified on or before April 28, 2008, gases which exhibit 20 percent opacity or greater.

(b) On and after the date on which the performance test is conducted or required to be completed under §60.8, whichever date comes first, an owner or operator of any coal processing and conveying equipment, coal storage system, or coal transfer and loading system processing coal constructed, reconstructed, or modified after April 28, 2008, must meet the requirements in paragraphs (b)(1) through (3) of this section, as applicable to the affected facility.

(1) Except as provided in paragraph (b)(3) of this section, the owner or operator must not cause to be discharged into the atmosphere from the affected facility any gases which exhibit 10 percent opacity or greater.

(2) The owner or operator must not cause to be discharged into the atmosphere from any mechanical vent on an affected facility gases which contain particulate matter in excess of 0.023 g/dscm (0.010 gr/dscf).

(3) Equipment used in the loading, unloading, and conveying operations of open storage piles are not subject to the opacity limitations of paragraph (b)(1) of this section.

(c) The owner or operator of an open storage pile, which includes the equipment used in the loading, unloading, and conveying operations of the affected facility, constructed, reconstructed, or modified after May 27, 2009, must prepare and operate in accordance with a submitted fugitive coal dust emissions control plan that is appropriate for the site conditions as specified in paragraphs (c)(1) through (6) of this section.

(1) The fugitive coal dust emissions control plan must identify and describe the control measures the owner or operator will use to minimize fugitive coal dust emissions from each open storage pile.

(2) For open coal storage piles, the fugitive coal dust emissions control plan must require that one or more of the following control measures be used to minimize to the greatest extent practicable fugitive coal dust: Locating the source inside a partial enclosure, installing and operating a water spray or fogging system, applying appropriate chemical dust suppression agents on the source (when the provisions of paragraph (c)(6) of this section are met), use of a wind barrier, compaction, or use of a vegetative cover. The owner or operator must select, for inclusion in the fugitive coal dust emissions control plan, the control measure or measures listed in this paragraph that are most appropriate for site conditions. The plan must also explain how the measure or measures selected are applicable and appropriate for site conditions. In addition, the plan must be revised as needed to reflect any changing conditions at the source.

(3) Any owner or operator of an affected facility that is required to have a fugitive coal dust emissions control plan may petition the Administrator to approve, for inclusion in the plan for the affected facility, alternative control measures other than those specified in paragraph (c)(2) of this section as specified in paragraphs (c)(3)(i) through (iv) of this section.

(i) The petition must include a description of the alternative control measures, a copy of the fugitive coal dust emissions control plan for the affected facility that includes the alternative control measures, and information sufficient for EPA to evaluate the demonstrations required by paragraph (c)(3)(ii) of this section.

(ii) The owner or operator must either demonstrate that the fugitive coal dust emissions control plan that includes the alternate control measures will provide equivalent overall environmental protection or demonstrate that it is either economically or technically infeasible for the affected facility to use the control measures specifically identified in paragraph (c)(2).

(iii) While the petition is pending, the owner or operator must comply with the fugitive coal dust emissions control plan including the alternative control measures submitted with the petition. Operation in accordance with the plan submitted with the petition shall be deemed to constitute compliance with the requirement to operate in accordance with a fugitive coal dust emissions control plan that contains one of the control measures specifically identified in paragraph (c)(2) of this section while the petition is pending.

(iv) If the petition is approved by the Administrator, the alternative control measures will be approved for inclusion in the fugitive coal dust emissions control plan for the affected facility. In lieu of amending this subpart, a letter will be sent to the facility describing the specific control measures approved. The facility shall make any such letters and the applicable fugitive coal dust emissions control plan available to the public. If the Administrator determines it is appropriate, the conditions and requirements of the letter can be reviewed and changed at any point.

(4) The owner or operator must submit the fugitive coal dust emissions control plan to the Administrator or delegated authority as specified in paragraphs (c)(4)(i) and (c)(4)(ii) of this section.

(i) The plan must be submitted to the Administrator or delegated authority prior to startup of the new, reconstructed, or modified affected facility, or 30 days after the effective date of this rule, whichever is later.

(ii) The plan must be revised as needed to reflect any changing conditions at the source. Such revisions must be dated and submitted to the Administrator or delegated authority before a source can operate pursuant to these revisions. The Administrator or delegated authority may also object to such revisions as specified in paragraph (c)(5) of this section.

(5) The Administrator or delegated authority may object to the fugitive coal dust emissions control plan as specified in paragraphs (c)(5)(i) and (c)(5)(ii) of this section.

(i) The Administrator or delegated authority may object to any fugitive coal dust emissions control plan that it has determined does not meet the requirements of paragraphs (c)(1) and (c)(2) of this section.

(ii) If an objection is raised, the owner or operator, within 30 days from receipt of the objection, must submit a revised fugitive coal dust emissions control plan to the Administrator or delegated authority. The owner or operator must operate in accordance with the revised fugitive coal dust emissions control plan. The Administrator or delegated authority retain the right, under paragraph (c)(5) of this section, to object to the revised control plan if it determines the plan does not meet the requirements of paragraphs (c)(1) and (c)(2) of this section.

(6) Where appropriate chemical dust suppression agents are selected by the owner or operator as a control measure to minimize fugitive coal dust emissions, (1) only chemical dust suppressants with Occupational Safety and Health Administration (OSHA)-compliant material safety data sheets (MSDS) are to be allowed; (2) the MSDS must be included in the fugitive coal dust emissions control plan; and (3) the owner or operator must consider and document in the fugitive coal dust emissions control plan the site-specific impacts associated with the use of such chemical dust suppressants.

#### **§ 60.255 Performance tests and other compliance requirements.**

(a) An owner or operator of each affected facility that commenced construction, reconstruction, or modification on or before April 28, 2008, must conduct all performance tests required by §60.8 to demonstrate compliance with the applicable emission standards using the methods identified in §60.257.

(b) An owner or operator of each affected facility that commenced construction, reconstruction, or modification after April 28, 2008, must conduct performance tests according to the requirements of §60.8

and the methods identified in §60.257 to demonstrate compliance with the applicable emissions standards in this subpart as specified in paragraphs (b)(1) and (2) of this section.

(1) For each affected facility subject to a PM, SO<sub>2</sub>, or combined NO<sub>x</sub> and CO emissions standard, an initial performance test must be performed. Thereafter, a new performance test must be conducted according to the requirements in paragraphs (b)(1)(i) through (iii) of this section, as applicable.

(i) If the results of the most recent performance test demonstrate that emissions from the affected facility are greater than 50 percent of the applicable emissions standard, a new performance test must be conducted within 12 calendar months of the date that the previous performance test was required to be completed.

(ii) If the results of the most recent performance test demonstrate that emissions from the affected facility are 50 percent or less of the applicable emissions standard, a new performance test must be conducted within 24 calendar months of the date that the previous performance test was required to be completed.

(iii) An owner or operator of an affected facility that has not operated for the 60 calendar days prior to the due date of a performance test is not required to perform the subsequent performance test until 30 calendar days after the next operating day.

(2) For each affected facility subject to an opacity standard, an initial performance test must be performed. Thereafter, a new performance test must be conducted according to the requirements in paragraphs (b)(2)(i) through (iii) of this section, as applicable, except as provided for in paragraphs (e) and (f) of this section. Performance test and other compliance requirements for coal truck dump operations are specified in paragraph (h) of this section.

(i) If any 6-minute average opacity reading in the most recent performance test exceeds half the applicable opacity limit, a new performance test must be conducted within 90 operating days of the date that the previous performance test was required to be completed.

(ii) If all 6-minute average opacity readings in the most recent performance test are equal to or less than half the applicable opacity limit, a new performance test must be conducted within 12 calendar months of the date that the previous performance test was required to be completed.

(iii) An owner or operator of an affected facility continuously monitoring scrubber parameters as specified in §60.256(b)(2) is exempt from the requirements in paragraphs (b)(2)(i) and (ii) if opacity performance tests are conducted concurrently with (or within a 60-minute period of) PM performance tests.

(c) If any affected coal processing and conveying equipment (e.g., breakers, crushers, screens, conveying systems), coal storage systems, or coal transfer and loading systems that commenced construction, reconstruction, or modification after April 28, 2008, are enclosed in a building, and emissions from the building do not exceed any of the standards in § 60.254 that apply to the affected facility, then the facility shall be deemed to be in compliance with such standards.

(d) An owner or operator of an affected facility (other than a thermal dryer) that commenced construction, reconstruction, or modification after April 28, 2008, is subject to a PM emission standard and uses a control device with a design controlled potential PM emissions rate of 1.0 Mg (1.1 tons) per year or less is exempted from the requirements of paragraphs (b)(1)(i) and (ii) of this section provided that the owner or operator meets all of the conditions specified in paragraphs (d)(1) through (3) of this section. This exemption does not apply to thermal dryers.

(1) PM emissions, as determined by the most recent performance test, are less than or equal to the applicable limit,

(2) The control device manufacturer's recommended maintenance procedures are followed, and

(3) All 6-minute average opacity readings from the most recent performance test are equal to or less than half the applicable opacity limit or the monitoring requirements in paragraphs (e) or (f) of this section are followed.

(e) For an owner or operator of a group of up to five of the same type of affected facilities that commenced construction, reconstruction, or modification after April 28, 2008, that are subject to PM emissions standards and use identical control devices, the Administrator or delegated authority may allow the owner or operator to use a single PM performance test for one of the affected control devices to demonstrate that the group of affected facilities is in compliance with the applicable emissions standards provided that the owner or operator meets all of the conditions specified in paragraphs (e)(1) through (3) of this section.

(1) PM emissions from the most recent performance test for each individual affected facility are 90 percent or less of the applicable PM standard;

(2) The manufacturer's recommended maintenance procedures are followed for each control device; and

(3) A performance test is conducted on each affected facility at least once every 5 calendar years.

(f) As an alternative to meeting the requirements in paragraph (b)(2) of this section, an owner or operator of an affected facility that commenced construction, reconstruction, or modification after April 28, 2008, may elect to comply with the requirements in paragraph (f)(1) or (f)(2) of this section.

(1) Monitor visible emissions from each affected facility according to the requirements in paragraphs (f)(1)(i) through (iii) of this section.

(i) Conduct one daily 15-second observation each operating day for each affected facility (during normal operation) when the coal preparation and processing plant is in operation. Each observation must be recorded as either visible emissions observed or no visible emissions observed. Each observer determining the presence of visible emissions must meet the training requirements specified in §2.3 of Method 22 of appendix A-7 of this part. If visible emissions are observed during any 15-second observation, the owner or operator must adjust the operation of the affected facility and demonstrate within 24 hours that no visible emissions are observed from the affected facility. If visible emissions are observed, a Method 9, of appendix A-4 of this part, performance test must be conducted within 45 operating days.

(ii) Conduct monthly visual observations of all process and control equipment. If any deficiencies are observed, the necessary maintenance must be performed as expeditiously as possible.

(iii) Conduct a performance test using Method 9 of appendix A-4 of this part at least once every 5 calendar years for each affected facility.

(2) Prepare a written site-specific monitoring plan for a digital opacity compliance system for approval by the Administrator or delegated authority. The plan shall require observations of at least one digital image every 15 seconds for 10-minute periods (during normal operation) every operating day. An approvable monitoring plan must include a demonstration that the occurrences of visible emissions are not in excess of 5 percent of the observation period. For reference purposes in preparing the monitoring plan, see OAQPS "Determination of Visible Emission Opacity from Stationary Sources Using Computer-Based Photographic Analysis Systems." This document is available from the U.S. Environmental Protection Agency (U.S. EPA); Office of Air Quality and Planning Standards; Sector Policies and Programs Division; Measurement Group (D243-02), Research Triangle Park, NC 27711. This document is also available on the Technology Transfer Network (TTN) under Emission Measurement Center Preliminary Methods. The monitoring plan approved by the Administrator or delegated authority shall be implemented by the owner or operator.

(g) As an alternative to meeting the requirements in paragraph (b)(2) of this section, an owner or operator of an affected facility that commenced construction, reconstruction, or modification after April 28, 2008, subject to a visible emissions standard under this subpart may install, operate, and maintain a continuous opacity monitoring system (COMS). Each COMS used to comply with provisions of this subpart must be installed, calibrated, maintained, and continuously operated according to the requirements in paragraphs (g)(1) and (2) of this section.

(1) The COMS must meet Performance Specification 1 in 40 CFR part 60, appendix B.

(2) The COMS must comply with the quality assurance requirements in paragraphs (g)(2)(i) through (v) of this section.

(i) The owner or operator must automatically (intrinsic to the opacity monitor) check the zero and upscale (span) calibration drifts at least once daily. For particular COMS, the acceptable range of zero and upscale calibration materials is as defined in the applicable version of Performance Specification 1 in 40 CFR part 60, appendix B.

(ii) The owner or operator must adjust the zero and span whenever the 24-hour zero drift or 24-hour span drift exceeds 4 percent opacity. The COMS must allow for the amount of excess zero and span drift measured at the 24-hour interval checks to be recorded and quantified. The optical surfaces exposed to the effluent gases must be cleaned prior to performing the zero and span drift adjustments, except for systems using automatic zero adjustments. For systems using automatic zero adjustments, the optical surfaces must be cleaned when the cumulative automatic zero compensation exceeds 4 percent opacity.

(iii) The owner or operator must apply a method for producing a simulated zero opacity condition and an upscale (span) opacity condition using a certified neutral density filter or other related technique to produce a known obscuration of the light beam. All procedures applied must provide a system check of the analyzer internal optical surfaces and all electronic circuitry including the lamp and photodetector assembly.

(iv) Except during periods of system breakdowns, repairs, calibration checks, and zero and span adjustments, the COMS must be in continuous operation and must complete a minimum of one cycle of sampling and analyzing for each successive 10-second period and one cycle of data recording for each successive 6-minute period.

(v) The owner or operator must reduce all data from the COMS to 6-minute averages. Six-minute opacity averages must be calculated from 36 or more data points equally spaced over each 6-minute period. Data recorded during periods of system breakdowns, repairs, calibration checks, and zero and span adjustments must not be included in the data averages. An arithmetic or integrated average of all data may be used.

(h) The owner or operator of each affected coal truck dump operation that commenced construction, reconstruction, or modification after April 28, 2008, must meet the requirements specified in paragraphs (h)(1) through (3) of this section.

(1) Conduct an initial performance test using Method 9 of appendix A-4 of this part according to the requirements in paragraphs (h)(1)(i) and(ii).

(i) Opacity readings shall be taken during the duration of three separate truck dump events. Each truck dump event commences when the truck bed begins to elevate and concludes when the truck bed returns to a horizontal position.

(ii) Compliance with the applicable opacity limit is determined by averaging all 15-second opacity readings made during the duration of three separate truck dump events.

(2) Conduct monthly visual observations of all process and control equipment. If any deficiencies are observed, the necessary maintenance must be performed as expeditiously as possible.

(3) Conduct a performance test using Method 9 of appendix A-4 of this part at least once every 5 calendar years for each affected facility.

#### **§ 60.256 Continuous monitoring requirements.**

(a) The owner or operator of each affected facility constructed, reconstructed, or modified on or before April 28, 2008, must meet the monitoring requirements specified in paragraphs (a)(1) and (2) of this section, as applicable to the affected facility.

(1) The owner or operator of any thermal dryer shall install, calibrate, maintain, and continuously operate monitoring devices as follows:

(i) A monitoring device for the measurement of the temperature of the gas stream at the exit of the thermal dryer on a continuous basis. The monitoring device is to be certified by the manufacturer to be accurate within  $\pm 1.7$  °C ( $\pm 3$  °F).

(ii) For affected facilities that use wet scrubber emission control equipment:

(A) A monitoring device for the continuous measurement of the pressure loss through the venturi constriction of the control equipment. The monitoring device is to be certified by the manufacturer to be accurate within  $\pm 1$  inch water gauge.

(B) A monitoring device for the continuous measurement of the water supply pressure to the control equipment. The monitoring device is to be certified by the manufacturer to be accurate within  $\pm 5$  percent of design water supply pressure. The pressure sensor or tap must be located close to the water discharge point. The Administrator shall have discretion to grant requests for approval of alternative monitoring locations.

(2) All monitoring devices under paragraph (a) of this section are to be recalibrated annually in accordance with procedures under §60.13(b).

(b) The owner or operator of each affected facility constructed, reconstructed, or modified after April 28, 2008, that has one or more mechanical vents must install, calibrate, maintain, and continuously operate the monitoring devices specified in paragraphs (b)(1) through (3) of this section, as applicable to the mechanical vent and any control device installed on the vent.

(1) For mechanical vents with fabric filters (baghouses) with design controlled potential PM emissions rates of 25 Mg (28 tons) per year or more, a bag leak detection system according to the requirements in paragraph (c) of this section.

(2) For mechanical vents with wet scrubbers, monitoring devices according to the requirements in paragraphs (b)(2)(i) through (iv) of this section.

(i) A monitoring device for the continuous measurement of the pressure loss through the venturi constriction of the control equipment. The monitoring device is to be certified by the manufacturer to be accurate within  $\pm 1$  inch water gauge.

(ii) A monitoring device for the continuous measurement of the water supply flow rate to the control equipment. The monitoring device is to be certified by the manufacturer to be accurate within  $\pm 5$  percent of design water supply flow rate.

(iii) A monitoring device for the continuous measurement of the pH of the wet scrubber liquid. The monitoring device is to be certified by the manufacturer to be accurate within  $\pm 5$  percent of design pH.

(iv) An average value for each monitoring parameter must be determined during each performance test. Each monitoring parameter must then be maintained within 10 percent of the value established during the most recent performance test on an operating day average basis.

(3) For mechanical vents with control equipment other than wet scrubbers, a monitoring device for the continuous measurement of the reagent injection flow rate to the control equipment, as applicable. The monitoring device is to be certified by the manufacturer to be accurate within  $\pm 5$  percent of design injection flow rate. An average reagent injection flow rate value must be determined during each performance test. The reagent injection flow rate must then be maintained within 10 percent of the value established during the most recent performance test on an operating day average basis.

(c) Each bag leak detection system used to comply with provisions of this subpart must be installed, calibrated, maintained, and continuously operated according to the requirements in paragraphs (c)(1) through (3) of this section.

(1) The bag leak detection system must meet the specifications and requirements in paragraphs (c)(1)(i) through (viii) of this section.

(i) The bag leak detection system must be certified by the manufacturer to be capable of detecting PM emissions at concentrations of 1 milligram per dry standard cubic meter (mg/dscm) (0.00044 grains per actual cubic foot (gr/acf)) or less.

(ii) The bag leak detection system sensor must provide output of relative PM loadings. The owner or operator shall continuously record the output from the bag leak detection system using electronic or other means ( e.g., using a strip chart recorder or a data logger).

(iii) The bag leak detection system must be equipped with an alarm system that will sound when the system detects an increase in relative particulate loading over the alarm set point established according to paragraph (c)(1)(iv) of this section, and the alarm must be located such that it can be heard by the appropriate plant personnel.

(iv) In the initial adjustment of the bag leak detection system, the owner or operator must establish, at a minimum, the baseline output by adjusting the sensitivity (range) and the averaging period of the device, the alarm set points, and the alarm delay time.

(v) Following initial adjustment, the owner or operator must not adjust the averaging period, alarm set point, or alarm delay time without approval from the Administrator or delegated authority except as provided in paragraph (c)(2)(vi) of this section.

(vi) Once per quarter, the owner or operator may adjust the sensitivity of the bag leak detection system to account for seasonal effects, including temperature and humidity, according to the procedures identified in the site-specific monitoring plan required by paragraph (c)(2) of this section.

(vii) The owner or operator must install the bag leak detection sensor downstream of the fabric filter.

(viii) Where multiple detectors are required, the system's instrumentation and alarm may be shared among detectors.

(2) The owner or operator must develop and submit to the Administrator or delegated authority for approval a site-specific monitoring plan for each bag leak detection system. This plan must be submitted to the Administrator or delegated authority 30 days prior to startup of the affected facility. The owner or operator must operate and maintain the bag leak detection system according to the site-specific monitoring plan at all times. Each monitoring plan must describe the items in paragraphs (c)(2)(i) through (vi) of this section.

(i) Installation of the bag leak detection system;

(ii) Initial and periodic adjustment of the bag leak detection system, including how the alarm set-point will be established;

(iii) Operation of the bag leak detection system, including quality assurance procedures;

(iv) How the bag leak detection system will be maintained, including a routine maintenance schedule and spare parts inventory list;

(v) How the bag leak detection system output will be recorded and stored; and

(vi) Corrective action procedures as specified in paragraph (c)(3) of this section. In approving the site-specific monitoring plan, the Administrator or delegated authority may allow the owner and operator more than 3 hours to alleviate a specific condition that causes an alarm if the owner or operator identifies in the monitoring plan this specific condition as one that could lead to an alarm, adequately explains why it is not feasible to alleviate this condition within 3 hours of the time the alarm occurs, and demonstrates that the requested time will ensure alleviation of this condition as expeditiously as practicable.

(3) For each bag leak detection system, the owner or operator must initiate procedures to determine the cause of every alarm within 1 hour of the alarm. Except as provided in paragraph (c)(2)(vi) of this section, the owner or operator must alleviate the cause of the alarm within 3 hours of the alarm by taking whatever corrective action(s) are necessary. Corrective actions may include, but are not limited to the following:

(i) Inspecting the fabric filter for air leaks, torn or broken bags or filter media, or any other condition that may cause an increase in PM emissions;

(ii) Sealing off defective bags or filter media;

(iii) Replacing defective bags or filter media or otherwise repairing the control device;

(iv) Sealing off a defective fabric filter compartment;

(v) Cleaning the bag leak detection system probe or otherwise repairing the bag leak detection system; or

(vi) Shutting down the process producing the PM emissions.

#### **§ 60.257 Test methods and procedures.**

(a) The owner or operator must determine compliance with the applicable opacity standards as specified in paragraphs (a)(1) through (3) of this section.

(1) Method 9 of appendix A-4 of this part and the procedures in §60.11 must be used to determine opacity, with the exceptions specified in paragraphs (a)(1)(i) and (ii).

(i) The duration of the Method 9 of appendix A-4 of this part performance test shall be 1 hour (ten 6-minute averages).

(ii) If, during the initial 30 minutes of the observation of a Method 9 of appendix A-4 of this part performance test, all of the 6-minute average opacity readings are less than or equal to half the applicable opacity limit, then the observation period may be reduced from 1 hour to 30 minutes.

(2) To determine opacity for fugitive coal dust emissions sources, the additional requirements specified in paragraphs (a)(2)(i) through (iii) must be used.

(i) The minimum distance between the observer and the emission source shall be 5.0 meters (16 feet), and the sun shall be oriented in the 140-degree sector of the back.

(ii) The observer shall select a position that minimizes interference from other fugitive coal dust emissions sources and make observations such that the line of vision is approximately perpendicular to the plume and wind direction.

(iii) The observer shall make opacity observations at the point of greatest opacity in that portion of the plume where condensed water vapor is not present. Water vapor is not considered a visible emission.

(3) A visible emissions observer may conduct visible emission observations for up to three fugitive, stack, or vent emission points within a 15-second interval if the following conditions specified in paragraphs (a)(3)(i) through (iii) of this section are met.

- (i) No more than three emissions points may be read concurrently.
- (ii) All three emissions points must be within a 70 degree viewing sector or angle in front of the observer such that the proper sun position can be maintained for all three points.
- (iii) If an opacity reading for any one of the three emissions points is within 5 percent opacity from the applicable standard (excluding readings of zero opacity), then the observer must stop taking readings for the other two points and continue reading just that single point.
- (b) The owner or operator must conduct all performance tests required by §60.8 to demonstrate compliance with the applicable emissions standards specified in §60.252 according to the requirements in §60.8 using the applicable test methods and procedures in paragraphs (b)(1) through (8) of this section.
- (1) Method 1 or 1A of appendix A–4 of this part shall be used to select sampling port locations and the number of traverse points in each stack or duct. Sampling sites must be located at the outlet of the control device (or at the outlet of the emissions source if no control device is present) prior to any releases to the atmosphere.
- (2) Method 2, 2A, 2C, 2D, 2F, or 2G of appendix A–4 of this part shall be used to determine the volumetric flow rate of the stack gas.
- (3) Method 3, 3A, or 3B of appendix A–4 of this part shall be used to determine the dry molecular weight of the stack gas. The owner or operator may use ANSI/ASME PTC 19.10–1981, “Flue and Exhaust Gas Analyses (incorporated by reference— see §60.17) as an alternative to Method 3B of appendix A–2 of this part.
- (4) Method 4 of appendix A–4 of this part shall be used to determine the moisture content of the stack gas.
- (5) Method 5, 5B or 5D of appendix A–4 of this part or Method 17 of appendix A–7 of this part shall be used to determine the PM concentration as follows:
- (i) The sampling time and sample volume for each run shall be at least 60 minutes and 0.85 dscm (30 dscf). Sampling shall begin no less than 30 minutes after startup and shall terminate before shutdown procedures begin. A minimum of three valid test runs are needed to comprise a PM performance test.
- (ii) Method 5 of appendix A of this part shall be used only to test emissions from affected facilities without wet flue gas desulfurization (FGD) systems.
- (iii) Method 5B of appendix A of this part is to be used only after wet FGD systems.
- (iv) Method 5D of appendix A–4 of this part shall be used for positive pressure fabric filters and other similar applications ( e.g., stub stacks and roof vents).
- (v) Method 17 of appendix A–6 of this part may be used at facilities with or without wet scrubber systems provided the stack gas temperature does not exceed a temperature of 160 °C (320 °F). The procedures of sections 8.1 and 11.1 of Method 5B of appendix A–3 of this part may be used in Method 17 of appendix A–6 of this part only if it is used after a wet FGD system. Do not use Method 17 of appendix A–6 of this part after wet FGD systems if the effluent is saturated or laden with water droplets.
- (6) Method 6, 6A, or 6C of appendix A–4 of this part shall be used to determine the SO<sub>2</sub> concentration. A minimum of three valid test runs are needed to comprise an SO<sub>2</sub> performance test.
- (7) Method 7 or 7E of appendix A–4 of this part shall be used to determine the NO<sub>x</sub> concentration. A minimum of three valid test runs are needed to comprise an NO<sub>x</sub> performance test.

(8) Method 10 of appendix A-4 of this part shall be used to determine the CO concentration. A minimum of three valid test runs are needed to comprise a CO performance test. CO performance tests are conducted concurrently (or within a 60-minute period) with NO<sub>x</sub> performance tests.

**§ 60.258 Reporting and recordkeeping.**

(a) The owner or operator of a coal preparation and processing plant that commenced construction, reconstruction, or modification after April 28, 2008, shall maintain in a logbook (written or electronic) on-site and make it available upon request. The logbook shall record the following:

(1) The manufacturer's recommended maintenance procedures and the date and time of any maintenance and inspection activities and the results of those activities. Any variance from manufacturer recommendation, if any, shall be noted.

(2) The date and time of periodic coal preparation and processing plant visual observations, noting those sources with visible emissions along with corrective actions taken to reduce visible emissions. Results from the actions shall be noted.

(3) The amount and type of coal processed each calendar month.

(4) The amount of chemical stabilizer or water purchased for use in the coal preparation and processing plant.

(5) Monthly certification that the dust suppressant systems were operational when any coal was processed and that manufacturer's recommendations were followed for all control systems. Any variance from the manufacturer's recommendations, if any, shall be noted.

(6) Monthly certification that the fugitive coal dust emissions control plan was implemented as described. Any variance from the plan, if any, shall be noted. A copy of the applicable fugitive coal dust emissions control plan and any letters from the Administrator providing approval of any alternative control measures shall be maintained with the logbook. Any actions, *e.g.* objections, to the plan and any actions relative to the alternative control measures, *e.g.* approvals, shall be noted in the logbook as well.

(7) For each bag leak detection system, the owner or operator must keep the records specified in paragraphs (a)(7)(i) through (iii) of this section.

(i) Records of the bag leak detection system output;

(ii) Records of bag leak detection system adjustments, including the date and time of the adjustment, the initial bag leak detection system settings, and the final bag leak detection settings; and

(iii) The date and time of all bag leak detection system alarms, the time that procedures to determine the cause of the alarm were initiated, the cause of the alarm, an explanation of the actions taken, the date and time the cause of the alarm was alleviated, and whether the cause of the alarm was alleviated within 3 hours of the alarm.

(8) A copy of any applicable monitoring plan for a digital opacity compliance system and monthly certification that the plan was implemented as described. Any variance from plan, if any, shall be noted.

(9) During a performance test of a wet scrubber, and each operating day thereafter, the owner or operator shall record the measurements of the scrubber pressure loss, water supply flow rate, and pH of the wet scrubber liquid.

(10) During a performance test of control equipment other than a wet scrubber, and each operating day thereafter, the owner or operator shall record the measurements of the reagent injection flow rate, as applicable.

(b) For the purpose of reports required under section 60.7(c), any owner operator subject to the provisions of this subpart also shall report semiannually periods of excess emissions as follow:

(1) The owner or operator of an affected facility with a wet scrubber shall submit semiannual reports to the Administrator or delegated authority of occurrences when the measurements of the scrubber pressure loss, water supply flow rate, or pH of the wet scrubber liquid vary by more than 10 percent from the average determined during the most recent performance test.

(2) The owner or operator of an affected facility with control equipment other than a wet scrubber shall submit semiannual reports to the Administrator or delegated authority of occurrences when the measurements of the reagent injection flow rate, as applicable, vary by more than 10 percent from the average determined during the most recent performance test.

(3) All 6-minute average opacities that exceed the applicable standard.

(c) The owner or operator of an affected facility shall submit the results of initial performance tests to the Administrator or delegated authority, consistent with the provisions of section 60.8. The owner or operator who elects to comply with the reduced performance testing provisions of sections 60.255(c) or (d) shall include in the performance test report identification of each affected facility that will be subject to the reduced testing. The owner or operator electing to comply with section 60.255(d) shall also include information which demonstrates that the control devices are identical.

(d) After July 1, 2011, within 60 days after the date of completing each performance evaluation conducted to demonstrate compliance with this subpart, the owner or operator of the affected facility must submit the test data to EPA by successfully entering the data electronically into EPA's WebFIRE data base available at <http://cfpub.epa.gov/oarweb/index.cfm?action=fire.main>. For performance tests that cannot be entered into WebFIRE ( *i.e.*, Method 9 of appendix A-4 of this part opacity performance tests) the owner or operator of the affected facility must mail a summary copy to United States Environmental Protection Agency; Energy Strategies Group; 109 TW Alexander DR; mail code: D243-01; RTP, NC 27711.

APPENDIX G  
40 CFR Part 63, Subpart ZZZZ  
*National Emissions Standards for Hazardous Air Pollutants for Reciprocating Internal Combustion  
Engines*

## **Subpart ZZZZ—National Emissions Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines**

**Source:** 69 FR 33506, June 15, 2004, unless otherwise noted.

### **What This Subpart Covers**

#### **§ 63.6580 What is the purpose of subpart ZZZZ?**

Subpart ZZZZ establishes national emission limitations and operating limitations for hazardous air pollutants (HAP) emitted from stationary reciprocating internal combustion engines (RICE) located at major and area sources of HAP emissions. This subpart also establishes requirements to demonstrate initial and continuous compliance with the emission limitations and operating limitations.

[73 FR 3603, Jan. 18, 2008]

#### **§ 63.6585 Am I subject to this subpart?**

You are subject to this subpart if you own or operate a stationary RICE at a major or area source of HAP emissions, except if the stationary RICE is being tested at a stationary RICE test cell/stand.

(a) A stationary RICE is any internal combustion engine which uses reciprocating motion to convert heat energy into mechanical work and which is not mobile. Stationary RICE differ from mobile RICE in that a stationary RICE is not a non-road engine as defined at 40 CFR 1068.30, and is not used to propel a motor vehicle or a vehicle used solely for competition.

(b) A major source of HAP emissions is a plant site that emits or has the potential to emit any single HAP at a rate of 10 tons (9.07 megagrams) or more per year or any combination of HAP at a rate of 25 tons (22.68 megagrams) or more per year, except that for oil and gas production facilities, a major source of HAP emissions is determined for each surface site.

(c) An area source of HAP emissions is a source that is not a major source.

(d) If you are an owner or operator of an area source subject to this subpart, your status as an entity subject to a standard or other requirements under this subpart does not subject you to the obligation to obtain a permit under 40 CFR part 70 or 71, provided you are not required to obtain a permit under 40 CFR 70.3(a) or 40 CFR 71.3(a) for a reason other than your status as an area source under this subpart. Notwithstanding the previous sentence, you must continue to comply with the provisions of this subpart as applicable.

(e) If you are an owner or operator of a stationary RICE used for national security purposes, you may be eligible to request an exemption from the requirements of this subpart as described in 40 CFR part 1068, subpart C.

[69 FR 33506, June 15, 2004, as amended at 73 FR 3603, Jan. 18, 2008]

#### **§ 63.6590 What parts of my plant does this subpart cover?**

This subpart applies to each affected source.

(a) *Affected source.* An affected source is any existing, new, or reconstructed stationary RICE located at a major or area source of HAP emissions, excluding stationary RICE being tested at a stationary RICE test cell/stand.

(1) *Existing stationary RICE.*

(i) For stationary RICE with a site rating of more than 500 brake horsepower (HP) located at a major source of HAP emissions, a stationary RICE is existing if you commenced construction or reconstruction of the stationary RICE before December 19, 2002.

(ii) For stationary RICE with a site rating of less than or equal to 500 brake HP located at a major source of HAP emissions, a stationary RICE is existing if you commenced construction or reconstruction of the stationary RICE before June 12, 2006.

(iii) For stationary RICE located at an area source of HAP emissions, a stationary RICE is existing if you commenced construction or reconstruction of the stationary RICE before June 12, 2006.

(iv) A change in ownership of an existing stationary RICE does not make that stationary RICE a new or reconstructed stationary RICE.

(2) *New stationary RICE.* (i) A stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions is new if you commenced construction of the stationary RICE on or after December 19, 2002.

(ii) A stationary RICE with a site rating of equal to or less than 500 brake HP located at a major source of HAP emissions is new if you commenced construction of the stationary RICE on or after June 12, 2006.

(iii) A stationary RICE located at an area source of HAP emissions is new if you commenced construction of the stationary RICE on or after June 12, 2006.

(3) *Reconstructed stationary RICE.* (i) A stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions is reconstructed if you meet the definition of reconstruction in §63.2 and reconstruction is commenced on or after December 19, 2002.

(ii) A stationary RICE with a site rating of equal to or less than 500 brake HP located at a major source of HAP emissions is reconstructed if you meet the definition of reconstruction in §63.2 and reconstruction is commenced on or after June 12, 2006.

(iii) A stationary RICE located at an area source of HAP emissions is reconstructed if you meet the definition of reconstruction in §63.2 and reconstruction is commenced on or after June 12, 2006.

(b) *Stationary RICE subject to limited requirements.* (1) An affected source which meets either of the criteria in paragraphs (b)(1)(i) through (ii) of this section does not have to meet the requirements of this subpart and of subpart A of this part except for the initial notification requirements of §63.6645(f).

(i) The stationary RICE is a new or reconstructed emergency stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions.

(ii) The stationary RICE is a new or reconstructed limited use stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions.

(2) A new or reconstructed stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions which combusts landfill or digester gas equivalent to 10 percent or more of the gross heat input on an annual basis must meet the initial notification requirements of §63.6645(f) and the requirements of §§63.6625(c), 63.6650(g), and 63.6655(c). These stationary RICE do not have to meet the emission limitations and operating limitations of this subpart.

(3) The following stationary RICE do not have to meet the requirements of this subpart and of subpart A of this part, including initial notification requirements:

(i) Existing spark ignition 2 stroke lean burn (2SLB) stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions;

(ii) Existing spark ignition 4 stroke lean burn (4SLB) stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions;

(iii) Existing emergency stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions;

(iv) Existing limited use stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions;

(v) Existing stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions that combusts landfill gas or digester gas equivalent to 10 percent or more of the gross heat input on an annual basis;

(vi) Existing residential emergency stationary RICE located at an area source of HAP emissions;

(vii) Existing commercial emergency stationary RICE located at an area source of HAP emissions; or

(viii) Existing institutional emergency stationary RICE located at an area source of HAP emissions.

(c) *Stationary RICE subject to Regulations under 40 CFR Part 60.* An affected source that meets any of the criteria in paragraphs (c)(1) through (7) of this section must meet the requirements of this part by meeting the requirements of 40 CFR part 60 subpart IIII, for compression ignition engines or 40 CFR part 60 subpart JJJJ, for spark ignition engines. No further requirements apply for such engines under this part.

(1) A new or reconstructed stationary RICE located at an area source;

(2) A new or reconstructed 2SLB stationary RICE with a site rating of less than or equal to 500 brake HP located at a major source of HAP emissions;

(3) A new or reconstructed 4SLB stationary RICE with a site rating of less than 250 brake HP located at a major source of HAP emissions;

(4) A new or reconstructed spark ignition 4 stroke rich burn (4SRB) stationary RICE with a site rating of less than or equal to 500 brake HP located at a major source of HAP emissions;

(5) A new or reconstructed stationary RICE with a site rating of less than or equal to 500 brake HP located at a major source of HAP emissions which combusts landfill or digester gas equivalent to 10 percent or more of the gross heat input on an annual basis;

(6) A new or reconstructed emergency or limited use stationary RICE with a site rating of less than or equal to 500 brake HP located at a major source of HAP emissions;

(7) A new or reconstructed compression ignition (CI) stationary RICE with a site rating of less than or equal to 500 brake HP located at a major source of HAP emissions.

[69 FR 33506, June 15, 2004, as amended at 73 FR 3604, Jan. 18, 2008; 75 FR 9674, Mar. 3, 2010; 75 FR 37733, June 30, 2010; 75 FR 51588, Aug. 20, 2010]

### **§ 63.6595 When do I have to comply with this subpart?**

(a) *Affected sources.* (1) If you have an existing stationary RICE, excluding existing non-emergency CI stationary RICE, with a site rating of more than 500 brake HP located at a major source of HAP emissions, you must comply with the applicable emission limitations and operating limitations no later than June 15, 2007. If you have an existing non-emergency CI stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions, an existing stationary CI RICE with a site rating of less than or equal to 500 brake HP located at a major source of HAP emissions, or an existing stationary CI RICE

located at an area source of HAP emissions, you must comply with the applicable emission limitations and operating limitations no later than May 3, 2013. If you have an existing stationary SI RICE with a site rating of less than or equal to 500 brake HP located at a major source of HAP emissions, or an existing stationary SI RICE located at an area source of HAP emissions, you must comply with the applicable emission limitations and operating limitations no later than October 19, 2013.

(2) If you start up your new or reconstructed stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions before August 16, 2004, you must comply with the applicable emission limitations and operating limitations in this subpart no later than August 16, 2004.

(3) If you start up your new or reconstructed stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions after August 16, 2004, you must comply with the applicable emission limitations and operating limitations in this subpart upon startup of your affected source.

(4) If you start up your new or reconstructed stationary RICE with a site rating of less than or equal to 500 brake HP located at a major source of HAP emissions before January 18, 2008, you must comply with the applicable emission limitations and operating limitations in this subpart no later than January 18, 2008.

(5) If you start up your new or reconstructed stationary RICE with a site rating of less than or equal to 500 brake HP located at a major source of HAP emissions after January 18, 2008, you must comply with the applicable emission limitations and operating limitations in this subpart upon startup of your affected source.

(6) If you start up your new or reconstructed stationary RICE located at an area source of HAP emissions before January 18, 2008, you must comply with the applicable emission limitations and operating limitations in this subpart no later than January 18, 2008.

(7) If you start up your new or reconstructed stationary RICE located at an area source of HAP emissions after January 18, 2008, you must comply with the applicable emission limitations and operating limitations in this subpart upon startup of your affected source.

(b) *Area sources that become major sources.* If you have an area source that increases its emissions or its potential to emit such that it becomes a major source of HAP, the compliance dates in paragraphs (b)(1) and (2) of this section apply to you.

(1) Any stationary RICE for which construction or reconstruction is commenced after the date when your area source becomes a major source of HAP must be in compliance with this subpart upon startup of your affected source.

(2) Any stationary RICE for which construction or reconstruction is commenced before your area source becomes a major source of HAP must be in compliance with the provisions of this subpart that are applicable to RICE located at major sources within 3 years after your area source becomes a major source of HAP.

(c) If you own or operate an affected source, you must meet the applicable notification requirements in §63.6645 and in 40 CFR part 63, subpart A.

[69 FR 33506, June 15, 2004, as amended at 73 FR 3604, Jan. 18, 2008; 75 FR 9675, Mar. 3, 2010; 75 FR 51589, Aug. 20, 2010]

## **Emission and Operating Limitations**

**§ 63.6600 What emission limitations and operating limitations must I meet if I own or operate a stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions?**

Compliance with the numerical emission limitations established in this subpart is based on the results of testing the average of three 1-hour runs using the testing requirements and procedures in §63.6620 and Table 4 to this subpart.

(a) If you own or operate an existing, new, or reconstructed spark ignition 4SRB stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions, you must comply with the emission limitations in Table 1a to this subpart and the operating limitations in Table 1b to this subpart which apply to you.

(b) If you own or operate a new or reconstructed 2SLB stationary RICE with a site rating of more than 500 brake HP located at major source of HAP emissions, a new or reconstructed 4SLB stationary RICE with a site rating of more than 500 brake HP located at major source of HAP emissions, or a new or reconstructed CI stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions, you must comply with the emission limitations in Table 2a to this subpart and the operating limitations in Table 2b to this subpart which apply to you.

(c) If you own or operate any of the following stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions, you do not need to comply with the emission limitations in Tables 1a, 2a, 2c, and 2d to this subpart or operating limitations in Tables 1b and 2b to this subpart: an existing 2SLB stationary RICE; an existing 4SLB stationary RICE; a stationary RICE that combusts landfill gas or digester gas equivalent to 10 percent or more of the gross heat input on an annual basis; an emergency stationary RICE; or a limited use stationary RICE.

(d) If you own or operate an existing non-emergency stationary CI RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions, you must comply with the emission limitations in Table 2c to this subpart and the operating limitations in Table 2b to this subpart which apply to you.

[73 FR 3605, Jan. 18, 2008, as amended at 75 FR 9675, Mar. 3, 2010]

**§ 63.6601 What emission limitations must I meet if I own or operate a new or reconstructed 4SLB stationary RICE with a site rating of greater than or equal to 250 brake HP and less than or equal to 500 brake HP located at a major source of HAP emissions?**

Compliance with the numerical emission limitations established in this subpart is based on the results of testing the average of three 1-hour runs using the testing requirements and procedures in §63.6620 and Table 4 to this subpart. If you own or operate a new or reconstructed 4SLB stationary RICE with a site rating of greater than or equal to 250 and less than or equal to 500 brake HP located at major source of HAP emissions manufactured on or after January 1, 2008, you must comply with the emission limitations in Table 2a to this subpart and the operating limitations in Table 2b to this subpart which apply to you.

[73 FR 3605, Jan. 18, 2008, as amended at 75 FR 9675, Mar. 3, 2010; 75 FR 51589, Aug. 20, 2010]

**§ 63.6602 What emission limitations must I meet if I own or operate an existing stationary RICE with a site rating of equal to or less than 500 brake HP located at a major source of HAP emissions?**

If you own or operate an existing stationary RICE with a site rating of equal to or less than 500 brake HP located at a major source of HAP emissions, you must comply with the emission limitations in Table 2c to this subpart which apply to you. Compliance with the numerical emission limitations established in this subpart is based on the results of testing the average of three 1-hour runs using the testing requirements and procedures in §63.6620 and Table 4 to this subpart.

[75 FR 51589, Aug. 20, 2010]

**§ 63.6603 What emission limitations and operating limitations must I meet if I own or operate an existing stationary RICE located at an area source of HAP emissions?**

[Link to an amendment published at 76 FR 12866, March 9, 2011.](#)

Compliance with the numerical emission limitations established in this subpart is based on the results of testing the average of three 1-hour runs using the testing requirements and procedures in §63.6620 and Table 4 to this subpart.

(a) If you own or operate an existing stationary RICE located at an area source of HAP emissions, you must comply with the requirements in Table 2d to this subpart and the operating limitations in Table 2b to this subpart which apply to you.

(b) If you own or operate an existing stationary non-emergency CI RICE greater than 300 HP located at area sources in areas of Alaska not accessible by the Federal Aid Highway System (FAHS) you do not have to meet the numerical CO emission limitations specified in Table 2d to this subpart. Existing stationary non-emergency CI RICE greater than 300 HP located at area sources in areas of Alaska not accessible by the FAHS must meet the management practices that are shown for stationary non-emergency CI RICE less than or equal to 300 HP in Table 2d to this subpart.

[75 FR 9675, Mar. 3, 2010, as amended at 75 FR 51589, Aug. 20, 2010]

#### **§ 63.6604 What fuel requirements must I meet if I own or operate an existing stationary CI RICE?**

If you own or operate an existing non-emergency, non-black start CI stationary RICE with a site rating of more than 300 brake HP with a displacement of less than 30 liters per cylinder that uses diesel fuel, you must use diesel fuel that meets the requirements in 40 CFR 80.510(b) for nonroad diesel fuel. Existing non-emergency CI stationary RICE located in Guam, American Samoa, the Commonwealth of the Northern Mariana Islands, or at area sources in areas of Alaska not accessible by the FAHS are exempt from the requirements of this section.

[75 FR 51589, Aug. 20, 2010]

#### **General Compliance Requirements**

#### **§ 63.6605 What are my general requirements for complying with this subpart?**

(a) You must be in compliance with the emission limitations and operating limitations in this subpart that apply to you at all times.

(b) At all times you must operate and maintain any affected source, including associated air pollution control equipment and monitoring equipment, in a manner consistent with safety and good air pollution control practices for minimizing emissions. The general duty to minimize emissions does not require you to make any further efforts to reduce emissions if levels required by this standard have been achieved. Determination of whether such operation and maintenance procedures are being used will be based on information available to the Administrator which may include, but is not limited to, monitoring results, review of operation and maintenance procedures, review of operation and maintenance records, and inspection of the source.

[75 FR 9675, Mar. 3, 2010]

#### **Testing and Initial Compliance Requirements**

#### **§ 63.6610 By what date must I conduct the initial performance tests or other initial compliance demonstrations if I own or operate a stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions?**

If you own or operate a stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions you are subject to the requirements of this section.

(a) You must conduct the initial performance test or other initial compliance demonstrations in Table 4 to this subpart that apply to you within 180 days after the compliance date that is specified for your stationary RICE in §63.6595 and according to the provisions in §63.7(a)(2).

(b) If you commenced construction or reconstruction between December 19, 2002 and June 15, 2004 and own or operate stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions, you must demonstrate initial compliance with either the proposed emission limitations or the promulgated emission limitations no later than February 10, 2005 or no later than 180 days after startup of the source, whichever is later, according to §63.7(a)(2)(ix).

(c) If you commenced construction or reconstruction between December 19, 2002 and June 15, 2004 and own or operate stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions, and you chose to comply with the proposed emission limitations when demonstrating initial compliance, you must conduct a second performance test to demonstrate compliance with the promulgated emission limitations by December 13, 2007 or after startup of the source, whichever is later, according to §63.7(a)(2)(ix).

(d) An owner or operator is not required to conduct an initial performance test on units for which a performance test has been previously conducted, but the test must meet all of the conditions described in paragraphs (d)(1) through (5) of this section.

(1) The test must have been conducted using the same methods specified in this subpart, and these methods must have been followed correctly.

(2) The test must not be older than 2 years.

(3) The test must be reviewed and accepted by the Administrator.

(4) Either no process or equipment changes must have been made since the test was performed, or the owner or operator must be able to demonstrate that the results of the performance test, with or without adjustments, reliably demonstrate compliance despite process or equipment changes.

(5) The test must be conducted at any load condition within plus or minus 10 percent of 100 percent load.

[69 FR 33506, June 15, 2004, as amended at 73 FR 3605, Jan. 18, 2008]

**§ 63.6611 By what date must I conduct the initial performance tests or other initial compliance demonstrations if I own or operate a new or reconstructed 4SLB SI stationary RICE with a site rating of greater than or equal to 250 and less than or equal to 500 brake HP located at a major source of HAP emissions?**

If you own or operate a new or reconstructed 4SLB stationary RICE with a site rating of greater than or equal to 250 and less than or equal to 500 brake HP located at a major source of HAP emissions, you must conduct an initial performance test within 240 days after the compliance date that is specified for your stationary RICE in §63.6595 and according to the provisions specified in Table 4 to this subpart, as appropriate.

[73 FR 3605, Jan. 18, 2008, as amended at 75 FR 51589, Aug. 20, 2010]

**§ 63.6612 By what date must I conduct the initial performance tests or other initial compliance demonstrations if I own or operate an existing stationary RICE with a site rating of less than or equal to 500 brake HP located at a major source of HAP emissions or an existing stationary RICE located at an area source of HAP emissions?**

If you own or operate an existing stationary RICE with a site rating of less than or equal to 500 brake HP located at a major source of HAP emissions or an existing stationary RICE located at an area source of HAP emissions you are subject to the requirements of this section.

(a) You must conduct any initial performance test or other initial compliance demonstration according to Tables 4 and 5 to this subpart that apply to you within 180 days after the compliance date that is specified for your stationary RICE in §63.6595 and according to the provisions in §63.7(a)(2).

(b) An owner or operator is not required to conduct an initial performance test on a unit for which a performance test has been previously conducted, but the test must meet all of the conditions described in paragraphs (b)(1) through (4) of this section.

(1) The test must have been conducted using the same methods specified in this subpart, and these methods must have been followed correctly.

(2) The test must not be older than 2 years.

(3) The test must be reviewed and accepted by the Administrator.

(4) Either no process or equipment changes must have been made since the test was performed, or the owner or operator must be able to demonstrate that the results of the performance test, with or without adjustments, reliably demonstrate compliance despite process or equipment changes.

[75 FR 9676, Mar. 3, 2010, as amended at 75 FR 51589, Aug. 20, 2010]

#### **§ 63.6615 When must I conduct subsequent performance tests?**

If you must comply with the emission limitations and operating limitations, you must conduct subsequent performance tests as specified in Table 3 of this subpart.

#### **§ 63.6620 What performance tests and other procedures must I use?**

(a) You must conduct each performance test in Tables 3 and 4 of this subpart that applies to you.

(b) Each performance test must be conducted according to the requirements that this subpart specifies in Table 4 to this subpart. If you own or operate a non-operational stationary RICE that is subject to performance testing, you do not need to start up the engine solely to conduct the performance test. Owners and operators of a non-operational engine can conduct the performance test when the engine is started up again.

(c) [Reserved]

(d) You must conduct three separate test runs for each performance test required in this section, as specified in §63.7(e)(3). Each test run must last at least 1 hour.

(e)(1) You must use Equation 1 of this section to determine compliance with the percent reduction requirement:

$$\frac{C_i - C_o}{C_i} \times 100 = R \quad (\text{Eq. 1})$$

Where:

$C_i$  = concentration of CO or formaldehyde at the control device inlet,

$C_o$  = concentration of CO or formaldehyde at the control device outlet, and

R = percent reduction of CO or formaldehyde emissions.

(2) You must normalize the carbon monoxide (CO) or formaldehyde concentrations at the inlet and outlet of the control device to a dry basis and to 15 percent oxygen, or an equivalent percent carbon dioxide (CO<sub>2</sub>). If pollutant concentrations are to be corrected to 15 percent oxygen and CO<sub>2</sub> concentration is measured in lieu of oxygen concentration measurement, a CO<sub>2</sub> correction factor is needed. Calculate the CO<sub>2</sub> correction factor as described in paragraphs (e)(2)(i) through (iii) of this section.

(i) Calculate the fuel-specific  $F_o$  value for the fuel burned during the test using values obtained from Method 19, section 5.2, and the following equation:

$$F_o = \frac{0.209 F_d}{F_c} \quad (\text{Eq. 2})$$

Where:

$F_o$  = Fuel factor based on the ratio of oxygen volume to the ultimate CO<sub>2</sub> volume produced by the fuel at zero percent excess air.

0.209 = Fraction of air that is oxygen, percent/100.

$F_d$  = Ratio of the volume of dry effluent gas to the gross calorific value of the fuel from Method 19,  $\text{dsm}^3/\text{J}$  ( $\text{dscf}/10^6 \text{ Btu}$ ).

$F_c$  = Ratio of the volume of CO<sub>2</sub> produced to the gross calorific value of the fuel from Method 19,  $\text{dsm}^3/\text{J}$  ( $\text{dscf}/10^6 \text{ Btu}$ ).

(ii) Calculate the CO<sub>2</sub> correction factor for correcting measurement data to 15 percent oxygen, as follows:

$$X_{\text{co}_2} = \frac{5.9}{F_o} \quad (\text{Eq. 3})$$

Where:

$X_{\text{co}_2}$  = CO<sub>2</sub> correction factor, percent.

5.9 = 20.9 percent O<sub>2</sub> - 15 percent O<sub>2</sub>, the defined O<sub>2</sub> correction value, percent.

(iii) Calculate the NO<sub>x</sub> and SO<sub>2</sub> gas concentrations adjusted to 15 percent O<sub>2</sub> using CO<sub>2</sub> as follows:

$$C_{\text{adj}} = C_d \frac{X_{\text{co}_2}}{\% \text{CO}_2} \quad (\text{Eq. 4})$$

Where:

%CO<sub>2</sub> = Measured CO<sub>2</sub> concentration measured, dry basis, percent.

(f) If you comply with the emission limitation to reduce CO and you are not using an oxidation catalyst, if you comply with the emission limitation to reduce formaldehyde and you are not using NSCR, or if you comply with the emission limitation to limit the concentration of formaldehyde in the stationary RICE exhaust and you are not using an oxidation catalyst or NSCR, you must petition the Administrator for operating limitations to be established during the initial performance test and continuously monitored thereafter; or for approval of no operating limitations. You must not conduct the initial performance test until after the petition has been approved by the Administrator.

(g) If you petition the Administrator for approval of operating limitations, your petition must include the information described in paragraphs (g)(1) through (5) of this section.

(1) Identification of the specific parameters you propose to use as operating limitations;

(2) A discussion of the relationship between these parameters and HAP emissions, identifying how HAP emissions change with changes in these parameters, and how limitations on these parameters will serve to limit HAP emissions;

(3) A discussion of how you will establish the upper and/or lower values for these parameters which will establish the limits on these parameters in the operating limitations;

(4) A discussion identifying the methods you will use to measure and the instruments you will use to monitor these parameters, as well as the relative accuracy and precision of these methods and instruments; and

(5) A discussion identifying the frequency and methods for recalibrating the instruments you will use for monitoring these parameters.

(h) If you petition the Administrator for approval of no operating limitations, your petition must include the information described in paragraphs (h)(1) through (7) of this section.

(1) Identification of the parameters associated with operation of the stationary RICE and any emission control device which could change intentionally ( e.g., operator adjustment, automatic controller adjustment, etc.) or unintentionally ( e.g., wear and tear, error, etc.) on a routine basis or over time;

(2) A discussion of the relationship, if any, between changes in the parameters and changes in HAP emissions;

(3) For the parameters which could change in such a way as to increase HAP emissions, a discussion of whether establishing limitations on the parameters would serve to limit HAP emissions;

(4) For the parameters which could change in such a way as to increase HAP emissions, a discussion of how you could establish upper and/or lower values for the parameters which would establish limits on the parameters in operating limitations;

(5) For the parameters, a discussion identifying the methods you could use to measure them and the instruments you could use to monitor them, as well as the relative accuracy and precision of the methods and instruments;

(6) For the parameters, a discussion identifying the frequency and methods for recalibrating the instruments you could use to monitor them; and

(7) A discussion of why, from your point of view, it is infeasible or unreasonable to adopt the parameters as operating limitations.

(i) The engine percent load during a performance test must be determined by documenting the calculations, assumptions, and measurement devices used to measure or estimate the percent load in a specific application. A written report of the average percent load determination must be included in the notification of compliance status. The following information must be included in the written report: the engine model

number, the engine manufacturer, the year of purchase, the manufacturer's site-rated brake horsepower, the ambient temperature, pressure, and humidity during the performance test, and all assumptions that were made to estimate or calculate percent load during the performance test must be clearly explained. If measurement devices such as flow meters, kilowatt meters, beta analyzers, stain gauges, etc. are used, the model number of the measurement device, and an estimate of its accuracy in percentage of true value must be provided.

[69 FR 33506, June 15, 2004, as amended at 75 FR 9676, Mar. 3, 2010]

### **§ 63.6625 What are my monitoring, installation, collection, operation, and maintenance requirements?**

[Link to an amendment published at 76 FR 12866, March 9, 2011.](#)

(a) If you elect to install a CEMS as specified in Table 5 of this subpart, you must install, operate, and maintain a CEMS to monitor CO and either oxygen or CO<sub>2</sub> at both the inlet and the outlet of the control device according to the requirements in paragraphs (a)(1) through (4) of this section.

(1) Each CEMS must be installed, operated, and maintained according to the applicable performance specifications of 40 CFR part 60, appendix B.

(2) You must conduct an initial performance evaluation and an annual relative accuracy test audit (RATA) of each CEMS according to the requirements in §63.8 and according to the applicable performance specifications of 40 CFR part 60, appendix B as well as daily and periodic data quality checks in accordance with 40 CFR part 60, appendix F, procedure 1.

(3) As specified in §63.8(c)(4)(ii), each CEMS must complete a minimum of one cycle of operation (sampling, analyzing, and data recording) for each successive 15-minute period. You must have at least two data points, with each representing a different 15-minute period, to have a valid hour of data.

(4) The CEMS data must be reduced as specified in §63.8(g)(2) and recorded in parts per million or parts per billion (as appropriate for the applicable limitation) at 15 percent oxygen or the equivalent CO<sub>2</sub> concentration.

(b) If you are required to install a continuous parameter monitoring system (CPMS) as specified in Table 5 of this subpart, you must install, operate, and maintain each CPMS according to the requirements in paragraphs (b)(1) through (8) of this section.

(1) The CPMS must complete a minimum of one cycle of operation for each successive 15-minute period. You must have a minimum of four successive cycles of operation to have a valid hour of data.

(2) Except for monitoring malfunctions, associated repairs, and required quality assurance or control activities (including, as applicable, calibration checks and required zero and span adjustments), you must conduct all monitoring in continuous operation at all times that the unit is operating. A monitoring malfunction is any sudden, infrequent, not reasonably preventable failure of the monitoring to provide valid data. Monitoring failures that are caused in part by poor maintenance or careless operation are not malfunctions.

(3) For purposes of calculating data averages, you must not use data recorded during monitoring malfunctions, associated repairs, out of control periods, or required quality assurance or control activities. You must use all the data collected during all other periods in assessing compliance. Any 15-minute period for which the monitoring system is out-of-control and data are not available for required calculations constitutes a deviation from the monitoring requirements.

(4) Determine the 3-hour block average of all recorded readings, except as provided in paragraph (b)(3) of this section.

(5) Record the results of each inspection, calibration, and validation check.

(6) You must develop a site-specific monitoring plan that addresses paragraphs (b)(6)(i) through (vi) of this section.

(i) Installation of the CPMS sampling probe or other interface at the appropriate location to obtain representative measurements;

(ii) Performance and equipment specifications for the sample interface, parametric signal analyzer, and the data collection and reduction systems;

(iii) Performance evaluation procedures and acceptance criteria ( e.g., calibrations);

(iv) Ongoing operation and maintenance procedures in accordance with the general requirements of §63.8(c)(1), (c)(3), and (c)(4)(ii);

(v) Ongoing data quality assurance procedures in accordance with the general requirements of §63.8(d); and

(vi) Ongoing recordkeeping and reporting procedures in accordance with the general requirements of §63.10(c), (e)(1), and (e)(2)(i).

(7) You must conduct a performance evaluation of each CPMS in accordance with your site-specific monitoring plan.

(8) You must operate and maintain the CPMS in continuous operation according to the site-specific monitoring plan.

(c) If you are operating a new or reconstructed stationary RICE which fires landfill gas or digester gas equivalent to 10 percent or more of the gross heat input on an annual basis, you must monitor and record your fuel usage daily with separate fuel meters to measure the volumetric flow rate of each fuel. In addition, you must operate your stationary RICE in a manner which reasonably minimizes HAP emissions.

(d) If you are operating a new or reconstructed emergency 4SLB stationary RICE with a site rating of greater than or equal to 250 and less than or equal to 500 brake HP located at a major source of HAP emissions, you must install a non-resettable hour meter prior to the startup of the engine.

(e) If you own or operate any of the following stationary RICE, you must operate and maintain the stationary RICE and after-treatment control device (if any) according to the manufacturer's emission-related written instructions or develop your own maintenance plan which must provide to the extent practicable for the maintenance and operation of the engine in a manner consistent with good air pollution control practice for minimizing emissions:

(1) An existing stationary RICE with a site rating of less than 100 HP located at a major source of HAP emissions;

(2) An existing emergency or black start stationary RICE with a site rating of less than or equal to 500 HP located at a major source of HAP emissions;

(3) An existing emergency or black start stationary RICE located at an area source of HAP emissions;

(4) An existing non-emergency, non-black start stationary CI RICE with a site rating less than or equal to 300 HP located at an area source of HAP emissions;

(5) An existing non-emergency, non-black start 2SLB stationary RICE located at an area source of HAP emissions;

- (6) An existing non-emergency, non-black start landfill or digester gas stationary RICE located at an area source of HAP emissions;
- (7) An existing non-emergency, non-black start 4SLB stationary RICE with a site rating less than or equal to 500 HP located at an area source of HAP emissions;
- (8) An existing non-emergency, non-black start 4SRB stationary RICE with a site rating less than or equal to 500 HP located at an area source of HAP emissions;
- (9) An existing, non-emergency, non-black start 4SLB stationary RICE with a site rating greater than 500 HP located at an area source of HAP emissions that is operated 24 hours or less per calendar year; and
- (10) An existing, non-emergency, non-black start 4SRB stationary RICE with a site rating greater than 500 HP located at an area source of HAP emissions that is operated 24 hours or less per calendar year.
- (f) If you own or operate an existing emergency stationary RICE with a site rating of less than or equal to 500 brake HP located at a major source of HAP emissions or an existing emergency stationary RICE located at an area source of HAP emissions, you must install a non-resettable hour meter if one is not already installed.
- (g) If you own or operate an existing non-emergency, non-black start CI engine greater than or equal to 300 HP that is not equipped with a closed crankcase ventilation system, you must comply with either paragraph (g)(1) or paragraph (g)(2) of this section. Owners and operators must follow the manufacturer's specified maintenance requirements for operating and maintaining the open or closed crankcase ventilation systems and replacing the crankcase filters, or can request the Administrator to approve different maintenance requirements that are as protective as manufacturer requirements. Existing CI engines located at area sources in areas of Alaska not accessible by the FAHS do not have to meet the requirements of paragraph (g) of this section.
- (1) Install a closed crankcase ventilation system that prevents crankcase emissions from being emitted to the atmosphere, or
- (2) Install an open crankcase filtration emission control system that reduces emissions from the crankcase by filtering the exhaust stream to remove oil mist, particulates, and metals.
- (h) If you operate a new, reconstructed, or existing stationary engine, you must minimize the engine's time spent at idle during startup and minimize the engine's startup time to a period needed for appropriate and safe loading of the engine, not to exceed 30 minutes, after which time the emission standards applicable to all times other than startup in Tables 1a, 2a, 2c, and 2d to this subpart apply.
- (i) If you own or operate a stationary CI engine that is subject to the work, operation or management practices in items 1 or 2 of Table 2c to this subpart or in items 1 or 4 of Table 2d to this subpart, you have the option of utilizing an oil analysis program in order to extend the specified oil change requirement in Tables 2c and 2d to this subpart. The oil analysis must be performed at the same frequency specified for changing the oil in Table 2c or 2d to this subpart. The analysis program must at a minimum analyze the following three parameters: Total Base Number, viscosity, and percent water content. The condemning limits for these parameters are as follows: Total Base Number is less than 30 percent of the Total Base Number of the oil when new; viscosity of the oil has changed by more than 20 percent from the viscosity of the oil when new; or percent water content (by volume) is greater than 0.5. If all of these condemning limits are not exceeded, the engine owner or operator is not required to change the oil. If any of the limits are exceeded, the engine owner or operator must change the oil within 2 days of receiving the results of the analysis; if the engine is not in operation when the results of the analysis are received, the engine owner or operator must change the oil within 2 days or before commencing operation, whichever is later. The owner or operator must keep records of the parameters that are analyzed as part of the program, the results of the analysis, and the oil changes for the engine. The analysis program must be part of the maintenance plan for the engine.

(j) If you own or operate a stationary SI engine that is subject to the work, operation or management practices in items 6, 7, or 8 of Table 2c to this subpart or in items 5, 6, 7, 9, or 11 of Table 2d to this subpart, you have the option of utilizing an oil analysis program in order to extend the specified oil change requirement in Tables 2c and 2d to this subpart. The oil analysis must be performed at the same frequency specified for changing the oil in Table 2c or 2d to this subpart. The analysis program must at a minimum analyze the following three parameters: Total Acid Number, viscosity, and percent water content. The condemning limits for these parameters are as follows: Total Acid Number increases by more than 3.0 milligrams of potassium hydroxide (KOH) per gram from Total Acid Number of the oil when new; viscosity of the oil has changed by more than 20 percent from the viscosity of the oil when new; or percent water content (by volume) is greater than 0.5. If all of these condemning limits are not exceeded, the engine owner or operator is not required to change the oil. If any of the limits are exceeded, the engine owner or operator must change the oil within 2 days of receiving the results of the analysis; if the engine is not in operation when the results of the analysis are received, the engine owner or operator must change the oil within 2 days or before commencing operation, whichever is later. The owner or operator must keep records of the parameters that are analyzed as part of the program, the results of the analysis, and the oil changes for the engine. The analysis program must be part of the maintenance plan for the engine.

(k) If you have an operating limitation that requires the use of a temperature measurement device, you must meet the requirements in paragraphs (k)(1) through (4) of this section.

(1) Locate the temperature sensor and other necessary equipment in a position that provides a representative temperature.

(2) Use a temperature sensor with a minimum tolerance of 2.8 degrees Celsius (5 degrees Fahrenheit), or 1.0 percent of the temperature value, whichever is larger, for a noncryogenic temperature range.

(3) Use a temperature sensor with a minimum tolerance of 2.8 degrees Celsius (5 degrees Fahrenheit), or 2.5 percent of the temperature value, whichever is larger, for a cryogenic temperature range.

(4) Conduct a temperature measurement device calibration check at least every 3 months.

[69 FR 33506, June 15, 2004, as amended at 73 FR 3606, Jan. 18, 2008; 75 FR 9676, Mar. 3, 2010; 75 FR 51589, Aug. 20, 2010]

### **§ 63.6630 How do I demonstrate initial compliance with the emission limitations and operating limitations?**

(a) You must demonstrate initial compliance with each emission and operating limitation that applies to you according to Table 5 of this subpart.

(b) During the initial performance test, you must establish each operating limitation in Tables 1b and 2b of this subpart that applies to you.

(c) You must submit the Notification of Compliance Status containing the results of the initial compliance demonstration according to the requirements in §63.6645.

### **Continuous Compliance Requirements**

#### **§ 63.6635 How do I monitor and collect data to demonstrate continuous compliance?**

[Link to an amendment published at 76 FR 12867, March 9, 2011.](#)

(a) If you must comply with emission and operating limitations, you must monitor and collect data according to this section.

(b) Except for monitor malfunctions, associated repairs, and required quality assurance or control activities (including, as applicable, calibration checks and required zero and span adjustments), you must monitor continuously at all times that the stationary RICE is operating.

(c) You may not use data recorded during monitoring malfunctions, associated repairs, and required quality assurance or control activities in data averages and calculations used to report emission or operating levels. You must, however, use all the valid data collected during all other periods.

**§ 63.6640 How do I demonstrate continuous compliance with the emission limitations and operating limitations?**

(a) You must demonstrate continuous compliance with each emission limitation and operating limitation in Tables 1a and 1b, Tables 2a and 2b, Table 2c, and Table 2d to this subpart that apply to you according to methods specified in Table 6 to this subpart.

(b) You must report each instance in which you did not meet each emission limitation or operating limitation in Tables 1a and 1b, Tables 2a and 2b, Table 2c, and Table 2d to this subpart that apply to you. These instances are deviations from the emission and operating limitations in this subpart. These deviations must be reported according to the requirements in §63.6650. If you change your catalyst, you must reestablish the values of the operating parameters measured during the initial performance test. When you reestablish the values of your operating parameters, you must also conduct a performance test to demonstrate that you are meeting the required emission limitation applicable to your stationary RICE.

(c) [Reserved]

(d) For new, reconstructed, and rebuilt stationary RICE, deviations from the emission or operating limitations that occur during the first 200 hours of operation from engine startup (engine burn-in period) are not violations. Rebuilt stationary RICE means a stationary RICE that has been rebuilt as that term is defined in 40 CFR 94.11(a).

(e) You must also report each instance in which you did not meet the requirements in Table 8 to this subpart that apply to you. If you own or operate a new or reconstructed stationary RICE with a site rating of less than or equal to 500 brake HP located at a major source of HAP emissions (except new or reconstructed 4SLB engines greater than or equal to 250 and less than or equal to 500 brake HP), a new or reconstructed stationary RICE located at an area source of HAP emissions, or any of the following RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions, you do not need to comply with the requirements in Table 8 to this subpart: An existing 2SLB stationary RICE, an existing 4SLB stationary RICE, an existing emergency stationary RICE, an existing limited use stationary RICE, or an existing stationary RICE which fires landfill gas or digester gas equivalent to 10 percent or more of the gross heat input on an annual basis. If you own or operate any of the following RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions, you do not need to comply with the requirements in Table 8 to this subpart, except for the initial notification requirements: a new or reconstructed stationary RICE that combusts landfill gas or digester gas equivalent to 10 percent or more of the gross heat input on an annual basis, a new or reconstructed emergency stationary RICE, or a new or reconstructed limited use stationary RICE.

(f) *Requirements for emergency stationary RICE.* (1) If you own or operate an existing emergency stationary RICE with a site rating of less than or equal to 500 brake HP located at a major source of HAP emissions, a new or reconstructed emergency stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions that was installed on or after June 12, 2006, or an existing emergency stationary RICE located at an area source of HAP emissions, you must operate the emergency stationary RICE according to the requirements in paragraphs (f)(1)(i) through (iii) of this section. Any operation other than emergency operation, maintenance and testing, and operation in non-emergency situations for 50 hours per year, as described in paragraphs (f)(1)(i) through (iii) of this section, is prohibited. If you do not operate the engine according to the requirements in paragraphs (f)(1)(i) through (iii) of this section, the engine will not be considered an emergency engine under this subpart and will need to meet all requirements for non-emergency engines.

(i) There is no time limit on the use of emergency stationary RICE in emergency situations.

(ii) You may operate your emergency stationary RICE for the purpose of maintenance checks and readiness testing, provided that the tests are recommended by Federal, State or local government, the manufacturer, the vendor, or the insurance company associated with the engine. Maintenance checks and readiness testing of such units is limited to 100 hours per year. The owner or operator may petition the Administrator for approval of additional hours to be used for maintenance checks and readiness testing, but a petition is not required if the owner or operator maintains records indicating that Federal, State, or local standards require maintenance and testing of emergency RICE beyond 100 hours per year.

(iii) You may operate your emergency stationary RICE up to 50 hours per year in non-emergency situations, but those 50 hours are counted towards the 100 hours per year provided for maintenance and testing. The 50 hours per year for non-emergency situations cannot be used for peak shaving or to generate income for a facility to supply power to an electric grid or otherwise supply power as part of a financial arrangement with another entity; except that owners and operators may operate the emergency engine for a maximum of 15 hours per year as part of a demand response program if the regional transmission organization or equivalent balancing authority and transmission operator has determined there are emergency conditions that could lead to a potential electrical blackout, such as unusually low frequency, equipment overload, capacity or energy deficiency, or unacceptable voltage level. The engine may not be operated for more than 30 minutes prior to the time when the emergency condition is expected to occur, and the engine operation must be terminated immediately after the facility is notified that the emergency condition is no longer imminent. The 15 hours per year of demand response operation are counted as part of the 50 hours of operation per year provided for non-emergency situations. The supply of emergency power to another entity or entities pursuant to financial arrangement is not limited by this paragraph (f)(1)(iii), as long as the power provided by the financial arrangement is limited to emergency power.

(2) If you own or operate an emergency stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions that was installed prior to June 12, 2006, you must operate the engine according to the conditions described in paragraphs (f)(2)(i) through (iii) of this section. If you do not operate the engine according to the requirements in paragraphs (f)(2)(i) through (iii) of this section, the engine will not be considered an emergency engine under this subpart and will need to meet all requirements for non-emergency engines.

(i) There is no time limit on the use of emergency stationary RICE in emergency situations.

(ii) You may operate your emergency stationary RICE for the purpose of maintenance checks and readiness testing, provided that the tests are recommended by the manufacturer, the vendor, or the insurance company associated with the engine. Required testing of such units should be minimized, but there is no time limit on the use of emergency stationary RICE in emergency situations and for routine testing and maintenance.

(iii) You may operate your emergency stationary RICE for an additional 50 hours per year in non-emergency situations. The 50 hours per year for non-emergency situations cannot be used for peak shaving or to generate income for a facility to supply power to an electric grid or otherwise supply power as part of a financial arrangement with another entity.

[69 FR 33506, June 15, 2004, as amended at 71 FR 20467, Apr. 20, 2006; 73 FR 3606, Jan. 18, 2008; 75 FR 9676, Mar. 3, 2010; 75 FR 51591, Aug. 20, 2010]

## **Notifications, Reports, and Records**

### **§ 63.6645 What notifications must I submit and when?**

(a) You must submit all of the notifications in §§63.7(b) and (c), 63.8(e), (f)(4) and (f)(6), 63.9(b) through (e), and (g) and (h) that apply to you by the dates specified if you own or operate any of the following;

(1) An existing stationary RICE with a site rating of less than or equal to 500 brake HP located at a major source of HAP emissions.

(2) An existing stationary RICE located at an area source of HAP emissions.

- (3) A stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions.
- (4) A new or reconstructed 4SLB stationary RICE with a site rating of greater than or equal to 250 HP located at a major source of HAP emissions.
- (5) This requirement does not apply if you own or operate an existing stationary RICE less than 100 HP, an existing stationary emergency RICE, or an existing stationary RICE that is not subject to any numerical emission standards.
- (b) As specified in §63.9(b)(2), if you start up your stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions before the effective date of this subpart, you must submit an Initial Notification not later than December 13, 2004.
- (c) If you start up your new or reconstructed stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions on or after August 16, 2004, you must submit an Initial Notification not later than 120 days after you become subject to this subpart.
- (d) As specified in §63.9(b)(2), if you start up your stationary RICE with a site rating of equal to or less than 500 brake HP located at a major source of HAP emissions before the effective date of this subpart and you are required to submit an initial notification, you must submit an Initial Notification not later than July 16, 2008.
- (e) If you start up your new or reconstructed stationary RICE with a site rating of equal to or less than 500 brake HP located at a major source of HAP emissions on or after March 18, 2008 and you are required to submit an initial notification, you must submit an Initial Notification not later than 120 days after you become subject to this subpart.
- (f) If you are required to submit an Initial Notification but are otherwise not affected by the requirements of this subpart, in accordance with §63.6590(b), your notification should include the information in §63.9(b)(2)(i) through (v), and a statement that your stationary RICE has no additional requirements and explain the basis of the exclusion (for example, that it operates exclusively as an emergency stationary RICE if it has a site rating of more than 500 brake HP located at a major source of HAP emissions).
- (g) If you are required to conduct a performance test, you must submit a Notification of Intent to conduct a performance test at least 60 days before the performance test is scheduled to begin as required in §63.7(b)(1).
- (h) If you are required to conduct a performance test or other initial compliance demonstration as specified in Tables 4 and 5 to this subpart, you must submit a Notification of Compliance Status according to §63.9(h)(2)(ii).
- (1) For each initial compliance demonstration required in Table 5 to this subpart that does not include a performance test, you must submit the Notification of Compliance Status before the close of business on the 30th day following the completion of the initial compliance demonstration.
- (2) For each initial compliance demonstration required in Table 5 to this subpart that includes a performance test conducted according to the requirements in Table 3 to this subpart, you must submit the Notification of Compliance Status, including the performance test results, before the close of business on the 60th day following the completion of the performance test according to §63.10(d)(2).

[73 FR 3606, Jan. 18, 2008, as amended at 75 FR 9677, Mar. 3, 2010; 75 FR 51591, Aug. 20, 2010]

#### **§ 63.6650 What reports must I submit and when?**

- (a) You must submit each report in Table 7 of this subpart that applies to you.

(b) Unless the Administrator has approved a different schedule for submission of reports under §63.10(a), you must submit each report by the date in Table 7 of this subpart and according to the requirements in paragraphs (b)(1) through (b)(9) of this section.

(1) For semiannual Compliance reports, the first Compliance report must cover the period beginning on the compliance date that is specified for your affected source in §63.6595 and ending on June 30 or December 31, whichever date is the first date following the end of the first calendar half after the compliance date that is specified for your source in §63.6595.

(2) For semiannual Compliance reports, the first Compliance report must be postmarked or delivered no later than July 31 or January 31, whichever date follows the end of the first calendar half after the compliance date that is specified for your affected source in §63.6595.

(3) For semiannual Compliance reports, each subsequent Compliance report must cover the semiannual reporting period from January 1 through June 30 or the semiannual reporting period from July 1 through December 31.

(4) For semiannual Compliance reports, each subsequent Compliance report must be postmarked or delivered no later than July 31 or January 31, whichever date is the first date following the end of the semiannual reporting period.

(5) For each stationary RICE that is subject to permitting regulations pursuant to 40 CFR part 70 or 71, and if the permitting authority has established dates for submitting semiannual reports pursuant to 40 CFR 70.6(a)(3)(iii)(A) or 40 CFR 71.6 (a)(3)(iii)(A), you may submit the first and subsequent Compliance reports according to the dates the permitting authority has established instead of according to the dates in paragraphs (b)(1) through (b)(4) of this section.

(6) For annual Compliance reports, the first Compliance report must cover the period beginning on the compliance date that is specified for your affected source in §63.6595 and ending on December 31.

(7) For annual Compliance reports, the first Compliance report must be postmarked or delivered no later than January 31 following the end of the first calendar year after the compliance date that is specified for your affected source in §63.6595.

(8) For annual Compliance reports, each subsequent Compliance report must cover the annual reporting period from January 1 through December 31.

(9) For annual Compliance reports, each subsequent Compliance report must be postmarked or delivered no later than January 31.

(c) The Compliance report must contain the information in paragraphs (c)(1) through (6) of this section.

(1) Company name and address.

(2) Statement by a responsible official, with that official's name, title, and signature, certifying the accuracy of the content of the report.

(3) Date of report and beginning and ending dates of the reporting period.

(4) If you had a malfunction during the reporting period, the compliance report must include the number, duration, and a brief description for each type of malfunction which occurred during the reporting period and which caused or may have caused any applicable emission limitation to be exceeded. The report must also include a description of actions taken by an owner or operator during a malfunction of an affected source to minimize emissions in accordance with §63.6605(b), including actions taken to correct a malfunction.

(5) If there are no deviations from any emission or operating limitations that apply to you, a statement that there were no deviations from the emission or operating limitations during the reporting period.

(6) If there were no periods during which the continuous monitoring system (CMS), including CEMS and CPMS, was out-of-control, as specified in §63.8(c)(7), a statement that there were no periods during which the CMS was out-of-control during the reporting period.

(d) For each deviation from an emission or operating limitation that occurs for a stationary RICE where you are not using a CMS to comply with the emission or operating limitations in this subpart, the Compliance report must contain the information in paragraphs (c)(1) through (4) of this section and the information in paragraphs (d)(1) and (2) of this section.

(1) The total operating time of the stationary RICE at which the deviation occurred during the reporting period.

(2) Information on the number, duration, and cause of deviations (including unknown cause, if applicable), as applicable, and the corrective action taken.

(e) For each deviation from an emission or operating limitation occurring for a stationary RICE where you are using a CMS to comply with the emission and operating limitations in this subpart, you must include information in paragraphs (c)(1) through (4) and (e)(1) through (12) of this section.

(1) The date and time that each malfunction started and stopped.

(2) The date, time, and duration that each CMS was inoperative, except for zero (low-level) and high-level checks.

(3) The date, time, and duration that each CMS was out-of-control, including the information in §63.8(c)(8).

(4) The date and time that each deviation started and stopped, and whether each deviation occurred during a period of malfunction or during another period.

(5) A summary of the total duration of the deviation during the reporting period, and the total duration as a percent of the total source operating time during that reporting period.

(6) A breakdown of the total duration of the deviations during the reporting period into those that are due to control equipment problems, process problems, other known causes, and other unknown causes.

(7) A summary of the total duration of CMS downtime during the reporting period, and the total duration of CMS downtime as a percent of the total operating time of the stationary RICE at which the CMS downtime occurred during that reporting period.

(8) An identification of each parameter and pollutant (CO or formaldehyde) that was monitored at the stationary RICE.

(9) A brief description of the stationary RICE.

(10) A brief description of the CMS.

(11) The date of the latest CMS certification or audit.

(12) A description of any changes in CMS, processes, or controls since the last reporting period.

(f) Each affected source that has obtained a title V operating permit pursuant to 40 CFR part 70 or 71 must report all deviations as defined in this subpart in the semiannual monitoring report required by 40 CFR 70.6(a)(3)(iii)(A) or 40 CFR 71.6(a)(3)(iii)(A). If an affected source submits a Compliance report pursuant to Table 7 of this subpart along with, or as part of, the semiannual monitoring report required by 40 CFR 70.6(a)(3)(iii)(A) or 40 CFR 71.6(a)(3)(iii)(A), and the Compliance report includes all required information concerning deviations from any emission or operating limitation in this subpart, submission of the

Compliance report shall be deemed to satisfy any obligation to report the same deviations in the semiannual monitoring report. However, submission of a Compliance report shall not otherwise affect any obligation the affected source may have to report deviations from permit requirements to the permit authority.

(g) If you are operating as a new or reconstructed stationary RICE which fires landfill gas or digester gas equivalent to 10 percent or more of the gross heat input on an annual basis, you must submit an annual report according to Table 7 of this subpart by the date specified unless the Administrator has approved a different schedule, according to the information described in paragraphs (b)(1) through (b)(5) of this section. You must report the data specified in (g)(1) through (g)(3) of this section.

(1) Fuel flow rate of each fuel and the heating values that were used in your calculations. You must also demonstrate that the percentage of heat input provided by landfill gas or digester gas is equivalent to 10 percent or more of the total fuel consumption on an annual basis.

(2) The operating limits provided in your federally enforceable permit, and any deviations from these limits.

(3) Any problems or errors suspected with the meters.

[69 FR 33506, June 15, 2004, as amended at 75 FR 9677, Mar. 3, 2010]

### **§ 63.6655 What records must I keep?**

(a) If you must comply with the emission and operating limitations, you must keep the records described in paragraphs (a)(1) through (a)(5), (b)(1) through (b)(3) and (c) of this section.

(1) A copy of each notification and report that you submitted to comply with this subpart, including all documentation supporting any Initial Notification or Notification of Compliance Status that you submitted, according to the requirement in §63.10(b)(2)(xiv).

(2) Records of the occurrence and duration of each malfunction of operation ( *i.e.*, process equipment) or the air pollution control and monitoring equipment.

(3) Records of performance tests and performance evaluations as required in §63.10(b)(2)(viii).

(4) Records of all required maintenance performed on the air pollution control and monitoring equipment.

(5) Records of actions taken during periods of malfunction to minimize emissions in accordance with §63.6605(b), including corrective actions to restore malfunctioning process and air pollution control and monitoring equipment to its normal or usual manner of operation.

(b) For each CEMS or CPMS, you must keep the records listed in paragraphs (b)(1) through (3) of this section.

(1) Records described in §63.10(b)(2)(vi) through (xi).

(2) Previous ( *i.e.*, superseded) versions of the performance evaluation plan as required in §63.8(d)(3).

(3) Requests for alternatives to the relative accuracy test for CEMS or CPMS as required in §63.8(f)(6)(i), if applicable.

(c) If you are operating a new or reconstructed stationary RICE which fires landfill gas or digester gas equivalent to 10 percent or more of the gross heat input on an annual basis, you must keep the records of your daily fuel usage monitors.

(d) You must keep the records required in Table 6 of this subpart to show continuous compliance with each emission or operating limitation that applies to you.

(e) You must keep records of the maintenance conducted on the stationary RICE in order to demonstrate that you operated and maintained the stationary RICE and after-treatment control device (if any) according to your own maintenance plan if you own or operate any of the following stationary RICE;

(1) An existing stationary RICE with a site rating of less than 100 brake HP located at a major source of HAP emissions.

(2) An existing stationary emergency RICE.

(3) An existing stationary RICE located at an area source of HAP emissions subject to management practices as shown in Table 2d to this subpart.

(f) If you own or operate any of the stationary RICE in paragraphs (f)(1) or (2) of this section, you must keep records of the hours of operation of the engine that is recorded through the non-resettable hour meter. The owner or operator must document how many hours are spent for emergency operation, including what classified the operation as emergency and how many hours are spent for non-emergency operation. If the engines are used for demand response operation, the owner or operator must keep records of the notification of the emergency situation, and the time the engine was operated as part of demand response.

(1) An existing emergency stationary RICE with a site rating of less than or equal to 500 brake HP located at a major source of HAP emissions that does not meet the standards applicable to non-emergency engines.

(2) An existing emergency stationary RICE located at an area source of HAP emissions that does not meet the standards applicable to non-emergency engines.

[69 FR 33506, June 15, 2004, as amended at 75 FR 9678, Mar. 3, 2010; 75 FR 51592, Aug. 20, 2010]

#### **§ 63.6660 In what form and how long must I keep my records?**

(a) Your records must be in a form suitable and readily available for expeditious review according to §63.10(b)(1).

(b) As specified in §63.10(b)(1), you must keep each record for 5 years following the date of each occurrence, measurement, maintenance, corrective action, report, or record.

(c) You must keep each record readily accessible in hard copy or electronic form for at least 5 years after the date of each occurrence, measurement, maintenance, corrective action, report, or record, according to §63.10(b)(1).

[69 FR 33506, June 15, 2004, as amended at 75 FR 9678, Mar. 3, 2010]

#### **Other Requirements and Information**

#### **§ 63.6665 What parts of the General Provisions apply to me?**

Table 8 to this subpart shows which parts of the General Provisions in §§63.1 through 63.15 apply to you. If you own or operate a new or reconstructed stationary RICE with a site rating of less than or equal to 500 brake HP located at a major source of HAP emissions (except new or reconstructed 4SLB engines greater than or equal to 250 and less than or equal to 500 brake HP), a new or reconstructed stationary RICE located at an area source of HAP emissions, or any of the following RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions, you do not need to comply with any of the requirements of the General Provisions specified in Table 8: An existing 2SLB stationary RICE, an existing 4SLB stationary RICE, an existing stationary RICE that combusts landfill or digester gas equivalent to 10 percent or more of the gross heat input on an annual basis, an existing emergency stationary RICE, or an existing limited use stationary RICE. If you own or operate any of the following RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions, you do not need to comply with the

requirements in the General Provisions specified in Table 8 except for the initial notification requirements: A new stationary RICE that combusts landfill gas or digester gas equivalent to 10 percent or more of the gross heat input on an annual basis, a new emergency stationary RICE, or a new limited use stationary RICE.

[75 FR 9678, Mar. 3, 2010]

### **§ 63.6670 Who implements and enforces this subpart?**

(a) This subpart is implemented and enforced by the U.S. EPA, or a delegated authority such as your State, local, or tribal agency. If the U.S. EPA Administrator has delegated authority to your State, local, or tribal agency, then that agency (as well as the U.S. EPA) has the authority to implement and enforce this subpart. You should contact your U.S. EPA Regional Office to find out whether this subpart is delegated to your State, local, or tribal agency.

(b) In delegating implementation and enforcement authority of this subpart to a State, local, or tribal agency under 40 CFR part 63, subpart E, the authorities contained in paragraph (c) of this section are retained by the Administrator of the U.S. EPA and are not transferred to the State, local, or tribal agency.

(c) The authorities that will not be delegated to State, local, or tribal agencies are:

(1) Approval of alternatives to the non-opacity emission limitations and operating limitations in §63.6600 under §63.6(g).

(2) Approval of major alternatives to test methods under §63.7(e)(2)(ii) and (f) and as defined in §63.90.

(3) Approval of major alternatives to monitoring under §63.8(f) and as defined in §63.90.

(4) Approval of major alternatives to recordkeeping and reporting under §63.10(f) and as defined in §63.90.

(5) Approval of a performance test which was conducted prior to the effective date of the rule, as specified in §63.6610(b).

### **§ 63.6675 What definitions apply to this subpart?**

[Link to an amendment published at 76 FR 12867, March 9, 2011.](#)

Terms used in this subpart are defined in the Clean Air Act (CAA); in 40 CFR 63.2, the General Provisions of this part; and in this section as follows:

*Area source* means any stationary source of HAP that is not a major source as defined in part 63.

*Associated equipment* as used in this subpart and as referred to in section 112(n)(4) of the CAA, means equipment associated with an oil or natural gas exploration or production well, and includes all equipment from the well bore to the point of custody transfer, except glycol dehydration units, storage vessels with potential for flash emissions, combustion turbines, and stationary RICE.

*Black start engine* means an engine whose only purpose is to start up a combustion turbine.

CAA means the Clean Air Act (42 U.S.C. 7401 *et seq.*, as amended by Public Law 101–549, 104 Stat. 2399).

*Commercial emergency stationary RICE* means an emergency stationary RICE used in commercial establishments such as office buildings, hotels, stores, telecommunications facilities, restaurants, financial institutions such as banks, doctor's offices, and sports and performing arts facilities.

*Compression ignition* means relating to a type of stationary internal combustion engine that is not a spark ignition engine.

*Custody transfer* means the transfer of hydrocarbon liquids or natural gas: After processing and/or treatment in the producing operations, or from storage vessels or automatic transfer facilities or other such equipment, including product loading racks, to pipelines or any other forms of transportation. For the purposes of this subpart, the point at which such liquids or natural gas enters a natural gas processing plant is a point of custody transfer.

*Deviation* means any instance in which an affected source subject to this subpart, or an owner or operator of such a source:

- (1) Fails to meet any requirement or obligation established by this subpart, including but not limited to any emission limitation or operating limitation;
- (2) Fails to meet any term or condition that is adopted to implement an applicable requirement in this subpart and that is included in the operating permit for any affected source required to obtain such a permit; or
- (3) Fails to meet any emission limitation or operating limitation in this subpart during malfunction, regardless of whether or not such failure is permitted by this subpart.
- (4) Fails to satisfy the general duty to minimize emissions established by §63.6(e)(1)(i).

*Diesel engine* means any stationary RICE in which a high boiling point liquid fuel injected into the combustion chamber ignites when the air charge has been compressed to a temperature sufficiently high for auto-ignition. This process is also known as compression ignition.

*Diesel fuel* means any liquid obtained from the distillation of petroleum with a boiling point of approximately 150 to 360 degrees Celsius. One commonly used form is fuel oil number 2. Diesel fuel also includes any non-distillate fuel with comparable physical and chemical properties ( e.g. biodiesel) that is suitable for use in compression ignition engines.

*Digester gas* means any gaseous by-product of wastewater treatment typically formed through the anaerobic decomposition of organic waste materials and composed principally of methane and CO<sub>2</sub>.

*Dual-fuel engine* means any stationary RICE in which a liquid fuel (typically diesel fuel) is used for compression ignition and gaseous fuel (typically natural gas) is used as the primary fuel.

*Emergency stationary RICE* means any stationary internal combustion engine whose operation is limited to emergency situations and required testing and maintenance. Examples include stationary RICE used to produce power for critical networks or equipment (including power supplied to portions of a facility) when electric power from the local utility (or the normal power source, if the facility runs on its own power production) is interrupted, or stationary RICE used to pump water in the case of fire or flood, etc. Stationary RICE used for peak shaving are not considered emergency stationary RICE. Stationary RICE used to supply power to an electric grid or that supply non-emergency power as part of a financial arrangement with another entity are not considered to be emergency engines, except as permitted under §63.6640(f). All emergency stationary RICE must comply with the requirements specified in §63.6640(f) in order to be considered emergency stationary RICE. If the engine does not comply with the requirements specified in §63.6640(f), then it is not considered to be an emergency stationary RICE under this subpart.

*Engine startup* means the time from initial start until applied load and engine and associated equipment reaches steady state or normal operation. For stationary engine with catalytic controls, engine startup means the time from initial start until applied load and engine and associated equipment, including the catalyst, reaches steady state or normal operation.

*Four-stroke engine* means any type of engine which completes the power cycle in two crankshaft revolutions, with intake and compression strokes in the first revolution and power and exhaust strokes in the second revolution.

*Gaseous fuel* means a material used for combustion which is in the gaseous state at standard atmospheric temperature and pressure conditions.

*Gasoline* means any fuel sold in any State for use in motor vehicles and motor vehicle engines, or nonroad or stationary engines, and commonly or commercially known or sold as gasoline.

*Glycol dehydration unit* means a device in which a liquid glycol (including, but not limited to, ethylene glycol, diethylene glycol, or triethylene glycol) absorbent directly contacts a natural gas stream and absorbs water in a contact tower or absorption column (absorber). The glycol contacts and absorbs water vapor and other gas stream constituents from the natural gas and becomes "rich" glycol. This glycol is then regenerated in the glycol dehydration unit reboiler. The "lean" glycol is then recycled.

*Hazardous air pollutants (HAP)* means any air pollutants listed in or pursuant to section 112(b) of the CAA.

*Institutional emergency stationary RICE* means an emergency stationary RICE used in institutional establishments such as medical centers, nursing homes, research centers, institutions of higher education, correctional facilities, elementary and secondary schools, libraries, religious establishments, police stations, and fire stations.

*ISO standard day conditions* means 288 degrees Kelvin (15 degrees Celsius), 60 percent relative humidity and 101.3 kilopascals pressure.

*Landfill gas* means a gaseous by-product of the land application of municipal refuse typically formed through the anaerobic decomposition of waste materials and composed principally of methane and CO<sub>2</sub>.

*Lean burn engine* means any two-stroke or four-stroke spark ignited engine that does not meet the definition of a rich burn engine.

*Limited use stationary RICE* means any stationary RICE that operates less than 100 hours per year.

*Liquefied petroleum gas* means any liquefied hydrocarbon gas obtained as a by-product in petroleum refining of natural gas production.

*Liquid fuel* means any fuel in liquid form at standard temperature and pressure, including but not limited to diesel, residual/crude oil, kerosene/naphtha (jet fuel), and gasoline.

*Major Source*, as used in this subpart, shall have the same meaning as in §63.2, except that:

(1) Emissions from any oil or gas exploration or production well (with its associated equipment (as defined in this section)) and emissions from any pipeline compressor station or pump station shall not be aggregated with emissions from other similar units, to determine whether such emission points or stations are major sources, even when emission points are in a contiguous area or under common control;

(2) For oil and gas production facilities, emissions from processes, operations, or equipment that are not part of the same oil and gas production facility, as defined in §63.1271 of subpart HHH of this part, shall not be aggregated;

(3) For production field facilities, only HAP emissions from glycol dehydration units, storage vessel with the potential for flash emissions, combustion turbines and reciprocating internal combustion engines shall be aggregated for a major source determination; and

(4) Emissions from processes, operations, and equipment that are not part of the same natural gas transmission and storage facility, as defined in §63.1271 of subpart HHH of this part, shall not be aggregated.

*Malfunction* means any sudden, infrequent, and not reasonably preventable failure of air pollution control equipment, process equipment, or a process to operate in a normal or usual manner which causes, or has the potential to cause, the emission limitations in an applicable standard to be exceeded. Failures that are caused in part by poor maintenance or careless operation are not malfunctions.

*Natural gas* means a naturally occurring mixture of hydrocarbon and non-hydrocarbon gases found in geologic formations beneath the Earth's surface, of which the principal constituent is methane. Natural gas may be field or pipeline quality.

*Non-selective catalytic reduction (NSCR)* means an add-on catalytic nitrogen oxides (NO<sub>x</sub>) control device for rich burn engines that, in a two-step reaction, promotes the conversion of excess oxygen, NO<sub>x</sub>, CO, and volatile organic compounds (VOC) into CO<sub>2</sub>, nitrogen, and water.

*Oil and gas production facility* as used in this subpart means any grouping of equipment where hydrocarbon liquids are processed, upgraded ( *i.e.*, remove impurities or other constituents to meet contract specifications), or stored prior to the point of custody transfer; or where natural gas is processed, upgraded, or stored prior to entering the natural gas transmission and storage source category. For purposes of a major source determination, facility (including a building, structure, or installation) means oil and natural gas production and processing equipment that is located within the boundaries of an individual surface site as defined in this section. Equipment that is part of a facility will typically be located within close proximity to other equipment located at the same facility. Pieces of production equipment or groupings of equipment located on different oil and gas leases, mineral fee tracts, lease tracts, subsurface or surface unit areas, surface fee tracts, surface lease tracts, or separate surface sites, whether or not connected by a road, waterway, power line or pipeline, shall not be considered part of the same facility. Examples of facilities in the oil and natural gas production source category include, but are not limited to, well sites, satellite tank batteries, central tank batteries, a compressor station that transports natural gas to a natural gas processing plant, and natural gas processing plants.

*Oxidation catalyst* means an add-on catalytic control device that controls CO and VOC by oxidation.

*Peaking unit or engine* means any standby engine intended for use during periods of high demand that are not emergencies.

*Percent load* means the fractional power of an engine compared to its maximum manufacturer's design capacity at engine site conditions. Percent load may range between 0 percent to above 100 percent.

*Potential to emit* means the maximum capacity of a stationary source to emit a pollutant under its physical and operational design. Any physical or operational limitation on the capacity of the stationary source to emit a pollutant, including air pollution control equipment and restrictions on hours of operation or on the type or amount of material combusted, stored, or processed, shall be treated as part of its design if the limitation or the effect it would have on emissions is federally enforceable. For oil and natural gas production facilities subject to subpart HH of this part, the potential to emit provisions in §63.760(a) may be used. For natural gas transmission and storage facilities subject to subpart HHH of this part, the maximum annual facility gas throughput for storage facilities may be determined according to §63.1270(a)(1) and the maximum annual throughput for transmission facilities may be determined according to §63.1270(a)(2).

*Production field facility* means those oil and gas production facilities located prior to the point of custody transfer.

*Production well* means any hole drilled in the earth from which crude oil, condensate, or field natural gas is extracted.

*Propane* means a colorless gas derived from petroleum and natural gas, with the molecular structure C<sub>3</sub>H<sub>8</sub>.

*Residential emergency stationary RICE* means an emergency stationary RICE used in residential establishments such as homes or apartment buildings.

*Responsible official* means responsible official as defined in 40 CFR 70.2.

*Rich burn engine* means any four-stroke spark ignited engine where the manufacturer's recommended operating air/fuel ratio divided by the stoichiometric air/fuel ratio at full load conditions is less than or equal to 1.1. Engines originally manufactured as rich burn engines, but modified prior to December 19, 2002 with passive emission control technology for NO<sub>x</sub>(such as pre-combustion chambers) will be considered lean burn engines. Also, existing engines where there are no manufacturer's recommendations regarding air/fuel ratio will be considered a rich burn engine if the excess oxygen content of the exhaust at full load conditions is less than or equal to 2 percent.

*Site-rated HP* means the maximum manufacturer's design capacity at engine site conditions.

*Spark ignition* means relating to either: A gasoline-fueled engine; or any other type of engine a spark plug (or other sparking device) and with operating characteristics significantly similar to the theoretical Otto combustion cycle. Spark ignition engines usually use a throttle to regulate intake air flow to control power during normal operation. Dual-fuel engines in which a liquid fuel (typically diesel fuel) is used for CI and gaseous fuel (typically natural gas) is used as the primary fuel at an annual average ratio of less than 2 parts diesel fuel to 100 parts total fuel on an energy equivalent basis are spark ignition engines.

*Stationary reciprocating internal combustion engine (RICE)* means any reciprocating internal combustion engine which uses reciprocating motion to convert heat energy into mechanical work and which is not mobile. Stationary RICE differ from mobile RICE in that a stationary RICE is not a non-road engine as defined at 40 CFR 1068.30, and is not used to propel a motor vehicle or a vehicle used solely for competition.

*Stationary RICE test cell/stand* means an engine test cell/stand, as defined in subpart P of this part, that tests stationary RICE.

*Stoichiometric* means the theoretical air-to-fuel ratio required for complete combustion.

*Storage vessel with the potential for flash emissions* means any storage vessel that contains a hydrocarbon liquid with a stock tank gas-to-oil ratio equal to or greater than 0.31 cubic meters per liter and an American Petroleum Institute gravity equal to or greater than 40 degrees and an actual annual average hydrocarbon liquid throughput equal to or greater than 79,500 liters per day. Flash emissions occur when dissolved hydrocarbons in the fluid evolve from solution when the fluid pressure is reduced.

*Subpart* means 40 CFR part 63, subpart ZZZZ.

*Surface site* means any combination of one or more graded pad sites, gravel pad sites, foundations, platforms, or the immediate physical location upon which equipment is physically affixed.

*Two-stroke engine* means a type of engine which completes the power cycle in single crankshaft revolution by combining the intake and compression operations into one stroke and the power and exhaust operations into a second stroke. This system requires auxiliary scavenging and inherently runs lean of stoichiometric.

[69 FR 33506, June 15, 2004, as amended at 71 FR 20467, Apr. 20, 2006; 73 FR 3607, Jan. 18, 2008; 75 FR 9679, Mar. 3, 2010; 75 FR 51592, Aug. 20, 2010]

**Table 1 to Subpart ZZZZ of Part 63— Emission Limitations for Existing, New, and Reconstructed Spark Ignition, 4SRB Stationary RICE >500 HP Located at a Major Source of HAP Emissions**

As stated in §§63.6600 and 63.6640, you must comply with the following emission limitations at 100 percent load plus or minus 10 percent for existing, new and reconstructed 4SRB stationary RICE >500 HP located at a major source of HAP emissions:

<b>For each . . .</b>	<b>You must meet the following emission limitation, except during</b>	<b>During periods of startup you must . . .</b>
-----------------------	---	---

	<b>periods of startup . . .</b>	
1. 4SRB stationary RICE	a. Reduce formaldehyde emissions by 76 percent or more. If you commenced construction or reconstruction between December 19, 2002 and June 15, 2004, you may reduce formaldehyde emissions by 75 percent or more until June 15, 2007 or	Minimize the engine's time spent at idle and minimize the engine's startup time at startup to a period needed for appropriate and safe loading of the engine, not to exceed 30 minutes, after which time the non-startup emission limitations apply. <sup>1</sup>
	b. Limit the concentration of formaldehyde in the stationary RICE exhaust to 350 ppbvd or less at 15 percent O <sub>2</sub>	

<sup>1</sup>Sources can petition the Administrator pursuant to the requirements of 40 CFR 63.6(g) for alternative work practices.

[75 FR 9679, Mar. 3, 2010, as amended at 75 FR 51592, Aug. 20, 2010]

**Table 1bto Subpart ZZZZ of Part 63—Operating Limitations for Existing, New, and Reconstructed Spark Ignition 4SRB Stationary RICE >500 HP Located at a Major Source of HAP Emissions and Existing Spark Ignition 4SRB Stationary RICE >500 HP Located at an Area Source of HAP Emissions**

[Link to an amendment published at 76 FR 12867, March 9, 2011.](#)

As stated in §§63.6600, 63.6630 and 63.6640, you must comply with the following operating limitations for existing, new and reconstructed 4SRB stationary RICE >500 HP located at a major source of HAP emissions and existing 4SRB stationary RICE >500 HP located at an area source of HAP emissions that operate more than 24 hours per calendar year:

<b>For each . . .</b>	<b>You must meet the following operating limitation . . .</b>
1. 4SRB stationary RICE complying with the requirement to reduce formaldehyde emissions by 76 percent or more (or by 75 percent or more, if applicable) and using NSCR; or	a. maintain your catalyst so that the pressure drop across the catalyst does not change by more than 2 inches of water at 100 percent load plus or minus 10 percent from the pressure drop across the catalyst measured during the initial performance test and
4SRB stationary RICE complying with the requirement to limit the concentration of formaldehyde in the stationary RICE exhaust to 350 ppbvd or less at 15 percent O <sub>2</sub> and using NSCR; or	b. maintain the temperature of your stationary RICE exhaust so the catalyst inlet temperature is greater than or equal to 750 °F and less than or equal to 1250 °F.

4SRB stationary RICE complying with the requirement to limit the concentration of formaldehyde in the stationary RICE exhaust to 2.7 ppmvd or less at 15 percent O <sub>2</sub> and using NSCR.	
2. 4SRB stationary RICE complying with the requirement to reduce formaldehyde emissions by 76 percent or more (or by 75 percent or more, if applicable) and not using NSCR; or	Comply with any operating limitations approved by the Administrator.
4SRB stationary RICE complying with the requirement to limit the concentration of formaldehyde in the stationary RICE exhaust to 350 ppbvd or less at 15 percent O <sub>2</sub> and not using NSCR; or	
4SRB stationary RICE complying with the requirement to limit the concentration of formaldehyde in the stationary RICE exhaust to 2.7 ppmvd or less at 15 percent O <sub>2</sub> and using NSCR.	

[75 FR 51592, Aug. 20, 2010]

**Table 2a to Subpart ZZZZ of Part 63—Emission Limitations for New and Reconstructed 2SLB and Compression Ignition Stationary RICE >500 HP and New and Reconstructed 4SLB Stationary RICE ≥250 HP Located at a Major Source of HAP Emissions**

As stated in §§63.6600 and 63.6640, you must comply with the following emission limitations for new and reconstructed lean burn and new and reconstructed compression ignition stationary RICE at 100 percent load plus or minus 10 percent:

<b>For each . . .</b>	<b>You must meet the following emission limitation, except during periods of startup . . .</b>	<b>During periods of startup you must . . .</b>
1. 2SLB stationary RICE	a. Reduce CO emissions by 58 percent or more; or b. Limit concentration of formaldehyde in the stationary RICE exhaust to 12 ppmvd or less at 15 percent O <sub>2</sub> . If you commenced construction or reconstruction between December 19, 2002 and June 15, 2004, you may limit concentration of formaldehyde	Minimize the engine's time spent at idle and minimize the engine's startup time at startup to a period needed for appropriate and safe loading of the engine, not to exceed 30 minutes, after which time the non-startup emission limitations apply. <sup>1</sup>

	to 17 ppmvd or less at 15 percent O <sub>2</sub> until June 15, 2007	
2. 4SLB stationary RICE	a. Reduce CO emissions by 93 percent or more; or	
	b. Limit concentration of formaldehyde in the stationary RICE exhaust to 14 ppmvd or less at 15 percent O <sub>2</sub>	
3. CI stationary RICE	a. Reduce CO emissions by 70 percent or more; or	
	b. Limit concentration of formaldehyde in the stationary RICE exhaust to 580 ppbvd or less at 15 percent O <sub>2</sub>	

<sup>1</sup>Sources can petition the Administrator pursuant to the requirements of 40 CFR 63.6(g) for alternative work practices.

[75 FR 9680, Mar. 3, 2010]

**Table 2b to Subpart ZZZZ of Part 63— Operating Limitations for New and Reconstructed 2SLB and Compression Ignition Stationary RICE >500 HP Located at a Major Source of HAP Emissions, New and Reconstructed 4SLB Stationary RICE ≥250 HP Located at a Major Source of HAP Emissions, Existing Compression Ignition Stationary RICE >500 HP, and Existing 4SLB Stationary RICE >500 HP Located at an Area Source of HAP Emissions**

[Link to an amendment published at 76 FR 12867, March 9, 2011.](#)

As stated in §§63.6600, 63.6601, 63.6630, and 63.6640, you must comply with the following operating limitations for new and reconstructed 2SLB and compression ignition stationary RICE located at a major source of HAP emissions; new and reconstructed 4SLB stationary RICE ≥250 HP located at a major source of HAP emissions; existing compression ignition stationary RICE >500 HP; and existing 4SLB stationary RICE >500 HP located at an area source of HAP emissions that operate more than 24 hours per calendar year:

For each . . .	You must meet the following operating limitation . . .
1. 2SLB and 4SLB stationary RICE and CI stationary RICE complying with the requirement to reduce CO emissions and using an oxidation catalyst; or 2SLB and 4SLB stationary RICE and CI stationary RICE complying with the requirement to limit the concentration of formaldehyde in the stationary RICE exhaust and using an oxidation catalyst; or 4SLB stationary RICE and CI stationary	a. maintain your catalyst so that the pressure drop across the catalyst does not change by more than 2 inches of water at 100 percent load plus or minus 10 percent from the pressure drop across the catalyst that was measured during the initial performance test; and b. maintain the temperature of your stationary RICE exhaust so that the

RICE complying with the requirement to limit the concentration of CO in the stationary RICE exhaust and using an oxidation catalyst	catalyst inlet temperature is greater than or equal to 450 °F and less than or equal to 1350 °F. <sup>1</sup>
2. 2SLB and 4SLB stationary RICE and CI stationary RICE complying with the requirement to reduce CO emissions and not using an oxidation catalyst; or 2SLB and 4SLB stationary RICE and CI stationary RICE complying with the requirement to limit the concentration of formaldehyde in the stationary RICE exhaust and not using an oxidation catalyst; or 4SLB stationary RICE and CI stationary RICE complying with the requirement to limit the concentration of CO in the stationary RICE exhaust and not using an oxidation catalyst	Comply with any operating limitations approved by the Administrator.

<sup>1</sup> Sources can petition the Administrator pursuant to the requirements of 40 CFR 63.8(g) for a different temperature range.

[75 FR 51593, Aug. 20, 2010]

**Table 2cto Subpart ZZZZ of Part 63—Requirements for Existing Compression Ignition Stationary RICE Located at a Major Source of HAP Emissions and Existing Spark Ignition Stationary RICE ≤500 HP Located at a Major Source of HAP Emissions**

As stated in §§63.6600, 63.6602, and 63.6640, you must comply with the following requirements for existing compression ignition stationary RICE located at a major source of HAP emissions and existing spark ignition stationary RICE ≤500 HP located at a major source of HAP emissions:

<b>For each . . .</b>	<b>You must meet the following requirement, except during periods of startup . . .</b>	<b>During periods of startup you must . . .</b>
1. Emergency stationary CI RICE and black start stationary CI RICE. <sup>1</sup>	a. Change oil and filter every 500 hours of operation or annually, whichever comes first; <sup>2</sup> b. Inspect air cleaner every 1,000 hours of operation or annually, whichever comes first; c. Inspect all hoses and belts every 500 hours of operation or annually, whichever comes first,	Minimize the engine's time spent at idle and minimize the engine's startup time at startup to a period needed for appropriate and safe loading of the engine, not to exceed 30 minutes, after which time the non-startup emission limitations apply. <sup>3</sup>

	and replace as necessary. <sup>3</sup>	
2. Non-Emergency, non-black start stationary CI RICE <100 HP	a. Change oil and filter every 1,000 hours of operation or annually, whichever comes first; <sup>2</sup>	
	b. Inspect air cleaner every 1,000 hours of operation or annually, whichever comes first;	
	c. Inspect all hoses and belts every 500 hours of operation or annually, whichever comes first, and replace as necessary. <sup>3</sup>	
3. Non-Emergency, non-black start CI stationary RICE 100≤HP≤300 HP	Limit concentration of CO in the stationary RICE exhaust to 230 ppmvd or less at 15 percent O <sub>2</sub>	
4. Non-Emergency, non-black start CI stationary RICE 300<HP≤500	a. Limit concentration of CO in the stationary RICE exhaust to 49 ppmvd or less at 15 percent O <sub>2</sub> ; or	
	b. Reduce CO emissions by 70 percent or more.	
5. Non-Emergency, non-black start stationary CI RICE >500 HP	a. Limit concentration of CO in the stationary RICE exhaust to 23 ppmvd or less at 15 percent O <sub>2</sub> ; or	
	b. Reduce CO emissions by 70 percent or more.	
6. Emergency stationary SI RICE and black start stationary SI RICE. <sup>1</sup>	a. Change oil and filter every 500 hours of operation or annually, whichever comes first; <sup>2</sup>	
	b. Inspect spark plugs every 1,000 hours of operation or annually, whichever comes first;	
	c. Inspect all hoses and belts every 500 hours of	

	operation or annually, whichever comes first, and replace as necessary. <sup>3</sup>	
7. Non-Emergency, non-black start stationary SI RICE <100 HP that are not 2SLB stationary RICE	a. Change oil and filter every 1,440 hours of operation or annually, whichever comes first; <sup>2</sup>	
	b. Inspect spark plugs every 1,440 hours of operation or annually, whichever comes first;	
	c. Inspect all hoses and belts every 1,440 hours of operation or annually, whichever comes first, and replace as necessary. <sup>3</sup>	
8. Non-Emergency, non-black start 2SLB stationary SI RICE <100 HP	a. Change oil and filter every 4,320 hours of operation or annually, whichever comes first; <sup>2</sup>	
	b. Inspect spark plugs every 4,320 hours of operation or annually, whichever comes first;	
	c. Inspect all hoses and belts every 4,320 hours of operation or annually, whichever comes first, and replace as necessary. <sup>3</sup>	
9. Non-emergency, non-black start 2SLB stationary RICE 100≤HP≤500	Limit concentration of CO in the stationary RICE exhaust to 225 ppmvd or less at 15 percent O <sub>2</sub>	
10. Non-emergency, non-black start 4SLB stationary RICE 100≤HP≤500	Limit concentration of CO in the stationary RICE exhaust to 47 ppmvd or less at 15 percent O <sub>2</sub>	
11. Non-emergency, non-black start 4SRB stationary RICE	Limit concentration of formaldehyde in the stationary RICE exhaust	

100≤HP≤500	to 10.3 ppmvd or less at 15 percent O <sub>2</sub>	
12. Non-emergency, non-black start landfill or digester gas-fired stationary RICE 100≤HP≤500	Limit concentration of CO in the stationary RICE exhaust to 177 ppmvd or less at 15 percent O <sub>2</sub>	

<sup>1</sup>If an emergency engine is operating during an emergency and it is not possible to shut down the engine in order to perform the work practice requirements on the schedule required in Table 2c of this subpart, or if performing the work practice on the required schedule would otherwise pose an unacceptable risk under Federal, State, or local law, the work practice can be delayed until the emergency is over or the unacceptable risk under Federal, State, or local law has abated. The work practice should be performed as soon as practicable after the emergency has ended or the unacceptable risk under Federal, State, or local law has abated. Sources must report any failure to perform the work practice on the schedule required and the Federal, State or local law under which the risk was deemed unacceptable.

<sup>2</sup>Sources have the option to utilize an oil analysis program as described in §63.6625(i) in order to extend the specified oil change requirement in Table 2c of this subpart.

<sup>3</sup>Sources can petition the Administrator pursuant to the requirements of 40 CFR 63.6(g) for alternative work practices.

[75 FR 51593, Aug. 20, 2010]

**Table 2d to Subpart ZZZZ of Part 63— Requirements for Existing Stationary RICE Located at Area Sources of HAP Emissions**

As stated in §§63.6603 and 63.6640, you must comply with the following requirements for existing stationary RICE located at area sources of HAP emissions:

<b>For each . . .</b>	<b>You must meet the following requirement, except during periods of startup . . .</b>	<b>During periods of startup you must . . .</b>
1. Non-Emergency, non-black start CI stationary RICE ≤300 HP	a. Change oil and filter every 1,000 hours of operation or annually, whichever comes first; <sup>1</sup>	Minimize the engine's time spent at idle and minimize the engine's startup time at startup to a period needed for appropriate and safe loading of the engine, not to exceed 30 minutes, after which time the non-startup emission limitations apply.
	b. Inspect air cleaner every 1,000 hours of operation or annually,	

	<p>whichever comes first;</p> <p>c. Inspect all hoses and belts every 500 hours of operation or annually, whichever comes first, and replace as necessary.</p>	
2. Non-Emergency, non-black start CI stationary RICE 300<HP≤500	a. Limit concentration of CO in the stationary RICE exhaust to 49 ppmvd at 15 percent O <sub>2</sub> ; or	
	b. Reduce CO emissions by 70 percent or more.	
3. Non-Emergency, non-black start CI stationary RICE >500 HP	a. Limit concentration of CO in the stationary RICE exhaust to 23 ppmvd at 15 percent O <sub>2</sub> ; or	
	b. Reduce CO emissions by 70 percent or more.	
4. Emergency stationary CI RICE and black start stationary CI RICE. <sup>2</sup>	a. Change oil and filter every 500 hours of operation or annually, whichever comes first; <sup>1</sup>	
	b. Inspect air cleaner every 1,000 hours of operation or annually, whichever comes first; and	
	c. Inspect all hoses and belts every 500 hours of operation or annually, whichever comes first, and replace as necessary.	
5. Emergency stationary SI RICE; black start stationary SI RICE; non-emergency, non-black start 4SLB	a. Change oil and filter every 500 hours of operation or	

<p>stationary RICE &gt;500 HP that operate 24 hours or less per calendar year; non-emergency, non-black start 4SRB stationary RICE &gt;500 HP that operate 24 hours or less per calendar year.<sup>2</sup></p>	<p>annually, whichever comes first;<sup>1</sup>  b. Inspect spark plugs every 1,000 hours of operation or annually, whichever comes first; and  c. Inspect all hoses and belts every 500 hours of operation or annually, whichever comes first, and replace as necessary.</p>	
<p>6. Non-emergency, non-black start 2SLB stationary RICE</p>	<p>a. Change oil and filter every 4,320 hours of operation or annually, whichever comes first;<sup>1</sup></p>	
	<p>b. Inspect spark plugs every 4,320 hours of operation or annually, whichever comes first; and</p>	
	<p>c. Inspect all hoses and belts every 4,320 hours of operation or annually, whichever comes first, and replace as necessary.</p>	
<p>7. Non-emergency, non-black start 4SLB stationary RICE ≤500 HP</p>	<p>a. Change oil and filter every 1,440 hours of operation or annually, whichever comes first;<sup>1</sup></p>	
	<p>b. Inspect spark plugs every 1,440 hours of operation or annually, whichever comes first; and</p>	
	<p>c. Inspect all hoses and belts every 1,440 hours of operation or annually, whichever</p>	

	comes first, and replace as necessary.	
8. Non-emergency, non-black start 4SLB stationary RICE >500 HP	a. Limit concentration of CO in the stationary RICE exhaust to 47 ppmvd at 15 percent O <sub>2</sub> ; or	
	b. Reduce CO emissions by 93 percent or more.	
9. Non-emergency, non-black start 4SRB stationary RICE ≤500 HP	a. Change oil and filter every 1,440 hours of operation or annually, whichever comes first; <sup>1</sup>	
	b. Inspect spark plugs every 1,440 hours of operation or annually, whichever comes first; and	
	c. Inspect all hoses and belts every 1,440 hours of operation or annually, whichever comes first, and replace as necessary.	
10. Non-emergency, non-black start 4SRB stationary RICE >500 HP	a. Limit concentration of formaldehyde in the stationary RICE exhaust to 2.7 ppmvd at 15 percent O <sub>2</sub> ; or	
	b. Reduce formaldehyde emissions by 76 percent or more.	
11. Non-emergency, non-black start landfill or digester gas-fired stationary RICE	a. Change oil and filter every 1,440 hours of operation or annually, whichever comes first; <sup>1</sup>	
	b. Inspect spark plugs	

	every 1,440 hours of operation or annually, whichever comes first; and	
	c. Inspect all hoses and belts every 1,440 hours of operation or annually, whichever comes first, and replace as necessary.	

<sup>1</sup>Sources have the option to utilize an oil analysis program as described in §63.6625(i) in order to extend the specified oil change requirement in Table 2d of this subpart.

<sup>2</sup>If an emergency engine is operating during an emergency and it is not possible to shut down the engine in order to perform the management practice requirements on the schedule required in Table 2d of this subpart, or if performing the management practice on the required schedule would otherwise pose an unacceptable risk under Federal, State, or local law, the management practice can be delayed until the emergency is over or the unacceptable risk under Federal, State, or local law has abated. The management practice should be performed as soon as practicable after the emergency has ended or the unacceptable risk under Federal, State, or local law has abated. Sources must report any failure to perform the management practice on the schedule required and the Federal, State or local law under which the risk was deemed unacceptable.

[75 FR 51595, Aug. 20, 2010]

**Table 3 to Subpart ZZZZ of Part 63—Subsequent Performance Tests**

As stated in §§63.6615 and 63.6620, you must comply with the following subsequent performance test requirements:

<b>For each . . .</b>	<b>Complying with the requirement to . . .</b>	<b>You must . . .</b>
1. New or reconstructed 2SLB stationary RICE with a brake horsepower >500 located at major sources; new or reconstructed 4SLB stationary RICE with a brake horsepower ≥250 located at major sources; and new or reconstructed CI stationary RICE with a brake horsepower >500 located at major sources	Reduce CO emissions and not using a CEMS	Conduct subsequent performance tests semiannually. <sup>1</sup>
2. 4SRB stationary RICE with a brake horsepower ≥5,000 located at major sources	Reduce formaldehyde emissions	Conduct subsequent performance tests semiannually. <sup>1</sup>
3. Stationary RICE with a brake horsepower >500 located at major sources and new or reconstructed 4SLB stationary RICE with a	Limit the concentration of formaldehyde in	Conduct subsequent performance tests semiannually. <sup>1</sup>

brake horsepower $250 \leq HP \leq 500$ located at major sources	the stationary RICE exhaust	
4. Existing non-emergency, non-black start CI stationary RICE with a brake horsepower $>500$ that are not limited use stationary RICE; existing non-emergency, non-black start 4SLB and 4SRB stationary RICE located at an area source of HAP emissions with a brake horsepower $>500$ that are operated more than 24 hours per calendar year that are not limited use stationary RICE	Limit or reduce CO or formaldehyde emissions	Conduct subsequent performance tests every 8,760 hrs. or 3 years, whichever comes first.
5. Existing non-emergency, non-black start CI stationary RICE with a brake horsepower $>500$ that are limited use stationary RICE; existing non-emergency, non-black start 4SLB and 4SRB stationary RICE located at an area source of HAP emissions with a brake horsepower $>500$ that are operated more than 24 hours per calendar year and are limited use stationary RICE	Limit or reduce CO or formaldehyde emissions	Conduct subsequent performance tests every 8,760 hrs. or 5 years, whichever comes first.

<sup>1</sup>After you have demonstrated compliance for two consecutive tests, you may reduce the frequency of subsequent performance tests to annually. If the results of any subsequent annual performance test indicate the stationary RICE is not in compliance with the CO or formaldehyde emission limitation, or you deviate from any of your operating limitations, you must resume semiannual performance tests.

[75 FR 51596, Aug. 20, 2010]

**Table 4 to Subpart ZZZZ of Part 63—Requirements for Performance Tests**

As stated in §§63.6610, 63.6611, 63.6612, 63.6620, and 63.6640, you must comply with the following requirements for performance tests for stationary RICE:

For each . . .	Complying with the requirement to . . .	You must . . .	Using . . .	According to the following requirements . . .
1. 2SLB, 4SLB, and CI stationary RICE	a. Reduce CO emissions	i. Measure the O <sub>2</sub> at the inlet and outlet of the control device; and	(1) Portable CO and O <sub>2</sub> analyzer	(a) Using ASTM D6522–00 (2005) <sup>a</sup> (incorporated by reference, see §63.14). Measurements to determine O <sub>2</sub> must be made at the same time as the measurements for

				CO concentration.
		ii. Measure the CO at the inlet and the outlet of the control device	(1) Portable CO and O <sub>2</sub> analyzer	(a) Using ASTM D6522–00 (2005) <sup>ab</sup> (incorporated by reference, see §63.14) or Method 10 of 40 CFR appendix A. The CO concentration must be at 15 percent O <sub>2</sub> , dry basis.
2. 4SRB stationary RICE	a. Reduce formaldehyde emissions	i. Select the sampling port location and the number of traverse points; and	(1) Method 1 or 1A of 40 CFR part 60, appendix A §63.7(d)(1)(i)	(a) Sampling sites must be located at the inlet and outlet of the control device.
		ii. Measure O <sub>2</sub> at the inlet and outlet of the control device; and	(1) Method 3 or 3A or 3B of 40 CFR part 60, appendix A, or ASTM Method D6522–00m (2005)	(a) Measurements to determine O <sub>2</sub> concentration must be made at the same time as the measurements for formaldehyde concentration.
		iii. Measure moisture content at the inlet and outlet of the control device; and	(1) Method 4 of 40 CFR part 60, appendix A, or Test Method 320 of 40 CFR part 63, appendix A, or ASTM D 6348–03	(a) Measurements to determine moisture content must be made at the same time and location as the measurements for formaldehyde concentration.
		iv. Measure formaldehyde at the inlet and the outlet of the control device	(1) Method 320 or 323 of 40 CFR part 63, appendix A; or ASTM D6348–03, <sup>c</sup> provided in ASTM D6348–03 Annex A5 (Analyte Spiking Technique), the percent R must be greater than or equal to 70 and less than or equal to	(a) Formaldehyde concentration must be at 15 percent O <sub>2</sub> , dry basis. Results of this test consist of the average of the three 1-hour or longer runs.

			130	
3. Stationary RICE	a. Limit the concentration of formaldehyde or CO in the stationary RICE exhaust	i. Select the sampling port location and the number of traverse points; and	(1) Method 1 or 1A of 40 CFR part 60, appendix A §63.7(d)(1)(i)	(a) If using a control device, the sampling site must be located at the outlet of the control device.
		ii. Determine the O <sub>2</sub> concentration of the stationary RICE exhaust at the sampling port location; and	(1) Method 3 or 3A or 3B of 40 CFR part 60, appendix A, or ASTM Method D6522-00 (2005)	(a) Measurements to determine O <sub>2</sub> concentration must be made at the same time and location as the measurements for formaldehyde concentration.
		iii. Measure moisture content of the stationary RICE exhaust at the sampling port location; and	(1) Method 4 of 40 CFR part 60, appendix A, or Test Method 320 of 40 CFR part 63, appendix A, or ASTM D 6348-03	(a) Measurements to determine moisture content must be made at the same time and location as the measurements for formaldehyde concentration.
		iv. Measure formaldehyde at the exhaust of the stationary RICE; or	(1) Method 320 or 323 of 40 CFR part 63, appendix A; or ASTM D6348-03, provided in ASTM D6348-03 Annex A5 (Analyte Spiking Technique), the percent R must be greater than or equal to 70 and less than or equal to 130	(a) Formaldehyde concentration must be at 15 percent O <sub>2</sub> , dry basis. Results of this test consist of the average of the three 1-hour or longer runs.
		v. Measure CO at the exhaust of the stationary RICE	(1) Method 10 of 40 CFR part 60, appendix A, ASTM Method D6522-00 (2005), <sup>a</sup> Method	(a) CO Concentration must be at 15 percent O <sub>2</sub> , dry basis. Results of this test consist of the average of the three 1-

			320 of 40 CFR part 63, appendix A, or ASTM D6348-03	hour longer runs.
--	--	--	---	-------------------

<sup>a</sup>You may also use Methods 3A and 10 as options to ASTM-D6522-00 (2005). You may obtain a copy of ASTM-D6522-00 (2005) from at least one of the following addresses: American Society for Testing and Materials, 100 Barr Harbor Drive, West Conshohocken, PA 19428-2959, or University Microfilms International, 300 North Zeeb Road, Ann Arbor, MI 48106. ASTM-D6522-00 (2005) may be used to test both CI and SI stationary RICE.

<sup>b</sup>You may also use Method 320 of 40 CFR part 63, appendix A, or ASTM D6348-03.

<sup>c</sup>You may obtain a copy of ASTM-D6348-03 from at least one of the following addresses: American Society for Testing and Materials, 100 Barr Harbor Drive, West Conshohocken, PA 19428-2959, or University Microfilms International, 300 North Zeeb Road, Ann Arbor, MI 48106.

[75 FR 51597, Aug. 20, 2010]

**Table 5 to Subpart ZZZZ of Part 63—Initial Compliance With Emission Limitations and Operating Limitations**

[Link to an amendment published at 76 FR 12867, March 9, 2011.](#)

As stated in §§63.6612, 63.6625 and 63.6630, you must initially comply with the emission and operating limitations as required by the following:

<b>For each . . .</b>	<b>Complying with the requirement to . . .</b>	<b>You have demonstrated initial compliance if . . .</b>
1. New or reconstructed non-emergency 2SLB stationary RICE >500 HP located at a major source of HAP, new or reconstructed non-emergency 4SLB stationary RICE ≥250 HP located at a major source of HAP, non-emergency stationary CI RICE >500 HP located at a major source of HAP, existing non-emergency stationary CI RICE >500 HP located at an area source of HAP, and existing non-emergency 4SLB stationary RICE >500 HP located at an area source of HAP that are operated more than 24 hours per calendar year	a. Reduce CO emissions and using oxidation catalyst, and using a CPMS	i. The average reduction of emissions of CO determined from the initial performance test achieves the required CO percent reduction; and ii. You have installed a CPMS to continuously monitor catalyst inlet temperature according to the requirements in §63.6625(b); and iii. You have recorded the catalyst pressure drop and catalyst inlet temperature during the initial performance test.
2. New or reconstructed non-emergency 2SLB stationary RICE	a. Reduce CO emissions and not	i. The average reduction of emissions of CO determined

<p>&gt;500 HP located at a major source of HAP, new or reconstructed non-emergency 4SLB stationary RICE <math>\geq</math>250 HP located at a major source of HAP, non-emergency stationary CI RICE &gt;500 HP located at a major source of HAP, existing non-emergency stationary CI RICE &gt;500 HP located at an area source of HAP, and existing non-emergency 4SLB stationary RICE &gt;500 HP located at an area source of HAP that are operated more than 24 hours per calendar year</p>	<p>using oxidation catalyst</p>	<p>from the initial performance test achieves the required CO percent reduction; and  ii. You have installed a CPMS to continuously monitor operating parameters approved by the Administrator (if any) according to the requirements in §63.6625(b); and  iii. You have recorded the approved operating parameters (if any) during the initial performance test.</p>
<p>3. New or reconstructed non-emergency 2SLB stationary RICE &gt;500 HP located at a major source of HAP, new or reconstructed non-emergency 4SLB stationary RICE <math>\geq</math>250 HP located at a major source of HAP, non-emergency stationary CI RICE &gt;500 HP located at a major source of HAP, existing non-emergency stationary CI RICE &gt;500 HP located at an area source of HAP, and existing non-emergency 4SLB stationary RICE &gt;500 HP located at an area source of HAP that are operated more than 24 hours per calendar year</p>	<p>a. Reduce CO emissions, and using a CEMS</p>	<p>i. You have installed a CEMS to continuously monitor CO and either O<sub>2</sub> or CO<sub>2</sub> at both the inlet and outlet of the oxidation catalyst according to the requirements in §63.6625(a); and  ii. You have conducted a performance evaluation of your CEMS using PS 3 and 4A of 40 CFR part 60, appendix B; and  iii. The average reduction of CO calculated using §63.6620 equals or exceeds the required percent reduction. The initial test comprises the first 4-hour period after successful validation of the CEMS. Compliance is based on the average percent reduction achieved during the 4-hour period.</p>
<p>4. Non-emergency 4SRB stationary RICE &gt;500 HP located at a major source of HAP, and existing non-emergency 4SRB stationary RICE &gt;500 HP located at an area source of HAP that are operated more than 24 hours per calendar year</p>	<p>a. Reduce formaldehyde emissions and using NSCR</p>	<p>i. The average reduction of emissions of formaldehyde determined from the initial performance test is equal to or greater than the required formaldehyde percent reduction; and  ii. You have installed a CPMS to continuously monitor catalyst inlet temperature according to</p>

		<p>the requirements in §63.6625(b); and</p> <p>iii. You have recorded the catalyst pressure drop and catalyst inlet temperature during the initial performance test.</p>
<p>5. Non-emergency 4SRB stationary RICE &gt;500 HP located at a major source of HAP, and existing non-emergency 4SRB stationary RICE &gt;500 HP located at an area source of HAP that are operated more than 24 hours per calendar year</p>	<p>a. Reduce formaldehyde emissions and not using NSCR</p>	<p>i. The average reduction of emissions of formaldehyde determined from the initial performance test is equal to or greater than the required formaldehyde percent reduction; and</p> <p>ii. You have installed a CPMS to continuously monitor operating parameters approved by the Administrator (if any) according to the requirements in §63.6625(b); and</p> <p>iii. You have recorded the approved operating parameters (if any) during the initial performance test.</p>
<p>6. New or reconstructed non-emergency stationary RICE &gt;500 HP located at a major source of HAP, new or reconstructed non-emergency 4SLB stationary RICE <math>250 \leq \text{HP} \leq 500</math> located at a major source of HAP, and existing non-emergency 4SRB stationary RICE &gt;500 HP</p>	<p>a. Limit the concentration of formaldehyde in the stationary RICE exhaust and using oxidation catalyst or NSCR</p>	<p>i. The average formaldehyde concentration, corrected to 15 percent O<sub>2</sub>, dry basis, from the three test runs is less than or equal to the formaldehyde emission limitation; and</p> <p>ii. You have installed a CPMS to continuously monitor catalyst inlet temperature according to the requirements in §63.6625(b); and</p> <p>iii. You have recorded the catalyst pressure drop and catalyst inlet temperature during the initial performance test.</p>
<p>7. New or reconstructed non-emergency stationary RICE &gt;500 HP located at a major source of HAP, new or reconstructed non-emergency 4SLB stationary RICE <math>250 \leq \text{HP} \leq 500</math> located at a major</p>	<p>a. Limit the concentration of formaldehyde in the stationary RICE exhaust and not using oxidation</p>	<p>i. The average formaldehyde concentration, corrected to 15 percent O<sub>2</sub>, dry basis, from the three test runs is less than or equal to the formaldehyde emission limitation; and</p>

source of HAP, and existing non-emergency 4SRB stationary RICE >500 HP	catalyst or NSCR	ii. You have installed a CPMS to continuously monitor operating parameters approved by the Administrator (if any) according to the requirements in §63.6625(b); and iii. You have recorded the approved operating parameters (if any) during the initial performance test.
8. Existing non-emergency stationary RICE $100 \leq \text{HP} \leq 500$ located at a major source of HAP, and existing non-emergency stationary CI RICE $300 < \text{HP} \leq 500$ located at an area source of HAP	a. Reduce CO or formaldehyde emissions	i. The average reduction of emissions of CO or formaldehyde, as applicable determined from the initial performance test is equal to or greater than the required CO or formaldehyde, as applicable, percent reduction.
9. Existing non-emergency stationary RICE $100 \leq \text{HP} \leq 500$ located at a major source of HAP, and existing non-emergency stationary CI RICE $300 < \text{HP} \leq 500$ located at an area source of HAP	a. Limit the concentration of formaldehyde or CO in the stationary RICE exhaust	i. The average formaldehyde or CO concentration, as applicable, corrected to 15 percent O <sub>2</sub> , dry basis, from the three test runs is less than or equal to the formaldehyde or CO emission limitation, as applicable.

[75 FR 51598, Aug. 20, 2010]

**Table 6 to Subpart ZZZZ of Part 63—Continuous Compliance With Emission Limitations, Operating Limitations, Work Practices, and Management Practices**

[Link to an amendment published at 76 FR 12870, March 9, 2011.](#)

As stated in §63.6640, you must continuously comply with the emissions and operating limitations and work or management practices as required by the following:

<b>For each . . .</b>	<b>Complying with the requirement to . . .</b>	<b>You must demonstrate continuous compliance by . . .</b>
1. New or reconstructed non-emergency 2SLB stationary RICE >500 HP located at a major source of HAP, new or reconstructed non-emergency 4SLB stationary RICE $\geq 250$ HP located at a major source of	a. Reduce CO emissions and using an oxidation catalyst, and using a CPMS	i. Conducting semiannual performance tests for CO to demonstrate that the required CO percent reduction is achieved; <sup>a</sup> and ii. Collecting the catalyst inlet temperature data according to

<p>HAP, and new or reconstructed non-emergency CI stationary RICE &gt;500 HP located at a major source of HAP</p>		<p>§63.6625(b); and  iii. Reducing these data to 4-hour rolling averages; and  iv. Maintaining the 4-hour rolling averages within the operating limitations for the catalyst inlet temperature; and</p>
		<p>v. Measuring the pressure drop across the catalyst once per month and demonstrating that the pressure drop across the catalyst is within the operating limitation established during the performance test.</p>
<p>2. New or reconstructed non-emergency 2SLB stationary RICE &gt;500 HP located at a major source of HAP, new or reconstructed non-emergency 4SLB stationary RICE ≥250 HP located at a major source of HAP, and new or reconstructed non-emergency CI stationary RICE &gt;500 HP located at a major source of HAP</p>	<p>a. Reduce CO emissions and not using an oxidation catalyst, and using a CPMS</p>	<p>i. Conducting semiannual performance tests for CO to demonstrate that the required CO percent reduction is achieved;<sup>a</sup>and  ii. Collecting the approved operating parameter (if any) data according to §63.6625(b); and  iii. Reducing these data to 4-hour rolling averages; and  iv. Maintaining the 4-hour rolling averages within the operating limitations for the operating parameters established during the performance test.</p>
<p>3. New or reconstructed non-emergency 2SLB stationary RICE &gt;500 HP located at a major source of HAP, new or reconstructed non-emergency 4SLB stationary RICE ≥250 HP located at a major source of HAP, new or reconstructed non-emergency stationary CI RICE &gt;500 HP located at a major source of HAP, existing non-emergency stationary CI RICE &gt;500 HP, existing non-emergency 4SLB stationary RICE &gt;500 HP located at an</p>	<p>a. Reduce CO emissions and using a CEMS</p>	<p>i. Collecting the monitoring data according to §63.6625(a), reducing the measurements to 1-hour averages, calculating the percent reduction of CO emissions according to §63.6620; and  ii. Demonstrating that the catalyst achieves the required percent reduction of CO emissions over the 4-hour averaging period; and  iii. Conducting an annual RATA of your CEMS using PS 3 and 4A of 40 CFR part 60, appendix</p>

area source of HAP that are operated more than 24 hours per calendar year		B, as well as daily and periodic data quality checks in accordance with 40 CFR part 60, appendix F, procedure 1.
4. Non-emergency 4SRB stationary RICE >500 HP located at a major source of HAP	a. Reduce formaldehyde emissions and using NSCR	i. Collecting the catalyst inlet temperature data according to §63.6625(b); and ii. Reducing these data to 4-hour rolling averages; and
		iii. Maintaining the 4-hour rolling averages within the operating limitations for the catalyst inlet temperature; and
		iv. Measuring the pressure drop across the catalyst once per month and demonstrating that the pressure drop across the catalyst is within the operating limitation established during the performance test.
5. Non-emergency 4SRB stationary RICE >500 HP located at a major source of HAP	a. Reduce formaldehyde emissions and not using NSCR	i. Collecting the approved operating parameter (if any) data according to §63.6625(b); and ii. Reducing these data to 4-hour rolling averages; and
		iii. Maintaining the 4-hour rolling averages within the operating limitations for the operating parameters established during the performance test.
6. Non-emergency 4SRB stationary RICE with a brake HP ≥5,000 located at a major source of HAP	a. Reduce formaldehyde emissions	Conducting semiannual performance tests for formaldehyde to demonstrate that the required formaldehyde percent reduction is achieved. <sup>a</sup>
7. New or reconstructed non-emergency stationary RICE >500 HP located at a major source of HAP and new or reconstructed non-emergency 4SLB stationary RICE 250≤HP≤500 located at a major	a. Limit the concentration of formaldehyde in the stationary RICE exhaust and using oxidation catalyst or NSCR	i. Conducting semiannual performance tests for formaldehyde to demonstrate that your emissions remain at or below the formaldehyde concentration limit; <sup>a</sup> and ii. Collecting the catalyst inlet

source of HAP		temperature data according to §63.6625(b); and
		iii. Reducing these data to 4-hour rolling averages; and
		iv. Maintaining the 4-hour rolling averages within the operating limitations for the catalyst inlet temperature; and
		v. Measuring the pressure drop across the catalyst once per month and demonstrating that the pressure drop across the catalyst is within the operating limitation established during the performance test.
8. New or reconstructed non-emergency stationary RICE >500 HP located at a major source of HAP and new or reconstructed non-emergency 4SLB stationary RICE 250≤HP≤500 located at a major source of HAP	a. Limit the concentration of formaldehyde in the stationary RICE exhaust and not using oxidation catalyst or NSCR	i. Conducting semiannual performance tests for formaldehyde to demonstrate that your emissions remain at or below the formaldehyde concentration limit; <sup>a</sup> and ii. Collecting the approved operating parameter (if any) data according to §63.6625(b); and
		iii. Reducing these data to 4-hour rolling averages; and
		iv. Maintaining the 4-hour rolling averages within the operating limitations for the operating parameters established during the performance test.
9. Existing emergency and black start stationary RICE ≤500 HP located at a major source of HAP, existing non-emergency stationary RICE <100 HP located at a major source of HAP, existing emergency and black start stationary RICE located at an area source of HAP, existing non-emergency stationary CI RICE ≤300 HP	a. Work or Management practices	i. Operating and maintaining the stationary RICE according to the manufacturer's emission-related operation and maintenance instructions; or ii. Develop and follow your own maintenance plan which must provide to the extent practicable for the maintenance and operation of the engine in a manner consistent with good air

<p>located at an area source of HAP, existing non-emergency 2SLB stationary RICE located at an area source of HAP, existing non-emergency landfill or digester gas stationary SI RICE located at an area source of HAP, existing non-emergency 4SLB and 4SRB stationary RICE <math>\leq 500</math> HP located at an area source of HAP, existing non-emergency 4SLB and 4SRB stationary RICE <math>&gt; 500</math> HP located at an area source of HAP that operate 24 hours or less per calendar year</p>		<p>pollution control practice for minimizing emissions.</p>
<p>10. Existing stationary CI RICE <math>&gt; 500</math> HP that are not limited use stationary RICE, and existing 4SLB and 4SRB stationary RICE <math>&gt; 500</math> HP located at an area source of HAP that operate more than 24 hours per calendar year and are not limited use stationary RICE</p>	<p>a. Reduce CO or formaldehyde emissions, or limit the concentration of formaldehyde or CO in the stationary RICE exhaust, and using oxidation catalyst or NSCR</p>	<p>i. Conducting performance tests every 8,760 hours or 3 years, whichever comes first, for CO or formaldehyde, as appropriate, to demonstrate that the required CO or formaldehyde, as appropriate, percent reduction is achieved or that your emissions remain at or below the CO or formaldehyde concentration limit; and</p>
		<p>ii. Collecting the catalyst inlet temperature data according to §63.6625(b); and</p>
		<p>iii. Reducing these data to 4-hour rolling averages; and</p>
		<p>iv. Maintaining the 4-hour rolling averages within the operating limitations for the catalyst inlet temperature; and</p>
		<p>v. Measuring the pressure drop across the catalyst once per month and demonstrating that the pressure drop across the catalyst is within the operating limitation established during the performance test.</p>

<p>11. Existing stationary CI RICE &gt;500 HP that are not limited use stationary RICE, and existing 4SLB and 4SRB stationary RICE &gt;500 HP located at an area source of HAP that operate more than 24 hours per calendar year and are not limited use stationary RICE</p>	<p>a. Reduce CO or formaldehyde emissions, or limit the concentration of formaldehyde or CO in the stationary RICE exhaust, and not using oxidation catalyst or NSCR</p>	<p>i. Conducting performance tests every 8,760 hours or 3 years, whichever comes first, for CO or formaldehyde, as appropriate, to demonstrate that the required CO or formaldehyde, as appropriate, percent reduction is achieved or that your emissions remain at or below the CO or formaldehyde concentration limit; and</p>
		<p>ii. Collecting the approved operating parameter (if any) data according to §63.6625(b); and</p>
		<p>iii. Reducing these data to 4-hour rolling averages; and</p>
		<p>iv. Maintaining the 4-hour rolling averages within the operating limitations for the operating parameters established during the performance test.</p>
<p>12. Existing limited use CI stationary RICE &gt;500 HP and existing limited use 4SLB and 4SRB stationary RICE &gt;500 HP located at an area source of HAP that operate more than 24 hours per calendar year</p>	<p>a. Reduce CO or formaldehyde emissions or limit the concentration of formaldehyde or CO in the stationary RICE exhaust, and using an oxidation catalyst or NSCR</p>	<p>i. Conducting performance tests every 8,760 hours or 5 years, whichever comes first, for CO or formaldehyde, as appropriate, to demonstrate that the required CO or formaldehyde, as appropriate, percent reduction is achieved or that your emissions remain at or below the CO or formaldehyde concentration limit; and</p>
		<p>ii. Collecting the catalyst inlet temperature data according to §63.6625(b); and</p>
		<p>iii. Reducing these data to 4-hour rolling averages; and</p>
		<p>iv. Maintaining the 4-hour rolling averages within the operating limitations for the catalyst inlet temperature; and</p>
		<p>v. Measuring the pressure drop across the catalyst once per month and demonstrating that</p>

		the pressure drop across the catalyst is within the operating limitation established during the performance test.
13. Existing limited use CI stationary RICE >500 HP and existing limited use 4SLB and 4SRB stationary RICE >500 HP located at an area source of HAP that operate more than 24 hours per calendar year	a. Reduce CO or formaldehyde emissions or limit the concentration of formaldehyde or CO in the stationary RICE exhaust, and using an oxidation catalyst or NSCR	i. Conducting performance tests every 8,760 hours or 5 years, whichever comes first, for CO or formaldehyde, as appropriate, to demonstrate that the required CO or formaldehyde, as appropriate, percent reduction is achieved or that your emissions remain at or below the CO or formaldehyde concentration limit; and
		ii. Collecting the approved operating parameter (if any) data according to §63.6625(b); and
		iii. Reducing these data to 4-hour rolling averages; and
		iv. Maintaining the 4-hour rolling averages within the operating limitations for the operating parameters established during the performance test.

<sup>a</sup>After you have demonstrated compliance for two consecutive tests, you may reduce the frequency of subsequent performance tests to annually. If the results of any subsequent annual performance test indicate the stationary RICE is not in compliance with the CO or formaldehyde emission limitation, or you deviate from any of your operating limitations, you must resume semiannual performance tests.

[75 FR 51600, Aug. 20, 2010]

**Table 7 to Subpart ZZZZ of Part 63—Requirements for Reports**

As stated in §63.6650, you must comply with the following requirements for reports:

<b>For each ...</b>	<b>You must submit a ...</b>	<b>The report must contain ...</b>	<b>You must submit the report ...</b>
1. Existing non-emergency, non-black start stationary RICE $100 \leq \text{HP} \leq 500$ located at a major source of HAP; existing non-emergency,	Compliance report	a. If there are no deviations from any emission limitations or operating limitations that apply to you, a statement that there were no deviations from	i. Semiannually according to the requirements in §63.6650(b)(1)–(5) for engines that are not limited use

<p>non-black start stationary CI RICE &gt;500 HP located at a major source of HAP; existing non-emergency 4SRB stationary RICE &gt;500 HP located at a major source of HAP; existing non-emergency, non-black start stationary CI RICE &gt;300 HP located at an area source of HAP; existing non-emergency, non-black start 4SLB and 4SRB stationary RICE &gt;500 HP located at an area source of HAP and operated more than 24 hours per calendar year; new or reconstructed non-emergency stationary RICE &gt;500 HP located at a major source of HAP; and new or reconstructed non-emergency 4SLB stationary RICE 250≤HP≤500 located at a major source of HAP</p>		<p>the emission limitations or operating limitations during the reporting period. If there were no periods during which the CMS, including CEMS and CPMS, was out-of-control, as specified in §63.8(c)(7), a statement that there were not periods during which the CMS was out-of-control during the reporting period; or</p> <p>b. If you had a deviation from any emission limitation or operating limitation during the reporting period, the information in §63.6650(d). If there were periods during which the CMS, including CEMS and CPMS, was out-of-control, as specified in §63.8(c)(7), the information in §63.6650(e); or</p> <p>c. If you had a malfunction during the reporting period, the information in §63.6650(c)(4)</p>	<p>stationary RICE subject to numerical emission limitations; and</p> <p>ii. Annually according to the requirements in §63.6650(b)(6)–(9) for engines that are limited use stationary RICE subject to numerical emission limitations.</p> <p>i. Semiannually according to the requirements in §63.6650(b).</p> <p>i. Semiannually according to the requirements in §63.6650(b).</p>
<p>2. New or reconstructed non-emergency stationary RICE that combusts landfill gas or digester gas equivalent to 10 percent or more of the gross heat input on an annual basis</p>	<p>Report</p>	<p>a. The fuel flow rate of each fuel and the heating values that were used in your calculations, and you must demonstrate that the percentage of heat input provided by landfill gas or digester gas, is equivalent to 10 percent or more of the gross heat input on an annual basis; and</p>	<p>i. Annually, according to the requirements in §63.6650.</p>
		<p>b. The operating limits provided in your federally enforceable permit, and any deviations from these</p>	<p>i. See item 2.a.i.</p>

		limits; and	
		c. Any problems or errors suspected with the meters.	i. See item 2.a.i.

[75 FR 51603, Aug. 20, 2010]

**Table 8 to Subpart ZZZZ of Part 63—Applicability of General Provisions to Subpart ZZZZ.**

As stated in §63.6665, you must comply with the following applicable general provisions.

<b>General provisions citation</b>	<b>Subject of citation</b>	<b>Applies to subpart</b>	<b>Explanation</b>
§63.1	General applicability of the General Provisions	Yes.	
§63.2	Definitions	Yes	Additional terms defined in §63.6675.
§63.3	Units and abbreviations	Yes.	
§63.4	Prohibited activities and circumvention	Yes.	
§63.5	Construction and reconstruction	Yes.	
§63.6(a)	Applicability	Yes.	
§63.6(b)(1)–(4)	Compliance dates for new and reconstructed sources	Yes.	
§63.6(b)(5)	Notification	Yes.	
§63.6(b)(6)	[Reserved]		
§63.6(b)(7)	Compliance dates for new and reconstructed area sources that become major sources	Yes.	
§63.6(c)(1)–(2)	Compliance dates for existing sources	Yes.	
§63.6(c)(3)–(4)	[Reserved]		
§63.6(c)(5)	Compliance dates for existing area sources that become major sources	Yes.	
§63.6(d)	[Reserved]		

§63.6(e)	Operation and maintenance	No.	
§63.6(f)(1)	Applicability of standards	No.	
§63.6(f)(2)	Methods for determining compliance	Yes.	
§63.6(f)(3)	Finding of compliance	Yes.	
§63.6(g)(1)–(3)	Use of alternate standard	Yes.	
§63.6(h)	Opacity and visible emission standards	No	Subpart ZZZZ does not contain opacity or visible emission standards.
§63.6(i)	Compliance extension procedures and criteria	Yes.	
§63.6(j)	Presidential compliance exemption	Yes.	
§63.7(a)(1)–(2)	Performance test dates	Yes	Subpart ZZZZ contains performance test dates at §§63.6610, 63.6611, and 63.6612.
§63.7(a)(3)	CAA section 114 authority	Yes.	
§63.7(b)(1)	Notification of performance test	Yes	Except that §63.7(b)(1) only applies as specified in §63.6645.
§63.7(b)(2)	Notification of rescheduling	Yes	Except that §63.7(b)(2) only applies as specified in §63.6645.
§63.7(c)	Quality assurance/test plan	Yes	Except that §63.7(c) only applies as specified in §63.6645.
§63.7(d)	Testing facilities	Yes.	
§63.7(e)(1)	Conditions for conducting performance tests	No.	Subpart ZZZZ specifies conditions for conducting performance tests at §63.6620.
§63.7(e)(2)	Conduct of performance tests and reduction of data	Yes	Subpart ZZZZ specifies test methods at §63.6620.
§63.7(e)(3)	Test run duration	Yes.	
§63.7(e)(4)	Administrator may require other testing under section	Yes.	

	114 of the CAA		
§63.7(f)	Alternative test method provisions	Yes.	
§63.7(g)	Performance test data analysis, recordkeeping, and reporting	Yes.	
§63.7(h)	Waiver of tests	Yes.	
§63.8(a)(1)	Applicability of monitoring requirements	Yes	Subpart ZZZZ contains specific requirements for monitoring at §63.6625.
§63.8(a)(2)	Performance specifications	Yes.	
§63.8(a)(3)	[Reserved]		
§63.8(a)(4)	Monitoring for control devices	No.	
§63.8(b)(1)	Monitoring	Yes.	
§63.8(b)(2)–(3)	Multiple effluents and multiple monitoring systems	Yes.	
§63.8(c)(1)	Monitoring system operation and maintenance	Yes.	
§63.8(c)(1)(i)	Routine and predictable SSM	Yes.	
§63.8(c)(1)(ii)	SSM not in Startup Shutdown Malfunction Plan	Yes.	
§63.8(c)(1)(iii)	Compliance with operation and maintenance requirements	Yes.	
§63.8(c)(2)–(3)	Monitoring system installation	Yes.	
§63.8(c)(4)	Continuous monitoring system (CMS) requirements	Yes	Except that subpart ZZZZ does not require Continuous Opacity Monitoring System (COMS).
§63.8(c)(5)	COMS minimum procedures	No	Subpart ZZZZ does not require COMS.
§63.8(c)(6)–(8)	CMS requirements	Yes	Except that subpart ZZZZ does not require COMS.

§63.8(d)	CMS quality control	Yes.	
§63.8(e)	CMS performance evaluation	Yes	Except for §63.8(e)(5)(ii), which applies to COMS.
		Except that §63.8(e) only applies as specified in §63.6645.	
§63.8(f)(1)–(5)	Alternative monitoring method	Yes	Except that §63.8(f)(4) only applies as specified in §63.6645.
§63.8(f)(6)	Alternative to relative accuracy test	Yes	Except that §63.8(f)(6) only applies as specified in §63.6645.
§63.8(g)	Data reduction	Yes	Except that provisions for COMS are not applicable. Averaging periods for demonstrating compliance are specified at §§63.6635 and 63.6640.
§63.9(a)	Applicability and State delegation of notification requirements	Yes.	
§63.9(b)(1)–(5)	Initial notifications	Yes	Except that §63.9(b)(3) is reserved.
		Except that §63.9(b) only applies as specified in §63.6645.	
§63.9(c)	Request for compliance extension	Yes	Except that §63.9(c) only applies as specified in §63.6645.
§63.9(d)	Notification of special compliance requirements for new sources	Yes	Except that §63.9(d) only applies as specified in §63.6645.
§63.9(e)	Notification of performance test	Yes	Except that §63.9(e) only applies as specified in §63.6645.

§63.9(f)	Notification of visible emission (VE)/opacity test	No	Subpart ZZZZ does not contain opacity or VE standards.
§63.9(g)(1)	Notification of performance evaluation	Yes	Except that §63.9(g) only applies as specified in §63.6645.
§63.9(g)(2)	Notification of use of COMS data	No	Subpart ZZZZ does not contain opacity or VE standards.
§63.9(g)(3)	Notification that criterion for alternative to RATA is exceeded	Yes	If alternative is in use.
		Except that §63.9(g) only applies as specified in §63.6645.	
§63.9(h)(1)–(6)	Notification of compliance status	Yes	Except that notifications for sources using a CEMS are due 30 days after completion of performance evaluations. §63.9(h)(4) is reserved.
			Except that §63.9(h) only applies as specified in §63.6645.
§63.9(i)	Adjustment of submittal deadlines	Yes.	
§63.9(j)	Change in previous information	Yes.	
§63.10(a)	Administrative provisions for recordkeeping/reporting	Yes.	
§63.10(b)(1)	Record retention	Yes.	
§63.10(b)(2)(i)–(v)	Records related to SSM	No.	
§63.10(b)(2)(vi)–(xi)	Records	Yes.	
§63.10(b)(2)(xii)	Record when under waiver	Yes.	

§63.10(b)(2)(xiii)	Records when using alternative to RATA	Yes	For CO standard if using RATA alternative.
§63.10(b)(2)(xiv)	Records of supporting documentation	Yes.	
§63.10(b)(3)	Records of applicability determination	Yes.	
§63.10(c)	Additional records for sources using CEMS	Yes	Except that §63.10(c)(2)–(4) and (9) are reserved.
§63.10(d)(1)	General reporting requirements	Yes.	
§63.10(d)(2)	Report of performance test results	Yes.	
§63.10(d)(3)	Reporting opacity or VE observations	No	Subpart ZZZZ does not contain opacity or VE standards.
§63.10(d)(4)	Progress reports	Yes.	
§63.10(d)(5)	Startup, shutdown, and malfunction reports	No.	
§63.10(e)(1) and (2)(i)	Additional CMS Reports	Yes.	
§63.10(e)(2)(ii)	COMS-related report	No	Subpart ZZZZ does not require COMS.
§63.10(e)(3)	Excess emission and parameter exceedances reports	Yes.	Except that §63.10(e)(3)(i) (C) is reserved.
§63.10(e)(4)	Reporting COMS data	No	Subpart ZZZZ does not require COMS.
§63.10(f)	Waiver for recordkeeping/reporting	Yes.	
§63.11	Flares	No.	
§63.12	State authority and delegations	Yes.	
§63.13	Addresses	Yes.	
§63.14	Incorporation by reference	Yes.	
§63.15	Availability of information	Yes.	

[75 FR 9688, Mar. 3, 2010]

**CERTIFICATE OF SERVICE**

I, Pam Owen, hereby certify that a copy of this permit has been mailed by first class mail to Entergy Arkansas, Inc. - Independence Plant, PO Box 551, Little Rock, AR, 72203, on this 22<sup>nd</sup> day of April, 2011.

Pam Owen  
Pam Owen, AAI, Air Division