RESPONSE TO COMMENTS

Georgia-Pacific LLC - Crossett Paper Operations
PERMIT #0597-AOP-R13
AFIN: 02-00013

On June 1, 2011, the Director of the Arkansas Department of Environmental Quality gave notice of a draft permitting decision for the above referenced facility. During the comment period, written comments on the draft permitting decision were submitted. The Department's response to these issues follows.

Note: The following page numbers and condition numbers refer to the draft permit. These references may have changed in the final permit based on changes made during the comment period.

Comment #1: Typographical error on spelling of "Venturi," and please add the word "new" before cooling towers

Response #1: The changes have been made to the permit as requested.

Comment #2: Please correct the emissions increases from the project to be 13.6 tons/year PM/PM_{10} and 17.9 tons per year VOC.

Response #2: The statement regarding emission increases was intended to be permitted increases rather than project related increases as represented in the application. However, after reviewing both emissions from the new equipment, SN-111 through 113 and SN-115ct though SN-117 ct, as well as the increases at SN-80 and 81, the statement has been amended as follows: "Permitted emission increases from these changes are 1.7 tpy PM/PM_{10} and 19.7 tons/yr VOC."

Comment #3: Please include "production" in the paragraph that starts "The replacement will not affect the mill's capacity or annual **production** and …"

Response #3: The change has been made to the permit as requested.

Comment #4: Please correct the boiler number to 10A Boiler for replacement of the primary, secondary, and intermediate superheater tube sections of **10A Boiler (SN-03).**

Response #4: The typographical error has been corrected as requested.

Regulations Section

Comment #5: Please add-in SN-111, SN-112, and SN-113 for three new converting lines to NESHAP JJJJ.

Response #5: The change have been made to the permit as requested

5A Boiler (SN-18)

Comment #6: Specific Condition 26, 5A Boiler – Chromium Total and POM emissions should be included in the table as they do meet the relative toxicity threshold. Please update the following chemicals in the table and their associated emissions:

Pollutant	lb/hr	tpy
Chromium Total	0.01	0.01
POM	0.01	0.01

Response #6: Chromium total is below the de minimis threshold on a Plantwide basis which is the reason this pollutant was not included in the draft permit. However POM will be added to the final permit as its omission was an oversight.

Comment #7: Specific Condition 28, 5A Boiler – Opacity – A weekly, full Method 9 stack reading for this source would be time consuming when done in conjunction with all the other new opacity requirements and unnecessary given the nature and good performance of the source. It is requested that this condition be changed to a weekly visual observation (and not a full Method 9), with follow-up action and full Method 9 if visible emissions are detected.

Response #7: Opacity compliance shall be demonstrated by the use of natural gas only as stated in Specific Condition 27. Specific Condition 28, which requires weekly observations of opacity, has been removed from the final permit.

6A Boiler (SN-19)

Comment #8: Specific Condition 31, 6A Boiler – Chromium Total and POM emissions should be included in the table as they do meet the relative toxicity threshold. Please update the following chemicals in the table and their associated emissions:

Pollutant	lb/hr	tpy
Chromium Total	0.01	0.01
POM	0.01	0.01

Response #8: Chromium total is below the de minimis threshold on a Plantwide basis which is the reason this pollutant was not included in the draft permit. However POM will be added to the final permit as its omission was an oversight.

Comment #9: Specific Condition 33, 6A Boiler – Opacity – A weekly, full Method 9 stack reading for this source would be time consuming when done in conjunction with all the other new opacity requirements and unnecessary given the nature and good performance of the source. It is requested that this condition be changed to a weekly visual observation (and not a full Method 9), with follow-up action and full Method 9 if emissions visible are detected.

Response #9: Opacity compliance shall be demonstrated by the use of natural gas only as stated in final Specific Condition 31. Draft Specific Condition 33, which requires weekly observations of opacity, has been removed from the final permit.

9A Boiler (SN-22)

Comment #10: Specific Condition 36, 9A Boiler –Xylene - Please revise the emission limits to match what was presented in the application. In addition, Chromium Total emissions should be included in the table as they do meet the relative toxicity threshold. Please update the following chemicals in the table and their associated emissions:

Pollutant	lb/hr	tpy
Chromium Total	0.01	0.03
Xylene	0.02	0.06

Response #10: Chromium total is below the de minimis threshold on a Plantwide basis which is the reason this pollutant was not included in the draft permit. However Xylene hourly emissions will be corrected in the final permit.

Comment #11: Specific Condition 38, 9A Boiler – Opacity – A daily, full Method 9 stack reading for this source would be time consuming and overly burdensome. It is requested that this condition be changed to a weekly full Method 9 as with 10A Boiler. If required, GP would be willing to change the stack testing frequency in Specific Condition 57 from every 5 years back to current practice of annually to match requirements of 10A Boiler.

Response #11: Weekly opacity for the 10A Boiler was because of an alternative scenario granted by EPA. More frequent source testing is not sufficient to show that the 9A Boiler is continuously meeting opacity limits. However, draft

condition 37 and 38 will be modified to state that, during periods where natural gas only is used there will be no opacity observation requirements and compliance with opacity limits shall be based upon the use of natural gas.

Comment #12: Specific Condition 47, 9A Boiler – Fuel Requirements – Please remove the phrase "only during periods when the Incinerator (SN-83) or its associated control equipment is inoperative." While this is normal operating procedure, there may be limited times that NCGs are routed to 9A to test systems, check procedures, etc not associated with an Incinerator malfunction.

Response #12: Because maintenance procedures may require venting of NCGs to the 9A Boiler, additional language will be added to this condition. The phrase will be modified to state "only during periods when the Incinerator (SN-83) or its associated control equipment is inoperative or undergoing maintenance."

Pulp Mill Operations (SN-33, 34, 60, and 61)

Comment #13: Specific Condition 73, Pulp Mill Operations – Ethylene Dichloride and Toluene emissions - Please revise the emission limits to match what was presented in the application. Please update the following chemicals in the table and their associated emissions:

SN	Description	Pollutant	lb/hr	ton/yr
33	Line 1 Washer	Ethylene Dichloride	0.01	0.02
		Toluene	0.02	0.05
34	Line 2 Washer	Ethylene Dichloride	0.01	0.02
		Toluene	0.02	0.05

Response #13: These pollutants were inadvertently left out of the draft permit. However, due to rounding, ethylene dichloride tpy emissions are 0.03 rather than 0.02. These pollutants will be corrected in the final permit as requested in the final version.

Bleach Plant (SN-30)

Comment #14: Specific Condition 78, Bleach Plant – Chlorine, Phenol, and Xylene - Please revise the emission limits to match what was presented in the application. Chlorine emissions should be included in the table as they do meet the relative toxicity threshold and Phenol and Xylene per ADEQ's general practice, should be rounded up to the nearest 0.01. Please update the following chemicals in the table and their associated emissions:

Pollutant	lb/hr	tpy
Chlorine	1.29	5.66
Phenol	0.04	0.14
Xylene	0.01	0.06

Response #14: While it is true NCASI does present data showing chlorine emissions, the facility has annually tested chlorine emissions at this source for several years and does not show that any chlorine higher than non-detectable levels. Therefore, chlorine will not be added to the final permit as requested.

Phenol was inadvertently left out of the draft permit and will be added to the final version as requested. The Xylene tpy factor presented above is higher than the sum total of m,p and o-xylene factors. Both were calculated in the renewal application, but the draft permit emissions for xylene are based upon the sum total of both o and m,p xylene NCASI factors. No changes to Xylene emissions are being made to the final permit.

8R Recovery Furnace and Salt Cake Mix Tank (SN-26 and 96)

Comment #15: Specific Condition 84, Salt Cake Mix Tank – VOC and TRS - Please revise the emission limits to match what was presented in the application. Please update the following chemicals in the table and their associated emissions:

SN	Description	Pollutant	lb/hr	ton/yr
96	Salt Cake Mix Tank	VOC TRS	0.6 0.1	2.0 0.1

Response #15: VOC calculations and emissions in the application, from which the emissions presented above are based upon, did not include the 1.2 safety factor as stated in the calculation example. The same 1.2 safety factor was also applied to the TRS presented in the draft permit for SN-96. No changes will be made to the final permit regarding VOC or TRS emissions at SN-96.

Comment #16: Specific Condition 85, 8R Recovery Furnace – SO_2 - Please revise the emission limits to match what was presented in the application. Please update the following chemicals in the table and their associated emissions:

SN	Pollutant	lb/hr	ton/yr
26	Startup – Specification Oil Only		
	SO_2	989.1	486.2

Response #16: This source went through PSD review for this pollutant in an earlier permit revision. Therefore, the emission rates requested and those submitted within the renewal application cannot be changed. The change will not be made to the final permit.

Comment #17: Specific Condition 90, 8R Recovery Furnace – TRS - Please revise the emission limits to match what was presented in the application. Please update the following chemicals in the table and their associated emissions:

SN	Pollutant	lb/hr	ton/yr
26	TRS	12.4	54.2

Response #17: The rates above requested by the permittee are based upon 466,745 dscfm; however, in previous applications (including an application for which the source went through BACT for other pollutants), the calculations have been based upon 350,000 dscfm. This basis for calculation will not be changed as requested.

However, the annual limits of 40.7 tpy were an error. The annualized emissions, of 11.2 lb/hr, should be 48.8 tpy. Therefore, the annual limit for SN-26 will be increased from 40.7 to 48.8 tpy.

Comment #18: Specific Condition 91, 8R Recovery Furnace – SAM - Please revise the emission limits to match what was presented in the application. Please update the following chemicals in the table and their associated emissions:

SN	Pollutant	lb/hr	ton/yr
26	Sulfuric Acid Mist (SAM)	3.5	13.2

Response #18: This source went through PSD review for this pollutant in an earlier permit revision. Therefore, the emission rates requested and those submitted within the renewal application cannot be changed, even to reduce emissions similar to this request. The change will not be made to the final permit.

Comment #19: Specific Condition 92, 8R Recovery Furnace and Salt Cake Mix Tank – Acetaldehyde, Benzene, Cadmium, and Xylene - Please revise the emission limits to match what was presented in the application. In addition, Chromium Total and POM emissions should be included in the

table as they do meet the relative toxicity threshold. Please update the following chemicals in the table and their associated emissions:

SN	Description	Pollutant	lb/hr	ton/yr
26	8R Recovery Furnace	Benzene	0.12	0.43
		Cadmium	0.01	0.01
		Chromium Total	**0.01**	**0.02**
		POM	**0.02**	**0.06**
		Xylene	0.09	0.34
96	Salt Cake Mix Tank	Acetaldehyde	0.03	0.12

Response #19: Chromium total is below the de minimis threshold on a Plantwide basis which is the reason this pollutant was not included in the draft permit. Benzene and cadmium emissions were switched. Xylene tpy for SN-26 and acetaldehyde tpy for SN-96 were switched as well. These pollutant emissions have been corrected in the final version. POM was inadvertently left out of the draft permit and will be added to the final version as requested also.

Comment #20: Specific Condition 97, 8R Recovery Furnace – Fuels – please add Ultra-Low Sulfur Diesel as an available fuel for 8R Boiler.

Response #20: In December 2008, the facility requested an allowance to burn ultra-low sulfur diesel fuel in addition to the currently permitted black liquor and specification oil at the 8R Recovery Furnace (SN-26) under the operational flexibility provisions of Regulation 26. According to the facility's request, the ultra-low sulfur diesel will be injected at a maximum rate of 1.0 gal/hr. This request has been added to the permit as an enforceable condition as Specific Condition 95.

Smelt Dissolving Tanks (SN-27A and 27B)

Comment #21: Specific Condition 107, Smelt Dissolving Tanks – VOC - Please revise the emission limits to match what was presented in the application. Please update the following chemicals in the table and their associated emissions:

SN	Description	Pollutant	ton/yr
27A	Smelt Dissolving Tank (East)	VOC	5.5
27B	Smelt Dissolving Tank (West)	VOC	5.5

Response #21: VOC emissions, as the sum total of all HAP, presented in the draft permit did not include contributions from POM. The changes requested above in VOC emissions will be made to the final permit as requested.

Comment #22: Specific Condition 110, Smelt Dissolving Tanks – Chromium Total and POM - Chromium Total and POM emissions should be included in the table as they do meet the relative toxicity threshold. Please update the following chemicals in the table and their associated emissions:

SN	Description	Pollutant	lb/hr	ton/yr
27A	Smelt Dissolving Tank (East)	Chromium Total	0.01	0.01
		POM	0.04	0.15
27B	Smelt Dissolving Tank (East)	Chromium Total	0.01	0.01
		POM	0.04	0.15

Response #22: Chromium total is below the de minimis threshold on a Plantwide basis which is the reason this pollutant was not included in the draft permit. However POM will be added to the final permit as its omission was an oversight.

Comment #23: Specific Condition 112, Smelt Dissolving Tanks – Opacity – A weekly, full Method 9 stack reading for these sources would be time consuming when done in conjunction with all the other new opacity requirements and unnecessary given the nature and good performance of the source. It is requested that this condition be changed to a weekly visual observation (and not a full Method 9), with follow-up action and full Method 9 if visual emissions are detected.

Response #23: Opacity requirements for SN-27A&B will be modified to only require a Method 9 if weekly opacity observations detect an exceedance of the visible emissions limit with corrective action following as requested. Scrubber monitoring will also serve as compliance with this limit.

Lime Kiln (SN-25)

Comment #24: Specific Condition 122, Lime Kiln – Chromium Total and POM emissions should be included in the table as they do meet the relative toxicity threshold. Please update the following chemicals in the table and their associated emissions:

Pollutant	lb/hr	ton/yr
Chromium Total	0.01	0.03
POM	0.01	0.01

Response #24: Chromium total is below the de minimis threshold on a Plantwide basis which is the reason this pollutant was not included in the draft permit. However, while POM was not included in the permit renewal application, its factors can be found in Table A-22b of NCASI TB 858. Emissions of POM, due to rounding and use of the NPRI factor (consistently used in other POM sources from the A-22 tables) is 0.01 lb/hr and 0.02 tpy, which will be added to the permit.

Comment #25: Specific Condition 124, Lime Kiln – Opacity – A daily, full Method 9 stack reading for this source would be time consuming and overly burdensome and unnecessary given the nature and good performance of the source. It is requested that this condition be changed to a weekly full Method 9 as with 10A Boiler. If required, GP would be willing to change the stack testing frequency in Specific Condition 132 from every 5 years back to current practice of annually to match requirements of 10A Boiler.

Response #25: The permit shall be modified to state that daily observations of opacity by personnel familiar with the source's emissions will only be required. However a Method 9 will be required if visible emissions appear to be in excess of permitted limits shall be required for SN-25.

Causticizing Area (SN-55F, 56F, SN-94, SN-98, SN-99, SN-100, SN-103, SN-105, SN-106, SN-107, SN-108, SN-109, and SN-110)

Comment #26: Specific Condition 138, Causticizing – VOC and TRS - Please revise the emission limits to match what was presented in the application. Please update the following chemicals in the table and their associated emissions:

SN	Description	Pollutant	lb/hr	ton/yr
55F	Lime Slaker Vent #1	VOC	0.7	2.5
56F	Lime Slaker Vent #2	VOC	0.7	2.5
94	Green Liquor Clarifier A	VOC	1.1	4.0
98	"A" Side Causticizers	VOC	0.1	0.1
99	"B" Side Causticizers	VOC	0.1	0.1
100	White Liquor Storage Tanks (4 total)	VOC	0.1	0.5
		TRS	0.1	0.1

Response #26: In addition to a typographical error in the calculation, these sources also now take into account the 10% reduction for methanol. VOC emissions at SN-55F, 56F, 94, 98, and 99 have been corrected in the final permit as presented above.

Also, SN-100 did not have all four tank emissions taken into account in the draft permit calculation.SN-100 emissions have been changed to 0.2

lb/hr and 0.6 tpy VOC due to rounding. Furthermore, emissions for TRS should be 0.3 lb/hr and 1.0 tpy for four tanks and an emission factor from NCASI TB 858 of 0.056 lb/hr/tank.

Comment #27: Specific Condition 139, Causticizing – VOC - Please revise the emission limits to match what was presented in the application. Please update the following chemicals in the table and their associated emissions:

SN	Description	Pollutant	lb/hr	ton/yr
103	Green Liquor Clarifier B	VOC	1.1	4.0
105	White Liquor Clarifier	VOC	0.2	0.7
110	White Liquor Splitter Box	VOC	0.2	0.7

Response #27: The above sources, in addition to SN-106-109 underwent a BACT analysis in the R10 permit revision. Therefore, it was an error to change these rates in the draft permit.

SN	Description	Pollutant	lb/hr	ton/yr
103	Green Liquor Clarifier B	VOC	0.2	0.8
105	White Liquor Clarifier	VOC	0.2	0.7
110	White Liquor Splitter Box	VOC	0.2	0.7

Comment #28: Specific Condition 140, Causticizing – Acetone, Ammonia, Chloroform, Methanol, and Xylene - Please revise the emission limits to match what was presented in the application. As the Pre-Coats Filter does not have an emission factor listed for Ammonia, please remove it from the table. Chloroform (Pre-coats Filter) and Xylene (White Liquor Splitter Box) emissions should be included in the table as they do meet the relative toxicity threshold. Please update the following chemicals in the table and their associated emissions:

SN	Description	Pollutant	lb/hr	ton/yr
55F	Lime Slaker Vent #1	Methanol	0.09	0.33
56F	Lime Slaker Vent #2	Methanol	0.09	0.33
94	Green Liquor Clarifier	Methanol	0.21	0.79
100	White Liquor Storage Tanks	Acetone	0.1	0.2
		Methanol	0.01	0.05

SN	Description	Pollutant	lb/hr	ton/yr
103	Green Liquor Clarifier B	Methanol	0.21	0.79
105	White Liquor Clarifier	Methanol	0.05	0.19
106	Mud Washer A	Methanol	0.03	0.10
107	Mud Washer B	Methanol	0.03	0.10
108	Pre-Coats Filter	~~Ammonia~~	~~0~~	~~0~~
		Chloroform	**0.01**	**0.01**
110	White Liquor Splitter Box	**Xylene**	**0.01**	**0.01**

Response #28: Ammonia will be removed from SN-108 and chloroform added. A 10% reduction in methanol was added sources of MeOH as noted in the above table. However, SN-100 was changed to 0.01 lb/hr and 0.02 tpy rather than as notated above; NCASI TB 858 was used rather than 973 for consistency with the other existing sources. Also, SN-110 methanol was changed to rates of 0.05 lb/hr and 0.19 tpy to reflect 10% MeOH.

However, the 20% safety factor to HAP emissions at SN-103 was removed in order to keep the actual unrounded emissions from exceeding the total VOC.

SN	Description	Pollutant	lb/hr	ton/yr
103	Green Liquor Clarifier B	Acetaldehyde	0.01	0.01
		Benzene	0.01	0.01
		Methanol	0.18	0.66
		Styrene	0.01	0.01
		Toluene	0.01	0.01
		Xylene	0.01	0.02

Board Machine No. 3 and Burners (SN-64 and 65)

Comment #29: Specific Condition 149, Board Machine Burners – Opacity – A weekly, full Method 9 stack reading for these sources would be time consuming when done in conjunction with all the other new opacity requirements and unnecessary given the nature and good performance of the source. It is requested that this condition be changed to a weekly visual observation (and not a full Method 9), with follow-up action and full Method 9 if visual emissions are detected.

Response #29: Opacity compliance shall be demonstrated by the use of natural gas only. Observations of opacity, as a weekly requirement within Specific Condition 149, are being removed from the final permit.

Tissue Machine No. 4 (SN-46, 66, and 67)

Comment #30: Specific Condition 157, Tissue Machine No. 4 Burners – Opacity – A weekly, full Method 9 stack reading for these sources would be time consuming when done in conjunction with all the other new opacity requirements and unnecessary given the nature and good performance of the source. It is requested that this condition be changed to a weekly visual observation (and not a full Method 9), with follow-up action and full Method 9 if visual emissions are detected.

Response #30: Opacity compliance shall be demonstrated by the use of natural gas only for the No. 4 Burners. However, Draft Specific Condition 157 also applies to the Tissue Machine No. 4 Dust System. While the comment does not specifically mention this source, it is implied. The opacity monitoring requirement for these sources will be modified to only require a Method 9 observation if visible emissions appear to be in excess of the permitted limit.

Tissue Machine No. 5 (SN-47, 54, and 68)

Comment #31: Specific Condition 164, Tissue Machine No. 5 Burners – Lead - Please revise the emission limits to match what was presented in the application. Please update the following chemicals in the table and their associated emissions:

SN	Description	Pollutant	lb/hr	ton/yr
47	Tissue Machine No. 5 Burners	Pb	0.01	0.01

Response #31: The typographical error in lb/hr from 2.0 to 0.01 has been changed as requested.

Comment #32: Specific Condition 165, Tissue Machine No. 5 Burners – PM/PM_{10} and CO - Please revise the emission limits to match what was presented in the application. Please update the following chemicals in the table and their associated emissions:

SN	Description	Pollutant	lb/hr	ton/yr
47	Tissue Machine No. 5 Burners	PM/PM_{10}	0.4	1.6
		CO	4.5	19.8

Response #32: The emissions presented above have rounded the BACT tpy limits for these two pollutants. However, the draft permit does not round these pollutants from how they appeared in the R0 permit in which these limits were first proposed. Therefore, there will be no change to the final permit for these pollutants at SN-47.

Comment #33: Specific Condition 168, Tissue Machine No. 5 Burners – Opacity – A weekly, full Method 9 stack reading for these sources would be time consuming when done in conjunction with all the other new opacity requirements and unnecessary given the nature and good performance of the source. It is requested that this condition be changed to a weekly visual observation (and not a full Method 9), with follow-up action and full Method 9 if visual emissions are detected.

Response #33: Opacity compliance shall be demonstrated by the use of natural gas only for the Tissue Machine No. 5 Burners. However, Draft Specific Condition 168 also applies to the Tissue Machine No. 5 Dust System. While the comment does not specifically mention this source, it is implied. The opacity monitoring requirement will be modified to only require a Method 9 observation if visible emissions appear to be in excess of the permitted limit.

Tissue Machine No. 6 (SN-48, 51, 52, and 69)

Comment #34: Specific Condition 177, Tissue Machine No. 6 Burners – PM/PM_{10} and VOC - Please revise the emission limits to match what was presented in the application. Please update the following chemicals in the table and their associated emissions:

SN	Description	Pollutant	lb/hr	ton/yr
48	Tissue Machine No. 6 Burners (41 MMBtu/hr)	PM/PM_{10}	0.4	1.7
		VOC	0.3	1.2

Response #34: BACT emissions above and reference in the permit renewal application do not match precisely those limits proposed in the R11 permit because of rounding. Tpy figures currently permitted are based upon an annualized rounded hourly emission rather than (as above) rounding the tpy. Therefore, no changes will be made to the final permit.

Comment #35: Specific Condition 180, Tissue Machine No. 6 Burners – Opacity – A weekly, full Method 9 stack reading for these sources would be time consuming when done in conjunction with all the other new opacity requirements and unnecessary given the nature and good performance of the source. It is requested that this condition be changed to a weekly

visual observation (and not a full Method 9), with follow-up action and full Method 9 if visual emissions are detected.

Response #35: Opacity compliance shall be demonstrated by the use of natural gas only for the No. 6 Tissue Machine Burners. However, Draft Specific Condition 180 also applies to the Tissue Machine No. 6 Dust System and Rewinders. While the comment does not specifically mention these sources, it is implied. The opacity monitoring requirement for these sources will be modified to only require a Method 9 observation if visible emissions appear to be in excess of the permitted limit.

Tissue Machine No. 7 (SN-49, 50, and 70)

Comment #36: Specific Condition 188, Tissue Machine No. 7 Burners – VOC - Please revise the emission limits to match what was presented in the application. Please update the following chemicals in the table and their associated emissions:

SN	Description	Pollutant	lb/hr	ton/yr
49	Tissue Machine No. 7 Burners	VOC	0.3	1.2

Response #36: VOC emissions for this source were incorrectly presented in the draft permit. This typographical error has been corrected as requested above.

Comment #37: Specific Condition 190, Tissue Machine No. 7 Burners – Non-Criteria Pollutants - All non-criteria pollutants were omitted for No. 7 Burners. In addition, Chromium Total emissions should be included in the table as they do meet the relative toxicity threshold. Please update the following chemicals in the table and their associated emissions:

SN	Description	Pollutant	lb/hr	ton/yr
49	Tissue Machine No. 7 Burners	Arsenic	0.01	0.01
		Benzene	0.01	0.01
		Cadmium	0.01	0.01
		Chromium Total	**0.01**	**0.01**
		Cobalt	0.01	0.01
		Formaldehyde	0.01	0.02
		Hexane	0.09	0.39
		Manganese	0.01	0.01
		Mercury	0.01	0.01
		Naphthalene	0.01	0.01
		Nickel	0.01	0.01
		Toluene	0.01	0.01

Response #37: The above HAPs were inadvertently left out of the draft permit, except total chromium (below de minimis thresholds). Therefore, with the exception of chromium, these pollutants will be added to the final version of the permit.

Comment #38: Specific Condition 192, Tissue Machine No. 7 Burners – Opacity – A weekly, full Method 9 stack reading for these sources would be time consuming when done in conjunction with all the other new opacity requirements and unnecessary given the nature and good performance of the source. It is requested that this condition be changed to a weekly visual observation (and not a full Method 9), with follow-up action and full Method 9 if visual emissions are detected.

Response #38: Opacity compliance shall be demonstrated by the use of natural gas only for the No. 7 Tissue Burners. However, Draft Specific Condition 192 also applies to the Tissue Machine No. 7 Dust System. While the comment does not specifically mention this source, it is implied. The opacity monitoring requirement will be modified to only require a Method 9 observation if visible emissions appear to be in excess of the permitted limit.

Tissue Machine No. 8 (SN-79, 80, and 81)

Comment #39: Specific Condition 201, Tissue Machine No. 8 Burners – VOC - The draft lists two sets of VOC limits (one is a copy of the SN-80 limit). The correct one is listed below. Please update the following chemicals in the table and their associated emissions:

SN	Description	Pollutant	lb/hr	ton/yr
79	Tissue Machine No. 8 Burners (50 MMBtu/hr)	VOC	1.0	4.2
			0.0192 lb.MMBtu	
			~~13.6~~	~~59.6~~
			~~1.29 lb/MDT~~	

Response #39: This typographical error has been corrected as requested.

Comment #40: Specific Condition 204, Tissue Machine No. 8 Burners – Opacity – A weekly, full Method 9 stack reading for these sources would be time consuming when done in conjunction with all the other new opacity requirements and unnecessary given the nature and good performance of the source. It is requested that this condition be changed to a weekly visual observation (and not a full Method 9), with follow-up action and full Method 9 if visual emissions are detected.

Response #40: Opacity compliance shall be demonstrated by the use of natural gas only for the No. 8 Tissue Burners. However, Draft Specific Condition 204 also applies to the Tissue Machine No. 8 Dust System. While the comment does not specifically mention this source, it is implied. The opacity monitoring requirement will be modified to only require a Method 9 observation if visible emissions appear to be in excess of the permitted limit.

No. 8 and 9 Extruder Machines (SN-71 and 72)

Comment #41: Specific Condition 215, No. 8 Extruder Machine – Ozone - Please revise the emission limits to match what was presented in the application. Please update the following chemicals in the table and their associated emissions:

SN	Description	Pollutant	lb/hr	ton/yr
71	No. 8 Extruder Electrostatic Treaters (A&B)	Ozone	0.8	3.2

Response #41: The above emissions at SN-71 will be changed in the permit as requested.

Comment #42: Specific Condition 217, No. 8 and 9 Extruder Machines – Opacity – A weekly, full Method 9 stack reading for these sources would be time consuming when done in conjunction with all the other new opacity requirements and unnecessary given the nature and good performance of the source. It is requested that this condition be changed to a weekly visual observation (and not a full Method 9), with follow-up action and full Method 9 if visual emissions are detected.

Response #42: Draft condition 217 has been changed to only require a person familiar with the sources' emissions and observations of visible emissions. The frequency remains weekly. If emissions appear to be in excess of opacity limits, then a Method 9 and corrective action is required.

Tanks and Miscellaneous Activities (SN-40, 75, 76F, 78F, 82F, and 97)

Comment #43: Specific Condition 222, Tanks and Miscellaneous Activities – PM_{10} and VOC - Please revise the emission limits to match what was presented in the application. In addition, Storage Tanks (SN-97) has been recalculated with 8 tanks after an inventory at the Mill. Please update the following chemicals in the table and their associated emissions:

SN	Description	Pollutant	lb/hr	ton/yr
40	Methanol Storage Tank	VOC	0.3	1.0

SN	Description	Pollutant	lb/hr	ton/yr
97	Storage Tanks	VOC TRS	4.4 0.9	19.0 3.9
78F	Road Emissions	PM_{10}	3.0	9.7
82F	Landfill Operations	PM_{10}	0.1	0.1

Response #43: VOC and TRS emissions at SN-97 have been recalculated for 8 tanks instead of 9. Also, TRS emissions were recalculated using NCASI TB 858 to be consistent with the rest of the renewal application. Emissions from SN-40, 78F, and 82F have been changed to reflect the application revisions submitted.

Comment #44: Specific Condition 223, Tanks and Miscellaneous Activities –Please revise the emission limits to match what was presented in the application. Please update the following chemicals in the table and their associated emissions:

SN	Description	Pollutant	lb/hr	ton/yr
97	Storage Tanks	Methanol	0.48	2.11
75	Pulp Storage Chests	Methanol	2.16	9.46
78F	Road Emissions	PM	12.0	39.0
82F	Landfill Operations	PM	0.2	0.1

Response #44: HAP emissions at SN-97 have been recalculated for 8 tanks instead of 9. In addition to the decreases in methanol presented above, carbon tetrachloride annual emissions have decreased by 0.01 tpy. Methanol for SN-75 will not be changed because that calculation uses a factor for TB 973 rather than TB 858. Emissions from SN-97, 78F, and 82F have been changed to reflect the application revisions submitted.

Incinerator and Scrubber (SN-83)

Comment #45: Specific Condition 232, Incinerator – VOC emissions are captured in Specific Condition 233 and should be removed from this condition.

Response #45: The change will be made as requested.

Comment #46: Specific Condition 233, Incinerator – VOC - Please revise the emission limits to match what was presented in the application. Please update the following chemicals in the table and their associated emissions:

Pollutant	lb/hr	ton/yr
VOC	0.8	3.6

Response #46: VOC emissions are subject to BACT from a previous revision of this the permit. Emissions for SN-83 in the draft permit are consistent with those

set within that PSD permit revision. Therefore, the VOC cannot be increased as presented in the renewal. The change will not be made as requested.

Comment #47: Specific Condition 234, Incinerator –Xylene - Please revise the emission limits to match what was presented in the application. Please update the following chemicals in the table and their associated emissions:

Pollutant	lb/hr	ton/yr
Xylene	0.02	0.05

Response #47: Xylene emissions in the final permit will be modified to match the table presented above as requested. Those in the draft permit had rounding errors.

Comment #48: Specific Condition 236, Incinerator – Opacity – A weekly, full Method 9 stack reading for these sources would be time consuming when done in conjunction with all the other new opacity requirements and unnecessary given the nature and good performance of the source. It is requested that this condition be changed to a weekly visual observation (and not a full Method 9), with follow-up action and full Method 9 if visual emissions are detected.

Response #48: The permit shall be modified to state that daily observations of opacity by personnel familiar with the source's emissions will only be required. However a Method 9 will be required if visible emissions appear to be in excess of permitted limits shall be required for SN-83.

Temporary Chipping and Debarking Equipment and Emergency Generators (SN-114, 115, 116, 117, 118, 119, 120, and 121)

Comment #49: Specific Condition 258, Chipping/Debarking and Generators – Naphthalene and PM - Please revise the emission limits to match what was presented in the application. Please update the following chemicals in the table and their associated emissions:

SN	Description	Pollutant	lb/hr	ton/yr
114	Temporary Debarking and Chipping equipment	PM	3.6	3.9
		Naphthalene	0.01	0.01

Response #49: Naphthalene emissions will be added to the final permit as these were inadvertently left out of the draft. PM emissions from the minor modification approval letter, and thusly presented in the draft permit, were incorrect. Therefore, PM emissions will be modified to match those in the table above.

Comment #50: Specific Condition 260, Chipping/Debarking and Generators – Opacity – A weekly, full Method 9 stack reading for these sources would be time consuming when done in conjunction with all the other new opacity requirements and unnecessary given the nature and good performance of the source. It is requested that this condition be changed to a weekly visual observation (and not a full Method 9), with follow-up action and full Method 9 if visual emissions are detected.

Response #50: SN-115 through SN-121 are emergency use engines, and SN-114 is for periodic use. Due to the intermittent nature of operation at these sources weekly observations are not sufficient. Daily observations of visible emissions by personnel familiar with the source's emissions rather than a full Method 9 will be required instead.

Comment #51: Because the Diamond Project may result in a reasonable possibility of significant emission increases of a regulated NSR pollutant, a condition should be added to the draft permit to comply with 40 CFR 52.21(r)(6) and (7). This would apply to NSR pollutants that exceed 50% of the significant emission rate (SER) of the applicable PSD standard.

Response #51: The No. 8 Tissue Machine Project Emission increases, including the Actual to Projected Actual applicability test for the existing units and the Actual to Potential test for the new units, shows increases above 50% of the SER for $PM_{2.5}$, PM_{10}, and PM. Plantwide Condition 12 was added to the permit to satisfy the requirements of 40 CFR 52.21(r)(6) and (7).

Comment #52: Prior to the permit draft period, the facility submitted modeling which included stack changes at the emergency generators, SN-115 through SN-121. These changes were necessary for a passing NAAQS and were inadvertently left out of the draft permit. A condition requiring these sources to be changed from horizontal to vertical stacks should be included in the final permit.

Response #52: The required stack changes have been added as Plantwide Condition 11. These changes, similarly to the ones required in Plantwide Condition 10 by the Plywood facility, are required to be completed prior to operation of any of the Diamond project sources.

Comment #53: The facility requests a distinction between broke (recycled paper) and pulp, both of which are processed at the repulpers, SN-93. Only broke uses hypochlorite.

Response #53: While the draft permit only limited broke processing at this source, the limit of 270 tons/broke in final Specific Condition 228 has been clarified to state that there is no limit specifically for pulp. The process description

has also been modified as well to make the difference between pulp and broke more clear.

ADEQ

ARKANSAS
Department of Environmental Quality

August 4, 2011

James Cutbirth
Superintendent -Environmental Services
Georgia-Pacific LLC - Crossett Paper Operations
P.O. Box 3333
Crossett, AR 71635-3333

Dear Mr. Cutbirth:

The enclosed Permit No. 0597-AOP-R13 is your authority to construct, operate, and maintain the equipment and/or control apparatus as set forth in your application initially received on 5/20/2008.

After considering the facts and requirements of A.C.A. §8-4-101 et seq., and implementing regulations, I have determined that Permit No. 0597-AOP-R13 for the construction, operation and maintenance of an air pollution control system for Georgia-Pacific LLC - Crossett Paper Operations to be issued and effective on the date specified in the permit, unless a Commission review has been properly requested under Arkansas Department of Pollution Control & Ecology Commission's Administrative Procedures, Regulation 8, within thirty (30) days after service of this decision.

The applicant or permittee and any other person submitting public comments on the record may request an adjudicatory hearing and Commission review of the final permitting decisions as provided under Chapter Six of Regulation No. 8, Administrative Procedures, Arkansas Pollution Control and Ecology Commission. Such a request shall be in the form and manner required by Regulation 8.603, including filing a written Request for Hearing with the APC&E Commission Secretary at 101 E. Capitol Ave., Suite 205, Little Rock, Arkansas 72201. If you have any questions about filing the request, please call the Commission at 501-682-7890.

Sincerely,

Mike Bates
Chief, Air Division

ADEQ
OPERATING
AIR PERMIT

Pursuant to the Regulations of the Arkansas Operating Air Permit Program, Regulation 26:

Permit No. : 0597-AOP-R13

IS ISSUED TO:

Georgia-Pacific LLC - Crossett Paper Operations
100 Paper Mill Road
Crossett, AR 71635
Ashley County
AFIN: 02-00013

THIS PERMIT AUTHORIZES THE ABOVE REFERENCED PERMITTEE TO INSTALL, OPERATE, AND MAINTAIN THE EQUIPMENT AND EMISSION UNITS DESCRIBED IN THE PERMIT APPLICATION AND ON THE FOLLOWING PAGES. THIS PERMIT IS VALID BETWEEN:

August 4, 2011 and August 2, 2016

THE PERMITTEE IS SUBJECT TO ALL LIMITS AND CONDITIONS CONTAINED HEREIN.

Signed:

Mike Bates
Chief, Air Division

August 4, 2011
Date

Georgia-Pacific LLC - Crossett Paper Operations
Permit #: 597-AOP-R13
AFIN: 02-00013

Table of Contents

SECTION I: FACILITY INFORMATION 5
SECTION II: INTRODUCTION 6
Process Description 8
Regulations 9
Emission Summary 10
SECTION III: PERMIT HISTORY 37
SECTION IV: SPECIFIC CONDITIONS 42
SN-03 42
SN-18 52
SN-19 54
SN-22 56
SN-57F, 58F, 101, and 102 64
SN-59 67
SN-33, 34, 60 and 61 71
SN-30 75
SN-26 and SN-96 79
SN-27A and 27B 87
SN-25 93
SN-55F, 56F, SN-94, SN-98, SN-99, SN-100
SN-103, SN-105, SN-106, SN-107, SN-108, SN-109, and SN-110 100
SN-62 and 63 105
SN-64 and 65 107
SN-46, 66, and 67 111
SN-47, 54, and 68 115
SN-48, 51, 52, and 69 120
SN-49, 50, and 70 125
SN-79, 80, and 81 130
SN-71 and 72 136
SN-40, 75, 76F, 78F, 82F, and 97 140
SN-93 143
SN-83 144
SN-111, 112, 113, 114 152
SN-115-ct, 116-ct, and 117-ct 154
SN-114, 115, SN-116, SN-117, SN-118, SN-119, SN-120, and SN-121 156
SECTION V: COMPLIANCE PLAN AND SCHEDULE 167
SECTION VI: PLANTWIDE CONDITIONS 168
Title VI Provisions 180
SECTION VII: INSIGNIFICANT ACTIVITIES 182
SECTION VIII: GENERAL PROVISIONS 183

APPENDIX A - CONTINUOUS EMISSION MONITORING SYSTEMS

APPENDIX B - NSPS D

APPENDIX C - NSPS BB

APPENDIX D - NSPS Kb

APPENDIX E - NESHAP S

APPENDIX F - 10A BOILER ALTERNATIVE MONITORING EXEMPTION

APPENDIX G - BLEACH PLANT ALTERNATIVE MONITORING EXEMPTION

APPENDIX H - NESHAP MM

APPENDIX I- LINE WASHER ALTERNATIVE MONITORING EXEMPTION

APPENDIX J - NESHAP JJJJ

APPENDIX K – NSPS IIII

APPENDIX L – NESHAP ZZZZ

List of Acronyms and Abbreviations

A.C.A.	Arkansas Code Annotated
AFIN	ADEQ Facility Identification Number
CFR	Code of Federal Regulations
CO	Carbon Monoxide
HAP	Hazardous Air Pollutant
lb/hr	Pound Per Hour
MVAC	Motor Vehicle Air Conditioner
No.	Number
NO_x	Nitrogen Oxide
PM	Particulate Matter
PM_{10}	Particulate Matter Smaller Than Ten Microns
SNAP	Significant New Alternatives Program (SNAP)
SO_2	Sulfur Dioxide
SSM	Startup, Shutdown, and Malfunction Plan
Tpy	Tons Per Year
UTM	Universal Transverse Mercator
VOC	Volatile Organic Compound

SECTION I: FACILITY INFORMATION

PERMITTEE:	Georgia-Pacific LLC - Crossett Paper Operations
AFIN:	02-00013
PERMIT NUMBER:	0597-AOP-R13
FACILITY ADDRESS:	100 Paper Mill Road Crossett, AR 71635
MAILING ADDRESS:	P.O. Box 3333
COUNTY:	Ashley County
CONTACT NAME:	James Cutbirth
CONTACT POSITION:	Superintendent – Environmental Services
TELEPHONE NUMBER:	870-567-8144
REVIEWING ENGINEER:	Paula Parker
UTM North South (Y):	Zone 15: 3667408.69 m
UTM East West (X):	Zone 15: 596029.30 m

SECTION II: INTRODUCTION

The Georgia-Pacific LLC - Paper Operations facility operates a kraft paper mill at 100 Paper Mill Road, Crossett, Arkansas 71635. This facility produces a variety of paper products on eight paper machines and two paper extruding machines. The paper machines include two fine paper machines, one board paper machine, and five tissue machines.

Summary of Permit Activity

This permit includes the following changes:

- Rebuild the No. 8 Tissue Machine (SN-80) and replace the venturi scrubber (SN-81) to make a new tissue product and install three new converting lines (SN-111, 112, and 113) plus a trim line system to process the improved product made on the rebuilt tissue machine and three new cooling towers (SN-115ct, SN-116ct, and SN-117ct).

Permitted emission increases from these changes are 1.7 tpy PM/PM_{10} and 19.7 tons/yr VOC. The proposed project is expected to improve production efficiency and allow for an increase in the paper machine design capacity. There will not be any changes made to the existing Yankee Dryer section of the tissue machine or the Yankee Dryer burners as part of this project. The changes will include:

•Replacement of the paper machine press section on the existing tissue machine to allow for more energy efficient drying.

•Replacement of the dry end dust collection equipment on the existing tissue machine, including a new wet venturi scrubber rated at 58,000 dry standard cubic feet per minute (dscfm). This new dust collection equipment will replace the existing wet venturi scrubber (SN-81, rated at 55,000 dscfm) and will be used to reduce particulate matter emissions from the dry end of the paper machine and wind-up reel.

•Construction of three new converting lines and a new trim line system. This equipment will be enclosed in a new building with each of the new lines equipped with a drum filtering system rated at 50,000 dscfm. The drum filtering systems will be designed to recirculate 100 percent of the exhaust air back into the building.

•Construction of three new, small cooling towers: one to serve the No. 8 Tissue Machine HVAC system, one for the No. 8 Tissue Machine vacuum pump, and one for the new converting building's HVAC system. The total circulating flow rate for the three cooling towers is 12,500 gallons per minute (gpm).

- Renewal of the Title V Air Permit
- The temporary use of debarking and chipping equipment (SN-114) including the associated diesel engines

Several sources were recalculated using updated technical bulletins. Emergency generators, SN-115 through SN-121, were also added to the permit as existing sources. A temporary chipper, SN-114, was installed but is limited to no more than 12 months of operation before removal from the site. Emission increases from SN-114 are 3.9 tpy PM, 2.6 tpy PM_{10}, 1.1 tpy SO_2, 2.6 tpy VOC, 22.5 tpy CO and 18.1 tpy NO_x. Emission decreases from the renewal are 446.4 tpy PM, 339.7 PM_{10}, 2,210.5 tpy SO_2, 1,911.6 tpy VOC, 2,003.8 tpy CO and 534.2 tpy NO_x, 23.17 tpy Pb, and 3.3 tpy TRS.

- Replace the existing pulp mill Distribution Control System and Quality Control System with new hardware and software components.

The replacement will not affect the mill's capacity or annual production and is expected to reduce downtime by three days. To be conservative, the facility calculated emissions for the pulp mill operation and upstream and downstream equipment. There are no emission changes.

- Burn chicken byproduct glycerin in the Recovery Boiler, SN-26.
- Add Ultra-Low Sulfur Diesel as an available fuel for the Recovery Boiler, SN-26.

  The approximate amount of the byproduct would be 5-10 gallons per minute; the flow of black liquor to the source, for comparison, is approximately 480 gallons per minute. In December 2008, the facility requested an allowance to burn ultra-low sulfur diesel fuel in addition to the currently permitted black liquor and specification oil at the 8R Recovery Furnace (SN-26) under the operational flexibility provisions of Regulation 26. According to the facility's request, the ultra-low sulfur diesel will be injected at a maximum rate of 1.0 gal/hr. These fuel changes would require no physical change to the boiler to accommodate the fuel. There are no permitted emission changes as a result of these allowances.

- Replace the primary, secondary, and intermediate superheater tube sections of the 10A Boiler (SN-03)
- Replace the soot blower system for the 9A Boiler (SN-22)

The replacement superheater tubes will be the same diameter and length and will use similar metallurgies compared to the existing unit. There will not be any increase in steam generating capacity or other operating characteristics as a result of the superheater replacement. The facility also requested a minor modification for the replacement of the soot blower system for the 9A Boiler (SN-22). The current soot blower system, due to age, is prone to failures, is obsolete, and the parts are no longer produced. There are no emission changes.

- Change CAM parameters for the 9A (SN-22) and 10A (SN-03) Boilers

The facility submitted a request for a minor modification in order to change CAM parameters for the 9A (SN-22) and 10A (SN-03) Boilers, based upon stack testing performed in 2008. Boiler parameters for both scrubber flow and pressure drop would be changing for these sources. There are no emission changes.

Process Description

Chips are received at the Mill by truck and rail. Upon unloading, the chips are pneumatically blown to the distribution tower and are then dropped onto the chip piles. Round logs are also received at the facility. After storage, the logs are transported to the debarking drums for bark removal. The debarked logs are fed to the chipper and the produced chips are then conveyed to the chip piles. The chips from the chip piles are screened prior to entering the chip silos. Rejected chips from the screening are burned in the Mill's combination boiler. The removed bark is pneumatically sent to bark piles for storage and eventual use in the Mill's boilers. The chips from the silos are conveyed to the Mill's thirteen batch digesters. The function of the digesters is to cook the chips using white liquor, black liquor, and the steam from the boilers. In the digestion process, these products are combined and cooked at a set pressure and temperature until the quality pulp is obtained. At the end of each "cook", the blow valves at the bottom of the digesters are opened, with the resulting pressure forcing the pulp mass through a blow line into one of the two blow tanks.

The blow tanks are at atmospheric pressure and the contents of the digesters enter the blow tanks tangentially at the top. When the chips hit the lower pressure in the tank, the liquor and water flash, blowing the chips apart to produce the pulp fibers. The vapors from the blow tanks are sent to the blow heat condensing system, where non condensable gases (NCGs) are removed. The steam vapors are condensed in the accumulator. The accumulator water is sent to the stripper and returned to the washers as cleaned condensate. Knots (e.g. undercooked wood chips, irregularly shaped or overly thick pieces of wood, etc.) are removed with the use of vibrating knotters/screens.

The pulp is washed to remove spent cooking chemicals. The Mill has two horizontal washers. In the washers, the wash water and pulp move in counter current directions. The washed pulp is passed through screening and cleaning stages which remove debris from the stock. After screening, the pulp passes through the decker system, which thickens the pulp for storage in high density storage chests.

The unbleached Kraft pulp is taken from the high density storage chests for further processing in the bleach plant. The bleaching process removes the remaining lignin and Kraft color from the unbleached pulp. Bleaching is performed in several stages using chlorine dioxide, caustic soda, oxygen, and hydrogen peroxide.

Recovery describes the set of operations that recovers the spent cooking chemicals for reuse in the digesters. The recovery process utilizes a multi-effect evaporator to concentrate weak black liquor. The concentrated black liquor is burned in the Mill's recovery furnace. The spent chemicals leave the recovery furnace from the bottom in a molten form and enter the smelt dissolving tanks. The causticizing operation reacts molten inorganic salts from the smelt dissolving tanks with weak wash water to form green liquor. This green liquor is then treated with slaked lime to form white liquor. The white liquor is then ready for use as the main cooking liquor in the digesters.

The facility, in order to accommodate production levels, may export black liquor to another mill with excess recovery capacity in exchange for white or green liquor. The 'liquor-swapping' is considered routine and normal for the industry, and equipment needed for the exchange has been present since the facility has been built.

Paper products are currently manufactured on eight paper machines and two paper extruding machines. The paper machines include two fine paper machines, one board paper machine, and five tissue machines. Each machine has its own stock preparation, head box, wire section, press section, dryer sections, coater section, calendar stacks, reel, and drum winder. The two fine paper machines produce a variety of products including but not limited to bond, envelope, tablet, and copier paper.

Tissue and towel converting includes the operations involved with converting large parent rolls of tissue/towel from the machines into finished product. This includes rewinding onto smaller sized rolls, folding, printing, cutting, packaging, and shipping.

The two extruding machines receive board from the board paper machine and from outside board customers and apply a polymer coating. Rolls of board are loaded onto an unwind stand before passing through a calendar stack, where they are subjected to burners which flame seal the board. An extruded poly sheet is then pressed together with the board.

Regulations

The following table contains the regulations applicable to this permit.

Source (SN)	Regulation
Arkansas Air Pollution Code (Regulation 18) effective June 18, 2010	
Regulations of the Arkansas Plan of Implementation for Air Pollution Control (Regulation 19) effective July 18, 2009	
Regulations of Arkansas Air Permit Operating Program (Regulation 26) effective June 18, 2010	
SN-03	NSPS Subpart D

Source (SN)	Regulation
SN-25	NSPS Subpart BB NESHAP Subpart MM
SN-26	NSPS Subpart BB NESHAP Subpart MM
SN-27A & 27B	NSPS Subpart BB NESHAP Subpart MM
SN-30	NESHAP Part S
SN-33 and SN-34	NSPS Subpart BB
SN-40	NSPS Subpart Kb
SN-59	NSPS Subpart BB
SN-71, SN-72, SN-80, SN-111, SN-112, and SN-113	NESHAP JJJJ
SN-115, 116, 117, 118, 119, 120, and 121	NESHAP ZZZZ
SN-118 and SN-119	NSPS IIII

Emission Summary

The following table is a summary of emissions from the facility. This table, in itself, is not an enforceable condition of the permit.

EMISSION SUMMARY				
Source #	Description	Pollutant	Emission Rates	
			lb/hr	tpy
Total Allowable Emissions		PM	334.0	1,307.8
		PM_{10}	323.8	1,276.9
		SO_2	1,539.8	1,914.4
		VOC	744.0	3,209.4
		CO	2,649.6	11,484.5
		NO_X	1,353.3	5,618.5

EMISSION SUMMARY				
Source #	Description	Pollutant	Emission Rates	
			lb/hr	tpy
		Pb	0.22	0.53
		TRS	32.3	130.7
	HAPs	Acetaldehyde*	7.81	32.50
		Acetophenone*	0.44	1.66
		Acrolein*	0.57	1.71
		Arsenic	0.13	0.25
		Benzene*	1.06	3.19
		Beryllium	0.06	0.06
		Biphenyl*	3.71	16.18
		Cadmium	0.13	0.13
		Carbon Disulfide*	0.33	1.34
		Carbon Tetrachloride*	0.15	0.39
		Carbonyl Sulfide*	0.14	0.50
		Chloroform*	9.88	42.71
		Chromium, Hex	0.04	0.08
		Cobalt	0.14	0.18
		Cresol*	2.34	8.86
		Cumene*	0.49	1.95
		2,4-Dinitrotoluene*	0.02	0.02
		Ethylene Dibromide*	0.03	0.11
		Ethylene Dichloride*	0.11	0.33
		Formaldehyde*	5.56	20.05
		Hexane*	4.95	21.16
		Hexachlorobenzene*	0.04	0.10
		Hexachloroethane*	0.21	0.90
		Hexachloropentadiene*	0.16	0.66
		Hydrogen chloride	12.30	48.36
		Manganese	0.19	0.49
		Mercury	0.13	0.13
		Methanol*	57.86	243.74
		Methylene Chloride	1.22	4.93
		Naphthalene*	1.01	3.42
		Nickel	0.30	0.92
		Phenol*	1.93	8.03
		Phosphorus	0.32	1.23
		Propionaldehyde*	0.43	1.61
		Propylene dichloride*	0.06	0.27
		POM*	0.66	2.41
		Selenium	0.06	0.08

EMISSION SUMMARY				
Source #	Description	Pollutant	Emission Rates	
			lb/hr	tpy
		Styrene*	0.52	1.52
		Tetrachloroethylene	0.75	2.73
		1,2,4-Trichlorobenzene*	0.60	2.11
		Toluene*	0.59	1.35
		Vinyl Chloride*	0.05	0.15
		Xylene*	0.98	3.13
Air Contaminants **		Acetone**	10.2	35.0
		Ammonia**	14.0	53.0
		Ozone	2.3	9.5
		Sulfuric Acid (SAM)**	38.5	83.4
03	10A Boiler	PM	100.1	438.5
		PM_{10}	100.1	438.5
		SO_2	21.0	92.0
		VOC	17.1	74.6
		CO	600.6	2,630.7
		NO_X	500.5	2,192.2
		Pb	0.06	0.26
		Acetaldehyde*	0.28	1.22
		Acetophenone*	0.01	0.01
		Acetone**	0.3	1.1
		Acrolein*	0.10	0.42
		Arsenic	0.01	0.02
		Benzene*	0.33	1.43
		Beryllium	0.01	0.01
		Cadmium	0.01	0.01
		Carbon Disulfide*	0.16	0.69
		Carbon Tetrachloride*	0.01	0.01
		Chloroform*	0.05	0.20
		Chromium, Hex	0.01	0.04
		Cobalt	0.01	0.01
		Cumene*	0.03	0.10
		2,4-Dinitrotoluene*	0.01	0.01
		Ethylene Dichloride*	0.04	0.16
		Formaldehyde*	0.86	3.74
		Hexane*	1.57	6.84
		Hexachlorobenzene	0.01	0.01
		Hydrogen chloride*	0.19	0.79
		Manganese	0.05	0.22
		Mercury	0.01	0.01
		Methanol*	1.04	4.53

EMISSION SUMMARY				
Source #	Description	Pollutant	Emission Rates	
			lb/hr	tpy
		Methylene Chloride	0.43	1.85
		Naphthalene*	0.13	0.53
		Nickel	0.01	0.03
		Phenol*	0.02	0.05
		Phosphorus	0.12	0.53
		Propionaldehyde*	0.08	0.33
		Propylene dichloride*	0.04	0.18
		POM*	0.30	1.30
		Selenium	0.01	0.02
		Styrene*	0.04	0.17
		Tetrachloroethylene	0.07	0.28
		Toluene*	0.04	0.15
		Vinyl Chloride*	0.03	0.10
		Xylene*	0.03	0.12
18	5A Boiler	PM	2.1	8.8
		PM_{10}	2.1	8.8
		SO_2	0.2	0.7
		VOC	1.5	6.4
		CO	22.2	97.2
		NO_X	74.0	323.8
		Pb	0.01	0.01
		Arsenic	0.01	0.01
		Benzene*	0.01	0.01
		Cadmium	0.01	0.01
		Cobalt	0.01	0.01
		Formaldehyde*	0.02	0.09
		Hexane*	0.48	2.09
		Manganese	0.01	0.01
		Mercury	0.01	0.01
		Naphthalene*	0.01	0.01
		Nickel	0.01	0.01
		POM*	0.01	0.01
		Toluene*	0.01	0.01
19	6A Boiler	PM	3.3	14.3
		PM_{10}	3.3	14.3
		SO_2	0.3	1.2
		VOC	2.4	10.4
		CO	36.0	157.7
		NO_X	120.0	525.4
		Pb	0.01	0.01

EMISSION SUMMARY				
Source #	Description	Pollutant	Emission Rates	
			lb/hr	tpy
		Arsenic	0.01	0.01
		Benzene*	0.01	0.01
		Cadmium	0.01	0.01
		Cobalt	0.01	0.01
		Formaldehyde*	0.04	0.15
		Hexane*	0.78	3.38
		Manganese	0.01	0.01
		Mercury	0.01	0.01
		Naphthalene*	0.01	0.01
		Nickel	0.01	0.01
		POM*	0.01	0.01
		Toluene*	0.01	0.01
22	9A Boiler	PM	75.8	243.3
		PM_{10}	75.8	243.3
		SO_2	502.5	1,361.6
		VOC	11.4	49.6
		CO	366.9	1,606.7
		NO_X	218.0	954.7
		Pb	0.04	0.14
		Acetaldehyde*	0.14	0.58
		Acetophenone*	0.01	0.01
		Acetone**	0.2	0.5
		Acrolein*	0.05	0.20
		Arsenic	0.01	0.03
		Benzene*	0.16	0.68
		Beryllium	0.01	0.01
		Cadmium	0.01	0.01
		Carbon Disulfide*	0.08	0.33
		Carbon Tetrachloride*	0.01	0.01
		Chloroform*	0.03	0.10
		Chromium, Hex	0.01	0.02
		Cobalt	0.02	0.06
		Cumene*	0.02	0.05
		2,4-Dinitrotoluene*	0.01	0.01
		Ethylene Dichloride*	0.02	0.08
		Formaldehyde*	0.47	2.06
		Hexane*	1.56	6.82
		Hexachlorobenzene*	0.01	0.01
		Hydrogen Chloride	0.13	0.57
		Manganese	0.03	0.13

EMISSION SUMMARY				
Source #	Description	Pollutant	Emission Rates	
			lb/hr	tpy
		Mercury	0.01	0.01
		Methanol*	0.50	2.15
		Methylene Chloride	0.20	0.88
		Naphthalene*	0.06	0.26
		Nickel	0.18	0.75
		Phenol*	0.01	0.03
		Phosphorus	0.08	0.33
		Propionaldehyde*	0.04	0.16
		Propylene Dichloride*	0.02	0.09
		POM*	0.15	0.63
		SAM**	16.8	48.9
		Selenium	0.01	0.02
		Styrene*	0.02	0.08
		Tetrachloroethylene	0.03	0.13
		Toluene*	0.03	0.13
		Vinyl Chloride*	0.02	0.05
		Xylene*	0.02	0.06
25	No. 4 Lime Kiln	PM	28.3	123.8
		PM_{10}	28.3	123.8
		SO_2	10.9	41.2
		VOC	1.5	5.6
		CO	5.8	21.9
		NO_X	53.5	203.6
		Pb	0.01	0.02
		TRS	2.2	9.6
		Acetaldehyde*	0.18	0.67
		Acetone**	0.1	0.1
		Acrolein*	0.01	0.01
		Arsenic	0.01	0.01
		Benzene*	0.02	0.04
		Beryllium	0.01	0.01
		Cadmium	0.01	0.01
		Carbon Disulfide*	0.01	0.04
		Chloroform*	0.01	0.01
		Chromium Hex	0.01	0.01
		Cobalt	0.01	0.01
		Formaldehyde*	0.18	0.67
		Hexane*	0.01	0.01
		Hydrogen Chloride	0.01	0.03
		Manganese	0.01	0.04

EMISSION SUMMARY				
Source #	Description	Pollutant	Emission Rates	
			lb/hr	tpy
		Mercury	0.01	0.01
		Methanol*	0.38	1.45
		Methylene Chloride	0.01	0.01
		Naphthalene*	0.42	1.57
		Nickel	0.01	0.02
		Phenol*	0.01	0.04
		Phosphorous	0.06	0.21
		POM*	0.01	0.02
		SAM**	0.7	2.6
		Selenium	0.01	0.01
		Styrene*	0.01	0.01
		Tetrachloroethylene	0.01	0.04
		Toluene*	0.01	0.01
		1,2,4-Trichlorobenzene*	0.01	0.02
		Xylene*	0.01	0.03
26	8R Recovery Furnace	PM	60.0	262.8
		PM_{10}	60.0	262.8
		SO_2	989.1	371.0
		VOC	25.9	98.6
		CO	1,420.0	6,219.6
		NO_X	276.0	1,208.6
		Pb	0.01	0.01
		TRS	11.2	48.8
		Acetaldehyde*	0.08	0.28
		Acetone**	2.3	8.6
		Arsenic	0.01	0.01
		Benzene*	0.12	0.43
		Beryllium	0.01	0.01
		Cadmium	0.01	0.01
		Chloroform*	0.01	0.02
		Chromium, Hex	0.01	0.01
		Cobalt	0.01	0.01
		Formaldehyde*	1.35	5.13
		Hexane*	0.05	0.17
		Hydrogen Chloride	9.49	36.14
		Manganese	0.01	0.04
		Methanol*	7.59	28.91
		Mercury	0.01	0.01
		Methylene Chloride	0.09	0.32
		Naphthalene*	0.05	0.18

EMISSION SUMMARY				
Source #	Description	Pollutant	Emission Rates	
			lb/hr	tpy
		Nickel	0.01	0.03
		Phosphorous	0.04	0.14
		POM*	0.02	0.06
		Selenium	0.01	0.01
		Styrene*	0.10	0.37
		SAM**	7.3	27.6
		Tetrachloroethylene	0.09	0.32
		Toluene*	0.01	0.03
		1,2,4-Trichlorobenzene*	0.14	0.51
		Xylene*	0.09	0.34
27A	Smelt Dissolving Tank (East)	PM	14.4	54.8
		PM_{10}	14.4	54.8
		SO_2	0.5	1.7
		VOC	1.5	5.5
		CO	0.7	2.7
		NOx	1.8	6.6
		Pb	0.01	0.01
		TRS	2.4	9.1
		Acetaldehyde*	0.08	0.30
		Acetone**	0.2	0.5
		Acrolein*	0.01	0.01
		Arsenic	0.01	0.01
		Benzene*	0.01	0.01
		Beryllium	0.01	0.01
		Cadmium	0.01	0.01
		Carbon Disulfide*	0.01	0.01
		Chloroform*	0.01	0.01
		Cobalt	0.01	0.01
		Cumene*	0.01	0.01
		Formaldehyde*	0.31	1.15
		Hexachlorocyclopentadiene*	0.01	0.04
		Hexane*	0.01	0.01
		Manganese	0.01	0.01
		Mercury	0.01	0.01
		Methanol*	0.95	3.62
		Methylene Chloride	0.01	0.01
		Naphthalene*	0.05	0.17
		Nickel	0.01	0.01
		Phosphorous	0.01	0.01
		POM*	0.04	0.15

EMISSION SUMMARY				
Source #	Description	Pollutant	Emission Rates	
			lb/hr	tpy
		Selenium	0.01	0.01
		Styrene*	0.02	0.04
		Tetrachloroethylene	0.01	0.01
		Toluene*	0.01	0.01
		1,2,4-Trichlorbenzene*	0.01	0.01
		Xylene*	0.01	0.01
27B	Smelt Dissolving Tank (West)	PM	14.4	54.8
		PM_{10}	14.4	54.8
		SO_2	0.5	1.7
		VOC	1.5	5.5
		CO	0.7	2.7
		NOx	1.8	6.6
		Pb	0.01	0.01
		TRS	2.4	9.1
		Acetaldehyde*	0.08	0.30
		Acetone**	0.2	0.5
		Acrolein*	0.01	0.01
		Arsenic	0.01	0.01
		Benzene*	0.01	0.01
		Beryllium	0.01	0.01
		Cadmium	0.01	0.01
		Carbon Disulfide*	0.01	0.01
		Chloroform*	0.01	0.01
		Cobalt	0.01	0.01
		Cumene*	0.01	0.01
		Formaldehyde*	0.31	1.15
		Hexachlorocyclopentadiene*	0.01	0.04
		Hexane*	0.01	0.01
		Manganese	0.01	0.01
		Mercury	0.01	0.01
		Methanol*	0.95	3.62
		Methylene Chloride	0.01	0.01
		Naphthalene*	0.05	0.17
		Nickel	0.01	0.01
		Phosphorous	0.01	0.01
		POM*	0.04	0.15
		Selenium	0.01	0.01
		Styrene*	0.02	0.04
		Tetrachloroethylene	0.01	0.01
		Toluene*	0.01	0.01

EMISSION SUMMARY				
Source #	Description	Pollutant	Emission Rates	
			lb/hr	tpy
		1,2,4-Trichlorbenzene*	0.01	0.01
		Xylene*	0.01	0.01
30	Bleach Plant	VOC	21.4	93.7
		CO	136.1	596.1
		Acetaldehyde*	0.23	0.99
		Acetone**	0.5	2.0
		Acrolein*	0.01	0.01
		Benzene*	0.01	0.01
		Carbon Tetrachloride*	0.01	0.01
		Chloroform*	7.64	33.44
		Cresol*	0.06	0.25
		Cumene*	0.01	0.01
		Ethylene Dibromide*	0.03	0.11
		Ethylene Dichloride*	0.01	0.01
		Formaldehyde*	0.05	0.21
		Hexachlorocyclopentadiene*	0.16	0.66
		Hexachloroethane*	0.21	0.90
		Hydrogen Chloride	2.48	10.83
		Hexane*	0.01	0.01
		Methanol*	12.90	56.51
		Methylene Chloride	0.01	0.03
		Propionaldehyde*	0.06	0.25
		Phenol*	0.04	0.14
		Styrene*	0.02	0.09
		Tetrachloroethylene	0.01	0.05
		Toluene*	0.01	0.01
		1,2,4-Trichlorbenzene*	0.01	0.03
		Xylene*	0.01	0.01
33	Line 1 Washer	VOC	7.5	28.4
		TRS	2.1	7.9
		Acetaldehyde*	0.10	0.35
		Acetone**	0.3	0.8
		Acetophenone*	0.21	0.79
		Acrolein*	0.01	0.02
		Benzene*	0.01	0.02
		Carbon Tetrachloride*	0.03	0.09
		Carbonyl Sulfide*	0.07	0.25
		Chloroform*	0.01	0.01
		Cresol*	0.34	1.29
		Ethylene Dichloride*	0.01	0.03

EMISSION SUMMARY				
Source #	Description	Pollutant	Emission Rates	
			lb/hr	tpy
		Formaldehyde*	0.01	0.01
		Hexane*	0.01	0.03
		Methanol*	4.66	17.69
		Methylene Chloride	0.01	0.01
		Phenol*	0.37	1.40
		Styrene*	0.01	0.04
		Tetrachloroethylene	0.04	0.15
		Toluene*	0.02	0.05
		1,2,4-Trichlorobenzene*	0.02	0.08
		Xylene*	0.01	0.02
34	Line 2 Washer	VOC	7.5	28.4
		TRS	2.1	7.9
		Acetaldehyde*	0.10	0.35
		Acetone**	0.3	0.8
		Acetophenone*	0.21	0.79
		Acrolein*	0.01	0.02
		Benzene*	0.01	0.02
		Carbon Tetrachloride*	0.03	0.09
		Carbonyl Sulfide*	0.07	0.25
		Chloroform*	0.01	0.01
		Cresol*	0.34	1.29
		Ethylene Dichloride*	0.01	0.03
		Formaldehyde*	0.01	0.01
		Hexane*	0.01	0.03
		Methanol*	4.66	17.69
		Methylene Chloride	0.01	0.01
		Phenol*	0.37	1.40
		Styrene*	0.01	0.04
		Tetrachloroethylene	0.04	0.15
		Toluene*	0.02	0.05
		1,2,4-Trichlorobenzene*	0.02	0.08
		Xylene*	0.01	0.02
35F	Aeration Stabilization Basin	VOC	17.3	75.5
		Acetaldehyde*	0.14	0.61
		Acrolein*	0.01	0.04
		Benzene*	0.02	0.07
		Biphenyl*	0.01	0.02
		Carbon Disulfide*	0.05	0.21
		Chloroform*	0.61	2.66
		Cresol*	0.01	0.01

EMISSION SUMMARY				
Source #	Description	Pollutant	Emission Rates	
			lb/hr	tpy
		Cumene*	0.41	1.77
		Formaldehyde*	0.04	0.18
		Methanol*	15.24	66.74
		Naphthalene*	0.09	0.36
		Phenol*	0.01	0.01
		Propionaldehyde*	0.01	0.04
		Styrene*	0.08	0.34
		Toluene*	0.03	0.11
		Xylene*	0.37	1.59
40	Methanol Storage Tank	VOC	0.3	1.0
		Methanol*	0.22	1.0
46	Tissue Machine No. 4 Burners	PM	0.2	0.8
		PM_{10}	0.2	0.8
		SO_2	0.1	0.1
		VOC	0.2	0.6
		CO	2.1	8.9
		NO_x	2.4	10.6
		Pb	0.01	0.01
		Arsenic	0.01	0.01
		Benzene*	0.01	0.01
		Cadmium	0.01	0.01
		Cobalt	0.01	0.01
		Formaldehyde*	0.01	0.01
		Hexane*	0.05	0.19
		Manganese	0.01	0.01
		Mercury	0.01	0.01
		Naphthalene*	0.01	0.01
		Nickel	0.01	0.01
		Toluene*	0.01	0.01
47	Tissue Machine No. 5 Burners	PM	0.4	1.6
		PM_{10}	0.4	1.6
		SO_2	0.1	0.1
		VOC	1.2	5.2
		CO	4.5	19.8
		NO_x	2.0	8.4
		Pb	0.01	0.01
		Arsenic	0.01	0.01
		Benzene*	0.01	0.01
		Cadmium	0.01	0.01
		Cobalt	0.01	0.01

EMISSION SUMMARY				
Source #	Description	Pollutant	Emission Rates	
			lb/hr	tpy
		Formaldehyde*	0.01	0.01
		Hexane*	0.05	0.20
		Manganese	0.01	0.01
		Mercury	0.01	0.01
		Naphthalene*	0.01	0.01
		Nickel	0.01	0.01
		Toluene*	0.01	0.01
48	Tissue Machine No. 6 Burners	PM	0.4	1.7
		PM_{10}	0.4	1.7
		SO_2	0.1	0.2
		VOC	0.3	1.4
		CO	4.5	19.8
		NO_x	2.0	8.4
		Pb	0.01	0.01
		Arsenic	0.01	0.01
		Benzene*	0.01	0.01
		Cadmium	0.01	0.01
		Cobalt	0.01	0.01
		Formaldehyde*	0.01	0.02
		Hexane*	0.09	0.39
		Manganese	0.01	0.01
		Mercury	0.01	0.01
		Naphthalene*	0.01	0.01
		Nickel	0.01	0.01
		Toluene*	0.01	0.01
49	Tissue Machine No. 7 Burners	PM	0.4	1.7
		PM_{10}	0.4	1.7
		SO_2	0.1	0.2
		VOC	0.3	1.2
		CO	4.2	18.2
		NO_x	2.5	10.8
		Pb	0.01	0.01
		Arsenic	0.01	0.01
		Benzene*	0.01	0.01
		Cadmium	0.01	0.01
		Cobalt	0.01	0.01
		Formaldehyde*	0.01	0.02
		Hexane*	0.09	0.39
		Manganese	0.01	0.01
		Mercury	0.01	0.01

EMISSION SUMMARY				
Source #	Description	Pollutant	Emission Rates	
			lb/hr	tpy
		Naphthalene*	0.01	0.01
		Nickel	0.01	0.01
		Toluene*	0.01	0.01
50	Tissue Machine No. 7 Dust System	PM	0.5	2.1
		PM_{10}	0.5	2.1
51	Tissue Machine No. 6 Rewinder	PM	0.5	1.9
		PM_{10}	0.5	1.9
52	Tissue Machine No. 6 Dust System	PM	0.5	1.9
		PM_{10}	0.5	1.9
54	Tissue Machine No. 5 Dust System	PM	0.3	1.1
		PM_{10}	0.3	1.1
55F	Slaker Vent #1	PM	0.4	1.4
		PM_{10}	0.4	1.4
		VOC	1.7	6.4
		TRS	0.8	2.8
		Acetaldehyde*	0.11	0.41
		Acetone**	0.2	0.5
		Acrolein*	0.01	0.01
		Ammonia**	7.0	26.5
		Benzene*	0.01	0.01
		Methanol*	0.86	3.26
		Styrene*	0.01	0.01
		Tetrachloroethylene	0.01	0.01
		Toluene*	0.01	0.02
		1,2,4-Trichlorobenzene*	0.01	0.01
		Xylene*	0.01	0.01
56F	Slaker Vent #2	PM	0.4	1.4
		PM_{10}	0.4	1.4
		VOC	1.7	6.4
		TRS	0.8	2.8
		Acetaldehyde*	0.11	0.41
		Acetone**	0.2	0.5
		Acrolein*	0.01	0.01
		Ammonia**	7.0	26.5
		Benzene*	0.01	0.01
		Methanol*	0.86	3.26
		Styrene*	0.01	0.01
		Tetrachloroethylene	0.01	0.01
		Toluene*	0.01	0.02

EMISSION SUMMARY				
Source #	Description	Pollutant	Emission Rates	
			lb/hr	tpy
		1,2,4-Trichlorobenzene*	0.01	0.01
		Xylene*	0.01	0.01
57F	Woodyard Debarking Drum and Associated Woodyard Chip Handling System	PM PM_{10} VOC	0.1 0.1 410.9	0.2 0.1 1,799.4
58F	Woodyard Chip Storage Piles & Chippers	PM PM_{10} VOC	2.5 1.3 2.1	10.8 5.4 8.8
59	Batch Digesters (13)	VOC TRS Acetaldehyde* Acetone** Acrolein* Benzene* Carbon Tetrachloride* Chloroform* Ethylene Dichloride* Formaldehyde* Hexane* Methanol* Styrene* Tetrachloroethylene Toluene* Xylene*	5.3 0.9 0.12 0.2 0.01 0.01 0.02 0.12 0.01 0.01 0.01 2.11 0.02 0.01 0.02 0.01	23.1 3.9 0.52 0.8 0.01 0.01 0.05 0.52 0.01 0.01 0.03 9.21 0.07 0.01 0.06 0.02
60	Line 1 Decker	Routed to the Incinerator (SN-83)		
61	Line 2 Decker	VOC TRS Acetaldehyde* Acetone** Acrolein* Benzene* Carbon Tetrachloride* Chloroform* Cresol* Formaldehyde* Methanol* Propionaldehyde*	4.5 2.1 0.33 0.5 0.01 0.01 0.02 0.13 1.56 0.09 2.02 0.10	16.9 7.7 1.23 1.8 0.02 0.01 0.07 0.49 5.90 0.33 7.65 0.35

EMISSION SUMMARY				
Source #	Description	Pollutant	Emission Rates	
			lb/hr	tpy
		Styrene*	0.02	0.06
		Tetrachloroethylene	0.04	0.15
		Toluene*	0.01	0.02
		1,2,4-Trichlorobenzene*	0.11	0.40
		Xylene*	0.02	0.05
62	Fine Paper Machine No. 1	VOC	18.6	81.3
		Acetaldehyde*	1.20	5.23
		Acetone**	0.8	3.6
		Acrolein*	0.05	0.20
		Formaldehyde*	0.24	1.05
		Methanol*	1.20	5.23
		Methylene Chloride	0.10	0.41
		Tetrachloroethylene	0.09	0.37
		1,2,4-Trichlorobenezene*	0.05	0.22
		Xylene*	0.03	0.11
63	Fine Paper Machine No. 2	VOC	11.3	49.3
		Acetaldehyde*	1.20	5.23
		Acetone**	0.8	3.6
		Acrolein*	0.05	0.20
		Formaldehyde*	0.24	1.05
		Methanol*	1.20	5.23
		Methylene Chloride	0.10	0.41
		Tetrachloroethylene	0.09	0.37
		1,2,4-Trichlorobenezene*	0.05	0.22
		Xylene*	0.03	0.11
64	Board Paper Machine No. 3	VOC	17.0	74.5
		Acetaldehyde*	1.95	8.51
		Acetone**	1.3	5.7
		Acrolein*	0.08	0.32
		Formaldehyde*	0.39	1.69
		Methanol*	1.95	8.51
		Methylene Chloride	0.15	0.66
		Tetrachloroethylene	0.14	0.59
		1,2,4-Trichlorobenzene*	0.09	0.36
		Xylene*	0.04	0.18
65	Board Paper Machine No. 3 Burners	PM	0.2	0.5
		PM_{10}	0.2	0.5
		SO_2	0.1	0.1
		VOC	0.1	0.4
		CO	1.3	5.5

EMISSION SUMMARY				
Source #	Description	Pollutant	Emission Rates	
			lb/hr	tpy
		NO_x	1.5	6.5
		Pb	0.01	0.01
		Arsenic	0.01	0.01
		Benzene*	0.01	0.01
		Cadmium	0.01	0.01
		Cobalt	0.01	0.01
		Formaldehyde*	0.01	0.01
		Hexane*	0.03	0.12
		Manganese	0.01	0.01
		Mercury	0.01	0.01
		Naphthalene*	0.01	0.01
		Nickel	0.01	0.01
		Toluene*	0.01	0.01
66	Tissue Machine No. 4	PM	0.5	2.0
		PM_{10}	0.5	2.0
		VOC	13.0	74.5
		Acetaldehyde*	0.11	0.47
		Biphenyl*	0.81	3.54
		Chloroform*	0.03	0.10
		Formaldehyde*	0.01	0.01
		Methanol*	0.05	0.19
		Methylene Chloride	0.01	0.04
		Phenol*	0.18	0.76
		Propionaldehyde*	0.01	0.01
		Toluene*	0.03	0.10
67	Tissue Machine No. 4 Dust System	PM	0.3	1.1
		PM_{10}	0.3	1.1
68	Tissue Machine No. 5	PM	0.3	1.1
		PM_{10}	0.3	1.1
		VOC	13.0	57.0
		Acetaldehyde*	0.07	0.27
		Biphenyl*	0.46	1.99
		Chloroform*	0.02	0.06
		Formaldehyde*	0.01	0.01
		Methanol*	0.03	0.11
		Methylene Chloride	0.01	0.03
		Phenol*	0.10	0.43
		Propionaldehyde*	0.01	0.01
		Toluene*	0.02	0.06

EMISSION SUMMARY				
Source #	Description	Pollutant	Emission Rates	
			lb/hr	tpy
69	Tissue Machine No. 6	PM	0.7	3.1
		PM_{10}	0.7	3.1
		VOC	26.7	116.6
		Acetaldehyde*	0.17	0.74
		Biphenyl*	1.26	5.52
		Chloroform*	0.04	0.15
		Formaldehyde*	0.01	0.01
		Methanol*	0.07	0.29
		Methylene Chloride	0.02	0.08
		Phenol*	0.27	1.19
		Propionaldehyde*	0.01	0.01
		Toluene*	0.04	0.15
70	Tissue Machine No. 7	PM	0.7	2.9
		PM_{10}	0.7	2.9
		VOC	17.7	77.4
		Acetaldehyde*	0.16	0.68
		Biphenyl*	1.17	5.11
		Chloroform*	0.04	0.14
		Formaldehyde*	0.01	0.01
		Methanol*	0.07	0.27
		Methylene Chloride	0.02	0.06
		Phenol*	0.25	1.10
		Propionaldehyde*	0.01	0.01
		Toluene*	0.04	0.14
71	No. 8 Extruder Electrostatic Treaters (A&B)	PM	0.4	1.5
		PM_{10}	0.4	1.5
		Ozone	0.8	3.2
72	No. 9 Extruder Electrostatic Treater	PM	0.6	2.5
		PM_{10}	0.6	2.5
		Ozone	1.5	6.3
75	Pulp Storage Chests	VOC	43.2	189.3
		TRS	3.8	16.6
		Acetaldehyde*	0.05	0.21
		Benzene*	0.01	0.01
		Chloroform*	0.10	0.44
		Hexane*	0.01	0.01
		Methanol*	0.22	0.95
		Phenol*	0.18	0.75
		Styrene*	0.01	0.02

EMISSION SUMMARY				
Source #	Description	Pollutant	Emission Rates	
			lb/hr	tpy
		Tetrachloroethylene	0.01	0.01
		Toluene*	0.01	0.01
		Xylene*	0.01	0.01
76F	Black Liquor Storage Basin No. 1	VOC	4.4	19.3
		Acetaldehyde*	0.20	0.87
		Acetone**	0.2	0.7
		Methanol*	4.02	17.61
78F	Road Emissions	PM	12.0	39.0
		PM_{10}	3.0	9.7
79	Tissue Machine No. 8 Burners	PM	0.9	3.6
		PM_{10}	0.9	3.6
		SO_2	0.1	0.2
		VOC	1.0	4.3
		CO	5.7	25.0
		NO_x	4.6	20.0
		Pb	0.01	0.01
		Arsenic	0.01	0.01
		Benzene*	0.01	0.01
		Cadmium	0.01	0.01
		Cobalt	0.01	0.01
		Formaldehyde*	0.01	0.02
		Hexane*	0.11	0.48
		Manganese	0.01	0.01
		Mercury	0.01	0.01
		Naphthalene*	0.01	0.01
		Nickel	0.01	0.01
		Toluene*	0.01	0.01

EMISSION SUMMARY				
Source #	Description	Pollutant	Emission Rates	
			lb/hr	tpy
80	Tissue Machine No. 8	PM	0.8	3.2
		PM_{10}	0.8	3.2
		VOC	13.6	59.6
		Acetaldehyde*	0.36	1.54
		Acetone**	0.2	0.8
		Acrolein*	0.03	0.10
		Benzene*	0.01	0.02
		Carbon Disulfide*	0.01	0.05
		Chloroform*	0.01	0.01
		Formaldehyde*	0.06	0.25
		Hexane*	0.01	0.02
		Methanol*	0.45	1.91
		Methylene Chloride	0.03	0.11
		Naphthalene*	0.01	0.03
		Phenol*	0.10	0.44
		Propionaldehyde*	0.10	0.44
		Styrene*	0.01	0.02
		Tetrachloroethylene	0.01	0.04
		Toluene*	0.01	0.01
		1,2,4 Trichlorobenzene*	0.03	0.11
		Xylene*	0.04	0.14
81	Tissue Machine No. 8 Dust System	PM	1.8	7.7
		PM_{10}	1.8	7.7
82F	Landfill Operations	PM	2.6	0.5
		PM_{10}	1.2	0.3
83	Incinerator	PM	2.7	11.9
		PM_{10}	2.7	11.9
		SO_2	9.1	39.9
		VOC	1.0	3.6
		CO	6.0	26.3
		NOx	23.0	100.8
		SAM**	1.0	4.3
		TRS	0.9	3.8
		Acetaldehyde*	0.03	0.11
		Acetone**	0.1	0.2
		Benzene*	0.04	0.14
		Carbon Tetrachloride*	0.01	0.04
		Formaldehyde*	0.03	0.09
		Hexane*	0.01	0.03
		Methanol*	0.81	3.06

EMISSION SUMMARY				
Source #	Description	Pollutant	Emission Rates	
			lb/hr	tpy
		Styrene*	0.01	0.01
		1,2,4-Trichlorobenzene*	0.01	0.02
		Xylene*	0.02	0.05
93	Repulper C	VOC	1.0	4.4
		Chloroform*	0.99	4.32
94	Green Liquor Clarifier A	VOC	2.2	8.0
		TRS	0.1	0.1
		Acetaldehyde*	0.01	0.01
		Acetone**	0.1	0.1
		Benzene*	0.01	0.01
		Methanol*	2.06	7.83
		Styrene*	0.01	0.01
		Toluene*	0.01	0.01
		Xylene*	0.01	0.02
96	Salt Cake Mix Tank	VOC	0.7	2.4
		TRS	0.1	0.2
		Acetaldehyde*	0.03	0.12
		Acetone**	0.1	0.2
		Acrolein*	0.01	0.01
		Benzene*	0.01	0.01
		Formaldehyde*	0.01	0.01
		Hexane*	0.01	0.01
		Methanol*	0.51	1.91
		Styrene*	0.01	0.01
		Tetrachloroethylene	0.01	0.01
		Toluene*	0.01	0.01
		1,2,4-Trichlorobenzene*	0.01	0.01
		Xylene*	0.01	0.01
97	Storage Tanks	VOC	4.4	19.0
		TRS	2.5	11.0
		Acetaldehyde*	0.01	0.02
		Acrolein*	0.01	0.01
		Benzene*	0.01	0.01
		Carbon Tetrachloride*	0.01	0.02
		Ethylene Dichloride*	0.01	0.01
		Hexane*	0.01	0.01
		Methanol*	0.48	2.11
		Styrene*	0.01	0.01
		Tetrachloroethylene	0.01	0.01
		Toluene*	0.01	0.01

EMISSION SUMMARY				
Source #	Description	Pollutant	Emission Rates	
			lb/hr	tpy
		1,2,4-Trichlorobenzene*	0.01	0.01
		Xylene*	0.01	0.03
98	"A" Side Causticizers	VOC	0.4	1.3
		TRS	0.4	1.2
		Acetaldehyde*	0.02	0.07
		Acetone**	0.1	0.1
		Benzene*	0.01	0.01
		Methanol*	0.01	0.01
		Styrene*	0.01	0.01
		Xylene*	0.01	0.01
99	"B" Side Causticizers	VOC	0.4	1.3
		TRS	0.4	1.2
		Acetaldehyde*	0.02	0.07
		Acetone**	0.1	0.1
		Benzene*	0.01	0.01
		Methanol*	0.01	0.01
		Styrene*	0.01	0.01
		Xylene*	0.01	0.01
100	White Liquor Storage Tanks (4 total)	VOC	0.2	0.6
		TRS	0.3	1.0
		Acetone**	0.1	0.2
		Methanol*	0.01	0.02
101	10A Boiler Bark Transfer System	PM	0.1	0.3
		PM_{10}	0.1	0.2
102	9A Boiler Bark Transfer System	PM	0.1	0.2
		PM_{10}	0.1	0.1
103	Green Liquor Clarifier B	VOC	0.2	0.8
		TRS	0.1	0.1
		Acetaldehyde*	0.01	0.01
		Acetone**	0.1	0.1
		Benzene*	0.01	0.01
		Methanol*	0.18	0.66
		Styrene*	0.01	0.01
		Toluene*	0.01	0.01
		Xylene*	0.01	0.02
105	White Liquor Clarifier	VOC	0.2	0.7
		Acetone**	0.1	0.1
		Benzene*	0.01	0.01
		Formaldehyde*	0.07	0.27

EMISSION SUMMARY				
Source #	Description	Pollutant	Emission Rates	
			lb/hr	tpy
		Methanol*	0.05	0.19
		Styrene*	0.01	0.01
		Xylene*	0.01	0.01
106	Mud Washer A	VOC	1.4	5.2
		TRS	0.1	0.2
		Acetone**	0.1	0.1
		Benzene*	0.01	0.01
		Formaldehyde*	0.04	0.14
		Methanol*	0.03	0.10
		Styrene*	0.01	0.01
		Xylene*	0.01	0.01
107	Mud Washer B	VOC	1.4	5.2
		TRS	0.1	0.2
		Acetone**	0.1	0.1
		Benzene*	0.01	0.01
		Formaldehyde*	0.04	0.14
		Methanol*	0.03	0.10
		Styrene*	0.01	0.01
		Xylene*	0.01	0.01
108	Pre-Coats Filter	VOC	0.1	0.2
		TRS	0.1	0.1
		Acetaldehyde*	0.01	0.01
		Acetone**	0.1	0.1
		Benzene*	0.01	0.01
		Chloroform	0.01	0.01
		Methanol*	0.04	0.14
		Tetrachloroethylene	0.01	0.01
		Toluene*	0.01	0.01
		Xylene*	0.01	0.01
109	Green Liquor Stabilization Tank	VOC	0.6	2.4
		TRS	0.1	0.2
		Acetaldehyde*	0.04	0.14
		Acetone**	0.2	0.6
		Cresol*	0.03	0.12
		Methanol*	0.37	1.63
		Phenol*	0.02	0.09
110	White Liquor Splitter Box	VOC	0.2	0.7
		Acetone**	0.1	0.1
		Benzene*	0.01	0.01
		Formaldehyde*	0.07	0.27

EMISSION SUMMARY				
Source #	Description	Pollutant	Emission Rates	
			lb/hr	tpy
		Methanol*	0.05	0.19
		Styrene*	0.01	0.01
111	Converting Line No. 1	VOC	1.8	7.8
112	Converting Line No. 2	VOC		
113	Converting Line No. 3	VOC		
114	Temporary Debarking and Chipping equipment	PM	3.6	3.9
		PM_{10}	2.5	2.6
		SO_2	1.1	1.1
		VOC	2.5	2.6
		CO	20.8	22.5
		NO_x	16.8	18.1
		Acetaldehyde*	0.01	0.01
		Acrolein*	0.01	0.01
		Benzene*	0.01	0.01
		Formaldehyde*	0.01	0.01
		POM*	0.01	0.01
		Toluene*	0.01	0.01
		Xylene*	0.01	0.01
115	Caterpillar Model No. 3406 Firewater Pump	PM	1.0	0.3
		PM_{10}	1.0	0.3
		SO_2	0.9	0.3
		VOC	1.1	0.3
		CO	2.9	0.8
		NO_x	13.1	3.3
		Acetaldehyde*	0.01	0.01
		Acrolein*	0.01	0.01
		Benzene*	0.01	0.01
		Formaldehyde*	0.01	0.01
		Naphthalene*	0.01	0.01
		POM*	0.01	0.01
		Toluene*	0.01	0.01
		Xylene*	0.01	0.01
115-ct	No. 8 TM Vac. Pump Cooling Tower	PM	0.1	0.1
		PM_{10}	0.1	0.1

EMISSION SUMMARY				
Source #	Description	Pollutant	Emission Rates	
			lb/hr	tpy
116	Caterpillar Model No. 3406 Firewater Pump	PM	1.0	0.3
		PM_{10}	1.0	0.3
		SO_2	0.9	0.3
		VOC	1.1	0.3
		CO	2.9	0.8
		NO_x	13.1	3.3
		Acetaldehyde*	0.01	0.01
		Acrolein*	0.01	0.01
		Benzene*	0.01	0.01
		Formaldehyde*	0.01	0.01
		Naphthalene*	0.01	0.01
		POM*	0.01	0.01
		Toluene*	0.01	0.01
		Xylene*	0.01	0.01
116-ct	No. 8 TM Chiller Cooling Tower	PM	0.1	0.1
		PM_{10}	0.1	0.1
117	Caterpillar Model No. 3406 Firewater Pump	PM	1.0	0.3
		PM_{10}	1.0	0.3
		SO_2	0.9	0.3
		VOC	1.1	0.3
		CO	2.9	0.8
		NO_x	13.1	3.3
		Acetaldehyde*	0.01	0.01
		Acrolein*	0.01	0.01
		Benzene*	0.01	0.01
		Formaldehyde*	0.01	0.01
		Naphthalene*	0.01	0.01
		POM*	0.01	0.01
		Toluene*	0.01	0.01
		Xylene*	0.01	0.01
117-ct	Conv. Building HVAC Cooling Tower	PM	0.1	0.2
		PM_{10}	0.1	0.2
118	John Deere JU6H-UF58 Firewater Pump	PM	0.2	0.1
		PM_{10}	0.2	0.1
		SO_2	0.3	0.1
		VOC	0.1	0.1
		CO	0.3	0.1
		NO_x	1.8	0.5

EMISSION SUMMARY				
Source #	Description	Pollutant	Emission Rates	
			lb/hr	tpy
		Acetaldehyde*	0.01	0.01
		Acrolein*	0.01	0.01
		Benzene*	0.01	0.01
		Formaldehyde*	0.01	0.01
		Naphthalene*	0.01	0.01
		POM*	0.01	0.01
		Toluene*	0.01	0.01
		Xylene*	0.01	0.01
119	John Deere JU6H-UF58 Firewater Pump	PM	0.2	0.1
		PM_{10}	0.2	0.1
		SO_2	0.3	0.1
		VOC	0.1	0.1
		CO	0.3	0.1
		NO_x	1.8	0.5
		Acetaldehyde*	0.01	0.01
		Acrolein*	0.01	0.01
		Benzene*	0.01	0.01
		Formaldehyde*	0.01	0.01
		Naphthalene*	0.01	0.01
		POM*	0.01	0.01
		Toluene*	0.01	0.01
		Xylene*	0.01	0.01
120	Cummins Series 382 Backup Generator	PM	0.2	0.1
		PM_{10}	0.2	0.1
		SO_2	0.2	0.1
		VOC	0.3	0.1
		CO	0.6	0.2
		NO_x	2.8	0.7
		Acetaldehyde*	0.01	0.01
		Acrolein*	0.01	0.01
		Benzene*	0.01	0.01
		Formaldehyde*	0.01	0.01
		Naphthalene*	0.01	0.01
		POM*	0.01	0.01
		Toluene*	0.01	0.01
		Xylene*	0.01	0.01
121	Caterpillar 3116 Backup Lime Kiln Rotation	PM	0.6	0.2
		PM_{10}	0.6	0.2
		SO_2	0.5	0.2
		VOC	0.6	0.2

EMISSION SUMMARY				
Source #	Description	Pollutant	Emission Rates	
			lb/hr	tpy
		CO	1.6	0.4
		NO_x	7.2	1.8
		Acetaldehyde*	0.01	0.01
		Acrolein*	0.01	0.01
		Benzene*	0.01	0.01
		Formaldehyde*	0.01	0.01
		Naphthalene*	0.01	0.01
		POM*	0.01	0.01
		Toluene*	0.01	0.01
		Xylene*	0.01	0.01

*HAPs included in the VOC totals. Other HAPs are not included in any other totals unless specifically stated.
**Air Contaminants such as ammonia, acetone, and certain halogenated solvents are not VOCs or HAPs.

SECTION III: PERMIT HISTORY

The first paper machine at Georgia-Pacific Crossett Paper Operations was constructed in 1937. On March 27, 1970, Georgia-Pacific was issued its first permit, Permit #16-A. On August 30, 1971 Georgia-Pacific was issued its second permit, Permit #68-A.

Permit #133-A, issued on December 15, 1972, allowed the installation of an extrusion and a laminating machine.

Permit #137-A was also issued on December 15, 1972. It permitted the installation of a fume scrubber on the digester feed system to control emissions from the digester and the installation of a cyclone and baghouse to control emissions from the sanding operations.

Permit #144-A, issued on March 28, 1973, allowed the installation of the 9A power boiler. Permit #149-A was also issued on March 28, 1973. It permitted the installation of an odor control system to collect, hold and distribute gases which are normally vented from the pulp mill digesters. The gases are burned in the lime kiln.

Permit #140-A was issued on July 23, 1976. This permit dealt with equipment maintenance problems such as the repair of boilers and the replacement of control devices. This permit allowed Georgia-Pacific to operate an additional boiler to provide steam while the existing boilers are taken out of service for repairs.

Permit #411-A, issued to Georgia-Pacific on May 27, 1977, permitted the installation of a venturi scrubber for the control of lime dust emissions from the lime slaker and lime handling system at the mill.

Permit #597-A, issued to Georgia-Pacific on March 6, 1980, permitted the installation of new equipment in the pulping and power utility areas. In the pulping area the 8R Recovery Furnace, the No. 4 Lime Kiln, a set of evaporators, new digesters and new washers were installed. In the power utility area two wood fire boilers each equipped with a multiclone and a venturi scrubber were installed.

Permit #597-AR-1 was issued on July 23, 1982. It was modified by Permit #597-AR-2, issued on November 1, 1984. Permit #597-AR-2 superseded all previously issued air permits. Permit #597-AR-2 allowed Georgia-Pacific to convert a recovery furnace to a power boiler, the 10A Boiler. This was a major modification of a major stationary source and therefore was subject to PSD review. Only NO_X and CO became subject to the PSD requirements because of reductions in all the other pollutants. Modeling predicted that the ambient air concentrations due to the increase in NO_X and CO emission would be less than the de minimis levels. Therefore, preconstruction ambient air monitoring was not required.

Permit #597-AR-3 was issued to Georgia-Pacific on August 18, 1988. Emission limits for the 10A Boiler, 8R Recovery Furnace and the No. 4 Lime Kiln were revised as the result of testing. Permit #597-AR-4 was issued on July 11, 1989. Expansions at the bleach plant were permitted.

Permit #597-AR-5 was issued to Georgia-Pacific on March 18, 1993. This permit included sources at the mill that were not previously permitted. It allowed Georgia-Pacific to burn Tire Derived Fuel (TDF), other scrap rubber products and Refuse Derived Fuel (RDF) in the 10A and 9A Boilers. In addition, a new hardwood brownstock washer system was installed to replace the existing drum washers installed in 1968.

Georgia-Pacific was issued a Prevention of Significant Deterioration (PSD) permit, Permit #1449-A, on May 18, 1993. Stack testing of the 8R Recovery Furnace showed that the current permitted emission rate for NO_X was not attainable. The allowable emission rate of NO_X from the 8R Recovery Furnace was increased by 402.1 tons per year, thus triggering PSD review. Permit #597-AOP-R0, issued on February 28, 1997, was the first operating air permit issued to Georgia-Pacific Corporation Crossett Paper Operations under Regulation #26. This permit incorporated sources that were not previously permitted. Some allowable emission rates were modified from the previous permit to reflect new emission factors, new test data and/or alternate fuel. This permit also incorporated the Prevention of Significant Deterioration (PSD) permit application submitted in relation to the installation of the new No. 8 Tissue Machine.

Permit #597-AOP-R1, issued on June 29, 1999, was the second Title V operating permit issued to Georgia-Pacific Corporation --Crossett Paper Operations under Regulation #26. The changes in this permit were solely related to air pollutant emission rates and did not affect the Mill's production limits established in the original Title V permit. One purpose of this modification was to address the requirements of a CAO regarding carbon monoxide emissions from the Bleach Plant Scrubber (SN-30). Due to a lack of industry or regulatory information suggesting otherwise, carbon monoxide emissions from the bleach plant were not included in Permit #597-AOP-R0. Specific Condition #73 of that permit required Georgia-Pacific to test for carbon monoxide emissions from SN-30. The required stack testing was performed on September 24, 1997. Emission rates were derived from the stack tests and were added to the permit.
On February 15, 1999, revised versions of Regulations #18 and #19 became effective. All regulatory citations in the permit were changed in 597-AOP-R1 to reflect the new regulations. Compliance demonstrations for all opacity limits have been added to the permit. Opacity demonstrations include, but are not limited to, daily or weekly observations and monitoring of control equipment operating parameters. The compliance demonstrations for all emission limits have been specifically identified in the permit. Applicable provisions of NSPS and NESHAP Subparts have been written into the permit.

The second purpose of this modification was to address the addition of pollution control equipment to comply with the requirements of 40 CFR Part 63 Subpart S -- National Emission Standards for Hazardous Air Pollutants from the Pulp and Paper Industry (NESHAP Subpart S or Cluster Rule). This modification qualified as a Pollution Control Project (PCP), and thus the new point source (an Incinerator, SN-83) was exempt from PSD.

Section 19.8 of Regulation #19 provides that the Lime Kiln at GP Crossett should have a TRS emission limit of 8 ppm. Because a source limited to 5 ppm was routed to the Lime Kiln, the lime kiln was assigned a 5 ppm limit. 597-AOP-R1 stipulated that once the HVLC system was

outed to collect the emissions from the 5 ppm source, the emission rate for the Lime Kiln could be raised back to 8 ppm. This change has been completed.

597-AOP-R2 was finalized on December 14, 1999. A typographical error was made in a previous permit application which listed the minimum scrubbing liquid flow rate to the #4 tissue machine scrubber (SN-67) as 300 gpm. The actual minimum scrubber flow rate was 70 gpm. Note that the #4 and #5 tissue machine scrubbers are similar and that the #5 tissue machine minimum scrubbing flow rate was also 70 gpm. There was no emission increase associated with this minor modification.

On March 29, 1999, EPA Region 6 issued GP Crossett Paper Operations a NOV addressing the failure to install a continuous opacity monitor for SN-03, the 10A boiler. The current permit will be revised, in a timely manner, to assure compliance with any new applicable requirements resulting from the resolution of this issue.

597-AOP-R3 was finalized on December 14, 2001. This modification, which required PSD review, allowed the Crossett Mill to add the No. 9 Machine to produce tissue and towel. The No. 9 Machine was projected to have a production capacity of 250 Machine Dried Tons of paper (MDT) per day. The installation included the machine itself along with associated stock preparation and converting equipment. The proposed modification exceeded the PSD significant rate thresholds for PM_{10}, VOC, CO, and NOx.

597-AOP-R4 was finalized on November 12, 2003. The Georgia-Pacific Crossett - Paper Operations facility renewed their Title V permit and included CAM requirements for SN-03, SN-22, SN-50, SN-81, and SN-83. Also included with the renewal permit were four modifications, two of which were minor.

The first modification was to rebuild a Repulper (SN-93) damaged by a fire. The second minor modification involved the installation of an additional electrostatic treater and associated burner to the No. 8 Extruder, SN-71.

Previous to this modification, particulate emissions for the incinerator were underestimated. The assumed stack gas temperature and moisture content were also assumed incorrectly. In addition, the scrubber removal efficiency for particulate was actually 93% instead of 95% as stated in the application. Air Permit 597-AOP-R4 corrected these values.

Carbon monoxide emissions from the bleach plant, resulting from the converting of bleaching operations to elemental chlorine free (ECF) bleaching, were also previously underestimated. The new permit acknowledged that the source required a permitted increase of 242.6 tons of CO per year. Limited data was available at the time of the modification to illustrate any potential increase in CO emissions and none was assumed. The bleach plant conversion was part of a modification which included a PCP (Pollution Control Project) involving an incinerator (SN-83). Both of these changes allowed the facility to comply with Cluster Rule requirements.

597-AOP-R5 was finalized on November 12, 2003. The permit was modified to include applicable requirements of NESHAP Subpart MM - National Emission Standards for Hazardous Air Pollutants for Chemical Recovery Combustion Sources at Kraft, Sulfite, and Stand-Alone Semichemical Pulp Mills. Affected sources include Smelt Dissolving Tank (East and West, SN-27A and B), the No. 4 Lime Kiln (SN-25), and the 8R Recovery Furnace (SN-26). The permitted particulate emissions at the lime kiln were reduced to comply with the standards of the subpart. The current controls at SN-25, as indicated by stack test data, were sufficient to comply with the more stringent PM emission limit. The permitted particulate emission rate at SN-25 was decreased by 20.5 tons per year. Permitted limits, at the time, were sufficient to meet the established standards set forth in the subpart for the recovery furnace and smelt dissolving tanks.

597-AOP-R6 was finalized on May 31, 2005. The facility modified their permit in order to allow for the relaxation of the O_2 limits for the 10A Boiler (SN-03) during periods of startup, shutdown, and malfunction. There is no actual or permitted emission increase as a result of this modification.

Furthermore, two activities were added to the Insignificant Activity list. First, the baghouse for the Perini Towel Rewinder and Spectrum Towel Printer has been included as an A-13 activity. The Spectrum Towel Printer, which uses inks of low weight percent VOC and no HAPs, were also added as an A-13 activity.

597-AOP-R7 was finalized on December 5, 2005. An allowance to the permit was added for the continued operation of the No. 4 Tissue Machine (SN-66) during the repair of its dust control equipment (SN-67). This allowance has been granted to the facility's other paper machines since the renewal permit.

597-AOP-R8 was finalized May 12, 2006. This revision allowed the facility to modify nine of their Digesters (SN-59) by replacing the six-inch blow valves with eight-inch valves. The modification resulted in an increase in hardwood pulp production of approximately 50 tons per day. The facility is also requested the ability to receive 1.5% sulfur fuel oil while still keeping a 1.0% sulfur average on a 30-day basis. This change affected SN-19, SN-22, SN-25, and SN-26. The facility is also recalculated both criteria and non-criteria pollutants from many of their permitted sources. This recalculation has resulted in a significant drop in annual permitted rates for most criteria pollutants. Several small, existing sources were added to the permit, which were overlooked in the initial and renewal permits: A and B Side Causticizers (SN-98 and 99), White Liquor Storage Tanks (SN-100), and the 9A and 10A Boiler Bark Transfer systems (SN-101 and SN-102). The facility has also requested to remove the No. 9 Paper Machine sources, SN-84 through SN-92 from the permit. The machine was never installed.

597-AOP-R9 was finalized on April 2, 2007. This revision was to incorporate the provisions of the Health-Based Compliance Alternatives for Manganese for Total Selected Metals (TSM), contained within Appendix A to 40 CFR 63, Subpart DDDDD—National Emission Standards for Hazardous Air Pollutants for Industrial, Commercial, and Institutional Boilers and Process Heaters.

597-AOP-R10 was finalized on April 2, 2007. This PSD revision was submitted for replacement of the economizer section of the 8R Recovery Furnace; installation of steam boxes on Machines 6, 7 and 8; upgrades and changes in the causticizing area; and modifications to the pine and hardwood screen rooms.

597-AOP-R11 was finalized on November 1, 2007. This modification was for the replacement of the No. 6 Tissue Machine Burners (SN-48). The facility replaced the existing Hauck burners with Maxon burners rated at 20.5 MMBTU/hr each. With this revision, the PM/PM_{10} and VOC BACT limits for the No. 6 Tissue Machine decreased. SO_2, CO, NO_x factors and associated BACT limits remained unchanged. In addition to this modification, the Health Based Compliance conditions for the Boiler MACT (NESHAP DDDDD) were removed since that subpart has been vacated.

597-AOP-R12 was finalized on May 5, 2008. This modification was to revise CAM parameters for the 10A (SN-03) and 9A (SN-22) Boilers. The facility, in future testing events, must operate the scrubbers at these sources at the minimum CAM parameters. The facility has also applied for a minor modification to allow for an alternative operating scenario for maintenance on the scrubbers associated with the 10A (SN-03) and 9A (SN-22) Boilers. This condition is similar to the conditions established for monitoring of scrubber parameters on the dust collection systems for the Tissue Machines.

SECTION IV: SPECIFIC CONDITIONS

SN-03
10A Boiler

Source Description

The 10A Boiler is capable of firing woodwaste, refuse derived fuel (RDF), agriculture derived fuel (ADF), tire derived fuel (TDF) and natural gas. A woodwaste storage pile is associated with the 10A Boiler. Woodwaste consists of bark, wood scraps, wax coated paper, wax coated cardboard, wax coated sawdust, creosote treated railroad crossties and paper pellets (waste paper and wax paper). The majority of the woodwaste for the boiler is delivered by truck and occasionally by rail. It is then transferred by conveyors to either the 9A or the 10A woodwaste storage pile.

RDF and ADF are directly added to the chip piles. RDF consists of pelletized paper, lawn clippings and similar materials. TDF and other scrap rubber products are stored in segregated piles near the woodwaste piles. TDF is loaded several times a day by a front end loader into feeder bins in the vicinity. These solid fuels are then fed onto a conveyor system and delivered to the boilers. ADF consists of, but is not limited to, corn cobs, shucks, and vegetable starch.

The 7R Recovery Boiler was originally constructed in 1968. In 1984 it was converted to the 10A Boiler. The 10A Boiler (SN-03) is a 1001 million Btu per hour combination fuel boiler used to generate steam. This boiler is equipped with a wet venturi scrubber.

The 10A Boiler can operate under three different operating scenarios. The boiler can fire up to 1001 million Btu per hour of which only 669 million Btu per hour can be from natural gas. The first fuel firing scenario consists of the 10A Boiler burning just natural gas. The second fuel firing scenario consists of the 10A Boiler burning a combination of fuels none of which is natural gas. The third fuel firing scenario consists of the 10A Boiler burning a combination of fuels of which the contribution of natural gas cannot exceed 669 million Btu per hour.

The 10A boiler is subject to NSPS Subpart D- *Standards of Performance for Fossil-Fuel-Fired Steam Generators for Which Construction is Commenced after August 17, 1971.* Monitoring of NO_X is not required since the results of a performance test showed emissions of less than 70% of the applicable standard (40 CFR 60.45 (b)(3)). Monitoring of SO_2 is not required under 40 CFR 60.45(b)(1). The CO and NO_X emissions from this boiler are regulated under PSD.

Specific Conditions

1. The permittee shall not exceed the emission rates set forth in the following table. Compliance with this Specific Condition shall be demonstrated by compliance with Specific Conditions #14 through #18. [Regulation No. 19 §19.501 et seq. and 40 CFR Part 52, Subpart E]

Pollutant	lb/hr	ton/yr
SO_2	21.0	92.0
VOC	17.1	74.6
Pb	0.06	0.26

2. The permittee shall not exceed the emission rates set forth in the following table. Compliance with this Specific Condition shall be demonstrated by compliance with Specific Conditions #9 and #14 through #18. [§19.304, §19.501 et seq. and §19.901 of Regulation #19, 40 CFR Part 52 Subpart E, and 40 CFR §60.44]

Pollutant	lb/hr	ton/yr
Scenario #1: Natural gas only (669 MMBtu/hr)		
NO_X	133.8	586.1
	0.2 lb/MMBtu	
Scenario #3: Natural gas and any combination of woodwaste, sludge, TDF, RDF & ADF (1001 MMBtu/hr)		
NO_X	300.3	1,315.4
	0.3 lb/MMBtu	

3. The permittee shall not exceed the emission rates set forth in the following table. Compliance with this Specific Condition shall be demonstrated by compliance with Specific Conditions #9 and #14 through #18. [§19.501 et seq. and §19.901 of Regulation #19, and 40 CFR Part 52 Subpart E]

Pollutant	lb/hr	ton/yr
Scenario #1: Natural gas only (669 MMBtu/hr)		
CO	133.8	586.1
	0.2 lb/MMBtu	
Scenario #2: Any combination of woodwaste, sludge, TDF, RDF & ADF (1001 MMBtu/hr)		
NO_X	500.5	2,192.2
	0.5 lb/MMBtu	
CO	600.6	2,630.7
	0.6 lb/MMBtu	
Scenario #3: Natural gas and any combination of woodwaste, sludge, TDF, RDF & ADF (1001 MMBtu/hr)		
CO	600.6	2,630.7
	0.6 lb/MMBtu	

4. The permittee shall not exceed the emission rates set forth in the following table. Compliance with this Specific Condition shall be demonstrated by compliance with Specific Conditions #9, #14 through #18, and #21. [§19.304 and §19.501 et seq. of Regulation #19, 40 CFR Part 52 Subpart E, and 40 CFR §60.42]

Pollutant	lb/hr	ton/yr
Scenario #1: Natural gas only (669 MMBtu/hr)		
PM	66.9	293.1
PM_{10}	0.1 lb/MMBtu	
Scenario #2: Any combination of woodwaste, sludge, TDF, RDF & ADF (1001 MMBtu/hr) Scenario #3: Natural gas and any combination of woodwaste, sludge, TDF, RDF & ADF (1001 MMBtu/hr)		
PM	100.1	438.5
PM_{10}	0.1 lb/MMBtu	

5. The 10A Boiler shall not exceed the emission rates set forth in the following table. Compliance with this Specific Condition shall be demonstrated by compliance with Specific Conditions #14 through #18. [§18.801 of Regulation #18 and A.C.A. §8-4 203 as referenced by §8-4 304 and §8-4 311]

Pollutant	lb/hr	tpy
Acetaldehyde	0.28	1.22
Acetophenone	0.01	0.01
Acetone	0.3	1.1
Acrolein	0.10	0.42
Arsenic	0.01	0.02
Benzene	0.33	1.43
Beryllium	0.01	0.01
Cadmium	0.01	0.01
Carbon Disulfide	0.16	0.69
Carbon Tetrachloride	0.01	0.01
Chloroform	0.05	0.20
Chromium, Hex	0.01	0.04

Pollutant	lb/hr	tpy
Cobalt	0.01	0.01
Cumene	0.03	0.10
2,4-Dinitrotoluene	0.01	0.01
Ethylene Dichloride	0.04	0.16
Formaldehyde	0.86	3.74
Hexane	1.57	6.84
Hexachlorobenzene	0.01	0.01
Hydrogen Chloride	0.19	0.79
Manganese	0.05	0.22
Mercury	0.01	0.01
Methanol	1.04	4.53
Methylene Chloride	0.43	1.85
Naphthalene	0.13	0.53
Nickel	0.01	0.03
Phenol	0.02	0.05
Phosphorus	0.12	0.53
Propionaldehyde	0.08	0.33
Propylene Dichloride	0.04	0.18
POM	0.30	1.30
Selenium	0.01	0.02
Styrene	0.04	0.17
Tetrachloroethylene	0.07	0.28
Toluene	0.04	0.15
Vinyl Chloride	0.03	0.10
Xylene	0.03	0.12

Opacity

6. When operating under any scenario, the permittee shall not cause to be discharged to the atmosphere from the 10A Boiler gases which exhibit opacity greater than 20% except for one six-minute period per hour of not more than 27% opacity. [§19.304 of Regulation #19 and 40 CFR §60.42(a)(2)]

   When operating under Scenario #1, the permittee shall not cause to be discharged to the atmosphere from the 10A Boiler gases which exhibit opacity greater than 5%. [§18.501 of Regulation #18 and A.C.A. §8-4-203 as referenced by §8-4-304 and §8-4-311]

7. The permittee shall conduct weekly observations of the opacity at SN-03. Observations shall be conducted by personnel familiar with the permittee's visible emissions and certified in the EPA Reference Method 9. If visible emissions in excess of the permitted opacity are detected, the permittee shall take immediate action to identify the cause of the visible emissions, implement all necessary corrective action, and reassess the visible emissions after corrective action is taken. The permittee shall maintain records related to all Method 9 Readings, to be updated on a weekly basis. The records shall contain the date and time of each observation/reading, the cause of any observed exceedance of opacity limits, corrective action taken, and results of the reassessment, and the name of the person conducting the observation/reading. The records shall be kept on site and made available to Department personnel upon request. [§19.705 of Regulation 19, Alternative Monitoring exemption of NSPS D, and 40 CFR Part 52, Subpart E]

8. The permittee may, in the event of maintenance on the 10A Boiler (SN-03) scrubber system, continue to operate the boiler without the scrubber for a period of time not to exceed 24 hours. During these events, natural gas will replace all other permitted fuels in the boiler. Woodwaste or any other permitted fuel, with the exception of natural gas, fed to the boiler will be stopped at least one hour before the scrubber is taken offline. If the event lasts longer than 6 hours, a Method 9 opacity reading is required as soon as possible during daylight hours. A log of these maintenance events will be kept which includes date, starting and ending times of event, reason for maintenance, and results of any opacity checks. The permittee shall notify the Department of the event once the scrubber is operational. [§19.703 of Regulation #19, 40 CFR Part 52 Subpart E, and A.C.A. §8-4-203 as referenced by §8-4-304and §8-4-311]

NSPS D

9. The 10A Boiler (SN-03) is subject to and shall comply with all applicable provisions of 40 CFR Part 60 Subpart D- *Standards of Performance for Fossil-Fuel-Fired Steam Generators for Which Construction is Commenced After August 17, 1971*, because it burns natural gas, was constructed after August 17, 1971, and is greater than 250 million Btu per hour.

a. The permittee shall not cause to be discharged into the atmosphere gases which contain particulate matter in excess of 0.10 lb per million Btu derived from gaseous fossil fuel of fossil fuel and wood residue. [§19.304 of Regulation #19 and 40 CFR §60.42(a)(1)]

b. Compliance with the sulfur dioxide standard shall be based on the total heat input from all fossil fuels burned, including gaseous fuels. [§19.304 of Regulation #19 and 40 CFR §60.43(c)]

c. The permittee shall not cause to be discharged into the atmosphere gases which contain nitrogen oxides, expressed as NO_2, in excess of 0.20 lb per million Btu derived from gaseous fossil fuel. [§19.304 of Regulation #19 and 40 CFR §60.44(a)(1)]

d. The permittee shall not cause to be discharged into the atmosphere gases which contain nitrogen oxides, expressed as NO_2, in excess of 0.30 lb per million Btu derived from gaseous fossil fuel and wood residue. [§19.304 of Regulation #19 and 40 CFR §60.44(a)(2)]

e. The permittee shall install, calibrate, maintain, and operate continuous monitoring systems for measuring opacity and either oxygen or carbon dioxide. In an Alternative Monitoring exemption granted by the EPA in 1999, the facility is not required to install a continuous monitoring system for opacity provided the facility conducts periodic testing, scrubber parameter monitoring, and weekly opacity observations. This exemption is included in Appendix F. [§19.304 of Regulation #19 and 40 CFR §60.45(a)]

f. The permittee shall submit excess emission and monitoring system performance reports to the Department for every calendar quarter to the address specified in General Provision 7. All quarterly reports shall be postmarked by the 30th day following the end of each calendar quarter. Each excess emission and MSP report shall include the information required in 40 CFR §60.7(c). [§19.304 of Regulation #19 and 40 CFR §60.45(g)]

g. The permittee shall use as reference methods and procedures the test methods in Appendix A of this part or other methods and procedures as specified in this section, except as provided in 40 CFR §60.8(b) in conducting the performance tests required in 40 CFR §60.8. [§19.304 of Regulation #19 and 40 CFR §60.46(a)]

CEM Requirements

10. The permittee shall operate the Continuous Emission Monitor (CEM) for CO using O_2 monitoring on the 10A Boiler in accordance with the Department Continuous Emission Monitoring Systems Conditions (Appendix A) and the applicable Performance Standards

of 40 CFR Part 60 Appendix B. [§19.703 of Regulation #19, 40 CFR Part 52 Subpart E, and A.C.A. §8-4-203 as referenced by §8-4-304 and §8-4-311]

11. The permittee shall properly maintain and operate the following existing continuous monitoring instrumentation: O_2, pressure drop across the scrubber and the liquid flow rate of the scrubber at the 10A Boiler (SN-03). [§19.703 and §19.901 Regulation #19, 40 CFR Part 52 Subpart E, and A.C.A. §8-4-203 as referenced by §8-4-304 and §8-4-311]

12. All continuous monitoring data for O_2 may, at the discretion of the Department, be used to determine violations of NO_X or CO emissions limits. Continuous monitoring data shall be used to demonstrate compliance with the three different fuel firing scenarios of the 10A Boiler. [§19.703 of Regulation #19, 40 CFR Part 52 Subpart E, and A.C.A. §8-4-203 as referenced by §8-4-304 and §8-4-311]

13. Compliance with the NO_X and CO limits for the 10A Boiler shall be demonstrated by monitoring flue gas O_2 and maintaining the hourly average percent O_2 within the following limits when the steam flow is greater than 100,000 pounds per hour (at actual stack gas moisture contents) and fuel is being fired :

    a. Full load on natural gas and any combination of woodwaste, sludge, RDF, TDF and ADF: not less than 2.0% nor more than 7.5% O_2

    b. Reduced load (100,000 to 400,000 pounds per hour steam) on natural gas and any combination of woodwaste, sludge, RDF, TDF and ADF: not less than 2.2% not more than 8.0% O_2

    c. Full load on gas only: not less than 1.5% nor more than 6.0% O_2

    d. Reduced load (100,000 to 400,000 pounds per hour steam) on gas only: not less than 1.5% nor more than 4.5% O_2

    [§19.703 and §19.901 of Regulation #19, and 40 CFR Part 52 Subpart E]

The above limits for gas shall not apply when firing gas only for periods of two consecutive hours or less due to an unscheduled outage of woodwaste feed, instead, the above limits for natural gas and any combination of woodwaste, sludge, RDF, TDF and ADF shall apply. Records shall be kept of each unscheduled outage. An operation outside of these average limits shall constitute noncompliance with this Specific Condition and shall be reported quarterly along with excess emissions. The permittee shall maintain records of all flue gas O_2 for the 10A Boiler, including those readings which are to be excluded from the hourly average due to steam flow and fuel firing requirements. The permittee shall make these records available to Department personnel upon request.

Fuel Requirements

14. The permittee may use as fuel in the 10A Boiler, TDF, ADF, RDF, woodwaste, sludge, and natural gas. RDF is defined as pelletized paper, lawn clippings, or similar materials. Creosote treated railroad crossties shall not constitute more than 22.5% of the fuel requirement of the 10A Boiler. [§19.705 of Regulation #19, A.C.A. §8-4-203 as referenced by §8-4-304 and §8-4-311, and 40 CFR §70.6]

15. The permittee shall not burn in excess of 669 thousand standard cubic feet (scf) of natural gas per hour and 5860.5 million scf of natural gas per twelve consecutive months in the 10A Boiler (SN-03). [§19.705 of Regulation #19, A.C.A. §8-4-203 as referenced by §8-4-304 and §8-4-311, and 40 CFR §70.6]

16. The permittee shall not burn in excess of 100 pounds of TDF per minute in the 10A Boiler (SN-03). [§19.705 of Regulation #19, A.C.A. §8-4-203 as referenced by §8-4-304 and §8-4-311, and 40 CFR §70.6]

17. The permittee shall not burn in excess of 250 tons of RDF per day in the 10A Boiler. [§19.705 of Regulation #19, A.C.A. §8-4-203 as referenced by §8-4-304and §8-4-311, and 40 CFR §70.6]

18. The permittee shall not burn in excess of 62.5 BDT sludge per hour in the 10A Boiler. [§19.705 of Regulation #19, A.C.A. §8-4-203 as referenced by §8-4-304and §8-4-311, and 40 CFR §70.6]

19. The permittee shall maintain records which demonstrate compliance with Specific Conditions #14, #15, #16, #17, and #18. The permittee shall maintain records of the types and quantities of fuels being used in the 10A Boiler. These records, in combination with the most recent stack tests, shall be sufficient to demonstrate compliance with the three fuel firing scenarios of the 10A Boiler. The records shall be updated on a monthly basis. These records shall be kept on site, provided to Department personnel upon request and may be used by the Department for enforcement purposes. A twelve month total and each month's individual fuel usage data shall be submitted to the Department in accordance with General Provision #7. [§19.705 of Regulation #19 and 40 CFR Part 52 Subpart E]

20. Prior to combustion of the mill's wastewater treatment sludge in the 10A Boiler, the permittee shall submit a notification to the Department concerning the applicability of 40 CFR 61 Subpart E - National Emission Standard for Mercury, and if applicable, submit a permit modification to incorporate the requirements of this subpart into the current Title V Air Permit. [§19.702 of Regulation #19 and 40 CFR Part 52 Subpart E]

CAM

21. The 10A Boiler (SN-03) is subject to and shall comply with all applicable provisions §19.304 of Regulation 19, 40 CFR Part 52 Subpart E, and Part §64.6 for Compliance Assurance Monitoring. Post control of particulate emissions from SN-03 is above major source levels.

    a. The permittee shall maintain a scrubber liquid flow rate of at least gallons 2,572 per minute. [40 CFR Part §64.6(c)(1)]

    b. The permittee shall maintain a gas pressure drop of at least 6.48 inches of water. [40 CFR Part §64.6(c)(1)]

    c. The permittee shall monitor and maintain records at least every 15 minutes of the parameters in Specific Condition #21 (A) and (B). Compliance shall be based upon a 3-hr average. Records shall be kept onsite and made available to the Department upon request. [40 CFR Part §64.6(c)(3)]

    d. The permittee shall maintain the scrubber in good working condition at all times so that pollutant removal is maintained. [40 CFR Part §64.6(c)(1)]

22. The 10A Boiler (SN-03) is subject to and shall comply with all applicable provisions §19.304 of Regulation 19, 40 CFR Part 52 Subpart E, and Part §64.9 for Compliance Assurance Monitoring. The following information pertaining to exceedances or excursions from permitted values shall be submitted in semi-annual reports in accordance with General Provision #7 as outlined in 40 CFR §70.6.

    a. The permittee shall maintain records for SN-03 that summarizes the number, duration, and cause of excursions or exceedances of emission limits as well as corrective action taken. [40 CFR §64.9(a)(2)(i) and §64.9(b)]

    b. The permittee shall maintain records for SN-03 that summarizes the number, duration, and cause of monitoring equipment downtime incidents, other than routine downtime for calibration checks. [40 CFR §64.9(a)(2)(ii) and §64.9(b)]

    c. The permittee shall maintain a quality improvement plan (QIP) threshold for each indicator of no more than nine excursions or 5% of the daily averages in a six-month period. [40 CFR §64.9(a)(2)(iii) and §64.9(b)]

    d. The permittee shall develop and implement a new QIP if the threshold is exceeded during any six-month period. [40 CFR §64.9(a)(2)(iii) and §64.9(b)]

    e. The permittee shall maintain records for SN-03 that describes the actions taken to implement the QIP. Upon completion of the QIP, documentation shall be

maintained to confirm that the plan was completed and reduced the likelihood of similar excursions or exceedances. [40 CFR §64.9(a)(2)(iii) and §64.9(b)]

Testing Requirements

23. The permittee shall annually test particulate matter emissions from the 10A Boiler (SN-03) using EPA Reference Method 5 with inclusion of back half sampling train particulate. The permittee shall test at the minimum scrubber parameters of Specific Condition 21. Results from the Method 5 test shall be compared to the NSPS limit of 0.1 lb/MMBTU for compliance purposes. The testing shall be conducted using a representative fuel mixture. The proportions of each permitted fuel in the representative fuel mixture shall be based upon the month during which the fuel that generates the highest particulate matter emissions was used in greatest proportion. During the test the permittee shall operate the boiler within 10 percent of the rated throughput capacity. If 90 percent of the rated throughout capacity cannot be achieved, the permittee shall be limited to 10 percent over the actual tested throughput. The permittee shall reference this limitation in any compliance reports submitted to the Department. [§19.702 of Regulation #19, Alternative Monitoring exemption of NSPS D, and 40 CFR Part 52 Subpart E]

24. The permittee shall test sulfur dioxide emissions from the 10A Boiler (SN-03) every five years. Testing shall be performed in accordance with Plantwide Condition #3 and EPA Reference Method 6. The testing shall be conducted using the maximum TDF firing rate. During the test the permittee shall operate the boiler within 10 percent of the rated throughput capacity. If 90 percent of the rated throughput capacity cannot be achieved, the permittee shall be limited to 10 percent above the actual tested throughput. The permittee shall reference this limitation in any compliance reports submitted to the Department. [§19.702 of Regulation #19 and 40 CFR Part 52 Subpart E]

SN-18
5A Boiler

Source Description

The 5A Boiler (SN-18) is a 220 million Btu per hour boiler. The boiler is only permitted to burn natural gas. The 5A Boiler was manufactured in 1953 and has never been modified. Therefore it is not subject to NSPS regulations.

Specific Conditions

25. The permittee shall not exceed the emission rates set forth in the following table. Compliance with this Specific Condition shall be demonstrated by compliance with Specific Condition #28. [Regulation No. 19 §19.501 et seq. and 40 CFR Part 52, Subpart E]

Pollutant	lb/hr	tpy
PM_{10}	2.1	8.8
SO_2	0.2	0.7
VOC	1.5	6.4
CO	22.2	97.2
NO_x	74.0	323.8
Pb	0.01	0.01

26. The permittee shall not exceed the emission rates set forth in the following table. Compliance with this Specific Condition shall be demonstrated by compliance with Specific Condition #28. [Regulation No.§18.801 and A.C.A. §8-4-203 as referenced by §8-4-304 and §8-4-311]

Pollutant	lb/hr	tpy
PM	2.1	8.8
Arsenic	0.01	0.01
Benzene	0.01	0.01
Cadmium	0.01	0.01
Cobalt	0.01	0.01
Formaldehyde	0.02	0.09

Pollutant	lb/hr	tpy
Hexane	0.48	2.09
Manganese	0.01	0.01
Mercury	0.01	0.01
Naphthalene	0.01	0.01
Nickel	0.01	0.01
POM	0.01	0.01
Toluene	0.01	0.01

Opacity

27. The permittee shall not cause to be discharged to the atmosphere from the 5A Boiler gases which exhibit opacity greater than 5%. Compliance with this opacity limit shall be the use of natural gas only. [§18.501 of Regulation #18 and A.C.A. §8-4-203 as referenced by §8-4-304 and §8-4-311]

Fuel Requirements

28. Natural gas may only be used as fuel in the 5A Boiler. [§18.1004 of Regulation #18, §19.705 of Regulation #19, A.C.A. §8-4-203 as referenced by §8-4-304 and §8-4-311, and 40 CFR §70.6]

SN-19
6A Boiler

Source Description

The 6A Boiler (SN-19) is a 357 million Btu per hour boiler. The 6A Boiler was manufactured in 1962 and has never been modified. Therefore it is not subject to NSPS regulations. The 6A Boiler can use natural gas as fuel.

Specific Conditions

29. The permittee shall not exceed the emission rates set forth in the following table. Compliance with this Specific Condition shall be demonstrated by compliance with Specific Condition #32. [Regulation No. 19 §19.501 et seq. and 40 CFR Part 52, Subpart E]

Pollutant	lb/hr	tpy
PM_{10}	3.3	14.3
SO_2	0.3	1.2
VOC	2.4	10.4
CO	36.0	157.7
NO_x	120.0	525.4
Pb	0.01	0.01

30. The permittee shall not exceed the emission rates set forth in the following table. Compliance with this Specific Condition shall be demonstrated by compliance with Specific Condition #32. [Regulation No. §18.801and A.C.A. §8-4-203 as referenced by §8-4-304 and §8-4-311]

Pollutant	lb/hr	tpy
PM	3.3	14.3
Arsenic	0.01	0.01
Benzene	0.01	0.01
Cadmium	0.01	0.01
Cobalt	0.01	0.01
Formaldehyde	0.04	0.15

Pollutant	lb/hr	tpy
Hexane	0.78	3.38
Manganese	0.01	0.01
Mercury	0.01	0.01
Naphthalene	0.01	0.01
Nickel	0.01	0.01
POM	0.01	0.01
Toluene	0.01	0.01

Opacity

31. The permittee shall not cause to be discharged to the atmosphere from the 6A Boiler gases which exhibit opacity greater than 5%. Compliance with this opacity limit shall be the use of natural gas only. [§18.501 of Regulation #18 and A.C.A. §8-4-203 as referenced by §8-4-304 and §8-4-311]

Fuel Requirements

32. Natural gas may only be used as fuel in the 6A Boiler. [§18.1004 of Regulation #18, §19.705 of Regulation #19, A.C.A. §8-4-203 as referenced by §8-4-304 and §8-4-311, and 40 CFR §70.6]

SN-22
9A Boiler

Source Description

The 9A Boiler is a 720 million Btu per hour combination fuel boiler used to generate steam. The source is equipped with a wet venturi scrubber. The boiler may serve as backup combustion unit during times when the incinerator (SN-83) is offline.

The 9A Boiler is capable of firing tire derived fuel (TDF), agriculture derived fuel (ADF), refuse derived fuel (RDF), non-condensable gases (NCGs), woodwaste, specification grade oil, natural gas and sludge. A woodwaste storage pile is associated with the 9A Boiler. Woodwaste consists of bark, wood scraps, wax coated paper, wax coated cardboard, wax coated sawdust, creosote treated railroad crossties and paper pellets (waste paper and wax paper). Bark from the debarker in the Woodyard is pneumatically transferred to the 9A pile. A cyclone is located at the end of the pneumatic transfer line to control particulate matter emissions. The majority of the woodwaste is delivered by truck and occasionally by rail. It is then transferred by conveyors to either the 9A or the 10A woodwaste storage pile.

RDF, ADF and sludge are directly added to the chip piles. RDF consists of pelletized paper, lawn clippings and similar materials. TDF and other scrap rubber products are stored in segregated piles near the woodwaste piles. TDF is loaded several times a day by a front end loader into feeder bins in the vicinity. These solid fuels are then fed onto a conveyor system and delivered to the boilers. ADF consists of, but is not limited to, corn cobs, shucks, and vegetable starch.

Specification grade oil consists of new oil, used oil, used oil absorbent material and pitch from the production of tall oil. Used oil absorbent material shall include used oil filter paper, used rags, sorbant booms, etc. that meet the specification grade oil criteria (40 CFR 279.11).

Specific Conditions

33. The permittee shall not exceed the emission rates set forth in the following table. Compliance with this Specific Condition shall be demonstrated by compliance with Specific Conditions #43, #47, #48, #49, #50, and #52. [Regulation No. 19 §19.501 et seq. and 40 CFR Part 52, Subpart E]

Pollutant	lb/hr	tpy
PM_{10}	75.8	243.3
SO_2	502.5	1,361.6
VOC	11.4	49.6
CO	366.9	1,606.7

Pollutant	lb/hr	tpy
NO_x	218.0	954.7
Pb	0.04	0.14

34. The permittee shall not exceed the emission rates set forth in the following table. Compliance with this Specific Condition shall be demonstrated by compliance with Specific Conditions #43, #47, #48, #49, #50, and #52. [Regulation No. §18.801 and A.C.A. §8-4-203 as referenced by §8-4-304 and §8-4-311]

Pollutant	lb/hr	tpy
PM	75.8	243.3
Acetaldehyde	0.14	0.58
Acetophenone	0.01	0.01
Acetone	0.2	0.5
Acrolein	0.05	0.20
Arsenic	0.01	0.03
Benzene	0.16	0.68
Beryllium	0.01	0.01
Cadmium	0.01	0.01
Carbon Disulfide	0.08	0.33
Carbon Tetrachloride	0.01	0.01
Chloroform	0.03	0.10
Chromium, Hex	0.01	0.02
Cobalt	0.02	0.06
Cumene	0.02	0.05
2,4-Dinitrotoluene	0.01	0.01
Ethylene Dichloride	0.02	0.08
Formaldehyde	0.47	2.06
Hexane	1.56	6.82
Hexachlorobenzene	0.01	0.01

Pollutant	lb/hr	tpy
Hydrogen Chloride	0.13	0.57
Manganese	0.03	0.13
Mercury	0.01	0.01
Methanol	0.50	2.15
Methylene Chloride	0.20	0.88
Naphthalene	0.06	0.26
Nickel	0.18	0.75
Phenol	0.01	0.03
Phosphorus	0.08	0.33
Propionaldehyde	0.04	0.16
Propylene Dichloride	0.02	0.09
POM	0.15	0.63
SAM	16.8	48.9
Selenium	0.01	0.02
Styrene	0.02	0.08
Tetrachloroethylene	0.03	0.13
Toluene	0.03	0.13
Vinyl Chloride	0.02	0.05
Xylene	0.02	0.06

Opacity

35. For all fuel scenarios except natural gas only, the permittee shall not cause to be discharged to the atmosphere from the 9A Boiler, gases which exhibit opacity greater than 20%. Emissions not exceeding 60% opacity will be allowed for six (6) minutes in any consecutive 60-minute period and no more three (3) times during any 24-hour period. [§19.503 of Regulation #19 and 40 CFR Part 52 Subpart E]

When operating using natural gas only, the permittee shall not cause to be discharged to the atmosphere from the 9A Boiler gases which exhibit opacity greater than 5%. Compliance with this limit shall be use of natural gas only. [§18.501 of Regulation #18 and A.C.A. §8-4-203 as referenced by §8-4-304 and §8-4-311]

36. For all fuel scenarios except natural gas only, the permittee shall conduct daily observations of the opacity at SN-22. Observations shall be conducted by personnel familiar with the permittee's visible emissions. If visible emissions in excess of the permitted opacity are detected, then a Method 9 reading is required. The permittee shall then take immediate action to identify the cause of the visible emissions, implement all necessary corrective action, and reassess the visible emissions after corrective action is taken. The permittee shall maintain records related to all observations/readings, to be updated on a daily basis. The records shall contain the date and time of each observation/reading, the cause of any observed exceedance of opacity limits, corrective action taken, and results of the reassessment, and the name of the person conducting the observation/reading. The records shall be kept on site and made available to Department personnel upon request. [§19.705 of Regulation 19 and 40 CFR Part 52, Subpart E]

37. SN-22, as a wood fired boiler, shall meet all visible emissions of this chapter except that visible emissions may exceed the permitted opacity for up to 45 minutes once in any consecutive 8 hour period, three times in any consecutive 24 hour period for soot blowing, grate cleaning, ash raking, and refiring necessary for proper operation of these units. This practice is to be scheduled for the same specific time each day and shall be recorded. The Department shall be notified in advance and in writing of the schedule or any changes. The process of soot blowing, grate cleaning, ash raking, and refiring or any part thereof is considered one activity and the time limit on this activity is 45 minutes. [§18.501(A)(4) of Regulation #18 and A.C.A. §8-4-203 as referenced by §8-4-304and §8-4-311]

38. The permittee may, in the event of maintenance on the 9A Boiler (SN-22) scrubber system, continue to operate the boiler without the scrubber for a period of time not to exceed 24 hours. During these events, natural gas will replace all other fuels in the boiler. Woodwaste or any other permitted fuel, with the exception of natural gas, fed to the boiler will be stopped at least one hour before the scrubber is taken offline. If the event lasts longer than 6 hours, a Method 9 opacity reading is required as soon as possible during daylight hours. A log of these maintenance events will be kept which includes date, starting and ending times of event, reason for maintenance, and results of any opacity checks. The permittee shall notify the Department of the event once the scrubber is operational. [§19.703 of Regulation #19, 40 CFR Part 52 Subpart E, and A.C.A. §8-4-203 as referenced by §8-4-304 and §8-4-311]

CEM Requirements

39. The Continuous Emission Monitor (CEM) for CO using O_2 monitoring on the 9A Boiler shall be operated in accordance with the Department Continuous Emission Monitoring Systems Conditions (Appendix A) and the applicable Performance Standards of 40 CFR Part 60 Appendix B. [§19.703 of Regulation #19, 40 CFR Part 52 Subpart E, and A.C.A. §8-4-203 as referenced by §8-4-304and §8-4-311]

40. The permittee shall properly maintain and operate the following existing continuous monitoring instrumentation: O_2, pressure drop across the scrubber and liquid supply flow at the 9A Boiler. [§19.703 of Regulation #19, 40 CFR Part 52 Subpart E, and A.C.A. §8-4-203 as referenced by §8-4-304and §8-4-311]

41. Continuous monitoring data from the continuous monitoring instrumentation listed in Specific Condition #40 may, at the discretion of the Department, be used to determine violations of the emissions limits or conditions of this permit. [§19.703 of Regulation #19, 40 CFR Part 52 Subpart E, and A.C.A. §8-4-203 as referenced by §8-4-304 and §8-4-311]

42. Compliance with the CO limit for the 9A Boiler shall be demonstrated by monitoring flue gas O_2 and maintaining the O_2 setpoint at not less than 2.0% O_2 (dry basis). Any operation outside this hourly average limit shall constitute noncompliance with this Specific Condition. The permittee shall maintain records of flue gas O_2 for the 9A Boiler and shall make them available to Department personnel upon request. These limits do not apply during startup and shutdown of the 9A Boiler. Startup and shutdown shall be defined as when the steam flow is less than 100,000 pounds per hour. [§19.703 of Regulation #19, 40 CFR Part 52 Subpart E, and A.C.A. §8-4-203 as referenced by §8-4-304 and §8-4-311]

CAM

43. The 9A Boiler (SN-22) is subject to and shall comply with all applicable provisions §19.304 of Regulation 19, 40 CFR Part 52 Subpart E, and Part §64.6 for Compliance Assurance Monitoring. Post control of particulate emissions from SN-22 is above major source levels.

    a. The permittee shall maintain a scrubber liquid flow rate of at least 2,772 gallons per minute. [40 CFR Part §64.6(c)(1)]

    b. The permittee shall maintain a gas pressure drop of at least 9.16 inches of water. [40 CFR Part §64.6(c)(1)]

    c. The permittee shall monitor and maintain records at least every 15 minutes of the parameters in Specific Condition #43 (A) and (B). Compliance shall be based upon a 3-hr average. Records shall be kept onsite and made available to the Department upon request. [40 CFR Part §64.6(c)(3)]

    d. The permittee shall maintain the scrubber in good working condition at all times so that pollutant removal is maintained. [40 CFR Part §64.6(c)(1)]

44. The 9A Boiler (SN-22) is subject to and shall comply with all applicable provisions §19.304 of Regulation 19, 40 CFR Part 52 Subpart E, and Part §64.9 for Compliance Assurance Monitoring. The following information pertaining to exceedances or

excursions from permitted values shall be submitted in semi-annual reports in accordance with General Provision 7 as outlined in 40 CFR §70.6.

a. The permittee shall maintain records for SN-22 that summarizes the number, duration, and cause of excursions or exceedances of emission limits as well as corrective action taken. [40 CFR §64.9(a)(2)(i) and §64.9(b)]

b. The permittee shall maintain records for SN-22 that summarizes the number, duration, and cause of monitoring equipment downtime incidents, other than routine downtime for calibration checks. [40 CFR §64.9(a)(2)(ii) and §64.9(b)]

c. The permittee shall maintain a quality improvement plan (QIP) threshold for each indicator of no more than nine excursions or 5% of the daily averages in a six-month period. [40 CFR §64.9(a)(2)(iii) and §64.9(b)]

d. The permittee shall develop and implement a new QIP if the threshold is exceeded during any six-month period. [40 CFR §64.9(a)(2)(iii) and §64.9(b)]

e. The permittee shall maintain records for SN-22 that describes the actions taken to implement the QIP. Upon completion of the QIP, documentation shall be maintained to confirm that the plan was completed and reduced the likelihood of similar excursions or exceedances. [40 CFR §64.9(a)(2)(iii) and §64.9(b)]

Fuel Requirements

45. The permittee may use the 9A Boiler as an alternate incinerator for NCGs and SOGs only during periods when the Incinerator (SN-83) or its associated control equipment is inoperative or undergoing maintenance. [§19.304 of Regulation #19 and 40 CFR §63.443(d)(4)]

46. Specification grade oils, natural gas, woodwaste, TDF, ADF, RDF and wastewater sludge may be used as fuel in the 9A Boiler. RDF is defined as pelletized paper, lawn clippings or other similar materials. Creosote treated railroad crossties shall not constitute more than 25% of the fuel requirement of the 9A Boiler. [§18.1004 of Regulation #18, §19.705 of Regulation #19, A.C.A. §8-4-203 as referenced by §8-4-304 and §8-4-311, and 40 CFR §70.6]

47. The permittee shall not burn in excess of 35 pounds per minute of TDF in the 9A Boiler. [§18.1004 of Regulation #18, §19.705 of Regulation #19, A.C.A. §8-4-203 as referenced by §8-4-304 and §8-4-311, and 40 CFR §70.6]

48. The permittee shall not burn in excess of 250 tons of RDF per day in the 9A Boiler. [§18.1004 of Regulation #18, §19.705 of Regulation #19, A.C.A. §8-4-203 as referenced by §8-4-304and §8-4-311, and 40 CFR §70.6]

49. The permittee shall not burn in excess of 45 BDT sludge per hour in the 9A Boiler. [§19.705 of Regulation #19, A.C.A. §8-4-203 as referenced by §8-4-304and §8-4-311, and 40 CFR §70.6]

50. The permittee shall not burn in excess of 200 tons of used oil absorbent material per month in the 9A Boiler. The used oil absorbent material shall meet the specification grade oil criteria found in 40 CFR §279.11. [§18.1004 of Regulation #18, §19.705 of Regulation #19, A.C.A. §8-4-203 as referenced by §8-4-304and §8-4-311, and 40 CFR §70.6]

51. The permittee shall maintain records which demonstrate compliance with Specific Conditions #46, #47, #48, #49, and #50. The records shall be updated on a monthly basis. These records shall be kept on site, provided to Department personnel upon request and may be used by the Department for enforcement purposes. A twelve month total and each individual month's data shall be submitted in accordance with General Provision #7. [§18.1004 of Regulation #18, §19.705 of Regulation #19, 40 CFR Part 52 Subpart E, and A.C.A. §8-4-203 as referenced by §8-4-304and §8-4-311]

52. The sulfur content of the specification grade oils shall not exceed 1.5% by weight and 1.0% on a 30-day average. [§19.705 of Regulation #19, A.C.A. §8-4-203 as referenced by §8-4-304 and §8-4-311, and 40 CFR §70.6]

53. Sulfur dioxide emission shall be determined through a mass balance based on incoming materials, worst-case firing of specification grade oil based on the limits in Condition #52, and periods where the source is used as an alternate incinerator. This mass balance shall be submitted to the Department in accordance with General Provision #7. [§19.703 of Regulation #19, 40 CFR Part 52 Subpart E, and A.C.A. §8-4-203 as referenced by §8-4-304 and §8-4-311]

54. Prior to combustion of the mill's wastewater treatment sludge in the 9A Boiler, the permittee shall submit a notification to the Department concerning the applicability of 40 CFR 61 Subpart E - National Emission Standard for Mercury, and if applicable, submit a permit modification to incorporate the requirements of this subpart into the current Title V Air Permit. [§19.702 of Regulation #19 and 40 CFR Part 52 Subpart E]

Testing Requirements

55. The permittee shall test particulate matter emissions from the 9A Boiler (SN-22) using EPA Reference Method 5 with inclusion of back half sampling train particulate every five years. The permittee shall test at the minimum scrubber parameters of Specific Condition 43. The permittee shall submit an application to correct emission rates, if corrections are necessary. The testing shall be conducted using a representative fuel mixture. The proportions of each permitted fuel in the representative fuel mixture shall be based upon the month during which the fuel that generates the highest particulate matter emissions was used in greatest proportion. During the test the permittee shall operate the boiler within 10 percent of the rated throughput capacity. If 90 percent of the

rated throughout capacity cannot be achieved, the permittee shall be limited to 10 percent above the actual tested throughput. The permittee shall reference this limitation in any compliance reports submitted to the Department. [§18.1002 of Regulation #18, §19.702 of Regulation #19, 40 CFR Part 52 Subpart E, and A.C.A. §8-4-203 as referenced by §8-4-304 and §8-4-311]

56. The permittee shall test nitrogen oxides emissions from the 9A Boiler (SN-22) every five years. Testing shall be performed in accordance with Plantwide Condition #3 and EPA Reference Method 7E as found in 40 CFR Part 60 Appendix A. The testing shall be done using a representative fuel mixture. The proportions of each permitted fuel in the representative fuel mixture shall be based upon the month during which the fuel that generates the highest nitrogen oxides emissions was used in greatest proportion. During the test the permittee shall operate the boiler within 10 percent of the rated throughput capacity. If 90 percent of the rated throughout capacity cannot be achieved, the permittee shall be limited to 10 percent above the actual tested throughput. The permittee shall reference this limitation in any compliance reports submitted to the Department. [§19.702 of Regulation #19 and 40 CFR Part 52 Subpart E]

57. The permittee shall test sulfur dioxide emissions from the 9A Boiler (SN-22) every five years. Testing shall be performed in accordance with Plantwide Condition #3 and EPA Reference Method 6. The testing shall be conducted using the maximum TDF firing rates. During the test the permittee shall operate the boiler within 10 percent of the rated throughput capacity. If 90 percent of the rated throughout capacity cannot be achieved, the permittee shall be limited to 10 percent above the actual tested throughput. The permittee shall reference this limitation in any compliance reports submitted to the Department. [§19.702 of Regulation #19 and 40 CFR Part 52 Subpart E]

SN-57F, 58F, 101, and 102
Woodyard

Source Description

Activities in the Woodyard include unloading incoming chips and wood, wood transferring, debarking (SN-57F), chipping (SN-58F), chip storage (SN-58F) and chip screening. Emissions are controlled by the use of water sprays.

Chips are delivered either by trucks or rail cars. The truck shipments are unloaded at an inclining truck dump. The rail car shipments are emptied by rolling the rail car over. From these two delivery points the chips are conveyed to the distribution tower and are then dropped into the chip piles. Water is added to the pneumatic transfer system to control dust.

In addition to chips, Georgia-Pacific also receives round logs. After storage, the logs are transported to the debarking drum for bark removal. The removed bark is pneumatically sent to the bark piles for storage and eventual use in the 9A and 10A Boilers of the Utilities Operations. The debarked logs are fed to the chipper. The chips that are produced are conveyed to the distribution tower and deposited onto the chip piles.

Chips from the chip piles are screened prior to entering the chip silo. Rejected chips from the screening process are sent to the combination boilers for use in steam production.
Bark either purchased or from the Woodyard is transferred by enclosed conveyors to the 9A and 10A Boilers' associated fuel storage piles. Emissions for these sources are calculated using drop transfer points.

As a part of the R10 modification, some existing pine screen and hardwood screen room equipment were replaced with new more efficient equipment. The changes are to improve chip thickness and quality by removing a larger quantity of fines and contaminants from the wood chips prior to the pulp mill. BACT for SN-58F is the use of a totally enclosed building for the new pine and hardwood screen room equipment.

Specific Conditions

58. The permittee shall not exceed the emission rates set forth in the following table. Compliance with this Specific Condition shall be demonstrated by compliance with Specific Conditions 61 and 63. [Regulation No. 19 §19.501 et seq. and 40 CFR Part 52, Subpart E]

SN	Description	Pollutant	lb/hr	ton/yr
57F	Woodyard Debarking Drum and Associated Woodyard Chip Handling System	PM_{10} VOC	0.1 410.9	0.1 1,799.4

SN	Description	Pollutant	lb/hr	ton/yr
101	10A Boiler Bark Transfer System	PM_{10}	0.1	0.2
102	9A Boiler Bark Transfer System	PM_{10}	0.1	0.1

59. The permittee shall not exceed the emission rates set forth in the following table. Compliance with this Specific Condition shall be demonstrated by compliance with Specific Conditions 61 and 63. [Regulation No. 19 §19.501 et seq., 19.901, and 40 CFR Part 52, Subpart E]

SN	Description	Pollutant	lb/hr	ton/yr
58F	Woodyard Chip Storage Piles & Chippers	PM/PM_{10}	1.1	4.5

60. The permittee shall not exceed the emission rates set forth in the following table. Compliance with this Specific Condition shall be demonstrated by compliance with Specific Conditions 61 and 63. [Regulation No. §18.801 and A.C.A. §8-4-203 as referenced by §8-4-304 and §8-4-311]

SN	Description	Pollutant	lb/hr	ton/yr
57F	Woodyard Debarking Drum and Associated Woodyard Chip Handling System	PM	0.1	0.2
101	10A Boiler Bark Transfer System	PM	0.1	0.3
102	9A Boiler Bark Transfer System	PM	0.1	0.2

Throughput Requirements

61. The permittee shall not process in excess of 8,400 tons of wet wood as received in the Woodyard per day, 30 day rolling average. [§18.1004 of Regulation #18, §19.705 of Regulation #19, A.C.A. §8-4-203 as referenced by §8-4-304 and §8-4-311, and 40 CFR §70.6]

62. The permittee shall maintain records which demonstrate compliance with the limit in Specific Condition #61. The records shall be updated on a monthly basis. These records shall be kept on site, provided to Department personnel upon request and may be used by the Department for enforcement purposes. A twelve month total and each individual month's data shall be submitted in accordance with General Provision #7. [§18.1004 of

Regulation #18, §19.705 of Regulation #19, 40 CFR Part 52 Subpart E, and A.C.A. §8-4-203 as referenced by §8-4-304 and §8-4-311]

Dust Suppression

63. The permittee shall use water sprays in the discharge from the conveyance system in the Woodyard area to reduce particulate matter emissions except during periods when rain provides equivalent dust suppression, or when inclement weather creates a safety hazard to operators. [§19.303 of Regulation #19 and A.C.A. §8-4-203 as referenced by §8-4-304 and §8-4-311]

SN-59
Batch Digesters

Source Description

Chips from the Woodyard are sent to the pulp mill where they are converted to pulp using the chemical Kraft process. The chip conveying system regulates the flow of chips from the silos in the Woodyard to one of the thirteen batch digesters (SN-59). The function of the digesters is to cook chips using white liquor, black liquor and steam from the boilers. In the digestion process these products are combined and cooked at a set pressure and temperature until a quality pulp is obtained. At the end of each cook the blow valve at the bottom of the digester is opened. The pressure in the digester forces the pulp mass through a blow line into the blow tanks.

The mill has two large cylindrical blow tanks. All remaining process equipment in the Pulp Mill is divided into two parallel but separate lines. The blow tanks are at atmospheric pressure. When the chips hit the lower pressure in the tank, the liquor and water flash, blowing apart the chips to produce the pulp fibers. The fibers and the spent cooking liquor fall to the bottom of the blow tank.

The vapors from the blow tanks exit through a vapor line at the top of each blow tank. The vapors from each tank are combined and sent to the blow heat condensing system. Flow to the condensing system is maintained in the absence of blow downs by steam supplements. There is a series of condensers that remove condensable gases (primarily turpentine) from the blow gas. The steam vapors are condensed in the accumulator tank and used as hot water for the washers. Gases that do not condense are sent to the Incinerator (primary) or the Lime Kiln (backup) for thermal destruction.

The operation of the digesters during the cooking time is subject to NSPS Subpart BB. However, during the time that chips are loaded into the digesters (the digester caps are opened allowing any displaced fugitive emissions to be emitted to the atmosphere), the Subpart BB rules are not applicable since only residual quantities of TRS gases remain in the digester after this activity is completed.

In 597-AOP-R8, the facility underwent PSD review in order to modify nine of their Digesters (SN-59), replacing the six-inch blow valves with eight-inch valves. All six hardwood pulp digesters were modified, along with one "swing" pulp digester (used for either hardwood or softwood) and two softwood pulp digesters. BACT for VOC was determined to be combustion of the digester gases in an incinerator, SN-83. Emissions here are fugitives from the opening of the digesters to load chips.

Specific Conditions

64. The permittee shall not exceed the emission rates set forth in the following table. Compliance with this Specific Condition shall be demonstrated by compliance with

Specific Condition #68. [Regulation No. 19 §19.501 et seq. and 40 CFR Part 52, Subpart E]

Pollutant	lb/hr	tpy
VOC	5.3	23.1

65. The permittee shall not exceed the emission rates set forth in the following table. Compliance with this Specific Condition shall be demonstrated by compliance with Specific Condition #68. [§19.304 and §19.501 et seq. of Regulation #19, 40 CFR Part 52 Subpart E]

Pollutant	lb/hr	ton/yr
TRS	0.9	3.9

66. The permittee shall not exceed the emission rates set forth in the following table. Compliance with this Specific Condition shall be demonstrated by compliance with Specific Condition #68. [Regulation No. §18.801 and A.C.A. §8-4-203 as referenced by §8-4-304 and §8-4-311]

Pollutant	lb/hr	tpy
Acetaldehyde	0.12	0.52
Acetone	0.2	0.8
Acrolein	0.01	0.01
Benzene	0.01	0.01
Carbon Tetrachloride	0.02	0.05
Chloroform	0.12	0.52
Ethylene Dichloride	0.01	0.01
Formaldehyde	0.01	0.01
Hexane	0.01	0.03
Methanol	2.11	9.21
Styrene	0.02	0.07
Tetrachloroethylene	0.01	0.01
Toluene	0.02	0.06

Pollutant	lb/hr	tpy
Xylene	0.01	0.02

NSPS BB

67. The Batch Digesters (SN-59) are subject to and shall comply with all applicable provisions of §19.304 of Regulation 19 and 40 CFR Part 60 BB - *Standards of Performance for Kraft Pulp and Paper Mills.* The Incinerator (SN-83) satisfies the requirements under §60.283(a)(1)(iii). A copy of Subpart BB is provided in Appendix C.

a. The permittee shall not cause to be discharged into the atmosphere from the digester system any gases which contain TRS in excess of 5 ppm by volume on a dry basis, corrected to 10 percent oxygen, unless the conditions of 40 CFR §60.283(a)(1)(i)-(vi) are met. [§19.304 of Regulation 19 and 40 CFR §60.283(a)(1)]

b. The permittee shall install, calibrate, maintain, and operate a continuous monitoring system to monitor and record the concentration of TRS emissions on a dry basis and the percent of oxygen by volume on a dry basis in the gases discharged into the atmosphere from the digester system, except where the provisions of 40 CFR §60.283(a)(1)(iii) or (iv) apply. This system shall be located downstream of the control device and the span shall be set at a TRS concentration of 30 ppm for the TRS continuous monitoring system and at 25 percent oxygen for the continuous oxygen monitoring system. [§19.304 of Regulation 19 and 40 CFR §60.284(a)(2)]

c. The permittee shall calculate and record on a daily basis 12-hour average TRS concentrations for the two consecutive periods of each operating day. Each 12-hour average shall be determined as the arithmetic mean of the appropriate 12 contiguous 1-hour average total reduced sulfur concentrations provided by each continuous monitoring system installed under paragraph (a)(2) of this section. [§19.304 of Regulation 19 and 40 CFR §284(c)(1)]

d. For the purpose of reports required under 40 CFR §60.7(c), the permittee shall report semiannually periods of excess emissions where 60.284(c)(3)(i) and (ii) apply. The applicant must also report the nature and cause of the excess emissions in accordance with 40 CFR §60.7(c)(2). Excess emission reports shall be submitted to the address in General Provision 7. [§19.304 of Regulation 19 and 40 CFR§60.284(d)]

e. The permittee shall use as reference methods and procedures the test methods in appendix A of this part or other methods and procedures in this section, except as provided in 40 CFR §60.8(b). Acceptable alternative methods and procedures are

given in paragraph (f) of this section. [§19.304 of Regulation 19 and 40 CFR §60.285(a]

Recordkeeping

68. The permittee shall not process in excess of 8,757 tons of wood chips per day, 30 day rolling average. [§19.705 of Regulation #19, A.C.A. §8-4-203 as referenced by §8-4-304 and §8-4-311, and 40 CFR §70]

69. The permittee shall maintain records which demonstrate compliance with the limits specified in Specific Condition #68. The records shall be updated on a monthly basis. These records shall be kept on site, provided to Department personnel upon request and may be used by the Department for enforcement purposes. A rolling twelve month total and each individual month's data shall be submitted in accordance with General Provision #7. [§19.705 of Regulation #19 and 40 CFR Part 52 Subpart E]

SN-33, 34, 60 and 61
Pulp Mill Operations

Source Description

When the pulp and black liquor exit the blow tank, the pulp goes through several processing steps before it is stored in the unbleached high density storage chest. First, knots are removed prior to washing. The knots are recovered and used as woodwaste fuel. Second, the pulp is washed to separate the pulp from the spent cooking chemicals and the black liquor. There are two horizontal washers. The emissions from the associated black liquor storage tank and Line 1 Decker (SN-60) are routed to the Incinerator (SN-83) with the 9A Boiler (SN-22) operating as a backup control device. Next, the pulp passes through the decker system. The decker system (SN-60 and 61) thickens the pulp for storage in the high density storage chests. Although the operations at the pulp mill are in parallel, the two lines are run separately.

Specific Conditions

70. The permittee shall not exceed the emission rates set forth in the following table. Compliance with this Specific Condition shall be demonstrated by compliance with Specific Conditions #77. [Regulation No. 19 §19.501 et seq. and 40 CFR Part 52, Subpart E]

SN	Description	Pollutant	lb/hr	ton/yr
33	Line 1 Washer	VOC	7.5	28.4
		TRS	2.1	7.9
34	Line 2 Washer	VOC	7.5	28.4
		TRS	2.1	7.9
60	Line 1 Decker	Routed to the Incinerator (SN-83)		
61	Line 2 Decker	VOC	4.5	16.9
		TRS	2.1	7.7

71. The permittee shall not exceed the emission rates set forth in the following table. Compliance with this Specific Condition shall be demonstrated by compliance with Specific Condition #77. [Regulation No. §18.801 and A.C.A. §8-4-203 as referenced by §8-4-304 and §8-4-311]

SN	Description	Pollutant	lb/hr	ton/yr
33	Line 1 Washer	Acetaldehyde	0.10	0.35
		Acetone	0.3	0.8
		Acetophenone	0.21	0.79
		Acrolein	0.01	0.02
		Benzene	0.01	0.02
		Carbon Tetrachloride	0.03	0.09

SN	Description	Pollutant	lb/hr	ton/yr
		Carbonyl Sulfide	0.07	0.25
		Chloroform	0.01	0.01
		Cresol	0.34	1.29
		Ethylene Dichloride	0.01	0.03
		Formaldehyde	0.01	0.01
		Hexane	0.01	0.03
		Methanol	4.66	17.69
		Methylene Chloride	0.01	0.01
		Phenol	0.37	1.40
		Styrene	0.01	0.04
		Tetrachloroethylene	0.04	0.15
		Toluene	0.02	0.05
		1,2,4-Trichlorobenzene	0.02	0.08
		Xylene	0.01	0.02
34	Line 2 Washer	Acetaldehyde	0.10	0.35
		Acetone	0.3	0.8
		Acetophenone	0.21	0.79
		Acrolein	0.01	0.02
		Benzene	0.01	0.02
		Carbon Tetrachloride	0.03	0.09
		Carbonyl Sulfide	0.07	0.25
		Chloroform	0.01	0.01
		Cresol	0.34	1.29
		Ethylene Dichloride	0.01	0.03
		Formaldehyde	0.01	0.01
		Hexane	0.01	0.03
		Methanol	4.66	17.69
		Methylene Chloride	0.01	0.01
		Phenol	0.37	1.40
		Styrene	0.01	0.04
		Tetrachloroethylene	0.04	0.15
		Toluene	0.02	0.05
		1,2,4-Trichlorobenzene	0.02	0.08
		Xylene	0.01	0.02
61	Line 2 Decker	Acetaldehyde	0.33	1.23
		Acetone	0.5	1.8
		Acrolein	0.01	0.02
		Benzene	0.01	0.01
		Carbon Tetrachloride	0.02	0.07
		Chloroform	0.13	0.49
		Cresol	1.56	5.90

SN	Description	Pollutant	lb/hr	ton/yr
		Formaldehyde	0.09	0.33
		Methanol	2.02	7.65
		Propionaldehyde	0.10	0.35
		Styrene	0.02	0.06
		Tetrachloroethylene	0.04	0.15
		Toluene	0.01	0.02
		1,2,4-Trichlorobenzene	0.11	0.40
		Xylene	0.02	0.05

NSPS BB

72. The Line 1 Washer (SN-33) and the Line 2 Washer (SN-34) are subject to and shall comply with all applicable provisions of §19.304 of Regulation 19 and 40 CFR Part 60 Subpart BB - *Standards of Performance for Kraft Pulp and Paper Mills*. The Incinerator (SN-83) satisfies the requirements under §60.283(a)(1)(iii). A copy of Subpart BB is provided in Appendix C.

a. The permittee shall not cause to be discharged into the atmosphere from SN-33 and SN-34 any gases which contain TRS in excess of 5 ppm by volume on a dry basis, corrected to 10 percent oxygen, unless the conditions of 40 CFR §60.283(a)(1)(i)-(vi) are met. [§19.304 of Regulation #19 and 40 CFR §60.283(a)(1)]

b. The permittee shall install, calibrate, maintain, and operate a continuous monitoring system to monitor and record the concentration of TRS emissions on a dry basis and the percent of oxygen by volume on a dry basis in the gases discharged into the atmosphere from SN-33 and SN-34, except where the provisions of 40 CFR §60.283(a)(1)(iii) or (iv) apply. This system shall be located downstream of the control device and the span shall be set at a TRS concentration of 30 ppm for the TRS continuous monitoring system and at 25 percent oxygen for the continuous oxygen monitoring system. [§19.304 of Regulation #19 and 40 CFR §60.284(a)(2)]

c. The permittee shall calculate and record on a daily basis 12-hour average TRS concentrations for the two consecutive periods of each operating day. Each 12-hour average shall be determined as the arithmetic mean of the appropriate 12 contiguous 1-hour average total reduced sulfur concentrations provided by each continuous monitoring system installed under paragraph (a)(2) of this section. [§19.304 of Regulation #19 and 40 CFR §60.284(c)(1), except where the provisions of 40 CFR §60.283(a)(1)(iv) or (a)(4) apply]

d. For the purpose of reports required under 40 CFR §60.7(c), the permittee shall report semiannually periods of excess emissions where 60.284(c)(3)(i) and (ii)

apply. The applicant must also report the nature and cause of the excess emissions in accordance with 40 CFR §60.7(c)(2). Excess emission reports shall be submitted to the address in General Provision 7. [§19.304 of Regulation #19 and 40 CFR §60.284(d)]

e. In conducting the performance tests required in 40 CFR §60.8, the permittee shall use as reference methods and procedures the test methods in appendix A of this part or other methods and procedures in this section, except as provided in 40 CFR §60.8(b). Acceptable alternative methods and procedures are given in paragraph (f) of this section. [§19.304 of Regulation #19 and 40 CFR §60.285(a)]

NESHAP S

73. The Line 1 Washer (SN-33) and the Line 2 Washer (SN-34) shall comply with applicable provisions of §19.304 of Regulation 19 and 40 CFR Part 63 Subpart S - *National Emission Standards for Hazardous Air Pollutants from the Pulp and Paper Industry.* A copy of Subpart S is provided in Appendix E.

a. The permittee shall visually inspect each closed-vent system every 30 days. The visual inspection shall include inspection of ductwork, piping, enclosures, and connections to covers for visible evidence of defects. [40 CFR §63.453(k)(2)]

b. The permittee shall demonstrate no detectable leaks as specified in §63.450(c) measured initially and annually by the procedures specified in §63.457(d). [40 CFR §63.453(k)(3)]

c. The permittee shall operate the closed-vent system with no detectable leaks as indicated by an instrument reading of less than 500 parts per million by volume (ppm) above background as specified by §63.457(d). [40 CFR §63.450(c)]

d. The permittee shall perform corrective action, in the event of visible leak detection or instrument reading of 500 ppm above background, according to §63.453(k)(6)(i) and (ii). [40 CFR §63.457(k)(6)]

As part of an alternative monitoring requirement approved by the EPA, a copy of which is located in Appendix I, the permittee shall comply with the following:

e. In lieu of monthly visual monitoring, the permittee shall conduct monthly Method 21 monitoring of leaks found around the feed and exit roll seals and along the side gaskets of the washers. [40 CFR §63.453(d)(4)]

SN-30
Bleach Plant

Source Description

The unbleached Kraft pulp is taken from the high density storage chest for further processing in the bleach plant. The bleaching process removes lignin and Kraft color from the unbleached pulp.

Bleaching is performed in several stages using chlorine/chlorine dioxide, caustic soda, oxygen, acid, hydrogen peroxide, and other non-chlorine bleaching aids. Chlorine dioxide is generated using sodium chlorate, methanol and sulfuric acid. The chlorine dioxide gas that is produced is absorbed in chilled water and sent to storage for further use in the bleaching operations. The bleach plant uses a scrubber (SN-30) to control chlorine/chlorine dioxide emissions. All equipment in the bleach plant is either pressurized or is kept under negative pressure and connected to the scrubbing system. The Bleach Plant scrubber is a packed tower with mist eliminators. In order to satisfy Cluster Rule requirements, Crossett Paper Operations has phased out Cl_2 and hypochlorite usage by the Cluster Rule compliance date of deadline of April 16, 2001.

As part of permit revision 597-AOP-R4, the Bleach Plant was required to undergo BACT for CO. Due to the phasing out of hypochlorite and limited available data concerning the resulting carbon monoxide emissions, the facility was required to modify the permit. The increase was above the PSD significance threshold for CO. BACT was determined to be no controls.

Specific Conditions

74. The permittee shall not exceed the emission rates set forth in the following table. Compliance with this Specific Condition shall be demonstrated by compliance with Specific Condition #77. [Regulation No. 19 §19.501 et seq. and 40 CFR Part 52, Subpart E]

Pollutant	lb/hr	tpy
VOC	21.4	93.7

75. The permittee shall not exceed the emission rates set forth in the following table. Compliance with this Specific Condition shall be demonstrated by compliance with Specific Condition #77. [§19.501 et seq. and §19.901 of Regulation #19, and 40 CFR Part 52 Subpart E]

Pollutant	lb/hr	ton/yr
CO	136.1	596.1

76. The permittee shall not exceed the emission rates set forth in the following table. Compliance with this Specific Condition shall be demonstrated by compliance with Specific Condition #77. [Regulation No. §18.801 and A.C.A. §8-4-203 as referenced by §8-4-304 and §8-4-311]

Pollutant	lb/hr	tpy
Acetaldehyde	0.23	0.99
Acetone	0.5	2.0
Acrolein	0.01	0.01
Benzene	0.01	0.01
Carbon Tetrachloride	0.01	0.01
Chloroform	7.64	33.44
Cresol	0.06	0.25
Cumene	0.01	0.01
Ethylene Dibromide	0.03	0.11
Ethylene Dichloride	0.01	0.01
Formaldehyde	0.05	0.21
Hexachlorocyclopentadiene	0.16	0.66
Hexachloroethane	0.21	0.90
Hydrogen Chloride	2.48	10.83
Hexane	0.01	0.01
Methanol	12.90	56.51
Methylene Chloride	0.01	0.03
Propionaldehyde	0.06	0.25
Phenol	0.04	0.14
Styrene	0.02	0.09
Tetrachloroethylene	0.01	0.05
Toluene	0.01	0.01
1,2,4-Trichlorbenzene	0.01	0.03
Xylene	0.01	0.01

Throughput Requirements

77. The permittee shall not produce in excess of 2,150 air dried tons of bleached pulp per day, 30 day rolling average. [§19.705 of Regulation #19, A.C.A. §8-4-203 as referenced by §8-4-304 and §8-4-311, and 40 CFR §70.6]

78. The permittee shall maintain records which demonstrate compliance with the limits listed in Specific Condition #77. The records shall be updated on a monthly basis. These records shall be kept on site, provided to Department personnel upon request and may be used by the Department for enforcement purposes. A twelve month total and each individual month's data shall be submitted in accordance with General Provision #7. [§19.705 of Regulation #19 and 40 CFR Part 52 Subpart E]

Testing Requirements

79. The permittee shall test for carbon monoxide emissions from the Bleach Plant Scrubber (SN-30) every five years. Testing shall be performed in accordance with Plantwide Condition #3 and EPA Reference Method 10 as found in 40 CFR Appendix A. During the test the permittee shall operate the plant within 10 percent of the rated throughput capacity. If 90 percent of the rated throughout capacity cannot be achieved, the permittee shall be limited to 10 percent above the actual tested throughput. The permittee shall reference this limitation in any compliance reports submitted to the Department. [§19.702 and §19.901 of Regulation #19 and 40 CFR Part 52 Subpart E]

NESHAP S

80. The Bleach Plant is subject to and shall comply with applicable provisions of §19.304 of Regulation 19 and 40 CFR Part 63 Subpart S – *National Emission Standards for Hazardous Air Pollutants from the Pulp and Paper Industry*. A copy of Subpart S is provided in Appendix E.

    a. The equipment at each bleaching stage, of the bleaching systems listed in paragraph (a) of 40 CFR §63.445, where chlorinated compounds are introduced shall be enclosed and vented into a closed-vent system and routed to a control device that meets the requirements specified in paragraph (c) of 40 CFR §63.445. The enclosures and closed-vent system shall meet the requirements specified in 40 CFR §63.450. [40 CFR §63.445(b)]

    b. The control device used to reduce chlorinated HAP emission (not including chloroform) from the equipment specified in paragraph (b) of 40 CFR §63.445, the permittee shall comply with the emissions limitations required for bleaching systems by one of the following methods 1) achieving a 99% reduction efficiency across the scrubber or 2) achieving <10 ppm HAPs or 0.002 lbs/ODTP, measured as chlorine. [40 CFR §63.445(c)(3)]

c. The owner or operator of each bleaching system subject to paragraph (a)(2) of 40 CFR §63.445 shall comply with paragraph (d)(1) or (d)(2) of 40 CFR §63.445 to reduce chloroform air emissions to the atmosphere, except where the owner or operator of each bleaching system complying with extended compliance under 40 CFR §63.440(d)(3)(ii) shall comply with paragraph (d)(1) of 40 CFR §63.445. [40 CFR §63.445(d)]

d. The permittee shall use no hypochlorite or elemental chlorine for bleaching in the bleaching system or line. [40 CFR §63.445(d)(2)]

81. The Bleach Plant scrubber shall be kept in good working condition at all times and shall meet the following conditions as part of an alternative monitoring requirement approved by the EPA on July 26, 2001. A copy of this letter is included in Appendix G. [40 CFR §63.453(m)]

a. Perform a successful initial performance test to determine an acceptable range of electrical current (amps) within which the fan needs to be operated. The fan amp range is 30-70 amps.

b. Continuously record and monitor the fan motor amperage loading to ensure proper rotational fan speed and pressure drop for the bleach plant scrubber fan.

c. Conduct monthly visual inspections under the Leak Detection and Repair plan provisions for the scrubber fan and associated process.

d. Conduct annual negative pressure checks to ensure that the bleach plant scrubber fan induces the desired negative pressure across the system.

e. Conduct periodic preventative maintenance of the bleach plant scrubber fan to ensure safe and proper operation of the system.

f. Respond immediately to any signs or indications of visible emissions from the scrubber stack, washer hoods, or towers at the bleach plant.

g. Replacement of fan blades or fan motor will require a demonstration by the facility that gas flow rate to the scrubber has not increased or a performance test to ensure that the scrubber meets the emission limitations.

SN-26 and SN-96
8R Recovery Furnace and Salt Cake Mix Tank

Source Description

Recovery is the set of operations that recover spent cooking chemicals for reuse in the digesters. The recovery process uses a multi-effect evaporator to concentrate weak black liquor. Concentrated black liquor is burned in the 8R Recovery Furnace (SN-26) to recover spent chemicals, the inorganic chemicals that are necessary for pulp making. Auxiliary fuels, such as oil, may be used by the furnace for startup or to augment liquor combustion. Exhaust gases from the recovery furnace are treated in an electrostatic wet bottom precipitator. The spent chemicals leave the recovery furnace in a molten form and enter the smelt dissolving tanks.

Evaporation and concentration operations remove water from the black liquor in order to facilitate combustion in the recovery furnace. The solids in the liquor are generated from the digester and washing filtrates. The evaporators convert the weak black liquor to strong (heavy) black liquor.

There are six effects in the evaporator train at the mill, each effect operating at a different pressure. Plant steam flows countercurrent to the black liquor through the evaporators. Combined condensate from the evaporator is used in washing and recausticizing. A Low Energy Environmental Pre-evaporator and Stripper (LEEPS) system added to the evaporator system treats the foul (or strip) condensates produced in the evaporation process. The LEEPS system also treats foul condensates generated from the pulping process. The clean water produced is re-used for pulp washing. The stripped condensate (methanol) is routed to the incinerator as a liquid for destruction. The stripper overhead gases (SOGs) are routed to the incinerator for destruction, or as a backup, to the No. 4 Lime Kiln or the 9A Boiler.

Black liquor of varying concentration is stored in above ground storage tanks. There are two large weak black liquor tanks and one weak black liquor storage basin (approximately 4 acres, SN-76F). In addition, there are two strong black liquor tanks and two concentrated strong black liquor holding tanks. There are also seven multiple service tanks that may store black liquor. There are also additional, smaller black liquor storage tanks.

The concentrated black liquor is burned in the 8R Recovery Furnace with the heat being used to produce steam and electricity. Flue gas from the furnace is sent through an economizer followed by an electrostatic precipitator (ESP). The ESP is used to control particulate matter emissions. Salt cake from the ESP is sent to the Salt Cake Mix Tank (SN-96).

The 8R Recovery Furnace was installed in 1981. It is subject to regulation under NSPS Subpart BB and NESHAP Subpart MM. As a result of the R10 modification, this source has undergone PSD review for PM/PM_{10}, SO_2, VOC, CO, and NO_x. BACT is defined as the use of an ESP, boiler design, and combustion control.

Specific Conditions

82. The permittee shall not exceed the emission rates set forth in the following table. Compliance with this Specific Condition shall be demonstrated by compliance with Specific Conditions #92 and #93. [Regulation No. 19 §19.501 et seq. and 40 CFR Part 52, Subpart E]

SN	Description	Pollutant	lb/hr	ton/yr
26	8R Recovery Furnace	Pb	0.01	0.01
96	Salt Cake Mix Tank	VOC TRS	0.7 0.1	2.4 0.2

83. The permittee shall not exceed the emission rates set forth in the following table. Compliance with this Specific Condition shall be demonstrated by compliance with Specific Conditions #93, #94, #95, and #98. [§19.501 et seq. and §19.901 of Regulation #19, and 40 CFR Part 52 Subpart E]

SN	Pollutant	lb/hr	ton/yr
26	Startup – Specification Oil Only		
	SO_2	989.1	371.0
	Normal Operation – BLS with Supplemental Specification Oil Firing		
	SO_2	84.7	371.0
		0.589 lb/ton BLS	

84. The permittee shall not exceed the emission rates set forth in the following table. Compliance with this Specific Condition shall be demonstrated by compliance with Specific Conditions #92 and #93. [§19.501 et seq. and §19.901 of Regulation #19, and 40 CFR Part 52 Subpart E]

SN	Pollutant	lb/hr	ton/yr
26	NO_x	276.0	1,208.6
		110 ppmdv @ 8% O_2	

85. The permittee shall not exceed the emission rates set forth in the following table. Compliance with this Specific Condition shall be demonstrated by compliance with Specific Conditions #92 and #93. [§19.501 et seq., §19.901 of Regulation #19, and 40 CFR Part 52 Subpart E]

SN	Pollutant	lb/hr	ton/yr
26	CO	1,420.0	6,219.6
		930 ppmdv @ 8% O_2	

86. The permittee shall not exceed the emission rates set forth in the following table. Compliance with this Specific Condition shall be demonstrated by compliance with Specific Conditions #92 and #93. [§19.304, §19.501 et seq., §19.901 of Regulation #19, 40 CFR Part 52 Subpart E]

SN	Pollutant	lb/hr	ton/yr
26	PM/PM_{10}	60.0	262.8
		0.02 gr/dscf @ 8% O_2	

87. The permittee shall not exceed the emission rates set forth in the following table. Compliance with this Specific Condition shall be demonstrated by compliance with Specific Conditions #92 and #93. [§19.501 et seq., §19.901 of Regulation #19, and 40 CFR Part 52 Subpart E]

SN	Pollutant	lb/hr	ton/yr
26	VOC	25.9	98.6
		0.18 lb/ton of BLS	

88. The permittee shall not exceed the emission rates set forth in the following table. Compliance with this Specific Condition shall be demonstrated by compliance with Specific Conditions #92 and #93. [§19.304, §19.501 et seq., and §19.801 of Regulation #19; 40 CFR Part 52 Subpart E; and 40 CFR §60.283]

SN	Pollutant	lb/hr	ton/yr
26	TRS	11.2	48.8
		5 ppm @ 8% O_2, 12-hr average	

89. The permittee shall not exceed the emission rates set forth in the following table. Compliance with this Specific Condition shall be demonstrated by compliance with Specific Conditions #92. [§19.501 et seq. and §19.901 of Regulation #19, and 40 CFR Part 52 Subpart E]

SN	Pollutant	lb/hr	ton/yr
26	Sulfuric Acid Mist (SAM)	7.3	27.6
		0.0504 lb/ton of BLS	

90. The permittee shall not exceed the emission rates set forth in the following table. Compliance with this Specific Condition shall be demonstrated by compliance with

Specific Conditions #93, #94, #95, and #98. [Regulation No. §18.801 and A.C.A. §8-4-203 as referenced by §8-4-304 and §8-4-311]

SN	Description	Pollutant	lb/hr	ton/yr
26	8R Recovery Furnace	Acetaldehyde	0.08	0.28
		Acetone	2.3	8.6
		Arsenic	0.01	0.01
		Benzene	0.12	0.43
		Beryllium	0.01	0.01
		Cadmium	0.01	0.01
		Chloroform	0.01	0.02
		Chromium, Hex	0.01	0.01
		Cobalt	0.01	0.01
		Formaldehyde	1.35	5.13
		Hexane	0.05	0.17
		Hydrogen Chloride	9.49	36.14
		Manganese	0.01	0.04
		Methanol	7.59	28.91
		Mercury	0.01	0.01
		Methylene Chloride	0.09	0.32
		Naphthalene	0.05	0.18
		Nickel	0.01	0.03
		Phosphorous	0.04	0.14
		POM	0.02	0.06
		Selenium	0.01	0.01
		Styrene	0.10	0.37
		Tetrachloroethylene	0.09	0.32
		Toluene	0.01	0.03
		1,2,4-Trichlorobenzene	0.14	0.51
		Xylene	0.09	0.34
96	Salt Cake Mix Tank	Acetaldehyde	0.03	0.12
		Acetone	0.1	0.2
		Acrolein	0.01	0.01
		Benzene	0.01	0.01
		Formaldehyde	0.01	0.01
		Hexane	0.01	0.01
		Methanol	0.51	1.91
		Styrene	0.01	0.01
		Tetrachloroethylene	0.01	0.01
		Toluene	0.01	0.01
		1,2,4-Trichlorobenzene	0.01	0.01
		Xylene	0.01	0.01

Opacity

91. The permittee shall not cause to be discharged to the atmosphere from the 8R Recovery Furnace gases which exhibit opacity greater than 20%. Compliance shall be demonstrated by the use of the Recovery Furnace's continuous opacity monitor. [§19.503 of Regulation #19 and 40 CFR Part 52 Subpart E]

NSPS BB

92. The 8R Recovery Furnace (SN-26) is subject to and shall comply with all applicable provisions of §19.304 of Regulation 19, 40 CFR Part 60 Subpart BB - *Standards of Performance for Kraft Pulp and Paper Mills*, and 40 CFR Part 63 Subpart MM - *National Emission Standards for Hazardous Air Pollutants for Chemical Recovery Combustion Sources at Kraft, Sulfite, and Stand-Alone Semichemical Pulp Mills*. A copy of Subpart BB is provided in Appendix C. The Incinerator (SN-83) satisfies the requirements under §60.283(a)(1)(iii). A copy of Subpart MM is provided in Appendix H.

a. The permittee shall not cause to be discharged into the atmosphere from the recovery furnace gases which contain particulate matter in excess of 0.044 gr/dscf corrected to 8 percent oxygen. [§19.304 of Regulation #19 and 40 CFR §60.282(a)(1)(i) and 40 CFR §63.862(a)(i)(A)]

b. The permittee shall not cause to be discharged into the atmosphere from the recovery furnace gases which exhibit 35 percent opacity or greater. [§19.304 of Regulation #19 and 40 CFR §60.282(a)(1)(ii)]

c. The permittee shall not cause to be discharged into the atmosphere from the recovery furnace gases which contain TRS in excess of 5 ppm by volume on a dry basis, corrected to 8 percent oxygen. [§19.304 of Regulation #19 and 40 CFR §60.283(a)(2)]

d. The permittee shall install, calibrate, maintain, and operate continuous monitoring systems (CEMs) to monitor and record the concentration of TRS emissions on a dry basis and the percent of oxygen by volume on a dry basis in the gases discharged into the atmosphere from the recovery furnace, except where the provisions of §60.283(a)(1) (iii) or (iv) apply. This system shall be located downstream of the control device and the span shall be set at a TRS concentration of 50 ppm for the TRS continuous monitoring system and at 25 percent oxygen for the continuous oxygen monitoring system. [§19.304 of Regulation #19 and 40 CFR §60.284(a)(2)]

e. The permittee shall calculate and record on a daily basis 12-hour average TRS concentrations for the two consecutive periods of each operating day. Each 12-

hour average shall be determined as the arithmetic mean of the appropriate 12 contiguous 1-hour average total reduced sulfur concentrations provided by each continuous monitoring system installed under paragraph (a)(2) of this section. [§19.304 of Regulation #19 and 40 CFR §60.284(c)(1)]

f. The permittee shall calculate and record on a daily basis 12-hour average oxygen concentrations for the two consecutive periods of each operating day for the recovery furnace. These 12-hour averages shall correspond to the 12-hour average TRS concentrations under paragraph (c)(1) of this section and shall be determined as an arithmetic mean of the appropriate 12 contiguous 1-hour average oxygen concentrations provided by each continuous monitoring system installed under paragraph (a)(2) of this section. [§19.304 of Regulation #19 and 40 CFR §60.284(c)(2)]

g. For the purpose of reports required under 40 CFR §60.7(c), the permittee shall report semiannually periods of excess emissions where 60.284(c)(3)(i) and (ii) apply. The applicant must also report the nature and cause of the excess emissions in accordance with 40 CFR §60.7(c)(2). Excess emission reports shall be submitted to the address in General Provision 7. [§19.304 of Regulation #19 and 40 CFR §60.284(d)]

h. The permittee shall use as reference methods and procedures the test methods in appendix A of this part or other methods and procedures in this section, except as provided in 40 CFR §60.8(b). Acceptable alternative methods and procedures are given in paragraph (f) of this section. [§19.304 of Regulation #19 and 40 CFR §60.285(a)]

i. The permittee is limited to a particulate concentration of no more than 0.044 gr/scf at 8% O_2. [§19.304 of Regulation #19 and 40 CFR §60.282, and 40 CFR §63.862(a)(i)(A)

Fuel Requirements

93. The permittee shall not fire in excess of 1.095 million tons of black liquor solids to the recovery furnace per twelve consecutive months. [§19.705 of Regulation #19, A.C.A. §8-4-203 as referenced by §8-4-304 and §8-4-311, and 40 CFR §70.6]

94. The permittee shall not fire in excess of 5,256,000 gallons of glycerin to the recovery furnace per twelve consecutive months. [§19.705 of Regulation #19, A.C.A. §8-4-203 as referenced by §8-4-304 and §8 4-311, and 40 CFR §70.6]

95. The permittee may fire up to 1.0 gal/min ultra-low sulfur diesel to the recovery furnace. [§19.705 of Regulation #19, A.C.A. §8-4-203 as referenced by §8-4-304 and §8 4-311, and 40 CFR §70.6]

96. Specification grade oil, ultra-low sulfur diesel, and glycerin may be used as fuel in the 8R Recovery Furnace (SN-26) during startup and to supplement BLS firing during periods deemed necessary by operations. [§19.705 of Regulation #19, A.C.A. §8-4-203 as referenced by §8-4-304 and §8-4-311, and 40 CFR §70.6]

97. The permittee shall maintain records of fuel usage which demonstrate compliance with Specific Conditions #93, #94, #95, and #96. These records shall be updated monthly, kept on site, provided to Department personnel upon request and may be used by the Department for enforcement purposes. A twelve month total and each month's individual data shall be submitted to the Department in accordance with General Provision #7. [§19.705 of Regulation #19 and 40 CFR Part 52 Subpart E]

98. The sulfur content of the specification grade oil shall not exceed 1.5% by weight and 1.0% on a 30-day average. [§19.705 of Regulation #19, A.C.A. §8-4-203 as referenced by §8-4-304 and §8-4-311, and 40 CFR §70.6]

99. Sulfur dioxide emissions shall be determined through a mass balance based on incoming materials and worst-case firing of specification grade oil based on the limits in Condition #98. This mass balance shall be submitted to the Department in accordance with General Provision #7. [§19.703 of Regulation #19, 40 CFR Part 52 Subpart E, and A.C.A. §8-4-203 as referenced by §8-4-304 and §8-4-311]

Testing Requirements

100. The permittee shall perform testing of particulate matter emissions from the 8R Recovery Furnace (SN-26) every five years. Testing shall be performed in accordance with Plantwide Condition #3 and using EPA Reference Method 5 with inclusion of back half sampling train particulate. Results from the Method 5 test shall be compared to the NSPS limit 0.044 gr/scf at 8% O_2 for compliance purposes. During the test the permittee shall operate the source within 10 percent of the rated throughput capacity. If 90 percent of the rated throughout capacity cannot be achieved, the permittee shall be limited to 10 percent above the actual tested throughput. The permittee shall reference this limitation in any compliance reports submitted to the Department. [§19.702 of Regulation #19 and 40 CFR Part 52 Subpart E]

101. The permittee shall perform testing of the following emissions from the 8R Recovery Furnace (SN-26) every five years to verify compliance with the BACT emission limits. During the test the permittee shall operate the source within 10 percent of the rated throughput capacity. If 90 percent of the rated throughout capacity cannot be achieved, the permittee shall be limited to 10 percent above the actual tested throughput. The permittee shall reference this limitation in any compliance reports submitted to the Department. [§19.702 and §19.901 of Regulation #19, and 40 CFR Part 52 Subpart E]

Pollutant	Reference Method (or other pre-approved)
SO_2	6C
VOC	25A
NOx	7E
CO	10
SAM	8

CEMS Requirements

102. The permittee shall continue to operate and maintain opacity, TRS and O_2 continuous emission monitors at the 8R Recovery Furnace (SN-26). [§19.304 and §19.703 of Regulation #19, 40 CFR Part 52 Subpart E, A.C.A. §8-4-203 as referenced by §8-4-304 and §8-4-311, and 40 CFR §60.284]

103. The continuous emission monitors for TRS and O_2 at the 8R Recovery Furnace shall be operated in accordance with the Department Continuous Emission Monitoring Systems Conditions (Appendix A) and the applicable Performance Standards of 40 CFR Part 60 Appendix B. [§19.703 of Regulation #19, 40 CFR Part 52 Subpart E, and A.C.A. §8-4-203 as referenced by §8-4-304 and §8-4-311]

104. All continuous monitoring data may, at the discretion of the Department, be used to determine violations of the emissions limits or conditions of this permit. [§19.703 of Regulation #19, 40 CFR Part 52 Subpart E, and A.C.A. §8-4-203 as referenced by §8-4-304 and §8-4-311]

105. The TRS concentration of gases leaving the 8R Recovery Furnace (SN-26) shall not exceed 5 ppm, measured as H_2S on a dry basis and on a 12 hour average, corrected to 8% volume oxygen. The permittee shall continue to operate and maintain CEMs which record the TRS concentration of gases leaving the 8R Recovery Furnace (SN-26). The TRS monitors shall be operated in accordance with the requirements of 40 CFR §60.284 (date of installation notwithstanding) and the Department Continuous Emission Monitoring Systems Conditions (Appendix A). [§19.304 and §19.801 of Regulation #19, 40 CFR §60.283, and 40 CFR §60.284]

SN-27A and 27B
Smelt Dissolving Tanks

Source Description

The combusted black liquor generates molten salts that are drained from the bottom of the 8R Recovery Furnace into one of two smelt dissolving tanks (SN-27A and SN-27B) on either side of the 8R Recovery Furnace. The smelt dissolving tanks cool the molten salts in large water tanks. Each smelt dissolving tank has an independent stack that is routed through a wet scrubber. The smelt dissolving tanks are subject to NSPS Subpart BB - *National Emission Standards for Hazardous Air Pollutants from the Pulp and Paper Industry* and NESHAP Subpart MM - *National Emission Standards for Hazardous Air Pollutants for Chemical Recovery Combustion Sources at Kraft, Sulfite, and Stand-Alone Semichemical Pulp Mills.*

Specific Conditions

106. The permittee shall not exceed the emission rates set forth in the following table. Compliance with this Specific Condition shall be demonstrated by compliance with Specific Condition #93. [Regulation No. 19 §19.501 et seq. and 40 CFR Part 52, Subpart E]

SN	Description	Pollutant	lb/hr	ton/yr
27A	Smelt Dissolving Tank (East)	SO_2	0.5	1.7
		VOC	1.5	5.5
		CO	0.7	2.7
		NO_x	1.8	6.6
		Pb	0.01	0.01
27B	Smelt Dissolving Tank (West)	SO_2	0.5	1.7
		VOC	1.5	5.5
		CO	0.7	2.7
		NO_x	1.8	6.6
		Pb	0.01	0.01

107. The permittee shall not exceed the emission rates set forth in the following table. Compliance with this Specific Condition shall be demonstrated by compliance with Specific Condition #93, #113, and #115. [§19.304 and §19.501 et seq. of Regulation #19, and 40 CFR Part 52 Subpart E, and 40 CFR §63.862(a)(i)(B)]

SN	Description	Pollutant	lb/hr	ton/yr
27A	Smelt Dissolving Tank (East)	PM	14.4	54.8
		PM_{10}	0.2 lb PM/PM_{10} per ton of black liquor solids (TBLS)	
27B	Smelt Dissolving Tank (West)	PM	14.4	54.8
		PM_{10}	0.2 lb PM/PM_{10} per ton of black liquor solids (TBLS)	

108. The permittee shall not exceed the emission rates set forth in the following table. Compliance with this Specific Condition shall be demonstrated by compliance with Specific Condition #93, #115, and #117. [§19.304, §19.501 et seq., and §19.801 of Regulation #19; 40 CFR Part 52 Subpart E, 40 CFR §60.283]

SN	Description	Pollutant	lb/hr	ton/yr
27A	Smelt Dissolving Tank (East)	TRS	2.4	9.1
			0.016 g TRS per kg of black liquor solids 0.033 lb/TBLS) as H_2S	
27B	Smelt Dissolving Tank (West)	TRS	2.4	9.1
			0.016 g TRS per ton of black liquor solids (0.033 lb/TBLS) as H_2S	

109. The permittee shall not exceed the emission rates set forth in the following table. Compliance with this Specific Condition shall be demonstrated by compliance with Specific Condition #93. [Regulation No.§18.801 and A.C.A. §8-4-203 as referenced by §8-4-304 and §8-4-311]

SN	Description	Pollutant	lb/hr	ton/yr
27A	Smelt Dissolving Tank (East)	Acetaldehyde	0.08	0.30
		Acetone	0.2	0.5
		Acrolein	0.01	0.01
		Arsenic	0.01	0.01
		Benzene	0.01	0.01
		Beryllium	0.01	0.01
		Cadmium	0.01	0.01
		Carbon Disulfide	0.01	0.01
		Chloroform	0.01	0.01

SN	Description	Pollutant	lb/hr	ton/yr
		Cobalt	0.01	0.01
		Cumene	0.01	0.01
		Formaldehyde	0.31	1.15
		Hexachlorocyclopentadiene	0.01	0.04
		Hexane	0.01	0.01
		Manganese	0.01	0.01
		Mercury	0.01	0.01
		Methanol	0.95	3.62
		Methylene Chloride	0.01	0.01
		Naphthalene	0.05	0.17
		Nickel	0.01	0.01
		Phosphorous	0.01	0.01
		POM	0.04	0.15
		Selenium	0.01	0.01
		Styrene	0.02	0.04
		Tetrachloroethylene	0.01	0.01
		Toluene	0.01	0.01
		1,2,4-Trichlorbenzene	0.01	0.01
		Xylene	0.01	0.01
27B	Smelt Dissolving Tank (East)	Acetaldehyde	0.08	0.30
		Acetone	0.2	0.5
		Acrolein	0.01	0.01
		Arsenic	0.01	0.01
		Benzene	0.01	0.01
		Beryllium	0.01	0.01
		Cadmium	0.01	0.01
		Carbon Disulfide	0.01	0.01
		Chloroform	0.01	0.01
		Cobalt	0.01	0.01
		Cumene	0.01	0.01
		Formaldehyde	0.31	1.15
		Hexachlorocyclopentadiene	0.01	0.04
		Hexane	0.01	0.01
		Manganese	0.01	0.01
		Mercury	0.01	0.01
		Methanol	0.95	3.62
		Methylene Chloride	0.01	0.01
		Naphthalene	0.05	0.17
		Nickel	0.01	0.01
		Phosphorous	0.01	0.01
		POM	0.04	0.15

SN	Description	Pollutant	lb/hr	ton/yr
		Selenium	0.01	0.01
		Styrene	0.02	0.04
		Tetrachloroethylene	0.01	0.01
		Toluene	0.01	0.01
		1,2,4-Trichlorbenzene	0.01	0.01
		Xylene	0.01	0.01

Opacity

110. The permittee shall not cause to be discharged from the Smelt Dissolving Tanks (SN-27A and 27B) gases which exhibit opacity greater than 20%. [§19.503 of Regulation #19 and 40 CFR Part 52 Subpart E]

111. The permittee shall conduct weekly observations of the opacity at SN-27A and B. Observations shall be conducted by personnel familiar with the permittee's visible emissions. If visible emissions in excess of the permitted opacity are detected, then a Method 9 reading is required. The permittee shall then take immediate action to identify the cause of the visible emissions, implement all necessary corrective action, and reassess the visible emissions after corrective action is taken. The permittee shall maintain records related to all observations/readings, to be updated on a weekly basis. The records shall contain the date and time of each observation/reading, the cause of any observed exceedance of opacity limits, corrective action taken, and results of the reassessment, and the name of the person conducting the observation/reading. The records shall be kept on site and made available to Department personnel upon request. [§19.705 of Regulation 19 and 40 CFR Part 52, Subpart E]

Scrubber Monitoring Requirements

112. The permittee shall continue to operate and maintain a monitoring device for the continuous measurement of the differential pressure drop across the scrubber. [§19.304 and §19.703 of Regulation #19, 40 CFR Part 52 Subpart E, A.C.A. §8-4-203 as referenced by §8-4-304 and §8-4-311, and 40 CFR §60.284]

113. The scrubbers shall be kept in good working condition at all times and shall meet the conditions shown in the following table. The scrubber liquid flow rate and the gas pressure drop across the units shall be measured hourly and compliance shall be based upon the daily average of these measurements. The results shall be kept on site and be available to the Department personnel upon request. Future compliance tests may be used to establish the daily average pressure drop and flow rate values that are contained in the permit. [§19.303 of Regulation #19 and A.C.A §8-4-203 as referenced by §8-4-304 and §8-4-311]

SN	Control Equipment	Parameter	Units	Operation Limits (minimum)
27A	scrubber	liquid flow rate	gal/min	135
		gas pressure drop across unit	inches, H_2O	5
27B	scrubber	liquid flow rate	gal/min	135
		gas pressure drop across unit	inches, H_2O	5

114. The permittee shall abide by the following alternative scenario only during emergency maintenance for scrubbers for the Smelt Dissolving Tanks (SN-27A and 27B). [§19.303 of Regulation #19 and A.C.A. §8-4-203 as referenced by §8-4-304 and §8-4-311]

a. Black liquor solids feed to the 8R Boiler (SN-26) shall be reduced to 3.91 MM lb/day.

b. Uncontrolled emissions shall be quantified and recorded.

c. Repair time must not extend beyond a 6 hour period.

d. Down time of the equipment will be monitored and submitted to the Department in accordance with General Provision 8.

NSPS BB and NESHAP S

115. The Smelt Dissolving Tanks (SN-27A and 27B) are subject to and shall comply with all applicable provisions of §19.304 of Regulation 19, 40 CFR Part 60 Subpart BB - *Standards of Performance for Kraft Pulp and Paper Mills* and 40 CFR Part 63 Subpart MM - *National Emission Standards for Hazardous Air Pollutants for Chemical Recovery Combustion Sources at Kraft, Sulfite, and Stand-Alone Semichemical Pulp Mills*. A copy of Subpart BB is provided in Appendix C. The Incinerator (SN-83) satisfies the requirements under §60.283(a)(1)(iii). A copy of Subpart MM is provided in Appendix H.

a. The permittee shall not cause to be discharged into the atmosphere from the smelt dissolving tanks any gases which contain particulate matter in excess of 0.2 lb/ton black liquor solids (dry weight). [§19.304 of Regulation 19, 40 CFR §60.282(a)(2) and 40 CFR §63.862(a)(i)(B)]

b. The permittee shall not cause to be discharged into the atmosphere from the smelt dissolving tanks any gases which contain TRS in excess of 0.033 lb/ton black liquor solids as H_2S. [§19.304 of Regulation 19 and 40 CFR §60.283(a)(4)]

c. The permittee shall install, calibrate, maintain, and operate continuous monitoring devices for the smelt dissolving tanks because they use a scrubber emission control device. [§19.304 of Regulation 19 and 40 CFR §60.284(b)(2)]

d. For the purpose of reports required under 40 CFR §60.7(c), the permittee shall report semiannually periods of excess emissions where 60.284(c)(3)(i) and (ii) apply. The applicant must also report the nature and cause of the excess emissions in accordance with 40 CFR §60.7(c)(2). Excess emission reports shall be submitted to the address in General Provision 7. [§19.304 of Regulation 19 and 40 CFR §60.284(d)]

e. The permittee shall use as reference methods and procedures the test methods in appendix A of this part or other methods and procedures in this section, except as provided in 40 CFR §60.8(b). Acceptable alternative methods and procedures are given in paragraph (f) of this section. [§19.304 of Regulation 19 and 40 CFR §60.285(a)]

Testing Requirements

116. The permittee shall test particulate matter emissions from the Smelt Dissolving Tanks (SN-27A and 27B) every 5 years. Testing shall be performed in accordance with Plantwide Condition #3 and EPA Reference Method 5 with inclusion of back half sampling train particulate. Results from the Method 5 test shall be compared to the NSPS limit of 0.2 lb PM/PM_{10} per ton of black liquor solids (TBLS) for compliance purposes. During the test the permittee shall operate the sources within 10 percent of the rated throughput capacity. If 90 percent of the rated throughout capacity cannot be achieved, the permittee shall be limited to 10 percent above the actual tested throughput. The permittee shall reference this limitation in any compliance reports submitted to the Department. [§19.702 of Regulation #19 and 40 CFR Part 52 Subpart E]

117. The TRS concentration of gases leaving the Smelt Dissolving Tanks (SN-27A and 27B) shall not exceed 0.0168 g TRS per kg of black liquor solids. The permittee shall conduct annual compliance testing of TRS emissions from the Smelt Dissolving Tanks (SN-27A and 27B). Data reduction shall be performed as set forth in 40 CFR §60.8. Testing shall be performed in accordance with Plantwide Condition #3 and EPA Reference Method 16 or 16A. During the test the permittee shall operate the source within 10 percent of the rated throughput capacity. If 90 percent of the rated throughout capacity cannot be achieved, the permittee shall be limited to 10 percent above the actual tested throughput. The permittee shall reference this limitation in any compliance reports submitted to the Department. [§19.702 and §19.801 et seq of Regulation #19, and 40 CFR Part 52 Subpart E]

SN-25
Lime Kiln

Source Description

The lime kiln heats calcium carbonate (lime mud) to form calcium oxide (lime product). Fuels used in the lime kiln include specification grade oil and natural gas. Emissions from the lime kiln are controlled by a wet scrubber. Non-condensable gases (NCGs) from processes are routed to the lime kiln for thermal destruction. The lime kiln is subject to NSPS Subpart BB and NESHAP Subpart MM. The kiln is also subject to CAM requirements due to SO_2 emissions. The maximum firing rate of the lime kiln is 128 million Btu per hour. NCGs from several pulp mill sources are collected and routed to the lime kiln for combustion. The evaporator vents, digester vents and blow tank condensers are all part of the NCG system at the Crossett Paper Operations.

Reburnt lime product from the lime kiln is conveyed to a lime bin where it is fed into the slaker. The lime handling and storage system includes elevators, conveyors and lime bins. Conveyors transport lime from the storage silos to the slakers. Fresh lime is added to the system from delivery trucks by pneumatic conveyance to the two lime silos.

Specific Conditions

118. The permittee shall not exceed the emission rates set forth in the following table. Compliance with this Specific Condition shall be demonstrated by compliance with Specific Conditions #126, #127, #129 and #130. [Regulation No. 19 §19.501 et seq. and 40 CFR Part 52, Subpart E]

Pollutant	lb/hr	ton/yr
SO_2	10.9	41.2
VOC	1.5	5.6
CO	5.8	21.9
NO_x	53.5	203.6
Pb	0.01	0.02

119. The permittee shall not exceed the emission rates set forth in the following table. Compliance with this Specific Condition shall be demonstrated by compliance with Specific Condition #126, #127, and #130. [§19.304 and §19.501 et seq. of Regulation #19, 40 CFR Part 52 Subpart E, and 40 CFR §63.862(a)(i)(C)]

Pollutant	lb/hr	ton/yr
PM	28.3	123.8
PM_{10}	0.064 gr/dscf corrected to 10% O_2	

120. The permittee shall not exceed the emission rates set forth in the following table. Compliance with this Specific Condition shall be demonstrated by compliance with Specific Conditions #126, #127, and #130. [§19.304, §19.501 et seq., §19.801 of Regulation #19; CFR Part 52 Subpart E; and 40 CFR §60.283]

Pollutant	lb/hr	ton/yr
TRS	2.2	9.6
	8 ppm measured as H_2S on a dry basis, on a 12-hour average, corrected to 10% O_2	

121. The permittee shall not exceed the emission rates set forth in the following table. Compliance with this Specific Condition shall be demonstrated by compliance with Specific Condition #127. [Regulation No. §18.801 and A.C.A. §8-4-203 as referenced by §8-4-304 and §8-4-311]

Pollutant	lb/hr	ton/yr
Acetaldehyde	0.18	0.67
Acetone	0.1	0.1
Acrolein	0.01	0.01
Arsenic	0.01	0.01
Benzene	0.02	0.04
Beryllium	0.01	0.01
Cadmium	0.01	0.01
Carbon Disulfide	0.01	0.04
Chloroform	0.01	0.01
Chromium Hex	0.01	0.01
Cobalt	0.01	0.01
Formaldehyde	0.18	0.67
Hexane	0.01	0.01
Hydrogen Chloride	0.01	0.03
Manganese	0.01	0.04
Mercury	0.01	0.01
Methanol	0.38	1.45
Methylene Chloride	0.01	0.01
Naphthalene	0.42	1.57
Nickel	0.01	0.02
Phenol	0.01	0.04
Phosphorous	0.06	0.21
POM	0.01	0.02
SAM	0.7	2.6
Selenium	0.01	0.01

Pollutant	lb/hr	ton/yr
Styrene	0.01	0.01
Tetrachloroethylene	0.01	0.04
Toluene	0.01	0.01
1,2,4-Trichlorobenzene	0.01	0.02
Xylene	0.01	0.03

Opacity

122. The permittee shall not cause to be discharged to the atmosphere gases which exhibit opacity greater than 20%. [§19.503 of Regulation #19 and 40 CFR Part 52 Subpart E]

123. The permittee shall conduct daily observations of the opacity at SN-25. Observations shall be conducted by personnel familiar with the permittee's visible emissions. If visible emissions in excess of the permitted opacity are detected, then a Method 9 reading is required. The permittee shall then take immediate action to identify the cause of the visible emissions, implement all necessary corrective action, and reassess the visible emissions after corrective action is taken. The permittee shall maintain records related to all observations/readings, to be updated on a daily basis. The records shall contain the date and time of each observation/reading, the cause of any observed exceedance of opacity limits, corrective action taken, and results of the reassessment, and the name of the person conducting the observation/reading. The records shall be kept on site and made available to Department personnel upon request. [§19.705 of Regulation 19 and 40 CFR Part 52, Subpart E]

CAM

124. The Lime Kiln (SN-25) is subject to and shall comply with all applicable provisions §19.304 of Regulation 19, 40 CFR Part 52 Subpart E, and Part §64.6 for Compliance Assurance Monitoring. Post control of particulate emissions from SN-25 is above major source levels.

a. The permittee shall maintain caustic liquid flow rate in the scrubber of at least 500 gallons per minute. [40 CFR Part §64.6(c)(1)]

b. The permittee shall maintain a gas pressure drop of at least 25 inches of water. [40 CFR Part §64.6(c)(1)]

c. The permittee shall monitor and maintain records every 15 minutes of the parameters in Specific Conditions #124 (A) and (B). Compliance shall be based upon a 3-hr average. Records shall be kept onsite and made available to the Department upon request. [40 CFR Part §64.6(c)(3)]

d. The permittee shall maintain the scrubber in good working condition at all times so that pollutant removal is maintained. [40 CFR Part §64.6(c)(1)]

125. The Lime Kiln (SN-25) is subject to and shall comply with all applicable provisions §19.304 of Regulation 19, 40 CFR Part 52 Subpart E, and Part §64.9 for Compliance Assurance Monitoring. The following information pertaining to exceedances or excursions from permitted values shall be submitted in semi-annual reports in accordance with General Provision 7 as outlined in 40 CFR §70.6.

a. The permittee shall maintain records for SN-25 that summarizes the number, duration, and cause of excursions or exceedances of emission limits as well as corrective action taken. [40 CFR §64.9(a)(2)(i) and §64.9(b)]

b. The permittee shall maintain records for SN-25 that summarizes the number, duration, and cause of monitoring equipment downtime incidents, other than routine downtime for calibration checks. [40 CFR §64.9(a)(2)(ii) and §64.9(b)]

c. The permittee shall maintain a quality improvement plan (QIP) threshold for each indicator of no more than nine excursions or 5% of the daily averages in a six-month period. [40 CFR §64.9(a)(2)(iii) and §64.9(b)]

d. The permittee shall develop and implement a new QIP if the threshold is exceeded during any six-month period. [40 CFR §64.9(a)(2)(iii) and §64.9(b)]

e. The permittee shall maintain records for SN-25 that describes the actions taken to implement the QIP. Upon completion of the QIP, documentation shall be maintained to confirm that the plan was completed and reduced the likelihood of similar excursions or exceedances. [40 CFR §64.9(a)(2)(iii) and §64.9(b)]

NSPS BB and NESHAP MM

126. The No. 4 Lime Kiln (SN-25) is subject to and shall comply with all applicable provisions of §19.304 of Regulation 19, 40 CFR Part 60 Subpart BB - *Standards of Performance for Kraft Pulp and Paper Mills* and 40 CFR Part 63 Subpart MM - *National Emission Standards for Hazardous Air Pollutants for Chemical Recovery Combustion Sources at Kraft, Sulfite, and Stand-Alone Semichemical Pulp Mills*. A copy of Subpart BB is provided in Appendix C. The Incinerator (SN-83) satisfies the requirements under §60.283(a)(1)(iii). A copy of Subpart MM is provided in Appendix H.

a. The permittee shall not cause to be discharged into the atmosphere from the lime kiln any gases which contain particulate matter in excess of 0.064 gr/dscf corrected to 10 percent oxygen, when gaseous fossil fuel is burned. [40 CFR §63.862(a)(i)(C)]

b. The permittee shall not cause to be discharged into the atmosphere from the lime kiln gases which contain TRS in excess of 8 ppm by volume on a dry basis, corrected to 10 percent oxygen. [§19.304 of Regulation 19 and 40 CFR §60.283(a)(5)]

c. The permittee shall install, calibrate, maintain, and operate continuous monitoring systems to monitor and record the concentration of TRS emissions on a dry basis and the percent of oxygen by volume on a dry basis in the gases discharged into the atmosphere from the lime kiln. This system shall be located downstream of the control device and the span shall be set at a TRS concentration of 30 ppm for the TRS continuous monitoring system and at 20 percent oxygen for the continuous oxygen monitoring system. [§19.304 of Regulation 19 and 40 CFR §60.284(a)(2)]

d. The permittee shall install, calibrate, maintain, and operate continuous monitoring devices (CEMs) for the lime kiln because it uses a scrubber emission control device. [§19.304 of Regulation 19 and 40 CFR §60.284(b)(2)]

e. The permittee shall calculate and record on a daily basis 12-hour average TRS concentrations for the two consecutive periods of each operating day. Each 12-hour average shall be determined as the arithmetic mean of the appropriate 12 contiguous 1-hour average total reduced sulfur concentrations provided by each continuous monitoring system installed under paragraph (a)(2) of this section. [§19.304 of Regulation 19 and 40 CFR §60.284(c)(1)]

f. The permittee shall calculate and record on a daily basis 12-hour average oxygen concentrations for the two consecutive periods of each operating day for the lime kiln. These 12-hour averages shall correspond to the 12-hour average TRS concentrations under paragraph (c)(1) of this section and shall be determined as an arithmetic mean of the appropriate 12 contiguous 1-hour average oxygen concentrations provided by each continuous monitoring system installed under paragraph (a)(2) of this section. [§19.304 of Regulation 19 and 40 CFR §60.284(c)(2)]

g. For the purpose of reports required under 40 CFR §60.7(c), the permittee shall report semiannually periods of excess emissions where 60.284(c)(3)(i) and (ii) apply. The applicant must also report the nature and cause of the excess emissions in accordance with 40 CFR §60.7(c)(2). Excess emission reports shall be submitted to the address in General Provision 7. [§19.304 of Regulation 19 and 40 CFR §60.284(d)]

h. The permittee shall use as reference methods and procedures the test methods in appendix A of this part or other methods and procedures in this section, except as provided in 40 CFR §60.8(b). Acceptable alternative methods and procedures are

given in paragraph (f) of this section. [§19.304 of Regulation 19 and 40 CFR §60.285(a)]

Production Limits

127. Calcium oxide production at this source is limited to 632.4 tons/day, maximum, and 550 tons/day on an annual average. [§19.705 of Regulation #19, A.C.A. §8-4-203 as referenced by §8-4-304 and §8-4-311, and 40 CFR §70.6]

128. The permittee shall maintain a record daily calcium oxide production. These records shall be kept on site, provided to Department personnel upon request and may be used by the Department for enforcement purposes. A twelve month total and each individual month's data shall be submitted in accordance with General Provision #7. [§19.705 of Regulation #19 and 40 CFR Part 52 Subpart E]

Fuel Requirements

129. Either natural gas, specification oil, or a combination of natural gas and specification oil may be used as fuel in the No. 4 Lime Kiln. [§19.705 of Regulation #19, A.C.A. §8-4-203 as referenced by §8-4-304 and §8-4-311, and 40 CFR §70.6]

130. The sulfur content of the specification grade oil shall not exceed 1.5% by weight and 1.0% on a 30-day average. [§19.705 of Regulation #19, A.C.A. §8-4-203 as referenced by §8-4-304 and §8-4-311, and 40 CFR §70.6]

Testing Requirements

131. The permittee shall test particulate matter emissions from the No. 4 Lime Kiln (SN-25) every five years. The permittee shall test at the minimum scrubber parameters of Specific Condition 124. Testing shall be performed in accordance with Plantwide Condition #3 and EPA Reference Method 5 with inclusion of back half sampling train particulate. Results from the Method 5 test shall be compared to the NSPS limit 0.064 gr/dscf corrected to 10% O_2 for compliance purposes. During the test the permittee shall operate the source within 10 percent of the rated throughput capacity. If 90 percent of the rated throughout capacity cannot be achieved, the permittee shall be limited to 10 percent above the actual tested throughput. The permittee shall reference this limitation in any compliance reports submitted to the Department. [§19.702 of Regulation #19 and 40 CFR Part 52 Subpart E]

132. The permittee shall test sulfur dioxide emissions from the No. 4 Lime Kiln (SN-25) every five years. Testing shall be performed in accordance with Plantwide Condition #3 and EPA Reference Method 6C. The permittee shall test at the minimum scrubber parameters of Specific Condition 124. During the test the permittee shall operate the source within 10 percent of the rated throughput capacity. If 90 percent of the rated throughout capacity cannot be achieved, the permittee shall be limited to 10 percent above the actual

tested throughput. The permittee shall reference this limitation in any compliance reports submitted to the Department. [§19.702 of Regulation #19 and 40 CFR Part 52 Subpart E]

CEM Requirements

133. The permittee shall continue to operate and maintain for the No. 4 Lime Kiln a continuous monitoring system to monitor and record TRS concentration on a dry basis, percent of O_2 by volume on a dry basis, pressure drop across the scrubber and liquid supply pressure. [§19.304 and §19.703 of Regulation #19, 40 CFR Part 52 Subpart E, A.C.A. §8-4-203 as referenced by §8-4-304 and §8-4-311, and 40 CFR §60.284]

134. The continuous emission monitors at the No. 4 Lime Kiln shall be operated in accordance with the Department Continuous Emission Monitoring Systems Conditions (Appendix A) and the applicable Performance Standards of 40 CFR Part 60 Appendix B. [§19.703 of Regulation #19, 40 CFR Part 52 Subpart E, and A.C.A. §8-4-203 as referenced by §8-4-304 and §8-4-311]

135. All continuous monitoring data may, at the discretion of the Department, be used to determine violations of the emissions limits or conditions of this permit. [§19.703 of Regulation #19, 40 CFR Part 52 Subpart E, and A.C.A. §8-4-203 as referenced by §8-4-304 and §8-4-311]

136. The TRS concentration of gases leaving the No. 4 Lime Kiln (SN-25) shall not exceed 8 ppm, measured as H_2S on a dry basis and on a 12 hour average, corrected to 10% volume oxygen. The permittee shall continue to operate and maintain CEMs which record the TRS concentration of gases leaving the No. 4 Lime Kiln (SN-25). The TRS monitors shall be operated in accordance with the requirements of 40 CFR §60.284 (date of installation notwithstanding) and the Department Continuous Emission Monitoring Systems Conditions (Appendix A). [§19.304, §19.501 et seq., and §19.801 et seq of Regulation #19; 40 CFR §60.283; and 40 CFR §60.284]

SN-55F, 56F, SN-94, SN-98, SN-99, SN-100
SN-103, SN-105, SN-106, SN-107, SN-108, SN-109, and SN-110

Slaker Vents, Green Liquor Clarifier A, "A" and "B" Side Causticizers, White Liquor Storage Tanks, Green Liquor Clarifier A, White Liquor Clarifier, Mud Washers A and B, Pre-Coats Filter, Green Liquor Stabilization Tank, and White Liquor Splitter Box

Source Description

Causticizing vents contributions are also included with the slaker emission estimates. The causticizing operation reacts molten inorganic salts from the smelt dissolving tanks with weak wash to form green liquor. Undissolved particles in the green liquor are allowed to settle out in the Green Liquor Clarifiers A or B (SN-94 and SN-103).

The mixing of green liquor with lime to form slurry is termed slaking. The slaking process is designed to combine green liquor and burnt lime (CaO). This mixing, which involves an exothermic chemical reaction, takes place in one of two Slakers. The emissions are exhausted through two adjacent Slaker Vents, SN-55 and SN-56. After being mixed with lime in the slakers the green liquor goes through a series of causticizing tanks. These causticizers provide the residence time necessary for the lime to react with the green liquor and form white liquor. White liquor is used as the main cooking liquor in the digester. The white liquor is allowed to settle in the White Liquor Clarifier (SN-105).

The facility also has four white liquor storage tanks (SN-100) of approximately 1 million (3) and 5 million (1) gallons.

As a result of the R10 modification, SN-103, SN-105, SN-106, SN-107, SN-108, SN-109, and SN-110 underwent PSD review for VOC. BACT is defined as no controls.

Specific Conditions

137. The permittee shall not exceed the emission rates set forth in the following table. Compliance with this Specific Condition is demonstrated by compliance with Specific Condition #68. [Regulation No. 19 §19.501 et seq. and 40 CFR Part 52, Subpart E]

SN	Description	Pollutant	lb/hr	ton/yr
55F	Lime Slaker Vent #1	PM_{10}	0.4	1.4
		VOC	0.7	2.5
		TRS	0.8	2.8
56F	Lime Slaker Vent #2	PM_{10}	0.4	1.4
		VOC	0.7	2.5
		TRS	0.8	2.8
94	Green Liquor Clarifier A	VOC	1.1	4.0
		TRS	0.1	0.1

SN	Description	Pollutant	lb/hr	ton/yr
98	"A" Side Causticizers	VOC	0.1	0.1
		TRS	0.4	1.2
99	"B" Side Causticizers	VOC	0.1	0.1
		TRS	0.4	1.2
100	White Liquor Storage Tanks (4 total)	VOC	0.2	0.6
		TRS	0.3	1.0
103	Green Liquor Clarifier B	TRS	0.1	0.1
106	Mud Washer A	TRS	0.1	0.2
107	Mud Washer B	TRS	0.1	0.2
108	Pre-Coats Filter	TRS	0.1	0.1
109	Green Liquor Stabilization Tank	TRS	0.1	0.2

138. The permittee shall not exceed the emission rates set forth in the following table. Compliance with this Specific Condition is demonstrated by compliance with Specific Condition #68. [Regulation No. 19 §19.501 et seq., §19.901, and 40 CFR Part 52, Subpart E]

SN	Description	Pollutant	lb/hr	ton/yr
103	Green Liquor Clarifier B	VOC	0.2	0.8
105	White Liquor Clarifier	VOC	0.2	0.7
106	Mud Washer A	VOC	1.4	5.2
107	Mud Washer B	VOC	1.4	5.2
108	Pre-Coats Filter	VOC	0.1	0.2
109	Green Liquor Stabilization Tank	VOC	0.6	2.4
110	White Liquor Splitter Box	VOC	0.2	0.7

139. The permittee shall not exceed the emission rates set forth in the following table. Compliance with this Specific Condition is demonstrated by compliance with Specific Condition #68. [Regulation No.§18.801 and A.C.A. §8-4-203 as referenced by §8-4-304 and §8-4-311]

SN	Description	Pollutant	lb/hr	ton/yr
55F	Lime Slaker Vent #1	Acetaldehyde	0.11	0.41
		Acetone	0.2	0.5
		Acrolein	0.01	0.01

SN	Description	Pollutant	lb/hr	ton/yr
		Ammonia	7.0	26.5
		Benzene	0.01	0.01
		Methanol	0.09	0.33
		Styrene	0.01	0.01
		Tetrachloroethylene	0.01	0.01
		Toluene	0.01	0.02
		1,2,4-Trichlorobenzene	0.01	0.01
		Xylene	0.01	0.01
56F	Lime Slaker Vent #2	Acetaldehyde	0.11	0.41
		Acetone	0.2	0.5
		Acrolein	0.01	0.01
		Ammonia	7.0	26.5
		Benzene	0.01	0.01
		Methanol	0.09	0.33
		Styrene	0.01	0.01
		Tetrachloroethylene	0.01	0.01
		Toluene	0.01	0.02
		1,2,4-Trichlorobenzene	0.01	0.01
		Xylene	0.01	0.01
94	Green Liquor Clarifier	Acetaldehyde	0.01	0.01
		Acetone	0.1	0.1
		Benzene	0.01	0.01
		Methanol	0.21	0.79
		Styrene	0.01	0.01
		Toluene	0.01	0.01
		Xylene	0.01	0.02
98	"A" Side Causticizers	Acetaldehyde	0.02	0.07
		Acetone	0.1	0.1
		Benzene	0.01	0.01
		Methanol	0.01	0.01
		Styrene	0.01	0.01
		Xylene	0.01	0.01
99	"B" Side Causticizers	Acetaldehyde	0.02	0.07
		Acetone	0.1	0.1
		Benzene	0.01	0.01
		Methanol	0.01	0.01
		Styrene	0.01	0.01
		Xylene	0.01	0.01
100	White Liquor Storage Tanks	Acetone	0.1	0.2
		Methanol	0.01	0.02
103	Green Liquor	Acetaldehyde*	0.01	0.01

SN	Description	Pollutant	lb/hr	ton/yr
	Clarifier B	Acetone	0.1	0.1
		Benzene*	0.01	0.01
		Methanol*	0.18	0.66
		Styrene*	0.01	0.01
		Toluene*	0.01	0.01
		Xylene*	0.01	0.02
105	White Liquor Clarifier	Acetone	0.1	0.1
		Benzene	0.01	0.01
		Formaldehyde	0.07	0.27
		Methanol	0.05	0.19
		Styrene	0.01	0.01
		Xylene	0.01	0.01
106	Mud Washer A	Acetone	0.1	0.1
		Benzene	0.01	0.01
		Formaldehyde	0.04	0.14
		Methanol	0.03	0.10
		Styrene	0.01	0.01
		Xylene	0.01	0.01
107	Mud Washer B	Acetone	0.1	0.1
		Benzene	0.01	0.01
		Formaldehyde	0.04	0.14
		Methanol	0.03	0.10
		Styrene	0.01	0.01
		Xylene	0.01	0.01
108	Pre-Coats Filter	Acetaldehyde	0.01	0.01
		Acetone	0.1	0.1
		Benzene	0.01	0.01
		Chloroform	0.01	0.01
		Methanol	0.04	0.14
		Tetrachloroethylene	0.01	0.01
		Toluene	0.01	0.01
		Xylene	0.01	0.01
109	Green Liquor Stabilization Tank	Acetaldehyde	0.04	0.14
		Acetone	0.2	0.6
		Chloroform	0.01	0.01
		Cresol	0.03	0.12
		Methanol	0.37	1.63
		Phenol	0.02	0.09
110	White Liquor Splitter Box	Acetone	0.1	0.1
		Benzene	0.01	0.01
		Formaldehyde	0.07	0.27

SN	Description	Pollutant	lb/hr	ton/yr
		Methanol	0.05	0.19
		Styrene	0.01	0.01
		Xylene	0.01	0.01

*Actual, unrounded emissions of all HAP are less than the total VOCs

SN-62 and 63
No. 1 and 2 Fine Paper Machines

Source Description

Communication paper is made on the two fine paper machines (No. 1 and 2 Fine Paper Machines). Each machine includes its own stock preparation, head box, wire section, press section, dryer sections, coater section, calendar stacks, reel and drum winder. The fine paper machines produce a variety of products, including but not limited to, bond paper, envelope, tablet and copier paper. Emissions from Fine Paper Machine No. 1 (SN-62) occur primarily from the fourdrinier vacuum pump exhausts, press section vents, dryer exhaust and coating section. Fine Paper Machine No. 2 (SN-63) is nearly identical to Fine Paper Machine No. 1.

Specific Conditions

140. The permittee shall not exceed the emission rates set forth in the following table. Compliance with this Specific Condition shall be demonstrated by compliance with Specific Condition #142. [Regulation No. 19 §19.501 et seq., §19.901, and 40 CFR Part 52, Subpart E]

SN	Description	Pollutant	lb/hr	ton/yr
62	Fine Paper Machine No. 1	VOC	18.6	81.3
			0.89 lb/ADTFP*	
63	Fine Paper Machine No. 2	VOC	11.3	49.3
			0.54 lb/ADTFP*	

*Air Dried Tons of Finished Paper

141. The permittee estimates the emission rates set forth in the following table will not be exceeded. The pollutant emission rates are effectively limited by Specific Condition #142. [Regulation No. §18.801 and A.C.A. §8-4-203 as referenced by §8-4-304 and §8-4-311]

SN	Description	Pollutant	lb/hr	ton/yr
62	Fine Paper Machine No. 1	Acetaldehyde	1.20	5.23
		Acetone	0.8	4.0
		Acrolein	0.05	0.20
		Formaldehyde	0.24	1.05
		Methanol	1.20	5.23
		Methylene Chloride	0.10	0.41
		Tetrachloroethylene	0.09	0.37
		1,2,4-Trichlorobenezene	0.05	0.22
		Xylene	0.03	0.11

SN	Description	Pollutant	lb/hr	ton/yr
62	Fine Paper Machine No. 2	Acetaldehyde	1.20	5.23
		Acetone	0.8	4.0
		Acrolein	0.05	0.20
		Formaldehyde	0.24	1.05
		Methanol	1.20	5.23
		Methylene Chloride	0.10	0.41
		Tetrachloroethylene	0.09	0.37
		1,2,4-Trichlorobenezene	0.05	0.22
		Xylene	0.03	0.11

Production Limits

142. The permittee shall not produce in excess of 1050 machine dried tons of paper per day from the Fine Paper Machines No. 1 and No. 2 combined, 30 day rolling average. A conversion factor of 1.05 MDT/ ADTFP is used to account for fiber loss. [§19.705 of Regulation #19, A.C.A. §8-4-203 as referenced by §8-4-304 and §8-4-311, and 40 CFR §70.6]

143. The permittee shall maintain records which demonstrate compliance with the paper production limits, VOC annual emission limits in tpy, and VOC BACT limits in lb/MDT listed in Specific Conditions #140 and #142. The records shall be updated on a monthly basis. These records shall be kept on site, provided to Department personnel upon request and may be used by the Department for enforcement purposes. A twelve month rolling total and each individual month's data shall be submitted in accordance with General Provision #7. [§19.705 of Regulation #19 and 40 CFR Part 52 Subpart E]

SN-64 and 65
Board Machine No. 3 and Burners

Source Description

The Board Machine No. 3 produces bleached board using the wet end, dry end and broke systems. The board is used primarily as cup stock and liner board for boxes. Emissions from Board Machine No. 3 occur primarily from the vacuum pump exhausts, press section vents, dryer exhausts, coating section and combustion sources in the coating section. Emissions from the wet end, dry end and coating operations of Board Machine No. 3 are bubbled together (SN-64). There are sixteen gas burners (SN-65) with a total heating value of 12.3 million Btu per hour located on the board machine following the coating operations.

Specific Conditions

144. The permittee shall not exceed the emission rates set forth in the following table. Compliance with this Specific Condition shall be demonstrated by compliance with Specific Conditions #148 and #149. [Regulation No. 19 §19.501 et seq. and 40 CFR Part 52, Subpart E]

SN	Description	Pollutant	lb/hr	ton/yr
65	Board Machine No. 3 Burners	PM_{10}	0.2	0.5
		SO_2	0.1	0.1
		VOC	0.1	0.4
		CO	1.3	5.5
		NO_x	1.5	6.5
		Pb	0.01	0.01

145. The permittee shall not exceed the emission rates set forth in the following table. Compliance with this Specific Condition shall be demonstrated by compliance with Specific Conditions #150. [Regulation No. 19 §19.501 et seq., §19.901, and 40 CFR Part 52, Subpart E]

SN	Description	Pollutant	lb/hr	ton/yr
64	Board Machine No. 3	VOC	10.6	46.4
			0.31 lb/ADTFP Annual Average	

*Air Dried Tons of Finished Paper

146. The permittee estimates the emission rates set forth in the following table will not be exceeded. The pollutant emission rates are effectively limited by Specific Conditions

#148 and #149. [Regulation No. §18.801 and A.C.A. §8-4-203 as referenced by §8-4-304 and §8-4-311]

SN	Description	Pollutant	lb/hr	ton/yr
64	Board Machine No. 3	Acetaldehyde	1.95	8.51
		Acetone	1.3	5.7
		Acrolein	0.08	0.32
		Formaldehyde	0.39	1.69
		Methanol	1.95	8.51
		Methylene Chloride	0.15	0.66
		Tetrachloroethylene	0.14	0.59
		1,2,4-Trichlorobenzene	0.09	0.36
		Xylene	0.04	0.18
65	Board Machine No. 3 Burners	PM	0.2	0.5
		Arsenic	0.01	0.01
		Benzene	0.01	0.01
		Cadmium	0.01	0.01
		Cobalt	0.01	0.01
		Formaldehyde	0.01	0.01
		Hexane	0.03	0.12
		Manganese	0.01	0.01
		Mercury	0.01	0.01
		Naphthalene	0.01	0.01
		Nickel	0.01	0.01
		Toluene	0.01	0.01

Opacity

147. The permittee shall not cause to be discharged to the atmosphere from the Board Machine No. 3 Burners (SN-65) gases which exhibit opacity greater than 5%. Compliance with this opacity limit shall be the use of natural gas only. [§18.501 of Regulation #18 and A.C.A. §8-4-203 as referenced by §8-4-304 and §8-4-11]

148. Natural gas shall be the only fuel used for the Board Machine No. 3 Burners (SN-65). [§18.1004 of Regulation #18, §19.705 of Regulation #19, A.C.A. §8-4-203 as referenced by §8-4-304 and §8-4-311, and 40 CFR §70.6]

Production Limits

149. The permittee shall not produce in excess of 850 machine dried tons of paper per day, 30 day rolling average, from the Board Machine No. 3. A conversion factor of 1.05 MDT/ ADTFP is used to account for fiber loss. [§18.1004 of Regulation #18, §19.705 of Regulation #19, A.C.A. §8-4-203 as referenced by §8-4-304 and §8-4-311, and 40 CFR §70.6]

150. The permittee shall maintain records which demonstrate compliance with the paper production limits, VOC annual emissions in tpy, and VOC BACT limits listed in Specific Conditions #145 and #149. The records shall be updated on a monthly basis. These records shall be kept on site, provided to Department personnel upon request and may be used by the Department for enforcement purposes. A twelve month rolling otal and each individual month's data shall be submitted in accordance with General Provision #7. [§18.1004 of Regulation #18, §19.705 of Regulation #19, 40 CFR Part 52 Subpart E, and A.C.A. §8-4-203 as referenced by §8-4-304 and §8-4-311]

Tissue Machines No. 4 through No. 8

Source Description

There are currently five tissue machines (Tissue Machines No. 4 through No. 8) at the Georgia-Pacific Crossett Paper Mill which manufacture tissue for conversion into bathroom tissue, towel, facial tissues, and napkins. In addition, the Mill also has an additional three machines that produce communications papers and bleached paperboard.

Pulp is supplied to the five tissue machines in varying proportions depending upon the desired product. The tissue papermaking process involves stock preparation, wet end - fourdrinier, press sections mix tanks and blend tanks, dry end - dryer sections with air hoods, reel and winder, and broke system finishing operations. Pulp stock is made into paper by forming a sheet on a continuously moving wire screen (the fourdrinier); removing water by gravity, vacuum and pressing, and drying with heated rolls. The water removed from the stock is called white water. The white water is collected for reuse in stock preparation or sewered as wastewater. Scrubbers control particulate from the reel sections of the No. 4 through No. 8 Tissue machines as well as the Rewinder of the No. 6 Tissue Machine.

Tissue converting includes the operations involved in converting large parent rolls of tissue from the tissue machines into finished products. This includes rewinding into smaller sized rolls, folding, printing, cutting, packaging and shipping.

Dust in the tissue converting area is controlled using filters with the exhaust air being recycled back into the building. Trim from the converting operations is sent to the repulpers by pneumatic systems. A cyclone removes the trim from the air stream prior to discharging the air through the roof. Minimal amounts of VOCs may be emitted from the glue that is used to seal boxes, the lubricants used on the machines and the dye used for printing patterns on the material.

SN-46, 66, and 67
Tissue Machine No. 4

Source Description

Emissions from the wet end and dry end of Tissue Machine No. 4 (SN-66) have been bubbled together. The Tissue Machine No. 4 Burners (SN-46) have a total heating rate of 20 million Btu per hour. Tissue Machine No. 4 Dust System (SN-67) uses a 20,000 cfm scrubber to control particulate matter emissions.

Specific Conditions

151. The permittee shall not exceed the emission rates set forth in the following table. Compliance with this Specific Condition shall be demonstrated by compliance with Specific Conditions #158 and #159. [Regulation No. 19 §19.501 et seq. and 40 CFR Part 52, Subpart E]

SN	Description	Pollutant	lb/hr	ton/yr
46	Tissue Machine No. 4 Burners	PM_{10}	0.2	0.8
		SO_2	0.1	0.1
		VOC	0.2	0.6
		CO	2.1	8.9
		NO_x	2.4	10.6
		Pb	0.01	0.01
67	Tissue Machine No. 4 Dust System	PM_{10}	0.3	1.1

152. The permittee shall not exceed the emission rates set forth in the following table. Compliance with this Specific Condition shall be demonstrated by compliance with Specific Conditions #159 and #160. [Regulation No. 19 §19.501 et seq., §19.901, and 40 CFR Part 52, Subpart E]

SN	Description	Pollutant	lb/hr	ton/yr
66	Tissue Machine No. 4	PM_{10}	0.5	2.0
			0.0646 lb/ ADTFP*	
		VOC	17.0	74.5
			2.47 lb/ADTFP* Annual Average	

*Air Dried Tons of Finished Paper

153. The permittee estimates the emission rates set forth in the following table will not be exceeded. The pollutant emission rates are effectively limited by Specific Conditions

#158 and #159. [Regulation No.§18.801 and A.C.A. §8-4-203 as referenced by §8-4-304 and §8-4-311]

SN	Description	Pollutant	lb/hr	ton/yr
46	Tissue Machine No. 4 Burners	Arsenic	0.01	0.01
		Benzene	0.01	0.01
		Cadmium	0.01	0.01
		Cobalt	0.01	0.01
		Formaldehyde	0.01	0.01
		Hexane	0.05	0.19
		Manganese	0.01	0.01
		Mercury	0.01	0.01
		Naphthalene	0.01	0.01
		Nickel	0.01	0.01
		Toluene	0.01	0.01
66	Tissue Machine No. 4	Acetaldehyde	0.11	0.47
		Biphenyl	0.81	3.54
		Chloroform	0.03	0.10
		Formaldehyde	0.01	0.01
		Methanol	0.05	0.19
		Methylene Chloride	0.01	0.04
		Phenol	0.18	0.76
		Propionaldehyde	0.01	0.01
		Toluene	0.03	0.10
67	Tissue Machine No. 4 Dust System	PM	0.3	1.1

Opacity

154. The permittee shall not cause to be discharged to the atmosphere from SN-46 and SN-67 gases which exhibit opacity greater than 5%. Compliance with this opacity limit shall be the use of natural gas only for SN-46. §18.501 of Regulation #18 and A.C.A. §8-4-203 as referenced by §8-4-304 and §8-4-311]

155. The permittee shall conduct weekly observations of the opacity at SN-67. Observations shall be conducted by personnel familiar with the permittee's visible emissions. If visible emissions in excess of the permitted opacity are detected, then a Method 9 reading is required. The permittee shall then take immediate action to identify the cause of the visible emissions, implement all necessary corrective action, and reassess the visible emissions after corrective action is taken. The permittee shall maintain records related to all observations/readings, to be updated on a weekly basis. The records shall contain the date and time of each observation/reading, the cause of any observed exceedance of opacity limits, corrective action taken, and results of the reassessment, and the name of

the person conducting the observation/reading. The records shall be kept on site and made available to Department personnel upon request. [§19.705 of Regulation 19 and 40 CFR Part 52, Subpart E]

156. The permittee shall not cause to be discharged to the atmosphere from SN-66 gases which exhibit any visible emissions exceeding 6 minutes during a 60-minute period. The permittee shall check for the presence of visible emissions from each corner of the building housing SN-66 once during each calendar week. This test will not be an EPA Method 9 test, only a yes/no check for visible emissions, and does not require that the observer be a certified visible emission reader. If visible emissions are detected for more than 6 minutes per hour, then the permittee shall determine the source of the visible emissions. Once the source is identified, the permittee shall immediately take action to identify the cause of the visible emissions, implement corrective action, and document that visible emissions did not appear following the corrective action. The permittee shall maintain log records which contain the following items in order to demonstrate compliance with this specific condition. These records shall be updated weekly, kept on site, and made available to Department personnel upon request. [§19.503 and §19.901 et seq of Regulation #19, and 40 CFR Part 52 Subpart E]

a. The date and time of the observation

b. If visible emissions were detected

c. If visible emissions were detected, the source number causing the visible emissions, the cause of the visible emissions, the corrective action taken, and whether any visible emissions appeared after the corrective action was taken.

d. The name of the person conducting the observation.

157. The permittee may, in the event of emergency maintenance on SN-67 (Tissue No. 4 Dust System), shut down the dust collection system and contain the tissue dust within the building during the continued operation of the paper machine. Good housekeeping practices shall be used to control tissue dust and prevent visible emissions to the atmosphere. In the event that repairs on a scrubber extend beyond 12 hours, then a 6 minute observation for visible emissions shall be conducted once per 12 hour shift. The observation shall be a yes/no check and shall be conducted at the outside corners of the affected Tissue Machine building. If visible tissue dust emissions are detected for more than 6 minutes per hour, then corrective action shall be taken to reduce emissions and document that visible emissions do not appear after corrective action is taken. [§19.303 of Regulation #19 and A.C.A. §8-4-203 as referenced by §8-4-304 and §8-4-311]

Fuel Requirements

158. Natural gas shall be the only fuel used for Tissue Machine No. 4 Burners (SN-46). [§18.1004 of Regulation #18, §19.705 of Regulation #19, A.C.A. §8-4-203 as referenced by §8-4-304 and §8-4-311, and 40 CFR §70.6]

Production Limits

159. The permittee shall not produce in excess of 173 machine dried tons of paper per day, 30 day rolling average, from the Tissue Machine No. 4. A conversion factor of 1.05 MDT/ ADTFP is used to account for fiber loss. [§18.1004 of Regulation #18, §19.705 of Regulation #19, A.C.A. §8-4-203 as referenced by §8-4-304 and §8-4-311, and 40 CFR §70.6]

160. The permittee shall maintain records which demonstrate compliance with the paper production limits, VOC annual emission, and VOC BACT limits listed in Specific Conditions #152 and #159. The records shall be updated on a monthly basis. These records shall be kept on site, provided to Department personnel upon request and may be used by the Department for enforcement purposes. A twelve month rolling total and each individual month's data shall be submitted in accordance with General Provision #7. [§18.1004 of Regulation #18, §19.705 of Regulation #19, 40 CFR Part 52 Subpart E, and A.C.A. §8-4-203 as referenced by §8-4-304 and §8-4-311]

Scrubber Monitoring

161. The scrubber shall be kept in good working condition at all times and shall meet the conditions shown in the following table. The scrubber liquid flow rate shall be measured daily. The results shall be kept on site and be available to Department personnel upon request. [§18.1104 of Regulation #18, §19.303 of Regulation #19, and A.C.A. §8-4-203 as referenced by §8-4-304 and §8-4 311]

SN	Control Equipment	Parameter	Units	Minimum Operating Limits
67	scrubber	liquid flow rate	gal/min	70

SN-47, 54, and 68
Tissue Machine No. 5

Source Description

Emissions from the wet end and dry end of Tissue Machine No. 5 (SN-68) have been bubbled together. The Tissue Machine No. 5 Burners (SN-47) are rated at 21 million Btu per hour. The burners are low NO_X burners. The Tissue Machine No. 5 Dust System (SN-54) uses a 20,000 cfm scrubber to control particulate matter emissions. The No. 5 Tissue Machine Burners (SN-47) underwent a BACT review in Air Permit 597-AOP-R0. Clean fuel, good combustion practice, and low NO_x burners were chosen as BACT at the time.

Specific Conditions

162. The permittee shall not exceed the emission rates set forth in the following table. Compliance with this Specific Condition shall be demonstrated by compliance with Specific Condition #169 and #170. [Regulation No. 19 §19.501 et seq. and 40 CFR Part 52, Subpart E]

SN	Description	Pollutant	lb/hr	ton/yr
47	Tissue Machine No. 5 Burners	Pb	0.01	0.01
54	Tissue Machine No. 5 Dust System	PM_{10}	0.3	1.1

163. The permittee shall not exceed the emission rates set forth in the following table. Compliance with this Specific Condition shall be demonstrated by compliance with Specific Conditions #169, #170. [§19.501 et seq. and §19.901 of Regulation #19, and 40 CFR Part 52 Subpart E]

SN	Description	Pollutant	lb/hr	ton/yr
47	Tissue Machine No. 5 Burners	PM	0.4	1.5
		PM_{10}	0.0164 lb/MMBtu	
		SO_2	0.1	0.1
			0.0007 lb/MMBtu	
		VOC	1.2	5.2
			0.0564 lb/MMBtu	
		CO	4.5	19.7
			0.2142 lb/MMBtu	
		NO_X	2.0	8.4

SN	Description	Pollutant	lb/hr	ton/yr
			0.0913 lb/MMBtu	
68	Tissue Machine No. 5	PM PM_{10}	0.3	1.1
			0.0646 lb/ ADTFP*	
		VOC	13.0	57.0
			3.37 lb/ ADTFP* Annual Average	

*Air Dried Tons of Finished Paper

164. The permittee estimates the emission rates set forth in the following table will not be exceeded. The pollutant emission rates are effectively limited by Specific Conditions #169 and #170. [Regulation No.§18.801 and A.C.A. §8-4-203 as referenced by §8-4-304 and §8-4-311]

SN	Description	Pollutant	lb/hr	ton/yr
47	Tissue Machine No. 5 Burners	Arsenic	0.01	0.01
		Benzene	0.01	0.01
		Cadmium	0.01	0.01
		Cobalt	0.01	0.01
		Formaldehyde	0.01	0.01
		Hexane	0.05	0.20
		Manganese	0.01	0.01
		Mercury	0.01	0.01
		Naphthalene	0.01	0.01
		Nickel	0.01	0.01
		Toluene	0.01	0.01
54	Tissue Machine No. 5 Dust System	PM	0.3	1.1
68	Tissue Machine No. 5	Acetaldehyde	0.07	0.27
		Biphenyl	0.46	1.99
		Chloroform	0.02	0.06
		Formaldehyde	0.01	0.01
		Methanol	0.03	0.11
		Methylene Chloride	0.01	0.03
		Phenol	0.10	0.43
		Propionaldehyde	0.01	0.01
		Toluene	0.02	0.06

Opacity

165. The permittee shall not cause to be discharged to the atmosphere from SN-47 and SN-54 gases which exhibit opacity greater than 5%. Compliance with this opacity limit shall be the use of natural gas only at SN-47. [§18.501 of Regulation #18 and A.C.A. §8-4-203 as referenced by §8-4-304 and §8-4-311]

166. The permittee shall conduct weekly observations of the opacity at SN-54. Observations shall be conducted by personnel familiar with the permittee's visible emissions. If visible emissions in excess of the permitted opacity are detected, then a Method 9 reading is required. The permittee shall then take immediate action to identify the cause of the visible emissions, implement all necessary corrective action, and reassess the visible emissions after corrective action is taken. The permittee shall maintain records related to all observations/readings, to be updated on a weekly basis. The records shall contain the date and time of each observation/reading, the cause of any observed exceedance of opacity limits, corrective action taken, and results of the reassessment, and the name of the person conducting the observation/reading. The records shall be kept on site and made available to Department personnel upon request. [§19.705 of Regulation 19 and 40 CFR Part 52, Subpart E]

167. The permittee shall not cause to be discharged to the atmosphere from SN-68 gases which exhibit any visible emissions exceeding 6 minutes during a 60-minute period. The permittee shall check for the presence of visible emissions from each corner of the building housing SN-68 once during each calendar week. This test will not be an EPA Method 9 test, only a yes/no check for visible emissions, and does not require that the observer be a certified visible emission reader. If visible emissions are detected for more than 6 minutes per hour, then the permittee shall determine the source of the visible emissions. Once the source is identified, the permittee shall immediately take action to identify the cause of the visible emissions, implement corrective action, and document that visible emissions did not appear following the corrective action. The permittee shall maintain log records which contain the following items in order to demonstrate compliance with this specific condition. These records shall be updated weekly, kept on site, and made available to Department personnel upon request. [§19.503 and §19.901 et seq of Regulation #19, and 40 CFR Part 52 Subpart E]

a. The date and time of the observation

b. If visible emissions were detected

c. If visible emissions were detected, the source number causing the visible emissions, the cause of the visible emissions, the corrective action taken, and whether any visible emissions appeared after the corrective action was taken.

d. The name of the person conducting the observation.

168. The permittee may, in the event of emergency maintenance on SN-54, shut down the dust collection system and contain the tissue dust within the building during the continued operation of the paper machine. Good housekeeping practices shall be used to control tissue dust and prevent visible emissions to the atmosphere. In the event that repairs on a scrubber extend beyond 12 hours, then a 6 minute observation for visible emissions shall be conducted once per 12 hour shift. The observation shall be a yes/no check and shall be conducted at the outside corners of the affected Tissue Machine building. If visible tissue dust emissions are detected for more than 6 minutes per hour, then corrective action shall be taken to reduce emissions and document that visible emissions do not appear after corrective action is taken. [§19.303 of Regulation #19 and A.C.A. §8-4-203 as referenced by §8-4-304 and §8-4-311]

Fuel Requirements

169. Natural gas shall be the only fuel used for the Tissue Machine No. 5 Burners (SN-47). [§19.705 of Regulation #19, A.C.A. §8-4-203 as referenced by §8-4-304 and §8-4-311, and 40 CFR §70.6]

Production Limits

170. The permittee shall not produce in excess of 97 machine dried tons of paper per day, 30 day rolling average, from the Tissue Machine No. 5. A conversion factor of 1.05 MDT/ ADTFP is used to account for fiber loss. [§18.1004 of Regulation #18, §19.705 of Regulation #19, A.C.A. §8-4-203 as referenced by §8-4-304 and §8-4-311, and 40 CFR §70.6]

171. The permittee shall maintain records which demonstrate compliance with the paper production limits, paper machine VOC annual emission, and paper machine VOC BACT limits listed in Specific Conditions #167 and #170. The records shall be updated on a monthly basis. These records shall be kept on site, provided to Department personnel upon request and may be used by the Department for enforcement purposes. A twelve month rolling total and each individual month's data shall be submitted in accordance with General Provision #7. [§18.1004 of Regulation #18, §19.705 of Regulation #19, 40 CFR Part 52 Subpart E, and A.C.A. §8-4-203 as referenced by §8-4-304 and §8-4-311]

Scrubber Monitoring

172. The scrubber shall be kept in good working condition at all times and shall meet the conditions shown in the following table. The scrubber liquid flow rate and the gas pressure drop across the unit shall be measured daily. The results shall be kept on site and be available to the Department personnel upon request. [§18.1104 of Regulation #18 and A.C.A. §8-4-203 as referenced by §8-4-304 and §8-4-311]

SN	Control Equipment	Parameter	Units	Minimum Operating Limits
54	scrubber	liquid flow rate	gal/min	70
		gas pressure drop across unit	inches, H_20	8

Testing Requirements

173. The permittee shall test SN-47 for CO and NO_X to verify compliance with the BACT emission limits specified in Specific Condition #167 every five years. Testing shall be performed in accordance with Plantwide Condition #3. Testing for CO and NO_X shall also be performed in accordance with EPA Reference Methods 10 and 7E respectively. During the test the permittee shall operate the source within 10 percent of the rated throughput capacity. If 90 percent of the rated throughout capacity cannot be achieved, the permittee shall be limited to 10 percent above the actual tested throughput. The permittee shall reference this limitation in any compliance reports submitted to the Department. [§19.702 and §19.901 et seq of Regulation #19, and 40 CFR Part 52 Subpart E]

SN-48, 51, 52, and 69
Tissue Machine No. 6

Source Description

Emissions from the wet end and dry end of Tissue Machine No. 6 (SN-69) have been bubbled together. The Tissue Machine No. 6 Burners (SN-48) are rated at 41.0 million Btu per hour. The burners are low NO_X burners. Tissue Machine No. 6 Dust System (SN-52) uses a 47,000 cfm scrubber to control particulate matter emissions. A 47,000 cfm scrubber is used to control particulate emissions from the Rewinder (SN-51) near Tissue Machine No. 6. The No. 6 Tissue Machine Burners (SN-48) underwent a BACT review in Air Permit 597-AOP-R0. Clean fuel, good combustion practice, and low NO_x burners were chosen as BACT at the time.

The R11 modification was for the replacement of the No. 6 Tissue Machine Burners (SN-48). The facility replaced the existing Hauck burners with Maxon burners rated at 20.5 MMBTU/hr each. BACT limits for particulate and VOC decreased. The source will continue to meet the CO, NO_x, and SO_2 limits.

Specific Conditions

174. The permittee shall not exceed the emission rates set forth in the following table. Compliance with this Specific Condition shall be demonstrated by compliance with Specific Conditions #182 and #190. [Regulation No. 19 §19.501 et seq. and 40 CFR Part 52, Subpart E]

SN	Description	Pollutant	lb/hr	ton/yr
48	Tissue Machine No. 6 Burners (41 MMBtu/hr)	Pb	0.01	0.01
51	Tissue Machine No. 6 Rewinder	PM_{10}	0.5	1.9
52	Tissue Machine No. 6 Dust System	PM_{10}	0.5	1.9

175. The permittee shall not exceed the emission rates set forth in the following table. Compliance with this Specific Condition shall be demonstrated by compliance with Specific Conditions #189. [§19.501 et seq. and §19.901 of Regulation #19, and 40 CFR Part 52 Subpart E]

SN	Description	Pollutant	lb/hr	ton/yr
48	Tissue Machine No. 6 Burners (41 MMBtu/hr)	PM PM_{10}	0.4	1.8
			0.00912 lb/MMBtu	
		SO_2	0.1	0.2
			0.0007 lb/MMBtu	
		VOC	0.3	1.4
			0.0066 lb/MMBtu	
		CO	4.7	20.6
			0.1139 lb/MMBtu	
		NO_X	3.8	16.7
			0.0913 lb/MMBtu	
69	Tissue Machine No. 6	PM_{10} PM	0.7	3.1
			0.0646 lb/ ADTFP*	
		VOC	26.7	116.6
			2.48 lb/ ADTFP*	

*Air Dried Tons of Finished Paper

176. The permittee estimates the emission rates set forth in the following table will not be exceeded. The pollutant emission rates are effectively limited by Specific Conditions #188 and #190. [Regulation No.§18.801 and A.C.A. §8-4-203 as referenced by §8-4-304 and §8-4-311]

SN	Description	Pollutant	lb/hr	ton/yr
48	Tissue Machine No. 6 Burners	Arsenic	0.01	0.01
		Benzene	0.01	0.01
		Cadmium	0.01	0.01
		Cobalt	0.01	0.01
		Formaldehyde	0.01	0.02
		Hexane	0.09	0.39
		Manganese	0.01	0.01
		Mercury	0.01	0.01
		Naphthalene	0.01	0.01
		Nickel	0.01	0.01
		Toluene	0.01	0.01
51	Tissue Machine No. 6 Rewinder	PM	0.5	1.9

SN	Description	Pollutant	lb/hr	ton/yr
52	Tissue Machine No. 6 Dust System	PM	0.5	1.9
69	Tissue Machine No. 6	Acetaldehyde	0.17	0.74
		Biphenyl	1.26	5.52
		Chloroform	0.04	0.15
		Formaldehyde	0.01	0.01
		Methanol	0.07	0.29
		Methylene Chloride	0.02	0.08
		Phenol	0.27	1.19
		Propionaldehyde	0.01	0.01
		Toluene	0.04	0.15

Opacity

177. The permittee shall not cause to be discharged to the atmosphere from SN-48, SN-51, and SN-52 gases which exhibit opacity greater than 5%. Compliance with this opacity limit shall be the use of natural gas only at SN-48. [§18.501 of Regulation #18 and A.C.A. §8-4-203 as referenced by §8-4-304 and §8-4-311]

178. The permittee shall conduct weekly observations of the opacity at SN-51 and 52. Observations shall be conducted by personnel familiar with the permittee's visible emissions. If visible emissions in excess of the permitted opacity are detected, then a Method 9 reading is required. The permittee shall then take immediate action to identify the cause of the visible emissions, implement all necessary corrective action, and reassess the visible emissions after corrective action is taken. The permittee shall maintain records related to all observations/readings, to be updated on a weekly basis. The records shall contain the date and time of each observation/reading, the cause of any observed exceedance of opacity limits, corrective action taken, and results of the reassessment, and the name of the person conducting the observation/reading. The records shall be kept on site and made available to Department personnel upon request. [§19.705 of Regulation 19 and 40 CFR Part 52, Subpart E]

179. The permittee shall not cause to be discharged to the atmosphere from SN-69 gases which exhibit any visible emissions exceeding 6 minutes during a 60-minute period. The permittee shall check for the presence of visible emissions from each corner of the building housing SN-69 once during each calendar week. This test will not be an EPA Method 9 test, only a yes/no check for visible emissions, and does not require that the observer be a certified visible emission reader. If visible emissions are detected for more than 6 minutes per hour, then the permittee shall determine the source of the visible emissions. Once the source is identified, the permittee shall immediately take action to identify the cause of the visible emissions, implement corrective action, and document that visible emissions did not appear following the corrective action. The permittee shall

maintain log records which contain the following items in order to demonstrate compliance with this specific condition. These records shall be updated weekly, kept on site, and made available to Department personnel upon request. [§19.503 and §19.901 et seq of Regulation #19, and 40 CFR Part 52 Subpart E]

a. The date and time of the observation.

b. If visible emissions were detected.

c. If visible emissions were detected, the source number causing the visible emissions, the cause of the visible emissions, the corrective action taken, and whether any visible emissions appeared after the corrective action was taken.

d. The name of the person conducting the observation.

Scrubber Monitoring

180. The permittee shall keep the scrubber on SN-52 in good working condition at all times and shall meet the conditions shown in the following table. The scrubber liquid flow rate and the gas pressure drop across the unit shall be measured daily. The results shall be kept on site and be available to the Department personnel upon request. [§18.1104 of Regulation #18 and A.C.A. §8-4-203 as referenced by §8-4-304 and §8-4-311]

SN	Control Equipment	Parameter	Units	Minimum Operating Limits
52	scrubber	liquid flow rate	gal/min	300
		gas pressure drop across unit	inches, H_20	8

181. The permittee may, in the event of emergency maintenance on SN-52, shut down the dust collection system and contain the tissue dust within the building during the continued operation of the paper machine. Good housekeeping practices shall be used to control tissue dust and prevent visible emissions to the atmosphere. In the event that repairs on a scrubber extend beyond 12 hours, then a 6 minute observation for visible emissions shall be conducted once per 12 hour shift. The observation shall be a yes/no check and shall be conducted at the outside corners of the affected Tissue Machine building. If visible tissue dust emissions are detected for more than 6 minutes per hour, then corrective action shall be taken to reduce emissions and document that visible emissions do not appear after corrective action is taken. [§19.303 of Regulation #19 and A.C.A. §8-4-203 as referenced by §8-4-304 and §8-4-311]

Fuel Requirements

182. Natural gas shall be the only fuel used for the Tissue Machine No. 6 Burners (SN-48). [§19.705 of Regulation #19, A.C.A. §8-4-203 as referenced by §8-4-304 and §8-4-311, and 40 CFR §70.6]

Production Limits

183. The permittee shall not produce in excess of 270 machine dried tons of paper per day, 30 day rolling average, from the Tissue Machine No. 6. A conversion factor of 1.05 MDT/ ADTFP is used to account for fiber loss. [§18.1004 of Regulation #18, §19.705 of Regulation #19, A.C.A. §8-4-203 as referenced by A.C.A. §8-4-304 and §8-4-311, and 40 CFR §70.6]

184. The permittee shall maintain records which demonstrate compliance with the paper production limits, the paper machine VOC annual emissions, and the paper machine VOC BACT limits Specific Condition #175 and #183. The records shall be updated on a monthly basis. These records shall be kept on site, provided to Department personnel upon request and may be used by the Department for enforcement purposes. A twelve month rolling total and each individual month's data shall be submitted in accordance with General Provision #7. [§18.1004 of Regulation #18, §19.705 of Regulation #19, 40 CFR Part 52 Subpart E, and A.C.A. §8-4-203 as referenced by §8-4-304 and §8-4-311]

Testing Requirements

185. The permittee shall test SN-48 for CO and NO_X to verify compliance with the BACT emission limits specified in Specific Condition #180 every five years thereafter. Testing shall be performed in accordance with Plantwide Condition #3. Testing for CO and NO_X shall also be performed in accordance with EPA Reference Methods 10 and 7E respectively. During the test the permittee shall operate the source within 10 percent of the rated throughput capacity. If 90 percent of the rated throughout capacity cannot be achieved, the permittee shall be limited to 10 percent above the actual tested throughput. The permittee shall reference this limitation in any compliance reports submitted to the Department. [§19.702 and §19.901 of Regulation #19, and 40 CFR Part 52 Subpart E]

SN-49, 50, and 70
Tissue Machine No. 7

Emissions from the wet end and dry end of Tissue Machine No. 7 (SN-70) have been bubbled together. The Tissue Machine No. 7 Burners (SN-49) combust natural gas at a total heating rate of 41 million Btu per hour. The burners are low NO_X burners. Tissue Machine No. 7 Dust System (SN-50) uses a 44,000 cfm scrubber to control particulate matter emissions.

186. The permittee shall not exceed the emission rates set forth in the following table. Compliance with this Specific Condition shall be demonstrated by compliance with Specific Conditions #197 and #198. [Regulation No. 19 §19.501 et seq. and 40 CFR Part 52, Subpart E]

SN	Description	Pollutant	lb/hr	ton/yr
49	Tissue Machine No. 7 Burners	PM_{10}	0.4	1.7
		SO_2	0.1	0.2
		VOC	0.3	1.2
		CO	4.2	18.2
		NO_x	2.5	10.8
		Pb	0.01	0.01
50	Tissue Machine No. 7 Dust System	PM_{10}	0.5	2.1

187. The permittee shall not exceed the emission rates set forth in the following table. Compliance with this Specific Condition shall be demonstrated by compliance with Specific Condition #198. [§19.501 et seq. and §19.901 of Regulation #19, and 40 CFR Part 52 Subpart E]

SN	Description	Pollutant	lb/hr	ton/yr
70	Tissue Machine No. 7	PM_{10} PM	0.7	2.9
			0.0646 lb/ ADTFP*	
		VOC	17.7	77.4
			1.78 lb/ ADTFP* Annual Average	

*Air Dried Tons of Finished Paper

188. The permittee estimates the emission rates set forth in the following table will not be exceeded. The pollutant emission rates are effectively limited by Specific Conditions #197 and #198. [Regulation No.§18.801 and A.C.A. §8-4-203 as referenced by §8-4-304 and §8-4-311]

SN	Description	Pollutant	lb/hr	ton/yr
49	Tissue Machine No. 7 Burners	PM	0.4	1.7
		Arsenic	0.01	0.01
		Benzene	0.01	0.01
		Cadmium	0.01	0.01
		Cobalt	0.01	0.01
		Formaldehyde	0.01	0.02
		Hexane	0.09	0.39
		Manganese	0.01	0.01
		Mercury	0.01	0.01
		Naphthalene	0.01	0.01
		Nickel	0.01	0.01
		Toluene	0.01	0.01
50	Tissue Machine No. 7 Dust System	PM	0.5	2.1
70	Tissue Machine No. 7	Acetaldehyde	0.16	0.68
		Biphenyl	1.17	5.11
		Chloroform	0.04	0.14
		Formaldehyde	0.01	0.01
		Methanol	0.07	0.27
		Methylene Chloride	0.02	0.06
		Phenol	0.25	1.10
		Propionaldehyde	0.01	0.01
		Toluene	0.04	0.14

Opacity

189. The permittee shall not cause to be discharged to the atmosphere from SN-49 and SN-50 gases which exhibit opacity greater than 5%. Compliance with this opacity limit shall be the use of natural gas only at SN-49. [§18.501 of Regulation #18 and A.C.A. §8-4-203 as referenced by §8-4-304 and §8-4-311]

190. The permittee shall conduct weekly observations of the opacity at SN-50. Observations shall be conducted by personnel familiar with the permittee's visible emissions. If visible emissions in excess of the permitted opacity are detected, then a Method 9 reading is required. The permittee shall then take immediate action to identify the cause of the visible emissions, implement all necessary corrective action, and reassess the visible emissions after corrective action is taken. The permittee shall maintain records related to all observations/readings, to be updated on a weekly basis. The records shall contain the date and time of each observation/reading, the cause of any observed exceedance of opacity limits, corrective action taken, and results of the reassessment, and the name of the person conducting the observation/reading. The records shall be kept on site and

made available to Department personnel upon request. [§19.705 of Regulation 19 and 40 CFR Part 52, Subpart E]

191. The permittee shall not cause to be discharged to the atmosphere from SN-70 gases which exhibit any visible emissions exceeding 6 minutes during a 60-minute period. The permittee shall check for the presence of visible emissions from each corner of the building housing SN-70 once during each calendar week. This test will not be an EPA Method 9 test, only a yes/no check for visible emissions, and does not require that the observer be a certified visible emission reader. If visible emissions are detected for more than 6 minutes per hour, then the permittee shall determine the source of the visible emissions. Once the source is identified, the permittee shall immediately take action to identify the cause of the visible emissions, implement corrective action, and document that visible emissions did not appear following the corrective action. The permittee shall maintain log records which contain the following items in order to demonstrate compliance with this specific condition. These records shall be updated weekly, kept on site, and made available to Department personnel upon request. [§19.503 and §19.901 et seq of Regulation #19, and 40 CFR Part 52 Subpart E]

a. The date and time of the observation.

b. If visible emissions were detected.

c. If visible emissions were detected, the source number causing the visible emissions, the cause of the visible emissions, the corrective action taken, and whether any visible emissions appeared after the corrective action was taken.

d. The name of the person conducting the observation.

192. The permittee may, in the event of emergency maintenance on SN-50, shut down the dust collection system and contain the tissue dust within the building during the continued operation of the paper machine. Good housekeeping practices shall be used to control tissue dust and prevent visible emissions to the atmosphere. In the event that repairs on a scrubber extend beyond 12 hours, then a 6 minute observation for visible emissions shall be conducted once per 12 hour shift. The observation shall be a yes/no check and shall be conducted at the outside corners of the affected Tissue Machine building. If visible tissue dust emissions are detected for more than 6 minutes per hour, then corrective action shall be taken to reduce emissions and document that visible emissions do not appear after corrective action is taken. [§19.303 of Regulation #19 and A.C.A. §8-4-203 as referenced by §8-4-304 and §8-4-311]

Fuel Requirements

193. Natural gas shall be the only fuel used for Tissue Machine No. 7 Burners (SN-49). [§18.1004 of Regulation #18, §19.705 of Regulation #19, A.C.A. §8-4-203 as referenced by §8-4-304 and §8-4-311, and 40 CFR §70.6]

Production Limits

194. The permittee shall not produce in excess of 250 machine dried tons of paper per day, 30 day rolling average, from the Tissue Machine No. 7. A conversion factor of 1.05 MDT/ ADTFP is used to account for fiber loss. [§18.1004 of Regulation #18, §19.705 of Regulation #19, A.C.A. §8-4-203 as referenced by §8-4-304 and §8-4-311, and 40 CFR §70.6]

195. The permittee shall maintain records which demonstrate compliance with the paper production limits, the VOC annual emissions, and the VOC BACT limits Specific Condition #187 and #194. The records shall be updated on a monthly basis. These records shall be kept on site, provided to Department personnel upon request and may be used by the Department for enforcement purposes. A twelve month rolling total and each individual month's data shall be submitted in accordance with General Provision #7. [§18.1004 of Regulation #18, §19.705 of Regulation #19, 40 CFR Part 52 Subpart E, and A.C.A. §8-4-203 as referenced by §8-4-304 and §8-4-311]

CAM

196. The Tissue Machine No. 7 Dust System (SN-50) is subject to and shall comply with all applicable provisions of §19.304 of Regulation 19, 40 CFR Part 52 Subpart E, and Part §64.6 for Compliance Assurance Monitoring. Post control of particulate emissions from SN-50 is below major source levels.

a. The permittee shall maintain a scrubber liquid flow rate of at least 300 gallons per minute. [40 CFR Part §64.6(c)(1)]

b. The permittee shall monitor and maintain daily records to demonstrate compliance with Specific Condition #196 (A). Records shall be kept onsite and made available to the Department upon request. [40 CFR Part §64.6(c)(3)]

c. The permittee shall maintain the scrubber in good working condition at all times so that pollutant removal is maintained. [40 CFR Part §64.6(c)(1)]

197. The Tissue Machine No. 7 Dust System (SN-50) is subject to and shall comply with all applicable provisions §19.304 of Regulation 19, 40 CFR Part 52 Subpart E, and Part §64.6 for Compliance Assurance Monitoring. The following information pertaining to exceedances or excursions from permitted values shall be submitted in semi-annual reports in accordance with General Provision #7 as outlined in 40 CFR §70.6.

a. The permittee shall maintain records for SN-50 that summarizes the number, duration, and cause of excursions or exceedances of emission limits as well as corrective action taken. [40 CFR §64.9(a)(2)(i) and §64.9(b)]

b. The permittee shall maintain records for SN-50 that summarizes the number, duration, and cause of monitoring equipment downtime incidents, other than routine downtime for calibration checks. [40 CFR §64.9(a)(2)(ii) and §64.9(b)]

c. The permittee shall maintain a quality improvement plan (QIP) threshold for each indicator of no more than nine excursions or 5% of the daily averages in a six-month period. [40 CFR §64.9(a)(2)(iii) and §64.9(b)]

d. The permittee shall develop and implement a new QIP if the threshold is exceeded during any six-month period. [40 CFR §64.9(a)(2)(iii) and §64.9(b)]

e. The permittee shall maintain records for SN-50 that describes the actions taken to implement the QIP. Upon completion of the QIP, documentation shall be maintained to confirm that the plan was completed and reduced the likelihood of similar excursions or exceedances. [40 CFR §64.9(a)(2)(iii) and §64.9(b)]

SN-79, 80, and 81
Tissue Machine No. 8

Source Description

The Tissue Machine No. 8 Burners (SN-79) combusts natural gas at a total heating rate of 50 million Btu per hour. The burners are low NO_X burners. Tissue Machine No. 8 Dust System (SN-81) is equipped with a 58,000 cfm wet venturi scrubber dust system to control particulate matter emissions.

The No. 8 Tissue Machine (SN-80) and associate equipment was subjected to a BACT review in Air Permit 597-AOP-R0. Clean fuel, good combustion practice, and low NO_x burners were chosen as BACT for the burners. For particulate control on the dust system, a wet scrubber was determined as BACT.

The proposed project, which is expected to improve production efficiency and allow for an increase in the paper machine design capacity. There will not be any changes made to the existing Yankee Dryer section of the tissue machine or the Yankee Dryer burners as part of this project. The changes will include replacement of the paper machine press section on the existing tissue machine to allow for more energy efficient drying and replacement of the dry end dust collection equipment on the existing tissue machine, including a new wet venturi scrubber rated at 58,000 dry standard cubic feet per minute (dscfm). This new dust collection equipment will replace the existing wet venturi scrubber (SN-81, rated at 55,000 dscfm) and will be used to reduce particulate matter emissions from the dry end of the paper machine and wind-up reel.

Specific Conditions

198. The permittee shall not exceed the emission rates set forth in the following table. Compliance with this Specific Condition shall be demonstrated by compliance with Specific Condition #205. [Regulation No. 19 §19.501 et seq. and 40 CFR Part 52, Subpart E]

SN	Description	Pollutant	lb/hr	ton/yr
79	Tissue Machine No. 8 Burners	Pb	0.01	0.01

199. The permittee shall not exceed the emission rates set forth in the following table. Compliance with this Specific Condition shall be demonstrated by compliance with Specific Conditions #205, #206, and #207. [§19.501 et seq. and §19.901 of Regulation #19, and 40 CFR Part 52 Subpart E]

SN	Description	Pollutant	lb/hr	ton/yr
79		PM/ PM_{10}	0.9	3.6
			0.0164 lb/MMBtu	

SN	Description	Pollutant	lb/hr	ton/yr
	Tissue Machine No. 8 Burners (50 MMBtu/hr)	SO_2	0.1	0.2
			0.0007 lb/MMBtu	
		VOC	1.0	4.2
			0.0192 lb/MMBtu	
		CO	5.7	24.9
			0.1139 lb/MMBtu	
		NO_X	4.6	20.0
			0.0913 lb/MMBtu	
80	Tissue Machine No. 8	PM/ PM_{10}	0.8	3.2
			0.0646 lb/ ADTFP*	
		VOC	13.6	59.6
			1.29 lb/MDT Annual Average	
81	Tissue Machine No. 8 Dust System	PM/ PM_{10}	1.8	7.7
			0.0035 gr/dscf	

200. The permittee estimates the emission rates set forth in the following table will not be exceeded. The pollutant emission rates are effectively limited by Specific Condition #205 and #206. [Regulation No.§18.801 and A.C.A. §8-4-203 as referenced by §8-4-304 and §8-4-311]

SN	Description	Pollutant	lb/hr	ton/yr
79	Tissue Machine No. 8 Burners	Arsenic	0.01	0.01
		Benzene	0.01	0.01
		Cadmium	0.01	0.01
		Cobalt	0.01	0.01
		Formaldehyde	0.01	0.02
		Hexane	0.11	0.48
		Manganese	0.01	0.01
		Mercury	0.01	0.01
		Naphthalene	0.01	0.01
		Nickel	0.01	0.01
		Toluene	0.01	0.01
80	Tissue Machine No. 8	Acetaldehyde	0.36	1.54
		Acetone	0.2	0.8
		Acrolein	0.03	0.10
		Benzene	0.01	0.02
		Carbon Disulfide	0.01	0.05
		Chloroform	0.01	0.01
		Formaldehyde	0.06	0.25
		Hexane	0.01	0.02

SN	Description	Pollutant	lb/hr	ton/yr
		Methanol	0.45	1.91
		Methylene Chloride	0.03	0.11
		Naphthalene	0.01	0.03
		Phenol	0.10	0.44
		Propionaldehyde	0.10	0.44
		Styrene	0.01	0.02
		Tetrachloroethylene	0.01	0.04
		Toluene	0.01	0.01
		1,2,4 Trichlorobenzene	0.03	0.11
		Xylene	0.04	0.14

Opacity

201. The permittee shall not cause to be discharged to the atmosphere from SN-79 and SN-81 gases which exhibit opacity greater than 5%. Compliance with this opacity limit shall be the use of natural gas only at SN-79. [§19.503 and §19.901 of Regulation #19, and 40 CFR Part 52 Subpart E]

202. The permittee shall conduct weekly observations of the opacity at SN-81. Observations shall be conducted by personnel familiar with the permittee's visible emissions. If visible emissions excess of the permitted opacity are detected, then a Method 9 reading is required. The permittee shall then take immediate action to identify the cause of the visible emissions, implement all necessary corrective action, and reassess the visible emissions after corrective action is taken. The permittee shall maintain records related to all observations/readings, to be updated on a weekly basis. The records shall contain the date and time of each observation/reading, the cause of any observed exceedance of opacity limits, corrective action taken, and results of the reassessment, and the name of the person conducting the observation/reading. The records shall be kept on site and made available to Department personnel upon request. [§19.705 of Regulation 19 and 40 CFR Part 52, Subpart E]

203. The permittee shall not cause to be discharged to the atmosphere from SN-80 gases which exhibit any visible emissions exceeding 6 minutes during a 60-minute period. The permittee shall check for the presence of visible emissions from each corner of the building housing SN-80 once during each calendar week. This test will not be an EPA Method 9 test, only a yes/no check for visible emissions, and does not require that the observer be a certified visible emission reader. If visible emissions are detected for more than 6 minutes per hour, then the permittee shall determine the source of the visible emissions. Once the source is identified, the permittee shall immediately take action to identify the cause of the visible emissions, implement corrective action, and document that visible emissions did not appear following the corrective action. The permittee shall maintain log records which contain the following items in order to demonstrate compliance with this specific condition. These records shall be updated weekly, kept on

site, and made available to Department personnel upon request. [§19.503 and §19.901 et seq of Regulation #19, and 40 CFR Part 52 Subpart E]

a. The date and time of the observation

b. If visible emissions were detected

c. If visible emissions were detected, the source number causing the visible emissions, the cause of the visible emissions, the corrective action taken, and whether any visible emissions appeared after the corrective action was taken.

d. The name of the person conducting the observation.

204. The permittee may, in the event of emergency maintenance on SN-81, shut down the dust collection system and contain the tissue dust within the building during the continued operation of the paper machine. Good housekeeping practices shall be used to control tissue dust and prevent visible emissions to the atmosphere. In the event that repairs on a scrubber extend beyond 12 hours, then a 6 minute observation for visible emissions shall be conducted once per 12 hour shift. The observation shall be a yes/no check and shall be conducted at the outside corners of the affected Tissue Machine building. If visible tissue dust emissions are detected for more than 6 minutes per hour, then corrective action shall be taken to reduce emissions and document that visible emissions do not appear after corrective action is taken. [§19.303 of Regulation #19 and A.C.A. §8-4-203 as referenced by §8-4-304 and §8-4-311]

Fuel Requirements

205. Natural gas shall be the only fuel used for Tissue Machine No. 8 Burners (SN-79). [§19.705 of Regulation #19, A.C.A. §8-4-203 as referenced by §8-4-304 and §8-4-311, and 40 CFR §70.6]

Production Limits

206. The permittee shall not produce in excess the machine dried tons of paper per day, 30 day rolling average, from the Tissue Machine No. 8 as represented in the January 2011 confidential application submitted Department. [18.1004 of Regulation #18, §19.705 of Regulation #19, A.C.A. §8-4-203 as referenced by §8-4-304 and §8-4-311, and 40 CFR §70.6]

207. The permittee shall maintain records which demonstrate compliance with the paper production limits, the paper machine VOC annual emissions, and the paper machine VOC BACT limits listed in Specific Conditions #199 and #206. The records shall be updated on a monthly basis. These records shall be kept on site, provided to Department personnel upon request and may be used by the Department for enforcement purposes. For VOC annual emissions and the paper machine VOC BACT limit, a twelve month

rolling total and each individual month's data shall be submitted in accordance with General Provision #7. [§18.1004 of Regulation #18, §19.705 of Regulation #19, 40 CFR Part 52 Subpart E, and A.C.A. §8-4-203 as referenced by §8-4-304 and §8-4-311]

CAM

208. The Tissue Machine No. 8 Dust System (SN-81) is subject to and shall comply with all applicable provisions of §19.304 of Regulation 19, 40 CFR Part 52 Subpart E, and Part §64.6 for Compliance Assurance Monitoring. Post control of particulate emissions from SN-81 is below major source levels.

a. The permittee shall maintain a scrubber liquid pressure of at least 8 inches of water. [40 CFR Part §64.6(c)(1)]
b. The permittee shall monitor and maintain daily records to demonstrate compliance with Specific Condition #208(A). Records shall be kept onsite and made available to the Department upon request. [40 CFR Part §64.6(c)(3)]

c. The permittee shall maintain the scrubber in good working condition at all times so that pollutant removal is maintained. [40 CFR Part §64.6(c)(1)]

209. The Tissue Machine No. 8 Dust System (SN-81) is subject to and shall comply with all applicable provisions of §19.304 of Regulation 19, 40 CFR Part 52 Subpart E, and Part §64.6 for Compliance Assurance Monitoring. The following information pertaining to exceedances or excursions from permitted values shall be submitted in semi-annual reports in accordance with General Provision 7 as outlined in 40 CFR §70.6.

a. The permittee shall maintain records for SN-81 that summarizes the number, duration, and cause of excursions or exceedances of emission limits as well as corrective action taken. [40 CFR §64.9(a)(2)(i) and §64.9(b)]

b. The permittee shall maintain records for SN-81 that summarizes the number, duration, and cause of monitoring equipment downtime incidents, other than routine downtime for calibration checks. [40 CFR §64.9(a)(2)(ii) and §64.9(b)]

c. The permittee shall maintain a quality improvement plan (QIP) threshold for each indicator of no more than nine excursions or 5% of the daily averages in a six-month period. [40 CFR §64.9(a)(2)(iii) and §64.9(b)]

d. The permittee shall develop and implement a new QIP if the threshold is exceeded during any six-month period. [40 CFR §64.9(a)(2)(iii) and §64.9(b)]

e. The permittee shall maintain records for SN-81 that describes the actions taken to implement the QIP. Upon completion of the QIP, documentation shall be maintained to confirm that the plan was completed and reduced the likelihood of similar excursions or exceedances. [40 CFR §64.9(a)(2)(iii) and §64.9(b)]

Testing Requirements

210. The permittee shall test SN-79 for CO and NO_X to verify compliance with the BACT emission limits specified in Specific Condition #199 every five years. Testing for CO and NO_X shall be performed in accordance with Plantwide Condition #3 and EPA Reference Methods 10 and 7E respectively. During the test the permittee shall operate the source within 10 percent of the rated throughput capacity. If 90 percent of the rated throughout capacity cannot be achieved, the permittee shall be limited to 10 percent above the actual tested throughput. The permittee shall reference this limitation in any compliance reports submitted to the Department. [§19.702 and §19.901 et seq of Regulation #19, and 40 CFR Part 52 Subpart E]

211. The permittee shall test SN-81 for PM/PM_{10} to verify compliance with the BACT emission limit specified in Specific Conditions #199 every five years. Testing shall be performed in accordance with Plantwide Condition #3 and EPA Reference Method 5 with inclusion of back half sampling train particulate. The permittee shall test at the minimum scrubber parameters of Specific Condition 208. During the test the permittee shall operate the source within 10 percent of the rated throughput capacity. If 90 percent of the rated throughout capacity cannot be achieved, the permittee shall be limited to 10 percent above the actual tested throughput. The permittee shall reference this limitation in any compliance reports submitted to the Department. [§19.702 and §19.901 et seq of Regulation #19, and 40 CFR Part 52 Subpart E]

SN-71 and 72
No. 8 and No. 9 Extruder Machines

Source Description

The extrusion plant includes the No. 8 and No. 9 extruder machines which polycoat board. The extrusion plant receives board from the board machine and outside board customers and applies a polymer coating. Rolls of board are loaded onto an unwind stand. The board passes through a calender stack and is subjected to a burner which flame seals the board. An extruded poly sheet is then pressed together with the board. The combined product is then passed through an electrostatic treater (SN-71 for No. 8 Extruder and SN-72 for No. 9 Extruder) which enhances the surface quality of the product. Each extruder has two electrostatic treaters which emit ozone. Both extrusion lines also include rewinding facilities which can be used to cut the extruded product to size and rewind the material so poly can be applied to the opposite side. The extrusion plant also performs shredding, trim chopping and spool cutting. Particulate matter emissions from these activities are controlled by cyclones.

Specific Conditions

212. The permittee shall not exceed the emission rates set forth in the following table. Compliance with this Specific Condition shall be demonstrated by compliance with Specific Conditions #216. [§19.501 et seq. and §19.901 et seq of Regulation #19, and 40 CFR Part 52 Subpart E]

SN	Description	Pollutant	lb/hr	ton/yr
71	No. 8 Extruder Electrostatic Treaters (A&B)	PM_{10}	0.4	1.5
72	No. 9 Extruder Electrostatic Treater	PM_{10}	0.6	2.5

213. The permittee shall not exceed the emission rates set forth in the following table. Compliance with this Specific Condition shall be demonstrated by compliance with Specific Condition #216. [Regulation No.§18.801 and A.C.A. §8-4-203 as referenced by §8-4-304 and §8-4-311]

SN	Description	Pollutant	lb/hr	ton/yr
71	No. 8 Extruder Electrostatic Treaters (A&B)	PM Ozone	0.4 0.8	1.5 3.2
72	No. 9 Extruder Electrostatic Treater	PM Ozone	0.6 1.5	2.5 6.3

Opacity

214. The permittee shall not cause to be discharged to the atmosphere from SN-71 and SN-72 gases which exhibit opacity greater than 10%. [§19.503 and §19.901 of Regulation #19, and 40 CFR Part 52 Subpart E]

215. The permittee shall conduct weekly observations of the opacity at SN-71and SN-72. Observations shall be conducted by personnel familiar with the permittee's visible emissions. If visible emissions excess of the permitted opacity are detected, then a Method 9 reading is required. The permittee shall then take immediate action to identify the cause of the visible emissions, implement all necessary corrective action, and reassess the visible emissions after corrective action is taken. The permittee shall maintain records related to all observations/readings, to be updated on a weekly basis. The records shall contain the date and time of each observation/reading, the cause of any observed exceedance of opacity limits, corrective action taken, and results of the reassessment, and the name of the person conducting the observation/reading. The records shall be kept on site and made available to Department personnel upon request. [§19.705 of Regulation 19 and 40 CFR Part 52, Subpart E]

Production Limits

216. The permittee shall not produce in excess of 750 machine dried tons of coated paper per day, 30 day rolling average, from the No. 8 and No. 9 Extruder Machines combined. [§18.1004 of Regulation #19 and A.C.A. §8-4-203 as referenced by §8-4-304 and §8-4-311]

217. The permittee shall maintain records which demonstrate compliance with the limits listed in Specific Condition #216. The records shall be updated on a monthly basis. These records shall be kept on site, provided to Department personnel upon request and may be used by the Department for enforcement purposes. A twelve month total and each individual month's data shall be submitted in accordance with General Provision #7. [§18.1004 of Regulation #18 and A.C.A. §8-4-203 as referenced by §8-4-304 and §8-4-311]

SN-35
Aeration Stabilization Basin

Source Description

Wastewater is treated by the Crossett Paper Operations treatment plant. The wastewater is gathered in two open sewers, a bleach plant/utilities sewer and a process sewer. Wastewater Treatment System nutrients are added to the bleach plant/utilities sewer to enhance biological activity. After primary clarification, the process sewer and the bleach plant/utilities sewer combine and flow into one of two settling basins. The effluent travels through a surge basin and is combined with the City of Crossett's treated effluent as it enters a 265 acre extended aeration stabilization basin (ASB, SN-35F). The effluent from the ASB is sent to a holding basin called Mossy Lake, which has a surface area that varies from 200 to 600 acres. Treated effluent is discharged from Mossy Lake to the Ouachita River via Coffee Creek.

Air emissions result from the biological wastewater treatment processes. The air emissions are a factor of such things as the flow to the secondary treatment, the volume of the aeration stabilization basin, the temperature of the aeration stabilization basin and the surface area of the aeration stabilization basin. Also included in the estimation, are contributions from the wastewater clarifier, settling ponds, and sludge dewatering. These potential emissions were not accounted for in the initial permit.

Specific Conditions

218. The permittee shall not exceed the emission rates set forth in the following table. The emissions from this source are limited by the production levels of the mill. [Regulation No. 19 §19.501 et seq. and 40 CFR Part 52, Subpart E]

Pollutant	lb/hr	ton/yr
VOC	17.3	75.5

219. The permittee shall not exceed the emission rates set forth in the following table. The emissions from this source are limited by the production levels of the mill. [Regulation No. §18.801 and A.C.A. §8-4-203 as referenced by §8-4-304 and §8-4-311]

Pollutant	lb/hr	ton/yr
Acetaldehyde	0.14	0.61
Acrolein	0.01	0.04
Benzene	0.02	0.07
Biphenyl	0.01	0.02
Carbon Disulfide	0.05	0.21
Chloroform	0.61	2.66
Cresol	0.01	0.01

Pollutant	lb/hr	ton/yr
Cumene	0.41	1.77
Formaldehyde	0.04	0.18
Methanol	15.24	66.74
Naphthalene	0.09	0.36
Phenol	0.01	0.01
Propionaldehyde	0.01	0.04
Styrene	0.08	0.34
Toluene	0.03	0.11
Xylene	0.37	1.59

SN-40, 75, 76F, 78F, 82F, and 97
Tanks and Miscellaneous Activities

Source Description

There are nine large pulp storage tanks located at Crossett Paper Operations (SN-75). An open storage basin (SN-76F) at the facility stores black liquor. The front black liquor storage basin at the facility was closed in 1996.

Fugitive emissions from unpaved roads (SN-78F) are generated by vehicle traffic. Unpaved roads are located in the utilities area, Woodyard, laydown area, contractors' area and around the wastewater treatment system.

The Methanol Tank (SN-40) is subject to regulation under NSPS Subpart Kb. The emissions are due to the working and standing losses from the tank.

There are two landfills at Crossett Paper Operations, the East Landfill and the North Landfill. The East Landfill is permitted to operate as a Class IV Landfill and accepts only woodwaste and concrete debris. The North Landfill is an industrial landfill which accepts general waste from the mill. No municipal waste is disposed in either landfill. The only significant source of emissions expected from these landfills is VOC emissions from the North Landfill. The North Landfill was permitted by the Department and began operation on September 1, 1998. The North Landfill is located approximately two miles north of the mill. The West Landfill ceased operation on September 1, 1998.

Specific Conditions

220. The permittee shall not exceed the emission rates set forth in the following table. Compliance with the pollutant emission rates associated with the Methanol Tank is demonstrated by compliance with Specific Condition #223. The emissions from the other sources are limited by the production levels of the mill. [Regulation No. 19 §19.501 et seq. and 40 CFR Part 52, Subpart E]

SN	Description	Pollutant	lb/hr	ton/yr
40	Methanol Storage Tank	VOC	0.3	1.0
75	Pulp Storage Chests	VOC	43.2	189.3
		TRS	3.8	16.6
97	Storage Tanks	VOC	4.4	19.0
		TRS	2.5	11.0
76F	Black Liquor Storage Basin No. 1	VOC	4.4	19.3
78F	Road Emissions	PM_{10}	3.0	9.7
82F	Landfill Operations	PM_{10}	0.1	0.1

221. The permittee estimates the emission rates set forth in the following table will not be exceeded. The pollutant emission rates associated with the Methanol Tank are effectively limited by Specific Condition #223. The emissions from the other sources are limited by the production levels of the mill. [Regulation No.§18.801 and A.C.A. §8-4-203 as referenced by §8-4-304 and §8-4-311]

SN	Description	Pollutant	lb/hr	ton/yr
40	Methanol Storage Tank	Methanol	0.22	1.0
97	Storage Tanks	Acetaldehyde	0.01	0.02
		Acrolein	0.01	0.01
		Benzene	0.01	0.01
		Carbon Tetrachloride	0.01	0.02
		Ethylene Dichloride	0.01	0.01
		Hexane	0.01	0.01
		Methanol	0.48	2.11
		Styrene	0.01	0.01
		Tetrachloroethylene	0.01	0.01
		Toluene	0.01	0.01
		1,2,4-Trichlorobenzene	0.01	0.01
		Xylene	0.01	0.03
75	Pulp Storage Chests	Acetaldehyde	0.05	0.21
		Benzene	0.01	0.01
		Chloroform	0.10	0.44
		Hexane	0.01	0.01
		Methanol	0.22	0.95
		Phenol	0.18	0.75
		Styrene	0.01	0.02
		Tetrachloroethylene	0.01	0.02
		Toluene	0.01	0.01
		Xylene	0.01	0.01
76F	Black Liquor Storage Basin No. 1	Acetaldehyde	0.20	0.87
		Acetone	0.2	0.7
		Methanol	4.02	17.61
78F	Road Emissions	PM	12.0	39.0
82F	Landfill Operations	PM	0.2	0.1

NSPS Kb

222. The Methanol Tank is subject to and shall comply with all applicable provisions of 40 CFR Part 60 Subpart Kb - Standards of Performance for Volatile Organic Liquid Storage Vessels. A copy of Subpart Kb is provided in Appendix D.

Applicable provisions include, but are not limited to, maintaining records showing the dimension of the storage vessel, and an analysis showing the design capacity of the storage vessel. [§19.304 of Regulation #19 and 40 CFR 60.116b (a) and (b)]

Throughput Limits

223. Throughput of methanol at SN-40 shall not exceed 40,000 barrels per twelve consecutive months. [§19.705 of Regulation #19, A.C.A. §8-4-203 as referenced by §8-4-304 and §8-4-311, and 40 CFR §70.6]

224. The permittee shall maintain records which demonstrate compliance with the limits listed in Specific Condition #223. These records shall be updated on a monthly basis. These records shall be kept on site, provided to Department personnel upon request and may be used by the Department for enforcement purposes. A twelve month total and each individual month's data shall be submitted in accordance with General Provision #7. [§19.705 of Regulation #19 and 40 CFR Part 52 Subpart E]

Dust Suppression

225. Dust suppression activities should be conducted in a manner and at a rate of application that will not cause runoff from the area being applied. Best Management Practices (40 CFR §122.44(k)) should be used around streams and waterbodies to prevent the dust suppression agent from entering Waters of the State. Except for potable water, no agent shall be applied within 100 feet of wetlands, lakes, ponds, springs, streams, or sinkholes. Failure to meet this condition may require the permittee to obtain a National Pollutant Discharge Elimination System (NPDES) permit in accordance with 40 CFR §122.1(b). [A.C.A. §8-4-203 as referenced by A.C.A. §8-4-304 and §8-4-311]

SN-93
Repulpers A, B, and C

Source Description

Three repulpers are used to reprocess broke as well as pulp that is purchased and produced in-house. These are identified as Repulpers A, B, and C. Each repulper is identical. The repulpers operate without any hoods or fans. A sodium hypochlorite pulping aid is required to break down the broke; however not the pulp. The sodium hypochlorite is added subsurface to the repulpers. All VOC emissions are non-stack in nature. The broke that is repulped is stored in the existing broke stock chests. As part of the permit renewal, the repulpers were added as permitted sources. A minor modification allowed the reconstruction of Repulper A.

Specific Conditions

226. The permittee shall not exceed the emission rates set forth in the following table. Compliance with this Specific Condition shall be demonstrated by compliance with Specific Condition #228. [Regulation No. 19 §19.501 et seq. and 40 CFR Part 52, Subpart E]

Pollutant	lb/hr	ton/yr
VOC	1.0	4.4

227. The permittee estimates the emission rates set forth in the following table will not be exceeded. Compliance with this Specific Condition shall be demonstrated by compliance with Specific Condition #228. [Regulation No.§18.801 and A.C.A. §8-4-203 as referenced by §8-4-304 and §8-4-311]

Pollutant	lb/hr	ton/yr
Chloroform	0.99	4.32

Throughput Limits

228. The permittee shall not process in excess of 270 tons per day of broke, 30-day rolling average , total combined, at all repulpers at SN-93. This limit does not apply to purchased pulp or pulp produced in-house for purposes of recycle. [§18.1004 of Regulation #18, §19.705 of Regulation #19, A.C.A. §8-4-203 as referenced by §8-4-304 and §8-4-311, and 40 CFR §70.6]

229. The permittee shall maintain records of the amount of broke that is processed in Repulpers A, B and C which demonstrate compliance with the limits listed in Specific Condition #228. These records shall be updated on a monthly basis. These records shall be kept on site, provided to Department personnel upon request and may be used by the

Department for enforcement purposes. A twelve month total and each individual month's data shall be submitted in accordance with General Provision #7. [§19.705 of Regulation #19 and 40 CFR Part 52 Subpart E]

SN-83
Incinerator and Scrubber

Source Description

Gas streams from the LVHC Collection System, the HVLC Collection System, and SOGs from the LEEPS System are fed into the Incinerator via a common burner. The HVLC system is diluted with combustion air before being fed to the combustion chamber. The Incinerator consists of a horizontal combustion chamber followed by a vertical SO_2 caustic packed-tower scrubber which, in turn, is followed by several mist eliminators.

Minimum incineration temperature in the primary combustion zone is required for efficient oxidation. For this Kraft mill application, combustion requirements dictate a minimum temperature of 1,600°F with a 0.75 second retention time (*see* 40 CFR §63.443(d)(3)). Since the Incinerator combusts NCGs from both LVHC and HVLC Collection Systems, it has to meet a 96% uptime requirement. Crossett Paper Operations complies by using the Incinerator as the primary combustion device with the 9A Boiler (SN-22) as a backup combustion device for the LVHC NCGs and SOGs only. The HVLC gases, which by definition have lower concentrations of NCGs, are vented to the atmosphere when the Incinerator is down. In the event that downtime occurs, excess emissions will be reported as required by 40 CFR §63.455.

Under normal operation, the fuel flow is controlled by the operating temperature in the Incinerator. The fuel requirements will vary with the amount of waste gases introduced into the collection system. Maximum fuel consumption will be required to bring the system up to temperature, but the consumption will be greatly reduced during normal incineration of the NCGs and SOGs. The NCGs have some heat content which reduces fuel consumption once normal incineration begins.

The Incinerator system consists of a refractory lined Incinerator, a waste heat boiler, a cooler section, an SO_2 scrubber, a sulfuric acid removal system, and a discharge stack.
The waste heat boiler is located between the Incinerator outlet and the scrubber inlet. This boiler is a fire-tube type boiler with three passes. The boiler does not combust fuels; rather it scavenges the waste heat from the Incinerator to produce steam.

The gases exiting the Incinerator are in excess of 1,600°F. In order to scrub the SO_2 from these gases, the temperature is lowered. The gases pass through a waste heat boiler. The boiler is followed by a vertical SO_2 scrubber that continues to lower the temperature as it removes most of the sulfur gases from the combustion exhaust.

The adsorption tower is followed by a sulfuric acid removal system that uses a caustic solution. A recirculation loop is used to minimize caustic use. The makeup caustic is controlled by scrubber pH to maintain scrubbing effectiveness and efficiency.

The primary fuels for the Incinerator are methanol recovered from the foul condensates via the steam stripper and the LVHC gases. Natural gas is used as a backup fuel. For a given pollutant,

the combustion of methanol produces the highest emission rates. The Incinerator is equipped with low-NO_x burners to control NO_x emissions and a scrubber to control PM/PM_{10} and SO_2 emissions.

In 597-AOP-R8, the facility underwent PSD review in order to modify nine of their Digesters (SN-59), replacing the six-inch blow valves with eight-inch valves. All six hardwood pulp digesters were modified, along with one "swing" pulp digester (used for either hardwood or softwood) and two softwood pulp digesters. BACT for VOC was determined to be combustion of the digester gases in an incinerator, SN-83.

Specific Conditions

230. The permittee shall not exceed the emission rates set forth in the following table for the Incinerator (SN-83). Emissions are based on maximum capacity. [Regulation No. 19 §19.501 et seq. and 40 CFR Part 52, Subpart E]

Pollutant	lb/hr	ton/yr
PM_{10}	2.7	11.9
SO_2	9.1	39.9
CO	6.0	26.3
NO_x	23.0	100.8
TRS	0.9	3.8

231. The permittee shall not exceed the emission rates set forth in the following table for the Incinerator (SN-83). Emissions are based on maximum capacity. [Regulation No. 19 §19.501 et seq. , §19.901, and 40 CFR Part 52, Subpart E]

Pollutant	lb/hr	ton/yr
VOC	0.8	3.5

232. The permittee shall not exceed the emission rates set forth in the following table for the Incinerator (SN-83). Emissions are based on maximum capacity. [Regulation No.§18.801 effective and A.C.A. §8-4-203 as referenced by §8-4-304 and §8-4-311]

Pollutant	lb/hr	ton/yr
PM	2.7	11.9
SAM	13.7	4.3
Acetaldehyde	0.03	0.11
Acetone	0.1	0.2
Benzene	0.04	0.14
Carbon Tetrachloride	0.01	0.04
Formaldehyde	0.03	0.09

Pollutant	lb/hr	ton/yr
Hexane	0.01	0.03
Methanol	0.81	3.06
Styrene	0.01	0.01
1,2,4-Trichlorobenzene	0.01	0.02
Xylene	0.02	0.05

Opacity

233. The permittee shall not cause to be discharged to the atmosphere from the Incinerator gases which exhibit opacity greater than 20%. [§19.503 of Regulation #19 and 40 C.F.R. Part 52 Subpart E]

234. The permittee shall conduct weekly observations of the opacity at SN-83. Observations shall be conducted by personnel familiar with the permittee's visible. If visible emissions excess of the permitted opacity are detected, then a Method 9 reading is required. The permittee shall then take immediate action to identify the cause of the visible emissions, implement all necessary corrective action, and reassess the visible emissions after corrective action is taken. The permittee shall maintain records related to all observations/readings, to be updated on a weekly basis. The records shall contain the date and time of each observation/reading, the cause of any observed exceedance of opacity limits, corrective action taken, and results of the reassessment, and the name of the person conducting the observation/reading. The records shall be kept on site and made available to Department personnel upon request. [§19.705 of Regulation 19 and 40 CFR Part 52, Subpart E]

Fuel Requirements

235. Natural gas may be used as a backup fuel for the Incinerator. [§19.705 of Regulation #19, A.C.A. §8-4-203 as referenced by §8-4-304 and §8-4-311, and 40 CFR §70.6]

236. The permittee shall maintain records which demonstrate compliance with Specific Condition #235. These records shall be updated on a monthly basis and shall include periods of usage of natural gas, (not quantities) of fuel used. These records shall be kept on site, provided to Department personnel upon request and may be used by the Department for enforcement purposes. A twelve month total and each individual month's data shall be submitted in accordance with General Provision #7. [§19.705 of Regulation #19 and 40 CFR Part 52 Subpart E]

CAM

237. Incinerator (SN-83) is subject to and shall comply with all applicable provisions §19.304 of Regulation 19, 40 CFR Part 52 Subpart E, and Part §64.6 for Compliance Assurance Monitoring. Post control of sulfur dioxide emissions from SN-83 are below major source levels.

a. The permittee shall maintain a scrubber liquid flow rate of at least 768 gallons per minute. [40 CFR Part §64.6(c)(1)]

b. The permittee shall maintain a pH of at least 7.6 in the scrubber liquid. [40 CFR Part §64.6(c)(1)]

c. The permittee shall monitor and maintain daily records to demonstrate compliance with Specific Condition #237 (A) and (B). Records shall be kept onsite and made available to the Department upon request. [40 CFR Part §64.6(c)(3)]

d. The permittee shall maintain the caustic scrubber in good working condition at all times so that pollutant removal is maintained. [40 CFR Part §64.6(c)(1)]

238. The Incinerator (SN-83) is subject to and shall comply with all applicable provisions §19.304 of Regulation 19, 40 CFR Part 52 Subpart E, and Part §64.9 for Compliance Assurance Monitoring. The following information pertaining to exceedances or excursions from permitted values shall be submitted in semi-annual reports in accordance with General Provision 7 as outlined in 40 CFR §70.6.

a. The permittee shall maintain records for SN-83 that summarizes the number, duration, and cause of excursions or exceedances of emission limits as well as corrective action taken. [40 CFR §64.9(a)(2)(i) and §64.9(b)]

b. The permittee shall maintain records for SN-83 that summarizes the number, duration, and cause of monitoring equipment downtime incidents, other than routine downtime for calibration checks. [40 CFR §64.9(a)(2)(ii) and §64.9(b)]

c. The permittee shall maintain a quality improvement plan (QIP) threshold for each indicator of no more than nine excursions or 5% of the total daily averages in a six-month period.

d. The permittee shall develop and implement a new QIP if the threshold is exceeded during any six-month period. [40 CFR §64.9(a)(2)(iii) and §64.9(b)]

e. The permittee shall maintain records for SN-83 that describes the actions taken to implement the QIP. Upon completion of the QIP, documentation shall be

maintained to confirm that the plan was completed and reduced the likelihood of similar excursions or exceedances. [40 CFR §64.9(a)(2)(iii) and §64.9(b)]

Testing Requirements

239. The permittee shall test volatile organic compound emissions from the Incinerator every five years to confirm the BACT limit for this source. Testing shall be performed in accordance with Plantwide Condition #3 and EPA Reference Method 25A. During the test the permittee shall operate the source within 10 percent of the rated throughput capacity. If 90 percent of the rated throughout capacity cannot be achieved, the permittee shall be limited to 10 percent above the actual tested throughput. The permittee shall reference this limitation in any compliance reports submitted to the Department. [§19.702 and §19.901 of Regulation #19 and 40 CFR Part 52 Subpart E]

240. The permittee shall test sulfur dioxide emissions from the Incinerator every five years. Testing shall be performed in accordance with Plantwide Condition #3 and EPA Reference Method 6C. The permittee shall test at the minimum scrubber parameters of Specific Condition 237. During the test the permittee shall operate the source within 10 percent of the rated throughput capacity. If 90 percent of the rated throughout capacity cannot be achieved, the permittee shall be limited to 10 percent above the actual tested throughput. The permittee shall reference this limitation in any compliance reports submitted to the Department. [§19.702 of Regulation #19 and 40 CFR Part 52 Subpart E]

241. The permittee shall test carbon monoxide emissions from the Incinerator every five years. Testing shall be performed in accordance with Plantwide Condition #3 and EPA Reference Method 10. During the test the permittee shall operate the source within 10 percent of the rated throughput capacity. If 90 percent of the rated throughout capacity cannot be achieved, the permittee shall be limited to 10 percent above the actual tested throughput. The permittee shall reference this limitation in any compliance reports submitted to the Department. [§19.702 of Regulation #19 and 40 CFR Part 52 Subpart E]

242. The permittee shall test nitrogen oxides emissions from the Incinerator every five years. Testing shall be performed in accordance with Plantwide Condition #3 and EPA Reference Method 7E. During the test the permittee shall operate the source within 10 percent of the rated throughput capacity. If 90 percent of the rated throughout capacity cannot be achieved, the permittee shall be limited to 10 percent above the actual tested throughput. The permittee shall reference this limitation in any compliance reports submitted to the Department. [§19.702 of Regulation #19 and 40 CFR Part 52 Subpart E]

NSPS BB and NESHAP S

243. The Incinerator (SN-83) is subject to and shall comply with applicable provisions of §19.804 of Regulation #19, NSPS Subpart BB, and NESHAP Subpart S. Section 19.804 of Regulation #19 and NSPS Subpart BB both require incineration of NCGs at a minimum temperature of 1200°F for at least 0.5 seconds. NESHAP Subpart S requires

incineration at a minimum temperature of 1600°F for at least 0.75 seconds. [§19.804 of Regulation #19, NSPS Subpart BB, and NESHAP Subpart S]

244. The permittee shall maintain records which demonstrate compliance with Specific Condition #243. These records shall be kept on site, provided to Department personnel upon request and may be used by the Department for enforcement purposes. [§19.705 of Regulation #19 and 40 CFR Part 52 Subpart E]

245. The pulping system (which is comprised of all pulping process equipment beginning with the digester system, up to and including the last piece of pulp conditioning equipment prior to the bleaching system) is subject to and shall comply with applicable provisions of 40 CFR Part 63 Subpart S -*National Emission Standards for Hazardous Air Pollutants from the Pulp and Paper Industry*. A copy of Subpart S is provided in Appendix E.

Standards for the Kraft pulping systems.

a. The permittee shall control the total HAP emissions from the equipment systems listed in 40 CFR §63.443(a), as specified in paragraphs (c) and (d) of 40 CFR §63.443. [40 CFR §63.443(a)]

b. The equipment systems listed in paragraphs (a) and (b) of 40 CFR §63.443 shall be enclosed and vented into a closed-vent system and routed to a control device that meets the requirements specified in paragraph (d) of 40 CFR §63.443. The enclosure and closed-vent system shall meet the requirements specified in 40 CFR §63.450. [40 CFR §63.443(c)]

c. The control device used to reduce total HAP emissions from each equipment system listed in paragraphs (a) and (b) of 40 CFR §63.443 shall reduce total HAP emissions using a thermal oxidizer designed and operated at a minimum temperature of 871oC (1600oF) and a minimum residence time of 0.75 seconds. [40 CFR §63.443(d)(3)]

d. Periods of excess emissions reported under 40 CFR §63.455 shall not be a violation of 40 CFR §63.443 (c) and (d) provided that the time of excess emissions (excluding periods of startup, shutdown, or malfunction) divided by the total process operating time in a semi-annual period does not exceed the following levels: (1) one percent for control devices used to reduce the total HAP emissions from the LVHC system; and (2) four percent for control devices used to reduce the total HAP emissions from the HVLC system; and (3) four percent for control devices used to reduce the total HAP emissions from both the LVHC and HVLC systems. [40 CFR §63.443(e)]

Standards for Kraft pulping process condensates.

e. The pulping process condensates from the equipment systems listed in 40 CFR §63.446(b) shall be treated to meet the requirements specified in paragraphs (c), (d), and (e) of 40 CFR §63.446. [40 CFR §63.446(b)]

f. One of the combinations of HAP-containing pulping process condensates listed in 40 CFR §63.446(c) which is generated, produced, or associated with the equipment systems listed in paragraph (b) of 40 CFR §63.446 shall be subject to the requirements of paragraph (d) and (e) of 40 CFR §63.446. [40 CFR §63.446(c)]

g. The pulping process condensates from the equipment systems listed in paragraph (b) of 40 CFR §63.446 shall be conveyed in a closed collection system that is designed and operated to meet the requirements specified in paragraphs (d)(1) and (d)(2) of 40 CFR §63.446. [40 CFR §63.446(d)]

h. Each pulping process condensate from the equipment systems listed in paragraph (b) of 40 CFR §63.446 shall be treated according to the following option: at mills that perform bleaching, treat the pulping process condensates to remove 5.1 kilograms or more of total HAP per megagram (10.2 pounds per ton) of ODP (bleached), or achieve a total HAP concentration of 330 parts per million or less by weight at the outlet of the control device. [40 CFR §63.446(e)(5)]

i. Each HAP removed from a pulping process condensate stream during treatment and handling under paragraph (d) or (e) of 40 CFR §63.446 shall be controlled as specified in 40 CFR '43.443(c) and (d). [40 CFR §63.446(f)]

j. The permittee shall evaluate all new or modified pulping process condensates or changes in the annual bleached or non-bleached ODP used to comply with paragraph (i) of 40 CFR §63.446, to determine if they meet the applicable requirements of 40 CFR §63.446. [40 CFR §63.446(h)]

k. For the purposes of meeting the requirements in paragraphs (c)(2), (e)(4), or (e)(5) of 40 CFR §63.446 at mills producing both bleached and unbleached pulp products, the permittee may meet a prorated mass standard that is calculated by prorating the applicable mass standards (kilograms of total HAP per megagram of ODP) for bleached and unbleached specified in paragraphs (c)(2), (e)(4), or (e)(5) of 40 CFR §63.446 by the ratio of annual megagrams of bleached and unbleached ODP. [40 CFR §63.446(i)]

Monitoring Requirements

l. The Incinerator shall meet the monitoring requirements set forth in 40 CFR §63.453(b). [40 CFR §63.453(b)]

m. The Steam Stripper shall meet the monitoring requirements set forth in 40 CFR §63.453(g). [40 CFR §63.453(g)]

n. The Closed Vent System shall meet the monitoring requirements set forth in 40 CFR §63.453(k). [40 CFR §63.453(k)]

Recordkeeping and Reporting Requirements

o. The permittee shall prepare and maintain a site-specific inspection plan for the closed vent LVHC, HVLC, and SOG collection systems. [40 CFR §63.454(b)]

p. Excess emissions shall be reported as required by 40 CFR §63.455. [40 CFR §63.455]

246. The permittee may allow emissions from the incinerator and associated scrubber to be released to the atmosphere bypassing the associated candle filter sulfuric acid mist eliminator. Bypass shall only be allowed during periods of emergency maintenance to the sulfuric acid mist eliminator system. Bypass emissions shall also be counted toward annual limits. [A.C.A. §8-4-203 as referenced by §8-4-304 and §8-4-311]

SN-111, 112, 113, 114
Converting Lines No. 1, 2, and 3
and Trim System

Source Description

This section is being installed due to the changes at the No. 8 Paper Machine. The converting lines prepare the paper for the consumer by uses of inks, glues, and cleaners. This equipment will be enclosed in a building with a drum filtering system rated at 50,000 dscfm for each line. The drum filtering system will be designed to recirculate 100% of the exhaust air back into the building. This drum filtering system is used to eliminate any potential particulate emissions from the trim line in addition to the converting lines. The drum filtering systems will be designed to recirculate 100 percent of the exhaust air back into the building.

Specific Conditions

247. The permittee shall not exceed the totals set forth in the following table for combined emissions from Converting Lines (SN-111, 112, and 113). Compliance with the VOC emission rates shall be demonstrated by Specific Condition #249. [Regulation No. 19 §19.501 et seq. and 40 CFR Part 52, Subpart E]

SN	Pollutant	lb/hr	ton/yr
111	VOC	1.8	7.8
112			
113			

Throughput Limits

248. The permittee shall maintain MSDS or other records which indicate the VOC content of all inks, glues and cleaners in use in converting lines SN-111, 112, and 113. MSDS sheets should be updated annually. These records shall be maintained on-site and shall be made available to Department personnel upon request. [§19.705 of Regulation 19 and 40 CFR Part 52 Subpart E and/or §18.1004 of Regulation 18 and A.C.A. §8-4-203 as referenced by §8-4-304 and §8-4-311]

249. The permittee shall maintain monthly records which demonstrate the amount of VOC emitted from the converting lines SN-111, 112, and 113. These records shall be maintained in a spreadsheet, database, or other well-organized format. These records shall indicate the amount of each ink, glue, or cleaner used. It shall include the corresponding VOC content of each material, and the total amount of VOC emissions from usage. Each individual month's data and a 12-month rolling total shall be maintained on-site, shall be made available to Department personnel upon request, and

shall be submitted in accordance with General Provision #7. [§19.705 of Regulation 19 and 40 CFR Part 52 Subpart E]

SN-115-ct, 116-ct, and 117-ct
Cooling Towers

Source Description

Cooling towers shall be installed for servicing the HVAC system (117-ct), No.8 Tissue Machine vacuum pump (115-ct), and No.8 Tissue Machine building HVAC system(116-ct). The total circulation flow rate for the three cooling towers shall be 12,500 gallons per minute (gpm).

Specific Conditions

250. The permittee shall not exceed the emission rates set forth in the following table for the Cooling Towers SN-115-ct, 116-ct, and 117-ct. Compliance with the PM_{10} emission rates shall be demonstrated by Specific Condition #253. [Regulation No. 19 §19.501 et seq. and 40 CFR Part 52, Subpart E]

SN	Pollutant	lb/hr	ton/yr
115-ct	PM_{10}	0.1	0.1
116-ct	PM_{10}	0.1	0.1
117-ct	PM_{10}	0.1	0.2

251. The permittee estimates the emission rates set forth in the following table for the Cooling Towers (SN115-ct, 116-ct, and 117-ct) will not be exceeded. Compliance with the PM emissions shall be demonstrated by Specific Condition #253. [Regulation No.§18.801 effective and A.C.A. §8-4-203 as referenced by §8-4-304 and §8-4-311]

SN	Pollutant	lb/hr	ton/yr
115-ct	PM	0.1	0.1
116-ct	PM	0.1	0.1
117-ct	PM	0.1	0.2

252. Visible emissions may not exceed the limits specified in the following table.

SN	Limit	Regulatory Citation
115-ct, 116-ct, & 117-ct	20%	[§19.503 and 40 CFR Part 52, Subpart E]

253. The total dissolved solids shall not exceed 750 mg/l at SN-115-ct, 116-ct, and 117-ct. [§19.705, A.C.A. §8-4-203 as referenced by §8-4-304 and §8-4-311, and 40 CFR 70.6]

254. The permittee shall monitor and maintain monthly records which demonstrate compliance with the limits set in Specific Condition #253. Records shall be updated by the 15th day following the end of the month to which the records pertain. These records shall be kept on site and made available to Department personnel upon request. [§19.705 and 40 CFR Part 52, Subpart E]

SN-114, 115, SN-116, SN-117, SN-118, SN-119, SN-120, and SN-121
Temporary Chipping and Debarking Equipment
and
Emergency Generators

Source Description

The facility has seven emergency engines on site which use diesel fuel. SN-115, SN-116, and SN-117 Firewater Pumps are Caterpillar Model 3406 engines of model year 2002 (SN-115) and 2004 (SN-116, 117) of 420 hp each. These engines are subject to NSPS ZZZZ requirements but not NSPS IIII. SN-118 and SN-119 are John Deere JU6H-UF58 engines are model year 2007 and are 138 hp. These engines are subject to both ZZZZ and IIII NSPS requirements. The facility also has a backup generator for two leachate pumps

Specific Conditions

255. The permittee shall not exceed the emission rates set forth in the following table. Compliance shall be demonstrated by compliance with Specific Condition #259. [Regulation No. 19 §19.501 et seq. and 40 CFR Part 52, Subpart E]

SN	Description	Pollutant	lb/hr	ton/yr
114	Temporary Debarking and Chipping equipment	PM_{10}	2.5	2.6
		SO_2	1.1	1.1
		VOC	2.5	2.6
		CO	20.8	22.5
		NO_X	16.8	18.1
115	Caterpillar Model No. 3406 Firewater Pump	PM_{10}	1.0	0.3
		SO_2	0.9	0.3
		VOC	1.1	0.3
		CO	2.9	0.8
		NO_x	13.1	3.3
116	Caterpillar Model No. 3406 Firewater Pump	PM_{10}	1.0	0.3
		SO_2	0.9	0.3
		VOC	1.1	0.3
		CO	2.9	0.8
		NO_x	13.1	3.3
117	Caterpillar Model No. 3406 Firewater Pump	PM_{10}	1.0	0.3
		SO_2	0.9	0.3
		VOC	1.1	0.3
		CO	2.9	0.8
		NO_x	13.1	3.3
118	John Deere JU6H-UF58	PM_{10}	0.2	0.1
		SO_2	0.3	0.1

SN	Description	Pollutant	lb/hr	ton/yr
	Firewater Pump	VOC	0.1	0.1
		CO	0.3	0.1
		NO_x	1.8	0.5
119	John Deere JU6H-UF58 Firewater Pump	PM_{10}	0.2	0.1
		SO_2	0.3	0.1
		VOC	0.1	0.1
		CO	0.3	0.1
		NO_x	1.8	0.5
120	Cummins Series 382 Backup Generator	PM_{10}	0.2	0.1
		SO_2	0.2	0.1
		VOC	0.3	0.1
		CO	0.6	0.2
		NO_x	2.8	0.7
121	Caterpillar 3116 Backup Lime Kiln Rotation	PM_{10}	0.6	0.2
		SO_2	0.5	0.2
		VOC	0.6	0.2
		CO	1.6	0.4
		NO_x	7.2	1.8

256. The permittee shall not exceed the emission rates set forth in the following table. Compliance shall be demonstrated by compliance with Specific Condition #259. [Regulation No.§18.801 and A.C.A. §8-4-203 as referenced by §8-4-304 and §8-4-311]

SN	Description	Pollutant	lb/hr	ton/yr
114	Temporary Debarking and Chipping equipment	PM	3.6	3.9
		Acetaldehyde	0.01	0.01
		Acrolein	0.01	0.01
		Benzene	0.01	0.01
		Formaldehyde	0.01	0.01
		POM	0.01	0.01
		Naphthalene	0.01	0.01
		Toluene	0.01	0.01
		Xylene	0.01	0.01
115	Caterpillar Model No. 3406 Firewater Pump	PM	1.0	0.3
		Acetaldehyde	0.01	0.01
		Acrolein	0.01	0.01
		Benzene	0.01	0.01
		Formaldehyde	0.01	0.01
		Naphthalene	0.01	0.01
		POM	0.01	0.01
		Toluene	0.01	0.01

SN	Description	Pollutant	lb/hr	ton/yr
		Xylene	0.01	0.01
116	Caterpillar Model No. 3406 Firewater Pump	PM	1.0	0.3
		Acetaldehyde	0.01	0.01
		Acrolein	0.01	0.01
		Benzene	0.01	0.01
		Formaldehyde	0.01	0.01
		Naphthalene	0.01	0.01
		POM	0.01	0.01
		Toluene	0.01	0.01
		Xylene	0.01	0.01
117	Caterpillar Model No. 3406 Firewater Pump	PM	1.0	0.3
		Acetaldehyde	0.01	0.01
		Acrolein	0.01	0.01
		Benzene	0.01	0.01
		Formaldehyde	0.01	0.01
		Naphthalene	0.01	0.01
		POM	0.01	0.01
		Toluene	0.01	0.01
		Xylene	0.01	0.01
118	John Deere JU6H-UF58 Firewater Pump	PM	0.2	0.1
		Acetaldehyde	0.01	0.01
		Acrolein	0.01	0.01
		Benzene	0.01	0.01
		Formaldehyde	0.01	0.01
		Naphthalene	0.01	0.01
		POM	0.01	0.01
		Toluene	0.01	0.01
		Xylene	0.01	0.01
119	John Deere JU6H-UF58 Firewater Pump	PM	0.2	0.1
		Acetaldehyde	0.01	0.01
		Acrolein	0.01	0.01
		Benzene	0.01	0.01
		Formaldehyde	0.01	0.01
		Naphthalene	0.01	0.01
		POM	0.01	0.01
		Toluene	0.01	0.01
		Xylene	0.01	0.01
120	Cummins Series 382 Backup Generator	PM	0.2	0.1
		Acetaldehyde	0.01	0.01
		Acrolein	0.01	0.01
		Benzene	0.01	0.01

SN	Description	Pollutant	lb/hr	ton/yr
		Formaldehyde	0.01	0.01
		Naphthalene	0.01	0.01
		POM	0.01	0.01
		Toluene	0.01	0.01
		Xylene	0.01	0.01
121	Caterpillar 3116 Backup Lime Kiln Rotation	PM	0.6	0.2
		Acetaldehyde	0.01	0.01
		Acrolein	0.01	0.01
		Benzene	0.01	0.01
		Formaldehyde	0.01	0.01
		Naphthalene	0.01	0.01
		POM	0.01	0.01
		Toluene	0.01	0.01
		Xylene	0.01	0.01

Opacity

257. The permittee shall not cause to be discharged to the atmosphere from the Emergency Generators, SN-115 through SN-121, and the Temporary Chipper and Debarker, SN-114, gases which exhibit opacity greater than 20%. [§19.503 of Regulation #19 and 40 CFR Part 52 Subpart E]

258. The permittee shall conduct daily observations when use exceeds 24-hours per event. Observations shall be conducted by personnel familiar with the permittee's visible emissions. If visible emissions excess of the permitted opacity are detected, then a Method 9 reading is required. The permittee shall then take immediate action to identify the cause of the visible emissions, implement all necessary corrective action, and reassess the visible emissions after corrective action is taken. The permittee shall maintain records related to all observations/readings, to be updated on a weekly basis. The records shall contain the date and time of each observation/reading, the cause of any observed exceedance of opacity limits, corrective action taken, and results of the reassessment, and the name of the person conducting the observation/reading. The records shall be kept on site and made available to Department personnel upon request. [§19.705 of Regulation 19 and 40 CFR Part 52, Subpart E]

Fuel Requirements

259. The permittee is limited to 500 hours of operation for each source, SN-115 through SN-121. [Regulation No. 19 §19.501 et seq. and 40 CFR Part 52, Subpart E]

260. Diesel fuel shall be the only fuel used for the Emergency Generators, SN-115 through SN-121. [§19.705 of Regulation #19, A.C.A. §8-4-203 as referenced by §8-4-304 and §8-4-311, and 40 CFR §70.6]

Limits at Temporary Debarker and Chipper

261. The permittee shall not operate either the debarker or the chipper engine in excess of 2,160 hours. The generator shall have a non-resettable hour meter in order to verify compliance with this limit. The permittee shall maintain monthly and 12-month total records in order to demonstrate compliance with the limit and which may be used by the Department for enforcement purposes. These records shall be updated no later than the fifteenth day of the month following the month which the records represent, shall be kept on site, and shall be made available to Department personnel upon request. [Regulation 18, §18.1004 and Regulation 19, §19.705 et seq. and A.C.A. §8-4-203 as referenced by A.C.A. §8-4-304 and §8-4-311]

262. The permittee shall remove the debarker/chipper engines after 12 months at the location or the maximum hours allowed in Specific Condition #261, whichever occurs first. The permittee shall maintain records of equipment placement and removal in order to demonstrate compliance with these limits. These records shall include the dates the engines are moved and the correlating hour meter readings. These records shall be kept on site and shall be made available to Department personnel upon request. [40 CFR 1068.30(2)(iii) and §19.304 of Regulation #19]

263. The permittee shall operate and maintain the stationary CI internal combustion engine and control device according to the manufacturer's written instructions or procedures developed by the owner or operator that are approved by the engine manufacturer. Records of required maintenance shall be kept on site and shall be made available to Department personnel upon request. [Regulation 18, §18.1004 and Regulation 19, §19.705 et seq. and A.C.A. §8-4-203 as referenced by A.C.A. §8-4-304 and §8-4-311]

NSPS IIII

264. SN-118 and SN-119, as CI ICE, certified National Fire Protection Association (NFPA) fire pump engine after July 1, 2006, are subject to the requirements of Subpart IIII—*Standards of Performance for Stationary Compression Ignition Internal Combustion Engines*. [40 CFR §60.4200]

265. As owners or operations of SN-118 and SN-119, engines with a displacement of less than 30 liters per cylinder, the permittee must comply with the emission standards in Table 4 to this subpart, for all pollutants. [40 CFR §60.4205(c)]

Size	Year	NMHC + NO_X g/HP-hr	CO g/HP-hr	PM g/HP-hr
100≤HP<175	2009 and earlier	7.8	3.7	0.6

266. Owners and operators of stationary CI ICE must operate and maintain stationary CI ICE that achieve the emission standards as required in §60.4205 according to the manufacturer's written instructions or procedures developed by the owner or operator that

are approved by the engine manufacturer, over the entire life of the engine. [40 CFR §60.4206]

267. Beginning October 1, 2010, owners and operators of stationary CI ICE subject to this subpart with a displacement of less than 30 liters per cylinder that use diesel fuel must use diesel fuel that meets the requirements of 40 CFR 80.510(b) for non-road diesel fuel. [40 CFR §60.4207(b)]

268. Owners and operators of pre-2011 model year stationary CI ICE subject to this subpart may petition the Administrator for approval to use remaining non-compliant fuel that does not meet the fuel requirements of paragraphs (a) and (b) of this section beyond the dates required for the purpose of using up existing fuel inventories. If approved, the petition will be valid for a period of up to 6 months. If additional time is needed, the owner or operator is required to submit a new petition to the Administrator. [40 CFR §60.4207(c)]

269. The permittee must install a non-resettable hour meter at SN-118 and SN-119. [40 CFR §60.4209(a)]

270. The permittee must operate and maintain the stationary CI internal combustion engine and control device according to the manufacturer's written instructions or procedures developed by the owner or operator that are approved by the engine manufacturer. In addition, owners and operators may only change those settings that are permitted by the manufacturer. The permittee must also meet the requirements of 40 CFR parts 89, 94 and/or 1068, as they apply to you. [40 CFR §60.4211(a)]

271. The permittee, as an owner or operator of a CI fire pump engine that is manufactured prior to the model years in table 3 to this subpart and must comply with the emission standards specified in §60.4205(c), must demonstrate compliance according to one of the methods specified in paragraphs (b)(1) through (5) of this section. [40 CFR §60.4211(b)]

a. Purchasing an engine certified according to 40 CFR part 89 or 40 CFR part 94, as applicable, for the same model year and maximum engine power. The engine must be installed and configured according to the manufacturer's specifications.

b. Keeping records of performance test results for each pollutant for a test conducted on a similar engine. The test must have been conducted using the same methods specified in this subpart and these methods must have been followed correctly.

c. Keeping records of engine manufacturer data indicating compliance with the standards.

d. Keeping records of control device vendor data indicating compliance with the standards.

e. Conducting an initial performance test to demonstrate compliance with the emission standards according to the requirements specified in §60.4212, as applicable.

272. Emergency stationary ICE may be operated for the purpose of maintenance checks and readiness testing, provided that the tests are recommended by Federal, State, or local government, the manufacturer, the vendor, or the insurance company associated with the engine. Maintenance checks and readiness testing of such units is limited to 100 hours per year. There is no time limit on the use of emergency stationary ICE in emergency situations. Anyone may petition the Administrator for approval of additional hours to be used for maintenance checks and readiness testing, but a petition is not required if the owner or operator maintains records indicating that Federal, State, or local standards require maintenance and testing of emergency ICE beyond 100 hours per year. For owners and operators of emergency engines meeting standards under §60.4205 but not §60.4204, any operation other than emergency operation, and maintenance and testing as permitted in this section, is prohibited. [40 CFR §60.4211(e)]

273. The permittee must conduct performance tests according to paragraphs (a) through (d) of this section. [40 CFR §60.4212]

a. The performance test must be conducted according to the in-use testing procedures in 40 CFR part 1039, subpart F.

b. Exhaust emissions from stationary CI ICE that are complying with the emission standards for new CI engines in 40 CFR part 1039 must not exceed the not-to-exceed (NTE) standards for the same model year and maximum engine power as required in 40 CFR 1039.101(e) and 40 CFR 1039.102(g)(1), except as specified in 40 CFR 1039.104(d). This requirement starts when NTE requirements take effect for nonroad diesel engines under 40 CFR part 1039.

c. Exhaust emissions from stationary CI ICE that are complying with the emission standards for new CI engines in 40 CFR 89.112 or 40 CFR 94.8, as applicable, must not exceed the NTE numerical requirements, rounded to the same number of decimal places as the applicable standard in 40 CFR 89.112 or 40 CFR 94.8, as applicable, determined from the following equation:

$$\text{NTE requirement for each pollutant} = (1.25) \times (\text{STD}) \qquad \text{(Eq. 1)}$$

Where:

STD = The standard specified for that pollutant in 40 CFR 89.112 or 40 CFR 94.8, as applicable.

Alternatively, stationary CI ICE that are complying with the emission standards for new CI engines in 40 CFR 89.112 or 40 CFR 94.8 may follow the testing procedures specified in §60.4213 of this subpart, as appropriate.

d. Exhaust emissions from stationary CI ICE that are complying with the emission standards for pre-2007 model year engines in §60.4204(a), §60.4205(a), or §60.4205(c) must not exceed the NTE numerical requirements, rounded to the same number of decimal places as the applicable standard in §60.4204(a), §60.4205(a), or §60.4205(c), determined from the equation in paragraph (c) of this section.

Where:

STD = The standard specified for that pollutant in §60.4204(a), §60.4205(a), or §60.4205(c).

Alternatively, stationary CI ICE that are complying with the emission standards for pre-2007 model year engines in §60.4204(a), §60.4205(a), or §60.4205(c) may follow the testing procedures specified in §60.4213, as appropriate.

274. If the stationary CI internal combustion engine is an emergency stationary internal combustion engine, the owner or operator is not required to submit an initial notification. [40 CFR §60.4214(b)]

NESHAP ZZZZ

275. The Emergency Generators, SN-115 through SN-121, are subject to the requirements of NESHAP ZZZZ- *National Emissions Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines*.

a. SN-118 and SN-119 are new (commenced construction on or after June 12, 2006) compression ignition (CI) stationary RICEs with a site rating of less than or equal to 500 brake HP and located at a major source of HAP emissions. [40 CFR §63.6590(a)(2)(ii)]

b. SN-115, SN-116, SN-117, SN-120, and SN-121 are existing (commenced construction before June 12, 2006) compression ignition (CI) stationary RICEs with a site rating of less than or equal to 500 brake HP located at a major source of HAP. [40 CFR §63.6590(a)(1)(ii)]

276. SN-118 and SN-119, as new compression ignition stationary RICE with a site rating of less than or equal to 500 HP, must meet the requirements of NESHAP ZZZZ by meeting the requirements of 40 CFR part 60 subpart IIII, for compression ignition engines. No further requirements apply for such engines under this subpart. [40 CFR §63.6590(c)]

277. SN-115, SN-116, SN-117, SN-120, and SN-121 must comply with the applicable requirements in Table 2c. [40 CFR §63.6602 and Table 2c]

a. Change oil and filter every 500 hours of operation or annually, whichever comes first.

b. Inspect air cleaner every 1,000 hours of operation or annually, whichever comes first.

c. Inspect all hoses and belts every 500 hours of operation or annually, whichever comes first, and replace as necessary.

d. Sources have the option to utilize an oil analysis program as described in §63.6625(i) in order to extend the specified oil change requirement in Table 2c of this subpart.

e. Sources can petition the Administrator pursuant to the requirements of 40 CFR 63.6(g) for alternative work practices.

278. The permittee must be in compliance with the operating limitations in this subpart that apply to you at all times. [40 CFR §63.6605(a)]

279. The permittee must operate and maintain any affected source, including associated air pollution control equipment and monitoring equipment, in a manner consistent with safety and good air pollution control practices for minimizing emissions. Determination of whether such operation and maintenance procedures are being used will be based on information available to the Administrator which may include, but is not limited to, monitoring results, review of operation and maintenance procedures, review of operation and maintenance records, and inspection of the source. [40 CFR §63.6605(b)]

280. The permittee must operate and maintain the stationary RICE and after-treatment control device (if any) according to the manufacturer's emission-related written instructions or develop your own maintenance plan which must provide to the extent practicable for the maintenance and operation of the engine in a manner consistent with good air pollution control practice for minimizing emissions. [40 CFR §63.6625(e)]

281. The permittee must install a non-resettable hour meter at SN-115, SN-116, SN-117, SN-120, and SN-121, if one has not already been installed. [40 CFR §63.6625 (f)]

282. The permittee has the option of utilizing an oil analysis program in order to extend the specified oil change requirement in Tables 2c and 2d to this subpart. The oil analysis must be performed at the same frequency specified for changing the oil in Table 2c or 2d to this subpart. The analysis program must at a minimum analyze the following three parameters: Total Base Number, viscosity, and percent water content. The condemning limits for these parameters are as follows: Total Base Number is less than 30 percent of

the Total Base Number of the oil when new; viscosity of the oil has changed by more than 20 percent from the viscosity of the oil when new; or percent water content (by volume) is greater than 0.5. If all of these condemning limits are not exceeded, the engine owner or operator is not required to change the oil. If any of the limits are exceeded, the engine owner or operator must change the oil within 2 days of receiving the results of the analysis; if the engine is not in operation when the results of the analysis are received, the engine owner or operator must change the oil within 2 days or before commencing operation, whichever is later. The owner or operator must keep records of the parameters that are analyzed as part of the program, the results of the analysis, and the oil changes for the engine. The analysis program must be part of the maintenance plan for the engine. [40 CFR §63.6625(h)(i)]

283. The permittee must operate the emergency stationary RICE according to the requirements in paragraphs (f)(1)(i) through (iii) of this section. Any operation other than emergency operation, maintenance and testing, and operation in non-emergency situations for 50 hours per year, as described in paragraphs (f)(1)(i) through (iii) of this section, is prohibited. If you do not operate the engine according to the requirements in paragraphs (f)(1)(i) through (iii) of this section, the engine will not be considered an emergency engine under this subpart and will need to meet all requirements for non-emergency engines. [40 CFR §63.6640(f)]

a. There is no time limit on the use of emergency stationary RICE in emergency situations. [40 CFR §63.6640(f)(i)]

b. You may operate your emergency stationary RICE for the purpose of maintenance checks and readiness testing, provided that the tests are recommended by Federal, State or local government, the manufacturer, the vendor, or the insurance company associated with the engine. Maintenance checks and readiness testing of such units is limited to 100 hours per year. The owner or operator may petition the Administrator for approval of additional hours to be used for maintenance checks and readiness testing, but a petition is not required if the owner or operator maintains records indicating that Federal, State, or local standards require maintenance and testing of emergency RICE beyond 100 hours per year. [40 CFR §63.6640(f)(ii)]

c. You may operate your emergency stationary RICE up to 50 hours per year in non-emergency situations, but those 50 hours are counted towards the 100 hours per year provided for maintenance and testing. The 50 hours per year for non-emergency situations cannot be used for peak shaving or to generate income for a facility to supply power to an electric grid or otherwise supply power as part of a financial arrangement with another entity; except that owners and operators may operate the emergency engine for a maximum of 15 hours per year as part of a demand response program if the regional transmission organization or equivalent balancing authority and transmission operator has determined there are emergency conditions that could lead to a potential electrical blackout, such as

unusually low frequency, equipment overload, capacity or energy deficiency, or unacceptable voltage level. The engine may not be operated for more than 30 minutes prior to the time when the emergency condition is expected to occur, and the engine operation must be terminated immediately after the facility is notified that the emergency condition is no longer imminent. The 15 hours per year of demand response operation are counted as part of the 50 hours of operation per year provided for non-emergency situations. The supply of emergency power to another entity or entities pursuant to financial arrangement is not limited by this paragraph (f)(1)(iii), as long as the power provided by the financial arrangement is limited to emergency power. [40 CFR §63.6640(f)(iii)]

284. As existing stationary emergency RICE, or an existing stationary RICE that is not subject to any numerical emission standards, the permittee is exempt from submitting the notifications in §§63.7(b) and (c), 63.8(e), (f)(4) and (f)(6), 63.9(b) through (e), and (g) and (h). [40 CFR §63.6645(a)(5)]

285. The permittee must keep records of the maintenance conducted on the stationary RICE in order to demonstrate that you operated and maintained the stationary RICE and after-treatment control device (if any) according to your own maintenance plan if you own or operate any of the following stationary RICE. [40 CFR §63.6655(e)]

286. The permittee must keep records of the hours of operation of the engine that is recorded through the non-resettable hour meter. The owner or operator must document how many hours are spent for emergency operation, including what classified the operation as emergency and how many hours are spent for non-emergency operation. If the engines are used for demand response operation, the owner or operator must keep records of the notification of the emergency situation, and the time the engine was operated as part of demand response. [40 CFR §63.6655(f)]

287. The permittee must be in a form suitable and readily available for expeditious review according to §63.10(b)(1). [40 CFR §63.6660(a)]

288. The permittee must keep each record for 5 years following the date of each occurrence, measurement, maintenance, corrective action, report, or record. [40 CFR §63.6660(b)]

289. The permittee must keep each record readily accessible in hard copy or electronic form for at least 5 years after the date of each occurrence, measurement, maintenance, corrective action, report, or record, according to §63.10(b)(1). [40 CFR §63.6660(c)]

SECTION V: COMPLIANCE PLAN AND SCHEDULE

Georgia-Pacific LLC - Crossett Paper Operations will continue to operate in compliance with those identified regulatory provisions. The facility will examine and analyze future regulations that may apply and determine their applicability with any necessary action taken on a timely basis.

SECTION VI: PLANTWIDE CONDITIONS

1. The permittee shall notify the Director in writing within thirty (30) days after commencing construction, completing construction, first placing the equipment and/or facility in operation, and reaching the equipment and/or facility target production rate. [Regulation 19, §19.704, 40 CFR Part 52, Subpart E, and A.C.A. §8-4-203 as referenced by A.C.A. §8-4-304 and §8-4-311]

2. If the permittee fails to start construction within eighteen months or suspends construction for eighteen months or more, the Director may cancel all or part of this permit. [Regulation 19, §19.410(B) and 40 CFR Part 52, Subpart E]

3. The permittee must test any equipment scheduled for testing, unless otherwise stated in the Specific Conditions of this permit or by any federally regulated requirements, within the following time frames: (1) new equipment or newly modified equipment within sixty (60) days of achieving the maximum production rate, but no later than 180 days after initial start up of the permitted source or (2) operating equipment according to the time frames set forth by the Department or within 180 days of permit issuance if no date is specified. The permittee must notify the Department of the scheduled date of compliance testing at least fifteen (15) business days in advance of such test. The permittee shall submit the compliance test results to the Department within thirty (30) calendar days after completing the testing. [Regulation 19 §19.702 and/or Regulation 18 §18.1002 and A.C.A. §8-4-203 as referenced by §8-4-304 and §8-4-311]

4. The permittee must provide:

   a. Sampling ports adequate for applicable test methods;
   b. Safe sampling platforms;
   c. Safe access to sampling platforms; and
   d. Utilities for sampling and testing equipment.

   [Regulation 19, §19.702 and/or Regulation 18, §18.1002 and A.C.A. §8-4-203 as referenced by A.C.A. §8-4-304 and §8-4-311]

5. The permittee must operate the equipment, control apparatus and emission monitoring equipment within the design limitations. The permittee shall maintain the equipment in good condition at all times. [Regulation 19, §19.303 and A.C.A. §8-4-203 as referenced by A.C.A. §8-4-304 and §8-4-311]

6. This permit subsumes and incorporates all previously issued air permits for this facility. [Regulation 26 and A.C.A. §8-4-203 as referenced by A.C.A. §8-4-304 and §8-4-311]

Chemical Accident Prevention Provisions

7. The permittee shall comply with all applicable provisions of 40 CFR §68.1 through §68.220. [40 CFR Part §68]

Oil Tank Requirement for SN-22, SN-25, and SN-26

8. The permittee shall monitor and record on a daily basis the fuel oil storage tank level which will be used to calculate the as fired sulfur content on a 30-day rolling average. The recorded 30-day rolling average value shall not exceed 1.0% by weight. This record shall be updated on a monthly basis. This report shall be submitted to the Department in accordance with General Provision #7 [§19.705 of Regulation #19 and 40 CFR Part 52 Subpart E]

9. The sulfur content of the fuel oil shall be verified by testing or vendors' guarantees. The permittee shall maintain a record of each fuel shipment and the associated sulfur content. This record shall be updated with each shipment, kept on site, shall be made available to Department personnel upon request and may be used by the Department for enforcement purposes. This report shall be submitted to the Department in accordance with General Provision #7. [§19.705 of Regulation #19 and 40 CFR Part 52 Subpart E]

Requirements for a Passing NAAQS Demonstration

10. In accordance with the air dispersion modeling analyses report submitted for the Crossett Complex on March 29, 2011, the permittee shall assure that the following changes to the Plywood/Studmill are completed before starting up any new and/or modified air emitting equipment associated with the Diamond Project. Upon completion of the changes, Georgia-Pacific's Crossett Paper Operations will submit a written report to the Department certifying that all of the changes described in sections a- c below, or as alternatively agreed pursuant to section d below, have been completed:

    a. Install a powered ventilation system over each board press and discharge the press exhaust through a stack. Each stack will have a height of 40 feet or greater, and a stack diameter of 4.5 feet or less.

    b. Pave sections of unpaved log truck roads at the Plywood/Studmill facility to mitigate fugitive dust emissions. The sections of log truck roads to be paved are identified in the March 29, 2011 modeling analyses report.

    c. The following wood residual material handling cyclones shall be retrofitted with baghouses to reduce PM_{10} emissions. The permittee shall maintain documentation that each baghouse achieves an outlet PM_{10} grain loading of 0.005 grain/dscf or less:

        i. C9, Wood Residuals Collection System (Plant #2)

ii. C11, Wood Residuals Collection System (Plant #1)
iii. C12, Wood Residuals Collection System (Plant #1)

d. Georgia-Pacific Plywood/Studmill may elect to conduct additional air dispersion modeling which demonstrates compliance with the National Ambient Air Quality Standards (NAAQS) modeled in the March 29, 2011 report. Such additional modeling may consider any combination of the above listed changes, or any other facility configuration (including other changes not listed above) that achieves a modeling resolution showing compliance with the pertinent NAAQS. Any such additional modeling, along with supporting documentation, shall be submitted to the Department prior to the planned commencement of any of the Plywood/Studmill changes. If such additional modeling demonstrates that any of the facility changes listed in #s 1-3 above are no longer necessary for NAAQS compliance demonstration purposes, and written concurrence is obtained from the Department, then the permittee shall only be required to complete the facility changes, if any, relied upon in the updated modeling analysis.

e. Prior to starting up any new and/or modified air emitting equipment associated with the Diamond Project, the Paper Operations shall submit written certification to the Department that the Plywood/Studmill has completed all such required changes (i.e., those listed in #s 1-3 above or as relied upon in any revised complex-wide air dispersion modeling analyses reviewed and approved by the Department). [§19.705 of Regulation #19 and 40 CFR Part 52 Subpart E]

11. In accordance with the air dispersion modeling analyses report submitted for the Crossett Complex on March 29, 2011, the permittee shall assure that the following changes to the Paper facility are completed before starting up any new and/or modified air emitting equipment associated with the Diamond Project of Air Permit 597-AOP-R13:

Source	Stack Change
SN-115	Modify to Vertical Stack
SN-116	
SN-117	
SN-118	
SN-119	
SN-120	
SN-121	

Upon completion of the changes, Georgia-Pacific's Crossett Paper Operations will submit a written report to the Department certifying that all of the changes described below have been completed. [§19.705 of Regulation #19 and 40 CFR Part 52 Subpart E]

12. The following requirements shall apply to any new Diamond project source or any existing source affected by the Diamond project changes as submitted to the Department in the January 11, 2011 application.

    a. Except as otherwise provided in paragraph (r)(6)(vi)(b) of this section, the provisions of this paragraph (r)(6) apply with respect to any regulated NSR pollutant emitted from projects at existing emissions units at a major stationary source (other than projects at a source with a PAL) in circumstances where there is a reasonable possibility, within the meaning of paragraph (r)(6)(vi) of this section, that a project that is not a part of a major modification may result in a significant emissions increase of such pollutant, and the owner or operator elects to use the method specified in paragraphs (b)(41)(ii)(a) through (c) of this section for calculating projected actual emissions.

        i. Before beginning actual construction of the project, the owner or operator shall document and maintain a record of the following information:

        ii. A description of the project;

        iii. Identification of the emissions unit(s) whose emissions of a regulated NSR pollutant could be affected by the project; and

        iv. A description of the applicability test used to determine that the project is not a major modification for any regulated NSR pollutant, including the baseline actual emissions, the projected actual emissions, the amount of emissions excluded under paragraph (b)(41)(ii)(c) of this section and an explanation for why such amount was excluded, and any netting calculations, if applicable.

    b. The owner or operator shall monitor the emissions of any regulated NSR pollutant that could increase as a result of the project and that is emitted by any emissions unit identified in paragraph (r)(6)(i)(b) of this section; and calculate and maintain a record of the annual emissions, in tons per year on a calendar year basis, for a period of 5 years following resumption of regular operations after the change, or for a period of 10 years following resumption of regular operations after the change if the project increases the design capacity or potential to emit that regulated NSR pollutant at such emissions unit.

    c. If the unit is an existing unit other than an electric utility steam generating unit, the owner or operator shall submit a report to the Administrator if the annual emissions, in tons per year, from the project identified in paragraph (r)(6)(i) of this section, exceed the baseline actual emissions (as documented and maintained pursuant to paragraph (r)(6)(i)(c) of this section), by a significant amount (as defined in paragraph (b)(23) of this section) for that regulated NSR pollutant, and if such emissions differ from the preconstruction projection as documented and

maintained pursuant to paragraph (r)(6)(i)(c) of this section. Such report shall be submitted to the Administrator within 60 days after the end of such year. The report shall contain the following:

i. The name, address and telephone number of the major stationary source;

ii. The annual emissions as calculated pursuant to paragraph (r)(6)(iii) of this section; and

iii. Any other information that the owner or operator wishes to include in the report (e.g., an explanation as to why the emissions differ from the preconstruction projection).

d. A "reasonable possibility" under paragraph (r)(6) of this section occurs when the owner or operator calculates the project to result in either:

i. A projected actual emissions increase of at least 50 percent of the amount that is a "significant emissions increase," as defined under paragraph (b)(40) of this section (without reference to the amount that is a significant net emissions increase), for the regulated NSR pollutant; or

ii. A projected actual emissions increase that, added to the amount of emissions excluded under paragraph (b)(41)(ii)(c) of this section, sums to at least 50 percent of the amount that is a "significant emissions increase," as defined under paragraph (b)(40) of this section (without reference to the amount that is a significant net emissions increase), for the regulated NSR pollutant. For a project for which a reasonable possibility occurs only within the meaning of paragraph (r)(6)(vi)(b) of this section, and not also within the meaning of paragraph (r)(6)(vi)(a) of this section, then provisions (r)(6)(ii) through (v) do not apply to the project.

e. The owner or operator of the source shall make the information required to be documented and maintained pursuant to paragraph (r)(6) of this section available for review upon a request for inspection by the Administrator or the general public pursuant to the requirements contained in §70.4(b)(3)(viii) of this chapter.

NESHAP JJJ

13. The permittee must limit organic HAP emissions at SN-71, 72, and 80 to the level specified in paragraph (b)(1), (2), or (3) of this section. [40 CFR Part §63.3320(b)(i-iii)]

a. **New Sources**

i. No more than 2 percent of the organic HAP applied for each month (98 percent reduction) [40 CFR §63.3320(b)(1)]

ii. No more than 1.6 percent of the mass of coating materials applied for each month [40 CFR §63.3320(b)(2)]

iii. No more than 8 percent of the coating solids applied for each month [40 CFR §63.3320(b)(3)]

b. **Existing Sources**

i. No more than 5 percent of the organic HAP applied for each month (95 percent reduction) [40 CFR §63.3320(b)(1)]

ii. No more than 4 percent of the mass of coating materials applied for each month [40 CFR §63.3320(b)(2)]

iii. No more than 20 percent of the mass of coating solids applied for each month [40 CFR §63.3320(b)(3)]

14. A new affected source subject to the provisions of this subpart, your compliance date is immediately upon start-up of the new affected source or by December 4, 2002, whichever is later. You must complete any performance test required in §63.3360 within the time limits specified in §63.7(a)(2). [40 CFR Part §63.3330(a)]

15. An existing affected source subject to the provisions of this subpart, you must comply by the compliance date. The compliance date for existing affected sources in this subpart is December 5, 2005. You must complete any performance test required in §63.3360 within the time limits specified in §63.7(a)(2). [40 CFR Part §63.3330(b)]

16. **Organic HAP content**. If you determine compliance with the emission standards in §63.3320 by means other than determining the overall organic HAP control efficiency of a control device, you must determine the organic HAP mass fraction of each coating material "as-purchased" by following one of the procedures in paragraphs (c)(1) through (3) of this section, and determine the organic HAP mass fraction of each coating material "as-applied" by following the procedures in paragraph (c)(4) of this section. If the organic HAP content values are not determined using the procedures in paragraphs (c)(1) through (3) of this section, the owner or operator must submit an alternative test method for determining their values for approval by the Administrator in accordance with §63.7(f). The recovery efficiency of the test method must be determined for all of the target organic HAP and a correction factor, if necessary, must be determined and applied.

a. **Method 311.** You may test the coating material in accordance with Method 311 of appendix A of this part. The Method 311 determination may be performed by the manufacturer of the coating material and the results provided to the owner or operator. The organic HAP content must be calculated according to the criteria and procedures in paragraphs (c)(1)(i) through (iii) of this section. [40 CFR §63.3360(c)(1)]

i. Include each organic HAP determined to be present at greater than or equal to 0.1 mass percent for Occupational Safety and Health Administration (OSHA)-defined carcinogens as specified in 29 CFR 1910.1200(d)(4) and greater than or equal to 1.0 mass percent for other organic HAP compounds. [40 CFR §63.3360(c)(1)(i)]

ii. Express the mass fraction of each organic HAP you include according to paragraph (c)(1)(i) of this section as a value truncated to four places after the decimal point (for example, 0.3791). [40 CFR §63.3360(c)(1)(ii)]

iii. Calculate the total mass fraction of organic HAP in the tested material by summing the counted individual organic HAP mass fractions and truncating the result to three places after the decimal point (for example, 0.763). [40 CFR §63.3360(c)(1)(iii)]

b. **Method 24.** For coatings, determine the volatile organic content as mass fraction of non-aqueous volatile matter and use it as a substitute for organic HAP using Method 24 of 40 CFR part 60, appendix A. The Method 24 determination may be performed by the manufacturer of the coating and the results provided to you. [40 CFR §63.3360(c)(2)]

c. **Formulation data.** You may use formulation data to determine the organic HAP mass fraction of a coating material. Formulation data may be provided to the owner or operator by the manufacturer of the material. In the event of an inconsistency between Method 311 (appendix A of 40 CFR part 63) test data and a facility's formulation data, and the Method 311 test value is higher, the Method 311 data will govern. Formulation data may be used provided that the information represents all organic HAP present at a level equal to or greater than 0.1 percent for OSHA-defined carcinogens as specified in 29 CFR 1910.1200(d)(4) and equal to or greater than 1.0 percent for other organic HAP compounds in any raw material used. [40 CFR §63.3360(c)(3)]

d. **As-applied organic HAP mass fraction.** If the as-purchased coating material is applied to the web without any solvent or other material added, then the as-applied organic HAP mass fraction is equal to the as-purchased organic HAP mass fraction. Otherwise, the as-applied organic HAP mass fraction must be calculated using Equation 1a of §63.3370. [40 CFR §63.3360(c)(4)]

17. **Volatile organic and coating solids content**. If you determine compliance with the emission standards in §63.3320 by means other than determining the overall organic HAP control efficiency of a control device and you choose to use the volatile organic content as a surrogate for the organic HAP content of coatings, you must determine the as-purchased volatile organic content and coating solids content of each coating material applied by following the procedures in paragraph (d)(1) or (2) of this section, and the as-

applied volatile organic content and coating solids content of each coating material by following the procedures in paragraph (d)(3) of this section.

a. **Method 24**. You may determine the volatile organic and coating solids mass fraction of each coating applied using Method 24 (40 CFR part 60, appendix A.) The Method 24 determination may be performed by the manufacturer of the material and the results provided to you. If these values cannot be determined using Method 24, you must submit an alternative technique for determining their values for approval by the Administrator. [40 CFR §63.3360(d)(1)]

b. **Formulation data**. You may determine the volatile organic content and coating solids content of a coating material based on formulation data and may rely on volatile organic content data provided by the manufacturer of the material. In the event of any inconsistency between the formulation data and the results of Method 24 of 40 CFR part 60, appendix A, and the Method 24 results are higher, the results of Method 24 will govern. [40 CFR §63.3360(d)(2)]

c. **As-applied volatile organic content and coating solids content**. If the as-purchased coating material is applied to the web without any solvent or other material added, then the as-applied volatile organic content is equal to the as-purchased volatile content and the as-applied coating solids content is equal to the as-purchased coating solids content. Otherwise, the as-applied volatile organic content must be calculated using Equation 1b of §63.3370 and the as-applied coating solids content must be calculated using Equation 2 of §63.3370. [40 CFR §63.3360(d)(3)]

18. **Volatile matter retained in the coated web or otherwise not emitted to the atmosphere.** The permittee may choose to take into account the mass of volatile matter retained in the coated web after curing or drying or otherwise not emitted to the atmosphere when determining compliance with the emission standards in §63.3320. If you choose this option, you must develop a testing protocol to determine the mass of volatile matter retained in the coated web or otherwise not emitted to the atmosphere and submit this protocol to the Administrator for approval. You must submit this protocol with your site-specific test plan under §63.7(f). If you intend to take into account the mass of volatile matter retained in the coated web after curing or drying or otherwise not emitted to the atmosphere and demonstrate compliance according to §63.3370(c)(3), (c)(4), (c)(5), or (d), then the test protocol you submit must determine the mass of organic HAP retained in the coated web or otherwise not emitted to the atmosphere. Otherwise, compliance must be shown using the volatile organic matter content as a surrogate for the HAP content of the coatings. [40 CFR Part §63.3360(g)]

19. The permittee must demonstrate compliance with this subpart by following the procedures in §63.3370.

a. **As-purchased "compliant" coating materials**

i. If you comply by using coating materials that individually meet the emission standards in §63.3320(b)(2) or (3), you must demonstrate that each coating material applied during the month at an existing affected source contains no more than 0.04 mass fraction organic HAP or 0.2 kg organic HAP per kg coating solids, and that each coating material applied during the month at a new affected source contains no more than 0.016 mass fraction organic HAP or 0.08 kg organic HAP per kg coating solids on an as-purchased basis as determined in accordance with §63.3360(c). [40 CFR Part §63.3370(b)(1)]

ii. You are in compliance with emission standards in §63.3320(b)(2) and (3) if each coating material applied at an existing affected source is applied as-purchased and contains no more than 0.04 kg organic HAP per kg coating material or 0.2 kg organic HAP per kg coating solids, and each coating material applied at a new affected source is applied as-purchased and contains no more than 0.016 kg organic HAP per kg coating material or 0.08 kg organic HAP per kg coating solids. [40 CFR Part §63.3370(b)(2)]

b. **Use of "as-applied" compliant coating materials**

i. Each coating material as-applied meets the mass fraction of coating material standard (§63.3320(b)(2)). You must demonstrate that each coating material applied at an existing affected source during the month contains no more than 0.04 kg organic HAP per kg coating material applied, and each coating material applied at a new affected source contains no more than 0.016 kg organic HAP per kg coating material applied as determined in accordance with paragraphs (c)(1)(i) and (ii) of this section. You must calculate the as-applied organic HAP content of as-purchased coating materials which are reduced, thinned, or diluted prior to application. [40 CFR Part §63.3370(c)(1)(i) and (ii)]

1. Determine the organic HAP content or volatile organic content of each coating material applied on an as-purchased basis in accordance with §63.3360(c).

2. Calculate the as-applied organic HAP content of each coating material using Equation 1a or 1b of this section

ii. Each coating material as-applied meets the mass fraction of coating solids standard (§63.3320(b)(3)). You must demonstrate that each coating material applied at an existing affected source contains no more than 0.20 kg of organic HAP per kg of coating solids applied and each coating material applied at a new affected source contains no more than 0.08 kg of

organic HAP per kg of coating solids applied. You must demonstrate compliance in accordance with paragraphs (c)(2)(i) and (ii) of this section. [40 CFR Part §63.3370(c)(2)(i) and (ii)]

1. Determine the as-applied coating solids content of each coating material following the procedure in §63.3360(d). You must calculate the as-applied coating solids content of coating materials which are reduced, thinned, or diluted prior to application, using Equation 2 of this section

2. Calculate the as-applied organic HAP to coating solids ratio using Equation 3 of this section.

iii. Monthly average organic HAP content of all coating materials as-applied is less than the mass percent limit (§63.3320(b)(2)). Demonstrate that the monthly average as-applied organic HAP content of all coating materials applied at an existing affected source is less than 0.04 kg organic HAP per kg of coating material applied, and all coating materials applied at a new affected source are less than 0.016 kg organic HAP per kg of coating material applied, as determined by Equation 4 of this section. [40 CFR Part §63.3370(c)(3)]

iv. Monthly average organic HAP content of all coating materials as-applied is less than the mass percent limit (§63.3320(b)(2)). Demonstrate that the monthly average as-applied organic HAP content of all coating materials applied at an existing affected source is less than 0.04 kg organic HAP per kg of coating material applied, and all coating materials applied at a new affected source are less than 0.016 kg organic HAP per kg of coating material applied, as determined by Equation 4 of this section. [40 CFR Part §63.3370(c)(4)]

v. The affected source is in compliance with emission standards in §63.3320(b)(2) or (3) if: [40 CFR Part §63.3370(c)(5)(i) and (ii)]

1. The organic HAP content of each coating material as-applied at an existing affected source is no more than 0.04 kg organic HAP per kg coating material or 0.2 kg organic HAP per kg coating solids, and the organic HAP content of each coating material as-applied at a new affected source contains no more than 0.016 kg organic HAP per kg coating material or 0.08 kg organic HAP per kg coating solids; or

2. The monthly average organic HAP content of all as-applied coating materials at an existing affected source are no more than 0.04 kg organic HAP per kg coating material or 0.2 kg organic

HAP per kg coating solids, and the monthly average organic HAP content of all as-applied coating materials at a new affected source is no more than 0.016 kg organic HAP per kg coating material or 0.08 kg organic HAP per kg coating solids.

c. **Tracking total monthly organic HAP applied.** Demonstrate that the total monthly organic HAP applied as determined by Equation 6 of this section is less than the calculated equivalent allowable organic HAP as determined by Equation 13a or b in paragraph (l) of this section. [40 CFR Part §63.3370(d)]

20. The permittee must submit an initial notification as required by §63.9(b). [40 CFR Part §63.3400(b)(1-4)]

a. Initial notification for existing affected sources must be submitted no later than 1 year before the compliance date specified in §63.3330(a).

b. Initial notification for new and reconstructed affected sources must be submitted as required by §63.9(b).

c. For the purpose of this subpart, a title V or part 70 permit application may be used in lieu of the initial notification required under §63.9(b), provided the same information is contained in the permit application as required by §63.9(b) and the State to which the permit application has been submitted has an approved operating permit program under part 70 of this chapter and has received delegation of authority from the EPA to implement and enforce this subpart.

d. If you are using a permit application in lieu of an initial notification in accordance with paragraph (b)(3) of this section, the permit application must be submitted by the same due date specified for the initial notification.

21. The permittee must submit a semiannual compliance report according to paragraphs (c)(1) and (2) of this section.

a. Compliance report dates. [40 CFR Part §63.3400(c)(1)(i-v)]

i. The first compliance report must cover the period beginning on the compliance date that is specified for your affected source in §63.3330 and ending on June 30 or December 31, whichever date is the first date following the end of the calendar half immediately following the compliance date that is specified for your affected source in §63.3330.

ii. The first compliance report must be postmarked or delivered no later than July 31 or January 31, whichever date follows the end of the calendar half immediately following the compliance date that is specified for your affected source in §63.3330.

iii. Each subsequent compliance report must cover the semiannual reporting period from January 1 through June 30 or the semiannual reporting period from July 1 through December 31.

iv. Each subsequent compliance report must be postmarked or delivered no later than July 31 or January 31, whichever date is the first date following the end of the semiannual reporting period.

v. For each affected source that is subject to permitting regulations pursuant to 40 CFR part 70 or 40 CFR part 71, and the permitting authority has established dates for submitting semiannual reports pursuant to §70.6(a)(3)(iii)(A) or §71.6(a)(3)(iii)(A), you may submit the first and subsequent compliance reports according to the dates the permitting authority has established instead of according to the dates in paragraphs (c)(1)(i) through (iv) of this section.

b. The compliance report must contain the information in paragraphs (c)(2)(i) through (vi) of this section: [40 CFR Part §63.3400(c)(2)(i-v)]

i. Company name and address.

ii. Statement by a responsible official with that official's name, title, and signature certifying the accuracy of the content of the report.

iii. Date of report and beginning and ending dates of the reporting period.

iv. If there are no deviations from any emission limitations (emission limit or operating limit) that apply to you, a statement that there were no deviations from the emission limitations during the reporting period, and that no CMS was inoperative, inactive, malfunctioning, out-of-control, repaired, or adjusted.

v. For each deviation from an emission limitation (emission limit or operating limit) that applies to you and that occurs at an affected source where you are not using a CEMS to comply with the emission limitations in this subpart, the compliance report must contain the information in paragraphs (c)(2)(i) through (iii) of this section, and:

1. The total operating time of each affected source during the reporting period.

2. Information on the number, duration, and cause of deviations (including unknown cause), if applicable, and the corrective action taken.

3. Information on the number, duration, and cause for CPMS downtime incidents, if applicable, other than downtime associated with zero and span and other calibration checks.

22. The permittee must submit a Notification of Compliance Status as specified in §63.9(h). [40 CFR Part §63.3400(e)]

23. Each owner or operator of an affected source subject to this subpart must maintain the records specified in paragraphs (a)(1) and (2) of this section on a monthly basis in accordance with the requirements of §63.10(b)(1).. Records specified in §63.10(b)(2) of all measurements needed to demonstrate compliance with this standard, including: [40 CFR Part §63.3401(a)(1)(i-vi)]

a. Organic HAP content data for the purpose of demonstrating compliance in accordance with the requirements of §63.3360(c);
b. Volatile matter and coating solids content data for the purpose of demonstrating compliance in accordance with the requirements of §63.3360(d);

c. Material usage, organic HAP usage, volatile matter usage, and coating solids usage and compliance demonstrations using these data in accordance with the requirements of §63.3370(b), (c), and (d).

Title VI Provisions

24. The permittee must comply with the standards for labeling of products using ozone-depleting substances. [40 CFR Part 82, Subpart E]

a. All containers containing a class I or class II substance stored or transported, all products containing a class I substance, and all products directly manufactured with a class I substance must bear the required warning statement if it is being introduced to interstate commerce pursuant to §82.106.

b. The placement of the required warning statement must comply with the requirements pursuant to §82.108.

c. The form of the label bearing the required warning must comply with the requirements pursuant to §82.110.

d. No person ma y modify, remove, or interfere with the required warning statement except as described in §82.112.

25. The permittee must comply with the standards for recycling and emissions reduction, except as provided for MVACs in Subpart B. [40 CFR Part 82, Subpart F]

a. Persons opening appliances for maintenance, service, repair, or disposal must comply with the required practices pursuant to §82.156.

b. Equipment used during the maintenance, service, repair, or disposal of appliances must comply with the standards for recycling and recovery equipment pursuant to §82.158.

c. Persons performing maintenance, service repair, or disposal of appliances must be certified by an approved technician certification program pursuant to §82.161.

d. Persons disposing of small appliances, MVACs, and MVAC like appliances must comply with record keeping requirements pursuant to §82.166. ("MVAC like appliance" as defined at §82.152)

e. Persons owning commercial or industrial process refrigeration equipment must comply with leak repair requirements pursuant to §82.156.

f. Owners/operators of appliances normally containing 50 or more pounds of refrigerant must keep records of refrigerant purchased and added to such appliances pursuant to §82.166.

26. If the permittee manufactures, transforms, destroys, imports, or exports a class I or class II substance, the permittee is subject to all requirements as specified in 40 CFR Part 82, Subpart A, Production and Consumption Controls.

27. If the permittee performs a service on motor (fleet) vehicles when this service involves ozone depleting substance refrigerant (or regulated substitute substance) in the motor vehicle air conditioner (MVAC), the permittee is subject to all the applicable requirements as specified in 40 CFR part 82, Subpart B, Servicing of Motor Vehicle Air Conditioners.

28. The term "motor vehicle" as used in Subpart B does not include a vehicle in which final assembly of the vehicle has not been completed. The term "MVAC" as used in Subpart B does not include the air tight sealed refrigeration system used as refrigerated cargo, or the system used on passenger buses using HCFC 22 refrigerant.

29. The permittee can switch from any ozone depleting substance to any alternative listed in the Significant New Alternatives Program (SNAP) promulgated pursuant to 40 CFR Part 82, Subpart G.

SECTION VII: INSIGNIFICANT ACTIVITIES

The following sources are insignificant activities. Any activity that has a state or federal applicable requirement shall be considered a significant activity even if this activity meets the criteria of §26.304 of Regulation 26 or listed in the table below. Insignificant activity determinations rely upon the information submitted by the permittee in an application dated 5/15/2008.

Description	Category
9A Cyclone	A-13
Trim Paper Cyclone	A-13
Perini Towel Rewinder and Spectrum Towel Printer Baghouse	A-13
Spectrum Towel Printer, utilizing 0.21 wt% VOC, no HAP inks	A-13
Filling Starch Silos	A-13
Diesel Fuel Tank	A-3
Turpentine Tank	A-3
No. 8 Extruder Burner, 1.55 and 0.85 MMBTU/hr	A-1
No. 9 Extruder Burners, 1.0 MMBTU/hr (total)	A-1
Gasoline Tank	A-13
No. 6 Fuel Oil Tank 1	A-13
No. 6 Fuel Oil Tank 2	A-13

SECTION VIII: GENERAL PROVISIONS

1. Any terms or conditions included in this permit which specify and reference Arkansas Pollution Control & Ecology Commission Regulation 18 or the Arkansas Water and Air Pollution Control Act (A.C.A. §8-4-101 et seq.) as the sole origin of and authority for the terms or conditions are not required under the Clean Air Act or any of its applicable requirements, and are not federally enforceable under the Clean Air Act. Arkansas Pollution Control & Ecology Commission Regulation 18 was adopted pursuant to the Arkansas Water and Air Pollution Control Act (A.C.A. §8-4-101 et seq.). Any terms or conditions included in this permit which specify and reference Arkansas Pollution Control & Ecology Commission Regulation 18 or the Arkansas Water and Air Pollution Control Act (A.C.A. §8-4-101 et seq.) as the origin of and authority for the terms or conditions are enforceable under this Arkansas statute. [40 CFR 70.6(b)(2)]

2. This permit shall be valid for a period of five (5) years beginning on the date this permit becomes effective and ending five (5) years later. [40 CFR 70.6(a)(2) and §26.701(B) of the Regulations of the Arkansas Operating Air Permit Program (Regulation 26)]

3. The permittee must submit a complete application for permit renewal at least six (6) months before permit expiration. Permit expiration terminates the permittee's right to operate unless the permittee submitted a complete renewal application at least six (6) months before permit expiration. If the permittee submits a complete application, the existing permit will remain in effect until the Department takes final action on the renewal application. The Department will not necessarily notify the permittee when the permit renewal application is due. [Regulation 26, §26.406]

4. Where an applicable requirement of the Clean Air Act, as amended, 42 U.S.C. 7401, et seq. (Act) is more stringent than an applicable requirement of regulations promulgated under Title IV of the Act, the permit incorporates both provisions into the permit, and the Director or the Administrator can enforce both provisions. [40 CFR 70.6(a)(1)(ii) and Regulation 26, §26.701(A)(2)]

5. The permittee must maintain the following records of monitoring information as required by this permit.

    a. The date, place as defined in this permit, and time of sampling or measurements;
    b. The date(s) analyses performed;
    c. The company or entity performing the analyses;
    d. The analytical techniques or methods used;
    e. The results of such analyses; and
    f. The operating conditions existing at the time of sampling or measurement.

    [40 CFR 70.6(a)(3)(ii)(A) and Regulation 26, §26.701(C)(2)]

6. The permittee must retain the records of all required monitoring data and support information for at least five (5) years from the date of the monitoring sample, measurement, report, or application. Support information includes all calibration and maintenance records and all original strip chart recordings for continuous monitoring instrumentation, and copies of all reports required by this permit. [40 CFR 70.6(a)(3)(ii)(B) and Regulation 26, §26.701(C)(2)(b)]

7. The permittee must submit reports of all required monitoring every six (6) months. If permit establishes no other reporting period, the reporting period shall end on the last day of the anniversary month of the initial Title V permit. The report is due within thirty (30) days of the end of the reporting period. Although the reports are due every six months, each report shall contain a full year of data. The report must clearly identify all instances of deviations from permit requirements. A responsible official as defined in Regulation No. 26, §26.2 must certify all required reports. The permittee will send the reports to the address below:

    Arkansas Department of Environmental Quality
    Air Division
    ATTN: Compliance Inspector Supervisor
    5301 Northshore Drive
    North Little Rock, AR 72118-5317

    [40 C.F.R. 70.6(a)(3)(iii)(A) and Regulation 26, §26.701(C)(3)(a)]

8. The permittee shall report to the Department all deviations from permit requirements, including those attributable to upset conditions as defined in the permit.

    a. For all upset conditions (as defined in Regulation19, § 19.601), the permittee will make an initial report to the Department by the next business day after the discovery of the occurrence. The initial report may be made by telephone and shall include:

        i. The facility name and location;
        ii. The process unit or emission source deviating from the permit limit;
        iii. The permit limit, including the identification of pollutants, from which deviation occurs;
        iv. The date and time the deviation started;
        v. The duration of the deviation;
        vi. The average emissions during the deviation;
        vii. The probable cause of such deviations;
        viii. Any corrective actions or preventive measures taken or being taken to prevent such deviations in the future; and
        ix. The name of the person submitting the report.

The permittee shall make a full report in writing to the Department within five (5) business days of discovery of the occurrence. The report must include, in addition to the information required by the initial report, a schedule of actions taken or planned to eliminate future occurrences and/or to minimize the amount the permit's limits were exceeded and to reduce the length of time the limits were exceeded. The permittee may submit a full report in writing (by facsimile, overnight courier, or other means) by the next business day after discovery of the occurrence, and the report will serve as both the initial report and full report.

b. For all deviations, the permittee shall report such events in semi-annual reporting and annual certifications required in this permit. This includes all upset conditions reported in 8a above. The semi-annual report must include all the information as required by the initial and full reports required in 8a.

[Regulation 19, §19.601 and §19.602, Regulation 26, §26.701(C)(3)(b), and 40 CFR 70.6(a)(3)(iii)(B)]

9. If any provision of the permit or the application thereof to any person or circumstance is held invalid, such invalidity will not affect other provisions or applications hereof which can be given effect without the invalid provision or application, and to this end, provisions of this Regulation are declared to be separable and severable. [40 CFR 70.6(a)(5), Regulation 26, §26.701(E), and A.C.A. §8-4-203 as referenced by A.C.A. §8-4-304 and §8-4-311]

10. The permittee must comply with all conditions of this Part 70 permit. Any permit noncompliance with applicable requirements as defined in Regulation 26 constitutes a violation of the Clean Air Act, as amended, 42 U.S.C. §7401, et seq. and is grounds for enforcement action; for permit termination, revocation and reissuance, for permit modification; or for denial of a permit renewal application. [40 CFR 70.6(a)(6)(i) and Regulation 26, §26.701(F)(1)]

11. It shall not be a defense for a permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity to maintain compliance with the conditions of this permit. [40 CFR 70.6(a)(6)(ii) and Regulation 26, §26.701(F)(2)]

12. The Department may modify, revoke, reopen and reissue the permit or terminate the permit for cause. The filing of a request by the permittee for a permit modification, revocation and reissuance, termination, or of a notification of planned changes or anticipated noncompliance does not stay any permit condition. [40 CFR 70.6(a)(6)(iii) and Regulation 26, §26.701(F)(3)]

13. This permit does not convey any property rights of any sort, or any exclusive privilege. [40 CFR 70.6(a)(6)(iv) and Regulation 26, §26.701(F)(4)]

14. The permittee must furnish to the Director, within the time specified by the Director, any information that the Director may request in writing to determine whether cause exists for modifying, revoking and reissuing, or terminating the permit or to determine compliance with the permit. Upon request, the permittee must also furnish to the Director copies of records required by the permit. For information the permittee claims confidentiality, the Department may require the permittee to furnish such records directly to the Director along with a claim of confidentiality. [40 CFR 70.6(a)(6)(v) and Regulation 26, §26.701(F)(5)]

15. The permittee must pay all permit fees in accordance with the procedures established in Regulation 9. [40 CFR 70.6(a)(7) and Regulation 26, §26.701(G)]

16. No permit revision shall be required, under any approved economic incentives, marketable permits, emissions trading and other similar programs or processes for changes provided for elsewhere in this permit. [40 CFR 70.6(a)(8) and Regulation 26, §26.701(H)]

17. If the permit allows different operating scenarios, the permittee shall, contemporaneously with making a change from one operating scenario to another, record in a log at the permitted facility a record of the operational scenario. [40 CFR 70.6(a)(9)(i) and Regulation 26, §26.701(I)(1)]

18. The Administrator and citizens may enforce under the Act all terms and conditions in this permit, including any provisions designed to limit a source's potential to emit, unless the Department specifically designates terms and conditions of the permit as being federally unenforceable under the Act or under any of its applicable requirements. [40 CFR 70.6(b) and Regulation 26, §26.702(A) and (B)]

19. Any document (including reports) required by this permit must contain a certification by a responsible official as defined in Regulation 26, §26.2. [40 CFR 70.6(c)(1) and Regulation 26, §26.703(A)]

20. The permittee must allow an authorized representative of the Department, upon presentation of credentials, to perform the following: [40 CFR 70.6(c)(2) and Regulation 26, §26.703(B)]

    a. Enter upon the permittee's premises where the permitted source is located or emissions related activity is conducted, or where records must be kept under the conditions of this permit;
    b. Have access to and copy, at reasonable times, any records required under the conditions of this permit;
    c. Inspect at reasonable times any facilities, equipment (including monitoring and air pollution control equipment), practices, or operations regulated or required under this permit; and

d. As authorized by the Act, sample or monitor at reasonable times substances or parameters for assuring compliance with this permit or applicable requirements.

21. The permittee shall submit a compliance certification with the terms and conditions contained in the permit, including emission limitations, standards, or work practices. The permittee must submit the compliance certification annually within 30 days following the last day of the anniversary month of the initial Title V permit. The permittee must also submit the compliance certification to the Administrator as well as to the Department. All compliance certifications required by this permit must include the following: [40 CFR 70.6(c)(5) and Regulation 26, §26.703(E)(3)]

a. The identification of each term or condition of the permit that is the basis of the certification;
b. The compliance status;
c. Whether compliance was continuous or intermittent;
d. The method(s) used for determining the compliance status of the source, currently and over the reporting period established by the monitoring requirements of this permit; and
e. Such other facts as the Department may require elsewhere in this permit or by §114(a)(3) and §504(b) of the Act.

22. Nothing in this permit will alter or affect the following: [Regulation 26, §26.704(C)]

a. The provisions of Section 303 of the Act (emergency orders), including the authority of the Administrator under that section;
b. The liability of the permittee for any violation of applicable requirements prior to or at the time of permit issuance;
c. The applicable requirements of the acid rain program, consistent with §408(a) of the Act; or
d. The ability of EPA to obtain information from a source pursuant to §114 of the Act.

23. This permit authorizes only those pollutant emitting activities addressed in this permit. [A.C.A. §8-4-203 as referenced by A.C.A. §8-4-304 and §8-4-311]

24. The permittee may request in writing and at least 15 days in advance of the deadline, an extension to any testing, compliance or other dates in this permit. No such extensions are authorized until the permittee receives written Department approval. The Department may grant such a request, at its discretion in the following circumstances:

a. Such an extension does not violate a federal requirement;
b. The permittee demonstrates the need for the extension; and
c. The permittee documents that all reasonable measures have been taken to meet the current deadline and documents reasons it cannot be met.

[Regulation 18, §18.314(A), Regulation 19, §19.416(A), Regulation 26, §26.1013(A), A.C.A. §8-4-203 as referenced by A.C.A. §8-4-304 and §8-4-311, and 40 CFR Part 52, Subpart E]

25. The permittee may request in writing and at least 30 days in advance, temporary emissions and/or testing that would otherwise exceed an emission rate, throughput requirement, or other limit in this permit. No such activities are authorized until the permittee receives written Department approval. Any such emissions shall be included in the facility's total emissions and reported as such. The Department may grant such a request, at its discretion under the following conditions:

a. Such a request does not violate a federal requirement;
b. Such a request is temporary in nature;
c. Such a request will not result in a condition of air pollution;
d. The request contains such information necessary for the Department to evaluate the request, including but not limited to, quantification of such emissions and the date/time such emission will occur;
e. Such a request will result in increased emissions less than five tons of any individual criteria pollutant, one ton of any single HAP and 2.5 tons of total HAPs; and
f. The permittee maintains records of the dates and results of such temporary emissions/testing.

[Regulation 18, §18.314(B), Regulation 19, §19.416(B), Regulation 26, §26.1013(B), A.C.A. §8-4-203 as referenced by A.C.A. §8-4-304 and §8-4-311, and 40 CFR Part 52, Subpart E]

26. The permittee may request in writing and at least 30 days in advance, an alternative to the specified monitoring in this permit. No such alternatives are authorized until the permittee receives written Department approval. The Department may grant such a request, at its discretion under the following conditions:

a. The request does not violate a federal requirement;
b. The request provides an equivalent or greater degree of actual monitoring to the current requirements; and
c. Any such request, if approved, is incorporated in the next permit modification application by the permittee.

[Regulation 18, §18.314(C), Regulation 19, §19.416(C), Regulation 26, §26.1013(C), A.C.A. §8-4-203 as referenced by A.C.A. §8-4-304 and §8-4-311, and 40 CFR Part 52, Subpart E]

Arkansas Department of Environmental Quality

CONTINUOUS EMISSION MONITORING SYSTEMS CONDITIONS

Revised August 2004

PREAMBLE

These conditions are intended to outline the requirements for facilities required to operate Continuous Emission Monitoring Systems/Continuous Opacity Monitoring Systems (CEMS/COMS). Generally there are three types of sources required to operate CEMS/COMS:

1. CEMS/COMS required by 40 CFR Part 60 or 63,
2. CEMS required by 40 CFR Part 75,
3. CEMS/COMS required by ADEQ permit for reasons other that Part 60, 63 or 75.

These CEMS/COMS conditions are not intended to supercede Part 60, 63 or 75 requirements.

- Only CEMS/COMS in the third category (those required by ADEQ permit for reasons other than Part 60, 63, or 75) shall comply with SECTION II, MONITORING REQUIREMENTS and SECTION IV, QUALITY ASSURANCE/QUALITY CONTROL.

- All CEMS/COMS shall comply with Section III, NOTIFICATION AND RECORDKEEPING.

SECTION I

DEFINITIONS

Continuous Emission Monitoring System (CEMS) - The total equipment required for the determination of a gas concentration and/or emission rate so as to include sampling, analysis and recording of emission data.

Continuous Opacity Monitoring System (COMS) - The total equipment required for the determination of opacity as to include sampling, analysis and recording of emission data.

Calibration Drift (CD) - The difference in the CEMS output reading from the established reference value after a stated period of operation during which no unscheduled maintenance, repair, or adjustments took place.

Back-up CEMS (Secondary CEMS) - A CEMS with the ability to sample, analyze and record stack pollutant to determine gas concentration and/or emission rate. This CEMS is to serve as a back-up to the primary CEMS to minimize monitor downtime.

Excess Emissions - Any period in which the emissions exceed the permit limits.

Monitor Downtime - Any period during which the CEMS/COMS is unable to sample, analyze and record a minimum of four evenly spaced data points over an hour, except during one daily zero-span check during which two data points per hour are sufficient.

Out-of-Control Period - Begins with the time corresponding to the completion of the fifth, consecutive, daily CD check with a CD in excess of two times the allowable limit, or the time corresponding to the completion of the daily CD check preceding the daily CD check that results in a CD in excess of four times the allowable limit and the time corresponding to the completion of the sampling for the RATA, RAA, or CGA which exceeds the limits outlined in Section IV. Out-of-Control Period ends with the time corresponding to the completion of the CD check following corrective action with the results being within the allowable CD limit or the completion of the sampling of the subsequent successful RATA, RAA, or CGA.

Primary CEMS - The main reporting CEMS with the ability to sample, analyze, and record stack pollutant to determine gas concentration and/or emission rate.

Relative Accuracy (RA) - The absolute mean difference between the gas concentration or emission rate determined by the CEMS and the value determined by the reference method plus the 2.5 percent error confidence coefficient of a series of tests divided by the mean of the reference method tests of the applicable emission limit.

Span Value – The upper limit of a gas concentration measurement range.

SECTION II

MONITORING REQUIREMENTS

A. For new sources, the installation date for the CEMS/COMS shall be no later than thirty (30) days from the date of start-up of the source.

B. For existing sources, the installation date for the CEMS/COMS shall be no later than sixty (60) days from the issuance of the permit unless the permit requires a specific date.

C. Within sixty (60) days of installation of a CEMS/COMS, a performance specification test (PST) must be completed. PST's are defined in 40 CFR, Part 60, Appendix B, PS 1-9. The Department may accept alternate PST's for pollutants not covered by Appendix B on a case-by-case basis. Alternate PST's shall be approved, in writing, by the ADEQ CEM Coordinator prior to testing.

D. Each CEMS/COMS shall have, as a minimum, a daily zero-span check. The zero-span shall be adjusted whenever the 24-hour zero or 24-hour span drift exceeds two times the limits in the applicable performance specification in 40 CFR, Part 60, Appendix B. Before any adjustments are made to either the zero or span drifts measured at the 24-hour interval the excess zero and span drifts measured must be quantified and recorded.

E. All CEMS/COMS shall be in continuous operation and shall meet minimum frequency of operation requirements of 95% up-time for each quarter for each pollutant measured. Percent of monitor down-time is calculated by dividing the total minutes the monitor is not in operation by the total time in the calendar quarter and multiplying by one hundred. Failure to maintain operation time shall constitute a violation of the CEMS conditions.

F. Percent of excess emissions are calculated by dividing the total minutes of excess emissions by the total time the source operated and multiplying by one hundred. Failure to maintain compliance may constitute a violation of the CEMS conditions.

G. All CEMS measuring emissions shall complete a minimum of one cycle of operation (sampling, analyzing, and data recording) for each successive fifteen minute period unless more cycles are required by the permit. For each CEMS, one-hour averages shall be computed from four or more data points equally spaced over each one hour period unless more data points are required by the permit.

H. All COMS shall complete a minimum of one cycle of sampling and analyzing for each successive 10-second period and one cycle of data recording for each successive 6-minute period.

I. When the pollutant from a single affected facility is released through more than one point, a CEMS/COMS shall be installed on each point unless installation of fewer systems is approved, in writing, by the ADEQ CEM Coordinator. When more than one CEM/COM is used to monitor emissions from one affected facility the owner or operator shall report the results as required from each CEMS/COMS.

SECTION III

NOTIFICATION AND RECORD KEEPING

A. When requested to do so by an owner or operator, the ADEQ CEM Coordinator will review plans for installation or modification for the purpose of providing technical advice to the owner or operator.

B. Each facility which operates a CEMS/COMS shall notify the ADEQ CEM Coordinator of the date for which the demonstration of the CEMS/COMS performance will commence (i.e. PST, RATA, RAA, CGA). Notification shall be received in writing no less than 15 days prior to testing. Performance test results shall be submitted to the Department within thirty days after completion of testing.

C. Each facility which operates a CEMS/COMS shall maintain records of the occurrence and duration of start up/shut down, cleaning/soot blowing, process problems, fuel problems, or other malfunction in the operation of the affected facility which causes excess emissions. This includes any malfunction of the air pollution control equipment or any period during which a continuous monitoring device/system is inoperative.

D. Except for Part 75 CEMs, each facility required to install a CEMS/COMS shall submit an excess emission and monitoring system performance report to the Department (Attention: Air Division, CEM Coordinator) at least quarterly, unless more frequent submittals are warranted to assess the compliance status of the facility. Quarterly reports shall be postmarked no later than the 30th day of the month following the end of each calendar quarter. Part 75 CEMs shall submit this information semi-annually and as part of Title V six (6) month reporting requirement if the facility is a Title V facility.

E. All excess emissions shall be reported in terms of the applicable standard. Each report shall be submitted on ADEQ Quarterly Excess Emission Report Forms. Alternate forms may be used with prior written approval from the Department.

F. Each facility which operates a CEMS/COMS must maintain on site a file of CEMS/COMS data including all raw data, corrected and adjusted, repair logs, calibration checks, adjustments, and test audits. This file must be retained for a period of at least five years, and is required to be maintained in such a condition that it can easily be audited by an inspector.

G. Except for Part 75 CEMs, quarterly reports shall be used by the Department to determine compliance with the permit. For Part 75 CEMs, the semi-annual report shall be used.

SECTION IV

QUALITY ASSURANCE/QUALITY CONTROL

A. For each CEMS/COMS a Quality Assurance/Quality Control (QA/QC) plan shall be submitted to the Department (Attn.: Air Division, CEM Coordinator). CEMS quality assurance procedures are defined in 40 CFR, Part 60, Appendix F. This plan shall be submitted within 180 days of the CEMS/COMS installation. A QA/QC plan shall consist of procedure and practices which assures acceptable level of monitor data accuracy, precision, representativeness, and availability.

B. The submitted QA/QC plan for each CEMS/COMS shall not be considered as accepted until the facility receives a written notification of acceptance from the Department.

C. Facilities responsible for one, or more, CEMS/COMS used for compliance monitoring shall meet these minimum requirements and are encouraged to develop and implement a more extensive QA/QC program, or to continue such programs where they already exist. Each QA/QC program must include written procedures which should describe in detail, complete, step-by-step procedures and operations for each of the following activities:

1. Calibration of CEMS/COMS
   a. Daily calibrations (including the approximate time(s) that the daily zero and span drifts will be checked and the time required to perform these checks and return to stable operation)
2. Calibration drift determination and adjustment of CEMS/COMS
   a. Out-of-control period determination
   b. Steps of corrective action
3. Preventive maintenance of CEMS/COMS
   a. CEMS/COMS information
      1) Manufacture
      2) Model number
      3) Serial number
   b. Scheduled activities (check list)
   c. Spare part inventory
4. Data recording, calculations, and reporting
5. Accuracy audit procedures including sampling and analysis methods
6. Program of corrective action for malfunctioning CEMS/COMS

D. A Relative Accuracy Test Audit (RATA), shall be conducted at least once every four calendar quarters. A Relative Accuracy Audit (RAA), or a Cylinder Gas Audit (CGA), may be conducted in the other three quarters but in no more than three quarters in succession. The RATA should be conducted in accordance with the applicable test procedure in 40 CFR Part 60 Appendix A and calculated in accordance with the applicable performance specification in 40 CFR Part 60 Appendix B. CGA's and RAA's should be conducted and the data calculated in accordance with the procedures outlined on 40 CFR Part 60 Appendix F.

If alternative testing procedures or methods of calculation are to be used in the RATA, RAA or CGA audits prior authorization must be obtained from the ADEQ CEM Coordinator.

E. Criteria for excessive audit inaccuracy.

RATA

All Pollutants except Carbon Monoxide	> 20% Relative Accuracy
Carbon Monoxide	> 10% Relative Accuracy
All Pollutants except Carbon Monoxide	> 10% of the Applicable Standard
Carbon Monoxide	> 5% of the Applicable Standard
Diluent (O_2 & CO_2)	> 1.0 % O2 or CO2
Flow	> 20% Relative Accuracy

CGA

Pollutant	> 15% of average audit value or 5 ppm difference
Diluent (O_2 & CO_2)	> 15% of average audit value or 5 ppm difference

RAA

Pollutant	> 15% of the three run average or > 7.5 % of the applicable standard
Diluent (O_2 & CO_2)	> 15% of the three run average or > 7.5 % of the applicable standard

F. If either the zero or span drift results exceed two times the applicable drift specification in 40 CFR, Part 60, Appendix B for five consecutive, daily periods, the CEMS is out-of-control. If either the zero or span drift results exceed four times the applicable drift specification in Appendix B during a calibration drift check, the CEMS is out-of-control. If the CEMS exceeds the audit inaccuracies listed above, the CEMS is out-of-control. If a CEMS is out-of-control, the data from that out-of-control period is not counted towards meeting the minimum data availability as required and described in the applicable subpart. The end of the out-of-control period is the time corresponding to the completion of the successful daily zero or span drift or completion of the successful CGA, RAA or RATA.

G. A back-up monitor may be placed on an emission source to minimize monitor downtime. This back-up CEMS is subject to the same QA/QC procedure and practices as the primary CEMS. The back-up CEMS shall be certified by a PST. Daily zero-span checks must be performed and recorded in accordance with standard practices. When the primary CEMS goes down, the back-up CEMS may then be engaged to sample, analyze and record the emission source pollutant until repairs are made and the primary unit is placed back in service. Records must be maintained on site when the back-up CEMS is placed in service, these records shall include at a minimum the reason the primary CEMS is out of service, the date and time the primary CEMS was out of service and the date and time the primary CEMS was placed back in service.

Electronic Code of Federal Regulations
e-CFR™

e-CFR Data is current as of May 12, 2011

Title 40: Protection of Environment

PART 60—STANDARDS OF PERFORMANCE FOR NEW STATIONARY SOURCES

Browse Previous | Browse Next

Subpart D—Standards of Performance for Fossil-Fuel-Fired Steam Generators for Which Construction Is Commenced After August 17, 1971

Source: 72 FR 32717, June 13, 2007, unless otherwise noted.

§ 60.40 Applicability and designation of affected facility.

(a) The affected facilities to which the provisions of this subpart apply are:

(1) Each fossil-fuel-fired steam generating unit of more than 73 megawatts (MW) heat input rate (250 million British thermal units per hour (MMBtu/hr)).

(2) Each fossil-fuel and wood-residue-fired steam generating unit capable of firing fossil fuel at a heat input rate of more than 73 MW (250 MMBtu/hr).

(b) Any change to an existing fossil-fuel-fired steam generating unit to accommodate the use of combustible materials, other than fossil fuels as defined in this subpart, shall not bring that unit under the applicability of this subpart.

(c) Except as provided in paragraph (d) of this section, any facility under paragraph (a) of this section that commenced construction or modification after August 17, 1971, is subject to the requirements of this subpart.

(d) The requirements of §§60.44 (a)(4), (a)(5), (b) and (d), and 60.45(f)(4)(vi) are applicable to lignite-fired steam generating units that commenced construction or modification after December 22, 1976.

(e) Any facility covered under subpart Da is not covered under this subpart.

§ 60.41 Definitions.

As used in this subpart, all terms not defined herein shall have the meaning given them in the Act, and in subpart A of this part.

Boiler operating day means a 24-hour period between 12 midnight and the following midnight during which any fuel is combusted at any time in the steam-generating unit. It is not necessary for fuel to be combusted the entire 24-hour period.

Coal means all solid fuels classified as anthracite, bituminous, subbituminous, or lignite by ASTM D388 (incorporated by reference, see §60.17).

Coal refuse means waste-products of coal mining, cleaning, and coal preparation operations (e.g. culm, gob, etc.) containing coal, matrix material, clay, and other organic and inorganic material.

Fossil fuel means natural gas, petroleum, coal, and any form of solid, liquid, or gaseous fuel derived from such materials for the purpose of creating useful heat.

Fossil fuel and wood residue-fired steam generating unit means a furnace or boiler used in the process of burning fossil fuel and wood residue for the purpose of producing steam by heat transfer.

Fossil-fuel-fired steam generating unit means a furnace or boiler used in the process of burning fossil fuel for the purpose of producing steam by heat transfer.

Wood residue means bark, sawdust, slabs, chips, shavings, mill trim, and other wood products derived from wood processing and forest management operations.

§ 60.42 Standard for particulate matter (PM).

Link to an amendment published at 76 FR 3522, Jan. 20, 2011.

(a) On and after the date on which the performance test required to be conducted by §60.8 is completed, no owner or operator subject to the provisions of this subpart shall cause to be discharged into the atmosphere from any affected facility any gases that:

(1) Contain PM in excess of 43 nanograms per joule (ng/J) heat input (0.10 lb/MMBtu) derived from fossil fuel or fossil fuel and wood residue.

(2) Exhibit greater than 20 percent opacity except for one six-minute period per hour of not more than 27 percent opacity.

(b)(1) On or after December 28, 1979, no owner or operator shall cause to be dischargedinto the atmosphere from the Southwestern Public Service Company's Harrington Station #1, in Amarillo, TX, any gases which exhibit greater than 35 percent opacity, except that a maximum or 42 percent opacity shall be permitted for not more than 6 minutes in any hour.

(2) Interstate Power Company shall not cause to be discharged into the atmosphere from its Lansing Station Unit No. 4 in Lansing, IA, any gases which exhibit greater than 32 percert opacity, except that a maximum of 39 percent opacity shall be permitted for not more than six minutes in any hour.

(c) As an alternate to meeting the requirements of paragraph (a) of this section, an owner or operator that elects to install, calibrate, maintain, and operate a continuous emissions monitoring systems (CEMS) for measuring PM emissions can petition the Administrator (in writing) to comply with §60.42Da (a) of subpart Da of this part. If the Administrator grants the petition, the source will from then on (unless the unit is modified or reconstructed in the future) have to comply with the requirements in §60.43Da(a) of subpart Da of this part.

[60 FR 65415, Dec. 19, 1995, as amended at 74 FR 5077, Jan. 28, 2009]

§ 60.43 Standard for sulfur dioxide (SO_2).

(a) Except as provided under paragraph (d) of this section, on and after the date on which the performance test required to be conducted by §60.8 is completed, no owner or operator subject to the provisions of this subpart shall cause to be discharged into the atmosphere from any affected facility any gases that contain SO_2 in excess of:

(1) 340 ng/J heat input (0.80 lb/MMBtu) derived from liquid fossil fuel or liquid fossil fuel and wood residue.

(2) 520 ng/J heat input (1.2 lb/MMBtu) derived from solid fossil fuel or solid fossil fuel and wood residue, except as provided in paragraph (e) of this section.

(b) Except as provided under paragraph (d) of this section, when different fossil fuels are burned simultaneously in any combination, the applicable standard (in ng/J) shall be determined by proration using the following formula:

$$PS_{SO_2} = \frac{y\,(340) + z\,(520)}{(y + z)}$$

Where:

$PS_{SO}2$= Prorated standard for $S_{O2}$when burning different fuels simultaneously, in ng/J heat input derived from all fossil fuels or from all fossil fuels and wood residue fired;

y = Percentage of total heat input derived from liquid fossil fuel; and

z = Percentage of total heat input derived from solid fossil fuel.

(c) Compliance shall be based on the total heat input from all fossil fuels burned, including gaseous fuels.

(d) As an alternate to meeting the requirements of paragraphs (a) and (b) of this section, an owner or operator can petition the Administrator (in writing) to comply with §60.43Da(i)(3) of subpart Da of this part or comply with §60.42b(k)(4) of subpart Db of this part, as applicable to the afected source. If the Administrator grants the petition, the source will from then on (unless the unit is modified or reconstructed in the future) have to comply with the requirements in §60.43Da(i)(3) of subpart Da of this part or §60.42b(k)(4) of subpart Db of this part, as applicable to the afected source.

(e) Units 1 and 2 (as defined in appendix G of this part) at the Newton Power Station owned or operated by the Central Illinois Public Service Company will be in compliance with paragraph (a)(2) of this section if Unit 1 and Unit 2 individually comply with paragraph (a)(2) of this section or if the combined emission rate from Units 1 and 2 does not exceed 470 ng/J (1.1 lb/MMBtu) combined heat input to Units 1 and 2.

[60 FR 65415, Dec. 19, 1995, as amended at 74 FR 5077, Jan. 28, 2009]

§ 60.44 Standard for nitrogen oxides (NOX).

(a) Except as provided under paragraph (e) of this section, on and after the date on which the performance test required to be conducted by §60.8 is completed, no owner or operator subject to the provisions of this subpart shall cause to be discharged into the atmosphere from any affected facility any gases that contain NO_X, expressed as NO_2 in excess of:

(1) 86 ng/J heat input (0.20 lb/MMBtu) derived from gaseous fossil fuel.

(2) 129 ng/J heat input (0.30 lb/MMBtu) derived from liquid fossil fuel, liquid fossil fuel and wood residue, or gaseous fossil fuel and wood residue.

(3) 300 ng/J heat input (0.70 lb/MMBtu) derived from solid fossil fuel or solid fossil fuel and wood residue (except lignite or a solid fossil fuel containing 25 percent, by weight, or more of coal refuse).

(4) 260 ng/J heat input (0.60 lb MMBtu) derived from lignite or lignite and wood residue (except as provided under paragraph (a)(5) of this section).

(5) 340 ng/J heat input (0.80 lb MMBtu) derived from lignite which is mined in North Dakota, South Dakota, or Montana and which is burned in a cyclone-fired unit.

(b) Except as provided under paragraphs (c), (d), and (e) of this section, when different fossil fuels are burned simultaneously in any combination, the applicable standard (in ng/J) is determined by proration using the following formula:

$$PS_{NO_2} = \frac{w\,(260) + x\,(86) + y\,(130) + z\,(300)}{(w + x + y + z)}$$

Where:

PS_{NOX}= Prorated standard for $NO_X$when burning different fuels simultaneously, in ng/J heat input derived from all fossil fuels fired or from all fossil fuels and wood residue fired;

w = Percentage of total heat input derived from lignite;

x = Percentage of total heat input derived from gaseous fossil fuel;

y = Percentage of total heat input derived from liquid fossil fuel; and

z = Percentage of total heat input derived from solid fossil fuel (except lignite).

(c) When a fossil fuel containing at least 25 percent, by weight, of coal refuse is burned in combination with gaseous, liquid, or other solid fossil fuel or wood residue, the standard for NO_Xdoes not apply.

(d) Except as provided under paragraph (e) of this section, cyclone-fired units which burn fuels containing at least 25 percent of lignite that is mined in North Dakota, South Dakota, or Montana remain subject to paragraph (a)(5) of this section regardless of the types of fuel combusted in combination with that lignite.

(e) As an alternate to meeting the requirements of paragraphs (a), (b), and (d) of this section, an owner or operator can petition the Administrator (in writing) to comply with §60.44Da(e)(3) of subpart Da of this part. If the Administrator grants the petition, the source will from then on (unless the unit is modified or reconstructed in the future) have to comply with the requirements in §60.44Da(e)(3) of subpart Da of this part.

§ 60.45 Emissions and fuel monitoring.

(a) Each owner or operator shall install, calibrate, maintain, and operate continuous opacity monitoring system (COMS) for measuring opacity and a CEMS for measuring SO2 emissions, NOX emissions, and either oxygen (O2) or carbon dioxide (CO2) except as provided in paragraph (b) of this section.

(b) Certain of the CEMS requirements under paragraph (a) of this section do not apply to owners or operators under the following conditions:

(1) For a fossil-fuel-fired steam generator that burns only gaseous or liquid fossil fuel (excluding residual oil) with potential SO2 emissions rates of 26 ng/J (0.060 lb/MMBtu) or less and that does not use post-combustion technology to reduce emissions of SO2 or PM, CEMS for measuring the opacity of emissions and SO2 emissions are not required if the owner or operator monitors SO2 emissions by fuel sampling and analysis or fuel receipts.

(2) For a fossil-fuel-fired steam generator that does not use a flue gas desulfurization device, a CEMS for measuring SO_2 emissions is not required if the owner or operator monitors SO_2 emissions by fuel sampling and analysis.

(3) Notwithstanding §60.13(b), installation of a CEMS for NO_X may be delayed until after the initial performance tests under §60.8 have been conducted. If the owner or operator demonstrates during the performance test that emissions of NO_X are less than 70 percent of the applicable standards in §60.44, a CEMS for measuring NO_X emissions is not required. If the initial performance test results show that NO_X emissions are greater than 70 percent of the applicable standard, the owner or operator shall install a CEMS for NO_X within one year after the date of the initial performance tests under §60.8 and comply with all other applicable monitoring requirements under this part.

(4) If an owner or operator does not install any CEMS for sulfur oxides and NO_X, as provided under paragraphs (b)(1) and (b)(3) or paragraphs (b)(2) and (b)(3) of this section a CEMS for measuring either O_2 or CO_2 is not required.

(5) An owner or operator may petition the Administrator (in writing) to install a PM CEMS as an alternative to the CEMS for monitoring opacity emissions.

(6) A CEMS for measuring the opacity of emissions is not required for a fossil fuel-fired steam generator that does not use post-combustion technology (except a wet scrubber) for reducing PM, SO_2, or carbon monoxide (CO) emissions, burns only gaseous fuels or fuel oils that contain less than or equal to 0.30 weight percent sulfur, and is operated such that emissions of CO to the atmosphere from the affected source are maintained at levels less than or equal to 0.15 lb/MMBtu on a boiler operating day average basis. Owners and operators of affected sources electing to comply with this paragraph must demonstrate compliance according to the procedures specifed in paragraphs (b)(6)(i) through (iv) of this section.

(i) You must monitor CO emissions using a CEMS according to the procedures specifed in paragraphs (b)(6)(i)(A) through (D) of this section.

(A) The CO CEMS must be installed, certified, maintained, and operated according to the provisions in §60.58b(i)(3) of subpart Eb of this part.

(B) Each 1-hour CO emissions average is calculated using the data points generated by the CO CEMS expressed in parts per million by volume corrected to 3 percent oxygen (dry basis).

(C) At a minimum, valid 1-hour CO emissions averages must be obtained for at least 90 percent of the operating hours on a 30-day rolling average basis. The 1-hour averages are calculated using the data points required in §60.13(h)(2).

(D) Quarterly accuracy determinations and daily calibration drift tests for the CO CEMS must be performed in accordance with procedure 1 in appendix F of this part.

(ii) You must calculate the 1-hour average CO emissions levels for each boiler operating day by multiplying the average hourly CO output concentration measured by the CO CEMS times the corresponding average hourly flue gas flow rate and divided by the corresponding average hourly heat input to the affected source. The 24-hour average CO emission level is determined by calculating the arithmetic average of the hourly CO emission levels computed for each boiler operating day.

(iii) You must evaluate the preceding 24-hour average CO emission level each boiler operating day excluding periods of affected source startup, shutdown, or malfunction. If the 24-hour average CO emission level is greater than 0.15 lb/MMBtu, you must initiate investigation of the relevant equipment and control systems within 24 hours of the first discovery of the high emission incident and, take the appropriate corrective action as soon as practicable to adjust control settings or repair equipment to reduce the 24-hour average CO emission level to 0.15 lb/MMBtu or less.

(iv) You must record the CO measurements and calculations performed according to paragraph (b)(6) of this section and any corrective actions taken. The record of corrective action taken must include the date and time during which the 24-hour average CO emission level was greater than 0.15 lb/MMBtu, and the date, time, and description of the corrective action.

(7) An owner or operator of an affected facility subject to an opacity standard under §60.42 that elects to not use a COMS because the affected facility burns only fuels as specified under paragraph (b)(1) of this section, monitors PM emissions as specified under paragraph (b)(5) of this section, or monitors CO emissions as specifed under paragraph (b)(6) of this section, shall conduct a performance test using Method 9 of appendix A–4 of this part and the procedures in §60.11 to demonstrate compliance with the applicable limit in §60.42 by April 29, 2011 or within 45 days after stopping use of an existing COMS, whichever is later, and shall comply with either paragraph (b)(7)(i), (b)(7)(ii), or (b)(7)(iii) of this section. The observation period for Method 9 of appendix A–4 of this part performance tests may be reduced from 3 hours to 60 minutes if all 6-minute averages are less than 10 percent and all individual 15-second observations are less than or equal to 20 percent during the initial 60 minutes of observation. The permitting authority may exempt owners or operators of affected facilities burning only natural gas from the opacity monitoring requirements.

(i) Except as provided in paragraph (b)(7)(ii) or (b)(7)(iii) of this section, the owner or operator shall conduct subsequent Method 9 of appendix A–4 of this part performance tests using the procedures in paragraph (b)(7) of this section according to the applicable schedule in paragraphs (b)(7)(i)(A) through (b)(7)(i)(D) of this section, as determined by the most recent Method 9 of appendix A–4 of this part performance test results.

(A) If no visible emissions are observed, a subsequent Method 9 of appendix A–4 of this part performance test must be completed within 12 calendar months from the date that the most recent performance test was conducted;

(B) If visible emissions are observed but the maximum 6-minute average opacity is less than or equal to 5 percent, a subsequent Method 9 of appendix A–4 of this part performance test must be completed within 6 calendar months from the date that the most recent performance test was conducted;

(C) If the maximum 6-minute average opacity is greater than 5 percent but less than or equal to10 percent, a subsequent Method 9 of appendix A–4 of this part performance test must be completed within 3 calendar months from the date that the most recent performance test was conducted; or

(D) If the maximum 6-minute average opacity is greater than 10 percent, a subsequent Method 9 of appendix A–4 of this part performance test must be completed within 45 calendar days from the date that the most recent performance test was conducted.

(ii) If the maximum 6-minute opacity is less than 10 percent during the most recent Method 9 of appendix A–4 of this part performance test, the owner or operator may, as an alternative to performing subsequent Method 9 of appendix A–4 of this part performance test, elect to perform subsequent monitoring using Method 22 of appendix A–7 of this part according to the procedures specified in paragraphs (b)(7)(ii)(A) and (B) of this section.

(A) The owner or operator shall conduct 10 minute observations (during normal operation) each operating day the affected facility fires fuel for which an opacity standard is applicable using Method 22 of appendix A–7 of this part and demonstrate that the sum of the occurrences of any visible emissions is not in excess of 5 percent of the observation period (*i.e.* , 30 seconds per 10 minute period). If the sum of the occurrence of any visible emissions is greater than 30 seconds during the initial 10 minute observation, immediately conduct a 30 minute observation. If the sum of the occurrence of visible emissions is greater than 5 percent of the observation period (i.e., 90 seconds per 30 minute period), the owner or operator shall either document and adjust the operation of the facility and demonstrate within 24 hours that the sum of the occurrence of visible emissions is equal to or less than 5 percent during a 30 minute observation (i.e., 90 seconds) or conduct a new Method 9 of appendix A–4 of this part performance test using the procedures in paragraph (b)(7) of this section within 45 calendar days according to the requirements in §60.46(b)(3).

(B) If no visible emissions are observed for 30 operating days during which an opacity standard is applicable, observations can be reduced to once every 7 operating days during which an opacity standard is applicable. If any visible emissions are observed, daily observations shall be resumed.

(iii) If the maximum 6-minute opacity is less than 10 percent during the most recent Method 9 of appendix A–4 of this part performance test, the owner or operator may, as an alternative to performing subsequent Method 9 of appendix A–4 performance tests, elect to perform subsequent monitoring using a digital opacity compliance system according to a site-specific monitoring plan approved by the Administrator. The observations shall be similar, but not necessarily identical, to the requirements in paragraph (b)(7)(ii) of this section. For reference purposes in preparing the monitoring plan, see OAQPS "Determination of Visible Emission Opacity from Stationary Sources Using Computer-Based Photographic Analysis Systems." This document is available from the U.S. Environmental Protection Agency (U.S. EPA); Office of Air Quality and Planning Standards; Sector Policies and Programs Division; Measurement Policy Group (D243–02), Research Triangle Park, NC 27711. This document is also available on the Technology Transfer Network (TTN) under Emission Measurement Center Preliminary Methods.

(c) For performance evaluations under §60.13(c) and calibration checks under §60.13(d), the following procedures shall be used

(1) Methods 6, 7, and 3B of appendix A of this part, as applicable, shall be used for the performance evaluations of SO_2 and NO_X continuous monitoring systems. Acceptable alternative methods for Methods 6, 7, and 3B of appendix A of this part are given in §60.46(d).

(2) Sulfur dioxide or nitric oxide, as applicable, shall be used for preparing calibration gas mixtures under Performance Specification 2 of appendix B to this part.

(3) For affected facilities burning fossil fuel(s), the span value for a continuous monitoring system measuring the opacity of emissions shall be 80, 90, or 100 percent. For a continuous monitoring system measuring sulfur oxides or NO_X the span value shall be determined using one of the following procedures:

(i) Except as provided under paragraph (c)(3)(ii) of this section, SO_2 and NO_X span values shall be

determined as follows:

Fossil fuel	In parts per million	
	Span value for SO_2	Span value for NO_X
Gas	([1])	500.
Liquid	1,000	500.
Solid	1,500	1,000.
Combinations	1,000y + 1,500z	500 (x + y) + 1,000z.

[1]Not applicable.

Where:

x = Fraction of total heat input derived from gaseous fossil fuel;

y = Fraction of total heat input derived from liquid fossil fuel; and

z = Fraction of total heat input derived from solid fossil fuel.

(ii) As an alternative to meeting the requirements of paragraph (c)(3)(i) of this section, the owner or operator of an affected facility may elect to use the SO_2 and NO_X span values determined according to sections 2.1.1 and 2.1.2 in appendix A to part 75 of this chapter.

(4) All span values computed under paragraph (c)(3)(i) of this section for burning combinations of fossil fuels shall be rounded to the nearest 500 ppm. Span values that are computed under paragraph (c)(3)(ii) of this section shall be rounded off according to the applicable procedures in section 2 of appendix A to part 75 of this chapter.

(5) For a fossil-fuel-fired steam generator that simultaneously burns fossil fuel and nonfossil fuel, the span value of all CEMS shall be subject to the Administrator's approval.

(d) [Reserved]

(e) For any CEMS installed under paragraph (a) of this section, the following conversion procedures shall be used to convert the continuous monitoring data into units of the applicable standards (ng/J, lb/MMBtu):

(1) When a CEMS for measuring O_2 is selected, the measurement of the pollutant concentration and O_2 concentration shall each be on a consistent basis (wet or dry). Alternative procedures approved by the Administrator shall be used when measurements are on a wet basis. When measurements are on a dry basis, the following conversion procedure shall be used:

$$E = CF\left(\frac{20.9}{(20.9 - \%O_2)}\right)$$

Where E, C, F, and $\%O_2$ are determined under paragraph (f) of this section.

(2) When a CEMS for measuring CO_2 is selected, the measurement of the pollutant concentration and CO_2 concentration shall each be on a consistent basis (wet or dry) and the following conversion procedure shall be used

$$E = CF_c\left(\frac{100}{\%CO_2}\right)$$

Where E, C, F_c and $\%CO_2$ are determined under paragraph (f) of this section.

(f) The values used in the equations under paragraphs (e)(1) and (2) of this section are derived as follows:

(1) E = pollutant emissions, ng/J (lb/MMBtu).

(2) C = pollutant concentration, ng/dscm (lb/dscf), determined by multiplying the average concentration (ppm) for each one-hour period by 4.15×10^4 M ng/dscm per ppm (2.59×10^{-9}M lb/dscf per ppm) where M = pollutant molecular weight, g/g-mole (lb/lb-mole). M = 64.07 for SO_2 and 46.01 for NO_X.

(3) $\%O_2$, $\%CO_2$ = O_2 or CO_2 volume (expressed as percent), determined with equipment specified under paragraph (a) of this section.

(4) F, F_c = a factor representing a ratio of the volume of dry flue gases generated to the calorific value of the fuel combusted (F), and a factor representing a ratio of the volume of CO_2 generated to the calorific value of the fuel combusted (F_c), respectively. Values of F and F_c are given as follows:

(i) For anthracite coal as classifed according to ASTM D388 (incorporated by reference, see §60.17), F = $2,723 \times 10^{-17}$dscm/J (10,140 dscf/MMBtu) and $F_c = 0.532 \times 10^{-17}$scm CO_2/J (1,980 scf CO_2/MMBtu).

(ii) For subbituminous and bituminous coal as classifed according to ASTM D388 (incorporated by reference, see §60.17), F = 2.637×10^{-7}dscm/J (9,820 dscf/MMBtu) and $F_c = 0.486 \times 10^{-7}$scm CO_2/J (1,810 scf CO_2/MMBtu).

(iii) For liquid fossil fuels including crude, residual, and distillate oils, F = 2.476×10^{-7}dscm/J (9,220 dscf/MMBtu) and $F_c = 0.384 \times 10^{-7}$scm CO_2/J (1,430 scf CO_2/MMBtu).

(iv) For gaseous fossil fuels, F = 2.347×10^{-7}dscm/J (8,740 dscf/MMBtu). For natural gas, propane, and butane fuels, $F_c = 0.279 \times 10^{-7}$scm CO_2/J (1,040 scf CO_2/MMBtu) for natural gas, 0.322×10^{-7}scm CO_2/J (1,200 scf CO_2/MMBtu) for propane, and 0.338×10^{-7}scm CO_2/J (1,260 scf CO_2/MMBtu) for butane.

(v) For bark F = 2.589×10^{-7}dscm/J (9,640 dscf/MMBtu) and $F_c = 0.500 \times 10^{-7}$scm CO_2/J (1,840 scf CO_2/MMBtu). For wood residue other than bark F = 2.492×10^{-7}dscm/J (9,280 dscf/MMBtu) and F_c = 0.494×10^{-7}scm CO_2/J (1,860 scf CO_2/MMBtu).

(vi) For lignite coal as classifed according to ASTM D388 (incorporated by reference, see §60.17), F = 2.659×10^{-7}dscm/J (9,900 dscf/MMBtu) and $F_c = 0.516 \times 10^{-7}$scm CO_2/J (1,920 scf CO_2/MMBtu).

(5) The owner or operator may use the following equation to determine an F factor (dscm/J or dscf/MMBtu) on a dry basis (if it is desired to calculate F on a wet basis, consult the Administrator) or Fc factor (scm CO_2/J, or scf CO_2/MMBtu) on either basis in lieu of the F or F_c factors specified in paragraph (f)(4) of this section:

$$F = 10^{-6} \frac{[227.2\ (\%H) + 95.5\ (\%C) + 35.6\ (\%S) + 8.7\ (\%N) - 28.7\ (\%O)]}{GCV}$$

$$F_c = \frac{2.0 \times 10^{-5} (\%C)}{GCV\ (SI\ units)}$$

$$F = 10^{-6} \frac{[3.64\ (\%H) + 1.53\ (\%C) + 0.57\ (\%S) + 0.14\ (\%N) - 0.46\ (\%O)]}{GCV\ (English\ units)}$$

$$F_c = \frac{20.0\ (\%C)}{GCV\ (SI\ units)}$$

$$F_c = \frac{321 \times 10^3\ (\%C)}{GCV\ (English\ units)}$$

(i) %H, %C, %S, %N, and %O are content by weight of hydrogen, carbon, sulfur, nitrogen, and O_2 (expressed as percent), respectively, as determined on the same basis as GCV by ultimate analysis of the fuel fired, using ASTM D3178 or D3176 (solid fuels), or computed from results using ASTM D1137, D1945, or D1946 (gaseous fuels) as applicable. (These five methods are incorporated by reference, see §60.17.)

(ii) GVC is the gross calorific value (kJ/kg, Btu/lb) of the fuel combusted determined by the ASTM test methods D2015 or D5865 for solid fuels and D1826 for gaseous fuels as applicable. (These three methods are incorporated by reference, see §60.17.)

(iii) For affected facilities which fire both fossil fuels and nonfossil fuels, the F or Fc value shall be subject to the Administrator's approval.

(6) For affected facilities firing combinations of fossil fuels or fossil fuels and wood residue, the F or Fc factors determined by paragraphs (f)(4) or (f)(5) of this section shall be prorated in accordance with the applicable formula as follows:

$$F = \sum_{i=1}^{n} X_i F_i \quad \text{or} \quad F_c = \sum_{i=1}^{n} X_i (F_c)_i$$

Where:

X_i= Fraction of total heat input derived from each type of fuel (e.g. natural gas, bituminous coal, wood residue, etc.);

F_i or $(F_c)_i$= Applicable F or F_c factor for each fuel type determined in accordance with paragraphs (f)(4) and (f)(5) of this section; and

n = Number of fuels being burned in combination.

(g) Excess emission and monitoring system performance reports shall be submitted to the Administrator semiannually for each six-month period in the calendar year. All semiannual reports shall be postmarked by the 30th day following the end of each six-month period. Each excess emission and MSP report shall include the information required in §60.7(c). Periods of excess emissions and monitoring systems (MS) downtime that shall be reported are defined as follows:

(1) *Opacity*. Excess emissions are defined as any six-minute period during which the average opacity of emissions exceeds 20 percent opacity, except that one six-minute average per hour of up to 27 percent opacity need not be reported.

(i) For sources subject to the opacity standard of §60.42(b)(1), excess emissions are defined as any six-

minute period during which the average opacity of emissions exceeds 35 percent opacity, except that one six-minute average per hour of up to 42 percent opacity need not be reported.

(ii) For sources subject to the opacity standard of §60.42(b)(2), excess emissions are defined as any six-minute period during which the average opacity of emissions exceeds 32 percent opacity, except that one six-minute average per hour of up to 39 percent opacity need not be reported.

(2) *Sulfur dioxide.* Excess emissions for affected facilities are defined as:

(i) For affected facilities electing not to comply with §60.43(d), any three-hour period during which the average emissions (arithmetic average of three contiguous one-hour periods) of SO_2 as measured by a CEMS exceed the applicable standard in §60.43; or

(ii) For affected facilities electing to comply with §60.43(d), any 30 operating day period during which the average emissions (arithmetic average of all one-hour periods during the 30 operating days) of SO_2 as measured by a CEMS exceed the applicable standard in §60.43. Facilities complying with the 30-day SO_2 standard shall use the most current associated SO_2 compliance and monitoring requirements in §§60.48Da and 60.49Da of subpart Da of this part or §§60.45b and 60.47b of subpart Db of this part, as applicable.

(3) *Nitrogen oxides.* Excess emissions for affected facilities using a CEMS for measuring NO_X are defined as:

(i) For affected facilities electing not to comply with §60.44(e), any three-hour period during which the average emissions (arithmetic average of three contiguous one-hour periods) exceed the applicable standards in §60.44; or

(ii) For affected facilities electing to comply with §60.44(e), any 30 operating day period during which the average emissions (arithmetic average of all one-hour periods during the 30 operating days) of NO_X as measured by a CEMS exceed the applicable standard in §60.44. Facilities complying with the 30-day NO_X standard shall use the most current associated NO_X compliance and monitoring requirements in §§60.48Da and 60.49Da of subpart Da of this part.

(4) *Particulate matter.* Excess emissions for affected facilities using a CEMS for measuring PM are defined as any boiler operating day period during which the average emissions (arithmetic average of all operating one-hour periods) exceed the applicable standards in §60.42. Affected facilities using PM CEMS must follow the most current applicable compliance and monitoring provisions in §§60.48Da and 60.49Da of subpart Da of this part.

(h) The owner or operator of an affected facility subject to the opacity limits in §60.42 that elects to monitor emissions according to the requirements in §60.45(b)(7) shall maintain records according to the requirements specified in paragraphs (h)(1) through (3) of this section, as applicable to the visible emissions monitoring method used.

(1) For each performance test conducted using Method 9 of appendix A–4 of this part, the owner or operator shall keep the records including the information specified in paragraphs (h)(1)(i) through (iii) of this section.

(i) Dates and time intervals of all opacity observation periods;

(ii) Name, affiliation, and copy of current visible emission reading certification for each visible emission observer participating in the performance test; and

(iii) Copies of all visible emission observer opacity field data sheets;

(2) For each performance test conducted using Method 22 of appendix A–4 of this part, the owner or operator shall keep the records including the information specified in paragraphs (h)(2)(i) through (iv) of this section.

(i) Dates and time intervals of all visible emissions observation periods;

(ii) Name and affiliation for each visible emission observer participating in the performance test;

(iii) Copies of all visible emission observer opacity field data sheets; and

(iv) Documentation of any adjustments made and the time the adjustments were completed to the affected facility operation by the owner or operator to demonstrate compliance with the applicable monitoring requirements.

(3) For each digital opacity compliance system, the owner or operator shall maintain records and submit reports according to the requirements specified in the site-specific monitoring plan approved by the Administrator.

[60 FR 65415, Dec. 19, 1995, as amended at 74 FR 5077, Jan. 28, 2009; 76 FR 3522, Jan. 20, 2011]

§ 60.46 Test methods and procedures.

(a) In conducting the performance tests required in §60.8, and subsequent performance tests as requested by the EPA Administrator, the owner or operator shall use as reference methods and procedures the test methods in appendix A of this part or other methods and procedures as specified in this section, except as provided in §60.8(b). Acceptable alternative methods and procedures are given in paragraph (d) of this section.

(b) The owner or operator shall determine compliance with the PM, SO_2, and NO_X standards in §§60.42, 60.43, and 60.44 as follows:

(1) The emission rate (E) of PM, SO_2, or NO_X shall be computed for each run using the following equation:

$$E = CF_d\left(\frac{20.9}{(20.9 - \%O_2)}\right)$$

Where:

E = Emission rate of pollutant, ng/J (1b/million Btu);

C = Concentration of pollutant, ng/dscm (1b/dscf);

$\%O_2$= O_2 concentration, percent dry basis; and

F_d= Factor as determined from Method 19 of appendix A of this part.

(2) Method 5 of appendix A of this part shall be used to determine the PM concentration (C) at affected facilities without wet flue-gas-desulfurization (FGD) systems and Method 5B of appendix A of this part shall be used to determine the PM concentration (C) after FGD systems.

(i) The sampling time and sample volume for each run shall be at least 60 minutes and 0.85 dscm (30 dscf). The probe and filter holder heating systems in the sampling train shall be set to provide an average gas temperature of 160±14 °C (320±25 °F).

(ii) The emission rate correction factor, integrated or grab sampling and analysis procedure of Method 3B of appendix A of this part shall be used to determine the O_2 concentration ($\%O_2$). The O_2 sample shall be obtained simultaneously with, and at the same traverse points as, the particulate sample. If the grab sampling procedure is used, the O_2 concentration for the run shall be the arithmetic mean of the sample O_2 concentrations at all traverse points.

(iii) If the particulate run has more than 12 traverse points, the O_2 traverse points may be reduced to 12 provided that Method 1 of appendix A of this part is used to locate the 12 O_2 traverse points.

(3) Method 9 of appendix A of this part and the procedures in §60.11 shall be used to determine opacity.

(4) Method 6 of appendix A of this part shall be used to determine the SO_2 concentration.

(i) The sampling site shall be the same as that selected for the particulate sample. The sampling location in the duct shall be at the centroid of the cross section or at a point no closer to the walls than 1 m (3.28 ft). The sampling time and sample volume for each sample run shall be at least 20 minutes and 0.020 dscm (0.71 dscf). Two samples shall be taken during a 1-hour period, with each sample taken within a 30-minute interval.

(ii) The emission rate correction factor, integrated sampling and analysis procedure of Method 3B of appendix A of this part shall be used to determine the O_2 concentration ($\%O_2$). The O_2 sample shall be taken simultaneously with, and at the same point as, the SO_2 sample. The SO_2 emission rate shall be computed for each pair of SO_2 and O_2 samples. The SO_2 emission rate (E) for each run shall be the arithmetic mean of the results of the two pairs of samples.

(5) Method 7 of appendix A of this part shall be used to determine the NO_X concentration.

(i) The sampling site and location shall be the same as for the SO_2 sample. Each run shall consist of four grab samples, with each sample taken at about 15-minute intervals.

(ii) For each NO_X sample, the emission rate correction factor, grab sampling and analysis procedure of Method 3B of appendix A of this part shall be used to determine the O_2 concentration ($\%O_2$). The sample shall be taken simultaneously with, and at the same point as, the NO_X sample.

(iii) The NO_X emission rate shall be computed for each pair of NO_X and O_2 samples. The NO_X emission rate (E) for each run shall be the arithmetic mean of the results of the four pairs of samples.

(c) When combinations of fossil fuels or fossil fuel and wood residue are fired, the owner or operator (in order to compute the prorated standard as shown in §§60.43(b) and 60.44(b)) shall determine the percentage (w, x, y, or z) of the total heat input derived from each type of fuel as follows:

(1) The heat input rate of each fuel shall be determined by multiplying the gross calorific value of each fuel fired by the rate of each fuel burned.

(2) ASTM Methods D2015, or D5865 (solid fuels), D240 (liquid fuels), or D1826 (gaseous fuels) (all of these methods are incorporated by reference, see §60.17) shall be used to determine the gross calorific values of the fuels. The method used to determine the calorific value of wood residue must be approved by the Administrator.

(3) Suitable methods shall be used to determine the rate of each fuel burned during each test period, and a material balance over the steam generating system shall be used to confirm the rate.

(d) The owner or operator may use the following as alternatives to the reference methods and procedures in this section or in other sections as specifed:

(1) The emission rate (E) of PM, SO_2 and NO_X may be determined by using the Fc factor, provided that the following procedure is used:

(i) The emission rate (E) shall be computed using the following equation:

$$E = CF_c \left(\frac{100}{\%CO_2} \right)$$

Where:

E = Emission rate of pollutant, ng/J (lb/MMBtu);

C = Concentration of pollutant, ng/dscm (lb/dscf);

$\%CO_2$= CO_2concentration, percent dry basis; and

F_c= Factor as determined in appropriate sections of Method 19 of appendix A of this part.

(ii) If and only if the average Fc factor in Method 19 of appendix A of this part is used to calculate E and either E is from 0.97 to 1.00 of the emission standard or the relative accuracy of a continuous emission monitoring system is from 17 to 20 percent, then three runs of Method 3B of appendix A of this part shall be used to determine the $O_2$and CO_2concentration according to the procedures in paragraph(b)(2)(ii), (4)(ii), or (5)(ii) of this section. Then if F_o(average of three runs), as calculated fom the equation in Method 3B of appendix A of this part, is more than ±3 percent than the average $F_o$value, as determined from the average values of $F_d$and $F_c$in Method 19 of appendix A of this part, *i.e.* , F_{oa}= 0.209 (F_{da}/F_{ca}), then the following procedure shall be followed:

(A) When $F_o$is less than 0.97 F_{oa}, then E shall be increased bythat proportion under 0.97 F_{oa}, *e.g.* , if $F_o$is 0.95 F_{oa}, E shall be increased by 2 percent. This recalculated value shall be used to determine compliance with the emission standard.

(B) When $F_o$is less than 0.97 $F_{oa}$and when the average difference (d) between the continuous monitor minus the reference methods is negative, then E shall be increased bythat proportion under 0.97 F_{oa}, *e.g.* , if $F_o$is 0.95 F_{oa}, E shall be increased by 2 percent. This recalculated value shall be used to determine compliance with the relative accuracy specification.

(C) When $F_o$is greater than 1.03 $F_{oa}$and when the average difference d is positive, then E shall be decreased by that proportion over 1.03 F_{oa}, *e.g.* , if $F_o$is 1.05 F_{oa}, E shall be decreased by2 percent. This recalculated value shall be used to determine compliance with the relative accuracy specification.

(2) For Method 5 or 5B of appendix A–3 of this part, Method 17 of appendix A–6 of this part may be used at facilities with or without wet FGD systems if the stack gas temperature at the sampling location does not exceed an average temperature of 160 °C (320 °F). The procedures of sections 8.1 and 11.1 of Method 5B of appendix A–3 of this part may be used with Method 17 of appendix A–6 of this part only if it is used after wet FGD systems. Method 17 of appendix A–6 of this part shall not be used after wet FGD systems if the effluent gas is saturated or laden with water droplets.

(3) Particulate matter and SO_2may be determined simultaneously with the Method 5 of appendix A of this part train provided that the following changes are made:

(i) The filter and impinger apparatus in sections 2.1.5 and 2.1.6 ofMethod 8 of appendix A of this part is used in place of the condenser (section 2.1.7) ofMethod 5 of appendix A of this part.

(ii) All applicable procedures in Method 8 of appendix A of this part for the determination of SO_2 (including moisture) are used:

(4) For Method 6 of appendix A of this part, Method 6C of appendix A of this part may be used. Method 6A of appendix A of this part may also be used whenever Methods 6 and 3B of appendix A of this part data are specified to determine the SO_2emission rate, under the conditions in paragraph (d)(1) ofthis section.

(5) For Method 7 of appendix A of this part, Method 7A, 7C, 7D, or 7E of appendix A of this part may be used. If Method 7C, 7D, or 7E of appendix A of this part is used, the sampling time for each run shall be at least 1 hour and the integrated sampling approach shall be used todetermine the O_2concentration (% O_2) for the emission rate correction factor.

(6) For Method 3 of appendix A of this part, Method 3A or 3B of appendix A of this part may be used.

(7) For Method 3B of appendix A of this part, Method 3A of appendix A of this part may be used.

[60 FR 65415, Dec. 19, 1995, as amended at 74 FR 5078, Jan. 28, 2009]

Browse Previous | Browse Next

For questions or comments regarding e-CFR editorial content, features, or design, email ecfr@nara.gov.

For questions concerning e-CFR programming and delivery issues, email webteam@gpo.gov.

Section 508 / Accessibility

Electronic Code of Federal Regulations
e-CFR™

e-CFR Data is current as of May 12, 2011

Title 40: Protection of Environment

PART 60—STANDARDS OF PERFORMANCE FOR NEW STATIONARY SOURCES

Browse Previous | Browse Next

Subpart BB—Standards of Performance for Kraft Pulp Mills

§ 60.280 Applicability and designation of affected facility.

(a) The provisions of this subpart are applicable to the following affected facilities in kraft pulp mills: Digester system, brown stock washer system, multiple-effect evaporator system, recovery furnace, smelt dissolving tank, lime kiln, and condensate stripper system. In pulp mills where kraft pulping is combined with neutral sulfite semichemical pulping, the provisions of this subpart are applicable when any portion of the material charged to an affected facility is produced by the kraft pulping operation.

(b) Except as noted in §60.283(a)(1)(iv), any facility under paragraph (a) of this section that commences construction or modification after September 24, 1976, is subject to the requirements of this subpart.

[51 FR 18544, May 20, 1986]

§ 60.281 Definitions.

As used in this subpart, all terms not defined herein shall have the same meaning given them in the Act and in subpart A.

(a) *Kraft pulp mill* means any stationary source which produces pulp from wood by cooking (digesting) wood chips in a water solution of sodium hydroxide and sodium sulfide (white liquor) at high temperature and pressure. Regeneraton of the cooking chemicals through a recovery process is also considered part of the kraft pulp mill.

(b) *Neutral sulfite semichemical pulping operation* means any operation in which pulp is produced from wood by cooking (digesting) wood chips in a solution of sodium sulfite and sodium bicarbonate, followed by mechanical defibrating (grinding).

(c) *Total reduced sulfur (TRS)* means the sum of the sulfur compounds hydrogen sulfide, methyl mercaptan, dimethyl sulfide, and dimethyl disulfide, that are released during the kraf pulping operation and measured by Method 16.

(d) *Digester system* means each continuous digester or each batch digester used for the cooking of wood in white liquor, and associated flash tank(s), blow tank(s), chip steamer(s), and condenser(s).

(e) *Brown stock washer system* means brown stock washers and associated knotters, vacuum pumps, and filtrate tanks used to wash the pulp following the digester system. Diffusion washers are excluded from this definition.

(f) *Multiple-effect evaporator system* means the multiple-effect evaporators and associated condenser(s) and hotwell(s) used to concentrate the spent cooking liquid that is separated from the pulp (black liquor).

(g) *Black liquor oxidation system* means the vessels used to oxidize, with air or oxygen, the black liquor, and associated storage tank(s).

(h) *Recovery furnace* means either a straight kraft recovery furnace or a cross recovery furnace, and includes the direct-contact evaporator for a direct-contact furnace.

(i) *Straight kraft recovery furnace* means a furnace used to recover chemicals consisting primarily of sodium and sulfur compounds by burning black liquor which on a quarterly basis contains 7 weight percent or less of the total pulp solids from the neutral sulfite semichemical process or has green liquor sulfidity of 28 percent or less.

(j) *Cross recovery furnace* means a furnace used to recover chemicals consisting primarily of sodium and sulfur compounds by burning black liquor which on a quarterly basis contains more than 7 weight percent of the total pulp solids from the neutral sulfite semichemical process and has a green liquor sulfidity of more than 28 percent.

(k) *Black liquor solids* means the dry weight of the solids which enter the recovery furnace in the black liquor.

(l) *Green liquor sulfidity* means the sulfidity of the liquor which leaves the smelt dissolving tank.

(m) *Smelt dissolving tank* means a vessel used for dissolving the smelt collected from the recovery furnace.

(n) *Lime kiln* means a unit used to calcine lime mud, which consists primarily of calcium carbonate, into quicklime, which is calcium oxide.

(o) *Condensate stripper system* means a column, and associated condensers, used to strip, with air or steam, TRS compounds from condensate streams from various processes within a kraft pulp mill.

[43 FR 7572, Feb. 23, 1978, as amended at 51 FR 18544, May 20, 1986; 65 FR 61758, Oct. 17, 2000]

§ 60.282 Standard for particulate matter.

(a) On and after the date on which the performance test required to be conducted by §60.8 is completed, no owner or operator subject to the provisions of this subpart shall cause to be discharged into the atmosphere:

(1) From any recovery furnace any gases which:

(i) Contain particulate matter in excess of 0.10 g/dscm (0.044 gr/dscf) corrected to 8 percent oxygen.

(ii) Exhibit 35 percent opacity or greater.

(2) From any smelt dissolving tank any gases which contain particulate matter in excess of 0.1 g/kg black liquor solids (dry weight)[0.2 lb/ton black liquor solids (dry weight)].

(3) From any lime kiln any gases which contain particulate matter in excess of:

(i) 0.15 g/dscm (0.066 gr/dscf) corrected to 10 percent oxygen, when gaseous fossil fuel is burned.

(ii) 0.30 g/dscm (0.13 gr/dscf) corrected to 10 percent oxygen, when liquid fossil fuel is burned.

[43 FR 7572, Feb. 23, 1978, as amended at 65 FR 61758, Oct. 17, 2000]

§ 60.283 Standard for total reduced sulfur (TRS).

(a) On and after the date on which the performance test required to be conducted by §60.8 is completed, no owner or operator subject to the provisions of this subpart shall cause to be discharged into the atmosphere:

(1) From any digester system, brown stock washer system, multiple-effect evaporator system, or condensate stripper system any gases which contain TRS in excess of 5 ppm by volume on a dry basis, corrected to 10 percent oxygen, unless the following conditions are met:

(i) The gases are combusted in a lime kiln subject to the provisions of paragraph (a)(5) of this section; or

(ii) The gases are combusted in a recovery furnace subject to the provisions of paragraphs (a)(2) or (a)(3) of this section; or

(iii) The gases are combusted with other waste gases in an incinerator or other device, or combusted in a lime kiln or recovery furnace not subject to the provisions of this subpart, and are subjected to a minimum temperature of 650 °C (1200 °F) for at least 0.5 second; or

(iv) It has been demonstrated to the Administrator's satisfaction by the owner or operator that incinerating the exhaust gases from a new, modified, or reconstructed brown stock washer system is technologically or economically unfeasible. Any exempt system will become subject to the provisions of this subpart if the facility is changed so that the gases can be incinerated.

(v) The gases from the digester system, brown stock washer system, or condensate stripper system are controlled by a means other than combustion. In this case, this system shall not discharge any gases to the atmosphere which contain TRS in excess of 5 ppm by volume on a dry basis, uncorrected for oxygen content.

(vi) The uncontrolled exhaust gases from a new, modified, or reconstructed digester system contain TRS less than 0.005 g/kg air dried pulp (ADP) (0.01 lb/ton ADP).

(2) From any straight kraft recovery furnace any gases which contain TRS in excess of 5 ppm by volume on a dry basis, corrected to 8 percent oxygen.

(3) From any cross recovery furnace any gases which contain TRS in excess of 25 ppm by volume on a dry basis, corrected to 8 percent oxygen.

(4) From any smelt dissolving tank any gases which contain TRS in excess of 0.016 g/kg black liquor solids as H_2S (0.033 lb/ton black liquor solids as H_2S).

(5) From any lime kiln any gases which contain TRS in excess of 8 ppm by volume on a dry basis, corrected to 10 percent oxygen.

[43 FR 7572, Feb. 23, 1978, as amended at 50 FR 6317, Feb. 14, 1985; 51 FR 18544, May 20, 1986; 65 FR 61758, Oct. 17, 2000]

§ 60.284 Monitoring of emissions and operations.

(a) Any owner or operator subject to the provisions of this subpart shall install, calibrate, maintain, and operate the following continuous monitoring systems:

(1) A continuous monitoring system to monitor and record the opacity of the gases discharged into the atmosphere from any recovery furnace. The span of this system shall be set at 70 percent opacity.

(2) Continuous monitoring systems to monitor and record the concentration of TRS emissions on a dry basis and the percent of oxygen by volume on a dry basis in the gases discharged into the atmosphere from any lime kiln, recovery furnace, digester system, brown stock washer system, multiple-effect evaporator system, or condensate stripper system, except where the provisions of §60.283(a)(1) (iii) or (iv) apply. These systems shall be located downstream of the control device(s) and the spans of these continuous monitoring system(s) shall be set:

(i) At a TRS concentration of 30 ppm for the TRS continuous monitoring system, except that for any cross recovery furnace the span shall be set at 50 ppm.

(ii) At 25 percent oxygen for the continuous oxygen monitoring system.

(b) Any owner or operator subject to the provisions of this subpart shall install, calibrate, maintain, and

operate the following continuous monitoring devices:

(1) For any incinerator, a monitoring device which measures and records the combustion temperature at the point of incineration of effluent gases which are emitted from any digester system, brown stock washer system, multiple-effect evaporator system, black liquor oxidation system, or condensate stripper system where the provisions of §60.283(a)(1)(iii) apply. The monitoring device is to be certified by the manufacturer to be accurate within ±1 percent of the temperature being measured.

(2) For any lime kiln or smelt dissolving tank using a scrubber emission control device:

(i) A monitoring device for the continuous measurement of the pressure loss of the gas stream through the control equipment. The monitoring device is to be certified by the manufacturer to be accurate to within a gage pressure of ±500 pascals (ca. ±2 inches water gage pressure).

(ii) A monitoring device for the continuous measurement of the scrubbing liquid supply pressure to the control equipment. The monitoring device is to be certified by the manufacturer to be accurate within ±15 percent of design scrubbing liquid supply pressure. The pressure sensor or tap is to be located close to the scrubber liquid discharge point. The Administrator may be consulted for approval of alternative locations.

(c) Any owner or operator subject to the provisions of this subpart shall, except where the provisions of §60.283(a)(1)(iii) or (iv) apply, perform the following:

(1) Calculate and record on a daily basis 12-hour average TRS concentrations for the two consecutive periods of each operating day. Each 12-hour average shall be determined as the arithmetic mean of the appropriate 12 contiguous 1-hour average total reduced sulfur concentrations provided by each continuous monitoring system installed under paragraph (a)(2) of this section.

(2) Calculate and record on a daily basis 12-hour average oxygen concentrations for the two consecutive periods of each operating day for the recovery furnace and lime kiln. These 12-hour averages shall correspond to the 12-hour average TRS concentrations under paragraph (c)(1) of this section and shall be determined as an arithmetic mean of the appropriate 12 contiguous 1-hour average oxygen concentrations provided by each continuous monitoring system installed under paragraph (a)(2) of this section.

(3) Using the following equation, correct all 12-hour average TRS concentrations to 10 volume percent oxygen, except that all 12-hour average TRS concentrations from a recovery furnace shall be corrected to 8 volume percent oxygen instead of 10 percent, and all 12-hour average TRS concentrations from a facility to which the provisions of §60.283(a)(1)(v) apply shall not be corrected for oxygen content:

$$C_{corr} = C_{meas} \times (21 - X / 21 - Y)$$

where:

C_{corr} = the concentration corrected for oxygen.

C_{meas} = the concentration uncorrected for oxygen.

X = the volumetric oxygen concentration in percentage to be corrected to (8 percent for recovery furnaces and 10 percent for lime kilns, incinerators, or other devices).

Y = the measured 12-hour average volumetric oxygen concentration.

(4) Record once per shift measurements obtained from the continuous monitoring devices installed under paragraph (b)(2) of this section.

(d) For the purpose of reports required under §60.7(c), any owner or operator subject to the provisions of this subpart shall report semiannually periods of excess emissions as follows:

(1) For emissions from any recovery furnace periods of excess emissions are:

(i) All 12-hour averages of TRS concentrations above 5 ppm by volume for straight kraft recovery furnaces and above 25 ppm by volume for cross recovery furnaces.

(ii) All 6-minute average opacities that exceed 35 percent.

(2) For emissions from any lime kiln, periods of excess emissions are all 12-hour average TRS concentration above 8 ppm by volume.

(3) For emissions from any digester system, brown stock washer system, multiple-effect evaporator system, or condensate stripper system periods of excess emissions are:

(i) All 12-hour average TRS concentrations above 5 ppm by volume unless the provisions of §60.283(a)(1)(i), (ii), or (iv) apply; or

(ii) All periods in excess of 5 minutes and their duration during which the combustion temperature at the point of incineration is less than 650 °C (1200 °F), where the provisions of §60.283(a)(1)(iii) apply.

(e) The Administrator will not consider periods of excess emissions reported under paragraph (d) of this section to be indicative of a violation of §60.11(d) provided that:

(1) The percent of the total number of possible contiguous periods of excess emissions in a quarter (excluding periods of startup, shutdown, or malfunction and periods when the facility is not operating) during which excess emissions occur does not exceed:

(i) One percent for TRS emissions from recovery furnaces.

(ii) Six percent for average opacities from recovery furnaces.

(2) The Administrator determines that the affected facility, including air pollution control equipment, is maintained and operated in a manner which is consistent with good air pollution control practice for minimizing emissions during periods of excess emissions.

(f) The procedures under §60.13 shall be followed for installation, evaluation, and operation of the continuous monitoring systems required under this section. All continuous monitoring systems shall be operated in accordance with the applicable procedures under Performance Specifications 1, 3, and 5 of appendix B of this part.

[43 FR 7572, Feb. 23, 1978, as amended at 51 FR 18545, May 20, 1986; 65 FR 61759, Oct. 17, 2000; 71 FR 55127, Sept. 21, 2006]

§ 60.285 Test methods and procedures.

(a) In conducting the performance tests required in §60.8, the owner or operator shall use as reference methods and procedures the test methods in appendix A of this part or other methods and procedures in this section, except as provided in §60.8(b). Acceptable alternative methods and procedures are given in paragraph (f) of this section.

(b) The owner or operator shall determine compliance with the particulate matter standards in §60.282(a)(1) and (3) as follows:

(1) Method 5 shall be used to determine the particulate matter concentration. The sampling time and sample volume for each run shall be at least 60 minutes and 0.90 dscm (31.8 dscf). Water shall be used as the cleanup solvent instead of acetone in the sample recovery procedure. The particulate concentration shall be corrected to the appropriate oxygen concentration according to §60.284(c)(3).

(2) The emission rate correction factor, integrated sampling and analysis procedure of Method 3B shall be used to determine the oxygen concentration. The gas sample shall be taken at the same time and at the same traverse points as the particulate sample.

(3) Method 9 and the procedures in §60.11 shall be used to determine opacity.

(c) The owner or operator shall determine compliance with the particular matter standard in §60.282(a)

(2) as follows:

(1) The emission rate (E) of particulate matter shall be computed for each run using the following equation:

$E=c_s Q_{sd}/BLS$

where:

E=emission rate of particulate matter, g/kg (lb/ton) of BLS.

c_s= Concentration of particulate matter, g/dscm (lb/dscf).

Q_{sd}=volumetric flow rate of effluent gas, dscm/hr (dscf/hr).

BLS=black liquor solids (dry weight) feed rate, kg/hr (ton/hr).

(2) Method 5 shall be used to determine the particulate matter concentration (c_s) and the volumetric flow rate (Q_{sd}) of the effluent gas. The sampling time and sample volume shall be at least 60 minutes and 0.90 dscm (31.8 dscf). Water shall be used instead of acetone in the sample recovery.

(3) Process data shall be used to determine the black liquor solids (BLS) feed rate on a dry weight basis.

(d) The owner or operator shall determine compliance with the TRS standards in §60.283, except §60.283(a)(1)(vi) and (4), as follows:

(1) Method 16 shall be used to determine the TRS concentration. The TRS concentration shall be corrected to the appropriate oxygen concentration using the procedure in §60.284(c)(3). The sampling time shall be at least 3 hours, but no longer than 6 hours.

(2) The emission rate correction factor, integrated sampling and analysis procedure of Method 3B shall be used to determine the oxygen concentration. The sample shall be taken over the same time period as the TRS samples.

(3) When determining whether a furnace is a straight kraft recovery furnace or a cross recovery furnace, TAPPI Method T.624 (incorporated by reference—see §60.17) shall be used to determine sodium sulfide, sodium hydroxide, and sodium carbonate. These determinations shall be made 3 times daily from the green liquor, and the daily average values shall be converted to sodium oxide (Na_2O) and substituted into the following equation to determine the green liquor sulfidity:

$$GLS = 100\ C_{Na_2S}/\left(C_{Na_2S}C_{NaOH}C_{Na_2CO_3}\right)$$

Where:

GLS=green liquor sulfidity, percent.

C_{Na2S}=concentration of Na_2S as Na_2O, mg/liter (gr/gal).

C_{NaOH}=concentration of NaOH as Na_2O, mg/liter (gr/gal).

C_{Na2CO3}=concentration of Na_2CO_3 as Na_2O, mg/liter (gr/gal).

(e) The owner or operator shall determine compliance with the TRS standards in §60.283(a)(1)(v) and (4) as follows:

(1) The emission rate (E) of TRS shall be computed for each run using the following equation:

$E=C_{TRS}F\ Q_{sd}/P$

where:

E=emission rate of TRS, g/kg (lb/ton) of BLS or ADP.

C_{TRS}=average combined concentration of TRS, ppm.

F = conversion factor, 0.001417 g H_2S/m^3 -ppm (8.846×10^{-8}lb H_2S/ft^3 -ppm).

Q_{sd}=volumetric flow rate of stack gas, dscm/hr (dscf/hr).

P=black liquor solids feed or pulp production rate, kg/hr (ton/hr).

(2) Method 16 shall be used to determine the TRS concentration (C_{TRS}).

(3) Method 2 shall be usedto determine the volumetric flow rate (Q_{sd}) of the effluent gas.

(4) Process data shall be usedto determine the black liquor feed rate or the pulp production rate (P).

(f) The owner or operator may use the following as alternatives to the reference methods and procedures specified in this section:

(1) For Method 5, Method 17 may be used if a constant value of 0.009 g/dscm (0.004 gr/dscf) is added to the results of Method 17 and the stack temperature is no greater than 204 °C (400 °F).

(2) In place of Method 16, Method 16A or 16B may be used.

[54 FR 6673, Feb. 14, 1989; 54 FR 21344, May 17, 1989, as amended at 55 FR 5212, Feb. 14, 1990; 65 FR 61759, Oct. 17, 2000]

Browse Previous | Browse Next

For questions or comments regarding e-CFR editorial content, features, or design, email ecfr@nara.gov.

For questions concerning e-CFR programming and delivery issues, email webteam@gpo.gov.

Section 508 / Accessibility

Electronic Code of Federal Regulations
e-CFR™

e-CFR Data is current as of May 12, 2011

Title 40: Protection of Environment
PART 60—STANDARDS OF PERFORMANCE FOR NEW STATIONARY SOURCES

Browse Previous | Browse Next

Subpart Kb—Standards of Performance for Volatile Organic Liquid Storage Vessels (Including Petroleum Liquid Storage Vessels) for Which Construction, Reconstruction, or Modification Commenced After July 23, 1984

Source: 52 FR 11429, Apr. 8, 1987, unless otherwise noted.

§ 60.110b Applicability and designation of affected facility.

(a) Except as provided in paragraph (b) of this section, the affected facility to which this subpart applies is each storage vessel with a capacity greater than or equal to 75 cubic meters (m^3) that is used to store volatile organic liquids (VOL) for which construction, reconstruction, or modification is commenced after July 23, 1984.

(b) This subpart does not apply to storage vessels with a capacity greater than or equal to 151 m^3 storing a liquid with a maximum true vapor pressure less than 3.5 kilopascals (kPa) or with a capacity greater than or equal to 75 m^3 but less than 151 m^3 storing a liquid with a maximum true vapor pressure less than 15.0 kPa.

(c) [Reserved]

(d) This subpart does not apply to the following:

(1) Vessels at coke oven by-product plants.

(2) Pressure vessels designed to operate in excess of 204.9 kPa and without emissions to the atmosphere.

(3) Vessels permanently attached to mobile vehicles such as trucks, railcars, barges, or ships.

(4) Vessels with a design capacity less than or equal to 1,589.874 m^3 used for petroleum or condensate stored, processed, or treated prior to custody transfer.

(5) Vessels located at bulk gasoline plants.

(6) Storage vessels located at gasoline service stations.

(7) Vessels used to store beverage alcohol.

(8) Vessels subject to subpart GGGG of 40 CFR part 63.

(e) *Alternative means of compliance*—(1) *Option to comply with part 65.* Owners or operators may

choose to comply with 40 CFR part 65, subpart C, to satisfy the requirements of §§60.112b through 60.117b for storage vessels that are subject to this subpart that meet the specifications in paragraphs (e)(1)(i) and (ii) of this section. When choosing to comply with 40 CFR part 65, subpart C, the monitoring requirements of §60.116b(c), (e), (f)(1), and (g) still apply. Other provisions applying to owners or operators who choose to comply with 40 CFR part 65 are provided in 40 CFR 65.1.

(i) A storage vessel with a design capacity greater than or equal to 151 m^3 containing a VOL that, as stored, has a maximum true vapor pressure equal to or greater than 5.2 kPa; or

(ii) A storage vessel with a design capacity greater than 75 m^3 but less than 151 m^3 containing a VOL that, as stored, has a maximum true vapor pressure equal to or greater than 27.6 kPa.

(2) *Part 60, subpart A.* Owners or operators who choose to comply with 40 CFR part 65, subpart C, must also comply with §§60.1, 60.2, 60.5, 60.6, 60.7(a)(1) and (4), 60.14, 60.15, and 60.16 for those storage vessels. All sections and paragraphs of subpart A of this part that are not mentioned in this paragraph (e)(2) do not apply to owners or operators of storage vessels complying with 40 CFR part 65, subpart C, except that provisions required to be met prior to implementing 40 CFR part 65 still apply. Owners and operators who choose to comply with 40 CFR part 65, subpart C, must comply with 40 CFR part 65, subpart A.

(3) *Internal floating roof report.* If an owner or operator installs an internal floating roof and, at initial startup, chooses to comply with 40 CFR part 65, subpart C, a report shall be furnished to the Administrator stating that the control equipment meets the specifications of 40 CFR 65.43. This report shall be an attachment to the notification required by 40 CFR 65.5(b).

(4) *External floating roof report.* If an owner or operator installs an external floating roof and, at initial startup, chooses to comply with 40 CFR part 65, subpart C, a report shall be furnished to the Administrator stating that the control equipment meets the specifications of 40 CFR 65.44. This report shall be an attachment to the notification required by 40 CFR 65.5(b).

[52 FR 11429, Apr. 8, 1987, as amended at 54 FR 32973, Aug. 11, 1989; 65 FR 78275, Dec. 14, 2000; 68 FR 59332, Oct. 15, 2003]

§ 60.111b Definitions.

Terms used in this subpart are defined in the Act, in subpart A of this part, or in this subpart as follows:

Bulk gasoline plant means any gasoline distribution facility that has a gasoline throughput less than or equal to 75,700 liters per day. Gasoline throughput shall be the maximum calculated design throughput as may be limited by compliance with an enforceable condition under Federal requirement or Federal, State or local law, and discoverable by the Administrator and any other person.

Condensate means hydrocarbon liquid separated from natural gas that condenses due to changes in the temperature or pressure, or both, and remains liquid at standard conditions.

Custody transfer means the transfer of produced petroleum and/or condensate, after processing and/or treatment in the producing operations, from storage vessels or automatic transfer facilities to pipelines or any other forms of transportation.

Fill means the introduction of VOL into a storage vessel but not necessarily to complete capacity.

Gasoline service station means any site where gasoline is dispensed to motor vehicle fuel tanks from stationary storage tanks.

Maximum true vapor pressure means the equilibrium partial pressure exerted by the volatile organic compounds (as defined in 40 CFR 51.100) in the stored VOL at the temperature equal to the highest calendar-month average of the VOL storage temperature for VOL's stored above or below the ambient temperature or at the local maximum monthly average temperature as reported by the National Weather Service for VOL's stored at the ambient temperature, as determined:

(1) In accordance with methods described in American Petroleum institute Bulletin 2517, Evaporation Loss From External Floating Roof Tanks, (incorporated by reference—see §60.17); or

(2) As obtained from standard reference texts; or

(3) As determined by ASTM D2879–83, 96, or 97 (incorporated by reference—see §60.17);

(4) Any other method approved by the Administrator.

Petroleum means the crude oil removed from the earth and the oils derived from tar sands, shale, and coal.

Petroleum liquids means petroleum, condensate, and any finished or intermediate products manufactured in a petroleum refinery.

Process tank means a tank that is used within a process (including a solvent or raw material recovery process) to collect material discharged from a feedstock storage vessel or equipment within the process before the material is transferred to other equipment within the process, to a product or by-product storage vessel, or to a vessel used to store recovered solvent or raw material. In many process tanks, unit operations such as reactions and blending are conducted. Other process tanks, such as surge control vessels and bottoms receivers, however, may not involve unit operations.

Reid vapor pressure means the absolute vapor pressure of volatile crude oil and volatile nonviscous petroleum liquids except liquified petroleum gases, as determined by ASTM D323–82 or 94 (incorporated by reference—see §60.17).

Storage vessel means each tank, reservoir, or container used for the storage of volatile organic liquids but does not include:

(1) Frames, housing, auxiliary supports, or other components that are not directly involved in the containment of liquids or vapors;

(2) Subsurface caverns or porous rock reservoirs; or

(3) Process tanks.

Volatile organic liquid (VOL) means any organic liquid which can emit volatile organic compounds (as defined in 40 CFR 51.100) into the atmosphere.

Waste means any liquid resulting from industrial, commercial, mining or agricultural operations, or from community activities that is discarded or is being accumulated, stored, or physically, chemically, or biologically treated prior to being discarded or recycled.

[52 FR 11429, Apr. 8, 1987, as amended at 54 FR 32973, Aug. 11, 1989; 65 FR 61756, Oct. 17, 2000; 68 FR 59333, Oct. 15, 2003]

§ 60.112b Standard for volatile organic compounds (VOC).

(a) The owner or operator of each storage vessel either with a design capacity greater than or equal to 151 m^3 containing a VOL that, as stored, has a maximum true vapor pressure equal to or greater than 5.2 kPa but less than 76.6 kPa or with a design capacity greater than or equal to 75 m^3 but less than 151 m^3 containing a VOL that, as stored, has a maximum true vapor pressure equal to or greater than 27.6 kPa but less than 76.6 kPa, shall equip each storage vessel with one of the following:

(1) A fixed roof in combination with an internal floating roof meeting the following specifications:

(i) The internal floating roof shall rest or float on the liquid surface (but not necessarily in complete contact with it) inside a storage vessel that has a fixed roof. The internal floating roof shall be floating on the liquid surface at all times, except during initial fill and during those intervals when the storage vessel is completely emptied or subsequently emptied and refilled. When the roof is resting on the leg supports, the process of filling, emptying, or refilling shall be continuous and shall be accomplished as rapidly as possible.

(ii) Each internal floating roof shall be equipped with one of the following closure devices between the

wall of the storage vessel and the edge of the internal floating roof.

(A) A foam- or liquid-filled seal mounted in contact with the liquid (liquid-mounted seal). A liquid-mounted seal means a foam- or liquid-filled seal mounted in contact with the liquid between the wall of the storage vessel and the floating roof continuously around the circumference of the tank.

(B) Two seals mounted one above the other so that each forms a continuous closure that completely covers the space between the wall of the storage vessel and the edge of the internal floating roof. The lower seal may be vapor-mounted, but both must be continuous.

(C) A mechanical shoe seal. A mechanical shoe seal is a metal sheet held vertically against the wall of the storage vessel by springs or weighted levers and is connected by braces to the floating roof. A flexible coated fabric (envelope) spans the annular space between the metal sheet and the floating roof.

(iii) Each opening in a noncontact internal floating roof except for automatic bleeder vents (vacuum breaker vents) and the rim space vents is to provide a projection below the liquid surface.

(iv) Each opening in the internal floating roof except for leg sleeves, automatic bleeder vents, rim space vents, column wells, ladder wells, sample wells, and stub drains is to be equipped with a cover or lid which is to be maintained in a closed position at all times (i.e., no visible gap) except when the device is in actual use. The cover or lid shall be equipped with a gasket. Covers on each access hatch and automatic gauge float well shall be bolted except when they are in use.

(v) Automatic bleeder vents shall be equipped with a gasket and are to be closed at all times when the roof is floating except when the roof is being floated off or is being landed on the roof leg supports.

(vi) Rim space vents shall be equipped with a gasket and are to be set to open only when the internal floating roof is not floating or at the manufacturer's recommended setting.

(vii) Each penetration of the internal floating roof for the purpose of sampling shall be a sample well. The sample well shall have a slit fabric cover that covers at least 90 percent of the opening.

(viii) Each penetration of the internal floating roof that allows for passage of a column supporting the fixed roof shall have a flexible fabric sleeve seal or a gasketed sliding cover.

(ix) Each penetration of the internal floating roof that allows for passage of a ladder shall have a gasketed sliding cover.

(2) An external floating roof. An external floating roof means a pontoon-type or double-deck type cover that rests on the liquid surface in a vessel with no fixed roof. Each external floating roof must meet the following specifications:

(i) Each external floating roof shall be equipped with a closure device between the wall of the storage vessel and the roof edge. The closure device is to consist of two seals, one above the other. The lower seal is referred to as the primary seal, and the upper seal is referred to as the secondary seal.

(A) The primary seal shall be either a mechanical shoe seal or a liquid-mounted seal. Except as provided in §60.113b(b)(4), the seal shall completely cover the annular space between the edge of the floating roof and tank wall.

(B) The secondary seal shall completely cover the annular space between the external floating roof and the wall of the storage vessel in a continuous fashion except as allowed in §60.113b(b)(4).

(ii) Except for automatic bleeder vents and rim space vents, each opening in a noncontact external floating roof shall provide a projection below the liquid surface. Except for automatic bleeder vents, rim space vents, roof drains, and leg sleeves, each opening in the roof is to be equipped with a gasketed cover, seal, or lid that is to be maintained in a closed position at all times (i.e., no visible gap) except when the device is in actual use. Automatic bleeder vents are to be closed at all times when the roof is floating except when the roof is being floated off or is being landed on the roof leg supports. Rim vents are to be set to open when the roof is being floated off the roof legs supports or at the manufacturer's recommended setting. Automatic bleeder vents and rim space vents are to be gasketed Each emergency roof drain is to be provided with a slotted membrane fabric cover that covers at least 90 percent of the area of the opening.

(iii) The roof shall be floating on the liquid at all times (i.e., off the roof leg supports) except during initial fill until the roof is lifted off leg supports and when the tank is completely emptied and subsequently refilled. The process of filling, emptying, or refilling when the roof is resting on the leg supports shall be continuous and shall be accomplished as rapidly as possible.

(3) A closed vent system and control device meeting the following specifications:

(i) The closed vent system shall be designed to collect all VOC vapors and gases discharged from the storage vessel and operated with no detectable emissions as indicated by an instrument reading of less than 500 ppm above background and visual inspections, as determined in part 60, subpart VV, §60.485 (b).

(ii) The control device shall be designed and operated to reduce inlet VOC emissions by 95 percent or greater. If a flare is used as the control device, it shall meet the specifications described in the general control device requirements (§60.18) of the General Provisions.

(4) A system equivalent to those described in paragraphs (a)(1), (a)(2), or (a)(3) of this section as provided in §60.114b of this subpart.

(b) The owner or operator of each storage vessel with a design capacity greater than or equal to 75 m^3 which contains a VOL that, as stored, has a maximum true vapor pressure greater than or equal to 76.6 kPa shall equip each storage vessel with one of the following:

(1) A closed vent system and control device as specified in §60.112b(a)(3).

(2) A system equivalent to that described in paragraph (b)(1) as provided in §60.114b of this subpart.

(c) *Site-specific standard for Merck & Co., Inc.'s Stonewall Plant in Elkton, Virginia.* This paragraph applies only to the pharmaceutical manufacturing facility, commonly referred to as the Stonewall Plant, located at Route 340 South, in Elkton, Virginia ("site").

(1) For any storage vessel that otherwise would be subject to the control technology requirements of paragraphs (a) or (b) of this section, the site shall have the option of either complying directly with the requirements of this subpart, or reducing the site-wide total criteria pollutant emissions cap (total emissions cap) in accordance with the procedures set forth in a permit issued pursuant to 40 CFR 52.2454. If the site chooses the option of reducing the total emissions cap in accordance with the procedures set forth in such permit, the requirements of such permit shall apply in lieu of the otherwise applicable requirements of this subpart for such storage vessel.

(2) For any storage vessel at the site not subject to the requirements of 40 CFR 60.112b (a) or (b), the requirements of 40 CFR 60.116b (b) and (c) and the General Provisions (subpart A of this part) shall not apply.

[52 FR 11429, Apr. 8, 1987, as amended at 62 FR 52641, Oct. 8, 1997]

§ 60.113b Testing and procedures.

The owner or operator of each storage vessel as specified in §60.112b(a) shall meet the requirements of paragraph (a), (b), or (c) of this section. The applicable paragraph for a particular storage vessel depends on the control equipment installed to meet the requirements of §60.112b.

(a) After installing the control equipment required to meet §60.112b(a)(1) (permanently affixed roof and internal floating roof), each owner or operator shall:

(1) Visually inspect the internal floating roof, the primary seal, and the secondary seal (if one is in service), prior to filling the storage vessel with VOL. If there are holes, tears, or other openings in the primary seal, the secondary seal, or the seal fabric or defects in the internal floating roof, or both, the owner or operator shall repair the items before filling the storage vessel.

(2) For Vessels equipped with a liquid-mounted or mechanical shoe primary seal, visually inspect the internal floating roof and the primary seal or the secondary seal (if one is in service) through manholes and roof hatches on the fixed roof at least once every 12 months after initial fill. If the internal floating roof is not resting on the surface of the VOL inside the storage vessel, or there is liquid accumulated on

the roof, or the seal is detached, or there are holes or tears in the seal fabric, the owner or operator shall repair the items or empty and remove the storage vessel from service within 45 days. If a failure that is detected during inspections required in this paragraph cannot be repaired within 45 days and if the vessel cannot be emptied within 45 days, a 30-day extension may be requested from the Administrator in the inspection report required in §60.115b(a)(3). Such a request for an extension must document that alternate storage capacity is unavailable and specify a schedule of actions the company will take that will assure that the control equipment will be repaired or the vessel will be emptied as soon as possible.

(3) For vessels equipped with a double-seal system as specified in §60.112b(a)(1)(ii)(B):

(i) Visually inspect the vessel as specified in paragraph (a)(4) of this section at least every 5 years; or

(ii) Visually inspect the vessel as specified in paragraph (a)(2) of this section.

(4) Visually inspect the internal floating roof, the primary seal, the secondary seal (if one is in service), gaskets, slotted membranes and sleeve seals (if any) each time the storage vessel is emptied and degassed. If the internal floating roof has defects, the primary seal has holes, tears, or other openings in the seal or the seal fabric, or the secondary seal has holes, tears, or other openings in the seal or the seal fabric, or the gaskets no longer close off the liquid surfaces from the atmosphere, or the slotted membrane has more than 10 percent open area, the owner or operator shall repair the items as necessary so that none of the conditions specified in this paragraph exist before refilling the storage vessel with VOL. In no event shall inspections conducted in accordance with this provision occur at intervals greater than 10 years in the case of vessels conducting the annual visual inspection as specified in paragraphs (a)(2) and (a)(3)(ii) of this section and at intervals no greater than 5 years in the case of vessels specified in paragraph (a)(3)(i) of this section.

(5) Notify the Administrator in writing at least 30 days prior to the filling or refilling of each storage vessel for which an inspection is required by paragraphs (a)(1) and (a)(4) of this section to afford the Administrator the opportunity to have an observer present. If the inspection required by paragraph (a)(4) of this section is not planned and the owner or operator could not have known about the inspection 30 days in advance or refilling the tank, the owner or operator shall notify the Administrator at least 7 days prior to the refilling of the storage vessel. Notification shall be made by telephone immediately followed by written documentation demonstrating why the inspection was unplanned. Alternatively, this notification including the written documentation may be made in writing and sent by express mail so that it is received by the Administrator at least 7 days prior to the refilling.

(b) After installing the control equipment required to meet §60.112b(a)(2) (external floating roof), the owner or operator shall:

(1) Determine the gap areas and maximum gap widths, between the primary seal and the wall of the storage vessel and between the secondary seal and the wall of the storage vessel according to the following frequency.

(i) Measurements of gaps between the tank wall and the primary seal (seal gaps) shall be performed during the hydrostatic testing of the vessel or within 60 days of the initial fill with VOL and at least once every 5 years thereafter.

(ii) Measurements of gaps between the tank wall and the secondary seal shall be performed within 60 days of the initial fill with VOL and at least once per year thereafter.

(iii) If any source ceases to store VOL for a period of 1 year or more, subsequent introduction of VOL into the vessel shall be considered an initial fill for the purposes of paragraphs (b)(1)(i) and (b)(1)(ii) of this section.

(2) Determine gap widths and areas in the primary and secondary seals individually by the following procedures:

(i) Measure seal gaps, if any, at one or more floating roof levels when the roof is floating off the roof leg supports.

(ii) Measure seal gaps around the entire circumference of the tank in each place where a 0.32-cm diameter uniform probe passes freely (without forcing or binding against seal) between the seal and the wall of the storage vessel and measure the circumferential distance of each such location

(iii) The total surface area of each gap described in paragraph (b)(2)(ii) ofthis section shall be determined by using probes of various widths to measure accurately the actual distance from the tank wall to the seal and multiplying each such width by its respective circumferential distance.

(3) Add the gap surface area of each gap location for the primary seal and the secondary seal individually and divide the sum for each seal by the nominal diameter of the tank and compare each ratio to the respective standards in paragraph (b)(4) ofthis section.

(4) Make necessary repairs or empty the storage vessel within 45 days of identification in any inspection for seals not meeting the requirements listed in (b)(4) (i) and (ii) ofthis section:

(i) The accumulated area of gaps between the tank wall and the mechanical shoe or liquid-mounted primary seal shall not exceed 212 Cm^2 per meter of tank diameter, and the width of any portion of any gap shall not exceed 3.81 cm.

(A) One end of the mechanical shoe is to extend into the stored liquid, and the other end is to extend a minimum vertical distance of 61 cm above the stored liquid surface.

(B) There are to be no holes, tears, or other openings in the shoe, seal fabric, or seal envelope.

(ii) The secondary seal is to meet the following requirements:

(A) The secondary seal is to be installed above the primary seal so that it completely covers the space between the roof edge and the tank wall except as provided in paragraph (b)(2)(iii) of this section.

(B) The accumulated area of gaps between the tank wall and the secondary seal shall not exceed 21.2 cm^2 per meter of tank diameter, and the width of any portion of any gap shall not exceed 1.27 cm.

(C) There are to be no holes, tears, or other openings in the seal or seal fabric.

(iii) If a failure that is detected during inspections required in paragraph (b)(1) of §60.113b(b) cannot be repaired within 45 days and if the vessel cannot be emptied within 45 days, a 30-day extension may be requested from the Administrator in the inspection report required in §60.115b(b)(4). Such extension request must include a demonstration of unavailability of alternate storage capacity and a specification of a schedule that will assure that the control equipment will be repaired or the vessel will be emptied as soon as possible.

(5) Notify the Administrator 30 days in advance of any gap measurements required by paragraph (b)(1) of this section to afford the Administrator the opportunity to have an observer present.

(6) Visually inspect the external floating roof, the primary seal, secondary seal, and fittings each time the vessel is emptied and degassed.

(i) If the external floating roof has defects, the primary seal has holes, tears, or other openings in the seal or the seal fabric, or the secondary seal has holes, tears, or other openings in the seal or the seal fabric, the owner or operator shall repair the items as necessary so that none of the conditions specified in this paragraph exist before filling or refilling the storage vessel with VOL.

(ii) For all the inspections required by paragraph (b)(6) ofthis section, the owner or operator shall notify the Administrator in writing at least 30 days prior to the filling or refilling of each storage vessel to afford the Administrator the opportunity to inspect the storage vessel prior to refilling. If the inspection required by paragraph (b)(6) ofthis section is not planned and the owner or operator could not have known about the inspection 30 days in advance of refilling the tank, the owner or operator shall notify the Administrator at least 7 days prior to the refilling of the storage vessel. Notification shall be made by telephone immediately followed by written documentation demonstrating why the inspection was unplanned. Alternatively, this notification including the written documentation may be made in writing and sent by express mail so that it is received by the Administrator at least 7 days prior to the refilling.

(c) The owner or operator of each source that is equipped with a closed vent system and control device as required in §60.112b (a)(3) or (b)(2) (other than a flare) is exempt from §60.8 of the General Provisions and shall meet the following requirements.

(1) Submit for approval by the Administrator as an attachment to the notification required by §60.7(a)(1)

or, if the facility is exempt from §60.7(a)(1), as an attachment to the notification required by §60.7(a)(2), an operating plan containing the information listed below.

(i) Documentation demonstrating that the control device will achieve the required control efficiency during maximum loading conditions. This documentation is to include a description ofthe gas stream which enters the control device, including flow and VOC content under varying liquid level conditions (dynamic and static) and manufacturer's design specifications for the control device. If the control device or the closed vent capture system receives vapors, gases, or liquids other than fuels from sources that are not designated sources under this subpart, the eficiency demonstration is to include consideration of all vapors, gases, and liquids received by the closed vent capture system and control device. If an enclosed combustion device with a minimum residence time of 0.75 seconds and a minimum temperature of 816 °C is used to meet the 95 percent requirement, documentation that those conditions will exist is sufficient to meet the requirements of this paragraph.

(ii) A description ofthe parameter or parameters to be monitored to ensure that the control device will be operated in conformance with its design and an explanation of the criteria used for selection of that parameter (or parameters).

(2) Operate the closed vent system and control device and monitor the parameters of the closed vent system and control device in accordance with the operating plan submitted to the Administrator in accordance with paragraph (c)(1) of this section, unless the plan was modified by the Administrator during the review process. In this case, the modified plan applies.

(d) The owner or operator of each source that is equipped with a closed vent system and a flare to meet the requirements in §60.112b (a)(3) or (b)(2) shall meet the requirements as specified in the general control device requirements, §60.18 (e) and (f).

[52 FR 11429, Apr. 8, 1987, as amended at 54 FR 32973, Aug. 11, 1989]

§ 60.114b Alternative means of emission limitation.

(a) If, in the Administrator's judgment, an alternative means of emission limitation will achieve a reduction in emissions at least equivalent to the reduction in emissions achieved by any requirement in §60.112b, the Administrator will publish in the Federal Register a notice permitting the use of the alternative means for purposes of compliance with that requirement.

(b) Any notice under paragraph (a) of this section will be published only after notice and an opportunity for a hearing.

(c) Any person seeking permission under this section shall submit to the Administrator a written application including:

(1) An actual emissions test that uses a full-sized or scale-model storage vessel that accurately collects and measures all VOC emissions from a given control device and that accurately simulates wind and accounts for other emission variables such as temperature and barometric pressure.

(2) An engineering evaluation that the Administrator determines is an accurate method of determining equivalence.

(d) The Administrator may condition the permission on requirements that may be necessary to ensure operation and maintenance to achieve the same emissions reduction as specifed in §60.112b.

§ 60.115b Reporting and recordkeeping requirements.

The owner or operator of each storage vessel as specified in §60.112b(a) shall keep records and furnish reports as required by paragraphs (a), (b), or (c) of this section depending upon the control equipment installed to meet the requirements of §60.112b. The owner or operator shall keep copies of all reports and records required by this section, except for the record required by (c)(1), for at least 2 years. The record required by (c)(1) will be kept for the life of the control equipment.

(a) After installing control equipment in accordance with §60.112b(a)(1) (fixed roof and internal floating roof), the owner or operator shall meet the following requirements.

(1) Furnish the Administrator with a report that describes the control equipment and certifies that the control equipment meets the specifications of §60.112b(a)(1) and §60.113b(a)(1). This report shall be an attachment to the notification required by §60.7(a)(3).

(2) Keep a record of each inspection performed as required by §60.113b (a)(1), (a)(2), (a)(3), and (a)(4). Each record shall identify the storage vessel on which the inspection was performed and shall contain the date the vessel was inspected and the observed condition of each component of the control equipment (seals, internal floating roof, and fittings).

(3) If any of the conditions described in §60.113b(a)(2) are detected during the annual visual inspection required by §60.113b(a)(2), a report shall be furnished to the Administrator within 30 days of the inspection. Each report shall identify the storage vessel, the nature of the defects, and the date the storage vessel was emptied or the nature of and date the repair was made.

(4) After each inspection required by §60.113b(a)(3) that finds holes or tears in the seal or seal fabric, or defects in the internal floating roof, or other control equipment defects listed in §60.113b(a)(3)(ii), a report shall be furnished to the Administrator within 30 days of the inspection. The report shall identify the storage vessel and the reason it did not meet the specifications of §61.112b(a)(1) or §60.113b(a)(3) and list each repair made.

(b) After installing control equipment in accordance with §61.112b(a)(2) (external floating roof), the owner or operator shall meet the following requirements.

(1) Furnish the Administrator with a report that describes the control equipment and certifies that the control equipment meets the specifications of §60.112b(a)(2) and §60.113b(b)(2), (b)(3), and (b)(4). This report shall be an attachment to the notification required by §60.7(a)(3).

(2) Within 60 days of performing the seal gap measurements required by §60.113b(b)(1), furnish the Administrator with a report that contains:

(i) The date of measurement.

(ii) The raw data obtained in the measurement.

(iii) The calculations described in §60.113b (b)(2) and (b)(3).

(3) Keep a record of each gap measurement performed as required by §60.113b(b). Each record shall identify the storage vessel in which the measurement was performed and shall contain:

(i) The date of measurement.

(ii) The raw data obtained in the measurement.

(iii) The calculations described in §60.113b (b)(2) and (b)(3).

(4) After each seal gap measurement that detects gaps exceeding the limitations specified by §60.113b (b)(4), submit a report to the Administrator within 30 days of the inspection. The report will identify the vessel and contain the information specified in paragraph (b)(2) of this section and the date the vessel was emptied or the repairs made and date of repair.

(c) After installing control equipment in accordance with §60.112b (a)(3) or (b)(1) (closed vent system and control device other than a flare), the owner or operator shall keep the following records.

(1) A copy of the operating plan.

(2) A record of the measured values of the parameters monitored in accordance with §60.113b(c)(2).

(d) After installing a closed vent system and flare to comply with §60.112b, the owner or operator shall meet the following requirements.

(1) A report containing the measurements required by §60.18(f) (1), (2), (3), (4), (5), and (6) shall be furnished to the Administrator as required by §60.8 of the General Provisions. This report shall be

submitted within 6 months of the initial start-up date.

(2) Records shall be kept of all periods of operation during which the flare pilot flame is absent.

(3) Semiannual reports of all periods recorded under §60.115b(d)(2) in which the pilot flame was absent shall be furnished to the Administrator.

§ 60.116b Monitoring of operations.

(a) The owner or operator shall keep copies of all records required by this section, except for the record required by paragraph (b) of this section, for at least 2 years. The record required by paragraph (b) of this section will be kept for the life of the source.

(b) The owner or operator of each storage vessel as specified in §60.110b(a) shall keep readily accessible records showing the dimension of the storage vessel and an analysis showing the capacity of the storage vessel.

(c) Except as provided in paragraphs (f) and (g) of this section, the owner or operator of each storage vessel either with a design capacity greater than or equal to 151 m^3 storing a liquid with a maximum true vapor pressure greater than or equal to 3.5 kPa or with a design capacity greater than or equal to 75 m^3 but less than 151 m^3 storing a liquid with a maximum true vapor pressure greater than or equal to 15.0 kPa shall maintain a record of the VOL stored, the period of storage, and the maximum true vapor pressure of that VOL during the respective storage period.

(d) Except as provided in paragraph (g) of this section, the owner or operator of each storage vessel either with a design capacity greater than or equal to 151 m^3 storing a liquid with a maximum true vapor pressure that is normally less than 5.2 kPa or with a design capacity greater than or equal to 75 m^3 but less than 151 m^3 storing a liquid with a maximum true vapor pressure that is normally less than 27.6 kPa shall notify the Administrator within 30 days when the maximum true vapor pressure of the liquid exceeds the respective maximum true vapor vapor pressure values for each volume range.

(e) Available data on the storage temperature may be used to determine the maximum true vapor pressure as determined below.

(1) For vessels operated above or below ambient temperatures, the maximum true vapor pressure is calculated based upon the highest expected calendar-month average of the storage temperature. For vessels operated at ambient temperatures, the maximum true vapor pressure is calculated based upon the maximum local monthly average ambient temperature as reported by the National Weather Service.

(2) For crude oil or refined petroleum products the vapor pressure may be obtained by the following:

(i) Available data on the Reid vapor pressure and the maximum expected storage temperature based on the highest expected calendar-month average temperature of the stored product may be used to determine the maximum true vapor pressure from nomographs contained in API Bulletin 2517 (incorporated by reference—see §60.17), unless the Administrator specifically requests that the liquid be sampled, the actual storage temperature determined, and the Reid vapor pressure determined from the sample(s).

(ii) The true vapor pressure of each type of crude oil with a Reid vapor pressure less than 13.8 kPa or with physical properties that preclude determination by the recommended method is to be determined from available data and recorded if the estimated maximum true vapor pressure is greater than 3.5 kPa.

(3) For other liquids, the vapor pressure:

(i) May be obtained from standard reference texts, or

(ii) Determined by ASTM D2879–83, 96, or 97 (incorporated by reference—see §60.17); or

(iii) Measured by an appropriate method approved by the Administrator; or

(iv) Calculated by an appropriate method approved by the Administrator.

(f) The owner or operator of each vessel storing a waste mixture of indeterminate or variable composition shall be subject to the following requirements.

(1) Prior to the initial filling of the vessel, the highest maximum true vapor pressure for the range of anticipated liquid compositions to be stored will be determined using the methods described in paragraph (e) of this section.

(2) For vessels in which the vapor pressure of the anticipated liquid composition is above the cutoff for monitoring but below the cutoff for controls as defined in §60.112b(a), an initial physical test of the vapor pressure is required; and a physical test at least once every 6 months thereafter is required as determined by the following methods:

(i) ASTM D2879–83, 96, or 97 (incorporated by reference—see §60.17); or

(ii) ASTM D323–82 or 94 (incorporated by reference—see §60.17); or

(iii) As measured by an appropriate method as approved by the Administrator.

(g) The owner or operator of each vessel equipped with a closed vent system and control device meeting the specification of §60.112b or with emissions reductions equipment as specified in 40 CFR 65.42(b)(4), (b)(5), (b)(6), or (c) is exempt from the requirements of paragraphs (c) and (d) of this section.

[52 FR 11429, Apr. 8, 1987, as amended at 65 FR 61756, Oct. 17, 2000; 65 FR 78276, Dec. 14, 2000; 68 FR 59333, Oct. 15, 2003]

§ 60.117b Delegation of authority.

(a) In delegating implementation and enforcement authority to a State under section 111(c) of the Act, the authorities contained in paragraph (b) of this section shall be retained by the Administrator and not transferred to a State.

(b) Authorities which will not be delegated to States: §§60.111b(f)(4), 60.114b, 60.116b(e)(3)(iii), 60.116b(e)(3)(iv), and 60.116b(f)(2)(iii).

[52 FR 11429, Apr. 8, 1987, as amended at 52 FR 22780, June 16, 1987]

Browse Previous | Browse Next

For questions or comments regarding e-CFR editorial content, features, or design, email ecfr@nara.gov.

For questions concerning e-CFR programming and delivery issues, email webteam@gpo.gov.

Section 508 / Accessibility

Electronic Code of Federal Regulations
e-CFR™

e-CFR Data is current as of May 12, 2011

Title 40: Protection of Environment

PART 63—NATIONAL EMISSION STANDARDS FOR HAZARDOUS AIR POLLUTANTS FOR SOURCE CATEGORIES

Browse Previous | Browse Next

Subpart S—National Emission Standards for Hazardous Air Pollutants from the Pulp and Paper Industry

Source: 63 FR 18617, Apr. 15, 1998, unless otherwise noted.

§ 63.440 Applicability.

(a) The provisions of this subpart apply to the owner or operator of processes that produce pulp, paper, or paperboard; that are located at a plant site that is a major source as defined in §63.2 of subpart A of this part; and that use the following processes and materials:

(1) Kraft, soda, sulfite, or semi-chemical pulping processes using wood; or

(2) Mechanical pulping processes using wood; or

(3) Any process using secondary or non-wood fibers.

(b) The affected source to which the existing source provisions of this subpart apply is as follows:

(1) For the processes specified in paragraph (a)(1) of this section, the affected source is the total of all HAP emission points in the pulping and bleaching systems; or

(2) For the processes specified in paragraphs (a)(2) or (a)(3) of this section, the affected source is the total of all HAP emission points in the bleaching system.

(c) The new source provisions of this subpart apply to the total of all HAP emission points at new or existing sources as follows:

(1) Each affected source defined in paragraph (b)(1) of this section that commences construction or reconstruction after December 17, 1993;

(2) Each pulping system or bleaching system for the processes specified in paragraph (a)(1) of this section that commences construction or reconstruction after December 17, 1993;

(3) Each additional pulping or bleaching line at the processes specified in paragraph (a)(1) of this section, that commences construction after December 17, 1993;

(4) Each affected source defined in paragraph (b)(2) of this section that commences construction or reconstruction after March 8, 1996; or

(5) Each additional bleaching line at the processes specified in paragraphs (a)(2) or (a)(3) of this section,

that commences construction after March 8, 1996.

(d) Each existing source shall achieve compliance no later than April 16, 2001, except as provided in paragraphs (d)(1) through (d)(3) ofthis section.

(1) Each kraft pulping system shall achieve compliance with the pulping system provisions of §63.443 for the equipment listed in §63.443(a)(1)(ii) through (a)(1)(v) as expeditiously as practicable, but in no event later than April 17, 2006 and the owners and operators shall establish dates, update dates, and report the dates for the milestones specified in §63.455(b).

(2) Each dissolving-grade bleaching system at either kraft or sulfite pulping mills shall achieve compliance with the bleach plant provisions of §63.445 of this subpart as expeditiously as practicable, but in no event later than 3 years after the promulgation of the revised effluent limitation guidelines and standards under 40 CFR 430.14 through 430.17 and 40 CFR 430.44 through 430.47.

(3) Each bleaching system complying with the Voluntary Advanced Technology Incentives Program for Effluent Limitation Guidelines in 40 CFR 430.24, shall comply with the requirements specified in either paragraph (d)(3)(i) or (d)(3)(ii) ofthis section for the effluent limitation guidelines and standards in 40 CFR 430.24.

(i) Comply with the bleach plant provisions of §63.445 of this subpart as expeditiously as practicable, but in no event later than April 16, 2001.

(ii) Comply with paragraphs (d)(3)(ii)(A), (d)(3)(ii)(B), and (d)(3)(ii)(C) ofthis section.

(A) The owner or operator of a bleaching system shall comply with the bleach plant provisions of §63.445 of this subpart as expeditiously as practicable, but in no event later than April 15, 2004.

(B) The owner or operator of a bleaching system shall comply with the requirements specified in either paragraph (d)(3)(ii)(B)(*1*) or (d)(3)(ii)(B)(*2*) of this section.

(*1*) Not increase the application rate of chlorine or hypochlorite in kilograms (kg) of bleaching agent per megagram of ODP, in the bleaching system above the average daily rates used over the three months prior to June 15, 1998 until the requirements of paragraph (d)(3)(ii)(A) ofthis section are met and record application rates as specifed in §63.454(c).

(*2*) Comply with enforceable effluent limitations guidelines for 2,3,7,8-tetrachloro-dibenzo-p-dioxin and adsorbable organic halides at least as stringent as the baseline BATlevels set out in 40 CFR 430.24(a)(1) as expeditiously as possible, but in no event later than April 16, 2001.

(C) Owners and operators shall establish dates, update dates, and report the dates for the milestones specified in §63.455(b).

(e) Each new source, specified as the total of all HAP emission points for the sources specifed in paragraph (c) of this section, shall achieve compliance upon start-up or June 15, 1998, whichever is later, as provided in §63.6(b) of subpart A of this part.

(f) Each owner or operator of an affected source with affected process equipment shared by more than one type of pulping process, shall comply with the applicable requirement in this subpart that achieves the maximum degree of reduction in HAP emissions.

(g) Each owner or operator of an affected source specifed in paragraphs (a) through (c) of this section must comply with the requirements of subpart A—General Provisions of this part, as indicated in table 1 to this subpart.

[63 FR 18617, Apr. 15, 1998, as amended at 63 FR 71389, Dec. 28, 1998]

§ 63.441 Definitions.

All terms used in this subpart shall have the meaning given them in the CAA, in subpart A of this part, and in this section as follows:

Acid condensate storage tank means any storage tank containing cooking acid following the sulfur dioxide gas fortification process.

Black liquor means spent cooking liquor that has been separated from the pulp produced by the kraft, soda, or semi-chemical pulping process.

Bleaching means brightening of pulp by the addition of oxidizing chemicals or reducing chemicals.

Bleaching line means a group of bleaching stages arranged in series such that bleaching of the pulp progresses as the pulp moves from one stage to the next.

Bleaching stage means all process equipment associated with a discrete step of chemical application and removal in the bleaching process including chemical and steam mixers, bleaching towers, washers, seal (filtrate) tanks, vacuum pumps, and any other equipment serving the same function as those previously listed.

Bleaching system means all process equipment after high-density pulp storage prior to the first application of oxidizing chemicals or reducing chemicals following the pulping system, up to and including the final bleaching stage.

Boiler means any enclosed combustion device that extracts useful energy in the form of steam. A boiler is not considered a thermal oxidizer.

Chip steamer means a vessel used for the purpose of preheating or pretreating wood chips prior to the digester, using flash steam from the digester or live steam.

Closed-vent system means a system that is not open to the atmosphere and is composed of piping, ductwork, connections, and, if necessary, flow-inducing devices that transport gas or vapor from an emission point to a control device.

Combustion device means an individual unit of equipment, including but not limited to, a thermal oxidizer, lime kiln, recovery furnace, process heater, or boiler, used for the thermal oxidation of organic hazardous air pollutant vapors.

Decker system means all equipment used to thicken the pulp slurry or reduce its liquid content after the pulp washing system and prior to high-density pulp storage. The decker system includes decker vents, filtrate tanks, associated vacuum pumps, and any other equipment serving the same function as those previously listed.

Digester system means each continuous digester or each batch digester used for the chemical treatment of wood or non-wood fibers. The digester system equipment includes associated flash tank(s), blow tank(s), chip steamer(s) not using fresh steam, blow heat recovery accumulator(s), relief gas condenser(s), prehydrolysis unit(s) preceding the pulp washing system, and any other equipment serving the same function as those previously listed. The digester system includes any of the liquid streams or condensates associated with batch or continuous digester relief blow, or flash steam processes.

Emission point means any part of a stationary source that emits hazardous air pollutants regulated under this subpart, including emissions from individual process vents, stacks, open pieces of process equipment, equipment leaks, wastewater and condensate collection and treatment system units, and those emissions that could reasonably be conveyed through a stack, chimney, or duct where such emissions first reach the environment.

Evaporator system means all equipment associated with increasing the solids content and/or concentrating spent cooking liquor from the pulp washing system including pre-evaporators, multi-effect evaporators, concentrators, and vacuum systems, as well as associated condensers, hotwells, and condensate streams, and any other equipment serving the same function as those previously listed.

Flow indicator means any device that indicates gas or liquid flow in an enclosed system.

HAP means a hazardous air pollutant as defined in §63.2 of subpart A of this part.

High volume, low concentration or HVLC collection system means the gas collection and transport

system used to convey gases from the HVLC system to a control device.

High volume, low concentration or HVLC system means the collection of equipment including the pulp washing, knotter, screen, decker, and oxygen delignification systems, weak liquor storage tanks, and any other equipment serving the same function as those previously listed.

Knotter system means equipment where knots, oversized material, or pieces of uncooked wood are removed from the pulp slurry after the digester system and prior to the pulp washing system. The knotter system equipment includes the knotter, knot drainer tanks, ancillary tanks, and any other equipment serving the same function as those previously listed.

Kraft pulping means a chemical pulping process that uses a mixture of sodium hydroxide and sodium sulfide as the cooking liquor.

Lime kiln means an enclosed combustion device used to calcine lime mud, which consists primarily of calcium carbonate, into calcium oxide.

Low volume, high concentration or LVHC collection system means the gas collection and transport system used to convey gases from the LVHC system to a control device.

Low volume, high concentration or LVHC system means the collection of equipment including the digester, turpentine recovery, evaporator, steam stripper systems, and any other equipment serving the same function as those previously listed.

Mechanical pulping means a pulping process that only uses mechanical and thermo-mechanical processes to reduce wood to a fibrous mass. The mechanical pulping processes include, but are not limited to, stone groundwood, pressurized groundwood, refiner mechanical, thermal refiner mechanical, thermo-mechanical, and tandem thermo-mechanical.

Non-wood pulping means the production of pulp from fiber sources other than trees. The non-wood fiber sources include, but are not limited to, bagasse, cereal straw, cotton, flax straw, hemp, jute, kenaf, and leaf fibers.

Oven-dried pulp or ODP means a pulp sample at zero percent moisture content by weight. Pulp samples for applicability or compliance determinations for both the pulping and bleaching systems shall be unbleached pulp. For purposes of complying with mass emission limits in this subpart, megagram of ODP shall be measured to represent the amount of pulp entering and processed by the equipment system under the specified mass limit. For equipment that does not process pulp, megagram of ODP shall be measured to represent the amount of pulp that was processed to produce the gas and liquid streams.

Oxygen delignification system means the equipment that uses oxygen to remove lignin from pulp after high-density stock storage and prior to the bleaching system. The oxygen delignification system equipment includes the blow tank, washers, filtrate tanks, any interstage pulp storage tanks, and any other equipment serving the same function as those previously listed.

Primary fuel means the fuel that provides the principal heat input to the combustion device. To be considered primary, the fuel must be able to sustain operation of the combustion device without the addition of other fuels.

Process wastewater treatment system means a collection of equipment, a process, or specific technique that removes or destroys the HAPs in a process wastewater stream. Examples include, but are not limited to, a steam stripping unit, wastewater thermal oxidizer, or biological treatment unit.

Pulp washing system means all equipment used to wash pulp and separate spent cooking chemicals following the digester system and prior to the bleaching system, oxygen delignification system, or paper machine system (at unbleached mills). The pulp washing system equipment includes vacuum drum washers, diffusion washers, rotary pressure washers, horizontal belt filters, intermediate stock chests, and their associated vacuum pumps, filtrate tanks, foam breakers or tanks, and any other equipment serving the same function as those previously listed. The pulp washing system does not include deckers, screens, knotters, stock chests, or pulp storage tanks following the last stage of pulp washing.

Pulping line means a group of equipment arranged in series such that the wood chips are digested and the resulting pulp progresses through a sequence of steps that may include knotting, refining, washing,

thickening, blending, storing, oxygen delignification, and any other equipment serving the same function as those previously listed.

Pulping process condensates means any HAP-containing liquid that results from contact of water with organic compounds in the pulping process. Examples of process condensates include digester system condensates, turpentine recovery system condensates, evaporator system condensates, LVHC system condensates, HVLC system condensates, and any other condensates from equipment serving the same function as those previously listed. Liquid streams that are intended for byproduct recovery are not considered process condensate streams.

Pulping system means all process equipment, beginning with the digester system, and up to and including the last piece of pulp conditioning equipment prior to the bleaching system, including treatment with ozone, oxygen, or peroxide before the first application of a chemical bleaching agent intended to brighten pulp. The pulping system includes pulping process condensates and can include multiple pulping lines.

Recovery furnace means an enclosed combustion device where concentrated spent liquor is burned to recover sodium and sulfur, produce steam, and dispose of unwanted dissolved wood components in the liquor.

Screen system means equipment in which oversized particles are removed from the pulp slurry prior to the bleaching or papermaking system washed stock storage.

Secondary fiber pulping means a pulping process that converts a fibrous material, that has previously undergone a manufacturing process, into pulp stock through the addition of water and mechanical energy. The mill then uses that pulp as the raw material in another manufactured product. These mills may also utilize chemical, heat, and mechanical processes to remove ink particles from the fiber stock.

Semi-chemical pulping means a pulping process that combines both chemical and mechanical pulping processes. The semi-chemical pulping process produces intermediate yields ranging from 55 to 90 percent.

Soda pulping means a chemical pulping process that uses sodium hydroxide as the active chemical in the cooking liquor.

Spent liquor means process liquid generated from the separation of cooking liquor from pulp by the pulp washing system containing dissolved organic wood materials and residual cooking compounds.

Steam stripper system means a column (including associated stripper feed tanks, condensers, or heat exchangers) used to remove compounds from wastewater or condensates using steam The steam stripper system also contains all equipment associated with a methanol rectification process including rectifiers, condensers, decanters, storage tanks, and any other equipment serving the same function as those previously listed.

Strong liquor storage tanks means all storage tanks containing liquor that has been concentrated in preparation for combustion or oxidation in the recovery process.

Sulfite pulping means a chemical pulping process that uses a mixture of sulfurous acid and bisulfite ion as the cooking liquor.

Temperature monitoring device means a piece of equipment used to monitor temperature and having an accuracy of ±1.0 percent of the temperature being monitored expressed in degrees Celsius or ±0.5 degrees Celsius (°C), whichever is greater.

Thermal oxidizer means an enclosed device that destroys organic compounds by thermal oxidation.

Turpentine recovery system means all equipment associated with recovering turpentine from digester system gases including condensers, decanters, storage tanks, and any other equipment serving the same function as those previously listed. The turpentine recovery system includes any liquid streams associated with the turpentine recovery process such as turpentine decanter underflow. Liquid streams that are intended for byproduct recovery are not considered turpentine recovery system condensate streams.

Weak liquor storage tank means any storage tank except washer filtrate tanks containing spent liquor recovered from the pulping process and prior to the evaporator system.

[63 FR 18617, Apr. 15, 1998, as amended at 64 FR 17563, Apr. 12, 1999]

§ 63.442 [Reserved]

§ 63.443 Standards for the pulping system at kraft, soda, and semi-chemical processes.

(a) The owner or operator of each pulping system using the kraft process subject to the requirements of this subpart shall control the total HAP emissions from the following equipment systems, as specified in paragraphs (c) and (d) of this section.

(1) At existing affected sources, the total HAP emissions from the following equipment systems shall be controlled:

(i) Each LVHC system;

(ii) Each knotter or screen system with total HAP mass emission rates greater than or equal to the rates specified in paragraphs (a)(1)(ii)(A) or (a)(1)(ii)(B) of this section or the combined rate specified in paragraph (a)(1)(ii)(C) of this section.

(A) Each knotter system with emissions of 0.05 kilograms or more of total HAP per megagram of ODP (0.1 pounds per ton).

(B) Each screen system with emissions of 0.10 kilograms or more of total HAP per megagram of ODP (0.2 pounds per ton).

(C) Each knotter and screen system with emissions of 0.15 kilograms or more of total HAP per megagram of ODP (0.3 pounds per ton).

(iii) Each pulp washing system;

(iv) Each decker system that:

(A) Uses any process water other than fresh water or paper machine white water; or

(B) Uses any process water with a total HAP concentration greater than 400 parts per million by weight; and

(v) Each oxygen delignification system.

(2) At new affected sources, the total HAP emissions from the equipment systems listed in paragraphs (a)(1)(i), (a)(1)(iii), and (a)(1)(v) of this section and the following equipment systems shall be controlled:

(i) Each knotter system;

(ii) Each screen system;

(iii) Each decker system; and

(iv) Each weak liquor storage tank.

(b) The owner or operator of each pulping system using a semi-chemical or soda process subject to the requirements of this subpart shall control the total HAP emissions from the following equipment systems as specified in paragraphs (c) and (d) of this section.

(1) At each existing affected source, the total HAP emissions from each LVHC system shall be controlled.

(2) At each new affected source, the total HAP emissions from each LVHC system and each pulp washing system shall be controlled.

(c) Equipment systems listed in paragraphs (a) and (b) of this section shall be enclosed and vented into a closed-vent system and routed to a control device that meets the requirements specified in paragraph (d) of this section. The enclosures and closed-vent system shall meet the requirements specified in §63.450.

(d) The control device used to reduce total HAP emissions from each equipment system listed in paragraphs (a) and (b) of this section shall:

(1) Reduce total HAP emissions by 98 percent or more by weight; or

(2) Reduce the total HAP concentration at the outlet of the thermal oxidizer to 20 parts per million or less by volume, corrected to 10 percent oxygen on a dry basis; or

(3) Reduce total HAP emissions using a thermal oxidizer designed and operated at a minimum temperature of 871 °C (1600 °F) and a minimum residence time of 0.75 seconds; or

(4) Reduce total HAP emissions using one of the following:

(i) A boiler, lime kiln, or recovery furnace by introducing the HAP emission stream with the primary fuel or into the flame zone; or

(ii) A boiler or recovery furnace with a heat input capacity greater than or equal to 44 megawatts (150 million British thermal units per hour) by introducing the HAP emission stream with the combustion air.

(e) Periods of excess emissions reported under §63.455 shall not be a violation of §63.443 (c) and (d) provided that the time of excess emissions (excluding periods of startup, shutdown, or malfunction) divided by the total process operating time in a semi-annual reporting period does not exceed the following levels:

(1) One percent for control devices used to reduce the total HAP emissions from the LVHC system; and

(2) Four percent for control devices used to reduce the total HAP emissions from the HVLC system; and

(3) Four percent for control devices used to reduce the total HAP emissions from both the LVHC and HVLC systems.

[63 FR 18617, Apr. 15, 1998, as amended at 64 FR 17563, Apr. 12, 1999; 66 FR 80762, Dec. 22, 2000]

§ 63.444 Standards for the pulping system at sulfite processes.

(a) The owner or operator of each sulfite process subject to the requirements of this subpart shall control the total HAP emissions from the following equipment systems as specified in paragraphs (b) and (c) of this section.

(1) At existing sulfite affected sources, the total HAP emissions from the following equipment systems shall be controlled:

(i) Each digester system vent;

(ii) Each evaporator system vent; and

(iii) Each pulp washing system.

(2) At new affected sources, the total HAP emissions from the equipment systems listed in paragraph (a) (1) of this section and the following equipment shall be controlled:

(i) Each weak liquor storage tank;

(ii) Each strong liquor storage tank; and

(iii) Each acid condensate storage tank.

(b) Equipment listed in paragraph (a) of this section shall be enclosed and vented into a closed-vent system and routed to a control device that meets the requirements specified in paragraph (c) of this section. The enclosures and closed-vent system shall meet the requirements specified in §63.450. Emissions from equipment listed in paragraph (a) of this section that is not necessary to be reduced to meet paragraph (c) of this section is not required to be routed to a control device.

(c) The total HAP emissions from both the equipment systems listed in paragraph (a) of this section and the vents, wastewater, and condensate streams from the control device used to reduce HAP emissions, shall be controlled as follows.

(1) Each calcium-based or sodium-based sulfite pulping process shall:

(i) Emit no more than 0.44 kilograms of total HAP or methanol per megagram (0.89 pounds per ton) of ODP; or

(ii) Remove 92 percent or more by weight of the total HAP or methanol.

(2) Each magnesium-based or ammonium-based sulfite pulping process shall:

(i) Emit no more than 1.1 kilograms of total HAP or methanol per megagram (2.2 pounds per ton) of ODP; or

(ii) Remove 87 percent or more by weight of the total HAP or methanol.

§ 63.445 Standards for the bleaching system.

(a) Each bleaching system that does not use any chlorine or chlorinated compounds for bleaching is exempt from the requirements of this section. Owners or operators of the following bleaching systems shall meet all the provisions of this section:

(1) Bleaching systems that use chlorine;

(2) Bleaching systems bleaching pulp from kraft, sulfite, or soda pulping processes that use any chlorinated compounds; or

(3) Bleaching systems bleaching pulp from mechanical pulping processes using wood or from any process using secondary or non-wood fibers, that use chlorine dioxide.

(b) The equipment at each bleaching stage, of the bleaching systems listed in paragraph (a) of this section, where chlorinated compounds are introduced shall be enclosed and vented into a closed-vent system and routed to a control device that meets the requirements specified in paragraph (c) of this section. The enclosures and closed-vent system shall meet the requirements specified in §63.450. If process modifications are used to achieve compliance with the emission limits specified in paragraphs (c)(2) or (c)(3), enclosures and closed-vent systems are not required, unless appropriate.

(c) The control device used to reduce chlorinated HAP emissions (not including chloroform) from the equipment specified in paragraph (b) of this section shall:

(1) Reduce the total chlorinated HAP mass in the vent stream entering the control device by 99 percent or more by weight;

(2) Achieve a treatment device outlet concentration of 10 parts per million or less by volume of total chlorinated HAP; or

(3) Achieve a treatment device outlet mass emission rate of 0.001 kg of total chlorinated HAP mass per megagram (0.002 pounds per ton) of ODP.

(d) The owner or operator of each bleaching system subject to paragraph (a)(2) of this section shall comply with paragraph (d)(1) or (d)(2) of this section to reduce chloroform air emissions to the atmosphere, except the owner or operator of each bleaching system complying with extended compliance under §63.440(d)(3)(ii) shall comply with paragraph (d)(1) of this section.

(1) Comply with the following applicable effluent limitation guidelines and standards specified in 40 CFR part 430:

(i) Dissolving-grade kraft bleaching systems and lines, 40 CFR 430.14 through 430.17;

(ii) Paper-grade kraft and soda bleaching systems and lines, 40 CFR 430.24(a)(1) and (e), and 40 CFR 430.26 (a) and (c);

(iii) Dissolving-grade sulfite bleaching systems and lines, 40 CFR 430.44 through 430.47; or

(iv) Paper-grade sulfite bleaching systems and lines, 40 CFR 430.54(a) and (c), and 430.56(a) and (c).

(2) Use no hypochlorite or chlorine for bleaching in the bleaching system or line.

[63 FR 18617, Apr. 15, 1998, as amended at 64 FR 17563, Apr. 12, 1999]

§ 63.446 Standards for kraft pulping process condensates.

(a) The requirements of this section apply to owners or operators of kraft processes subject to the requirements of this subpart.

(b) The pulping process condensates from the following equipment systems shall be treated to meet the requirements specified in paragraphs (c), (d), and (e) of this section:

(1) Each digester system;

(2) Each turpentine recovery system;

(3) Each evaporator system condensate from:

(i) The vapors from each stage where weak liquor is introduced (feed stages); and

(ii) Each evaporator vacuum system for each stage where weak liquor is introduced (feed stages).

(4) Each HVLC collection system; and

(5) Each LVHC collection system.

(c) One of the following combinations of HAP-containing pulping process condensates generated, produced, or associated with the equipment systems listed in paragraph (b) of this section shall be subject to the requirements of paragraphs (d) and (e) of this section:

(1) All pulping process condensates from the equipment systems specified in paragraphs (b)(1) through (b)(5) of this section.

(2) The combined pulping process condensates from the equipment systems specified in paragraphs (b)(4) and (b)(5) of this section, plus pulping process condensate stream(s) that in total contain at least 65 percent of the total HAP mass from the pulping process condensates from equipment systems listed in paragraphs (b)(1) through (b)(3) of this section.

(3) The pulping process condensates from equipment systems listed in paragraphs (b)(1) through (b)(5) of this section that in total contain a total HAP mass of 3.6 kilograms or more of total HAP per megagram (7.2 pounds per ton) of ODP for mills that do not perform bleaching or 5.5 kilograms or more of total HAP per megagram (11.1 pounds per ton) of ODP for mills that perform bleaching.

(d) The pulping process condensates from the equipment systems listed in paragraph (b) of this section

shall be conveyed in a closed collection system that is designed and operatedto meet the requirements specified in paragraphs (d)(1) and (d)(2) of this section.

(1) Each closed collection system shall meet the individual drain system requirements specified in §§63.960, 63.961, and 63.962 of subpart RR of this part, except for closed vent systems and control devices shall be designed and operated in accordance with §§63.443(d) and 63.450, instead ofin accordance with §63.693 as specified in §63.962 (a)(3)(ii), (b)(3)(ii)(A), and (b)(5)(iii); and

(2) If a condensate tank is used in the closed collection system, the tank shall meet the following requirements:

(i) The fixed roof and all openings (e.g., access hatches, sampling ports, gauge wells) shall be designed and operated with no detectable leaks as indicated byan instrument reading of less than 500 parts per million above background, and vented into a closed-vent system that meets the requirements in §63.450 and routed to a control device that meets the requirements in §63.443(d); and

(ii) Each opening shall be maintained in a closed, sealed position (e.g., covered by a lid that is gasketed and latched) at all times that the tank contains pulping process condensates o any HAP removed from a pulping process condensate stream except when it is necessary to use the opening for sampling, removal, or for equipment inspection, maintenance, or repair.

(e) Each pulping process condensate from the equipment systems listed in paragraph (b) of this section shall be treated according to one of the following options:

(1) Recycle the pulping process condensate to an equipment system specified in §63.443(a) meeting the requirements specified in §63.443(c) and (d); or

(2) Discharge the pulping process condensate belowthe liquid surface of a biological treatment system and treat the pulping process condensates to meet the requirements specified in paragraph (e)(3), (4), or (5) of this section, and total HAP shall be measured as specified in §63.457(g); or

(3) Treat the pulping process condensates to reduce or destroythe total HAPs by at least 92 percent or more by weight; or

(4) At mills that do not perform bleaching, treat the pulping process condensates to remove 3.3 kilograms or more of total HAP per megagram (6.6 pounds per ton) ofODP, or achieve a total HAP concentration of 210 parts per million or less by weight at the outlet ofthe control device; or

(5) At mills that perform bleaching, treat the pulping process condensates to remove 5.1 kilograms or more of total HAP per megagram (10.2 pounds per ton) of ODP, or achieve a total HAP concentration of 330 parts per million or less by weight at the outlet of the control device.

(f) Each HAP removed from a pulping process condensate streamduring treatment and handling under paragraphs (d) or (e) ofthis section, except for those treated according to paragraph (e)(2) of this section, shall be controlledas specified in §63.443(c) and (d).

(g) For each control device (e.g. steam stripper system or other equipment serving the same function) used to treat pulping process condensates to comply with the requirements specified in paragraphs (e)(3) through (e)(5) of this section, periods of excess emissions reported under §63.455 shall not be a violation of paragraphs (d), (e)(3) through (e)(5), and (f) of this section provided that the time of excess emissions (including periods ofstartup, shutdown, or malfunction) divided by the total process operating time in a semi-annual reporting period does not exceed 10 percent. The 10 percent excess emissions allowance does not apply to treatment of pulping process condensates according to paragraph (e)(2) of this section (e.g. the biological wastewater treatment system used to treat multiple (primarily non-condensate) wastewater streams to comply with the Clean Water Act).

(h) Each owner or operator of a new or existing affected source subject to the requirements of this section shall evaluate all new or modified pulping process condensates or changes in the annual bleached or non-bleached ODP used to comply with paragraph (i) of this section, to determine if they meet the applicable requirements of this section.

(i) For the purposes of meeting the requirements in paragraph (c)(2) or (3) or paragraph (e)(4) or (5) of this section at mills producing both bleached and unbleached pulp products, owners and operators may meet a prorated mass standard that is calculated by prorating the applicable mass standards (kilograms

of total HAP per megagram of ODP) for bleached and unbleached mills specified in paragraph (c)(2) or (3) or paragraph (e)(4) or (5) ofthis section by the ratio of annual megagrams of bleached and unbleached ODP.

[63 FR 18617, Apr. 15, 1998; 63 FR 42239, Aug. 7, 1998, as amended at 63 FR 49459, Sept. 16, 1998; 64 FR 17563, Apr. 12, 1999; 65 FR 80762, Dec. 22, 2000]

§ 63.447 Clean condensate alternative.

As an alternative to the requirements specified in §63.443(a)(1)(ii) through (a)(1)(v) for the control of HAP emissions from pulping systems using the kraft process, an owner or operator must demonstrate to the satisfaction of the Administrator, by meeting all the requirements below, that the total HAP emissions reductions achieved by this clean condensate alternative technology are equal to or greater than the total HAP emission reductions that would have been achieved by compliance with §63.443(a)(1)(ii) through (a)(1)(v).

(a) For the purposes ofthis section only the following additional definitions apply.

(1) *Clean condensate alternative affected source* means the total of all HAP emission points in the pulping, bleaching, causticizing, and papermaking systems (exclusive of HAP emissions attributable to additives to paper machines and HAP emission points in the LVHC system).

(2) *Causticizing system* means all equipment associated with converting sodium carbonate into active sodium hydroxide. The equipment includes smelt dissolving tanks, lime mud washers and storage tanks, white and mud liquor clarifiers and storage tanks, slakers, slaker grit washers, lime kilns, green liquor clarifiers and storage tanks, and dreg washers ending with the white liquor storage tanks prior to the digester system, and any other equipment serving the same function as those previously listed.

(3) *Papermaking system* means all equipment used to convert pulp into paper, paperboard, or market pulp, including the stock storage and preparation systems, the paper or paperboard machines, and the paper machine white water system, broke recovery systems, and the systems involved in calendering, drying, on-machine coating, slitting, winding, and cutting.

(b) Each owner or operator shall install and operate a clean condensate alternative technology with a continuous monitoring system to reduce total HAP emissions by treating and reducing HAP concentrations in the pulping process water used within the clean condensate alternative affected source.

(c) Each owner or operator shall calculate HAP emissions on a kilogram per megagram of ODP basis and measure HAP emissions according to the appropriate procedures contained in §63.457.

(d) Each owner or operator shall determine the baseline HAP emissions for each equipment system and the total of all equipment systems in the clean condensate alternative affected source based on the following:

(1) Process and air pollution control equipment installed and operating on December 17, 1993, and

(2) Compliance with the following requirements that affect the level of HAP emissions from the clean condensate alternative affected source:

(i) The pulping process condensates requirements in §63.446;

(ii) The applicable effluent limitation guidelines and standards in 40 CFR part 430, subparts A, B, D, and E; and

(iii) All other applicable requirements of local, State, or Federal agencies or statutes.

(e) Each owner or operator shall determine the following HAP emission reductions from the baseline HAP emissions determined in paragraph (d) of this section for each equipment system and the total of all equipment systems in the clean condensate alternative affected source:

(1) The HAP emission reduction occurring by complying with the requirements of §63.443(a)(1)(ii)

through (a)(1)(v); and

(2) The HAP emissions reduction occurring by complying with the clean condensate alternative technology.

(f) For the purposes of all requirements in this section, each owner or operator may use as an alternative, individual equipment systems (instead of total of all equipment systems) within the clean condensate alternative affected source to determine emissions and reductions to demonstrate equal or greater than the reductions that would have been achieved by compliance with §63.443(a)(1)(ii) through (a)(1)(v).

(g) The initial and updates to the control strategy report specified in §63.455(b) shall include to the extent possible the following information:

(1) A detailed description of

(i) The equipment systems and emission points that comprise the clean condensate alternative affected source;

(ii) The air pollution control technologies that would be used to meet the requirements of §63.443(a)(1)(ii) through (a)(1)(v); and

(iii) The clean condensate alternative technology to be used.

(2) Estimates and basis for the estimates of total HAP emissions and emission reductions to fulfill the requirements of paragraphs (d), (e), and (f) of this section.

(h) Each owner or operator shall report to the Administrator by the applicable compliance date specified in §63.440(d) or (e) the rationale, calculations, test procedures, and data documentation used to demonstrate compliance with all the requirements of this section.

[63 FR 18617, Apr. 15, 1998; 63 FR 42239, Aug. 7, 1998, as amended at 64 FR 17563, Apr. 12, 1999]

§§ 63.448-63.449 [Reserved]

§ 63.450 Standards for enclosures and closed-vent systems.

(a) Each enclosure and closed-vent system specified in §§63.443(c), 63.444(b), and 63.445(b) for capturing and transporting vent streams that contain HAP shall meet the requirements specified in paragraphs (b) through (d) of this section.

(b) Each enclosure shall maintain negative pressure at each enclosure or hood opening as demonstrated by the procedures specified in §63.457(e). Each enclosure or hood opening closed during the initial performance test specified in §63.457(a) shall be maintained in the same closed and sealed position as during the performance test at all times except when necessary to use the opening for sampling, inspection, maintenance, or repairs.

(c) Each component of the closed-vent system used to comply with §§63.443(c), 63.444(b), and 63.445(b) that is operated at positive pressure and located prior to a control device shall be designed for and operated with no detectable leaks as indicated by an instrument reading of less than 500 parts per million by volume above background, as measured by the procedures specifed in §63.457(d).

(d) Each bypass line in the closed-vent system that could divert vent streams containing HAP to the atmosphere without meeting the emission limitations in §§63.443, 63.444, or 63.445 shall comply with either of the following requirements:

(1) On each bypass line, the owner or operator shall install, calibrate, maintain, and operate according to the manufacturer's specifications a flow indicator that is capable of taking periodic readings as frequently as specified in §63.454(e). The flow indicator shall be installed in the bypass line in such a way as to indicate flow in the bypass line; or

(2) For bypass line valves that are not computer controlled, the owner or operator shall maintain the

bypass line valve in the closed position with a car seal or a seal placed on the valve or closure mechanism in such a way that valve or closure mechanism cannot be opened without breaking the seal.

[63 FR 18617, Apr. 15, 1998, as amended at 64 FR 17563, Apr. 12, 1999; 68 FR 37348, June 23, 2003]

§§ 63.451-63.452 [Reserved]

§ 63.453 Monitoring requirements.

(a) Each owner or operator subject to the standards specifed in §§63.443(c) and (d), 63.444(b) and (c), 63.445(b) and (c), 63.446(c), (d), and (e), 63.447(b) or §63.450(d), shall install, calibrate, certify, operate, and maintain according to the manufacturer's specifications, a continuous monitoring system (CMS, as defined in §63.2 of this part) as specified in paragraphs (b) through (m) of this section, except as allowed in paragraph (m) of this section. The CMS shall include a continuous recorder.

(b) A CMS shall be operated to measure the temperature in the firebox or in the ductwork immediately downstream of the firebox and before any substantial heat exchange occurs for each thermal oxidizer used to comply with the requirements of §63.443(d)(1) through (d)(3). Owners and operators complying with the HAP concentration requirements in §63.443(d)(2) may install a CMS to monitor the thermal oxidizer outlet total HAP or methanol concentration, as an alternative to monitoring thermal oxidizer operating temperature.

(c) A CMS shall be operated to measure the following parameters for each gas scrubber used to comply with the bleaching system requirements of §63.445(c) or the sulfite pulping system requirements of §63.444(c).

(1) The pH or the oxidation/reduction potential of the gas scrubber effluent;

(2) The gas scrubber vent gas inlet flow rate; and

(3) The gas scrubber liquid infuent flow rate.

(d) As an option to the requirements specified in paragraph (c) of this section, a CMS shall be operated to measure the chlorine outlet concentration of each gas scrubber used to comply with the bleaching system outlet concentration requirement specified in §63.445(c)(2).

(e) The owner or operator of a bleaching system complying with 40 CFR 430.24, shall monitor the chlorine and hypochlorite application rates, in kg of bleaching agent per megagram of ODP, of the bleaching system during the extended compliance period specifed in §63.440(d)(3).

(f) A CMS shall be operated to measure the gas scrubber parameters specified in paragraphs (c)(1) through (c)(3) of this section or those site specific parameters determined according to the procedures specified in paragraph (n) of this section to comply with the sulfite pulping system requirements specified in §63.444(c).

(g) A CMS shall be operated to measure the following parameters for each steam stripper used to comply with the treatment requirements in §63.446(e) (3), (4), or (5):

(1) The process wastewater feed rate;

(2) The steam feed rate; and

(3) The process wastewater column feed temperature.

(h) As an option to the requirements specified in paragraph (g) of this section, a CMS shall be operated to measure the methanol outlet concentration to comply with the steam stripper outlet concentration requirement specified in §63.446 (e)(4) or (e)(5).

(i) A CMS shall be operated to measure the appropriate parameters determined according to the procedures specifed in paragraph (n) of this section to comply with the condensate applicability requirements specified in §63.446(c).

(j) Each owner or operator using an open biological treatment system to comply with §63.446(e)(2) shall perform the daily monitoring procedures specified in either paragraph (j)(1) or (2) of this section and shall conduct a performance test each quarter using the procedures specified in paragraph (j)(3) of this section.

(1) Comply with the monitoring and sampling requirements specified in paragraphs (j)(1)(i) and (ii) of this section.

(i) On a daily basis, monitor the following parameters for each open biological treatment unit:

(A) Composite daily sample of outlet soluble BOD_5 concentration to monitor for maximum daily and maximum monthly average;

(B) Mixed liquor volatile suspended solids;

(C) Horsepower of aerator unit(s);

(D) Inlet liquid flow; and

(E) Liquid temperature.

(ii) If the Inlet and Outlet Concentration Measurement Procedure (Procedure 3) in appendix C of this part is used to determine the fraction of HAP compounds degraded in the biological treatment system as specified in §63.457(l), conduct the sampling and archival requirements specified in paragraphs (j)(1)(ii)(A) and (B) of this section.

(A) Obtain daily inlet and outlet liquid grab samples from each biological treatment unit to have HAP data available to perform quarterly performance tests specified in paragraph (j)(3) of this section and the compliance tests specified in paragraph (p) of this section.

(B) Store the samples as specified in §63.457(n) until after the results of the soluble BOD_5 test required in paragraph (j)(1)(i)(A) of this section are obtained. The storage requirement is needed since the soluble BOD_5 test requires 5 days or more to obtain results. If the results of the soluble BOD_5 test are outside of the range established during the initial performance test, then the archive sample shall be used to perform the mass removal or percent reduction determinations.

(2) As an alternative to the monitoring requirements of paragraph (j)(1) of this section, conduct daily monitoring of the site-specific parameters established according to the procedures specified in paragraph (n) of this section.

(3) Conduct a performance test as specified in §63.457(l) within 45 days after the beginning of each quarter and meet the applicable emission limit in §63.446(e)(2).

(i) The performance test conducted in the first quarter (annually) shall be performed for total HAP as specified in §63.457(g) and meet the percent reduction or mass removal emission limit specified in §63.446(e)(2).

(ii) The remaining quarterly performance tests shall be performed as specified in paragraph (j)(3)(i) of this section except owners or operators may use the applicable methanol procedure in §63.457(l)(1) or (2) and the value of r determined during the first quarter test instead of measuring the additional HAP to determine a new value of r.

(k) Each enclosure and closed-vent system used to comply with §63.450(a) shall comply with the requirements specified in paragraphs (k)(1) through (k)(6) of this section.

(1) For each enclosure opening, a visual inspection of the closure mechanism specified in §63.450(b) shall be performed at least once every 30 days to ensure the opening is maintained in the closed position and sealed.

(2) Each closed-vent system required by §63.450(a) shall be visually inspected every 30 days and at other times as requested by the Administrator. The visual inspection shall include inspection of ductwork, piping, enclosures, and connections to covers for visible evidence of defects.

(3) For positive pressure closed-vent systems or portions of closed-vent systems, demonstrate no detectable leaks as specifed in §63.450(c) measured initially and annually by the procedures in §63.457 (d).

(4) Demonstrate initially and annually that each enclosure opening is maintained at negative pressure as specified in §63.457(e).

(5) The valve or closure mechanism specified in §63.450(d)(2) shall be inspected at least once every 30 days to ensure that the valve is maintained in the closed position and the emission point gas stream is not diverted through the bypass line.

(6) If an inspection required by paragraphs (k)(1) through (k)(5) ofthis section identifies visible defects in ductwork, piping, enclosures or connections to covers required by §63.450, or if an instrument reading of 500 parts per million by volume or greater above background is measured, or if enclosure openings are not maintained at negative pressure, then the following corrective actions shall be taken as soon as practicable.

(i) A first effort to repair or correct the closed-vent system shall be made as soon as practicable but no later than 5 calendar days after the problem is identified.

(ii) The repair or corrective action shall be completed no later than 15 calendar days after the problem is identified. Delay of repair or corrective action is allowed if the repair or corrective action is technically infeasible without a process unit shutdown or if the owner or operator determines that the emissions resulting from immediate repair would be greater than the emissions likely to result from delay of repair. Repair of such equipment shall be completed by the end of the next process unit shutdown.

(l) Each pulping process condensate closed collection system used to comply with §63.446(d) shall comply with the requirements specified in paragraphs (l)(1) through (l)(3) ofthis section.

(1) Each pulping process condensate closed collection system shall be visually inspected every 30 days and shall comply with the inspection and monitoring requirements specified in §63.964 of subpart RR of this part, except:

(i) Owners or operators shall comply with the recordkeeping requirements of §63.454 instead of the requirements specified in §63.964(a)(1)(vi) and (b)(3) of subpart RR of this part.

(ii) Owners or operators shall comply with the inspection and monitoring requirements for closed-vent systems and control devices specified in paragraphs (a) and (k) ofthis section instead ofthe requirements specified in §63.964(a)(2) of subpart RR of this part.

(2) Each condensate tank used in the closed collection system shall be operated with no detectable leaks as specified in §63.446(d)(2)(i) measured initially and annually by the procedures specified in §63.457(d).

(3) If an inspection required by this section identifies visible defects in the closed collection system, or if an instrument reading of 500 parts per million or greater above background is measured, then corrective actions specified in §63.964(b) of subpart RR of this part shall be taken.

(m) Each owner or operator using a control device, technique or an alternative parameter other than those specified in paragraphs (b) through (l) of this section shall install a CMS and establish appropriate operating parameters to be monitored that demonstrate, to the Administrator's satisfaction, continuous compliance with the applicable control requirements.

(n) To establish or reestablish the value for each operating parameter required to be monitored under paragraphs (b) through (j), (l), and (m) of this section or to establish appropriate parameters for paragraphs (f), (i), (j)(2), and (m) of this section, each owner or operator shall use the following procedures:

(1) During the initial performance test required in §63.457(a) or any subsequent performance test, continuously record the operating parameter;

(2) Determinations shall be based on the control performance and parameter data monitored during the performance test, supplemented if necessary by engineering assessments and the manufacturer's

recommendations;

(3) The owner or operator shall provide for the Administrator's approval the rationale for selecting the monitoring parameters necessary to comply with paragraphs (f), (i), and (m) of this section; and

(4) Provide for the Administrator's approval the rationale for the selected operating parameter value, and monitoring frequency, and averaging time. Include all data and calculations used to develop the value and a description of why the value, monitoring frequency, and averaging time demonstrate continuous compliance with the applicable emission standard.

(o) Each owner or operator of a control device subject to the monitoring provisions of this section shall operate the control device in a manner consistent with the minimum or maximum (as appropriate) operating parameter value or procedure required to be monitored under paragraphs (a) through (n) of this section and established under this subpart. Except as provided in paragraph (p) of this section, §63.443(e), or §63.446(g), operation of the control device below minimum operating parameter values or above maximum operating parameter values established under this subpart or failure to perform procedures required by this subpart shall constitute a violation of the applicable emission standard of this subpart and be reported as a period of excess emissions.

(p) The procedures of this paragraph apply to each owner or operator of an open biological treatment system complying with paragraph (j) of this section whenever a monitoring parameter excursion occurs, and the owner or operator chooses to conduct a performance test to demonstrate compliance with the applicable emission limit. A monitoring parameter excursion occurs whenever the monitoring parameters specified in paragraphs (j)(1)(i)(A) through (C) of this section or any of the monitoring parameters specified in paragraph (j)(2) of this section are below minimum operating parameter values or above maximum operating parameter values established in paragraph (n) of this section.

(1) As soon as practical after the beginning of the monitoring parameter excursion, the following requirements shall be met:

(i) Before the steps in paragraph (p)(1)(ii) or (iii) of this section are performed, all sampling and measurements necessary to meet the requirements in paragraph (p)(2) of this section shall be conducted.

(ii) Steps shall be taken to repair or adjust the operation of the process to end the parameter excursion period.

(iii) Steps shall be taken to minimize total HAP emissions to the atmosphere during the parameter excursion period.

(2) A parameter excursion is not a violation of the applicable emission standard if the results of the performance test conducted using the procedures in this paragraph demonstrate compliance with the applicable emission limit in §63.446(e)(2).

(i) Conduct a performance test as specified in §63.457 using the monitoring data specified in paragraph (j)(1) or (2) of this section that coincides with the time of the parameter excursion. No maintenance or changes shall be made to the open biological treatment system after the beginning of a parameter excursion that would influence the results of the performance test.

(ii) If the results of the performance test specified in paragraph (p)(2)(i) of this section demonstrate compliance with the applicable emission limit in §63.446(e)(2), then the parameter excursion is not a violation of the applicable emission limit.

(iii) If the results of the performance test specified in paragraph (p)(2)(i) of this section do not demonstrate compliance with the applicable emission limit in §63.446(e)(2) because the total HAP mass entering the open biological treatment system is below the level needed to demonstrate compliance with the applicable emission limit in §63.446(e)(2), then the owner or operator shall perform the following comparisons:

(A) If the value of f_{bio}(MeOH) determined during the performance test specified in paragraph (p)(2)(i) of this section is within the range of values established during the initial and subsequent performance tests approved by the Administrator, then the parameter excursion is not a violation of the applicable standard.

(B) If the value of f_{bio}(MeOH) determined during the performance test specified in paragraph (p)(2)(i) of this section is not within the range of values established during the initial and subsequent performance tests approved by the Administrator, then the parameter excursion is a violation of the applicable standard.

(iv) The results of the performance test specified in paragraph (p)(2)(i) of this section shall be recorded as specified in §63.454(f).

(3) If an owner or operator determines that performing the required procedures under paragraph (p)(2) of this section for a nonthoroughly mixed open biological system would expose a worker to dangerous, hazardous, or otherwise unsafe conditions, all of the following procedures shall be performed:

(i) Calculate the mass removal or percent reduction value using the procedures specified in §63.457(l) except the value for f_{bio}(MeOH) shall be determined using the procedures in appendix E to this part.

(ii) Repeat the procedures in paragraph (p)(3)(i) of this section for every day until the unsafe conditions have passed.

(iii) A parameter excursion is a violation of the standard if the percent reduction or mass removal determined in paragraph (p)(3)(i) of this section is less than the percent reduction or mass removal standards specified in §63.446(e)(2), as appropriate, unless the value of f_{bio}(MeOH) determined using the procedures in appendix E of this section, as specified in paragraph (p)(3)(i), is within the range of f_{bio} (MeOH) values established during the initial and subsequent performance tests previously approved by the Administrator.

(iv) The determination that there is a condition that exposes a worker to dangerous, hazardous, or otherwise unsafe conditions shall be documented according to requirements in §63.454(e) and reporting in §63.455(f).

(v) The requirements of paragraphs (p)(1) and (2) of this section shall be performed and met as soon as practical but no later than 24 hours after the conditions have passed that exposed a worker to dangerous, hazardous, or otherwise unsafe conditions.

[63 FR 18617, Apr. 15, 1998, as amended at 64 FR 17563, Apr. 12, 1999; 65 FR 80762, Dec. 22, 2000]

§ 63.454 Recordkeeping requirements.

(a) The owner or operator of each affected source subject to the requirements of this subpart shall comply with the recordkeeping requirements of §63.10, as shown in table 1 of this subpart, and the requirements specified in paragraphs (b) through (f) of this section for the monitoring parameters specified in §63.453.

(b) For each applicable enclosure opening, closed-vent system, and closed collection system, the owner or operator shall prepare and maintain a site-specific inspection plan including a drawing or schematic of the components of applicable affected equipment and shall record the following information for each inspection:

(1) Date of inspection;

(2) The equipment type and identification;

(3) Results of negative pressure tests for enclosures;

(4) Results of leak detection tests;

(5) The nature of the defect or leak and the method of detection (i.e., visual inspection or instrument detection);

(6) The date the defect or leak was detected and the date of each attempt to repair the defect or leak;

(7) Repair methods applied in each attempt to repair the defect or leak;

(8) The reason for the delay if the defect or leak is not repaired within 15 days after discovery;

(9) The expected date of successful repair of the defect or leak if the repair is not completed within 15 days;

(10) The date of successful repair of the defect or leak;

(11) The position and duration of opening of bypass line valves and the condition of any valve seals; and

(12) The duration of the use of bypass valves on computer controlled valves.

(c) The owner or operator of a bleaching system complying with §63.440(d)(3)(ii)(B) shall record the daily average chlorine and hypochlorite application rates, in kg of bleaching agent per megagram of ODP, of the bleaching system until the requirements specified in §63.440(d)(3)(ii)(A) are met.

(d) The owner or operator shall record the CMS parameters specified in §63.453 and meet the requirements specified in paragraph (a) of this section for any new affected process equipment or pulping process condensate stream that becomes subject to the standards in this subpart due to a process change or modification.

(e) The owner or operator shall set the flow indicator on each bypass line specified in §63.450(d)(1) to provide a record of the presence of gas stream flow in the bypass line at least once every 15 minutes.

(f) The owner or operator of an open biological treatment system complying with §63.453(p) shall prepare a written record specifying the results of the performance test specified in §63.453(p)(2).

[63 FR 18617, Apr. 15, 1998, as amended at 65 FR 80763, Dec. 22, 2000; 68 FR 37348, June 23, 2003]

§ 63.455 Reporting requirements.

(a) Each owner or operator of a source subject to this subpart shall comply with the reporting requirements of subpart A of this part as specified in table 1 and all the following requirements in this section. The initial notification report specified under §63.9(b)(2) of subpart A of this part shall be submitted by April 15, 1999.

(b) Each owner or operator of a kraft pulping system specified in §63.440(d)(1) or a bleaching system specified in §63.440(d)(3)(ii) shall submit, with the initial notification report specified under §63.9(b)(2) of subpart A of this part and paragraph (a) of this section and update every two years thereafter, a non-binding control strategy report containing, at a minimum, the information specified in paragraphs (b)(1) through (b)(3) of this section in addition to the information required in §63.9(b)(2) of subpart A of this part.

(1) A description of the emission controls or process modifications selected for compliance with the control requirements in this standard.

(2) A compliance schedule, including the dates by which each step toward compliance will be reached for each emission point or sets of emission points. At a minimum, the list of dates shall include:

(i) The date by which the major study(s) for determining the compliance strategy will be completed;

(ii) The date by which contracts for emission controls or process modifications will be awarded, or the date by which orders will be issued for the purchase of major components to accomplish emission controls or process changes;

(iii) The date by which on-site construction, installation of emission control equipment, or a process change is to be initiated;

(iv) The date by which on-site construction, installation of emissions control equipment, or a process change is to be completed;

(v) The date by which final compliance is to be achieved;

(vi) For compliance with paragraph §63.440(d)(3)(ii), the tentative dates by which compliance with effluent limitation guidelines and standards intermediate pollutant load effluent reductions and as available, all the dates for the best available technology's milestones reported in the National Pollutant Discharge Elimination System authorized under section 402 of the Clean Water Act and for the best professional milestones in the Voluntary Advanced Technology Incentives Program under 40 CFR 430.24 (b)(2); and

(vii) The date by which the final compliance tests will be performed.

(3) Until compliance is achieved, revisions or updates shall be made to the control strategy report required by paragraph (b) of this section indicating the progress made towards completing the installation of the emission controls or process modifications during the 2-year period.

(c) The owner or operator of each bleaching system complying with §63.440(d)(3)(ii)(B) shall certify in the report specified under §63.10(e)(3) of subpart A of this part that the daily application rates of chlorine and hypochlorite for that bleaching system have not increased as specified in §63.440(d)(3)(ii)(B) until the requirements of §63.440(d)(3)(ii)(A) are met.

(d) The owner or operator shall meet the requirements specified in paragraph (a) of this section upon startup of any new affected process equipment or pulping process condensate stream that becomes subject to the standards of this subpart due to a process change or modification.

(e) If the owner or operator uses the results of the performance test required in §63.453(p)(2) to revise the approved values or ranges of the monitoring parameters specified in §63.453(j)(1) or (2), the owner or operator shall submit an initial notification of the subsequent performance test to the Administrator as soon as practicable, but no later than 15 days, before the performance test required in §63.453(p)(2) is scheduled to be conducted. The owner or operator shall notify the Administrator as soon as practicable, but no later than 24 hours, before the performance test is scheduled to be conducted to confirm the exact date and time of the performance test.

(f) To comply with the open biological treatment system monitoring provisions of §63.453(p)(3), the owner or operator shall notify the Administrator as soon as practicable of the onset of the dangerous, hazardous, or otherwise unsafe conditions that did not allow a compliance determination to be conducted using the sampling and test procedures in §63.457(l). The notification shall occur no later than 24 hours after the onset of the dangerous, hazardous, or otherwise unsafe conditions and shall include the specific reason(s) that the sampling and test procedures in §63.457(l) could not be performed.

[63 FR 18617, Apr. 15, 1998, as amended at 65 FR 80763, Dec. 22, 2000]

§ 63.456 [Reserved]

§ 63.457 Test methods and procedures.

(a) *Initial performance test.* An initial performance test is required for all emission sources subject to the limitations in §§63.443, 63.444, 63.445, 63.446, and 63.447, except those controlled by a combustion device that is designed and operated as specified in §63.443(d)(3) or (d)(4).

(b) *Vent sampling port locations and gas stream properties.* For purposes of selecting vent sampling port locations and determining vent gas stream properties, required in §§63.443, 63444, 63.445, and 63.447, each owner or operator shall comply with the applicable procedures in paragraphs (b)(1) through (b)(6) of this section.

(1) Method 1 or 1A of part 60, appendix A, as appropriate, shall be used for selection of the sampling site as follows:

(i) To sample for vent gas concentrations and volumetric flow rates, the sampling site shall be located prior to dilution of the vent gas stream and prior to release to the atmosphere;

(ii) For determining compliance with percent reduction requirements, sampling sites shall be located prior to the inlet of the control device and at the outlet of the control device; measurements shall be performed simultaneously at the two sampling sites; and

(iii) For determining compliance with concentration limits or mass emission rate limits, the sampling site shall be located at the outlet of the control device.

(2) No traverse site selection method is needed for vents smaller than 0.10 meter (4.0 inches) in diameter.

(3) The vent gas volumetric flow rate shall be determined using Method 2, 2A, 2C, or 2D of part 60, appendix A, as appropriate.

(4) The moisture content of the vent gas shall be measured using Method 4 of part 60, appendix A.

(5) To determine vent gas concentrations, the owner or operator shall conduct a minimum of three test runs that are representative of normal conditions and average the resulting pollutant concentrations using the following procedures.

(i) Method 308 in Aappendix A of this part shall be used to determine the methanol concentration.

(ii) Except for the modifications specified in paragraphs (b)(5)(ii)(A) through (b)(5)(ii)(K) of this section, Method 26A of part 60, appendix A shall be used to determine chlorine concentration in the vent stream.

(A) *Probe/sampling line.* A separate probe is not required. The sampling line shall be an appropriate length of 0.64 cm (0.25 in) OD Teflon®tubing. The sample inlet end of the sampling line shall be inserted into the stack in such a way as to not entrain liquid condensation fom the vent gases. The other end shall be connected to the impingers. The length of the tubing may vary from one sampling site to another, but shall be as short as possible in each situation. If sampling is conducted in sunlight, opaque tubing shall be used. Alternatively, if transparent tubing is used, it shall be covered with opaque tape.

(B) *Impinger train.* Three 30 milliliter (ml) capacity midget impingers shall be connected in series to the sampling line. The impingers shall have regular tapered stems. Silica gel shall be placed in the third impinger as a desiccant. All impinger train connectors shall be glass and/or Teflon®.

(C) *Critical orifice.* The critical orifice shall have a flow rate of 200 to 250 ml/min and shall be followed by a vacuum pump capable of providing a vacuum of 640 millimeters of mercury (mm Hg). A 45 millimeter diameter in-line Teflon 0.8 micrometer filter shall follow the impingers to protect the critical orifce and vacuum pump.

(D) The following are necessary for the analysis apparatus:

(*1*) Wash bottle filled with deionized water;

(*2*) 25 or 50 ml graduated burette and stand;

(*3*) Magnetic stirring apparatus and stir bar;

(*4*) Calibrated pH Meter;

(*5*) 150–250 ml beaker or flask; and

(*6*) A 5 ml pipette.

(E) The procedures listed in paragraphs (b)(5)(ii)(E)(*1*) through (b)(5)(ii)(E)(7) of this section shall be used to prepare the reagents.

(*1*) To prepare the 1 molarity (M) potassium dihydrogen phosphate solution, dissolve 13.61 grams (g) of potassium dihydrogen phosphate in water and dilute to 100 ml.

(*2*) To prepare the 1 M sodium hydroxide solution (NaOH), dissolve 4.0 g of sodium hydroxide in water and dilute to 100 ml.

(*3*) To prepare the buffered 2 percent potassium iodide solution, dissolve 20 g of potassium iodide in 900 ml water. Add 50 ml of the 1 M potassium dihydrogen phosphate solution and 30 ml of the 1 M

sodium hydroxide solution. While stirring solution, measure the pH of solution electrometrically and add the 1 M sodium hydroxide solution to bring pH to between 6.95 and 7.05.

(*4*) To prepare the 0.1 normality (N) sodium thiosulfate solution, dissolve 25 g of sodium thiosulfate, pentahydrate, in 800 ml of freshly boiled and cooled distilled water in a 1-liter volumetric flask. Dilute to volume. To prepare the 0.01 N sodium thiosulfate solution, add 10.0 ml standardized 0.1 N sodium thiosulfate solution to a 100 ml volumetric flask, and dilute to volume with water.

(*5*) To standardize the 0.1 N sodium thiosulfate solution, dissolve 3.249 g of anhydrous potassium bi-iodate, primary standard quality, or 3.567 g potassium iodate dried at 103 =/-2 degrees Centigrade for 1 hour, in distilled water and dilute to 1000 ml to yield a 0.1000 N solution. Store in a glass-stoppered bottle. To 80 ml distilled water, add, with constant stirring, 1 ml concentrated sulfuric acid, 10.00 ml 0.1000 N anhydrous potassium bi-iodate, and 1 g potassium iodide. Titrate immediately with 0.1 n sodium thiosulfate titrant until the yellow color of the liberated iodine is almost discharged. Add 1 ml starch indicator solution and continue titrating until the blue color disappears. The normality of the sodium thiosulfate solution is inversely proportional to the ml of sodium thiosulfate solution consumed:

$$\text{Normality of } \textit{Sodium Thiosulfate} = \frac{1}{\text{ml Sodium Thiosulfate Consumed}}$$

(*6*) To prepare the starch indicator solution, add a small amount of cold water to 5 g starch and grind in a mortar to obtain a thin paste. Pour paste into 1 L of boiling distilled water, stir, and let settle overnight. Use clear supernate for starch indicator solution.

(*7*) To prepare the 10 percent sulfuric acid solution, add 10 ml of concentrated sulfuric acid to 80 ml water in a 100 ml volumetric flask. Dilute to volume.

(F) The procedures specifed in paragraphs (b)(5)(ii)(F)(*1*) through (b)(5)(ii)(F)(*5*) of this section shall be used to perform the sampling.

(*1*) *Preparation of collection train* Measure 20 ml buffered potassium iodide solution into each of the first two impingers and connect probe, impingers, filter, critical orifice, and pump. The sampling line and the impingers shall be shielded from sunlight.

(*2*) *Leak and flow check procedure.* Plug sampling line inlet tip and turn on pump. If a flow of bubbles is visible in either of the liquid impingers, tighten fittings and adjust connections and impingers. A leakage rate not in excess of 2 percent of the sampling rate is acceptable. Carefully remove the plug from the end of the probe. Check the flow rate at the probe inlet with a bubble tube flow meter. The flow should be comparable or slightly less than the flow rate of the critical orifice with the impingers off-line. Record the flow and turn off the pump.

(*3*) *Sample collection.* Insert the sampling line into the stack and secure it with the tip slightly lower than the port height. Start the pump, recording the time. End the sampling after 60 minutes, or after yellow color is observed in the second in-line impinger. Record time and remove the tubing from the vent. Recheck flow rate at sampling line inlet and turn off pump. If the flow rate has changed significantly, redo sampling with fresh capture solution. A slight variation (less than 5 percent) in fow may be averaged. With the inlet end of the line elevated above the impingers, add about 5 ml water into the inlet tip to rinse the line into the first impinger.

(*4*) *Sample analysis.* Fill the burette with 0.01 N sodium thiosulfate solution to the zero mark. Combine the contents of the impingers in the beaker or flask. Stir the solution and titrate with thiosulfate until the solution is colorless. Record the volume of the first endpoint (TN, ml). Add 5 ml of the 10 percent sulfuric acid solution, and continue the titration until the contents of the flask are again colorless. Record the total volume of titrant required to go through the first and to the second endpoint (TA, ml). If the volume of neutral titer is less than 0.5 ml, repeat the testing for a longer period of time. It is important that sufficient lighting be present to clearly see the endpoints, which are determined when the solution turns from pale yellow to colorless. A lighted stirring plate and a white background are useful for this purpose.

(*5*) *Interferences.* Known interfering agents of this method are sulfur dioxide and hydrogen peroxide. Sulfur dioxide, which is used to reduce oxidant residuals in some bleaching systems, reduces formed iodine to iodide in the capture solution. It is therefore a negative interference for chlorine, and in some cases could result in erroneous negative chlorine concentrations. Any agent capable of reducing iodine to iodide could interfere in this manner. A chromium trioxide impregnated filter will capture sulfur dioxide

and pass chlorine and chlorine dioxide. Hydrogen peroxide, which is commonly used as a bleaching agent in modern bleaching systems, reacts with iodide to form iodine and thus can cause a positive interference in the chlorine measurement. Due to the chemistry involved, the precision of the chlorine analysis will decrease as the ratio of chlorine dioxide to chlorine increases. Slightly negative calculated concentrations of chlorine may occur when sampling a vent gas with high concentrations of chlorine dioxide and very low concentrations of chlorine.

(G) The following calculation shall be performed to determine the corrected sampling flow rate:

$$S_C = S_U \left(\frac{BP - PW}{760} \right) \left(\frac{293}{273 + t} \right)$$

Where:

S_C=Corrected (dry standard) sampling flow rate, liters per minute;

S_U=Uncorrected sampling flow rate, L/min;

BP=Barometric pressure at time of sampling;

PW=Saturated partial pressure of water vapor, mm Hg at temperature; and

t=Ambient temperature, °C.

(H) The following calculation shall be performed to determine the moles of chlorine in the sample:

$$Cl_2 Moles = 1/8000 \left(5\, T_N - T_A \right) \times N_{Thio}$$

Where:

T_N=Volume neutral titer, ml;

T_A=Volume acid titer (total), ml; and

N_{Thio}=Normality of sodium thiosulfate titrant.

(I) The following calculation shall be performed to determine the concentration of chlorine in the sample:

$$Cl_2 ppmv = \frac{3005 \left(5\, T_N - T_A \right) \times N_{Thio}}{S_C \times t_S}$$

Where:

S_C=Corrected (dry standard) sampling flow rate, liters per minute;

t_S=Time sampled, minutes;

T_N=Volume neutral titer, ml;

T_A=Volume acid titer (total), ml; and

N_{Thio}=Normality of sodium thiosulfate titrant.

(J) The following calculation shall be performed to determine the moles of chlorine dioxide in the sample:

$$ClO_2\ Moles = 1/4000(T_A - T_N) \times N_{Thio}$$

Where:

T_A=Volume acid titer (total), ml;

T_N=Volume neutral titer, ml; and

N_{Thio}=Normality of sodium thiosulfate titrant.

(K) The following calculation shall be performed to determine the concentration ofchlorine dioxide in the sample:

$$ClO_2\ ppmv = \frac{6010(T_A - T_N) \times N_{Thio}}{S_C \times t_S}$$

Where:

S_C=Corrected (dry standard) sampling flow rate, liters per minute;

t_S=Time sampled, minutes;

T_A=Volume acid titer (total), ml;

T_N=Volume neutral titer, ml; and

N_{Thio}=Normality of sodium thiosulfate titrant.

(iii) Any other method that measures the total HAP or methanol concentration that has been demonstrated to the Administrator's satisfaction.

(6) The minimum sampling time for each of the three test runs shall be 1 hour in which either an integrated sample or four grab samples shall be taken. If grab sampling is used, then the samples shall be taken at approximately equal intervals in time, such as 15 minute intervals during the test run.

(c) *Liquid sampling locations and properties.* For purposes of selecting liquid sampling locations and for determining properties of liquid streams such as wastewaters, process waters, and condensates required in §§63.444, 63.446, and 63.447, the owner or operator shall comply with the following procedures:

(1) Samples shall be collected using the sampling procedures of the test method listed in paragraph (c)(3) of this section selected to determine liquid stream HAP concentrations;

(i) Where feasible, samples shall be taken from an enclosed pipe prior to the liquid streambeing exposed to the atmosphere; and

(ii) When sampling from an enclosed pipe is not feasible, samples shall be collected in a manner to minimize exposure of the sample to the atmosphere and loss of HAP compounds prior to sampling.

(2) The volumetric flow rate of the entering and exiting liquid streams shall be determined using the inlet

and outlet flow meters or other methods demonstrated to the Administrator's satisfaction. The volumetric flow rate measurements to determine actual mass removal shall be taken at the same time as the concentration measurements.

(3) The owner or operator shall conduct a minimum of three test runs that are representative of normal conditions and average the resulting pollutant concentrations. The minimum sampling time for each test run shall be 1 hour and the grab or composite samples shall be taken at approximately equally spaced intervals over the 1-hour test run period. The owner or operator shall use one of the following procedures to determine total HAP or methanol concentration:

(i) Method 305 in Appendix A of this part, adjusted using the following equation:

$$\overline{C} = \sum_{i=1}^{n} C_i / fm_i$$

Where:

C=Pollutant concentration for the liquid stream, parts per million by weight.

C_i=Measured concentration of pollutant i in the liquid stream sample determined using Method 305, parts per million by weight.

fm_i=Pollutant-specific constant that adjusts concentration measured by Method 305 to actual liquid concentration; the fm for methanol is 0.85. Additional pollutant fm values can be found in table 34, subpart G of this part.

n=Number of individual pollutants, i, summed to calculate total HAP.

(ii) For determining methanol concentrations, NCASI Method DI/MEOH–94.02, Methanol in Process Liquids by GC/FID, August 1998, Methods Manual, NCASI, Research Triangle Park, NC. This test method is incorporated by reference in §63.14(f) of subpart A of this part.

(iii) Any other method that measures total HAP concentration that has been demonstrated to the Administrator's satisfaction.

(4) To determine soluble BOD_5 in the effluent stream from an open biological treatment unit used to comply with §§63.446(e)(2) and 63.453(j), the owner or operator shall use Method 405.1 of part 136 of this chapter with the following modifications:

(i) Filter the sample through the filter paper, into an Erlenmeyer flask by applying a vacuum to the flask sidearm. Minimize the time for which vacuum is applied to prevent stripping of volatile organics from the sample. Replace filter paper as often as needed in order to maintain filter times of less than approximately 30 seconds per filter paper. No rinsing of sample container or filter bowl into the Erlenmeyer flask is allowed.

(ii) Perform Method 405.1 on the filtrate obtained in paragraph (c)(4) of this section. Dilution water shall be seeded with 1 milliliter of final effluent per liter of dilution water. Dilution ratios may require adjustment to reflect the lower oxygen demand of the filtered sample in comparison to the total BOD_5. Three BOD bottles and different dilutions shall be used for each sample.

(5) If the test method used to determine HAP concentration indicates that a specific HAP is not detectable, the value determined as the minimum measurement level (MML) of the selected test method for the specific HAP shall be used in the compliance demonstration calculations. To determine the MML for a specific HAP using one of the test methods specified in paragraph (c)(3) of this section, one of the procedures specified in paragraphs (c)(5)(i) and (ii) of this section shall be performed. The MML for a particular HAP must be determined only if the HAP is not detected in the normal working range of the method.

(i) To determine the MML for a specific HAP, the following procedures shall be performed each time the method is set up. Set up is defined as the first time the analytical apparatus is placed in operation, after

any shut down of 6 months or more, or any time a major component of the analytical apparatus is replaced.

(A) Select a concentration value for the specific HAP in question to represent the MML. The value of the MML selected shall not be below the calibration standard of the selected test method.

(B) Measure the concentration of the specific HAP in a minimum of three replicate samples using the selected test method. All replicate samples shall be run through the entire analytical procedure. The samples must contain the specific HAP at the selected MML concentration and should be representative of the liquid streams to be analyzed in the compliance demonstration. Spiking of the liquid samples with a known concentration of the target HAP may be necessary to ensure that the HAP concentration in the three replicate samples is at the selected MML. The concentration of the HAP in the spiked sample must be within 50 percent of the proposed MML for the demonstration to be valid. As an alternative to spiking, a field sample above the MML may be diluted to produce a HAP concentration at the MML. To be a valid demonstration, the diluted sample must have a HAP concentration within 20 percent of the proposed MML, and the field sample must not be diluted by more than a factor of five.

(C) Calculate the relative standard deviation (RSD) and the upper confidence limit at the 95 percent confidence level using the measured HAP concentrations determined in paragraph (c)(5)(i)(B) of this section. If the upper confidence limit of the RSD is less than 30 percent, then the selected MML is acceptable. If the upper confidence limit of the RSD is greater than or equal to 30 percent, then the selected MML is too low, and the procedures specified in paragraphs (c)(5)(i)(A) through (C) of this section must be repeated.

(ii) Provide for the Administrator's approval the selected value of the MML for a specific HAP and the rationale for selecting the MML including all data and calculations used to determine the MML. The approved MML must be used in all applicable compliance demonstration calculations.

(6) When using the MML determined using the procedures in paragraph (c)(5)(ii) of this section or when using the MML determined using the procedures in paragraph (c)(5)(i), except during set up, the analytical laboratory conducting the analysis must perform and meet the following quality assurance procedures each time a set of samples is analyzed to determine compliance.

(i) Using the selected test method, analyze in triplicate the concentration of the specific HAP in a representative sample. The sample must contain the specific HAP at a concentration that is within a factor of two of the MML. If there are no samples in the set being analyzed that contain the specific HAP at an appropriate concentration, then a sample below the MML may be spiked to produce the appropriate concentration, or a sample at a higher level may be diluted. After spiking, the sample must contain the specific HAP within 50 percent of the MML. If dilution is used instead, the diluted sample must contain the specific HAP within 20 percent of the MML and must not be diluted by more than a factor of five.

(ii) Calculate the RSD using the measured HAP concentrations determined in paragraph (c)(6)(i) of this section. If the RSD is less than 20 percent, then the laboratory is performing acceptably.

(d) *Detectable leak procedures.* To measure detectable leaks for closed-vent systems as specified in §63.450 or for pulping process wastewater collection systems as specified in §63.446(d)(2)(i), the owner or operator shall comply with the following:

(1) Method 21, of part 60, appendix A; and

(2) The instrument specified in Method 21 shall be calibrated before use according to the procedures specified in Method 21 on each day that leak checks are performed. The following calibration gases shall be used:

(i) Zero air (less than 10 parts per million by volume of hydrocarbon in air); and

(ii) A mixture of methane or n-hexane and air at a concentration of approximately, but less than, 10,000 parts per million by volume methane or n-hexane.

(e) *Negative pressure procedures.* To demonstrate negative pressure at process equipment enclosure openings as specified in §63.450(b), the owner or operator shall use one of the following procedures:

(1) An anemometer to demonstrate flow into the enclosure opening;

(2) Measure the static pressure across the opening;

(3) Smoke tubes to demonstrate flow into the enclosure opening; or

(4) Any other industrial ventilation test method demonstrated to the Administrator's satisfaction.

(f) *HAP concentration measurements.* For purposes of complying with the requirements in §§63.443, 63.444, and 63.447, the owner or operator shall measure the total HAP concentration as one of the following:

(1) As the sum of all individual HAPs; or

(2) As methanol.

(g) *Condensate HAP concentration measurement.* For purposes of complying with the kraft pulping condensate requirements in §63.446, the owner or operator shall measure the total HAP concentration as methanol. For biological treatment systems complying with §63.446(e)(2), the owner or operator shall measure total HAP as acetaldehyde, methanol, methyl ethyl ketone, and propionaldehyde and follow the procedures in §63.457(l)(1) or (2).

(h) *Bleaching HAP concentration measurement.* For purposes of complying with the bleaching system requirements in §63.445, the owner or operator shall measure the total HAP concentration as the sum of all individual chlorinated HAPs or as chlorine.

(i) *Vent gas stream calculations.* To demonstrate compliance with the mass emission rate, mass emission rate per megagram of ODP, and percent reduction requirements for vent gas streams specified in §§63.443, 63.444, 63.445, and 63.447, the owner or operator shall use the following:

(1) The total HAP mass emission rate shall be calculated using the following equation:

$$E = K_2 \left[\sum_{j=1}^{n} C_j M_j \right] Q_s$$

Where:

E=Mass emission rate of total HAP from the sampled vent, kilograms per hour.

K_2=Constant, 2.494×10^{-6}(parts per million by volume)$^{-1}$(gram-mole per standard cubic meter) (kilogram/gram) (minutes/hour), where standard temperature for (gram-mole per standard cubic meter) is 20 °C.

C_j=Concentration on a dry basis of pollutant j in parts per million by volume as measured by the test methods specified in paragraph (b) of this section.

M_j=Molecular weight of pollutant j, gram/gram-mole.

Q_s=Vent gas stream flow rate (dry standard cubic meter per minute) at a temperature of 20 °C as indicated in paragraph (b) of this section.

n=Number of individual pollutants, i, summed to calculate total HAP.

(2) The total HAP mass emission rate per megagram of ODP shall be calculated using the following equation:

$$F = \frac{E}{P}$$

Where:

F=Mass emission rate of total HAP from the sampled vent, in kilograms per megagram of ODP.

E=Mass emission rate of total HAP from the sampled vent, in kilograms per hour determined as specified in paragraph (i)(1) of this section.

P=The production rate of pulp during the sampling period, in megagrams of ODP per hour.

(3) The total HAP percent reduction shall be calculated using the following equation:

$$R = \frac{E_i - E_o}{E_i}(100)$$

Where:

R=Efficiency of control device, percent.

Ei=Inlet mass emission rate of total HAP from the sampled vent, in kilograms of pollutant per hour, determined as specified in paragraph (i)(1) of this section.

E_o=Outlet mass emission rate of total HAP from the sampled vent, in kilograms of pollutant per hour, determined as specified in paragraph (i)(1) of this section.

(j) *Liquid stream calculations.* To demonstrate compliance with the mass flow rate, mass per megagram of ODP, and percent reduction requirements for liquid streams specified in §63.446, the owner or operator shall use the following:

(1) The mass flow rates of total HAP or methanol entering and exiting the treatment process shall be calculated using the following equations:

$$E_b = \frac{K}{n \times 10^6}\left(\sum_{i=1}^{n} V_{bi} C_{bi}\right)$$

$$E_a = \frac{K}{n \times 10^6}\left(\sum_{i=1}^{n} V_{ai} C_{ai}\right)$$

Where:

E_b=Mass flow rate of total HAP or methanol in the liquid stream entering the treatment process, kilograms per hour.

E_a=Mass flow rate of total HAP or methanol in the liquid exiting the treatment process, kilograms per hour.

K=Density of the liquid stream, kilograms per cubic meter.

V_{bi}=Volumetric flow rate of liquid stream entering the treatment process during each run i, cubic meters per hour, determined as specified in paragraph (c) of this section.

V_{ai}=Volumetric flow rate of liquid stream exiting the treatment process during each run i, cubic meters per hour, determined as specified in paragraph (c) of this section.

C_{bi}=Concentration of total HAP or methanol in the stream entering the treatment process during each run i, parts per million by weight, determined as specified in paragraph (c) of this section.

C_{ai}=Concentration of total HAP or methanol in the stream exiting the treatment process during each run i, parts per million by weight, determined as specified in paragraph (c) of this section.

n=Number of runs.

(2) The mass of total HAP or methanol per megagram ODP shall be calculated using the following equation:

$$F = \frac{E_a}{P}$$

Where:

F=Mass loading of total HAP or methanol in the sample, in kilograms per megagram of ODP.

E_a=Mass flow rate of total HAP or methanol in the wastewater stream in kilograms per hour as determined using the procedures in paragraph (j)(1) of this section.

P=The production rate of pulp during the sampling period in megagrams of ODP per hour.

(3) The percent reduction of total HAP across the applicable treatment process shall be calculated using the following equation:

$$R = \frac{E_b - E_a}{E_b} \times 100$$

Where:

R=Control efficiency of the treatment process, percent.

E_b=Mass flow rate of total HAP in the stream entering the treatment process, kilograms per hour, as determined in paragraph (j)(1) of this section.

E_a=Mass flow rate of total HAP in the stream exiting the treatment process, kilograms per hour, as determined in paragraph (j)(1) of this section.

(4) Compounds that meet the requirements specified in paragraphs (j)(4)(i) or (4)(ii) of this section are not required to be included in the mass flow rate, mass per megagram of ODP, or the mass percent reduction determinations.

(i) Compounds with concentrations at the point of determination that are below 1 part per million by weight; or

(ii) Compounds with concentrations at the point of determination that are below the lower detection limit where the lower detection limit is greater than 1 part per million by weight.

(k) *Oxygen concentration correction procedures.* To demonstrate compliance with the total HAP concentration limit of 20 ppmv in §63.443(d)(2), the concentration measured using the methods specified in paragraph (b)(5) of this section shall be corrected to 10 percent oxygen using the following procedures:

(1) The emission rate correction factor and excess air integrated sampling and analysis procedures of

Methods 3A or 3B of part 60, appendix A shall be used to determine the oxygen concentration. The samples shall be taken at the same time that the HAP samples are taken.

(2) The concentration corrected to 10 percent oxygen shall be computed using the following equation:

$$C_c = C_m \left(\frac{10.9}{20.9 - \%O_{2d}} \right)$$

Where:

C_c=Concentration of total HAP corrected to 10 percent oxygen, dry basis, parts per million by volume.

C_m=Concentration of total HAP dry basis, parts per million by volume, as specified in paragraph (b) of this section.

$\%0_{2d}$=Concentration of oxygen, dry basis, percent by volume.

(l) *Biological treatment system percent reduction and mass removal calculations.* To demonstrate compliance with the condensate treatment standards specifed in §63.446(e)(2) and the monitoring requirements specified in §63.453(j)(3) using a biological treatment system, the owner or operator shall use one of the procedures specified in paragraphs (1)(1) and (2) of this section. Owners or operators using a nonthoroughly mixed open biological treatment system shall also comply with paragraph (1)(3) of this section.

(1) *Percent reduction methand procedure.* For the purposes of complying with the condensate treatment requirements specified in §63.446(e)(2) and (3), the methanol percent reduction shal be calculated using the following equations:

$$R = \frac{f_{bio}(\mathrm{MeOH})}{(1 + 1.087(r))} * 100$$

$$r = \frac{F_{(nonmethanol)}}{F_{(methanol)}}$$

Where:

R = Percent destruction.

f_{bio}(MeOH) = The fraction of methanol removed in the biological treatment system. The site-specific biorate constants shall be determined using the appropriate procedures specified in appendix C of this part.

r = Ratio of the sum of acetaldehyde, methyl ethyl ketone, and propionaldehyde mass to methanol mass.

F(nonmethanol)= The sum of acetaldehyde, methyl ethyl ketone, and propionaldehyde mass flow rates (kg/Mg ODP) entering the biological treatment system determined using the procedures in paragraph (j)(2) of this section.

F(methanol)= The mass flow rate (kg/Mg ODP) of methanol entering the system determined using the procedures in paragraph (j)(2) of this section.

(2) *Mass removal methanol procedure* For the purposes of complying with the condensate treatment requirements specified in §63.446(e)(2) and (4), or §63.446(e)(2) and (5), the methanol mass removal

shall be calculated using the following equation:

$$F = F_b * \left(f_{bio}(MeOH) / \left(1 + 1.087(r)\right)\right)$$

Where:

F = Methanol mass removal (kg/Mg ODP).

F_b= Inlet mass flow rate of methanol (kg/Mg ODP) determined using the procedures in paragraph (j)(2) of this section.

f_{bio}(MeOH) = The fraction of methanol removed in the biological treatment system. The site-specific biorate constants shall be determined using the appropriate procedures specified in appendix C of this part.

r = Ratio of the sum of acetaldehyde, methyl ethyl ketone, and propionaldehyde mass to methanol mass determined using the procedures in paragraph (1) of this section.

(3) The owner or operator of a nonthoroughly mixed open biological treatment system using the monitoring requirements specified in §63.453(p)(3) shall follow the procedures specifed in section III.B.1 of appendix E of this part to determine the borate constant, Ks, and characterize the open biological treatment system during the initial and any subsequent performance tests.

(m) *Condensate segregation procedures.* The following procedures shall be used to demonstrate compliance with the condensate segregation requirements specified in §63.446(c).

(1) To demonstrate compliance with the percent mass requirements specified in §63.446(c)(2), the procedures specifed in paragraphs (m)(1)(i) through (iii) of this section shall be performed.

(i) Determine the total HAP mass of all condensates from each equipment system listed in §63.446 (b) (1) through (b)(3) using the procedures specified in paragraphs (c) and (j) of this section.

(ii) Multiply the total HAP mass determined in paragraph (m)(1)(i) of this section by 0.65 to determine the target HAP mass for the high-HAP fraction condensate stream or streams.

(iii) Compliance with the segregation requirements specified in §63.446(c)(2) is demonstrated if the condensate stream or streams from each equipment system listed in §63.446(b)(1) through (3) being treated as specified in §63.446(e) contain at least as much total HAP mass as the target total HAP mass determined in paragraph (m)(1)(ii) of this section.

(2) To demonstrate compliance with the percent mass requirements specified in §63.446(c)(3), the procedures specifed in paragraphs (m)(2)(i) through (ii) of this section shall be performed.

(i) Determine the total HAP mass contained in the high-HAP fraction condensates from each equipment system listed in §63.446(b)(1) through (b)(3) and the total condensates streams from the equipment systems listed in §63.446(b)(4) and (b)(5), using the procedures specifed in paragraphs (c) and (j) of this section.

(ii) Compliance with the segregation requirements specified in §63.446(c)(3) is demonstrated if the total HAP mass determined in paragraph (m)(2)(i) of this section is equal to or greater than the appropriate mass requirements specified in §63.446(c)(3).

(n) *Open biological treatment system monitoring sampling storage.* The inlet and outlet grab samples required to be collected in §63.453(j)(1)(ii) shall be stored at 4 °C (40 °F) to minimize the biodegradation of the organic compounds in the samples.

[63 FR 18617, Apr. 15, 1998, as amended at 64 FR 17564, Apr. 12, 1999; 65 FR 80763, Dec. 22, 2000; 66 FR 24269, May 14, 2001]

§ 63.458 Implementation and enforcement.

(a) This subpart can be implemented and enforced by the U.S. EPA, or a delegated authority such as the applicable State, local, or Tribal agency. If the U.S. EPA Administrator has delegated authority to a State, local, or Tribal agency, then that agency, in addition to the U.S. EPA, has the authority to implement and enforce this subpart. Contact the applicable U.S. EPA Regional Office to find out if this subpart is delegated to a State, local, or Tribal agency.

(b) In delegating implementation and enforcement authority of this subpart to a State, local, or Tribal agency under subpart E of this part, the authorities contained in paragraph (c) of this section are retained by the Administrator of U.S. EPA and cannot be transferred to the State, local, or Tribal agency.

(c) The authorities that cannot be delegated to State, local, or Tribal agencies are as specified in paragraphs (c)(1) through (4) of this section.

(1) Approval of alternatives to the requirements in §§63.440, 63.443 through 63.447 and 63.450. Where these standards reference another subpart, the cited provisions will be delegated according to the delegation provisions of the referenced subpart.

(2) Approval of alternatives to using §§63.457(b)(5)(iii), 63.457(c)(3)(ii) through (iii), and 63.257(c)(5)(ii), and any major alternatives to test methods under §63.7(e)(2)(ii) and (f), as defined in §63.90, and as required in this subpart.

(3) Approval of alternatives using §64.453(m) and any major alternatives to monitoring under §63.8(f), as defined in §63.90, and as required in this subpart.

(4) Approval of major alternatives to recordkeeping and reporting under §63.10(f), as defined in §63.90, and as required in this subpart.

[68 FR 37348, June 23, 2003]

§ 63.459 Alternative standards.

(a) *Flint River Mill.* The owner or operator of the pulping system using the kraft process at the manufacturing facility, commonly called Weyerhaeuser Company Flint River Operations, at Old Stagecoach Road, Oglethorpe, Georgia, (hereafter the Site) shall comply with all provisions of this subpart, except as specified in paragraphs (a)(1) through (a)(5) of this section.

(1) The owner or operator of the pulping system is not required to control total HAP emissions from equipment systems specified in paragraphs (a)(1)(i) and (a)(1)(ii) if the owner or operator complies with paragraphs (a)(2) through (a)(5) of this section.

(i) The brownstock diffusion washer vent and first stage brownstock diffusion washer filtrate tank vent in the pulp washing system specified in §63.443(a)(1)(iii).

(ii) The oxygen delignification system specified in §63.443(a)(1)(v).

(2) The owner or operator of the pulping system shall control total HAP emissions from equipment systems listed in paragraphs (a)(2)(i) through (a)(2)(ix) of this section as specified in §63.443(c) and (d) of this subpart no later than April 16, 2002.

(i) The weak liquor storage tank;

(ii) The boilout tank;

(iii) The utility tank;

(iv) The fifty percent solids black liquor storage tank;

(v) The south sixty-seven percent solids black liquor storage tank;

(vi) The north sixty-seven percent solids black liquor storage tank;

(vii) The precipitator make down tanks numbers one, two and three;

(viii) The salt cake mix tank; and

(ix) The NaSH storage tank.

(3) The owner and operator of the pulping system shall operate the Isothermal Cooking system at the site while pulp is being produced in the continuous digester at anytime after April 16, 2002.

(i) The owner or operator shall monitor the following parameters to demonstrate that isothermal cooking is in operation:

(A) Continuous digester dilution factor; and

(B) The difference between the continuous digester vapor zone temperature and the continuous digester extraction header temperature.

(ii) The isothermal cooking system shall be in operation when the continuous digester dilution factor and the temperature difference between the continuous digester vapor zone temperature and the continuous digester extraction header temperature are maintained as set forth in Table 2:

Table 2 to Subpart S—Isothermal Cooking System Operational Values

Parameter	Instrument number	Limit	Units
Digester Dilution Factor	K1DILFAC	>0.0	None
Difference in Digester Vapor Zone Temperature and Digester	03TI0311	<10	Degrees F.
Extraction Header Temperature	03TI0329		

(iii) The owner or operator shall certify annually the operational status of the isothermal cooking system.

(4) [Reserved]

(5) *Definitions.* All descriptions and references to equipment and emission unit ID numbers refer to equipment at the Site. All terms used in this paragraph shall have the meaning given them in this part and this paragraph. For the purposes of this paragraph only the following additional definitions apply:

Boilout tank means the tank that provides tank storage capacity for recovery of black liquor spills and evaporator water washes for return to the evaporators (emission unit ID No. U606);

Brownstock diffusion washer means the equipment used to wash pulp from the surge chests to further reduce lignin carryover in the pulp;

Continuous digester means the digester system used to chemically and thermally remove the lignin binding the wood chips to produce individual pulp fibers (emission unit ID No. P300);

Fifty percent solids black liquor storage tank means the tank used to store intermediate black liquor prior to final evaporation in the 1A, 1B, and 1C Concentrators (emission unit ID No. U605);

First stage brownstock diffusion washer means the equipment that receives and stores filtrate from the first stage of washing for return to the pressure diffusion washer;

Isothermal cooking system means the 1995–1996 modernization of brownstock pulping process including conversion of the Kamyr continuous vapor phase digester to an extended delignification unit and changes in the knotting, screening, and oxygen stage systems:

NaSH storage tank means the tank used to store sodium hydrosulfite solution prior to use as make-up to the liquor system

North sixty-seven percent solids black liquor storage tank means one of two tanks used to store black liquor prior to burning in the Recovery Boiler for chemical recovery (emission unit ID No. U501);

Precipitator make down tank numbers one, two and three mean tanks used to mix collected particulate from electrostatic precipitator chamber number one with 67% black liquor for recycle to chemical recovery in the Recovery Boiler (emission unit ID Nos. U504, U505 and U506);

Salt cake mix tank means the tank used to mix collected particulate from economizer hoppers with black liquor for recycle to chemical recovery in the Recovery Boiler (emission unit ID No. U503);

South sixty-seven percent solids black liquor storage tank means one of two tanks used to store black liquor prior to burning in the Recovery Boiler for chemical recovery (emission unit ID No. U502);

Utility tank means the tank used to store fifty percent liquor and, during black liquor tank inspections and repairs, to serve as a backup liquor storage tank (emission unit ID No. U611);

Weak gas system means high volume, low concentration or HVLC system as defined in §63.441; and

Weak liquor storage tank means the tank that provide surge capacity for weak black liquor from digesting prior to feed to multiple effect evaporators (emission unit ID No. U610).

(b) *Tomahawk Wisconsin Mill*—(1) *Applicability.* (i) The provisions of this paragraph (b) apply to the owner or operator of the stand-alone semi-chemical pulp and paper mill located at N9090 County Road E in Tomahawk, Wisconsin, referred to as the Tomahawk Mill.

(ii) The owner or operator is not required to comply with the provisions of this paragraph (b) if the owner and operator chooses to comply with the otherwise applicable sections of this subpart and provides the EPA with notice.

(iii) If the owner or operator chooses to comply with the provisions of this paragraph (b) the owner or operator shall comply with all applicable provisions of this part, including this subpart, except the following:

(A) Section 63.443(b);

(B) Section 63.443(c); and

(C) Section 63.443(d).

(2) *Collection and routing of HAP emissions.* (i) The owner or operator shall collect the total HAP emissions from each LVHC system.

(ii) Each LVHC system shall be enclosed and the HAP emissions shall be vented into a closed-vent system. The enclosures and closed-vent system shall meet requirements specified in paragraph (b)(6) of this section.

(iii) The HAP emissions shall be routed as follows:

(A) The HAP emissions collected in the closed-vent system from the digester system shall be routed through the primary indirect contact condenser, secondary indirect contact condenser, and evaporator indirect contact condenser; and

(B) The HAP emissions collected in the closed-vent system from the evaporator system and foul condensate standpipe shall be routed through the evaporator indirect contact condenser.

(3) *Collection and routing of pulping process condensates.* (i) The owner or operator shall collect the pulping process condensates from the following equipment systems:

(A) Primary indirect contact condenser;

(B) Secondary indirect contact condenser; and

(C) Evaporator indirect contact condenser.

(ii) The collected pulping process condensates shall be conveyed in a closed collection system that is designed and operated to meet the requirements specified in paragraph (b)(7) of this section.

(iii) The collected pulping process condensates shall be routed in the closed collection system to the wastewater treatment plant anaerobic basins for biodegradation.

(iv) The pulping process condensates shall be discharged into the wastewater treatment plant anaerobic basins below the liquid surface of the wastewater treatment plant anaerobic basins.

(4) *HAP destruction efficiency requirements of the wastewater treatment plant.* (i) The owner or operator shall achieve a destruction efficiency of at least one pound of HAPs per ton of ODP by biodegradation in the wastewater treatment plant.

(ii) The following calculation shall be performed to determine the HAP destruction efficiency by biodegradation in the wastewater treatment plant:

$$HAP_d = \frac{\left[\left(RME_{fr} \times RME_c\right) + \left(PPC_{fr} \times PPC_c\right) - \left(ABD_{fr} \times ABD_c\right)\right] \times 8.34}{ODP_r}$$

Where:

HAP_d= HAP destruction efficiency of wastewater treatment plant (pounds of HAPs per ton of ODP);

RME_{fr}= flow rate of raw mill effluent (millions of gallons per day);

RME_c= HAP concentration of raw mill effluent (milligrams per liter);

PPC_{fr}= flow rate of pulping process condensates (millions of gallons per day);

PPC_c= HAP concentration of pulping process condensates (milligrams per liter);

ABD_{fr}= flow rate of anaerobic basin discharge (millions of gallons per day);

ABD_c= HAP concentration of anaerobic basin discharge (milligrams per liter); and

ODP_r= rate of production of oven dried pulp (tons per day).

(5) *Monitoring requirements and parameter ranges.* (i) The owner or operator shall install, calibrate, operate, and maintain according to the manufacturer's specifications a continuous monitoring system (CMS, as defined in §63.2), using a continuous recorder, to monitor the following parameters:

(A) Evaporator indirect contact condenser vent temperature;

(B) Pulping process condensates flow rate;

(C) Wastewater treatment plant effluent flow rate; and

(D) Production rate of ODP.

(ii) The owner or operator shall additionally monitor, on a daily basis, in each of the four anaerobic basins, the ratio of volatile acid to alkalinity (VA/A ratio). The owner or operator shall use the test methods identified for determining acidity and alkalinity as specified in 40 CFR 136.3, Table 1B.

(iii) The temperature of the evaporator indirect contact condenser vent shall be maintained at or below 140 °F on a continuous basis.

(iv) The VA/A ratio in each of the four anaerobic basins shall be maintained at or below 0.5 on a continuous basis.

(A) The owner or operator shall measure the methanol concentration of the outfall of any basin (using NCASI Method DI/MEOH 94.03) when the VA/A ratio of that basin exceeds the following:

(*1*) 0.38, or

(2) The highest VA/A ratio at which the outfall of any basin has previously measured non-detect for methanol (using NCASI Method DI/MEOH 94.03).

(B) If the outfall of that basin measures detect for methanol, the owner or operator shall verify compliance with the emission standard specified in paragraph (b)(4) of this section by conducting a performance test pursuant to the requirements specified in paragraph (b)(8) of this section.

(v) The owner or operator may seek to establish or reestablish the parameter ranges, and/or the parameters required to be monitored as provided in paragraphs (b)(5)(i) through (v) of this section, by following the provisions of §63.453(n)(1) through (4).

(6) *Standards and monitoring requirements for each enclosure and closed vent system.* (i) The owner or operator shall comply with the design and operational requirements specified in paragraphs (b)(6)(ii) through (iv) of this section, and the monitoring requirements of paragraphs (b)(6)(v) through (x) of this section for each enclosure and closed-vent system used for collecting and routing of HAP emissions as specified in paragraph (b)(2) of this section.

(ii) Each enclosure shall be maintained at negative pressure at each enclosure or hood opening as demonstrated by the procedures specified in §63.457(e). Each enclosure or hood opening closed during the initial performance test shall be maintained in the same closed and sealed position as during the performance test at all times except when necessary to use the opening for sampling, inspection, maintenance, or repairs.

(iii) Each component of the closed-vent system that is operated at positive pressure shall be designed for and operated with no detectable leaks as indicated by an instrument reading of less than 500 parts per million by volume above background, as measured by the procedures specifed in §63.457(d).

(iv) Each bypass line in the closed-vent system that could divert vent streams containing HAPs to the atmosphere without meeting the routing requirements specified in paragraph (b)(2) of this section shall comply with either of the following requirements:

(A) On each bypass line, the owner or operator shall install, calibrate, maintain, and operate according to the manufacturer's specifications a flow indicator that provides a record of the presence of gas stream flow in the bypass line at least once every 15 minutes. The flow indicator shall be installed in the bypass line in such a way as to indicate flow in the bypass line; or

(B) For bypass line valves that are not computer controlled, the owner or operator shall maintain the bypass line valve in the closed position with a car seal or seal placed on the valve or closure mechanism in such a way that the valve or closure mechanism cannot be opened without breaking the seal.

(v) For each enclosure opening the owner or operator shall perform, at least once every 30 days, a visual inspection of the closure mechanism specified in paragraph (b)(6)(ii) of this section to ensure the opening is maintained in the closed position and sealed.

(vi) For each closed-vent system required by paragraph (b)(2) of this section, the owner or operator shall perform a visual inspection every 30 days and at other times as requested by the Administrator. The visual inspection shall include inspection of ductwork, piping, enclosures, and connections to covers for visible evidence of defects.

(vii) For positive pressure closed-vent systems, or portions of closed-vent systems, the owner or operator shall demonstrate no detectable leaks as specifed in paragraph (b)(6)(iii) ofthis section, measured initially and annually by the procedures in §63.457(d).

(viii) For each enclosure that is maintained at negative pressure, the owner or operator shall demonstrate initially and annually that it is maintained at negative pressure as specified in §63.457(e).

(ix) For each valve or closure mechanism as specified in paragraph (b)(6)(iv)(B) of this section, the owner or operator shall perform an inspection at least once every 30 days to ensure that the valve is maintained in the closed position and the emissions point gas stream is not diverted through the bypass line.

(x) If an inspection required by paragraph (b)(6) of this section identifies visible defects in ductwork, piping, enclosures, or connections to covers required by paragraph (b)(6) of this section, or if an instrument reading of 500 parts per million by volume or greater above background is measured, or if the enclosure openings are not maintained at negative pressure, then the following corrective actions shall be taken as soon as follows:

(A) A first effort to repair or correct the closed-vent system shall be made as soon as practicable but no later than 5 calendar days after the problem is identified.

(B) The repair or corrective action shall be completed no later than 15 calendar days after the problem is identified.

(7) *Standards and monitoring requirements for the pulping process condensates closed collection system.* (i) The owner or operator shall comply with the design and operational requirements specified in paragraphs (b)(7)(ii) through (iii) of this section, and monitoring requirements of paragraph (b)(7)(iv) for the equipment systems in paragraph (b)(3) of this section used to route the pulping process condensates in a closed collection system.

(ii) Each closed collection system shall meet the individual drain system requirements specified in §§63.960, 63.961, and 63.962, except that the closed vent systems shall be designed and operated in accordance with paragraph (b)(6) of this section, instead of in accordance with §63.693 as specified in §63.692(a)(3)(ii), (b)(3)(ii)(A), and (b)(3)(ii)(B)(5)(iii); and

(iii) If a condensate tank is used in the closed collection system, the tank shall meet the following requirements:

(A) The fixed roof and all openings (e.g., access hatches, sampling ports, gauge wells) shall be designed and operated with no detectable leaks as indicated by an instrument reading of less than 500 parts per million above background, and vented into a closed-vent system that meets the requirements of paragraph (b)(6) of this section and routed in accordance with paragraph (b)(2) of this section; and

(B) Each opening shall be maintained in a closed, sealed position (e.g., covered by a lid that is gasketed and latched) at all times that the tank contains pulping process condensates or any HAPs removed from a pulping process condensate stream except when it is necessary to use the opening for sampling, removal, or for equipment inspection, maintenance, or repair.

(iv) For each pulping process condensate closed collection system used to comply with paragraph (b)(3) of this section, the owner or operator shall perform a visual inspection every 30 days and shall comply with the inspection and monitoring requirements specified in §63.964 except for the closed-vent system and control device inspection and monitoring requirements specified in §63.964(a)(2).

(8) *Quarterly performance testing.* (i) The owner or operator shall, within 45 days after the beginning of each quarter, conduct a performance test.

(ii) The owner or operator shall use NCASI Method DI/HAPS–99.01 to collect a grab sample and determine the HAP concentration of the Raw Mill Effluent, Pulping Process Condensates, and Anaerobic Basin Discharge for the quarterly performance test conducted during the first quarter each year.

(iii) For each of the remaining three quarters, the owner or operator may use NCASI Method DI/MEOH 94.03 as a surrogate to collect and determine the HAP concentration of the Raw Mill Effluent, Pulping Process Condensates, and Anaerobic Basin Discharge.

(iv) The sample used to determine the HAP or Methanol concentration in the RawMill Effluent, Pulping Process Condensates, or Anærobic Basin Discharge shall be a composite of four grab samples taken evenly spaced over an eight hour time period.

(v) The Raw Mill Effluent grab samples shall be taken from the raw mill effluent composite sampler.

(vi) The Pulping Process Condensates grab samples shall be taken from a line tap on the closed condensate collection system prior to discharge into the wastewater treatment plant.

(vii) The Anaerobic Basic Discharge grab samples shall be taken subsequent to the confluence of the four anaerobic basin discharges.

(viii) The flow rate of the Raw Mill Effluent, Pulping Process Condensates, and Anaerobic Basin Discharge, and the production rate of ODP shall be averaged over eight hours.

(ix) The data collected as specifed in paragraphs (b)(5) and (b)(8) ofthis section shall be usedto determine the HAP destruction efficiency of the wastewater treatment plant as specifed in paragraph (b)(4)(ii) of this section.

(x) The HAP destruction efficiency shall be at least as great as that specifed by paragraph (b)(4)(i) of this section.

(9) *Recordkeeping requirements.* (i) The owner or operator shall comply with the recordkeeping requirements as specified in Table 1 of subpart S of part 63 as it pertains to §63.10

(ii) The owner or operator shall comply with the recordkeeping requirements as specified in §63.454(b).

(iii) The owner or operator shall comply with the recordkeeping requirements as specified in §63.453(d).

(10) *Reporting requirements.* (i) Each owner or operator shall comply with the reporting requirements as specified in Table 1 of §63.10.

(ii) Each owner or operator shall comply with the reporting requirements as specifed in §63.455(d).

(11) *Violations.* (i) Failure to comply with any applicable provision of this part shall constitute a violation.

(ii) Periods of excess emissions shall not constitute a violation provided the time of excess emissions (excluding periods of startup, shutdown, or malfunction) divided by the total process operating time in a semi-annual reporting period does not exceed one percent. All periods ofexcess emission (including periods of startup, shutdown, and malfunction) shall be reported, and shall include:

(A) Failure to monitor a parameter, or maintain a parameter within minimum or maximum (as appropriate) ranges as specified in paragraph (b)(5), (b)(6), or (b)(7) ofthis section; and

(B) Failure to meet the HAP destruction efficiency standard specifed in paragraph (b)(4) ofthis section.

(iii) Notwithstanding paragraph (b)(11)(ii) of this section, any excess emissions that present an imminent threat to public health or the environment, or may cause serious harm to public health or the environment, shall constitute a violation.

[66 FR 34124, June 27, 2001, as amended at 66 FR 52538, Oct. 16, 2001; 69 FR 19740, Apr. 13, 2004]

Table 1 to Subpart S of Part 63—General Provisions Applicability to Subpart S[a]

Reference	Applies to Subpart S	Comment
63.1(a)(1)–(3)	Yes	
63.1(a)(4)	Yes	Subpart S (this table) specifies applicability of

		each paragraph in subpart A to subpart S.
63.1(a)(5)	No	Section reserved.
63.1(a)(6)–(8)	Yes	
63.1(a)(9)	No	Section reserved.
63.1(a)(10)	No	Subpart S and other cross-referenced subparts specify calendar or operating day.
63.1(a)(11)–(14)	Yes	
63.1(b)(1)	No	Subpart S specifies its own applicability.
63.1(b)(2)–(3)	Yes	
63.1(c)(1)–(2)	Yes	
63.1(c)(3)	No	Section reserved.
63.1(c)(4)–(5)	Yes	
63.1(d)	No	Section reserved.
63.1(e)	Yes	
63.2	Yes	
63.3	Yes	
63.4(a)(1)	Yes	
63.4(a)(3)		
63.4(a)(4)	No	Section reserved.
63.4(a)(5)	Yes	
63.4(b)	Yes	
63.4(c)	Yes	
63.5(a)	Yes	
63.5(b)(1)	Yes	
63.5(b)(2)	No	Section reserved.
63.5(b)(3)	Yes	
63.5(b)(4)–(6)	Yes	
63.5(c)	No	Section reserved.
63.5(d)	Yes	
63.5(e)	Yes	
63.5(f)	Yes	
63.6(a)	Yes	
63.6(b)	No	Subpart S specifies compliance dates for sources subject to subpart S.
63.6(c)	No	Subpart S specifies compliance dates for sources subject to subpart S.
63.6(d)	No	Section reserved.
63.6(e)	Yes	

63.6(f)	Yes	
63.6(g)	Yes	
63.6(h)	No	Pertains to continuous opacity monitors that are not part of this standard.
63.6(i)	Yes	
63.6(j)	Yes	
63.7	Yes	
63.8(a)(1)	Yes	
63.8(a)(2)	Yes	
63.8(a)(3)	No	Section reserved.
63.8(a)(4)	Yes	
63.8(b)(1)	Yes	
63.8(b)(2)	No	Subpart S specifies locations to conduct monitoring.
63.8(b)(3)	Yes	
63.8(c)(1)	Yes	
63.8(c)(2)	Yes	
63.8(c)(3)	Yes	
63.8(c)(4)	No	Subpart S allows site specific determination of monitoring frequency in §63.453(n)(4).
63.8(c)(5)	No	Pertains to continuous opacity monitors that are not part of this standard.
63.8(c)(6)	Yes	
63.8(c)(7)	Yes	
63.8(c)(8)	Yes	
63.8(d)	Yes	
63.8(e)	Yes	
63.8(f)(1)–(5)	Yes	
63.8(f)(6)	No	Subpart S does not specify relative accuracy test for CEMs.
63.8(g)	Yes	
63.9(a)	Yes	
63.9(b)	Yes	Initial notifications must be submitted within one year after the source becomes subject to the relevant standard.
63.9(c)	Yes	
63.9(d)	No	Special compliance requirements are only applicable to kraft mills.
63.9(e)	Yes	
63.9(f)	No	Pertains to continuous opacity monitors that are not part of this standard.
63.9(g)(1)	Yes	
63.9(g)(2)	No	Pertains to continuous opacity monitors that are

		not part of this standard.
63.9(g)(3)	No	Subpart S does not specify relative accuracy tests, therefore no notification is required for an alternative.
63.9(h)	Yes	
63.9(i)	Yes	
63.9(j)	Yes	
63.10(a)	Yes	
63.10(b)	Yes	
63.10(c)	Yes	
63.10(d)(1)	Yes	
63.10(d)(2)	Yes	
63.10(d)(3)	No	Pertains to continuous opacity monitors that are not part of this standard.
63.10(d)(4)	Yes	
63.10(d)(5)	Yes	
63.10(e)(1)	Yes	
63.10(e)(2)(i)	Yes	
63.10(e)(2)(ii)	No	Pertains to continuous opacity monitors that are not part of this standard.
63.10(e)(3)	Yes	
63.10(e)(4)	No	Pertains to continuous opacity monitors that are not part of this standard.
63.10(f)	Yes	
63.11–63.15	Yes	

[a]Wherever subpart A specifies "postmark" dates, submittals may be sent by methods other than the U.S. Mail (e.g., by fax or courier). Submittals shall be sent by the specified dates, but a postmark is not required.

[63 FR 18617, Apr. 15, 1998, as amended at 64 FR 17564, Apr. 12, 1999]

Browse Previous | Browse Next

For questions or comments regarding e-CFR editorial content, features, or design, email ecfr@nara.gov.

For questions concerning e-CFR programming and delivery issues, email webteam@gpo.gov.

Section 508 / Accessibility

UNITED STATES ENVIRONMENTAL PROTECTION AGENCY
REGION 6
1445 ROSS AVENUE, SUITE 1200
DALLAS, TX 75202-2733

JUL 3 0 1999

CERTIFIED MAIL - RETURN RECEIPT REQUESTED

RECEIVED
AUG 0 4 1999

Mr. Keith Michaels
Chief, Air Division
Arkansas Department of Environmental Quality
8001 National Drive
P.O. Box 8913
Little Rock, AR 72219-8913

Re. Georgia-Pacific Crossett Paper Operations 10A Boiler–Request for Alternative Monitoring

Dear Mr. Michaels:

On July 9, 1999, we received your letter of July 1, 1999, which supported and transmitted Georgia-Pacific's (GP) June 21, 1999, request for alternative monitoring of their 10A boiler that is subject to NSPS Subpart D. GP has noted that new Permit 597-AOP-R1 reflects an appropriate - s of monitoring opacity. The purpose of this letter is to approve GP's request given the ..wing:

The 10A boiler is required to have continuous monitoring systems (CMS) for measuring various emitted pollutants, including the opacity of emissions, pursuant to 40 C.F.R. 60.45. It is GP's request that given the fact that a venturi scrubber is the control equipment for this boiler and that liquid water interference from the scrubber renders the CMS inaccurate, that parametric monitoring of the scrubber along with weekly visual observation of the boiler's emissions using EPA Reference Method 9 be accepted in lieu of a CMS. This alternative may be accepted by EPA via the general provisions of NSPS Subpart A, at 40 C.F.R. 60.13(i).

Enclosed with GP's letter of June 21, 1991, were relevant sections of permit 597-AOP-R1. After review of these sections, there were questions regarding the annual particulate tests for he boiler and the relationship between the tests and the parametric monitoring of the scrubber. Accordingly, on July 16, 1999, Rich Raybourne of my staff spoke with GP's Scott Bailey and eceived clarification on this issue which included a fax of the entire 10A Boiler section of 597-AOP-R1. After review of the entire 10A Boiler section and the conversation with Mr. Bailey, the questions were resolved. By this letter we approve GP's request via the provisions of NSPS Subpart A, at 40 C.F.R. 60.13(i).

Recycled/Recyclable • Printed with Vegetable Oil Based Inks on 100% Recycled Paper (40% Postconsumer)

If you should have any questions regarding this letter, please contact Rich Raybourne, Senior Enforcement Officer of my staff, at 214-665-7260. Legal inquiries should be directed to Jan Gerro, Enforcement Counsel, Legal Branch at 214-665-2121.

Sincerely yours,

John R. Hepola

John R. Hepola
Chief
Air, Toxics and Inspection Coordination Branch

cc: Scott Bailey, GP
Drew Hodges, Esq. GP
Gordon Alphonso, Esq. GP
Tom Hudson, ADEQ
Melissa Blumenthal, ADEQ

UNITED STATES ENVIRONMENTAL PROTECTION AGENCY
REGION 6
1445 ROSS AVENUE, SUITE 1200
DALLAS, TX 75202-2733

P.P.

02.00013

DEC 10 2003

Charles E. Hodges
Senior Vice President
Manufacturing Southern Region
Georgia Pacific
Crossett Paper Operations
P.O. Box 3333
Crossett, Arkansas 71635

RECD DEC 15 2003

Dear Mr. Hodges:

This is in response to your letter dated August 18, 2003, regarding a 40 C.F.R. 63 Subpart S request for the use of alternative monitoring and inspection procedures for the closed vent systems subject to § 63.453(k)(2).

40 C.F.R. § 63.453(k) and 40 C.F.R. § 63.453(l) specify that monitoring occur every 30 days or at least once every 30 days. You are requesting approval to have monitoring established on a calendar month, due to the fact that you utilize the same third-party contractor for the 30-day visual inspections at the Crossett Paper and for inspections at the Crossett Chemical plant, and it would be easier to schedule both facilities in the same time frame.

We will allow Georgia Pacific Crossett Paper to conduct monitoring and inspections for the closed vent systems subject to § 63.453(k)(2), based upon the information contained in your letter, once during each calendar month, with at least 21 days elapsed time between inspection.

If you have any questions regarding this determination response, please contact me at (214) 665-7220 or Michelle Kelly, of my staff, at (214) 665-7580.

Sincerely yours,

William K. Honker, P.E.
Chief
Air/Toxic and Inspection
Coordination Branch

cc: Tom Hudson, ADEQ
Tom Rheaume, ADEQ

UNITED STATES ENVIRONMENTAL PROTECTION AGENCY
REGION 6
1445 ROSS AVENUE, SUITE 1200
DALLAS, TX 75202-2733

JUL 2 4 2001

Mr. Eric Reynolds
Environmental Engineer
Georgia-Pacific Corporation
Ashdown Operations
285 Highway 71 South
Ashdown, AR 71822

Dear Mr. Reynolds:

This is in response to your letter of March 7, 2001, requesting the approval of an alternative monitoring protocol, as required under Section 63.453(m) through (o), pursuant to the Pulp & Paper MACT standard, 40 C.F.R.63, Subpart S. Specifically, Georgia-Pacific Ashdown Operations is seeking approval to replace the required use of the §63.453(c)(2) "gas scrubber vent gas inlet flow rate" continuous monitoring system (CMS) with a system to continuously monitor amperage on the induced draft fans used to convey HAPs to the bleach plant scrubber.

Per 40 CFR 63.453(m), a source or an operator may choose to adopt an alternative monitoring parameter to comply with the standards established in Subpart S, provided that a ontinuous Monitoring System is in place and the source or operator establishes appropriate operating parameters to be monitored in such a way that it will demonstrate continuous compliance with the applicable control requirements to the satisfaction of the Administrator. However, per CFR 63.458(b)(2), the authority for determination and use of an alternative monitoring parameter can not be transferred (delegated) to a State.

Based on the discussion of the alternative monitoring parameter issue in the Environmental Protection Agency's (EPA's) O&A Document for the Pulp & Paper MACT (Volume 1, Page 8-10), Region 6 agrees that adequate rationale for using an alternative parameter (as required in §63.453(n)), has been demonstrated. Therefore, Region 6 concurs with Georgia-Pacific's request to substitute fan motor amperage as an alternative monitoring parameter to §63.453(c)(2), and accordingly approves this specific request.

In order to ensure compliance with Subpart S, we request that you perform the following:

a) conduct annual negative pressure checks to ensure that the bleach plant scrubber fan induces the desired negative pressure across the system;

b) conduct monthly visual inspections under the Leak Detection and Repair plan provisions for the scrubber fan and associated process;

c) conduct periodic preventive maintenance of the bleach plant scrubber fan to ensure safe and proper operation of the system;

d) respond immediately to any signs or indications of visible emissions from the scrubber stack, washer hoods, or towers at the bleach plant;

e) continuously record/monitor the fan motor amperage loading to ensure proper rotational fan speed and pressure drop for the bleach plant scrubber fan; and,

f) perform a successful initial performance test to determine an acceptable range of electrical current (amps) within which the fan needs to be operated.

Furthermore, in case of future replacement of the fan blades or fan motor, you must demonstrate that gas flow to the scrubber has not increased as a result of changes to the fan or conduct another performance test to ensure that the gas scrubber meets the emission limitations of the air permit.

Please be advised that this alternative monitoring determination shall by no means relieve you from complying with the applicable Record keeping and Reporting requirements established in 40 CFR 63.454 and 63.355 of Subpart S.

We also recommend that you share a copy of this alternative monitoring parameter determination letter with the appropriate State or local Title V permitting authority for any pending or future air permitting activities relevant to your mill. Consequently, the permitting authority would be able to craft air permit conditions tailored specifically for your bleach plant operations.

If you have any questions regarding this response, please contact Michelle Kelly, of my staff, at (214) 665-7580.

Sincerely yours,

John R. Hepola
Chief
Air/Toxic & Inspection
Coordination Branch

cc: Lyndon Poole, ADEQ
Tom Hudson, ADEQ
Tom Rheaume, ADEQ

Electronic Code of Federal Regulations
e-CFR™

e-CFR Data is current as of May 12, 2011

Title 40: Protection of Environment

PART 63—NATIONAL EMISSION STANDARDS FOR HAZARDOUS AIR POLLUTANTS FOR SOURCE CATEGORIES (CONTINUED)

Browse Previous | Browse Next

Subpart MM—National Emission Standards for Hazardous Air Pollutants for Chemical Recovery Combustion Sources at Kraft, Soda, Sulfite, and Stand-Alone Semichemical Pulp Mills

Source: 66 FR 3193, Jan. 12, 2001, unless otherwise noted.

§ 63.860 Applicability and designation of affected source.

(a) The requirements of this subpart apply to the owner or operator of each kraft, soda, sulfite, or stand-alone semichemical pulp mill that is a major source of hazardous air pollutants (HAP) emissions as defined in §63.2.

(b) *Affected sources.* The requirements of this subpart apply to each new or existing affected source listed in paragraphs (b)(1) through (7) of this section:

(1) Each existing chemical recovery system (as defined in §63.861) located at a kraf or soda pulp mill.

(2) Each new nondirect contact evaporator (NDCE) recovery furnace and associated smelt dissolving tank(s) located at a kraf or soda pulp mill.

(3) Each new direct contact evaporator (DCE) recovery furnace system (as defined in §63.861) and associated smelt dissolving tank(s) located at a kraft or soda pulp mill.

(4) Each new lime kiln located at a kraft or soda pulp mill.

(5) Each new or existing sulfite combustion unit located at a sulfte pulp mill, except such existing units at Weyerhaeuser Paper Company's Cosmopolis, Washington facility (Emission Unit no. AP–10).

(6) Each new or existing semichemical combustion unit located at a stand-alone semichemical pulp mill.

(7) The requirements of the alternative standard in §63.862(d) apply to the hog fuel dryer at Weyerhaeuser Paper Company's Cosmopolis, Washington facility (Emission Unit no. HD–14).

(c) The requirements of the General Provisions in subpart A of this part that apply to the owner or operator subject to the requirements of this subpart are identifed in Table 1 to this subpart.

[66 FR 3193, Jan. 12, 2001, as amended at 68 FR 7713, Feb. 18, 2003]

§ 63.861 Definitions.

All terms used in this subpart are defined in the Clean Air Act, in subpart A of this part, or in this section. For the purposes of this subpart, if the same term is defined in subpart A or any other subpart of this part and in this section, it must have the meaning given in this section.

Bag leak detection system means an instrument that is capable of monitoring PM loadings in the exhaust of a fabric filter in order to detect bag failures. A bag leak detection system includes, but is not limited to, an instrument that operates on triboelectric, light scattering, light transmittance, or other principle to monitor relative PM loadings.

Black liquor means spent cooking liquor that has been separated from the pulp produced by the kraft, soda, or semichemical pulping process.

Black liquor gasification means the thermochemical conversion of black liquor into a combustible gaseous product.

Black liquor oxidation (BLO) system means the vessels used to oxidize the black liquor, with air or oxygen, and the associated storage tank(s).

Black liquor solids (BLS) means the dry weight of the solids in the black liquor that enters the recovery furnace or semichemical combustion unit.

Black liquor solids firing rate means the rate at which black liquor solids are fed to the recovery furnace or the semichemical combustion unit.

Chemical recovery combustion source means any source in the chemical recovery area of a kraft, soda, sulfite or stand-alone semichemical pulp mill that is an NDCE recovery furnace, a DCE recovery furnace system, a smelt dissolving tank, a lime kiln, a sulfite combustion unit, or a semichemical combustion unit.

Chemical recovery system means all existing DCE and NDCE recovery furnaces, smelt dissolving tanks, and lime kilns at a kraft or soda pulp mill. Each existing recovery furnace, smelt dissolving tank, or lime kiln is considered a process unit within a chemical recovery system.

Direct contact evaporator (DCE) recovery furnace means a kraft or soda recovery furnace equipped with a direct contact evaporator that concentrates strong black liquor by direct contact between the hot recovery furnace exhaust gases and the strong black liquor.

Direct contact evaporator (DCE) recovery furnace system means a direct contact evaporator recovery furnace and any black liquor oxidation system, if present, at the pulp mill.

Dry electrostatic precipitator (ESP) system means an electrostatic precipitator with a dry bottom (*i.e.,* no black liquor, water, or other fluid is used in the ESP bottom) and a dry particulate matter return system (*i.e.,* no black liquor, water, or other fluid is used to transport the collected PM to the mix tank).

Fabric filter means an air pollution control device used to capture PM by filtering a gas stream through filter media; also known as a baghouse.

Hazardous air pollutants (HAP) metals means the sum of all emissions of antimony, arsenic, beryllium, cadmium, chromium, cobalt, lead, manganese, mercury, nickel, and selenium as measured by EPA Method 29 (40 CFR part 60, appendix A) and with all nondetect data treated as one-half of the method detection limit.

Hog fuel dryer means the equipment that combusts fine particles of wood waste (hog fuel) in a fluidized bed and directs the heated exhaust stream to a rotary dryer containing wet hog fuel to be dried prior to combustion in the hog fuel boiler at Weyerhaeuser Paper Company's Cosmopolis, Washington facility. The hog fuel dryer at Weyerhaeuser Paper Company's Cosmopolis, Washington facility is Emission Unit no. HD–14.

Kraft pulp mill means any stationary source that produces pulp from wood by cooking (digesting) wood chips in a solution of sodium hydroxide and sodium sulfide. The recovery process used to regenerate cooking chemicals is also considered part of the kraft pulp mill.

Kraft recovery furnace means a recovery furnace that is used to burn black liquor produced by the kraft pulping process, as well as any recovery furnace that burns black liquor produced from both the kraft

and semichemical pulping processes, and includes the direct contact evaporator, if applicable. Includes black liquor gasification.

Lime kiln means the combustion unit (*e.g.,* rotary lime kiln or fluidized-bed calciner) used at a kraft or soda pulp mill to calcine lime mud, which consists primarily of calcium carbonate, into quicklime, which is calcium oxide (CaO).

Lime production rate means the rate at which dry lime, measured as CaO, is produced in the lime kiln.

Method detection limit means the minimum concentration of an analyte that can be determined with 99 percent confidence that the true value is greater than zero.

Modification means, for the purposes of §63.862(a)(1)(ii)(E)(*1*), any physical change (excluding any routine part replacement or maintenance) or operational change (excluding any operational change that occurs during a start-up, shutdown, or malfunction) that is made to the air pollution control device that could result in an increase in PM emissions.

Nondetect data means, for the purposes of this subpart, any value that is below the method detection limit.

Nondirect contact evaporator (NDCE) recovery furnace means a kraft or soda recovery furnace that burns black liquor that has been concentrated by indirect contact with steam.

Particulate matter (PM) means total particulate matter as measured by EPA Method 5, EPA Method 17 (§63.865(b)(1)), or EPA Method 29 (40 CFR part 60, appendix A).

Process unit means an existing DCE or NDCE recovery furnace, smelt dissolving tank, or lime kiln in a chemical recovery system at a kraft or soda mill.

Recovery furnace means an enclosed combustion device where concentrated black liquor produced by the kraft or soda pulping process is burned to recover pulping chemicals and produce steam. Includes black liquor gasification.

Regenerative thermal oxidizer (RTO) means a thermal oxidizer that transfers heat from the exhaust gas stream to the inlet gas stream by passing the exhaust stream through a bed of ceramic stoneware or other heat-absorbing medium before releasing it to the atmosphere, then reversing the gas flow so the inlet gas stream passes through the heated bed, raising the temperature of the inlet stream close to or at its ignition temperature.

Semichemical combustion unit means any equipment used to combust or pyrolyze black liquor at stand-alone semichemical pulp mills for the purpose of chemical recovery. Includes black liquor gasifcation.

Similar process units means all existing DCE and NDCE recovery furnaces, smelt dissolving tanks, or lime kilns at a kraft or soda pulp mill.

Smelt dissolving tanks (SDT) means vessels used for dissolving the smelt collected from a kraft or soda recovery furnace.

Soda pulp mill means any stationary source that produces pulp fom wood by cooking (digesting) wood chips in a sodium hydroxide solution. The recovery process used to regenerate cooking chemicals is also considered part of the soda pulp mill.

Soda recovery furnace means a recovery furnace used to burn black liquor produced by the soda pulping process and includes the direct contact evaporator, if applicable. Includes black liquor gasification.

Stand-alone semichemical pulp mill means any stationary source that produces pulp fom wood by partially digesting wood chips in a chemical solution followed by mechanical defibrating (grinding), and has an onsite chemical recovery process that is not integrated with a kraft pulp mill.

Startup means, for the chemical recovery system employing black liquor gasification at Georgia-Pacific's facility in Big Island, Virginia only, the end of the gasification system commissioning phase. Commissioning is that period of time in which each part of the new gasification system will be checked

and operated on its own to make sure it is installed and functions properly. Commissioning will conclude with the successful completion of the gasification technology supplier's performance warranty demonstration, which proves the technology and equipment are performing to warranted levels and the system is ready to be placed in active service. For all other affected sources under this subpart, startup has the meaning given in §63.2.

Sulfite combustion unit means a combustion device, such as a recovery furnace or fluidized-bed reactor, where spent liquor from the sulfite pulping process (i.e., red liquor) is burned to recover pulping chemicals.

Sulfite pulp mill means any stationary source that produces pulp fom wood by cooking (digesting) wood chips in a solution of sulfurous acid and bisulfite ions. The recovery process used to regenerate cooking chemicals is also considered part of the sulfite pulp mill.

Total hydrocarbons (THC) means the sum of organic compounds measured as carbon using EPA Method 25A (40 CFR part 60, appendix A).

[66 FR 3193, Jan. 12, 2001, as amended at 66 FR 16408, Mar. 26, 2001; 68 FR 7713, Feb. 18, 2003]

§ 63.862 Standards.

(a) *Standards for HAP metals: existing sources.* (1) Each owner or operator of an existing kraft or soda pulp mill must comply with the requirements of either paragraph (a)(1)(i) or (ii) of this section.

(i) Each owner or operator of a kraft or soda pulp mill must comply with the PM emissions limits in paragraphs (a)(1)(i)(A) through (C) of this section.

(A) The owner or operator of each existing kraft or soda recovery furnace must ensure that the concentration of PM in the exhaust gases discharged to the atmosphere is less than or equal to 0.10 gram per dry standard cubic meter (g/dscm) (0.044 grain per dry standard cubic foot (gr/dscf)) corrected to 8 percent oxygen.

(B) The owner or operator of each existing kraft or soda smelt dissolving tank must ensure that the concentration of PM in the exhaust gases discharged to the atmosphere is less than or equal to 0.10 kilogram per megagram (kg/Mg) (0.20 pound per ton (lb/ton)) of black liquor solids fired.

(C) The owner or operator of each existing kraft or soda lime kiln must ensure that the concentration of PM in the exhaust gases discharged to the atmosphere is less than or equal to 015 g/dscm (0.064 gr/dscf) corrected to 10 percent oxygen.

(ii) As an alternative to meeting the requirements of §63.862(a)(1)(i), each owner or operator of a kraft or soda pulp mill may establish PM emissions limits for each existing kraft or soda recovery furnace, smelt dissolving tank, and lime kiln that operates 6,300 hours per year or more by:

(A) Establishing an overall PM emission limit for each existing process unit in the chemical recovery system at the kraft or soda pulp mill using the methods in §63.865(a)(1) and (2).

(B) The emissions limits for each kraft recovery furnace, smelt dissolving tank, and lime kiln that are used to establish the overall PM limit in paragraph (a)(1)(ii)(A) of this section must not be less stringent than the emissions limitations required by §60.282 of part 60 of this chapter for any kraft recovery furnace, smelt dissolving tank, or lime kiln that is subject to the requirements of §60.282.

(C) Each owner or operator of an existing kraft or soda recovery furnace, smelt dissolving tank, or lime kiln must ensure that the PM emissions discharged to the atmosphere from each of these sources are less than or equal to the applicable PM emissions limits, established using the methods in §63.865(a)(1), that are used to establish the overall PM emissions limits in paragraph (a)(1)(ii)(A) of this section.

(D) Each owner or operator of an existing kraft or soda recovery furnace, smelt dissolving tank, or lime kiln must reestablish the emissions limits determined in paragraph (a)(1)(ii)(A) of this section if either of the actions in paragraphs (a)(1)(ii)(D)(*1*) and (*2*) of this section are taken:

(*1*) The air pollution control system for any existing kraft or soda recovery furnace, smelt dissolving tank, or lime kiln for which an emission limit was established in paragraph (a)(1)(ii)(A) of this section is

modified (as defined in §63.861) or replaced; or

(2) Any kraft or soda recovery furnace, smelt dissolving tank, or lime kiln for which an emission limit was established in paragraph (a)(1)(ii)(A) of this section is shut down for more than 60 consecutive days.

(iii) Each owner or operator of an existing kraft or soda recovery furnace, smelt dissolving tank, or lime kiln that operates less than 6,300 hours per year must comply with the applicable PM emissions limits for that process unit provided in paragraph (a)(1)(i) of this section.

(2) Except as specified in paragraph (d) of this section, the owner or operator of each existing sulfite combustion unit must ensure that the concentration of PM in the exhaust gases discharged to the atmosphere is less than or equal to 0.092 g/dscm (0.040 gr/dscf) corrected to 8 percent oxygen.

(b) *Standards for HAP metals: new sources.* (1) The owner or operator of any new kraft or soda recovery furnace must ensure that the concentration of PM in the exhaust gases discharged to the atmosphere is less than or equal to 0.034 g/dscm (0.015 gr/dscf) corrected to 8 percent oxygen.

(2) The owner or operator of any new kraft or soda smelt dissolving tank must ensure that the concentration of PM in the exhaust gases discharged to the atmosphere is less than or equal to 0.06 kg/Mg (0.12 lb/ton) of black liquor solids fired.

(3) The owner or operator of any new kraft or soda lime kiln must ensure that the concentration of PM in the exhaust gases discharged to the atmosphere is less than or equal to 0.023 g/dscm (0.010 gr/dscf) corrected to 10 percent oxygen.

(4) The owner or operator of any new sulfite combustion unit must ensure that the concertration of PM in the exhaust gases discharged to the atmosphere is less than or equal to 0046 g/dscm (O.020 gr/dscf) corrected to 8 percent oxygen.

(c) *Standards for gaseous organic HAP.* (1) The owner or operator of any new recovery furnace at a kraft or soda pulp mill must ensure that the concentration or gaseous organic HAP, as measured by methanol, discharged to the atmosphere is no greater than 0.012 kg/Mg (0.025 lb/ton) of black liquor solids fired.

(2) The owner or operator of each existing or new semichemical combustion unit must ensure that:

(i) The concentration of gaseous organic HAP, as measured by total hydrocarbons reported as carbon, discharged to the atmosphere is less than or equal to 1.49 kg/Mg (2.97 lb/ton) of black liquor solids fired; or

(ii) The gaseous organic HAP emissions, as measured by total hydrocarbons reported as carbon, are reduced by at least 90 percent prior to discharge of the gases to the atmosphere.

(d) *Alternative standard.* As an alternative to meeting the requirements of paragraph (a)(2) of this section, the owner or operator of the existing hog fuel dryer at Weyerhaeuser Paper Company's Cosmopolis, Washington facility (Emission Unit no. HD–14) must ensure that the mass of PM in the exhaust gases discharged to the atmosphere from the hog fuel dryer is less than or equal to 4.535 kilograms per hour (kg/hr) (10.0 pounds per hour (lb/hr)).

[66 FR 3193, Jan. 12, 2001, as amended at 68 FR 7713, Feb. 18, 2003; 68 FR 67954, Dec. 5, 2003]

§ 63.863 Compliance dates.

(a) The owner or operator of an existing affected source or process unit must comply with the requirements in this subpart no later than March 13, 2004.

(b) The owner or operator of a new affected source that has an initial startup date after March 13, 2001 must comply with the requirements in this subpart immediately upon startup of the affected source, except as specified in §63.6(b).

(c) The two existing semichemical combustion units at Georgia-Pacific Corporation's Big Island, VA facility must comply with the requirements of this subpart no later than March 13, 2004, except as

provided in paragraphs (c)(1) and (c)(2) of this section.

(1) If Georgia-Pacific Corporation constructs a new black liquor gasification system at Big Island, VA, determines that its attempt to start up the new system has been a failure and, therefore, must construct another type of chemical recovery unit to replace the two existing semichemical combustion units at Big Island, then the two existing semichemical combustion units must comply with the requirements of this subpart by the earliest of the following dates: three years after Georgia-Pacific declares the gasification system a failure, upon startup of the new replacement unit(s), or March 1, 2008.

(2) After March 13, 2004 and if Georgia-Pacific Corporation constructs and successfully starts up a new black liquor gasification system, the provisions of this subpart will not apply to the two existing semichemical combustion units at Georgia-Pacific's facility in Big Island, VA for up to 1500 hours, while Georgia-Pacific conducts trials of the new gasification system on black liquor from a Kraft pulp mill.

[66 FR 3193, Jan. 12, 2001, as amended at 66 FR 16408, Mar. 26, 2001; 66 FR 37593, July 19, 2001; 68 FR 46108, Aug. 5, 2003]

§ 63.864 Monitoring requirements.

(a)–(c) [Reserved]

(d) *Continuous opacity monitoring system (COMS).* The owner or operator of each affected kraft or soda recovery furnace or lime kiln equipped with an ESP must install, calibrate, maintain, and operate a COMS according to the provisions in §§63.6(h) and 63.8 and paragraphs (d)(1) through (4) of this section.

(1)–(2) [Reserved]

(3) As specified in §63.8(c)(4)(i), each COMS must complete a minimum of one cycle of sampling and analyzing for each successive 10-second period and one cycle of data recording for each successive 6-minute period.

(4) The COMS data must be reduced as specified in §63.8(g)(2).

(e) *Continuous parameter monitoring system (CPMS).* For each CPMS required in this section, the owner or operator of each affected source or process unit must meet the requirements in paragraphs (e)(1) through (14) of this section.

(1)–(9) [Reserved]

(10) The owner or operator of each affected kraft or soda recovery furnace, kraft or soda lime kiln, sulfite combustion unit, or kraft or soda smelt dissolving tank equipped with a wet scrubber must install, calibrate, maintain, and operate a CPMS that can be used to determine and record the pressure drop across the scrubber and the scrubbing liquid flow rate at least once every successive 15-minute period using the procedures in §63.8(c), as well as the procedures in paragraphs (e)(10)(i) and (ii) of this section:

(i) The monitoring device used for the continuous measurement of the pressure drop of the gas stream across the scrubber must be certified by the manufacturer to be accurate to within a gage pressure of ±500 pascals (±2 inches of water gage pressure); and

(ii) The monitoring device used for continuous measurement of the scrubbing liquid flow rate must be certified by the manufacturer to be accurate within ±5 percent of the design scrubbing liquid flow rate.

(11) The owner or operator of each affected semichemical combustion unit equipped with an RTO must install, calibrate, maintain, and operate a CPMS that can be used to determine and record the operating temperature of the RTO at least once every successive 15-minute period using the procedures in §63.8(c). The monitor must compute and record the operating temperature at the point of incineration of effluent gases that are emitted using a temperature monitor accurate to within ±1 percent of the temperature being measured.

(12) The owner or operator of the affected hog fuel dryer at Weyerhaeuser Paper Company's Cosmopolis, Washington facility (Emission Unit no. HD–14) must meet the requirements in paragraphs

(e)(12)(i) through (xi) of this section for each bag leak detection system.

(i) The owner or operator must install, calibrate, maintain, and operate each triboelectric bag leak detection system according to the "Fabric Filter Bag Leak Detection Guidance", (EPA–454/R–98–015, September 1997). This document is available from the U.S. Environmental Protection Agency (U.S. EPA); Office of Air Quality Planning and Standards; Emissions, Monitoring and Analysis Division; Emission Measurement Center, MD-D205-02, Research Triangle Park, NC 27711. This document is also available on the Technology Transfer Network under Emission Measurement Center Continuous Emission Monitoring. The owner or operator must install, calibrate, maintain, and operate other types of bag leak detection systems in a manner consistent with the manufacturer's written specifications and recommendations.

(ii) The bag leak detection system must be certified by the manufacturer to be capable of detecting PM emissions at concentrations of 10 milligrams per actual cubic meter (0.0044 grains per actual cubic foot) or less.

(iii) The bag leak detection system sensor must provide an output of relative PM loadings.

(iv) The bag leak detection system must be equipped with a device to continuously record the output signal from the sensor.

(v) The bag leak detection system must be equipped with an audible alarm system that will sound automatically when an increase in relative PM emissions over a preset level is detected. The alarm must be located where it is easily heard by plant operating personnel.

(vi) For positive pressure fabric filter systems, a bag leak detector must be installed in each baghouse compartment or cell.

(vii) For negative pressure or induced air fabric filters, the bag leak detector must be installed downstream of the fabric filter.

(viii) Where multiple detectors are required, the system's instrumentation and alarm may be shared among detectors.

(ix) The baseline output must be established by adjusting the range and the averaging period of the device and establishing the alarm set points and the alarm delay time according to section 5.0 of the "Fabric Filter Bag Leak Detection Guidance."

(x) Following initial adjustment of the system, the sensitivity or range, averaging period, alarm set points, or alarm delay time may not be adjusted except as detailed in the site-specific monitoring plan. In no case may the sensitivity be increased by more than 100 percent or decreased more than 50 percent over a 365-day period unless such adjustment follows a complete fabric filter inspection which demonstrates that the fabric filter is in good operating condition. Record each adjustment.

(xi) The owner or operator must record the results of each inspection, calibration, and validation check.

(13) The owner or operator of each affected source or process unit that uses an ESP, wet scrubber, RTO, or fabric filter may monitor alternative control device operating parameters subject to prior written approval by the Administrator.

(14) The owner or operator of each affected source or process unit that uses an air pollution control system other than an ESP, wet scrubber, RTO, or fabric filter must provide to the Administrator an alternative monitoring request that includes the site-specific monitoring plan described in paragraph (a) of this section, a description of the control device, test results verifying the performance of the control device, the appropriate operating parameters that will be monitored, and the frequency of measuring and recording to establish continuous compliance with the standards. The alternative monitoring request is subject to the Administrator's approval. The owner or operator of the affected source or process unit must install, calibrate, operate, and maintain the monitor(s) in accordance with the alternative monitoring request approved by the Administrator. The owner or operator must include in the information submitted to the Administrator proposed performance specifications and quality assurance procedures for the monitors. The Administrator may request further information and will approve acceptable test methods and procedures. The owner or operator must monitor the parameters as approved by the Administrator using the methods and procedures in the alternative monitoring request.

(f) [Reserved]

(g) The owner or operator of each affected source or process unit complying with the gaseous organic HAP standard of §63.862(c)(1) through the use of an NDCE recovery furnace equipped with a dry ESP system is not required to conduct any continuous monitoring to demonstrate compliance with the gaseous organic HAP standard.

(h)–(i) [Reserved]

(j) *Determination of operating ranges.* (1) During the initial performance test required in §63.865, the owner or operator of any affected source or process unit must establish operating ranges for the monitoring parameters in paragraphs (e)(10) through (14) of this section, as appropriate; or

(2) The owner or operator may base operating ranges on values recorded during previous performance tests or conduct additional performance tests for the specific purpose of establishing operating ranges, provided that test data used to establish the operating ranges are or have been obtained using the test methods required in this subpart. The owner or operator of the affected source or process unit must certify that all control techniques and processes have not been modified subsequent to the testing upon which the data used to establish the operating parameter ranges were obtained.

(3) The owner or operator of an affected source or process unit may establish expanded or replacement operating ranges for the monitoring parameter values listed in paragraphs (e)(10) through (14) of this section and established in paragraph (j)(1) or (2) of this section during subsequent performance tests using the test methods in §63.865.

(4) The owner or operator of the affected source or process unit must continuously monitor each parameter and determine the arithmetic average value of each parameter during each performance test. Multiple performance tests may be conducted to establish a range of parameter values.

(5)–(6) [Reserved]

(k) *On-going compliance provisions.* (1) Following the compliance date, owners or operators of all affected sources or process units are required to implement corrective action if the monitoring exceedances in paragraphs (k)(1)(i) through (vi) of this section occur:

(i) For a new or existing kraft or soda recovery furnace or lime kiln equipped with an ESP, when the average of ten consecutive 6-minute averages result in a measurement greater than 20 percent opacity;

(ii) For a new or existing kraft or soda recovery furnace, kraft or soda smelt dissolving tank, kraft or soda lime kiln, or sulfite combustion unit equipped with a wet scrubber, when any 3-hour average parameter value is outside the range of values established in paragraph (j) of this section.

(iii) For a new or existing semichemical combustion unit equipped with an RTO, when any 1-hour average temperature falls below the temperature established in paragraph (j) of this section;

(iv) For the hog fuel dryer at Weyerhaeuser Paper Company's Cosmopolis, Washington facility (Emission Unit no. HD–14), when the bag leak detection system alarm sounds.

(v) For an affected source or process unit equipped with an ESP, wet scrubber, RTO, or fabric filter and monitoring alternative operating parameters established in paragraph (e)(13) of this section, when any 3-hour average value is outside the range of parameter values established in paragraph (j) of this section; and

(vi) For an affected source or process unit equipped with an alternative air pollution control system and monitoring operating parameters approved by the Administrator as established in paragraph (e)(14) of this section, when any 3-hour average value is outside the range of parameter values established in paragraph (j) of this section.

(2) Following the compliance date, owners or operators of all affected sources or process units are in violation of the standards of §63.862 if the monitoring exceedances in paragraphs (k)(2)(i) through (vii) of this section occur:

(i) For an existing kraft or soda recovery furnace equipped with an ESP, when opacity is greater than 35

percent for 6 percent or more of the operating time within any quarterly period;

(ii) For a new kraft or soda recovery furnace or a new or existing lime kiln equipped with an ESP, when opacity is greater than 20 percent for 6 percent or more of the operating time within any quarterly period;

(iii) For a new or existing kraft or soda recovery furnace, kraft or soda smelt dissolving tank, kraft or soda lime kiln, or sulfite combustion unit equipped with a wet scrubber, when six or more 3-hour average parameter values within any 6-month reporting period are outside the range ofvalues established in paragraph (j) of this section;

(iv) For a new or existing semichemical combustion unit equipped with an RTO, when any 3-hour average temperature falls below the temperature established in paragraph (j) of this section;

(v) For the hog fuel dryer at Weyerhaeuser Paper Company's Cosmopolis, Washington facility (Emission Unit no. HD-14), when corrective action is not initiated within 1 hour of a bag leak detection system alarm and the alarm is engaged for more than 5 percent ofthe total operating time in a 6-month block reporting period. In calculating the operating time fraction, if inspection of the fabric filter demonstrates that no corrective action is required, no alarm time is counted; if corrective action is required, each alarm is counted as a minimum of 1 hour; if corrective action is not initiated within 1 hour, the alarm time is counted as the actual amount of time taken to initiate corrective action.

(vi) For an affected source or process unit equipped with an ESP, wet scrubber, RTO, or fabric filter and monitoring alternative operating parameters established in paragraph (e)(13) ofthis section, when six or more 3-hour average values within any 6-month reporting period are outside the range of parameter values established in paragraph (j) of this section; and

(vii) For an affected source or process unit equipped with an alternative air pollution control system and monitoring operating parameters approved by the Administrator as established in paragraph (e)(14) of this section, when six or more 3-hour average values within any 6-month reporting period are outside the range of parameter values established in paragraph (j) of this section.

(3) For purposes of determining the number of nonopacity monitoring exceedances, no more than one exceedance will be attributed in any given 24-hour period.

[68 FR 7713, Feb. 18, 2003, as amended at 68 FR 42605, July 18, 2003; 68 FR 67955, Dec. 5, 2003; 71 FR 20458, Apr. 20, 2006]

§ 63.865 Performance test requirements and test methods.

The owner or operator of each affected source or process unit subject to the requirements of this subpart is required to conduct an initial performance test using the test methods and procedures listed in §63.7 and paragraph (b) of this section, except as provided in paragraph (c)(1) ofthis section.

(a) The owner or operator of a process unit seeking to comply with a PM emission limit under §63.862(a)(1)(ii)(A) must use the procedures in paragaphs (a)(1) and (2) ofthis section:

(1) Determine the overall PM emission limit for the chemical recovery system at the mill using Equation 1 of this section as follows:

$$EL_{PM} = \frac{\left[\left(C_{ref,RF}\right)\left(Q_{RFtot}\right) + \left(C_{ref,LK}\right)\left(Q_{LKtot}\right)\right](F1)}{\left(BLS_{tot}\right)} + ER1_{ref,SDT} \qquad \text{(Eq. 1)}$$

Where:

EL_{PM}= overall PM emission limit for all existing process units in the chemical recovery system at the kraft or soda pulp mill, kg/Mg (lb/ton) of black liquor solids fired.

$C_{ref, RF}$= reference concentration of 0.10 g/dscm (0.044 gr/dscf) corrected to 8 percent oxygen for existing kraft or soda recovery furnaces.

Q_{RFtot}= sum of the average volumetric gas flow rates measured during the performance test and corrected to 8 percent oxygen for all existing recovery furnaces in the chemical recovery system at the kraft or soda pulp mill, dry standard cubic meters per minute (dscm/min) (dry standard cubic feet per minute (dscf/min)).

$C_{ref,LK}$= reference concentration of 0.15 g/dscm (0.064 gr/dscf) corrected to 10 percent oxygen for existing kraft or soda lime kilns.

Q_{LKtot}= sum of the average volumetric gas flow rates measured during the performance test and corrected to 10 percent oxygen for all existing lime kilns in the chemical recovery system at the kraft or soda pulp mill, dscm/min (dscf/min).

F1 = conversion factor, 1.44 minutes·kilogram/day·gram (min·kg/d·g) (0.206 minutes·pound/day·grain (min·b/d·gr)).

BLS_{tot}= sum of the average black liquor solids firing rates of all existing recovery furnaces in the chemical recovery system at the kraft or soda pulp mill measured during the performance test, megagrams per day (Mg/d) (tons per day (ton/d)) of black liquor solids fired.

$ER1_{ref, SDT}$= reference emission rate of 0.10 kg/Mg (0.20 lb/ton) of black liquor solids fired for existing kraft or soda smelt dissolving tanks.

(2) Establish an emission limit for each kraft or soda recovery furnace, smelt dissolving tank, and lime kiln; and, using these emissions limits, determine the overall PM emission rate for the chemical recovery system at the mill using the procedures in paragraphs (a)(2)(i) through (v) of this section, such that the overall PM emission rate calculated in paragraph (a)(2)(v) of this section is less than or equal to the overall PM emission limit determined in paragraph (a)(1) of this section, as appropriate.

(i) The PM emission rate from each affected recovery furnace must be determined using Equation 2 of this section as follows:

$$ER_{RF} = (F1)(C_{EL,RF})(Q_{RF})/(BLS) \qquad (Eq.\ 2)$$

Where:

ER_{RF}=emission rate from each recovery furnace, kg/Mg (lb/ton) of black liquor solids.

F1=conversion factor, 1.44 min·kg/d·g (0.206 min·/d·gr).

$C_{EL, RF}$=PM emission limit proposed by owner or operator for the recovery furnace, g/dscm (gr/dscf) corrected to 8 percent oxygen.

Q_{RF}=average volumetric gas flow rate from the recovery furnace measured during the performance test and corrected to 8 percent oxygen, dscm/min (dscf/min).

BLS=average black liquor solids firing rate of the recovery furnace measured during the performance test, Mg/d (ton/d) of black liquor solids.

(ii) The PM emission rate from each affected smelt dissolving tank must be determined using Equation 3 of this section as follows:

$$ER_{SDT} = (F1)(C_{EL,SDT})(Q_{SDT})/(BLS) \qquad (Eq.\ 3)$$

Where:

ER_{SDT}=emission rate from each SDT, kg/Mg (lb/ton) of black liquor solids fired.

F1=conversion factor, 1.44 min·kg/d•g (0.206 min·lb/d·gr).

$C_{EL, SDT}$=PM emission limit proposed by owner or operator for the smelt dissolving tank, g/dscm (gr/dscf).

Q_{SDT}=average volumetric gas flow rate from the smelt dissolving tank measured during the performance test, dscm/min (dscf/min).

BLS=average black liquor solids firing rate of the associated recovery furnace measured during the performance test, Mg/d (ton/d) of black liquorsolids fired. If more than one SDT is used to dissolve the smelt from a given recovery furnace, then the black liquor solids firing rate of the furnace must be proportioned according to the size of the SDT.

(iii) The PM emission rate from each affected lime kiln must be determined using Equation 4 ofthis section as follows:

$$ER_{LK} = (F1)(C_{EL,LK})(Q_{LK})(CaO_{tot}/BLS_{tot})/(CaO_{LK}) \qquad (Eq.\ 4)$$

Where:

ER_{LK}=emission rate from each lime kiln, kg/Mg (lb/ton) of black liquor solids.

F1=conversion factor, 1.44 min·kg/d·g (0.206 min·lb/d·gr).

$C_{EL,LK}$=PM emission limit proposed by owner or operator for the lime kiln, g/dscm (gr/dscf) corrected to 10 percent oxygen.

Q_{LK}=average volumetric gas flow rate from the lime kiln measured during the performance test and corrected to 10 percent oxygen, dscm/min (dscf/min).

CaO_{LK}=lime production rate of the lime kiln, measured as CaO during the performance test, Mg/d (ton/d) of CaO.

CaO_{tot}=sum of the average lime production rates for all existing lime kilns in the chemical recovery system at the mill measured as CaO during the performance test, Mg/d (ton/d).

BLS_{tot}=sum of the average black liquor solids firing rates of all recovery furnaces in the chemical recovery system at the mill measured during the performance test, Mg/d (ton/d) of black liquor solids.

(iv) If more than one similar process unit is operated in the chemical recovery system at the kraft or soda pulp mill, Equation 5 ofthis section must be used to calculate the overall PM emission rate from all similar process units in the chemical recovery system at the mill and must be used in determining the overall PM emission rate for the chemical recovery system at the mill:

$$ER_{PUtot} = ER_{PU1}(PR_{PU1}/PR_{tot}) + \ldots + (ER_{PUi})(PR_{PUi}/PR_{tot}) \qquad (Eq.\ 5)$$

Where:

ER_{PUtot}=overall PM emission rate from all similar process units, kg/Mg (lb/ton) of black liquor solids fired.

ER_{PU1}=PM emission rate from process unit No. 1, kg/Mg (lb/ton) of black liquor solids fired, calculated using Equation 2, 3, or 4 in paragraphs (a)(2)(i) through (iii) of this section.

PR_{PU1}=black liquor solids firing rate in Mg/d (ton/d) for process unit No. 1, if process unit is a recovery furnace or SDT. The CaO production rate in Mg/d (ton/d) for process unit No. 1, if process unit is a lime kiln.

PR_{tot}=total black liquor solids firing rate in Mg/d (ton/d) for all recovery furnaces in the chemical recovery system at the kraft or soda pulp mill if the similar process units are recovery furnaces or SDT, or the total CaO production rate in Mg/d (ton/d) for all lime kilns in the chemical recovery system at the mill if the similar process units are lime kilns.

ER_{PUi}=PM emission rate from process unit No. i, kg/Mg (lb/ton) of black liquor solids fired.

PR_{PUi}=black liquor solids firing rate in Mg/d (ton/d) for process unit No. i, if process unit is a recovery furnace or SDT. The CaO production rate in Mg/d (ton/d) for process unit No. i, if process unit is a lime kiln.

i=number of similar process units located in the chemical recovery system at the kraft or soda pulp mill.

(v) The overall PM emission rate for the chemical recovery system at the mill must be determined using Equation 6 of this section as follows:

$$ER_{tot} = ER_{RFtot} + ER_{SDTtot} + ER_{LKtot} \qquad (Eq.\ 6)$$

Where:

ER_{tot}=overall PM emission rate for the chemical recovery system at the mill, kg/Mg (lb/ton) of black liquor solids fired.

ER_{RFtot}=PM emission rate from all kraft or soda recovery furnaces, calculated using Equation 2 or 5 in paragraphs (a)(2)(i) and (iv) of this section, where applicable, kg/Mg (lb/ton) of black liquor solids fired.

ER_{SDTtot}=PM emission rate from all smelt dissolving tanks, calculated using Equation 3 or 5 in paragraphs (a)(2)(ii) and (iv) of this section, where applicable, kg/Mg (lb/ton) of black liquor solids fired.

ER_{LKtot}=PM emission rate from all lime kilns, calculated using Equation 4 or 5 in paragraphs (a)(2)(iii) and (iv) of this section, where applicable, kg/Mg (lb/ton) of black liquor solids fired.

(vi) After the Administrator has approved the PM emissions limits for each kraft or soda recovery furnace, smelt dissolving tank, and lime kiln, the owner or operator complying with an overall PM emission limit established in §63.862(a)(1)(ii) must demonstrate compliance with the HAP metals standard by demonstrating compliance with the approved PM emissions limits for each affected kraft or soda recovery furnace, smelt dissolving tank, and lime kiln, using the test methods and procedures in paragraph (b) of this section.

(b) The owner or operator seeking to determine compliance with §63.862(a), (b), or (d) must use the procedures in paragraphs (b)(1) through (6) of this section.

(1) For purposes of determining the concentration or mass of PM emitted from each kraft or soda recovery furnace, sulfite combustion unit, smelt dissolving tank, lime kiln, or the hog fuel dryer at Weyerhaeuser Paper Company's Cosmopolis, Washington facility (Emission Unit no. HD-14), Method 5 or 29 in appendix A of 40 CFR part 60 must be used, except that Method 17 in appendix A of 40 CFR part 60 may be used in lieu of Method 5 or Method 29 if a constant value of 0.009 g/dscm (0.004 gr/dscf)

is added to the results ofMethod 17, and the stack temperature is no greater than 205 °C (400 °F). For Methods 5, 29, and 17, the sampling time and sample volume for each run must be at least 60 minutes and 0.90 dscm (31.8 dscf), and water must be used as the cleanup solvent instead of acetone in the sample recovery procedure.

(2) For sources complying with §63.862(a) or (b), the PM concentration must be corrected to the appropriate oxygen concentration using Equation 7 ofthis section as follows:

$$C_{corr} = C_{meas} \times \frac{(21-X)}{(21-Y)} \qquad \text{(Eq. 7)}$$

Where:

C_{corr}= The measured concentration corrected for oxygen, g/dscm (gr/dscf);

C_{meas}= The measured concentration uncorrected for oxygen, g/dscm (gr/dscf);

X = The corrected volumetric oxygen concentration (8 percent for kraft or soda recovery furnaces and sulfite combustion units and 10 percent for kraft or soda lime kilns); and

Y = The measured average volumetric oxygen concentration.

(3) Method 3A or 3B in appendix A of 40 CFR part 60 must be used to determine the oxygen concentration. The voluntary consensus standard ANSI/ASME PTC 19.10–1981—Part 10 (incorporated by reference—see §63.14) may be used as an alternative to using Method 3B. The gas sample must be taken at the same time and at the same traverse points as the particulate sample.

(4) For purposes ofcomplying with of §63.862(a)(1)(ii)(A), the volumetric gas flow rate must be corrected to the appropriate oxygen concentration using Equation 8 ofthis section as follows:

$Q_{corr}=Qmeas\times(21-Y)/(21-X)$ (Eq. 8)

Where:

Q_{corr}=the measured volumetric gas flow rate corrected for oxygen, dscm/min (dscf/min).

Q_{meas}=the measured volumetric gas flow rate uncorrected for oxygen, dscm/min (dscf/min).

Y=the measured average volumetric oxygen concentration.

X=the corrected volumetric oxygen concentration (8 percent for kraft or soda recovery furnaces and 10 percent for kraft or soda lime kilns).

(5)(i) For purposes ofselecting sampling port location and number of traverse points, Method 1 or 1A in appendix A of 40 CFR part 60 must be used;

(ii) For purposes ofdetermining stack gas velocity and volumetric flow rate, Method 2, 2A, 2C, 2D, 2F, or 2G in appendix A of 40 CFR part 60 must be used;

(iii) For purposes ofconducting gas analysis, Method 3, 3A, or 3B in appendixA of 40 CFR part 60 must be used. The voluntary consensus standard ANSI/ASME PTC 19.10–1981—Part 10 (incorporated by reference—see §63.14) may be used as an alternative to using Method 3B; and

(iv) For purposes ofdetermining moisture content of stack gas, Method 4 in appendix A of 40 CFR part 60 must be used.

(6) Process data measured during the performance test must be used to determine the black liquor

solids firing rate on a dry basis and the CaO production rate.

(c) The owner or operator of each affected source or process unit complying with the gaseous organic HAP standard in §63.862(c)(1) must demonstrate compliance according to the provisions in paragraphs (c)(1) and (2) of this section.

(1) The owner or operator complying through the use of an NDCE recovery furnace equipped with a dry ESP system is not required to conduct any performance testing to demonstrate compliance with the gaseous organic HAP standard.

(2) The owner or operator complying without using an NDCE recovery furnace equipped with a dry ESP system must use Method 308 in appendix A of this part, as well as the methods listed in paragraphs (b)(5)(i) through (iv) of this section. The sampling time and sample volume for each Method 308 run must be at least 60 minutes and 0.014 dscm (0.50 dscf), respectively.

(i) The emission rate from any new NDCE recovery furnace must be determined using Equation 9 of this section as follows:

$$ER_{NDCE} = \frac{(MR_{meas})}{BLS} \qquad \text{(Eq. 9)}$$

Where:

ER_{NDCE}= Methanol emission rate from the NDCE recovery furnace, kg/Mg (lb/ton) of black liquor solids fired;

MR_{meas}= Measured methanol mass emission rate from the NDCE recovery furnace, kg/hr (lb/hr); and

BLS = Average black liquor solids firing rate of the NDCE recovery furnace, megagrams per hour (Mg/hr) (tons per hour (ton/hr)) determined using process data measured during the performance test.

(ii) The emission rate from any new DCE recovery furnace system must be determined using Equation 10 of this section as follows:

$$ER_{DCE} = \left[\frac{(MR_{meas,RF})}{BLS_{RF}}\right] + \left[\frac{MR_{meas,BLO}}{BLS_{BLO}}\right] \qquad \text{(Eq. 10)}$$

Where:

ER_{DCE}= Methanol emission rate from each DCE recovery furnace system, kg/Mg (lb/ton) of black liquor solids fired;

$MR_{meas,RF}$= Average measured methanol mass emission rate from each DCE recovery furnace, kg/hr (lb/hr);

$MR_{meas,BLO}$= Average measured methanol mass emission rate from the black liquor oxidation system, kg/hr (lb/hr);

BLS_{RF}= Average black liquor solids firing rate for each DCE recovery furnace, Mg/hr (ton/hr) determined using process data measured during the performance test; and

BLS_{BLO}= The average mass rate of black liquor solids treated in the black liquor oxidation system, Mg/hr (ton/hr) determined using process data measured during the performance test.

(d) The owner or operator seeking to determine compliance with the gaseous organic HAP standards in §63.862(c)(2) for semichemical combustion units must use Method 25A in appendix A of 40 CFR part 60, as well as the methods listed in paragraphs (b)(5)(i) through (iv) of this section. The sampling time for each Method 25A run must be at least 60 minutes. The calibration gas for each Method 25A run must be propane.

(1) The emission rate from any new or existing semichemical combustion unit must be determined using Equation 11 of this section as follows:

$$ER_{SCCU} = \frac{(THC_{meas})}{BLS} \qquad (Eq.\ 11)$$

Where:

ER_{SCCU}= THC emission rate reported as carbon from each semichemical combustion unit, kg/Mg (lb/ton) of black liquor solids fired;

THC_{meas}= Measured THC mass emission rate reported as carbon, kg/hr (lb/hr); and

BLS = Average black liquor solids firing rate, Mg/hr (ton/hr); determined using process data measured during the performance test.

(2) If the owner or operator of the semichemical combustion unit has selected the percentage reduction standards for THC, under §63.862(c)(2)(ii), the percentage reduction in THC emissions is computed using Equation 12 of this section as follows, provided that Ei and Eo are measured simultaneously:

$$(\%R_{THC}) = \left(\frac{E_i - E_o}{E_i}\right) \times 100 \qquad (Eq.\ 12)$$

Where:

$\%R_{THC}$= percentage reduction of total hydrocarbons emissions achieved.

E_i= measured THC mass emission rate at the THC control device inlet, kg/hr (lb/hr).

E_o= measured THC mass emission rate at the THC control device outlet, kg/hr (lb/hr).

[66 FR 3193, Jan. 12, 2001, as amended at 66 FR 37593, July 19, 2001; 68 FR 7716, Feb. 18, 2003; 68 FR 67955, Dec. 5, 2003]

§ 63.866 Recordkeeping requirements.

(a) *Startup, shutdown, and malfunction plan.* The owner or operator must develop a written plan as described in §63.6(e)(3) that contains specific procedures for operating the source and maintaining the source during periods of startup, shutdown, and malfunction, and a program of corrective action for malfunctioning process and control systems used to comply with the standards. In addition to the information required in §63.6(e), the plan must include the requirements in paragraphs (a)(1) and (2) of this section.

(1) Procedures for responding to any process parameter level that is inconsistent with the level(s) established under §63.864(j), including the procedures in paragraphs (a)(1)(i) and (ii) of this section:

(i) Procedures to determine and record the cause of an operating parameter exceedance and the time the exceedance began and ended; and

(ii) Corrective actions to be taken in the event of an operating parameter exceedance, including

procedures for recording the actions taken to correct the exceedance.

(2) The startup, shutdown, and malfunction plan also must include the schedules listed in paragraphs (a)(2)(i) and (ii) of this section:

(i) A maintenance schedule for each control technique that is consistent with, but not limited to, the manufacturer's instructions and recommendations for routine and long-term maintenance; and

(ii) An inspection schedule for each continuous monitoring system required under §63.864 to ensure, at least once in each 24-hour period, that each continuous monitoring system is properly functioning.

(b) The owner or operator of an affected source or process unit must maintain records of any occurrence when corrective action is required under §63.864(k)(1), and when a violation is noted under §63.864(k)(2).

(c) In addition to the general records required by §63.10(b)(2), the owner or operator must maintain records of the information in paragraphs (c)(1) through (7) of this section:

(1) Records of black liquor solids firing rates in units of Mg/d or ton/d for all recovery furnaces and semichemical combustion units;

(2) Records of CaO production rates in units of Mg/d or ton/d for all lime kilns;

(3) Records of parameter monitoring data required under §63.864, including any period when the operating parameter levels were inconsistent with the levels established during the initial performance test, with a brief explanation of the cause of the deviation, the time the deviation occurred, the time corrective action was initiated and completed, and the corrective action taken;

(4) Records and documentation of supporting calculations for compliance determinations made under §§63.865(a) through (d);

(5) Records of monitoring parameter ranges established for each affected source or process unit;

(6) Records certifying that an NDCE recovery furnace equipped with a dry ESP system is used to comply with the gaseous organic HAP standard in §63.862(c)(1).

(7) For the bag leak detection system on the hog fuel dryer fabric filter at Weyerhaeuser Paper Company's Cosmopolis, Washington facility (Emission Unit no. HD–14), records of each alarm, the time of the alarm, the time corrective action was initiated and completed, and a brief description of the cause of the alarm and the corrective action taken.

(d) For operation under §63.863(c)(2), Georgia-Pacific Corporation must keep a record of the hours of operation of the two existing semichemical combustion units at their Big Island, VA facility.

[66 FR 3193, Jan. 12, 2001, as amended at 66 FR 16408, Mar. 26, 2001; 68 FR 7718, Feb. 18, 2003; 69 FR 25323, May 6, 2004; 71 FR 20458, Apr. 20, 2006]

§ 63.867 Reporting requirements.

(a) *Notifications.* (1) The owner or operator of any affected source or process unit must submit the applicable notifications from subpart A of this part, as specified in Table 1 of this subpart.

(2) Notifications specific to Georgia-Pacific Corporation's affected sources in Big Island, Virginia.

(i) For a compliance extension under §63.863(c)(1), submit a notice that provides the date of Georgia-Pacific's determination that the black liquor gasification system is not successful and the reasons why the technology is not successful. The notice must be submitted within 15 days of Georgia-Pacific's determination, but not later than March 16, 2005.

(ii) For operation under §63.863(c)(2), submit a notice providing: a statement that Georgia-Pacific Corporation intends to run the Kraft black liquor trials, the anticipated period in which the trials will take place, and a statement explaining why the trials could not be conducted prior to March 1, 2005. The

notice must be submitted at least 30 days prior to the start of the Kraft liquor trials.

(3) In addition to the requirements in subpart A of this part, the owner or operator of the hog fuel dryer at Weyerhaeuser Paper Company's Cosmopolis, Washington, facility (Emission Unit no. HD–14) must include analysis and supporting documentation demonstrating conformance with EPA guidance and specifications for bag leak detection systems in §63.864(e)(12) in the Notifcation of Compliance Status.

(b) *Additional reporting requirements for HAP metals standards.* (1) Any owner or operator of a group of process units in a chemical recovery system at a mill complying with the PM emissions limits in §63.862 (a)(1)(ii) must submit the PM emissions limits determined in §63.865(a) for each affected kraft or soda recovery furnace, smelt dissolving tank, and lime kiln to the Administrator for approval. The emissions limits must be submitted as part of the notification of compliance status required under subpart A of this part.

(2) Any owner or operator of a group of process units in a chemical recovery system at a mill complying with the PM emissions limits in §63.862(a)(1)(ii) must submit the calculations and supporting documentation used in §63.865(a)(1) and (2) to the Administrator as part of the notification of compliance status required under subpart A of this part.

(3) After the Administrator has approved the emissions limits for any process unit, the owner or operator of a process unit must notify the Administrator before any of the actions in paragraphs (b)(3)(i) through (iv) of this section are taken:

(i) The air pollution control system for any process unit is modified or replaced;

(ii) Any kraft or soda recovery furnace, smelt dissolving tank, or lime kiln in a chemical recovery system at a kraft or soda pulp mill complying with the PM emissions limits in §63.862(a)(1)(ii) is shut down for more than 60 consecutive days;

(iii) A continuous monitoring parameter or the value or range of values of a continuous monitoring parameter for any process unit is changed; or

(iv) The black liquor solids firing rate for any kraft or soda recovery furnace during any 24-hour averaging period is increased by more than 10 percent above the level measured during the most recent performance test.

(4) An owner or operator of a group of process units in a chemical recovery system at a mill complying with the PM emissions limits in §63.862(a)(1)(ii) and seeking to perform the actions in paragraph (b)(3)(i) or (ii) of this section must recalculate the overall PM emissions limit for the group of process units and resubmit the documentation required in paragraph (b)(2) of this section to the Administrator. All modified PM emissions limits are subject to approval by the Administrator.

(c) *Excess emissions report.* The owner or operator must report quarterly if measured parameters meet any of the conditions specified in paragraph (k)(1) or (2) of §63.864. This report must contain the information specified in §63.10(c) of this part as well as the number and duration of occurrences when the source met or exceeded the conditions in §63.864(k)(1), and the number and duration of occurrences when the source met or exceeded the conditions in §63.864(k)(2). Reporting excess emissions below the violation thresholds of §63.864(k) does not constitute a violation of the applicable standard.

(1) When no exceedances of parameters have occurred, the owner or operator must submit a semiannual report stating that no excess emissions occurred during the reporting period

(2) The owner or operator of an affected source or process unit subject to the requirements of this subpart and subpart S of this part may combine excess emissions and/or summary reports for the mill.

[66 FR 3193, Jan. 12, 2001 as amended at 66 FR 16408, Mar. 26, 2001; 68 FR 7718, Feb. 18, 2003; 68 FR 42605, July 18, 2003; 68 FR 46108, Aug. 5, 2003; 69 FR 25323, May 6, 2004]

§ 63.868 Delegation of authority.

(a) In delegating implementation and enforcement authority to a State under section 112(d) of the Clean Air Act, the authorities contained in paragraph (b) of this section must be retained by the Administrator

and not transferred to a State.

(b) The authorities which will not be delegated to States are listed in paragraphs (b)(1) through (4) of this section:

(1) Approval of alternatives to standards in §63.862 under §63.6(g).

(2) Approval of major alternatives to test methods under §63.7(e)(2)(ii) and (f) and as defined in §63.90.

(3) Approval of major alternatives to monitoring under §63.8(f) and as defined in §63.90.

(4) Approval of major alternatives to recordkeeping and reporting under §63.10(f) and as defined in §63.90.

Table 1 to Subpart MM of Part 63—General Provisions Applicability to Subpart MM

General provisions reference	Summary of requirements	Applies to supbart MM	Explanation
63.1(a)(1)	General applicability of the General Provisions	Yes	Additional terms defined in §63.861; when overlap between subparts A and MM of this part, subpart MM takes precedence.
63.1(a)(2)–(14)	General applicability of the General Provisions	Yes	
63.1(b)(1)	Initial applicability determination.	No.	Subpart MM specifies the applicability in §63.860.
63.1(b)(2)	Title V operating permit—see 40 CFR part 70	Yes	All major affected sources are required to obtain a title V permit.
63.1(b)(3)	Record of the applicability determination	No	All affected sources are subject to subpart MM according to the applicability definition of subpart MM.
63.1(c)(1)	Applicability of subpart A of this part after a relevant standard has been set	Yes	Subpart MM clarifies the applicability of each paragraph of subpart A of this part to sources subject to subpart MM.
63.1(c)(2)	Title V permit requirement	Yes	All major affected

			sources are required to obtain a title V permit. There are no area sources in the pulp and paper mill source category.
63.1(c)(3)	[Reserved]	NA.	
63.1(c)(4)	Requirements for existing source that obtains an extension of compliance	Yes	
63.1(c)(5)	Notification requirements for an area source that increases HAP emissions to major source levels	Yes	
63.1(d)	[Reserved]	NA	
63.1(e)	Applicability of permit program before a relevant standard has been set	Yes	
63.2	Definitions	Yes	Additional terms defined in §63.861; when overlap between subparts A and MM of this part occurs, subpart MM takes precedence.
63.3	Units and abbreviations	Yes	
63.4	Prohibited activities and circumvention	Yes	
63.5(a)	Construction and reconstruction—applicability	Yes	
63.5(b)(1)	Upon construction, relevant standards for new sources	Yes	
63.5(b)(2)	[Reserved]	NA	
63.5(b)(3)	New construction/reconstruction	Yes	
63.5(b)(4)	Construction/reconstruction notification	Yes	
63.5(b)(5)	Construction/reconstruction compliance	Yes	
63.5(b)(6)	Equipment addition or process change	Yes	
63.5(c)	[Reserved]	NA	
63.5(d)	Application for approval of construction/reconstruction	Yes	
63.5(e)	Construction/reconstruction approval	Yes	

63.5(f)	Construction/reconstruction approval based on prior State preconstruction review	Yes	
63.6(a)(1)	Compliance with standards and maintenance requirements—applicability	Yes	
63.6(a)(2)	Requirements for area source that increases emissions to become major	Yes	
63.6(b)	Compliance dates for new and reconstructed sources	Yes	
63.6(c)	Compliance dates for existing sources	Yes, except for sources granted extensions under 63.863(c)	Subpart MM specifically stipulates the compliance schedule for existing sources.
63.6(d)	[Reserved]	NA	
63.6(e)	Operation and maintenance requirements	Yes	
63.6(f)	Compliance with nonopacity emissions standards	Yes	
63.6(g)	Compliance with alternative nonopacity emissions standards	Yes	
63.6(h)	Compliance with opacity and visible emissions (VE) standards	Yes	Subpart MM does not contain any opacity or VE standards; however, §63.864 specifies opacity monitoring requirements.
63.6(i)	Extension of compliance with emission standards	Yes, except for sources granted extensions under 63.863(c)	
63.6(j)	Exemption from compliance with emissions standards	Yes	
63.7(a)(1)	Performance testing requirements—applicability	Yes	§63.865(c)(1) specifies the only exemption from performance testing allowed under subpart MM.
63.7(a)(2)	Performance test dates	Yes	

63.7(a)(3)	Performance test requests by Administrator under CAA section 114	Yes	
63.7(b)(1)	Notification of performance test	Yes	
63.7(b)(2)	Notification of delay in conducting a scheduled performance test	Yes	
63.7(c)	Quality assurance program	Yes	
63.7(d)	Performance testing facilities	Yes	
63.7(e)	Conduct of performance tests	Yes	
63.7(f)	Use of an alternative test method	Yes	
63.7(g)	Data analysis, recordkeeping, and reporting	Yes	
63.7(h)	Waiver of performance tests	Yes	§63.865(c)(1) specifies the only exemption from performance testing allowed under subpart MM.
63.8(a)	Monitoring requirements—applicability	Yes	See §63.864.
63.8(b)	Conduct of monitoring	Yes	See §63.864.
63.8(c)	Operation and maintenance of CMS	Yes	See §63.864.
63.8(d)	Quality control program	Yes	See §63.864.
63.8(e)(1)	Performance evaluation of CMS	Yes	
63.8(e)(2)	Notification of performance evaluation	Yes	
63.8(e)(3)	Submission of site-specific performance evaluation test plan	Yes	
63.8(e)(4)	Conduct of performance evaluation and performance evaluation dates	Yes	
63.8(e)(5)	Reporting performance evaluation results	Yes	
63.8(f)	Use of an alternative monitoring method	Yes	
63.8(g)	Reduction of monitoring data	Yes	
63.9(a)	Notification requirements—applicability and general information	Yes	
63.9(b)	Initial notifications	Yes	
63.9(c)	Request for extension of	Yes	

	compliance		
63.9(d)	Notification that source subject to special compliance requirements	Yes	
63.9(e)	Notification of performance test	Yes	
63.9(f)	Notification of opacity and VE observations	Yes	Subpart MM does not contain any opacity or VE standards; however, §63.864 specifies opacity monitoring requirements.
63.9(g)(1)	Additional notification requirements for sources with CMS	Yes	
63.9(g)(2)	Notification of compliance with opacity emissions standard	Yes	Subpart MM does not contain any opacity or VE emissions standards; however, §63.864 specifies opacity monitoring requirements.
63.9(g)(3)	Notification that criterion to continue use of alternative to relative accuracy testing has been exceeded	Yes	
63.9(h)	Notification of compliance status	Yes	
63.9(i)	Adjustment to time periods or postmark deadlines for submittal and review of required communications	Yes	
63.9(j)	Change in information already provided	Yes	
63.10(a)	Recordkeeping requirements—applicability and general information	Yes	See §63.866.
63.10(b)(1)	Records retention	Yes	
63.10(b)(2)	Information and documentation to support notifications and demonstrate compliance	Yes	
63.10(b)(3)	Records retention for sources not subject to relevant standard	Yes	Applicability requirements are given in §63.860.

63.10(c)	Additional recordkeeping requirements for sources with CMS.	Yes	
63.10(d)(1)	General reporting requirements	Yes	
63.10(d)(2)	Reporting results of performance tests	Yes	
63.10(d)(3)	Reporting results of opacity or VE observations	Yes	Subpart MM does not include any opacity or VE standards; however, §63.864 specifies opacity monitoring requirements.
63.10(d)(4)	Progress reports	Yes	
63.10(d)(5)	Periodic and immediate startup, shutdown, and malfunction reports	Yes	
63.10(e)	Additional reporting requirements for sources with CMS	Yes	
63.10(f)	Waiver of recordkeeping and reporting requirements	Yes	
63.11	Control device requirements for flares	No	The use of flares to meet the standards in subpart MM is not anticipated.
63.12	State authority and delegations	Yes	
63.13	Addresses of State air pollution control agencies and EPA Regional Offices	Yes	
63.14	Incorporations by reference	Yes	
63.15	Availability of information and confidentiality	Yes	

[66 FR 3193, Jan. 12, 2001, as amended at 66 FR 16408, Mar. 26, 2001]

Browse Previous | Browse Next

For questions or comments regarding e-CFR editorial content, features, or design, email ecfr@nara.gov.

For questions concerning e-CFR programming and delivery issues, email webteam@gpo.gov.

Section 508 / Accessibility

UNITED STATES ENVIRONMENTAL PROTECTION AGENCY
REGION 6
1445 ROSS AVENUE, SUITE 1200
DALLAS, TX 75202-2733

FEB 1 1 2004

Charles E. Hodges
Senior Vice President
Manufacturing Southern Region
Georgia-Pacific
Crossett Paper Operations
P.O. Box 3333
Crossett, Arkansas 71635

RE: Alternative Monitoring Request for Pulp Washing System (Chemiwashers) located at Georgia-Pacific Corporation's Crossett Paper Operations

Dear Mr. Hodges:

This is in response to your letter dated August 18, 2003, regarding a 40 CFR 63 Subpart S request for the use of alternative monitoring for the pulp washing systems subject to § 63.443(a)(1)(iii). The Georgia-Pacific (G-P) Crossett Paper Operations Mill, located in Crossett, Arkansas, is subject to the Maximum Achievable Control Technology (MACT) standards regulations for the pulp and paper industry, promulgated at 40 CFR Part 63, Subpart S.

One requirement of Subpart S is to control hazardous air pollutant (HAP) emissions from pulp washing systems (40 CFR 63.443(a)(1)(iii)). In your letter, you describe the pulp washing system used at the Crossett Mill, which consists of two Chemiwashers. These Chemiwashers are flat, belt-type washers rather than conventional drum washers. The washers pull a vacuum on the wire (or belt), pulling the wash water, black liquor, and air through the pulp. The air is separated in the washer and recycled back into the enclosing hood over the wire. The manufacturer designed the Chemiwashers as closed systems, and therefore, collection and incineration of emissions from these units are not required under Subpart S since there are no discreet emission points. However, you point out in your letter that even though the washing system is essentially closed, there are, however, minor fugitive leaks of steam around the feed and exit roll seals and along the side gaskets.

Subpart S does require monitoring of the closed vent collection system for visual defects at least every 30 days (40 CFR 63.453(k)(2)) and instrumental monitoring for "detectable leaks" using Method 21 annually (40 CFR 63.453(k)(3)). 40 CFR 63.453(k) further requires that "visual defects" (in ductwork, piping, etc.) and detectable leaks (i.e., those greater than 500 parts per million (ppm) as measured by Method 21) be repaired within a specific timeframe.

According to your letter, G-P Crossett conducted preliminary testing of the minor fugitive leaks found around the feed and exit roll seals and along the side gaskets of the Chemiwashers using EPA Method 21 and had found that all were well under 500 ppm. Based upon these tests, you believe that the closed Chemiwasher systems at the Crossett facility do meet the 500 ppm limit, and have no "detectable leaks", even though there are minor visible emissions.

Therefore, G-P Crossett is requesting an alternative monitoring parameter for the closed vent system visual inspections by proposing to conduct monthly testing of the Chemiwashers using EPA Method 21 in lieu of the requirement to demonstrate monthly that there are no visual defects. Any leaks greater than 500 ppm that are detected during these monthly tests will be repaired as outlined in 40 CFR 63.453(k)(6).

Based upon the information supplied in your letter dated August 18, 2003, EPA Region 6 approves your request to conduct monthly Method 21 monitoring, in lieu of monthly visual monitoring, of the fugitive leaks found around the feed and exit roll seals and along the side gaskets of the Chemiwashers. However, you are still required to satisfy all of the other applicable monitoring and recordkeeping requirements of Subpart S.

If you have any questions regarding this alternative monitoring parameter approval, please feel free to contact Ms. Michelle Kelly, of my staff, at (214) 665-7580.

Sincerely yours,

William K. Honker, P.E.
Chief
Air/Toxics and Inspection
Coordination Branch

cc: Tom Hudson, ADEQ
Anna Hubbard, ADEQ
Tom Rheaume, ADEQ

Electronic Code of Federal Regulations
e-CFR™

e-CFR Data is current as of May 12, 2011

Title 40: Protection of Environment

PART 63—NATIONAL EMISSION STANDARDS FOR HAZARDOUS AIR POLLUTANTS FOR SOURCE CATEGORIES (CONTINUED)

Browse Previous | Browse Next

Subpart JJJJ—National Emission Standards for Hazardous Air Pollutants: Paper and Other Web Coating

Source: 67 FR 72341, Dec. 4, 2002, unless otherwise noted.

What This Subpart Covers

§ 63.3280 What is in this subpart?

This subpart describes the actions you must take to reduce emissions of organic hazardous air pollutants (HAP) from paper and other web coating operations. This subpart establishes emission standards for web coating lines and specifies what you must do to comply if you own or operate a facility with web coating lines that is a major source of HAP. Certain requirements apply to all who are subject to this subpart; others depend on the means you use to comply with an emission standard.

§ 63.3290 Does this subpart apply to me?

The provisions of this subpart apply to each new and existing facility that is a major source of HAP, as defined in §63.2, at which web coating lines are operated.

§ 63.3300 Which of my emission sources are affected by this subpart?

The affected source subject to this subpart is the collection of all web coating lines at your facility. This includes web coating lines engaged in the coating of metal webs that are used in flexible packaging, and web coating lines engaged in the coating of fabric substrates for use in pressure sensitive tape and abrasive materials. Web coating lines specified in paragraphs (a) through (g) of this section are not part of the affected source of this subpart.

(a) Any web coating line that is stand-alone equipment under subpart KK of this part (National Emission Standards for the Printing and Publishing Industry) which the owner or operator includes in the affected source under subpart KK.

(b) Any web coating line that is a product and packaging rotogravure or wide-web flexographic press under subpart KK of this part (national emission standards for the printing and publishing industry) which is included in the affected source under subpart KK.

(c) Web coating in lithography, screenprinting, letterpress, and narrow-web flexographic printing processes.

(d) Any web coating line subject to subpart EE of this part (national emission standards for magnetic tape manufacturing operations).

(e) Any web coating line that will be subject to the national emission standards for hazardous air pollutants (NESHAP) for surface coating of metal coil currently under development.

(f) Any web coating line that will be subject to the NESHAP for the printing, coating, and dyeing of fabric and other textiles currently under development. This would include any web coating line that coats both a paper or other web substrate and a fabric or other textile substrate, except for a fabric substrate used for pressure sensitive tape and abrasive materials.

(g) Any web coating line that is defined as research or laboratory equipment in §63.3310.

[67 FR 72341, Dec. 4, 2002, as amended at 71 FR 29805, May 24, 2006]

§ 63.3310 What definitions are used in this subpart?

All terms used in this subpart that are not defined in this section have the meaning given to them in the Clean Air Act (CAA) and in subpart A of this part.

Always-controlled work station means a work station associated with a dryer from which the exhaust is delivered to a control device with no provision for the dryer exhaust to bypass the control device unless there is an interlock to interrupt and prevent continued coating during a bypass. Sampling lines for analyzers, relief valves needed for safety purposes, and periodic cycling of exhaust dampers to ensure safe operation are not considered bypass lines.

Applied means, for the purposes of this subpart, the amount of organic HAP, coating material, or coating solids (as appropriate for the emission standards in §63.3320(b)) used by the affected source during the compliance period.

As-applied means the condition of a coating at the time of application to a substrate, including any added solvent.

As-purchased means the condition of a coating as delivered to the user.

Capture efficiency means the fraction of all organic HAP emissions generated by a process that is delivered to a control device, expressed as a percentage.

Capture system means a hood, enclosed room, or other means of collecting organic HAP emissions into a closed-vent system that exhausts to a control device.

Car-seal means a seal that is placed on a device that is used to change the position of a valve or damper (*e.g.,* from open to closed) in such a way that the position of the valve or damper cannot be changed without breaking the seal.

Coating material(s) means all inks, varnishes, adhesives, primers, solvents, reducers, and other coating materials applied to a substrate via a web coating line. Materials used to form a substrate are not considered coating materials.

Control device means a device such as a solvent recovery device or oxidizer which reduces the organic HAP in an exhaust gas by recovery or by destruction.

Control device efficiency means the ratio of organic HAP emissions recovered or destroyed by a control device to the total organic HAP emissions that are introduced into the control device, expressed as a percentage.

Day means a 24-consecutive-hour period.

Deviation means any instance in which an affected source, subject to this subpart, or an owner or operator of such a source:

(1) Fails to meet any requirement or obligation established by this subpart including, but not limited to, any emission limitation (including any operating limit) or work practice standard;

(2) Fails to meet any term or condition that is adopted to implement an applicable requirement in this

subpart and that is included in the operating permit for any affected source required to obtain such a permit; or

(3) Fails to meet any emission limitation (including any operating limit) or work practice standard in this subpart during start-up, shutdown, or malfunction, regardless of whether or not such failure is permitted by this subpart.

Existing affected source means any affected source the construction or reconstruction of which is commenced on or before September 13, 2000, and has not undergone reconstruction as defined in §63.2.

Fabric means any woven, knitted, plaited, braided, felted, or non-woven material made of filaments, fibers, or yarns including thread. This term includes material made of fiberglass, natural fibers, synthetic fibers, or composite materials.

Facility means all contiguous or adjoining property that is under common ownership or control, including properties that are separated only by a road or other public right-of-way.

Flexible packaging means any package or part of a package the shape of which can be readily changed. Flexible packaging includes, but is not limited to, bags, pouches, labels, liners and wraps utilizing paper, plastic, film, aluminum foil, metalized or coated paper or film, or any combination of these materials.

Formulation data means data on the organic HAP mass fraction, volatile matter mass fraction, or coating solids mass fraction of a material that is generated by the manufacturer or means other than a test method specified in this subpart or an approved alternative method.

HAP means hazardous air pollutants.

HAP applied means the organic HAP content of all coating materials applied to a substrate by a web coating line at an affected source.

Intermittently-controlled work station means a work station associated with a dryer with provisions for the dryer exhaust to be delivered to or diverted from a control device through a bypass line, depending on the position of a valve or damper. Sampling lines for analyzers, relief valves needed for safety purposes, and periodic cycling of exhaust dampers to ensure safe operation are not considered bypass lines.

Metal coil means a continuous metal strip that is at least 0.15 millimeter (0.006 inch) thick which is packaged in a roll or coil prior to coating. After coating, it may or may not be rewound into a roll or coil. Metal coil does not include metal webs that are coated for use in flexible packaging.

Month means a calendar month or a pre-specified period of 28 days to 35 days to allow for flexibility in recordkeeping when data are based on a business accounting period.

Never-controlled work station means a work station that is not equipped with provisions by which any emissions, including those in the exhaust from any associated dryer, may be delivered to a control device.

New affected source means any affected source the construction or reconstruction of which is commenced after September 13, 2000.

Overall organic HAP control efficiency means the total efficiency of a capture and control system.

Pressure sensitive tape means a flexible backing material with a pressure-sensitive adhesive coating on one or both sides of the backing. Examples include, but are not limited to, duct/duct insulation tape and medical tape.

Research or laboratory equipment means any equipment for which the primary purpose is to conduct research and development into new processes and products where such equipment is operated under the close supervision of technically trained personnel and is not engaged in the manufacture of products for commercial sale in commerce except in a *de minimis* manner.

Rewind or cutting station means a unit from which substrate is collected at the outlet of a web coating line.

Uncontrolled coating line means a coating line consisting of only never-controlled work stations.

Unwind or feed station means a unit from which substrate is fed to a web coating line.

Web means a continuous substrate (*e.g.,* paper, film, foil) which is flexible enough to be wound or unwound as rolls.

Web coating line means any number of work stations, of which one or more applies a continuous layer of coating material across the entire width or any portion of the width of a web substrate, and any associated curing/drying equipment between an unwind or feed station and a rewind or cutting station.

Work station means a unit on a web coating line where coating material is deposited onto a web substrate.

Emission Standards and Compliance Dates

§ 63.3320 What emission standards must I meet?

(a) If you own or operate any affected source that is subject to the requirements of this subpart, you must comply with these requirements on and after the compliance dates as specified in §63.3330.

(b) You must limit organic HAP emissions to the level specified in paragraph (b)(1), (2), (3), or (4) of this section.

(1) No more than 5 percent of the organic HAP applied for each month (95 percent reduction) at existing affected sources, and no more than 2 percent of the organic HAP applied for each month (98 percent reduction) at new affected sources; or

(2) No more than 4 percent of the mass of coating materials applied for each month at existing affected sources, and no more than 1.6 percent of the mass of coating materials applied for each month at new affected sources; or

(3) No more than 20 percent of the mass of coating solids applied for each month at existing affected sources, and no more than 8 percent of the coating solids applied for each month at new affected sources.

(4) If you use an oxidizer to control organic HAP emissions, operate the oxidizer such that an outlet organic HAP concentration of no greater than 20 parts per million by volume (ppmv) by compound on a dry basis is achieved and the efficiency of the capture system is 100 percent.

(c) You must demonstrate compliance with this subpart by following the procedures in §63.3370.

§ 63.3321 What operating limits must I meet?

(a) For any web coating line or group of web coating lines for which you use add-on control devices, unless you use a solvent recovery system and conduct a liquid-liquid material balance, you must meet the operating limits specified in Table 1 to this subpart or according to paragraph (b) of this section. These operating limits apply to emission capture systems and control devices, and you must establish the operating limits during the performance test according to the requirements in §63.3360(e)(3). You must meet the operating limits at all times after you establish them.

(b) If you use an add-on control device other than those listed in Table 1 to this subpart or wish to monitor an alternative parameter and comply with a different operating limit, you must apply to the Administrator for approval of alternative monitoring under §63.8(f).

§ 63.3330 When must I comply?

(a) If you own or operate an existing affected source subject to the provisions of this subpart, you must comply by the compliance date. The compliance date for existing affected sources in this subpart is December 5, 2005. You must complete any performance test required in §63.3360 within the time limits specified in §63.7(a)(2).

(b) If you own or operate a new affected source subject to the provisions of this subpart, your compliance date is immediately upon start-up of the new affected source or by December 4, 2002, whichever is later. You must complete any performance test required in §63.3360 within the time limits specified in §63.7(a)(2).

(c) If you own or operate a reconstructed affected source subject to the provisions of this subpart, your compliance date is immediately upon startup of the affected source or by December 4, 2002, whichever is later. Existing affected sources which have undergone reconstruction as defined in §63.2 are subject to the requirements for new affected sources. The costs associated with the purchase and installation of air pollution control equipment are not considered in determining whether the existing affected source has been reconstructed. Additionally, the costs of retrofitting and replacing of equipment that is installed specifically to comply with this subpart are not considered reconstruction costs. You must complete any performance test required in §63.3360 within the time limits specified in §63.7(a)(2).

General Requirements for Compliance With the Emission Standards and for Monitoring and Performance Tests

§ 63.3340 What general requirements must I meet to comply with the standards?

Table 2 to this subpart specifes the provisions of subpart A of this part that apply if you are subject to this subpart, such as startup, shutdown, and malfunction plans (SSMP) in §63.6(e)(3) for affected sources using a control device to comply with the emission standards.

§ 63.3350 If I use a control device to comply with the emission standards, what monitoring must I do?

(a) A summary of monitoring you must do follows:

If you operate a web coating line, and have the following:	Then you must:
(1) Intermittently-controlled work stations	Record parameters related to possible exhaust flow bypass of control device and to coating use (§63.3350(c)).
(2) Solvent recovery unit	Operate continuous emission monitoring system and perform quarterly audits or determine volatile matter recovered and conduct a liquid-liquid material balance (§63.3350(d)).
(3) Control Device	Operate continuous parameter monitoring system (§63.3350(e)).
(4) Capture system	Monitor capture system operating parameter (§63.3350(f)).

(b) Following the date on which the initial performance test of a control device is completed to demonstrate continuing compliance with the standards, you must monitor and inspect each capture system and each control device used to comply with §63.3320. You must install and operate the monitoring equipment as specified in paragraphs (c) and (f) of this section.

(c) *Bypass and coating use monitoring.* If you own or operate web coating lines with intermittently-controlled work stations, you must monitor bypasses of the control device and the mass of each coating material applied at the work station during any such bypass. If using a control device for complying with the requirements of this subpart, you must demonstrate that any coating material applied on a never-controlled work station or an intermittently-controlled work station operated in bypass mode is allowed in your compliance demonstration according to §63.3370(n) and (o). The bypass monitoring must be conducted using at least one of the procedures in paragraphs (c)(1) through (4) of this section for each work station and associated dryer.

(1) *Flow control position indicator.* Install, calibrate, maintain, and operate according to the

manufacturer's specifications a flow control position indicator that provides a record indicating whether the exhaust stream from the dryer was directed to the control device or was diverted from the control device. The time and flow control position must be recorded at least once per hour as well as every time the flow direction is changed. A flow control position indicator must be installed at the entrance to any bypass line that could divert the exhaust stream away from the control device to the atmosphere.

(2) *Car-seal or lock-and-key valve closures.* Secure any bypass line valve in the closed position with a car-seal or a lock-and-key type configuration. A visual inspection of the seal or closure mechanism must be performed at least once every month to ensure that the valve or damper is maintained in the closed position, and the exhaust stream is not diverted through the bypass line.

(3) *Valve closure continuous monitoring.* Ensure that any bypass line valve or damper is in the closed position through continuous monitoring of valve position when the emission source is in operation and is using a control device for compliance with the requirements of this subpart. The monitoring system must be inspected at least once every month to verify that the monitor will indicate valve position.

(4) *Automatic shutdown system.* Use an automatic shutdown system in which the web coating line is stopped when flow is diverted away from the control device to any bypass line when the control device is in operation. The automatic system must be inspected at least once every month to verify that it will detect diversions of flow and would shut down operations in the event of such a diversion.

(d) *Solvent recovery unit.* If you own or operate a solvent recovery unit to comply with §63.3320, you must meet the requirements in either paragraph (d)(1) or (2) of this section depending on how control efficiency is determined.

(1) *Continuous emission monitoringsystem (CEMS).* If you are demonstrating compliance with the emission standards in §63.3320 through continuous emission monitoring of a control device, you must install, calibrate, operate, and maintain the CEMS according to paragraphs (d)(1)(i) through (iii) of this section.

(i) Measure the total organic volatile matter mass flow rate at both the control device inlet and the outlet such that the reduction efficiency can be determined. Each continuous emission monitor must comply with performance specification 6, 8, or 9 of 40 CFR part 60, appendix B, as appropriate.

(ii) You must follow the quality assurance procedures in procedure 1, appendix F of 40 CFR part 60. In conducting the quarterly audits of the monitors as required by procedure 1, appendix F, you must use compounds representative of the gaseous emission stream being controlled.

(iii) You must have valid data from at least 90 percent of the hours during which the process is operated.

(2) *Liquid-liquid material balance.* If you are demonstrating compliance with the emission standards in §63.3320 through liquid-liquid material balance, you must install, calibrate, maintain, and operate according to the manufacturer's specifications a device that indicates the cumulative amount of volatile matter recovered by the solvent recovery device on a monthly basis. The device must be certified by the manufacturer to be accurate to within ±2.0 percent by mass.

(e) *Continuous parameter monitoring system (CPMS).* If you are using a control device to comply with the emission standards in §63.3320, you must install, operate, and maintain each CPMS specified in paragraphs (e)(9) and (10) and (f) of this section according to the requirements in paragraphs (e)(1) through (8) of this section. You must install, operate, and maintain each CPMS specified in paragraph (c) of this section according to paragraphs (e)(5) through (7) of this section.

(1) Each CPMS must complete a minimum of one cycle of operation for each successive 15-minute period. You must have a minimum of four equally spaced successive cycles of CPMS operation to have a valid hour of data.

(2) You must have valid data from at least 90 percent of the hours during which the process operated.

(3) You must determine the hourly average of all recorded readings according to paragraphs (e)(3)(i) and (ii) of this section.

(i) To calculate a valid hourly value, you must have at least three of four equally spaced data values from that hour from a continuous monitoring system (CMS) that is not out-of-control.

(ii) Provided all of the readings recorded in accordance with paragraph (e)(3) of this section clearly demonstrate continuous compliance with the standard that applies to you, then you are not required to determine the hourly average of all recorded readings.

(4) You must determine the rolling 3-hour average of all recorded readings for each operating period. To calculate the average for each 3-hour averaging period, you must have at least two of three of the hourly averages for that period using only average values that are based on valid data (*i.e.,* not from out-of-control periods).

(5) You must record the results of each inspection, calibration, and validation check of the CPMS.

(6) At all times, you must maintain the monitoring system in proper working order including, but not limited to, maintaining necessary parts for routine repairs of the monitoring equipment.

(7) Except for monitoring malfunctions, associated repairs, or required quality assurance or control activities (including calibration checks or required zero and span adjustments), you must conduct all monitoring at all times that the unit is operating. Data recorded during monitoring malfunctions, associated repairs, out-of-control periods, or required quality assurance or control activities shall not be used for purposes of calculating the emissions concentrations and percent reductions specified in §63.3370. You must use all the valid data collected during all other periods in assessing compliance of the control device and associated control system. A monitoring malfunction is any sudden, infrequent, not reasonably preventable failure of the monitoring system to provide valid data. Monitoring failures that are caused in part by poor maintenance or careless operation are not malfunctions.

(8) Any averaging period for which you do not have valid monitoring data and such data are required constitutes a deviation, and you must notify the Administrator in accordance with §63.3400(c).

(9) *Oxidizer.* If you are using an oxidizer to comply with the emission standards, you must comply with paragraphs (e)(9)(i) through (iii) of this section.

(i) Install, calibrate, maintain, and operate temperature monitoring equipment according to the manufacturer's specifications. The calibration of the chart recorder, data logger, or temperature indicator must be verified every 3 months or the chart recorder, data logger, or temperature indicator must be replaced. You must replace the equipment whether you choose not to perform the calibration or the equipment cannot be calibrated properly.

(ii) For an oxidizer other than a catalytic oxidizer, install, calibrate, operate, and maintain a temperature monitoring device equipped with a continuous recorder. The device must have an accuracy of ±1 percent of the temperature being monitored in degrees Celsius, or ±1 °Celsius, whichever is greater. The thermocouple or temperature sensor must be installed in the combustion chamber at a location in the combustion zone.

(iii) For a catalytic oxidizer, install, calibrate, operate, and maintain a temperature monitoring device equipped with a continuous recorder. The device must be capable of monitoring temperature with an accuracy of ±1 percent of the temperature being monitored in degrees Celsius or ±1 degree Celsius, whichever is greater. The thermocouple or temperature sensor must be installed in the vent stream at the nearest feasible point to the inlet and outlet of the catalyst bed. Calculate the temperature rise across the catalyst.

(10) *Other types of control devices.* If you use a control device other than an oxidizer or wish to monitor an alternative parameter and comply with a different operating limit, you must apply to the Administrator for approval of an alternative monitoring method under §63.8(f).

(f) *Capture system monitoring.* If you are complying with the emission standards in §63.3320 through the use of a capture system and control device for one or more web coating lines, you must develop a site-specific monitoring plan containing the information specified in paragraphs (f)(1) and (2) of this section for these capture systems. You must monitor the capture system in accordance with paragraph (f)(3) of this section. You must make the monitoring plan available for inspection by the permitting authority upon request.

(1) The monitoring plan must:

(i) Identify the operating parameter to be monitored to ensure that the capture eficiency determined during the initial compliance test is maintained; and

(ii) Explain why this parameter is appropriate for demonstrating ongoing compliance; and

(iii) Identify the specific monitoring procedures.

(2) The monitoring plan must specify the operating parameter value or range of values that demonstrate compliance with the emission standards in §63.3320. The specified operating parameter value or range of values must represent the conditions present when the capture system is being properly operated and maintained.

(3) You must conduct all capture system monitoring in accordance with the plan.

(4) Any deviation from the operating parameter value or range of values which are monitored according to the plan will be considered a deviation from the operating limit.

(5) You must review and update the capture system monitoring plan at least annually

§ 63.3360 What performance tests must I conduct?

(a) The performance test methods you must conduct are as follows:

If you control organic HAP on any individual web coating line or any group of web coating lines by:	You must:
(1) Limiting organic HAP or volatile matter content of coatings	Determine the organic HAP or volatile matter and coating solids content of coating materials according to procedures in §63.3360(c) and (d). If applicable, determine the mass of volatile matter retained in the coated web or otherwise not emitted to the atmosphere according to §63.3360(g).
(2) Using a capture and control system	Conduct a performance test for each capture and control system to determine: the destruction or removal efficiency of each control device other than solvent recovery according to §63.3360(e), and the capture efficiency of each capture system according to §63.3360(f). If applicable, determine the mass of volatile matter retained in the coated web or otherwise not emitted to the atmosphere according to §63.3360 (g).

(b) If you are using a control device to comply with the emission standards in §63.3320, you are not required to conduct a performance test to demonstrate compliance if one or more of the criteria in paragraphs (b)(1) through (3) of this section are met.

(1) The control device is equipped with continuous emission monitors for determining inlet and outlet total organic volatile matter concentration and capture efficiency has been determined in accordance with the requirements of this subpart such that an overall organic HAP control efficiency can be calculated, and the continuous emission monitors are used to demonstrate continuous compliance in accordance with §63.3350; or

(2) You have met the requirements of §63.7(h) (for waiver of performance testing; or

(3) The control device is a solvent recovery system and you comply by means of a monthly liquid-liquid material balance.

(c) *Organic HAP content.* If you determine compliance with the emission standards in §63.3320 by means other than determining the overall organic HAP control efficiency of a control device, you must determine the organic HAP mass fraction of each coating material "as-purchased" by following one of the procedures in paragraphs (c)(1) through (3) of this section, and determine the organic HAP mass fraction of each coating material "as-applied" by following the procedures in paragraph (c)(4) of this section. If the organic HAP content values are not determined using the procedures in paragraphs (c)(1) through (3) of this section, the owner or operator must submit an alternative test method for determining their values for approval by the Administrator in accordance with §63.7(f). The recovery efficiency of the test method must be determined for all of the target organic HAP and a correction factor, if necessary, must be determined and applied.

(1) *Method 311.* You may test the coating material in accordance with Method 311 of appendix A of this part. The Method 311 determination may be performed by the manufacturer of the coating material and the results provided to the owner or operator. The organic HAP content must be calculated according to the criteria and procedures in paragraphs (c)(1)(i) through (iii) of this section.

(i) Include each organic HAP determined to be present at greater than or equal to 0.1 mass percent for Occupational Safety and Health Administration (OSHA)-defined carcinogens as specifed in 29 CFR 1910.1200(d)(4) and greater than or equal to 1.0 mass percent for other organic HAP compounds.

(ii) Express the mass fraction of each organic HAP you include according to paragraph (c)(1)(i) of this section as a value truncated to four places after the decimal point (for example, 0.3791).

(iii) Calculate the total mass fraction of organic HAP in the tested material by summing the counted individual organic HAP mass fractions and truncating the result to three places after the decimal point (for example, 0.763).

(2) *Method 24.* For coatings, determine the volatile organic content as mass fraction of nonaqueous volatile matter and use it as a substitute for organic HAP using Method 24 of 40 CFR part 60, appendix A. The Method 24 determination may be performed by the manufacturer of the coating and the results provided to you.

(3) *Formulation data.* You may use formulation data to determine the organic HAP mass fraction of a coating material. Formulation data may be provided to the owner or operator by the manufacturer of the material. In the event of an inconsistency between Method 311 (appendix A of 40 CFR part 63) test data and a facility's formulation data, and the Method 311 test value is higher, the Method 311 data will govern. Formulation data may be used provided that the information represents all organic HAP present at a level equal to or greater than 0.1 percent for OSHA-defined carcinogens as specified in 29 CFR 1910.1200(d)(4) and equal to or greater than 1.0 percent for other organic HAP compounds in any raw material used.

(4) *As-applied organic HAP mass fraction* If the as-purchased coating material is applied to the web without any solvent or other material added, then the as-applied organic HAP mass fraction is equal to the as-purchased organic HAP mass fraction. Otherwise, the as-applied organic HAP mass fraction must be calculated using Equation 1a of §63.3370.

(d) *Volatile organic and coating solids content.* If you determine compliance with the emission standards in §63.3320 by means other than determining the overall organic HAP control efficiency of a control device and you choose to use the volatile organic content as a surrogate for the organic HAP content of coatings, you must determine the as-purchased volatile organic content and coating solids content of each coating material applied by following the procedures in paragraph (d)(1) or (2) of this section, and the as-applied volatile organic content and coating solids content of each coating material by following the procedures in paragraph (d)(3) of this section.

(1) *Method 24.* You may determine the volatile organic and coating solids mass fraction of each coating applied using Method 24 (40 CFR part 60, appendix A.) The Method 24 determination may be performed by the manufacturer of the material and the results provided to you. If these values cannot be determined using Method 24, you must submit an alternative technique for determining their values for approval by the Administrator.

(2) *Formulation data.* You may determine the volatile organic content and coating solids content of a coating material based on formulation data and may rely on volatile organic content data provided by the manufacturer of the material. In the event of any inconsistency between the formulation data and the results of Method 24 of 40 CFR part 60, appendix A, and the Method 24 results are higher, the results of Method 24 will govern.

(ii) *Catalytic oxidizer.* If your add-on control device is a catalytic oxidizer, establish the operating limits according to paragraphs (e)(3)(ii)(A) and (B) or paragraphs (e)(3)(ii)(C) and (D) of this section.

(A) During the performance test, you must monitor and record the temperature just before the catalyst bed and the temperature difference across the catalyst bed at least once every 15 minutes during each of the three test runs.

(B) Use the data collected during the performance test to calculate and record the average temperature just before the catalyst bed and the average temperature difference across the catalyst bed maintained during the performance test. These are the minimum operating limits for your catalytic oxidizer.

(C) As an alternative to monitoring the temperature difference across the catalyst bed, you may monitor the temperature at the inlet to the catalyst bed and implement a site-specific inspection and maintenance plan for your catalytic oxidizer as specified in paragraph (e)(3)(ii)(D) of this section. During the performance test, you must monitor and record the temperature just before the catalyst bed at least once every 15 minutes during each of the three test runs. Use the data collected during the performance test to calculate and record the average temperature just before the catalyst bed during the performance test. This is the minimum operating limit for your catalytic oxidizer.

(D) You must develop and implement an inspection and maintenance plan for your catalytic oxidizer(s) for which you elect to monitor according to paragraph (e)(3)(ii)(C) of this section. The plan must address, at a minimum, the elements specified in paragraphs (e)(3)(ii)(D)(*1*) through (*3*) of this section.

(*1*) Annual sampling and analysis of the catalyst activity (*i.e.,* conversion efficiency) following the manufacturer's or catalyst supplier's recommended procedures,

(*2*) Monthly inspection of the oxidizer system including the burner assembly and fuel supply lines for problems, and

(*3*) Annual internal and monthly external visual inspection of the catalyst bed to check for channeling, abrasion, and settling. If problems are found, you must take corrective action consistent with the manufacturer's recommendations and conduct a new performance test to determine destruction efficiency in accordance with this section.

(f) *Capture efficiency.* If you demonstrate compliance by meeting the requirements of §63.3370(e), (f), (g), (h), (i)(2), (k), (n)(2) or (3), or (p), you must determine capture efficiency using the procedures in paragraph (f)(1), (2), or (3) of this section, as applicable.

(1) You may assume your capture efficiency equals 100 percent if your capture system is a permanent total enclosure (PTE). You must confirm that your capture system is a PTE by demonstrating that it meets the requirements of section 6 of EPA Method 204 of 40 CFR part 51, appendix M, and that all exhaust gases from the enclosure are delivered to a control device.

(2) You may determine capture efficiency according to the protocols for testing with temporary total enclosures that are specifed in Methods 204 and 204A through F of 40 CFR part 51, appendix M. You may exclude never-controlled work stations from such capture efficiency determinations.

(3) You may use any capture efficiency protocol and test methods that satisfy the criteria of either the Data Quality Objective or the Lower Confidence Limit approach as described in appendix A of subpart KK of this part. You may exclude never-controlled work stations from such capture efficiency determinations.

(g) *Volatile matter retained in the coated web or otherwise not emitted to the atmosphere.* You may choose to take into account the mass of volatile matter retained in the coated web after curing or drying or otherwise not emitted to the atmosphere when determining compliance with the emission standards in §63.3320. If you choose this option, you must develop a testing protocol to determine the mass of volatile matter retained in the coated web or otherwise not emitted to the atmosphere and submit this protocol to the Administrator for approval. You must submit this protocol with your site-specific test plan under §63.7(f). If you intend to take into account the mass of volatile matter retained in the coated web after curing or drying or otherwise not emitted to the atmosphere and demonstrate compliance according to §63.3370(c)(3), (c)(4), (c)(5), or (d), then the test protocol you submit must determine the mass of organic HAP retained in the coated web or otherwise not emitted to the atmosphere. Otherwise, compliance must be shown using the volatile organic matter content as a surrogate for the HAP content of the coatings.

(h) *Control devices in series.* If you use multiple control devices in series to comply with the emission standards in §63.3320, the performance test must include, at a minimum, the inlet to the first control device in the series, the outlet of the last control device in the series, and all intermediate streams (*e.g.,* gaseous exhaust to the atmosphere or a liquid stream from a recovery device) that are not subsequently treated by any of the control devices in the series.

Requirements for Showing Compliance

§ 63.3370 How do I demonstrate compliance with the emission standards?

(a) A summary of how you must demonstrate compliance follows:

If you choose to demonstrate compliance by:	Then you must demonstrate that:	To accomplish this:
(1) Use of "as-purchased" compliant coating materials	(i) Each coating material used at an existing affected source does not exceed 0.04 kg organic HAP per kg coating material, and each coating material used at a new affected source does not exceed 0.016 kg organic HAP per kg coating material as-purchased; or	Follow the procedures set out in §63.3370(b).
	(ii) Each coating material used at an existing affected source does not exceed 0.2 kg organic HAP per kg coating solids, and each coating material used at a new affected source does not exceed 0.08 kg organic HAP per kg coating solids as-purchased	Follow the procedures set out in §63.3370(b).
(2) Use of "as-applied" compliant coating materials	(i) Each coating material used at an existing affected source does not exceed 0.04 kg organic HAP per kg coating material, and each coating material used at a new affected source does not exceed 0.016 kg organic HAP per kg coating material as-applied; or	Follow the procedures set out in §63.3370(c)(1). Use either Equation 1a or b of §63.3370 to determine compliance with §63.3320(b)(2) in accordance with §63.3370(c)(5)(i).
	(ii) Each coating material used at an existing affected source does not exceed 0.2 kg organic HAP per kg coating solids, and each coating material used at a	Follow the procedures set out in §63.3370(c)(2). Use Equations 2 and 3 of §63.3370 to determine compliance with §63.3320(b)(3) in accordance with

	new affected source does not exceed 0.08 kg organic HAP per kg coating solids as-applied; or	§63.3370(c)(5)(i).
	(iii) Monthly average of all coating materials used at an existing affected source does not exceed 0.04 kg organic HAP per kg coating material, and monthly average of all coating materials used at a new affected source does not exceed 0.016 kg organic HAP per kg coating material as-applied on a monthly average basis; or	Follow the procedures set out in §63.3370(c)(3). Use Equation 4 of §63.3370 to determine compliance with §63.3320(b)(2) in accordance with §63.3370(c)(5)(ii).
	(iv) Monthly average of all coating materials used at an existing affected source does not exceed 0.2 kg organic HAP per kg coating solids, and monthly average of all coating materials used at a new affected source does not exceed 0.08 kg organic HAP per kg coating solids as-applied on a monthly average basis	Follow the procedures set out in §63.3370(c)(4). Use Equation 5 of §63.3370 to determine compliance with §63.3320(b)(3) in accordance with §63.3370(c)(5)(ii).
(3) Tracking total monthly organic HAP applied	Total monthly organic HAP applied does not exceed the calculated limit based on emission limitations	Follow the procedures set out in §63.3370(d). Show that total monthly HAP applied (Equation 6 of §63.3370) is less than the calculated equivalent allowable organic HAP (Equation 13a or b of §63.3370).
(4) Use of a capture system and control device	(i) Overall organic HAP control efficiency is equal to 95 percent at an existing affected source and 98 percent at a new affected source on a monthly basis; or oxidizer outlet organic HAP concentration is no greater than 20 ppmv by compound and capture efficiency is 100 percent; or operating parameters are continuously monitored; or	Follow the procedures set out in §63.3370(e) to determine compliance with §63.3320(b)(1) according to §63.3370(i) if using a solvent recovery device, or §63.3370(j) if using a control device and CPMS, or §63.3370(k) if using an oxidizer.
	(ii) Overall organic HAP	Follow the procedures set out

	emission rate does not exceed 0.2 kg organic HAP per kg coating solids for an existing affected source or 0.08 kg organic HAP per kg coating solids for a new affected source on a monthly average as-applied basis;	in §63.3370(f) to determine compliance with §63.3320(b)(3) according to §63.3370(i) if using a solvent recovery device, or §63.3370(k) if using an oxidizer.
	(iii) Overall organic HAP emission rate does not exceed 0.04 kg organic HAP per kg coating material for an existing affected source or 0.016 kg organic HAP per kg coating material for a new affected source on a monthly average as-applied basis; or	Follow the procedures set out in §63.3370(g) to determine compliance with §63.3320(b)(2) according to §63.3370(i) if using a solvent recovery device, or §63.3370(k) if using an oxidizer.
	(iv) Overall organic HAP emission rate does not exceed the calculated limit based on emission limitations	Follow the procedures set out in §63.3370(h). Show that the monthly organic HAP emission rate is less than the calculated equivalent allowable organic HAP emission rate (Equation 13a or b of §63.3370). Calculate the monthly organic HAP emission rate according to §63.3370(i) if using a solvent recovery device, or §63.3370(k) if using an oxidizer.
(5) Use of multiple capture and/or control devices	(i) Overall organic HAP control efficiency is equal to 95 percent at an existing affected source and 98 percent at a new affected source on a monthly basis; or	Follow the procedures set out in §63.3370(e) to determine compliance with §63.3320(b)(1) according to §63.3370(e)(1) or (2).
	(ii) Average equivalent organic HAP emission rate does not exceed 0.2 kg organic HAP per kg coating solids for an existing affected source or 0.08 kg organic HAP per kg coating solids for a new affected source on a monthly average as-applied basis; or	Follow the procedures set out in §63.3370(f) to determine compliance with §63.3320(b)(3) according to §63.3370(n).
	(iii) Average equivalent organic HAP emission rate does not exceed 0.04 kg organic HAP per kg coating	Follow the procedures set out in §63.3370(g) to determine compliance with §63.3320(b)(2) according to §63.3370(n).

	material for an existing affected source or 0.016 kg organic HAP per kg coating material for a new affected source on a monthly average as-applied basis; or	
	(iv) Average equivalent organic HAP emission rate does not exceed the calculated limit based on emission limitations	Follow the procedures set out in §63.3370(h). Show that the monthly organic HAP emission rate is less than the calculated equivalent allowable organic HAP emission rate (Equation 13a or b of §63.3370) according to §63.3370(n).
(6) Use of a combination of compliant coatings and control devices	(i) Average equivalent organic HAP emission rate does not exceed 0.2 kg organic HAP per kg coating solids for an existing affected source or 0.08 kg organic HAP per kg coating solids for a new affected source on a monthly average as-applied basis; or	Follow the procedures set out in §63.3370(f) to determine compliance with §63.3320(b)(3) according to §63.3370(n).
	(ii) Average equivalent organic HAP emission rate does not exceed 0.04 kg organic HAP per kg coating material for an existing affected source or 0.016 kg organic HAP per kg coating material for a new affected source on a monthly average as-applied basis; or	Follow the procedures set out in §63.3370(g) to determine compliance with §63.3320(b)(2) according to §63.3370(n).
	(iii) Average equivalent organic HAP emission rate does not exceed the calculated limit based on emission limitations	Follow the procedures set out in §63.3370(h). Show that the monthly organic HAP emission rate is less than the calculated equivalent allowable organic HAP emission rate (Equation 13a or b of §63.3370) according to §63.3370(n).

(b) *As-purchased "compliant" coating materials.* (1) If you comply by using coating materials that individually meet the emission standards in §63.3320(b)(2) or (3), you must demonstrate that each coating material applied during the month at an existing affected source contains no more than 0.04 mass fraction organic HAP or 0.2 kg organic HAP per kg coating solids, and that each coating material applied during the month at a new affected source contains no more than 0.016 mass fraction organic HAP or 0.08 kg organic HAP per kg coating solids on an as-purchased basis as determined in accordance with §63.3360(c).

(2) You are in compliance with emission standards in §63.3320(b)(2) and (3) if each coating material applied at an existing affected source is applied as-purchased and contains no more than 0.04 kg organic HAP per kg coating material or 0.2 kg organic HAP per kg coating solids, and each coating material applied at a new affected source is applied as-purchased and contains no more than 0.016 kg organic HAP per kg coating material or 0.08 kg organic HAP per kg coating solids.

(c) *As-applied "compliant" coating materials.* If you comply by using coating materials that meet the emission standards in §63.3320(b)(2) or (3) as-applied, you must demonstrate compliance by following one of the procedures in paragraphs (c)(1) through (4) of this section. Compliance is determined in accordance with paragraph (c)(5) of this section.

(1) *Each coating material as-applied meets the mass fraction of coating material standard (§63.3320(b)(2)).* You must demonstrate that each coating material applied at an existing affected source during the month contains no more than 0.04 kg organic HAP per kg coating material applied, and each coating material applied at a new affected source contains no more than 0.016 kg organic HAP per kg coating material applied as determined in accordance with paragraphs (c)(1)(i) and (ii) of this section. You must calculate the as-applied organic HAP content of as-purchased coating materials which are reduced, thinned, or diluted prior to application.

(i) Determine the organic HAP content or volatile organic content of each coating material applied on an as-purchased basis in accordance with §63.3360(c).

(ii) Calculate the as-applied organic HAP content of each coating material using Equation 1a of this section:

$$C_{ahi} = \frac{\left(C_{hi} M_i + \sum_{j=1}^{q} C_{hij} M_{ij} \right)}{M_i + \sum_{j=1}^{q} M_{ij}} \qquad \text{Eq. 1a}$$

Where:

C_{ahi}= Monthly average, as-applied, organic HAP content of coating material, i, expressed as a mass fraction, kg/kg.

C_{hi}= Organic HAP content of coating material, i, as-purchased, expressed as a mass fraction, kg/kg.

M_i= Mass of as-purchased coating material, i, applied in a month, kg.

q = number of different materials added to the coating material.

C_{hij}= Organic HAP content of material, j, added to as-purchased coating material, i, expressed as a mass fraction, kg/kg.

M_{ij}= Mass of material, j, added to as-purchased coating material, i, in a month, kg.

M_i= Mass of as-purchased coating material, i, applied in a month, kg.

or calculate the as-applied volatile organic content of each coating material using Equation 1b of this section:

$$C_{avi} = \frac{\left(C_{vi} M_i + \sum_{j=1}^{q} C_{vij} M_{ij} \right)}{M_i + \sum_{j=1}^{q} M_{ij}} \qquad \text{Eq. 1b}$$

Where:

C_{avi}= Monthly average, as-applied, volatile organic content of coating material, i, expressed as a mass fraction, kg/kg.

C_{vi}= Volatile organic content of coating material, i, expressed as a mass fraction, kg/kg.

M_i= Mass of as-purchased coating material, i, applied in a month, kg.

q = Number of different materials added to the coating material.

C_{vij}= Volatile organic content of material, j, added to as-purchased coating material, i, expressed as a mass fraction, kg/kg.

M_{ij}= Mass of material, j, added to as-purchased coating material, i, in a month, kg.

(2) *Each coating material as-applied meets the mass fraction of coating solids standard (§63.3320(b)(3)).* You must demonstrate that each coating material applied at an existing affected source contains no more than 0.20 kg of organic HAP per kg of coating solids applied and each coating material applied at a new affected source contains no more than 0.08 kg of organic HAP per kg of coating solids applied. You must demonstrate compliance in accordance with paragraphs (c)(2)(i) and (ii) of this section.

(i) Determine the as-applied coating solids content of each coating material following the procedure in §63.3360(d). You must calculate the as-applied coating solids content of coating materials which are reduced, thinned, or diluted prior to application, using Equation 2 of this section:

$$C_{asi} = \frac{\left(C_{si} M_i + \sum_{j=1}^{q} C_{sij} M_{ij} \right)}{M_i + \sum_{j=1}^{q} M_{ij}} \qquad \text{Eq. 2}$$

Where:

C_{si}= Coating solids content of coating material, i, expressed as a mass fraction, kg/kg.

M_i= Mass of as-purchased coating material, i, applied in a month, kg.

q = Number of different materials added to the coating material.

C_{sij}= Coating solids content of material, j, added to as-purchased coating material, i, expressed as a mass-fraction, kg/kg.

M_{ij}= Mass of material, j, added to as-purchased coating material, i, in a month, kg.

(ii) Calculate the as-applied organic HAP to coating solids ratio using Equation 3 of this section:

$$H_{si} = \frac{C_{ahi}}{C_{asi}} \qquad \text{Eq. 3}$$

Where:

H_{si}= As-applied, organic HAP to coating solids ratio of coating material, i.

C_{ahi}= Monthly average, as-applied, organic HAP content of coating material, i, expressed as a mass fraction, kg/kg.

C_{asi}= Monthly average, as-applied, coating solids content of coating material, i, expressed as a mass fraction, kg/kg.

(3) *Monthly average organic HAPcontent of all coating materials asapplied is less than themass percent limit (§63.3320(b)(2)).*Demonstrate that the monthly average as-applied organic HAP content of all coating materials applied at an existing affected source is less than 0.04 kg organic HAP per kg of coating material applied, and all coating materials applied at a newaffected source are less than 0.016 kg organic HAP per kg ofcoating material applied, as determined by Equation 4 of this section:

$$H_L = \frac{\sum_{i=1}^{p} C_{hi} M_i + \sum_{j=1}^{q} C_{hij} M_{ij} - M_{vret}}{\sum_{i=1}^{p} M_i + \sum_{j=1}^{q} M_{ij}} \qquad \text{Eq. 4}$$

Where:

H_L= Monthly average, as-applied, organic HAP content of all coating materials applied, expressed as kg organic HAP per kg of coating material applied, kg/kg.

p = Number of different coating materials applied in a month.

C_{hi}= Organic HAP content of coating material, i, as-purchased, expressed as a mass fraction, kg/kg.

M_i= Mass of as-purchased coating material, i, applied in a month, kg.

q = Number of different materials added to the coating material.

C_{hij}= Organic HAP content of material, j, added to as-purchased coating material, i, expressed as a mass fraction, kg/kg.

M_{ij}= Mass of material, j, added to as-purchased coating material, i, in a month, kg.

M_{vret}= Mass of volatile matter retained in the coated web after curing or drying, or otherwise not emitted to the atmosphere, kg. The value of this term will be zero in all cases except where you choose to take into account the volatile matter retained in the coated web or otherwise not emitted to the atmosphere for the compliance demonstration procedures in §63.3370.

(4) *Monthly average organic HAPcontent of all coating materials asapplied is less than themass fraction of coating solids limit (§633320(b)(3)).* Demonstrate that the monthly average as-applied organic HAP content on the basis of coating solids applied ofall coating materials applied at an existing affected source is less than 020 kg organic HAP per kg coating solids applied, and all coating materials applied at a newaffected source are less than 0.08 kg organic HAP per kg coating solids applied, as

determined by Equation 5 of this section:

$$H_s = \frac{\sum_{i=1}^{p} C_{hi} M_i + \sum_{j=1}^{q} C_{hij} M_{ij} - M_{vret}}{\sum_{i=1}^{p} C_{si} M_i + \sum_{j=1}^{q} C_{sij} M_{ij}} \qquad \text{Eq. 5}$$

Where:

H_s= Monthly average, as-applied, organic HAP to coating solids ratio, kg organic HAP/kg coating solids applied.

p = Number of different coating materials applied in a month.

C_{hi}= Organic HAP content of coating material, i, as-purchased, expressed as a mass fraction, kg/kg.

M_i= Mass of as-purchased coating material, i, applied in a month, kg.

q = Number of different materials added to the coating material.

C_{hij}= Organic HAP content of material, j, added to as-purchased coating material, i, expressed as a mass fraction, kg/kg.

M_{ij}= Mass of material, j, added to as-purchased coating material, i, in a month, kg.

M_{vret}= Mass of volatile matter retained in the coated web after curing or drying, or otherwise not emitted to the atmosphere, kg. The value of this term will be zero in all cases except where you choose to take into account the volatile matter retained in the coated web or otherwise not emitted to the atmosphere for the compliance demonstration procedures in §63.3370.

C_{si}= Coating solids content of coating material, i, expressed as a mass fraction, kg/kg.

C_{sij}= Coating solids content of material, j, added to as-purchased coating material, i, expressed as a mass-fraction, kg/kg.

(5) The affected source is in compliance with emission standards in §63.3320(b)(2) or (3) if

(i) The organic HAP content ofeach coating material as-applied at an existing affected source is no more than 0.04 kg organic HAP per kg coating material or 0.2 kg organic HAP per kg coating solids, and the organic HAP content of each coating material as-applied at a new affected source contains no more than 0.016 kg organic HAP per kg coating material or 0.08 kg organic HAP per kg coating solids; or

(ii) The monthly average organic HAP content of all as-applied coating materials at an existing affected source are no more than 0.04 kg organic HAP per kg coating material or 0.2 kg organic HAP per kg coating solids, and the monthly average organic HAP content ofall as-applied coating materials at a new affected source is no more than 0.016 kg organic HAP per kg coating material or 0.08 kg organic HAP per kg coating solids.

(d) *Monthly allowable organic HAP applied.* Demonstrate that the total monthly organic HAP applied as determined by Equation 6 of this section is less than the calculated equivalent allowable organic HAP as determined by Equation 13a or b in paragraph (l) ofthis section:

$$H_m = \sum_{i=1}^{p} C_{hi} M_i + \sum_{j=1}^{q} C_{hij} M_{ij} - M_{vret} \qquad \text{Eq. 6}$$

Where:

H_m= Total monthly organic HAP applied, kg.

p = Number of different coating materials applied in a month.

C_{hi}= Organic HAP content of coating material, i, as-purchased, expressed as a mass fraction, kg/kg.

M_i= Mass of as-purchased coating material, i, applied in a month, kg.

q = Number of different materials added to the coating material.

C_{hij}= Organic HAP content of material, j, added to as-purchased coating material, i, expressed as a mass fraction, kg/kg.

M_{ij}= Mass of material, j, added to as-purchased coating material, i, in a month, kg.

M_{vret}= Mass of volatile matter retained in the coated web after curing or drying, or otherwise not emitted to the atmosphere, kg. The value of this term will be zero in all cases except where you choose to take into account the volatile matter retained in the coated web or otherwise not emitted to the atmosphere for the compliance demonstration procedures in §63.3370.

(e) *Capture and control to reduce emissions to no more than allowable limit (§63.3320(b)(1)).* Operate a capture system and control device and demonstrate an overall organic HAP control efficiency of at least 95 percent at an existing affected source and at least 98 percent at a new affected source for each month, or operate a capture system and oxidizer so that an outlet organic HAP concentration of no greater than 20 ppmv by compound on a dry basis is achieved as long as the capture efficiency is 100 percent as detailed in §63.3320(b)(4). Unless one ofthe cases described in paragraph (e)(1), (2), or (3) of this section applies to theaffected source, you must either demonstrate compliance in accordance with the procedure in paragraph (i) of this section when emissions from the affected source are controlled by a solvent recovery device, or the procedure in paragraph (k) ofthis section when emissions are controlled by an oxidizer or demonstrate compliance for a web coating line by operating each capture system and each control device and continuous parameter monitoring according to the procedures in paragraph(j) of this section.

(1) If the affected source has only always-controlled work stations and operates more than one capture system or more than one control device, you must demonstrate compliance in accordance with the provisions of either paragraph (n) or (p) of this section.

(2) If the affected source operates one or more never-controlled work stations or one or more intermittently-controlled work stations, you must demonstrate compliance in accordance with the provisions of paragraph (n) of this section.

(3) An alternative method of demonstrating compliance with §63.3320(b)(1) is the installation of a PTE around the web coating line that achieves 100 percent capture efficiency and ventilation of all organic HAP emissions from the total enclosure to an oxidizer with an outlet organic HAP concentrationof no greater than 20 ppmv by compound on a dry basis. If this method is selected, you must demonstrate compliance by following the procedures in paragraphs (e)(3)(i) and (ii) ofthis section. Compliance is determined according to paragraph (e)(3)(iii) ofthis section.

(i) Demonstrate that a total enclosure is installed. An enclosure that meets the requirements in §63.3360 (f)(1) will be considered a total enclosure.

(ii) Determine the organic HAP concertration at the outlet of your total enclosure using the procedures in paragraph (e)(3)(ii)(A) or (B) of this section.

(A) Determine the control device efficiency using Equation 2 of §63.3360 and the applicable test methods and procedures specified in §63.3360(e).

(B) Use a CEMS to determine the organic HAP emission rate according to paragraphs (i)(2)(i) through (x) of this section.

(iii) You are in compliance if the installation of a total enclosure is demonstrated and the organic HAP concentration at the outlet of the incinerator is demonstrated to be no greater than 20 ppmv by compound on a dry basis.

(f) *Capture and control to achieve mass fraction of coating solids applied limit (§63.3320(b)(3)).* Operate a capture system and control device and limit the organic HAP emission rate from an existing affected source to no more than 0.20 kg organic HAP emitted per kg coating solids applied and from a new affected source to no more than 0.08 kg organic HAP emitted per kg coating solids applied as determined on a monthly average as-applied basis. If the affected source operates more than one capture system, more than one control device, one or more never-controlled work stations, or one or more intermittently-controlled work stations, then you must demonstrate compliance in accordance with the provisions of paragraph (n) of this section. Otherwise, you must demonstrate compliance following the procedure in paragraph (i) of this section when emissions from the affected source are controlled by a solvent recovery device or the procedure in paragraph (k) of this section when emissions are controlled by an oxidizer.

(g) *Capture and control to achieve mass fraction limit (§63.3320(b)(2)).* Operate a capture system and control device and limit the organic HAP emission rate to no more than 0.04 kg organic HAP emitted per kg coating material applied at an existing affected source, and no more than 0.016 kg organic HAP emitted per kg coating material applied at a new affected source as determined on a monthly average as-applied basis. If the affected source operates more than one capture system, more than one control device, one or more never-controlled work stations, or one or more intermittently-controlled work stations, then you must demonstrate compliance in accordance with the provisions of paragraph (n) of this section. Otherwise, you must demonstrate compliance following the procedure in paragraph (i) of this section when emissions from the affected source are controlled by a solvent recovery device or the procedure in paragraph (k) of this section when emissions are controlled by an oxidizer.

(h) *Capture and control to achieve allowable emission rate.* Operate a capture system and control device and limit the monthly organic HAP emissions to less than the allowable emissions as calculated in accordance with paragraph (l) of this section. If the affected source operates more than one capture system, more than one control device, one or more never-controlled work stations, or one or more intermittently-controlled work stations, then you must demonstrate compliance in accordance with the provisions of paragraph (n) of this section. Otherwise, the owner or operator must demonstrate compliance following the procedure in paragraph (i) of this section when emissions from the affected source are controlled by a solvent recovery device or the procedure in paragraph (k) of this section when emissions are controlled by an oxidizer.

(i) *Solvent recovery device compliance demonstration.* If you use a solvent recovery device to control emissions, you must show compliance by following the procedures in either paragraph (i)(1) or (2) of this section:

(1) *Liquid-liquid material balance.* Perform a monthly liquid-liquid material balance as specifed in paragraphs (i)(1)(i) through (v) of this section and use the applicable equations in paragraphs (i)(1)(vi) through (ix) of this section to convert the data to units of the selected compliance option in paragraphs (e) through (h) of this section. Compliance is determined in accordance with paragraph (i)(1)(x) of this section.

(i) Determine the mass of each coating material applied on the web coating line or group of web coating lines controlled by a common solvent recovery device during the month.

(ii) If demonstrating compliance on the basis of organic HAP emission rate based on coating solids applied, organic HAP emission rate based on coating material applied, or emission of less than the calculated allowable organic HAP, determine the organic HAP content of each coating material as-applied during the month following the procedure in §63.3360(c).

(iii) Determine the volatile organic content of each coating material as-applied during the month following

the procedure in §63.3360(d).

(iv) If demonstrating compliance on the basis of organic HAP emission rate based on coating solids applied or emission of less than the calculated allowable organic HAP, determine the coating solids content of each coating material applied during the month following the procedure in §63.3360(d).

(v) Determine and monitor the amount of volatile organic matter recovered for the month according to the procedures in §63.3350(d).

(vi) *Recovery efficiency.* Calculate the volatile organic matter collection and recovery efficiency using Equation 7 of this section:

$$R_v = \frac{M_{vr} + M_{vret}}{\sum_{i=1}^{p} C_{vi} M_i + \sum_{i=1}^{q} C_{vij} M_{ij}} \times 100 \quad \text{Eq. 7}$$

Where:

R_v = Organic volatile matter collection and recovery efficiency, percent.

M_{vr} = Mass of volatile matter recovered in a month, kg.

M_{vret} = Mass of volatile matter retained in the coated web after curing or drying, or otherwise not emitted to the atmosphere, kg. The value of this term will be zero in all cases except where you choose to take into account the volatile matter retained in the coated web or otherwise not emitted to the atmosphere for the compliance demonstration procedures in §63.3370.

p = Number of different coating materials applied in a month.

C_{vi} = Volatile organic content of coating material, i, expressed as a mass fraction, kg/kg.

M_i = Mass of as-purchased coating material, i, applied in a month, kg.

q = Number of different materials added to the coating material.

C_{vij} = Volatile organic content of material, j, added to as-purchased coating material, i, expressed as a mass fraction, kg/kg.

M_{ij} = Mass of material, j, added to as-purchased coating material, i, in a month, kg.

(vii) *Organic HAP emitted.* Calculate the organic HAP emitted during the month using Equation 8 of this section:

$$H_e = \left[1 - \frac{R_v}{100}\right]\left[\sum_{i=1}^{p} C_{hi} M_i + \sum_{j=1}^{q} C_{hij} M_{ij} - M_{wret}\right] \quad \text{Eq. 8}$$

Where:

H_e = Total monthly organic HAP emitted, kg.

R_v = Organic volatile matter collection and recovery efficiency, percent.

p = Number of different coating materials applied in a month.

C_{hi}= Organic HAP content of coating material, i, as-purchased, expressed as a mass fraction, kg/kg.

M_i= Mass of as-purchased coating material, i, applied in a month, kg.

q = Number of different materials added to the coating material.

C_{hij}= Organic HAP content of material, j, added to as-purchased coating material, i, expressed as a mass fraction, kg/kg.

M_{ij}= Mass of material, j, added to as-purchased coating material, i, in a month, kg.

M_{vret}= Mass of volatile matter retained in the coated web after curing or drying, or otherwise not emitted to the atmosphere, kg. The value of this term will be zero in all cases except where you choose to take into account the volatile matter retained in the coated web or otherwise not emitted to the atmosphere for the compliance demonstration procedures in §63.3370.

(viii) *Organic HAP emission rate based oncoating solids applied.* Calculate the organic HAP emission rate based on coating solids applied using Equation 9 ofthis section:

$$L = \frac{H_e}{\sum_{i=1}^{p} C_{si} M_i + \sum_{j=1}^{q} C_{sij} M_{ij}} \qquad \text{Eq. 9}$$

Where:

L = Mass organic HAP emitted per mass of coating solids applied, kg/kg.

H_e= Total monthly organic HAP emitted, kg.

p = Number of different coating materials applied in a month.

C_{si}= Coating solids content of coating material, i, expressed as a mass fraction, kg/kg.

M_i= Mass of as-purchased coating material, i, applied in a month, kg.

q = Number of different materials added to the coating material.

C_{sij}= Coating solids content of material, j, added to as-purchased coating material, i, expressed as a mass-fraction, kg/kg.

M_{ij}= Mass of material, j, added to as-purchased coating material, i, in a month, kg.

(ix) *Organic HAP emission rate based on coating materials applied.* Calculate the organic HAP emission rate based on coating material applied using Equation 10 ofthis section:

$$S = \frac{H_e}{\sum_{i=1}^{p} M_i + \sum_{j=1}^{q} M_{ij}} \qquad \text{Eq. 10}$$

Where:

S = Mass organic HAP emitted per mass of material applied, kg/kg.

H_e= Total monthly organic HAP emitted, kg.

p = Number of different coating materials applied in a month.

M_i= Mass of as-purchased coating material, i, applied in a month, kg.

q = Number of different materials added to the coating material.

M_{ij}= Mass of material, j, added to as-purchased coating material, i, in a month, kg.

(x) You are in compliance with the emission standards in §63.3320(b) if

(A) The volatile organic matter collection and recovery efficiency is 95 percent or greater at an existing affected source and 98 percent or greater at a new affected source; or

(B) The organic HAP emission rate based on coating solids applied is no more than 0.20 kg organic HAP per kg coating solids applied at an existing affected source and no more than 0.08 kg organic HAP per kg coating solids applied at a new affected source; or

(C) The organic HAP emission rate based on coating material applied is no more than 0.04 kg organic HAP per kg coating material applied at an existing affected source and no more than 0.016 kg organic HAP per kg coating material applied at a new affected source; or

(D) The organic HAP emitted during the month is less than the calculated allowable organic HAP as determined using paragraph (l) of this section.

(2) *Continuous emission monitoring of capture system and control device performance.* Demonstrate initial compliance through a performance test on capture efficiency and continuing compliance through continuous emission monitors and continuous monitoring of capture system operating parameters following the procedures in paragraphs (i)(2)(i) through (vii) of this section. Use the applicable equations specified in paragraphs (i)(2)(viii) through (x) of this section to convert the monitoring and other data into units of the selected compliance option in paragraphs (e) through (h) of this section. Compliance is determined in accordance with paragraph (i)(2)(xi) of this section.

(i) *Control device efficiency.* Continuously monitor the gas stream entering and exiting the control device to determine the total organic volatile matter mass flow rate (*e.g.,* by determining the concentration of the vent gas in grams per cubic meter and the volumetric flow rate in cubic meters per second such that the total organic volatile matter mass flow rate in grams per second can be calculated) such that the control device efficiency of the control device can be calculated for each month using Equation 2 of §63.3360.

(ii) *Capture efficiency monitoring.* Whenever a web coating line is operated, continuously monitor the operating parameters established in accordance with §63.3350(f) to ensure capture efficiency.

(iii) Determine the percent capture efficiency in accordance with §63.3360(f).

(iv) *Control efficiency.* Calculate the overall organic HAP control efficiency achieved for each month using Equation 11 of this section:

$$R = \frac{(E)(CE)}{100} \qquad \text{Eq. 11}$$

Where:

R = Overall organic HAP control efficiency, percent.

E = Organic volatile matter control efficiency of the control device, percent.

CE = Organic volatile matter capture efficiency of the capture system, percent.

(v) If demonstrating compliance on the basis of organic HAP emission rate based on coating solids applied, organic HAP emission rate based on coating materials applied, or emission of less than the calculated allowable organic HAP, determine the mass of each coating material applied on the web coating line or group of web coating lines controlled by a common control device during the month.

(vi) If demonstrating compliance on the basis of organic HAP emission rate based on coating solids applied, organic HAP emission rate based on coating material applied, or emission of less than the calculated allowable organic HAP, determine the organic HAP content of each coating material as-applied during the month following the procedure in §63.3360(c).

(vii) If demonstrating compliance on the basis of organic HAP emission rate based on coating solids applied or emission of less than the calculated allowable organic HAP, determine the coating solids content of each coating material as-applied during the month following the procedure in §63.3360(d).

(viii) *Organic HAP emitted.* Calculate the organic HAP emitted during the month for each month using Equation 12 of this section:

$$H_e = (1-R)\left(\sum_{i=1}^{p} C_{ahi} M_i\right) - M_{vret} \quad \text{Eq. 12}$$

Where:

H_e = Total monthly organic HAP emitted, kg.

R = Overall organic HAP control efficiency, percent.

p = Number of different coating materials applied in a month.

C_{ahi} = Monthly average, as-applied, organic HAP content of coating material, i, expressed as a mass fraction, kg/kg.

M_i = Mass of as-purchased coating material, i, applied in a month, kg.

M_{vret} = Mass of volatile matter retained in the coated web after curing or drying, or otherwise not emitted to the atmosphere, kg. The value of this term will be zero in all cases except where you choose to take into account the volatile matter retained in the coated web or otherwise not emitted to the atmosphere for the compliance demonstration procedures in this section.

(ix) *Organic HAP emission rate based on coating solids applied.* Calculate the organic HAP emission rate based on coating solids applied using Equation 9 of this section.

(x) *Organic HAP emission rate based on coating materials applied.* Calculate the organic HAP emission rate based on coating material applied using Equation 10 of this section.

(xi) *Compare actual performance to the performance required by compliance option.* The affected source is in compliance with the emission standards in §63.3320(b) for each month if the capture system is operated such that the average capture system operating parameter is greater than or less than (as appropriate) the operating parameter value established in accordance with §63.3350(f); and

(A) The organic volatile matter collection and recovery efficiency is 95 percent or greater at an existing affected source and 98 percent or greater at a new affected source; or

(B) The organic HAP emission rate based on coating solids applied is no more than 0.20 kg organic HAP per kg coating solids applied at an existing affected source and no more than 0.08 kg organic HAP per kg coating solids applied at a new affected source; or

(C) The organic HAP emission rate based on coating material applied is no more than 0.04 kg organic HAP per kg coating material applied at an existing affected source and no more than 0.016 kg organic HAP per kg coating material applied at a new affected source; or

(D) The organic HAP emitted during the month is less than the calculated allowable organic HAP as determined using paragraph (l) of this section.

(j) *Capture and control system compliance demonstration procedures using a CPMS.* If you use an add-on control device, you must demonstrate initial compliance for each capture system and each control device through performance tests and demonstrate continuing compliance through continuous monitoring of capture system and control device operating parameters as specified in paragraphs (j)(1) through (3) of this section. Compliance is determined in accordance with paragraph (j)(4) of this section.

(1) Determine the control device destruction or removal efficiency using the applicable test methods and procedures in §63.3360(e).

(2) Determine the emission capture efficiency in accordance with §63.3360(f).

(3) Whenever a web coating line is operated, continuously monitor the operating parameters established according to §63.3350(e) and (f).

(4) You are in compliance with the emission standards in §63.3320(b) if the control device is operated such that the average operating parameter value is greater than or less than (as appropriate) the operating parameter value established in accordance with §63.3360(e) for each 3-hour period, and the capture system operating parameter is operated at an average value greater than or less than (as appropriate) the operating parameter value established in accordance with §63.3350(f); and

(i) The overall organic HAP control efficiency is 95 percent or greater at an existing affected source and 98 percent or greater at a new affected source; or

(ii) The organic HAP emission rate based on coating solids applied is no more than 0.20 kg organic HAP per kg coating solids applied at an existing affected source and no more than 0.08 kg organic HAP per kg coating solids applied at a new affected source; or

(iii) The organic HAP emission rate based on coating material applied is no more than 0.04 kg organic HAP per kg coating material applied at an existing affected source and no more than 0.016 kg organic HAP per kg coating material applied at a new affected source; or

(iv) The organic HAP emitted during the month is less than the calculated allowable organic HAP as determined using paragraph (l) of this section.

(k) *Oxidizer compliance demonstration procedures.* If you use an oxidizer to control emissions, you must show compliance by following the procedures in paragraph (k)(1) of this section. Use the applicable equations specified in paragraph (k)(2) of this section to convert the monitoring and other data into units of the selected compliance option in paragraph (e) through (h) of this section. Compliance is determined in accordance with paragraph (k)(3) of this section.

(1) Demonstrate initial compliance through performance tests of capture efficiency and control device efficiency and continuing compliance through continuous monitoring of capture system and control device operating parameters as specified in paragraphs (k)(1)(i) through (vi) of this section:

(i) Determine the oxidizer destruction efficiency using the procedure in §63.3360(e).

(ii) Determine the capture system capture efficiency in accordance with §63.3360(f).

(iii) *Capture and control efficiency monitoring.* Whenever a web coating line is operated, continuously monitor the operating parameters established in accordance with §63.3350(e) and (f) to ensure capture and control efficiency.

(iv) If demonstrating compliance on the basis of organic HAP emission rate based on coating solids applied, organic HAP emission rate based on coating materials applied, or emission of less than the calculated allowable organic HAP, determine the mass of each coating material applied on the web coating line or group of web coating lines controlled by a common oxidizer during the month.

(v) If demonstrating compliance on the basis of organic HAP emission rate based on coating solids applied, organic HAP emission rate based on coating material applied, or emission of less than the calculated allowable organic HAP, determine the organic HAP content of each coating material as-applied during the month following the procedure in §63.3360(c).

(vi) If demonstrating compliance on the basis of organic HAP emission rate based on coating solids applied or emission of less than the calculated allowable organic HAP, determine the coating solids content of each coating material applied during the month following the procedure in §63.3360(d).

(2) Convert the information obtained under paragraph (p)(1) of this section into the units of the selected compliance option using the calculation procedures specified in paragraphs (k)(2)(i) through (iv) of this section.

(i) *Control efficiency.* Calculate the overall organic HAP control efficiency achieved using Equation 11 of this section.

(ii) *Organic HAP emitted.* Calculate the organic HAP emitted during the month using Equation 12 of this section.

(iii) *Organic HAP emission rate based on coating solids applied.* Calculate the organic HAP emission rate based on coating solids applied for each month using Equation 9 of this section.

(iv) *Organic HAP based on coating materials applied.* Calculate the organic HAP emission rate based on coating material applied using Equation 10 of this section.

(3) You are in compliance with the emission standards in §63.3320(b) if the oxidizer is operated such that the average operating parameter value is greater than the operating parameter value established in accordance with §63.3360(e) for each 3-hour period, and the capture system operating parameter is operated at an average value greater than or less than (as appropriate) the operating parameter value established in accordance with §63.3350(f); and

(i) The overall organic HAP control efficiency is 95 percent or greater at an existing affected source and 98 percent or greater at a new affected source; or

(ii) The organic HAP emission rate based on coating solids applied is no more than 0.20 kg organic HAP per kg coating solids applied at an existing affected source and no more than 0.08 kg organic HAP per kg coating solids applied at a new affected source; or

(iii) The organic HAP emission rate based on coating material applied is no more than 0.04 kg organic HAP per kg coating material applied at an existing affected source and no more than 0.016 kg organic HAP per kg coating material applied at a new affected source; or

(iv) The organic HAP emitted during the month is less than the calculated allowable organic HAP as determined using paragraph (l) of this section.

(l) *Monthly allowable organic HAP emissions.* This paragraph provides the procedures and calculations for determining monthly allowable organic HAP emissions for use in demonstrating compliance in accordance with paragraph (d), (h), (i)(1)(x)(D), (i)(2)(xi)(D), or (k)(3)(iv) of this section. You will need to determine the amount of coating material applied at greater than or equal to 20 mass percent coating solids and the amount of coating material applied at less than 20 mass percent coating solids. The allowable organic HAP limit is then calculated based on coating material applied at greater than or equal to 20 mass percent coating sdids complying with 0.2 kg organic HAP per kg coating solids at an existing affected source or 0.08 kg organic HAP per kg coating solids at a new affected source, and coating material applied at less than 20 mass percent coating solids complying with 4 mass percent organic HAP at an existing affected source and 1.6 mass-percent organic HAP at a new affected source as follows:

(1) Determine the as-purchased mass of each coating material applied each month.

(2) Determine the as-purchased coating solids content of each coating material applied each month in accordance with §63.3360(d)(1).

(3) Determine the as-purchased mass fraction of each coating material which was applied at 20 mass percent or greater coating sdids content on an as-applied basis.

(4) Determine the total mass of each solvent, diluent, thinner, or reducer added to coating materials which were applied at less than 20 mass percent coating solids content on an as-applied basis each month.

(5) Calculate the monthly allowable organic HAP emissions using Equation 13a of this section for an existing affected source:

$$H_a = 0.20\left[\sum_{i=1}^{p} M_i G_i C_{si}\right] + 0.04\left[\sum_{i=1}^{p} M_i (1 - G_i) + \sum_{j=1}^{q} M_{L_j}\right] \qquad \text{Eq. 13a}$$

Where:

H_a= Monthly allowable organic HAP emissions, kg.

p = Number of different coating materials applied in a month.

M_i= mass of as-purchased coating material, i, applied in a month, kg.

G_i= Mass fraction of each coating material, i, which was applied at 20 mass percent or greater coating solids content, on an as-applied basis, kg/kg.

C_{si}= Coating solids content of coating material, i, expressed as a mass fraction, kg/kg.

q = Number of different materials added to the coating material.

M_{Lj}= Mass of non-coating-solids-containing coating material, j, added to coating-solids-containing coating materials which were applied at less than 20 mass percent coating solids content, on an as-applied basis, in a month, kg.

or Equation 13b of this section for a new affected source:

$$H_a = 0.08\left[\sum_{i=1}^{p} M_i G_i C_{si}\right] + 0.016\left[\sum_{i=1}^{p} M_i (1 - G_i) + \sum_{j=1}^{q} M_{L_j}\right] \qquad \text{Eq. 13b}$$

Where:

H_a= Monthly allowable organic HAP emissions, kg.

p = Number of different coating materials applied in a month.

M_i= Mass of as-purchased coating material, i, applied in a month, kg.

G_i= Mass fraction of each coating material, i, which was applied at 20 mass percent or greater coating solids content, on an as-applied basis, kg/kg.

C_{si}= Coating solids content of coating material, i, expressed as a mass fraction, kg/kg.

q = Number of different materials added to the coating material.

M_{Lj} = Mass of non-coating-solids-containing coating material, j, added to coating-solids-containing coating materials which were applied at less than 20 mass percent coating solids content, on an as-applied basis, in a month, kg.

(m) [Reserved]

(n) *Combinations of capture and control.* If you operate more than one capture system, more than one control device, one or more never-controlled work stations, or one or more intermittently-controlled work stations, you must calculate organic HAP emissions according to the procedures in paragraphs (n)(1) through (4) of this section, and use the calculation procedures specified in paragraph (n)(5) of this section to convert the monitoring and other data into units of the selected control option in paragraphs (e) through (h) of this section. Use the procedures specified in paragraph (n)(6) of this section to demonstrate compliance.

(1) *Solvent recovery system using liquid-liquid material balance compliance demonstration.* If you choose to comply by means of a liquid-liquid material balance for each solvent recovery system used to control one or more web coating lines, you must determine the organic HAP emissions for those web coating lines controlled by that solvent recovery system either:

(i) In accordance with paragraphs (i)(1)(i) through (iii) and (v) through (vii) of this section, if the web coating lines controlled by that solvent recovery system have only always-controlled work stations; or

(ii) In accordance with paragraphs (i)(1)(ii), (iii), (v), and (vi) and (o) of this section, if the web coating lines controlled by that solvent recovery system have one or more never-controlled or intermittently-controlled work stations.

(2) *Solvent recovery system using performance test compliance demonstration and CEMS.* To demonstrate compliance through an initial test of capture efficiency, continuous monitoring of a capture system operating parameter, and a CEMS on each solvent recovery system used to control one or more web coating lines, you must:

(i) For each capture system delivering emissions to that solvent recovery system, monitor the operating parameter established in accordance with §63.3350(f) to ensure capture system efficiency; and

(ii) Determine the organic HAP emissions for those web coating lines served by each capture system delivering emissions to that solvent recovery system either:

(A) In accordance with paragraphs (i)(2)(i) through (iii), (v), (vi), and (viii) of this section, if the web coating lines served by that capture and control system have only always-controlled work stations; or

(B) In accordance with paragraphs (i)(2)(i) through (iii), (vi), and (o) of this section, if the web coating lines served by that capture and control system have one or more never-controlled or intermittently-controlled work stations.

(3) *Oxidizer.* To demonstrate compliance through performance tests of capture efficiency and control device efficiency, continuous monitoring of capture system, and CPMS for control device operating parameters for each oxidizer used to control emissions from one or more web coating lines, you must:

(i) Monitor the operating parameter in accordance with §63.3350(e) to ensure control device efficiency; and

(ii) For each capture system delivering emissions to that oxidizer, monitor the operating parameter established in accordance with §63.3350(f) to ensure capture efficiency; and

(iii) Determine the organic HAP emissions for those web coating lines served by each capture system delivering emissions to that oxidizer either:

(A) In accordance with paragraphs (k)(1)(i) through (vi) of this section, if the web coating lines served by that capture and control system have only always-controlled work stations; or

(B) In accordance with paragraphs (k)(1)(i) through (iii), (v), and (o) of this section, if the web coating lines served by that capture and control system have one or more never-controlled or intermittently-controlled work stations.

(4) *Uncontrolled coating lines.* If you own or operate one or more uncontrolled web coating lines, you must determine the organic HAP applied on those web coating lines using Equation 6 of this section. The organic HAP emitted from an uncontrolled web coating line is equal to the organic HAP applied on that web coating line.

(5) Convert the information obtained under paragraphs (n)(1) through (4) of this section into the units of the selected compliance option using the calculation procedures specified in paragraphs (n)(5)(i) through (iv) of this section.

(i) *Organic HAP emitted.* Calculate the organic HAP emissions for the affected source for the month by summing all organic HAP emissions calculated according to paragraphs (n)(1), (2)(ii), (3)(iii), and (4) of this section.

(ii) *Coating solids applied.* If demonstrating compliance on the basis of organic HAP emission rate based on coating solids applied or emission of less than the calculated allowable organic HAP, the owner or operator must determine the coating solids content of each coating material applied during the month following the procedure in §63.3360(d).

(iii) *Organic HAP emission rate based on coating solids applied.* Calculate the organic HAP emission rate based on coating solids applied for each month using Equation 9 of this section.

(iv) *Organic HAP based on materials applied.* Calculate the organic HAP emission rate based on material applied using Equation 10 of this section.

(6) *Compliance.* The affected source is in compliance with the emission standards in §63.3320(b) for the month if all operating parameters required to be monitored under paragraphs (n)(1) through (3) of this section were maintained at the values established under §§63.3350 and 63.3360; and

(i) The total mass of organic HAP emitted by the affected source based on coating solids applied is no more than 0.20 kg organic HAP per kg coating solids applied at an existing affected source and no more than 0.08 kg organic HAP per kg coating solids applied at a new affected source; or

(ii) The total mass of organic HAP emitted by the affected source based on material applied is no more than 0.04 kg organic HAP per kg material applied at an existing affected source and no more than 0.016 kg organic HAP per kg material applied at a new affected source; or

(iii) The total mass of organic HAP emitted by the affected source during the month is less than the calculated allowable organic HAP as determined using paragraph (l) of this section; or

(iv) The total mass of organic HAP emitted by the affected source was not more than 5 percent of the total mass of organic HAP applied for the month at an existing affected source and no more than 2 percent of the total mass of organic HAP applied for the month at a new affected source. The total mass of organic HAP applied by the affected source in the month must be determined using Equation 6 of this section.

(o) *Intermittently-controlled and never-controlled work stations.* If you have been expressly referenced to this paragraph by paragraphs (n)(1)(ii), (n)(2)(ii)(B), or (n)(3)(iii)(B) of this section for calculation procedures to determine organic HAP emissions for your intermittently-controlled and never-controlled work stations, you must:

(1) Determine the sum of the mass of all coating materials as-applied on intermittently-controlled work stations operating in bypass mode and the mass of all coating materials as-applied on never-controlled work stations during the month.

(2) Determine the sum of the mass of all coating materials as-applied on intermittently-controlled work stations operating in a controlled mode and the mass of all coating materials applied on always-controlled work stations during the month.

(3) *Liquid-liquid material balance compliance demonstration.* For each web coating line or group of web

coating lines for which you use the provisions of paragraph (n)(1)(ii) of this section, you must calculate the organic HAP emitted during the month using Equation 14 of this section:

$$H_e = \left[\sum_{i=1}^{p} M_{Ci} C_{ahi}\right]\left[1 - \frac{R_v}{100}\right] + \left[\sum_{i=1}^{p} M_{Bi} C_{ahi}\right] - M_{vret} \qquad \text{Eq. 14}$$

Where:

H_e= Total monthly organic HAP emitted, kg.

p = Number of different coating materials applied in a month.

M_{ci}= Sum of the mass of coating material, i, as-applied on intermittently-controlled work stations operating in controlled mode and the mass of coating material, i, as-applied on always-controlled work stations, in a month, kg.

C_{ahi}= Monthly average, as-applied, organic HAP content of coating material, i, expressed as a mass fraction, kg/kg.

R_V= Organic volatile matter collection and recovery efficiency, percent.

M_{Bi}= Sum of the mass of coating material, i, as-applied on intermittently-controlled work stations operating in bypass mode and the mass of coating material, i, as-applied on never-controlled work stations, in a month, kg.

C_{ahi}= Monthly average, as-applied, organic HAP content of coating material, i, expressed as a mass fraction, kg/kg.

M_{vret}= Mass of volatile matter retained in the coated web after curing or drying, or otherwise not emitted to the atmosphere, kg. The value of this term will be zero in all cases except where you choose to take into account the volatile matter retained in the coated web or otherwise not emitted to the atmosphere for the compliance demonstration procedures in this section.

(4) *Performance test to determine capture efficiency and control device efficiency.* For each web coating line or group of web coating lines for which you use the provisions of paragraph (n)(2)(ii)(B) or (n)(3)(iii)(B) of this section, you must calculate the organic HAP emitted during the month using Equation 15 of this section:

$$H_e = \left[\sum_{i=1}^{p} M_{Ci} C_{ahi}\right]\left[1 - \frac{R}{100}\right] + \left[\sum_{i=1}^{p} M_{Bi} C_{ahi}\right] - M_{vret} \qquad \text{Eq. 15}$$

Where:

H_e= Total monthly organic HAP emitted, kg.

p = Number of different coating materials applied in a month.

M_{ci}= Sum of the mass of coating material, i, as-applied on intermittently-controlled work stations operating in controlled mode and the mass of coating material, i, as-applied on always-controlled work stations, in a month, kg.

C_{ahi}= Monthly average, as-applied, organic HAP content of coating material, i, expressed as a

mass fraction, kg/kg.

R = Overall organic HAP control efficiency, percent.

M_{Bi}= Sum of the mass of coating material, i, as-applied on intermittently-controlled work stations operating in bypass mode and the mass of coating material, i, as-applied on never-controlled work stations, in a month, kg.

C_{ahi}= Monthly average, as-applied, organic HAP content of coating material, i, expressed as a mass fraction, kg/kg.

M_{vret}= Mass of volatile matter retained in the coated web after curing or drying, or otherwise not emitted to the atmosphere, kg. The value of this term will be zero in all cases except where you choose to take into account the volatile matter retained in the coated web or otherwise not emitted to the atmosphere for the compliance demonstration procedures in this section.

(p) *Always-controlled work stations with more than one capture and control system.*If you operate more than one capture system or more than one control device and only have always-controlled work stations, then you are in compliance with the emission standards in §63.3320(b)(1) for the month if for each web coating line or group ofweb coating lines controlled bya common control device:

(1) The volatile matter collection and recovery efficiency as determined by paragraphs (i)(1)(i), (iii), (v), and (vi) of this section is at least 95 percent at an existing affected source and at least 98 percent at a new affected source; or

(2) The overall organic HAP control efficiency as determined by paragraphs (i)(2)(i) through (iv) of this section for each web coating line or group ofweb coating lines served by that control device and a common capture system is at least 95 percent at an existing affected source and at least 98 percent at a new affected source; or

(3) The overall organic HAP control efficiency as determined by paragraphs (k)(1)(i) through (iii) and (k)(2)(i) of this section for each web coating line or group ofweb coating lines served by that control device and a common capture system is at least 95 percent at an existing affected source and at least 98 percent at a new affected source.

Notifications, Reports, and Records

§ 63.3400 What notifications and reports must I submit?

(a) Each owner or operator of an affected source subject to this subpart must submit the reports specified in paragraphs (b) through (g) of this section to the Administrator:

(b) You must submit an initial notification as required by §63.9(b).

(1) Initial notification for existing affected sources must be submitted no later than 1 year before the compliance date specified in §63.3330(a).

(2) Initial notification for new and reconstructed affected sources must be submitted as required by §63.9(b).

(3) For the purpose ofthis subpart, a title V or part 70 permit application may be used in lieu of the initial notification required under §63.9(b), provided the same information is contained in the permit application as required by §63.9(b) and the State to which the permit application has been submitted has an approved operating permit program under part 70 of this chapter and has received delegation of authority from the EPA to implement and enforce this subpart.

(4) If you are using a permit application in lieu of an initial notification in accordance with paragraph (b)(3) of this section, the permit application must be submitted by the same due date specified for the initial notification.

(c) You must submit a semiannual compliance report according to paragraphs (c)(1) and (2) of this section.

(1) Compliance report dates.

(i) The first compliance report must cover the period beginning on the compliance date that is specified for your affected source in §63.3330 and ending on June 30 or December 31, whichever date is the first date following the end of the calendar half immediately following the compliance date that is specified for your affected source in §63.3330.

(ii) The first compliance report must be postmarked or delivered no later than July 31 or January 31, whichever date follows the end of the calendar half immediately following the compliance date that is specified for your affected source in §63.3330.

(iii) Each subsequent compliance report must cover the semiannual reporting period from January 1 through June 30 or the semiannual reporting period from July 1 through December 31.

(iv) Each subsequent compliance report must be postmarked or delivered no later than July 31 or January 31, whichever date is the first date following the end of the semiannual reporting period.

(v) For each affected source that is subject to permitting regulations pursuant to 40 CFR part 70 or 40 CFR part 71, and the permitting authority has established dates for submitting semiannual reports pursuant to §70.6(a)(3)(iii)(A) or §71.6(a)(3)(iii)(A), you may submit the first and subsequent compliance reports according to the dates the permitting authority has established instead of according to the dates in paragraphs (c)(1)(i) through (iv) of this section.

(2) The compliance report must contain the information in paragraphs (c)(2)(i) through (vi) of this section:

(i) Company name and address.

(ii) Statement by a responsible official with that official's name, title, and signature certifying the accuracy of the content of the report.

(iii) Date of report and beginning and ending dates of the reporting period.

(iv) If there are no deviations from any emission limitations (emission limit or operating limit) that apply to you, a statement that there were no deviations from the emission limitations during the reporting period, and that no CMS was inoperative, inactive, malfunctioning, out-of-control, repaired, or adjusted.

(v) For each deviation from an emission limitation (emission limit or operating limit) that applies to you and that occurs at an affected source where you are not using a CEMS to comply with the emission limitations in this subpart, the compliance report must contain the information in paragraphs (c)(2)(i) through (iii) of this section, and:

(A) The total operating time of each affected source during the reporting period.

(B) Information on the number, duration, and cause of deviations (including unknown cause), if applicable, and the corrective action taken.

(C) Information on the number, duration, and cause for CPMS downtime incidents, if applicable, other than downtime associated with zero and span and other calibration checks.

(vi) For each deviation from an emission limit occurring at an affected source where you are using a CEMS to comply with the emission limit in this subpart, you must include the information in paragraphs (c)(2)(i) through (iii) and (vi)(A) through (J) of this section.

(A) The date and time that each malfunction started and stopped.

(B) The date and time that each CEMS and CPMS, if applicable, was inoperative except for zero (low-level) and high-level checks.

(C) The date and time that each CEMS and CPMS, if applicable, was out-of-control, including the

information in §63.8(c)(8).

(D) The date and time that each deviation started and stopped, and whether each deviation occurred during a period of startup, shutdown, or malfunction or during another period.

(E) A summary of the total duration (in hours) of each deviation during the reporting period and the total duration of each deviation as a percent of the total source operating time during that reporting period.

(F) A breakdown of the total duration of the deviations during the reporting period into those that are due to startup, shutdown, control equipment problems, process problems, other known causes, and other unknown causes.

(G) A summary of the total duration (in hours) of CEMS and CPMS downtime during the reporting period and the total duration of CEMS and CPMS downtime as a percent of the total source operating time during that reporting period.

(H) A breakdown of the total duration of CEMS and CPMS downtime during the reporting period into periods that are due to monitoring equipment malfunctions, nonmonitoring equipment malfunctions, quality assurance/quality control calibrations, other known causes, and other unknown causes.

(I) The date of the latest CEMS and CPMS certification or audit.

(J) A description of any changes in CEMS, CPMS, or controls since the last reporting period.

(d) You must submit a Notification of Performance Tests as specified in §§63.7 and 63.9(e) if you are complying with the emission standard using a control device and you are required to conduct a performance test of the control device. This notification and the site-specific test plan required under §63.7(c)(2) must identify the operating parameters to be monitored to ensure that the capture efficiency of the capture system and the control efficiency of the control device determined during the performance test are maintained. Unless EPA objects to the parameter or requests changes, you may consider the parameter approved.

(e) You must submit a Notification of Compliance Status as specifed in §63.9(h).

(f) You must submit performance test reports as specified in §63.10(d)(2) if you are using a control device to comply with the emission standard and you have not obtained a waiver from the performance test requirement or you are not exempted from this requirement by §63.3360(b). The performance test reports must be submitted as part of the notification of compliance status required in §633400(e).

(g) You must submit startup, shutdown, and malfunction reports as specifed in §63.10(d)(5), except that the provisions in subpart A of this part pertaining to startups, shutdowns, and malfunctions do not apply unless a control device is used to comply with this subpart.

(1) If actions taken by an owner or operator during a startup, shutdown, or malfunction of an affected source (including actions taken to correct a malfunction) are not consistent with the procedures specified in the affected source's SSMP required by §63.6(e)(3), the owner or operator must state such information in the report. The startup, shutdown, or malfunction report must consist of a letter containing the name, title, and signature of the responsible official who is certifying its accuracy and must be submitted to the Administrator.

(2) Separate startup, shutdown, and malfunction reports are not required if the information is included in the report specified in paragraph (c)(2)(vi) of this section.

§ 63.3410 What records must I keep?

(a) Each owner or operator of an affected source subject to this subpart must maintain the records specified in paragraphs (a)(1) and (2) of this section on a monthly basis in accordance with the requirements of §63.10(b)(1):

(1) Records specifed in §63.10(b)(2) of all measurements needed to demonstrate compliance with this standard, including:

(i) Continuous emission monitor data in accordance with the requirements of §63.3350(d);

(ii) Control device and capture system operating parameter data in accordance with the requirements of §63.3350(c), (e), and (f);

(iii) Organic HAP content data for the purpose of demonstrating compliance in accordance with the requirements of §63.3360(c);

(iv) Volatile matter and coating solids content data for the purpose of demonstrating compliance in accordance with the requirements of §63.3360(d);

(v) Overall control efficiency determination using capture efficiency and control device destruction or removal efficiency test results in accordance with the requirements of §63.3360(e) and (f); and

(vi) Material usage, organic HAP usage, volatile matter usage, and coating solids usage and compliance demonstrations using these data in accordance with the requirements of §63.3370(b), (c), and (d).

(2) Records specified in §63.10(c) for each CMS operated by the owner or operator in accordance with the requirements of §63.3350(b).

(b) Each owner or operator of an affected source subject to this subpart must maintain records of all liquid-liquid material balances performed in accordance with the requirements of §63.3370. The records must be maintained in accordance with the requirements of §63.10(b).

Delegation of Authority

§ 63.3420 What authorities may be delegated to the States?

(a) In delegating implementation and enforcement authority to a State under 40 CFR part 63, subpart E, the authorities contained in paragraph (b) of this section must be retained by the Administrator and not transferred to a State.

(b) Authority which will not be delegated to States: §63.3360(c), approval of alternate test method for organic HAP content determination; §63.3360(d), approval of alternate test method for volatile matter determination.

Table 1 to Subpart JJJJ of Part 63—Operating Limits if Using Add-On Control Devices and Capture System

If you are required to comply with operating limits by §63.3321, you must comply with the applicable operating limits in the following table:

For the following device:	You must meet the following operating limit:	And you must demonstrate continuous compliance with operating limits by:
1. Thermal oxidizer	a. The average combustion temperature in any 3-hour period must not fall below the combustion temperature limit established according to §63.3360(e)(3)(i)	i. Collecting the combustion temperature data according to §63.3350(e)(9); ii. Reducing the data to 3-hour block averages; and iii. Maintain the 3-hour average combustion temperature at or above the temperature limit.

2. Catalytic oxidizer	a. The average temperature at the inlet to the catalyst bed in any 3-hour period must not fall below the combustion temperature limit established according to §63.3360(e)(3)(ii)	i. Collecting the catalyst bed inlet temperature data according to §63.3350(e)(9); ii. Reducing the data to 3-hour block averages; and iii. Maintain the 3-hour average catalyst bed inlet temperature at or above the temperature limit.
	b. The temperature rise across the catalyst bed must not fall below the limit established according to §63.3360(e)(3)(ii)	i. Collecting the catalyst bed inlet and outlet temperature data according to §63.3350(e)(9); ii. Reducing the data to 3-hour block averages; and iii. Maintain the 3-hour average temperature rise across the catalyst bed at or above the limit.
3. Emission capture system	Submit monitoring plan to the Administrator that identifies operating parameters to be monitored according to §63.3350(f)	Conduct monitoring according to the plan (§63.3350(f)(3)).

Table 2 to Subpart JJJJ of Part 63—Applicability of 40 CFR Part 63 General Provisions to Subpart JJJJ

You must comply with the applicable General Provisions requirements according to the following table:

General provisions reference	Applicable to subpart JJJJ	Explanation
§63.1(a)(1)–(4)	Yes.	
§63.1(a)(5)	No	Reserved.
§63.1(a)(6)–(8)	Yes.	
§63.1(a)(9)	No	Reserved.
§63.1(a)(10)–(14)	Yes.	
§63.1(b)(1)	No	Subpart JJJJ specifies applicability.
§63.1(b)(2)–(3)	Yes.	
§63.1(c)(1)	Yes.	
§63.1(c)(2)	No	Area sources are not subject to emission standards of subpart JJJJ.
§63.1(c)(3)	No	Reserved.
§63.1(c)(4)	Yes.	
§63.1(c)(5)	Yes.	

§63.10(f)	Yes.	
§63.11	No.	
§63.12	Yes.	
§63.13	Yes.	
§63.14	Yes	Subpart JJJJ includes provisions for alternative ASME test methods that are incorporated by reference.
§63.15	Yes.	

Browse Previous | Browse Next

For questions or comments regarding e-CFR editorial content, features, or design, email ecfr@nara.gov.

For questions concerning e-CFR programming and delivery issues, email webteam@gpo.gov.

Section 508 / Accessibility

Electronic Code of Federal Regulations
e-CFR™

e-CFR Data is current as of May 12, 2011

Title 40: Protection of Environment

PART 60—STANDARDS OF PERFORMANCE FOR NEW STATIONARY SOURCES

Browse Previous | Browse Next

Subpart IIII—Standards of Performance for Stationary Compression Ignition Internal Combustion Engines

Source: 71 FR 39172, July 11, 2006, unless otherwise noted.

What This Subpart Covers

§ 60.4200 Am I subject to this subpart?

(a) The provisions of this subpart are applicable to manufacturers, owners, and operators of stationary compression ignition (CI) internal combustion engines (ICE) as specifed in paragraphs (a)(1) through (3) of this section. For the purposes of this subpart, the date that construction commences is the date the engine is ordered by the owner or operator.

(1) Manufacturers of stationary CI ICE with a displacement of less than 30 liters per cylinder where the model year is:

(i) 2007 or later, for engines that are not fire pump engines,

(ii) The model year listed in table 3 to this subpart or later model year, for fire pump engines.

(2) Owners and operators of stationary CI ICE that commence construction after July 11, 2005 where the stationary CI ICE are:

(i) Manufactured after April 1, 2006 and are not fire pump engines, or

(ii) Manufactured as a certified National Fire Protection Association (NFPA) fire pump engine after July 1, 2006.

(3) Owners and operators of stationary CI ICE that modify or reconstruct their stationary CI ICE after July 11, 2005.

(b) The provisions of this subpart are not applicable to stationary CI ICE being tested at a stationary CI ICE test cell/stand.

(c) If you are an owner or operator of an area source subject to this subpart, you are exempt from the obligation to obtain a permit under 40 CFR part 70 or 40 CFR part 71, provided you are not required to obtain a permit under 40 CFR 70.3(a) or 40 CFR 71.3(a) for a reason other than your status as an area source under this subpart. Notwithstanding the previous sentence, you must continue to comply with the provisions of this subpart applicable to area sources.

(d) Stationary CI ICE may be eligible for exemption from the requirements of this subpart as described in

40 CFR part 1068, subpart C (or the exemptions described in 40 CFR part 89, subpart J and40 CFR part 94, subpart J, for engines that would need to be certified to standards in those parts), except that owners and operators, as well as manufacturers, may be eligible to request an exemption for national security.

Emission Standards for Manufacturers

§ 60.4201 What emission standards must I meet for non-emergency engines if I am a stationary CI internal combustion engine manufacturer?

(a) Stationary CI internal combustion engine manufacturers must certify their 2007 model year and later non-emergency stationary CI ICE with a maximum engine power less than or equal to 2,237 kilowatt (KW) (3,000 horsepower (HP)) and a displacement of less than 10 liters per cylinder to the certification emission standards for new nonroad CI engines in 40 CFR 89.112, 40 CFR 89.113,40 CFR 1039.101, 40 CFR 1039.102, 40 CFR 1039.104, 40 CFR 1039.105, 40 CFR 1039.107 and 40 CFR 1039.115, as applicable, for all pollutants, for the same model year and maximum engine power.

(b) Stationary CI internal combustion engine manufacturers must certify their 2007 through 2010 model year non-emergency stationary CI ICE with a maximum engine power greater than 2,237 KW(3,000 HP) and a displacement of less than 10 liters per cylinder to the emission standards in table 1 to this subpart, for all pollutants, for the same maximum engine power.

(c) Stationary CI internal combustion engine manufacturers must certify their 2011 model year and later non-emergency stationary CI ICE with a maximum engine power greater than 2,237 KW(3,000 HP) and a displacement of less than 10 liters per cylinder to the certification emission standards for new nonroad CI engines in 40 CFR 1039101, 40 CFR 1039.102, 40 CFR 1039.104, 40 CFR 1039.105, 40 CFR 1039.107, and 40CFR 1039.115, as applicable, for all pollutants, for the same maximum engine power.

(d) Stationary CI internal combustion engine manufacturers must certify their 2007 model year and later non-emergency stationary CI ICE with a displacement of greater than or equal to 10 liters per cylinder and less than 30 liters per cylinder to the certification emission standards for new marine CI engines in 40 CFR 94.8, as applicable, for all pollutants, for the same displacement and maximum engine power.

§ 60.4202 What emission standards must I meet for emergency engines if I am a stationary CI internal combustion engine manufacturer?

(a) Stationary CI internal combustion engine manufacturers must certify their 2007 model year and later emergency stationary CI ICE with a maximum engine power less than or equal to 2,237 KW(3,000 HP) and a displacement of less than 10 liters per cylinder that are not fire pump engines to the emission standards specified in paragraphs (a)(1) through (2) ofthis section.

(1) For engines with a maximum engine power less than 37 KW(50 HP):

(i) The certification emission standards for new nonroad CI engines for the same model year and maximum engine power in 40 CFR 89.112 and 40 CFR 89.113 for all pollutants for model year 2007 engines, and

(ii) The certification emission standards for new nonroad CI engines in 40 CFR 1039.104, 40 CFR 1039.105, 40 CFR 1039.107, 40 CFR 1039.115, and table 2 to this subpart, for 2008 model year and later engines.

(2) For engines with a maximum engine power greater than or equal to 37 KW(50 HP), the certification emission standards for new nonroad CI engines for the same model year and maximum engine power in 40 CFR 89.112 and 40CFR 89.113 for all pollutants beginning in model year 2007.

(b) Stationary CI internal combustion engine manufacturers must certify their 2007 model year and later emergency stationary CI ICE with a maximum engine power greater than 2,237 KW(3,000 HP) and a displacement of less than 10 liters per cylinder that are not fire pump engines to the emission standards specified in paragraphs (b)(1) through (2) of this section.

(1) For 2007 through 2010 model years, the emission standards in table 1 to this subpart, for all pollutants, for the same maximum engine power.

(2) For 2011 model year and later, the certification emission standards for new nonroad CI engines for engines of the same model year and maximum engine power in 40 CFR 89.112 and 40 CFR 89.113 for all pollutants.

(c) Stationary CI internal combustion engine manufacturers must certify their 2007 model year and later emergency stationary CI ICE with a displacement of greater than or equal to 10 liters per cylinder and less than 30 liters per cylinder that are not fire pump engines to the certification emission standards for new marine CI engines in 40 CFR 94.8, as applicable, for all pollutants, for the same displacement and maximum engine power.

(d) Beginning with the model years in table 3 to this subpart, stationary CI internal combustion engine manufacturers must certify their fire pump stationary CI ICE to the emission standards in table 4 to this subpart, for all pollutants, for the same model year and NFPA nameplate power.

§ 60.4203 How long must my engines meet the emission standards if I am a stationary CI internal combustion engine manufacturer?

Engines manufactured by stationary CI internal combustion engine manufacturers must meet the emission standards as required in §§60.4201 and 60.4202 during the useful life of the engines.

Emission Standards for Owners and Operators

§ 60.4204 What emission standards must I meet for non-emergency engines if I am an owner or operator of a stationary CI internal combustion engine?

(a) Owners and operators of pre-2007 model year non-emergency stationary CI ICE with a displacement of less than 10 liters per cylinder must comply with the emission standards in table 1 to this subpart. Owners and operators of pre-2007 model year non-emergency stationary CI ICE with a displacement of greater than or equal to 10 liters per cylinder and less than 30 liters per cylinder must comply with the emission standards in 40 CFR 948(a)(1).

(b) Owners and operators of 2007 model year and later non-emergency stationary CI ICE with a displacement of less than 30 liters per cylinder must comply with the emission standards for new CI engines in §60.4201 for their 2007 model year and later stationary CI ICE, as applicable.

(c) Owners and operators of non-emergency stationary CI ICE with a displacement of greater than or equal to 30 liters per cylinder must meet the requirements in paragraphs (c)(1) and (2) of this section.

(1) Reduce nitrogen oxides (NO_X) emissions by 90 percent or more, or limit the emissions of NO_X in the stationary CI internal combustion engine exhaust to 1.6 grams per KW-hour (g/KW-hr) (1.2 grams per HP-hour (g/HP-hr)).

(2) Reduce particulate matter (PM) emissions by 60 percent or more, or limit the emissions of PM in the stationary CI internal combustion engine exhaust to 0.15 g/KW-hr (0.11 g/HP-hr).

§ 60.4205 What emission standards must I meet for emergency engines if I am an owner or operator of a stationary CI internal combustion engine?

(a) Owners and operators of pre-2007 model year emergency stationary CI ICE with a displacement of less than 10 liters per cylinder that are not fire pump engines must comply with the emission standards in table 1 to this subpart. Owners and operators of pre-2007 model year non-emergency stationary CI ICE with a displacement of greater than or equal to 10 liters per cylinder and less than 30 liters per cylinder that are not fire pump engines must comply with the emission standards in 40 CFR 94.8(a)(1).

(b) Owners and operators of 2007 model year and later emergency stationary CI ICE with a displacement of less than 30 liters per cylinder that are not fire pump engines must comply with the emission standards for new nonroad CI engines in §60.4202, for all pollutants, for the same model year and maximum engine power for their 2007 model year and later emergency stationary CI ICE.

(c) Owners and operators of fire pump engines with a displacement of less than 30 liters per cylinder must comply with the emission standards in table 4 to this subpart, for all pollutants.

(d) Owners and operators of emergency stationary CI ICE with a displacement of greater than or equal to 30 liters per cylinder must meet the requirements in paragraphs (d)(1) and (2) of this section.

(1) Reduce NO_X emissions by 90 percent or more, or limit the emissions of NO_X in the stationary CI internal combustion engine exhaust to 1.6 grams per KW-hour (1.2 grams per HP-hour).

(2) Reduce PM emissions by 60 percent or more, or limit the emissions of PM in the stationary CI internal combustion engine exhaust to 0.15 g/KW-hr (0.11 g/HP-hr).

§ 60.4206 How long must I meet the emission standards if I am an owner or operator of a stationary CI internal combustion engine?

Owners and operators of stationary CI ICE must operate and maintain stationary CI ICE that achieve the emission standards as required in §§60.4204 and 60.4205 according to the manufacturer's written instructions or procedures developed by the owner or operator that are approved by the engine manufacturer, over the entire life of the engine.

Fuel Requirements for Owners and Operators

§ 60.4207 What fuel requirements must I meet if I am an owner or operator of a stationary CI internal combustion engine subject to this subpart?

(a) Beginning October 1, 2007, owners and operators of stationary CI ICE subject to this subpart that use diesel fuel must use diesel fuel that meets the requirements of 40 CFR 80.510(a).

(b) Beginning October 1, 2010, owners and operators of stationary CI ICE subject to this subpart with a displacement of less than 30 liters per cylinder that use diesel fuel must use diesel fuel that meets the requirements of 40 CFR 80.510(b) for nonroad diesel fuel.

(c) Owners and operators of pre-2011 model year stationary CI ICE subject to this subpart may petition the Administrator for approval to use remaining non-compliant fuel that does not meet the fuel requirements of paragraphs (a) and (b) of this section beyond the dates required for the purpose of using up existing fuel inventories. If approved, the petition will be valid for a period of up to 6 months. If additional time is needed, the owner or operator is required to submit a new petition to the Administrator.

(d) Owners and operators of pre-2011 model year stationary CI ICE subject to this subpart that are located in areas of Alaska not accessible by the Federal Aid Highway System may petition the Administrator for approval to use any fuels mixed with used lubricating oil that do not meet the fuel requirements of paragraphs (a) and (b) of this section. Owners and operators must demonstrate in their petition to the Administrator that there is no other place to use the lubricating oil. If approved, the petition will be valid for a period of up to 6 months. If additional time is needed, the owner or operator is required to submit a new petition to the Administrator.

(e) Stationary CI ICE that have a national security exemption under §60.4200(d) are also exempt from the fuel requirements in this section.

Other Requirements for Owners and Operators

§ 60.4208 What is the deadline for importing or installing stationary CI ICE produced in the previous model year?

(a) After December 31, 2008, owners and operators may not install stationary CI ICE (excluding fire pump engines) that do not meet the applicable requirements for 2007 model year engines.

(b) After December 31, 2009, owners and operators may not install stationary CI ICE with a maximum engine power of less than 19 KW (25 HP) (excluding fire pump engines) that do not meet the applicable requirements for 2008 model year engines.

(c) After December 31, 2014, owners and operators may not install non-emergency stationary CI ICE with a maximum engine power of greater than or equal to 19 KW (25 HP) and less than 56 KW (75 HP) that do not meet the applicable requirements for 2013 model year non-emergency engines.

(d) After December 31, 2013, owners and operators may not install non-emergency stationary CI ICE with a maximum engine power of greater than or equal to 56 KW(75 HP) and less than 130 KW (175 HP) that do not meet the applicable requirements for 2012 model year non-emergency engines.

(e) After December 31, 2012, owners and operators may not install non-emergency stationary CI ICE with a maximum engine power of greater than or equal to 130 KW(175 HP), including those above 560 KW (750 HP), that do not meet the applicable requirements for 2011 model year non-emergency engines.

(f) After December 31, 2016, owners and operators may not install non-emergency stationary CI ICE with a maximum engine power of greater than or equal to 560 KW(750 HP) that do not meet the applicable requirements for 2015 model year non-emergency engines.

(g) In addition to the requirements specified in §§60.4201, 60.4202, 604204, and 60.4205, it is prohibited to import stationary CI ICE with a displacement of less than 30 liters per cylinder that do not meet the applicable requirements specified in paragraphs (a) through (f) of this section after the dates specified in paragraphs (a) through (f) of this section.

(h) The requirements of this section do not apply to owners or operators of stationary CI ICE that have been modified, reconstructed, and do not apply to engines that were removed from one existing location and reinstalled at a new location.

§ 60.4209 What are the monitoring requirements if I am an owner or operator of a stationary CI internal combustion engine?

If you are an owner or operator, you must meet the monitoring requirements of this section. In addition, you must also meet the monitoring requirements specified in §60.4211.

(a) If you are an owner or operator of an emergency stationary CI internal combustion engine, you must install a non-resettable hour meter prior to startup of the engine.

(b) If you are an owner or operator of a stationary CI internal combustion engine equipped with a diesel particulate filter to comply with the emission standards in §60.4204, the diesel particulate filter must be installed with a backpressure monitor that notifies the owner or operator when the high backpressure limit of the engine is approached.

Compliance Requirements

§ 60.4210 What are my compliance requirements if I am a stationary CI internal combustion engine manufacturer?

(a) Stationary CI internal combustion engine manufacturers must certify their stationary CI ICE with a displacement of less than 10 liters per cylinder to the emission standards specifed in §60.4201(a) through (c) and §60.4202(a), (b) and (d) using the certifcation procedures required in 40 CFR part 89, subpart B, or 40 CFR part 1039, subpart C, as applicable, and must test their engines as specified in those parts. For the purposes of this subpart, engines certifed to the standards in table 1 to this subpart shall be subject to the same requirements as engines certifed to the standards in 40 CFR part 89. For the purposes of this subpart, engines certifed to the standards in table 4 to this subpart shall be subject to the same requirements as engines certified to the standards in 40 CFR part 89, except that engines with NFPA nameplate power of less than 37 KW (50 HP) certified to model year 2011 or later standards shall be subject to the same requirements as engines certifed to the standards in 40 CFR part 1039.

(b) Stationary CI internal combustion engine manufacturers must certify their stationary CI ICE with a displacement of greater than or equal to 10 liters per cylinder and less than 30 liters per cylinder to the emission standards specifed in §60.4201(d) and §60.4202(c) using the certification procedures required in 40 CFR part 94 subpart C, and must test their engines as specifed in 40 CFR part 94.

(c) Stationary CI internal combustion engine manufacturers must meet the requirements of 40 CFR 1039.120, 40 CFR 1039.125, 40 CFR 1039.130, 40 CFR 1039.135, and 40 CFR part 1068 for engines that are certified to the emission standards in 40 CFR part 1039. Stationary CI internal combustion engine manufacturers must meet the corresponding provisions of 40 CFR part 89 or 40 CFR part 94 for engines that would be covered by that part if they were nonroad (including marine) engines. Labels on such engines must refer to stationary engines, rather than or in addition to nonroad or marine engines, as appropriate. Stationary CI internal combustion engine manufacturers must label their engines

according to paragraphs (c)(1) through (3) of this section.

(1) Stationary CI internal combustion engines manufactured from January 1, 2006 to March 31, 2006 (January 1, 2006 to June 30, 2006 for fire pump engines), other than those that are part of certified engine families under the nonroad CI engine regulations, must be labeled according to 40 CFR 1039.20.

(2) Stationary CI internal combustion engines manufactured from April 1, 2006 to December 31, 2006 (or, for fire pump engines, July 1, 2006 to December 31 of the year preceding the year listed in table 3 to this subpart) must be labeled according to paragraphs (c)(2)(i) through (iii) of this section:

(i) Stationary CI internal combustion engines that are part of certified engine families under the nonroad regulations must meet the labeling requirements for nonroad CI engines, but do not have to meet the labeling requirements in 40 CFR 1039.20.

(ii) Stationary CI internal combustion engines that meet Tier 1 requirements (or requirements for fire pumps) under this subpart, but do not meet the requirements applicable to nonroad CI engines must be labeled according to 40 CFR 1039.20. The engine manufacturer may add language to the label clarifying that the engine meets Tier 1 requirements (or requirements for fire pumps) of this subpart.

(iii) Stationary CI internal combustion engines manufactured after April 1, 2006 that do not meet Tier 1 requirements of this subpart, or fire pumps engines manufactured after July 1, 2006 that do not meet the requirements for fire pumps under this subpart, may not be used in the U.S. If any such engines are manufactured in the U.S. after April 1, 2006 (July 1, 2006 for fire pump engines), they must be exported or must be brought into compliance with the appropriate standards prior to initial operation. The export provisions of 40 CFR 1068.230 would apply to engines for export and the manufacturers must label such engines according to 40 CFR 1068.230.

(3) Stationary CI internal combustion engines manufactured after January 1, 2007 (for fire pump engines, after January 1 of the year listed in table 3 to this subpart, as applicable) must be labeled according to paragraphs (c)(3)(i) through (iii) of this section.

(i) Stationary CI internal combustion engines that meet the requirements of this subpart and the corresponding requirements for nonroad (including marine) engines of the same model year and HP must be labeled according to the provisions in part 89, 94 or 1039, as appropriate.

(ii) Stationary CI internal combustion engines that meet the requirements of this subpart, but are not certified to the standards applicable to nonroad (including marine) engines of the same model year and HP must be labeled according to the provisions in part 89, 94 or 1039, as appropriate, but the words "stationary" must be included instead of "nonroad" or "marine" on the label. In addition, such engines must be labeled according to 40 CFR 1039.20.

(iii) Stationary CI internal combustion engines that do not meet the requirements of this subpart must be labeled according to 40 CFR 1068.230 and must be exported under the provisions of 40 CFR 1068.230.

(d) An engine manufacturer certifying an engine family or families to standards under this subpart that are identical to standards applicable under parts 89, 94, or 1039 for that model year may certify any such family that contains both nonroad (including marine) and stationary engines as a single engine family and/or may include any such family containing stationary engines in the averaging, banking and trading provisions applicable for such engines under those parts.

(e) Manufacturers of engine families discussed in paragraph (d) of this section may meet the labeling requirements referred to in paragraph (c) of this section for stationary CI ICE by either adding a separate label containing the information required in paragraph (c) of this section or by adding the words "and stationary" after the word "nonroad" or "marine," as appropriate, to the label.

(f) Starting with the model years shown in table 5 to this subpart, stationary CI internal combustion engine manufacturers must add a permanent label stating that the engine is for stationary emergency use only to each new emergency stationary CI internal combustion engine greater than or equal to 19 KW (25 HP) that meets all the emission standards for emergency engines in §60.4202 but does not meet all the emission standards for non-emergency engines in §60.4201. The label must be added according to the labeling requirements specified in 40 CFR 1039.135(b). Engine manufacturers must specify in the owner's manual that operation of emergency engines is limited to emergency operations and required maintenance and testing.

(g) Manufacturers of fire pump engines may use the test cycle in table 6 to this subpart for testing fire pump engines and may test at the NFPA certified nameplate HP, provided that the engine is labeled as "Fire Pump Applications Only".

(h) Engine manufacturers, including importers, may introduce into commerce uncertified engines or engines certified to earlier standards that were manufactured before the new or changed standards took effect until inventories are depleted, as long as such engines are part of normal inventory. For example, if the engine manufacturers' normal industry practice is to keep on hand a one-month supply of engines based on its projected sales, and a new tier of standards starts to apply for the 2009 model year, the engine manufacturer may manufacture engines based on the normal inventory requirements late in the 2008 model year, and sell those engines for installation. The engine manufacturer may not circumvent the provisions of §§60.4201 or 60.4202 by stockpiling engines that are built before new or changed standards take effect. Stockpiling of such engines beyond normal industry practice is a violation of this subpart.

(i) The replacement engine provisions of 40 CFR 89.1003(b)(7), 40 CFR 94.1103(b)(3), 40 CFR 94.1103 (b)(4) and 40 CFR 1068.240 are applicable to stationary CI engines replacing existing equipment that is less than 15 years old.

§ 60.4211 What are my compliance requirements if I am an owner or operator of a stationary CI internal combustion engine?

(a) If you are an owner or operator and must comply with the emission standards specifed in this subpart, you must operate and maintain the stationary CI internal combustion engine and control device according to the manufacturer's written instructions or procedures developed by the owner or operator that are approved by the engine manufacturer. In addition, owners and operators may only change those settings that are permitted by the manufacturer. You must also meet the requirements of 40 CFR parts 89, 94 and/or 1068, as they apply to you.

(b) If you are an owner or operator of a pre-2007 model year stationary CI internal combustion engine and must comply with the emission standards specified in §§60.4204(a) or 60.4205(a), or if you are an owner or operator of a CI fire pump engine that is manufactured prior to the model years in table 3 to this subpart and must comply with the emission standards specifed in §60.4205(c), you must demonstrate compliance according to one of the methods specifed in paragraphs (b)(1) through (5) of this section.

(1) Purchasing an engine certified according to 40 CFR part 89 or 40 CFR part 94, as applicable, for the same model year and maximum engine power. The engine must be installed and configured according to the manufacturer's specifications.

(2) Keeping records of performance test results for each pollutant for a test conducted on a similar engine. The test must have been conducted using the same methods specifed in this subpart and these methods must have been followed correctly.

(3) Keeping records of engine manufacturer data indicating compliance with the standards.

(4) Keeping records of control device vendor data indicating compliance with the standards.

(5) Conducting an initial performance test to demonstrate compliance with the emission standards according to the requirements specified in §60.4212, as applicable.

(c) If you are an owner or operator of a 2007 model year and later stationary CI internal combustion engine and must comply with the emission standards specifed in §60.4204(b) or §60.4205(b), or if you are an owner or operator of a CI fire pump engine that is manufactured during or after the model year that applies to your fire pump engine power rating in table 3 to this subpart and must comply with the emission standards specifed in §60.4205(c), you must comply by purchasing an engine certified to the emission standards in §60.4204(b), or §60.4205(b) or (c), as applicable, for the same model year and maximum (or in the case of fire pumps, NFPA nameplate) engine power. The engine must be installed and configured according to the manufacturer's specifications.

(d) If you are an owner or operator and must comply with the emission standards specifed in §60.4204 (c) or §60.4205(d), you must demonstrate compliance according to the requirements specified in paragraphs (d)(1) through (3) of this section.

(1) Conducting an initial performance test to demonstrate initial compliance with the emission standards

as specified in §60.4213.

(2) Establishing operating parameters to be monitored continuously to ensure the stationary internal combustion engine continues to meet the emission standards. The owner or operator must petition the Administrator for approval of operating parameters to be monitored continuously. The petition must include the information described in paragraphs (d)(2)(i) through (v) of this section.

(i) Identification of the specific parameters you propose to monitor continuously;

(ii) A discussion of the relationship between these parameters and NO_X and PM emissions, identifying how the emissions of these pollutants change with changes in these parameters, and how limitations on these parameters will serve to limit NO_X and PM emissions;

(iii) A discussion of how you will establish the upper and/or lower values for these parameters which will establish the limits on these parameters in the operating limitations;

(iv) A discussion identifying the methods and the instruments you will use to monitor these parameters, as well as the relative accuracy and precision of these methods and instruments; and

(v) A discussion identifying the frequency and methods for recalibrating the instruments you will use for monitoring these parameters.

(3) For non-emergency engines with a displacement of greater than or equal to 30 liters per cylinder, conducting annual performance tests to demonstrate continuous compliance with the emission standards as specified in §60.4213.

(e) Emergency stationary ICE may be operated for the purpose of maintenance checks and readiness testing, provided that the tests are recommended by Federal, State, or local government, the manufacturer, the vendor, or the insurance company associated with the engine. Maintenance checks and readiness testing of such units is limited to 100 hours per year. There is no time limit on the use of emergency stationary ICE in emergency situations. Anyone may petition the Administrator for approval of additional hours to be used for maintenance checks and readiness testing, but a petition is not required if the owner or operator maintains records indicating that Federal, State, or local standards require maintenance and testing of emergency ICE beyond 100 hours per year. For owners and operators of emergency engines meeting standards under §60.4205 but not §60.4204, any operation other than emergency operation, and maintenance and testing as permitted in this section, is prohibited.

Testing Requirements for Owners and Operators

§ 60.4212 What test methods and other procedures must I use if I am an owner or operator of a stationary CI internal combustion engine with a displacement of less than 30 liters per cylinder?

Owners and operators of stationary CI ICE with a displacement of less than 30 liters per cylinder who conduct performance tests pursuant to this subpart must do so according to paragraphs (a) through (d) of this section.

(a) The performance test must be conducted according to the in-use testing procedures in 40 CFR part 1039, subpart F.

(b) Exhaust emissions from stationary CI ICE that are complying with the emission standards for new CI engines in 40 CFR part 1039 must not exceed the not-to-exceed (NTE) standards for the same model year and maximum engine power as required in 40 CFR 1039.101(e) and 40 CFR 1039102(g)(1), except as specified in 40 CFR 1039.104(d). This requirement starts when NTE requirements take effect for nonroad diesel engines under 40 CFR part 1039.

(c) Exhaust emissions from stationary CI ICE that are complying with the emission standards for new CI engines in 40 CFR 89.112 or 40 CFR 94.8, as applicable, must not exceed the NTE numerical requirements, rounded to the same number of decimal places as the applicable standard in 40 CFR 89.112 or 40 CFR 94.8, as applicable, determined from the following equation:

$$\text{NTE requirement for each pollutant} = (1.25) \times (\text{STD}) \qquad \text{(Eq. 1)}$$

Where:

STD = The standard specified for that pollutant in 40 CFR 89.112 or 40 CFR 94.8, as applicable.

Alternatively, stationary CI ICE that are complying with the emission standards for new CI engines in 40 CFR 89.112 or 40 CFR 94.8 may follow the testing procedures specifed in §60.4213 of this subpart, as appropriate.

(d) Exhaust emissions from stationary CI ICE that are complying with the emission standards for pre-2007 model year engines in §60.4204(a), §60.4205(a), or §60.4205(c) must not exceed the NTE numerical requirements, rounded to the same number of decimal places as the applicable standard in §60.4204(a), §60.4205(a), or §60.4205(c), determined from the equation in paragraph (c) of this section.

Where:

STD = The standard specified for that pollutant in §60.4204(a), §60.4205(a), or §60.4205(c).

Alternatively, stationary CI ICE that are complying with the emission standards for pre-2007 model year engines in §60.4204(a), §60.4205(a), or §60.4205(c) may follow the testing procedures specified in §60.4213, as appropriate.

§ 60.4213 What test methods and other procedures must I use if I am an owner or operator of a stationary CI internal combustion engine with a displacement of greater than or equal to 30 liters per cylinder?

Owners and operators of stationary CI ICE with a displacement of greater than or equal to 30 liters per cylinder must conduct performance tests according to paragraphs (a) through (d) of this section.

(a) Each performance test must be conducted according to the requirements in §60.8 and under the specific conditions that this subpart specifies in table 7. The test must be conducted within 10 percent of 100 percent peak (or the highest achievable) load.

(b) You may not conduct performance tests during periods of startup, shutdown, or malfunction, as specified in §60.8(c).

(c) You must conduct three separate test runs for each performance test required in this section as specified in §60.8(f). Each test run must last at least 1 hour.

(d) To determine compliance with the percent reduction requirement, you must follow the requirements as specified in paragraphs (d)(1) through (3) of this section.

(1) You must use Equation 2 of this section to determine compliance with the percent reduction requirement:

$$\frac{C_i - C_o}{C_i} \times 100 = R \qquad \text{(Eq. 2)}$$

Where:

C_i = concentration of NO_X or PM at the control device inlet,

C_o = concentration of NO_X or PM at the control device outlet, and

R = percent reduction of NO_X or PM emissions.

(2) You must normalize the NO_X or PM concentrations at the inlet and outlet of the control device to a dry basis and to 15 percent oxygen (O_2) using Equation 3 of this section, or an equivalent percent carbon dioxide (CO_2) using the procedures described in paragraph (d)(3) of this section.

$$C_{adj} = C_d \frac{5.9}{20.9 - \%O_2} \quad \text{(Eq. 3)}$$

Where:

C_{adj} = Calculated NO_X or PM concentration adjusted to 15 percent O_2.

C_d = Measured concentration of NO_X or PM, uncorrected.

5.9 = 20.9 percent O_2 − 15 percent O_2, the defined O_2 correction value, percent.

$\%O_2$ = Measured O_2 concentration, dry basis, percent.

(3) If pollutant concentrations are to be corrected to 15 percent O_2 and CO_2 concentration is measured in lieu of O_2 concentration measurement, a CO_2 correction factor is needed. Calculate the CO_2 correction factor as described in paragraphs (d)(3)(i) through (iii) of this section.

(i) Calculate the fuel-specific F_o value for the fuel burned during the test using values obtained from Method 19, Section 5.2, and the following equation:

$$F_o = \frac{0.209 F_d}{F_c} \quad \text{(Eq. 4)}$$

Where:

F_o = Fuel factor based on the ratio of O_2 volume to the ultimate CO_2 volume produced by the fuel at zero percent excess air.

0.209 = Fraction of air that is O_2, percent/100.

F_d = Ratio of the volume of dry effluent gas to the gross calorific value of the fuel from Method 19, dsm^3/J ($dscf/10^6$ Btu).

F_c = Ratio of the volume of CO_2 produced to the gross calorific value of the fuel from Method 19, dsm^3/J ($dscf/10^6$ Btu).

(ii) Calculate the CO_2 correction factor for correcting measurement data to 15 percent O_2, as follows:

$$X_{CO_2} = \frac{5.9}{F_o} \quad \text{(Eq. 5)}$$

Where:

X_{CO2} = CO_2 correction factor, percent.

5.9 = 20.9 percent O_2 − 15 percent O_2, the defined O_2 correction value, percent.

(iii) Calculate the NO_X and PM gas concentrations adjusted to 15 percent O_2 using CO_2 as follows:

$$C_{adj} = C_d \frac{X_{CO_2}}{\%CO_2} \qquad \text{(Eq. 6)}$$

Where:

C_{adj} = Calculated NO_X or PM concentration adjusted to 15 percent O_2.

C_d = Measured concentration of NO_X or PM, uncorrected.

$\%CO_2$ = Measured CO_2 concentration, dry basis, percent.

(e) To determine compliance with the NO_X mass per unit output emission limitation, convert the concentration of NO_X in the engine exhaust using Equation 7 of this section:

$$ER = \frac{C_d \times 1.912 \times 10^{-3} \times Q \times T}{\text{KW-hour}} \qquad \text{(Eq. 7)}$$

Where:

ER = Emission rate in grams per KW-hour.

C_d = Measured NO_X concentration in ppm.

1.912×10^{-3} = Conversion constant for ppm NO_X to grams per standard cubic meter at 25 degrees Celsius.

Q = Stack gas volumetric flow rate, in standard cubic meter per hour.

T = Time of test run, in hours.

KW-hour = Brake work of the engine, in KW-hour.

(f) To determine compliance with the PM mass per unit output emission limitation, convert the concentration of PM in the engine exhaust using Equation 8 of this section:

$$ER = \frac{C_{adj} \times Q \times T}{\text{KW-hour}} \qquad \text{(Eq. 8)}$$

Where:

ER = Emission rate in grams per KW-hour.

C_{adj} = Calculated PM concentration in grams per standard cubic meter.

Q = Stack gas volumetric flow rate, in standard cubic meter per hour.

T = Time of test run, in hours.

KW-hour = Energy output of the engine, in KW.

Notification, Reports, and Records for Owners and Operators

§ 60.4214 What are my notification, reporting, and recordkeeping requirements if I am an owner or operator of a stationary CI internal combustion engine?

(a) Owners and operators of non-emergency stationary CI ICE that are greater than 2,237 KW (3,000 HP), or have a displacement of greater than or equal to 10 liters per cylinder, or are pre-2007 model year engines that are greater than 130 KW (175 HP) and not certified, must meet the requirements of paragraphs (a)(1) and (2) of this section.

(1) Submit an initial notification as required in §60.7(a)(1). The notification must include the information in paragraphs (a)(1)(i) through (v) of this section.

(i) Name and address of the owner or operator;

(ii) The address of the affected source;

(iii) Engine information including make, model, engine family, serial number, model year, maximum engine power, and engine displacement;

(iv) Emission control equipment; and

(v) Fuel used.

(2) Keep records of the information in paragraphs (a)(2)(i) through (iv) of this section.

(i) All notifications submitted to comply with this subpart and all documentation supporting any notification.

(ii) Maintenance conducted on the engine.

(iii) If the stationary CI internal combustion is a certified engine, documentation from the manufacturer that the engine is certified to meet the emission standards.

(iv) If the stationary CI internal combustion is not a certified engine, documentation that the engine meets the emission standards.

(b) If the stationary CI internal combustion engine is an emergency stationary internal combustion engine, the owner or operator is not required to submit an initial notification. Starting with the model years in table 5 to this subpart, if the emergency engine does not meet the standards applicable to non-emergency engines in the applicable model year, the owner or operator must keep records of the operation of the engine in emergency and non-emergency service that are recorded through the non-resettable hour meter. The owner must record the time of operation of the engine and the reason the engine was in operation during that time.

(c) If the stationary CI internal combustion engine is equipped with a diesel particulate filter, the owner or operator must keep records of any corrective action taken after the backpressure monitor has notified the owner or operator that the high backpressure limit of the engine is approached.

Special Requirements

§ 60.4215 What requirements must I meet for engines used in Guam, American Samoa, or the Commonwealth of the Northern Mariana Islands?

(a) Stationary CI ICE that are used in Guam, American Samoa, or the Commonwealth of the Northern Mariana Islands are required to meet the applicable emission standards in §60.4205. Non-emergency stationary CI ICE with a displacement of greater than or equal to 30 liters per cylinder, must meet the applicable emission standards in §60.4204(c).

(b) Stationary CI ICE that are used in Guam, American Samoa, or the Commonwealth of the Northern Mariana Islands are not required to meet the fuel requirements in §60.4207.

§ 60.4216 What requirements must I meet for engines used in Alaska?

(a) Prior to December 1, 2010, owners and operators of stationary CI engines located in areas of Alaska not accessible by the Federal Aid Highway System should refer to 40 CFR part 69 to determine the diesel fuel requirements applicable to such engines.

(b) The Governor of Alaska may submit for EPA approval, by no later than January 11, 2008, an alternative plan for implementing the requirements of 40 CFR part 60, subpart IIII, for public-sector electrical utilities located in rural areas of Alaska not accessible by the Federal Aid Highway System. This alternative plan must be based on the requirements of section 111 of the Clean Air Act including any increased risks to human health and the environment and must also be based on the unique circumstances related to remote power generation, climatic conditions, and serious economic impacts resulting from implementation of 40 CFR part 60, subpart IIII. If EPA approves by rulemaking process an alternative plan, the provisions as approved by EPA under that plan shall apply to the diesel engines used in new stationary internal combustion engines subject to this paragraph.

§ 60.4217 What emission standards must I meet if I am an owner or operator of a stationary internal combustion engine using special fuels?

(a) Owners and operators of stationary CI ICE that do not use diesel fuel, or who have been given authority by the Administrator under §60.4207(d) of this subpart to use fuels that do not meet the fuel requirements of paragraphs (a) and (b) of §60.4207, may petition the Administrator for approval of alternative emission standards, if they can demonstrate that they use a fuel that is not the fuel on which the manufacturer of the engine certified the engine and that the engine cannot meet the applicable standards required in §604202 or §60.4203 using such fuels.

(b) [Reserved]

General Provisions

§ 60.4218 What parts of the General Provisions apply to me?

Table 8 to this subpart shows which parts of the General Provisions in §§60.1 through 60.19 apply to you.

Definitions

§ 60.4219 What definitions apply to this subpart?

As used in this subpart, all terms not defined herein shall have the meaning given them in the CAA and in subpart A of this part.

Combustion turbine means all equipment, including but not limited to the turbine, the fuel, air, lubrication and exhaust gas systems, control systems (except emissions control equipment), and any ancillary components and sub-components comprising any simple cycle combustion turbine, any regenerative/recuperative cycle combustion turbine, the combustion turbine portion of any cogeneration cycle combustion system, or the combustion turbine portion of any combined cycle steam/electric generating system.

Compression ignition means relating to a type of stationary internal combustion engine that is not a spark ignition engine.

Diesel fuel means any liquid obtained from the distillation of petroleum with a boiling point of approximately 150 to 360 degrees Celsius. One commonly used form is number 2 distillate oil.

Diesel particulate filter means an emission control technology that reduces PM emissions by trapping the particles in a flow filter substrate and periodically removes the collected particles by either physical action or by oxidizing (burning off) the particles in a process called regeneration.

Emergency stationary internal combustion engine means any stationary internal combustion engine whose operation is limited to emergency situations and required testing and maintenance. Examples include stationary ICE used to produce power for critical networks or equipment (including power supplied to portions of a facility) when electric power from the local utility (or the normal power source, if the facility runs on its own power production) is interrupted, or stationary ICE used to pump water in the case of fire or flood, etc. Stationary CI ICE used to supply power to an electric grid or that supply power

as part of a financial arrangement with another entity are not considered to be emergency engines.

Engine manufacturer means the manufacturer of the engine. See the definition of "manufacturer" in this section.

Fire pump engine means an emergency stationary internal combustion engine certified to NFPA requirements that is used to provide power to pump water for fire suppression or protection.

Manufacturer has the meaning given in section 216(1) of the Act. In general, this term includes any person who manufactures a stationary engine for sale in the United States or otherwise introduces a new stationary engine into commerce in the United States. This includes importers who import stationary engines for sale or resale.

Maximum engine power means maximum engine power as defined in 40 CFR 1039.801.

Model year means either:

(1) The calendar year in which the engine was originally produced, or

(2) The annual new model production period of the engine manufacturer if it is different than the calendar year. This must include January 1 of the calendar year for which the model year is named. It may not begin before January 2 of the previous calendar year and it must end by December 31 of the named calendar year. For an engine that is converted to a stationary engine after being placed into service as a nonroad or other non-stationary engine, model year means the calendar year or new model production period in which the engine was originally produced.

Other internal combustion engine means any internal combustion engine, except combustion turbines, which is not a reciprocating internal combustion engine or rotary internal combustion engine.

Reciprocating internal combustion engine means any internal combustion engine which uses reciprocating motion to convert heat energy into mechanical work.

Rotary internal combustion engine means any internal combustion engine which uses rotary motion to convert heat energy into mechanical work.

Spark ignition means relating to a gasoline, natural gas, or liquefied petroleum gas fueled engine or any other type of engine with a spark plug (or other sparking device) and with operating characteristics significantly similar to the theoretical Otto combustion cycle. Spark ignition engines usually use a throttle to regulate intake air flow to control power during normal operation. Dual-fuel engines in which a liquid fuel (typically diesel fuel) is used for CI and gaseous fuel (typically natural gas) is used as the primary fuel at an annual average ratio of less than 2 parts diesel fuel to 100 parts total fuel on an energy equivalent basis are spark ignition engines.

Stationary internal combustion engine means any internal combustion engine, except combustion turbines, that converts heat energy into mechanical work and is not mobile. Stationary ICE differ from mobile ICE in that a stationary internal combustion engine is not a nonroad engine as defined at 40 CFR 1068.30 (excluding paragraph (2)(ii) of that definition), and is not used to propel a motor vehicle or a vehicle used solely for competition. Stationary ICE include reciprocating ICE, rotary ICE, and other ICE, except combustion turbines.

Subpart means 40 CFR part 60, subpart IIII.

Useful life means the period during which the engine is designed to properly function in terms of reliability and fuel consumption, without being remanufactured, specified as a number of hours of operation or calendar years, whichever comes first. The values for useful life for stationary CI ICE with a displacement of less than 10 liters per cylinder are given in 40 CFR 1039.101(g). The values for useful life for stationary CI ICE with a displacement of greater than or equal to 10 liters per cylinder and less than 30 liters per cylinder are given in 40 CFR 94.9(a).

Table 1 to Subpart IIII of Part 60—Emission Standards for Stationary Pre-2007 Model Year Engines With a Displacement of <10 Liters per Cylinder and 2007–2010 Model Year Engines >2,237 KW (3,000 HP) and With a Displacement of <10 Liters per Cylinder

[As stated in §§60.4201(b), 60.4202(b), 60.4204(a), and 60.4205(a), you must comply with the following emission standards]

Maximum engine power	Emission standards for stationary pre-2007 model year engines with a displacement of <10 liters per cylinder and 2007–2010 model year engines >2,237 KW (3,000 HP) and with a displacement of <10 liters per cylinder in g/KW-hr (g/HP-hr)				
	NMHC + NO_X	HC	NO_X	CO	PM
KW<8 (HP<11)	10.5 (7.8)			8.0 (6.0)	1.0 (0.75)
8≤KW<19 (11≤HP<25)	9.5 (7.1)			6.6 (4.9)	0.80 (0.60)
19≤KW<37 (25≤HP<50)	9.5 (7.1)			5.5 (4.1)	0.80 (0.60)
37≤KW<56 (50≤HP<75)			9.2 (6.9)		
56≤KW<75 (75≤HP<100)			9.2 (6.9)		
75≤KW<130 (100≤HP<175)			9.2 (6.9)		
130≤KW<225 (175≤HP<300)		1.3 (1.0)	9.2 (6.9)	11.4 (8.5)	0.54 (0.40)
225≤KW<450 (300≤HP<600)		1.3 (1.0)	9.2 (6.9)	11.4 (8.5)	0.54 (0.40)
450≤KW≤560 (600≤HP≤750)		1.3 (1.0)	9.2 (6.9)	11.4 (8.5)	0.54 (0.40)
KW>560 (HP>750)		1.3 (1.0)	9.2 (6.9)	11.4 (8.5)	0.54 (0.40)

Table 2 to Subpart IIII of Part 60—Emission Standards for 2008 Model Year and Later Emergency Stationary CI ICE <37 KW (50 HP) With a Displacement of <10 Liters per Cylinder

[As stated in §60.4202(a)(1), you must comply with the following emission standards]

Engine power	Emission standards for 2008 model year and later emergency stationary CI ICE <37 KW (50 HP) with a displacement of <10 liters per cylinder in g/KW-hr (g/HP-hr)			
	Model year(s)	NO_X+ NMHC	CO	PM
KW<8 (HP<11)	2008+	7.5 (5.6)	8.0 (6.0)	0.40 (0.30)
8≤KW<19 (11≤HP<25)	2008+	7.5 (5.6)	6.6 (4.9)	0.40 (0.30)
19≤KW<37 (25≤HP<50)	2008+	7.5 (5.6)	5.5 (4.1)	0.30 (0.22)

Table 3 to Subpart IIII of Part 60—Certification Requirements for Stationary Fire Pump

Engines

[As stated in §60.4202(d), you must certify new stationary fire pump engines beginning with the following model years:]

Engine power	Starting model year engine manufacturers must certify new stationary fire pump engines according to §60.4202(d)
KW<75 (HP<100)	2011
75≤KW<130 (100≤HP<175)	2010
130≤KW≤560 (175≤HP≤750)	2009
KW>560 (HP>750)	2008

Table 4 to Subpart IIII of Part 60—Emission Standards for Stationary Fire Pump Engines

[As stated in §§60.4202(d) and 60.4205(c), you must comply with the following emission standards for stationary fire pump engines]

Maximum engine power	Model year(s)	NMHC + NO_X	CO	PM
KW<8 (HP<11)	2010 and earlier	10.5 (7.8)	8.0 (6.0)	1.0 (0.75)
	2011+	7.5 (5.6)		0.40 (0.30)
8≤KW<19 (11≤HP<25)	2010 and earlier	9.5 (7.1)	6.6 (4.9)	0.80 (0.60)
	2011+	7.5 (5.6)		0.40 (0.30)
19≤KW<37 (25≤HP<50)	2010 and earlier	9.5 (7.1)	5.5 (4.1)	0.80 (0.60)
	2011+	7.5 (5.6)		0.30 (0.22)
37≤KW<56 (50≤HP<75)	2010 and earlier	10.5 (7.8)	5.0 (3.7)	0.80 (0.60)
	2011+[1]	4.7 (3.5)		0.40 (0.30)
56≤KW<75 (75≤HP<100)	2010 and earlier	10.5 (7.8)	5.0 (3.7)	0.80 (0.60)
	2011+[1]	4.7 (3.5)		0.40 (0.30)
75≤KW<130 (100≤HP<175)	2009 and earlier	10.5 (7.8)	5.0 (3.7)	0.80 (0.60)
	2010+[2]	4.0 (3.0)		0.30 (0.22)
130≤KW<225	2008 and	10.5 (7.8)	3.5	0.54

(175≤HP<300)	earlier		(2.6)	(0.40)
	2009+[3]	4.0 (3.0)		0.20 (0.15)
225≤KW<450 (300≤HP<600)	2008 and earlier	10.5 (7.8)	3.5 (2.6)	0.54 (0.40)
	2009+[3]	4.0 (3.0)		0.20 (0.15)
450≤KW≤560 (600≤HP≤750)	2008 and earlier	10.5 (7.8)	3.5 (2.6)	0.54 (0.40)
	2009+	4.0 (3.0)		0.20 (0.15)
KW>560 (HP>750)	2007 and earlier	10.5 (7.8)	3.5 (2.6)	0.54 (0.40)
	2008+	6.4 (4.8)		0.20 (0.15)

[1]For model years 2011–2013, manufacturers, owners and operators of fire pump stationary CI ICE in this engine power category with a rated speed of greater than 2,650 revolutions per minute (rpm) may comply with the emission limitations for 2010 model year engines.

[2]For model years 2010–2012, manufacturers, owners and operators of fire pump stationary CI ICE in this engine power category with a rated speed of greater than 2,650 rpm may comply with the emission limitations for 2009 model year engines.

[3]In model years 2009–2011, manufacturers of fire pump stationary CI ICE in this engine power category with a rated speed of greater than 2,650 rpm may comply with the emission limitations for 2008 model year engines.

Table 5 to Subpart IIII of Part 60—Labeling and Recordkeeping Requirements for New Stationary Emergency Engines

[You must comply with the labeling requirements in §60.4210(f) and the recordkeeping requirements in §60.4214(b) for new emergency stationary CI ICE beginning in the following model years:]

Engine power	Starting model year
19≤KW<56 (25≤HP<75)	2013
56≤KW<130 (75≤HP<175)	2012
KW≥130 (HP≥175)	2011

Table 6 to Subpart IIII of Part 60—Optional 3-Mode Test Cycle for Stationary Fire Pump Engines

[As stated in §60.4210(g), manufacturers of fire pump engines may use the following test cycle for testing fire pump engines:]

Mode No.	Engine speed[1]	Torque (percent)[2]	Weighting factors
1	Rated	100	0.30
2	Rated	75	0.50
3	Rated	50	0.20

[1]Engine speed: ±2 percent of point.

[2]Torque: NFPA certified nameplate HP for 100 percent point. All points should be ±2 percent of engine percent load value.

Table 7 to Subpart IIII of Part 60—Requirements for Performance Tests for Stationary CI ICE With a Displacement of ≥30 Liters per Cylinder

[As stated in §60.4213, you must comply with the following requirements for performance tests for stationary CI ICE with a displacement of ≥30 liters per cylinder:]

For each	Complying with the requirement to	You must	Using	According to the following requirements
1. Stationary CI internal combustion engine with a displacement of ≥30 liters per cylinder	a. Reduce NO_X emissions by 90 percent or more	i. Select the sampling port location and the number of traverse points;	(1) Method 1 or 1A of 40 CFR part 60, appendix A	(a) Sampling sites must be located at the inlet and outlet of the control device.
		ii. Measure O_2 at the inlet and outlet of the control device;	(2) Method 3, 3A, or 3B of 40 CFR part 60, appendix A	(b) Measurements to determine O_2 concentration must be made at the same time as the measurements for NO_X concentration.
		iii. If necessary, measure moisture content at the inlet and outlet of the control device; and,	(3) Method 4 of 40 CFR part 60, appendix A, Method 320 of 40 CFR part 63, appendix A, or ASTM D 6348–03 (incorporated by reference, see §60.17)	(c) Measurements to determine moisture content must be made at the same time as the measurements for NO_X concentration.
		iv. Measure NO_X at the inlet and outlet of the control device	(4) Method 7E of 40 CFR part 60, appendix A, Method 320 of 40 CFR part 63, appendix A,	(d) NO_X concentration must be at 15 percent O_2, dry basis. Results of this test consist of the average of the

			or ASTM D 6348–03 (incorporated by reference, see §60.17)	three 1-hour or longer runs.
	b. Limit the concentration of NO_X in the stationary CI internal combustion engine exhaust.	i. Select the sampling port location and the number of traverse points;	(1) Method 1 or 1A of 40 CFR part 60, appendix A	(a) If using a control device, the sampling site must be located at the outlet of the control device.
		ii. Determine the O_2 concentration of the stationary internal combustion engine exhaust at the sampling port location; and,	(2) Method 3, 3A, or 3B of 40 CFR part 60, appendix A	(b) Measurements to determine O_2 concentration must be made at the same time as the measurement for NO_X concentration.
		iii. If necessary, measure moisture content of the stationary internal combustion engine exhaust at the sampling port location; and,	(3) Method 4 of 40 CFR part 60, appendix A, Method 320 of 40 CFR part 63, appendix A, or ASTM D 6348–03 (incorporated by reference, see §60.17)	(c) Measurements to determine moisture content must be made at the same time as the measurement for NO_X concentration.
		iv. Measure NO_X at the exhaust of the stationary internal combustion engine	(4) Method 7E of 40 CFR part 60, appendix A, Method 320 of 40 CFR part 63, appendix A, or ASTM D 6348–03 (incorporated by reference, see §60.17)	(d) NO_X concentration must be at 15 percent O_2, dry basis. Results of this test consist of the average of the three 1-hour or longer runs.
	c. Reduce PM	i. Select the	(1) Method 1	(a) Sampling sites

	emissions by 60 percent or more	sampling port location and the number of traverse points;	or 1A of 40 CFR part 60, appendix A	must be located at the inlet and outlet of the control device.
		ii. Measure O_2 at the inlet and outlet of the control device;	(2) Method 3, 3A, or 3B of 40 CFR part 60, appendix A	(b) Measurements to determine O_2 concentration must be made at the same time as the measurements for PM concentration.
		iii. If necessary, measure moisture content at the inlet and outlet of the control device; and	(3) Method 4 of 40 CFR part 60, appendix A	(c) Measurements to determine and moisture content must be made at the same time as the measurements for PM concentration.
		iv. Measure PM at the inlet and outlet of the control device	(4) Method 5 of 40 CFR part 60, appendix A	(d) PM concentration must be at 15 percent O_2, dry basis. Results of this test consist of the average of the three 1-hour or longer runs.
	d. Limit the concentration of PM in the stationary CI internal combustion engine exhaust	i. Select the sampling port location and the number of traverse points;	(1) Method 1 or 1A of 40 CFR part 60, appendix A	(a) If using a control device, the sampling site must be located at the outlet of the control device.
		ii. Determine the O_2 concentration of the stationary internal combustion engine exhaust at the sampling port location; and	(2) Method 3, 3A, or 3B of 40 CFR part 60, appendix A	(b) Measurements to determine O_2 concentration must be made at the same time as the measurements for PM concentration.
		iii. If necessary, measure	(3) Method 4 of 40 CFR	(c) Measurements to determine

Electronic Code of Federal Regulations
e-CFR™

e-CFR Data is current as of May 12, 2011

Title 40: Protection of Environment

PART 63—NATIONAL EMISSION STANDARDS FOR HAZARDOUS AIR POLLUTANTS FOR SOURCE CATEGORIES (CONTINUED)

Browse Next

Subpart ZZZZ—National Emissions Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines

Source: 69 FR 33506, June 15, 2004, unless otherwise noted.

What This Subpart Covers

§ 63.6580 What is the purpose of subpart ZZZZ?

Subpart ZZZZ establishes national emission limitations and operating limitations for hazardous air pollutants (HAP) emitted from stationary reciprocating internal combustion engines (RICE) located at major and area sources of HAP emissions. This subpart also establishes requirements to demonstrate initial and continuous compliance with the emission limitations and operating limitations.

[73 FR 3603, Jan. 18, 2008]

§ 63.6585 Am I subject to this subpart?

You are subject to this subpart if you own or operate a stationary RICE at a major or area source of HAP emissions, except if the stationary RICE is being tested at a stationary RICE test cell/stand.

(a) A stationary RICE is any internal combustion engine which uses reciprocating motion to convert heat energy into mechanical work and which is not mobile. Stationary RICE differ from mobile RICE in that a stationary RICE is not a non-road engine as defined at 40 CFR 1068.30, and is not used to propel a motor vehicle or a vehicle used solely for competition.

(b) A major source of HAP emissions is a plant site that emits or has the potential to emit any single HAP at a rate of 10 tons (9.07 megagrams) or more per year or any combination of HAP at a rate of 25 tons (22.68 megagrams) or more per year, except that for oil and gas production facilities, a major source of HAP emissions is determined for each surface site.

(c) An area source of HAP emissions is a source that is not a major source.

(d) If you are an owner or operator of an area source subject to this subpart, your status as an entity subject to a standard or other requirements under this subpart does not subject you to the obligation to obtain a permit under 40 CFR part 70 or 71, provided you are not required to obtain a permit under 40 CFR 70.3(a) or 40 CFR 71.3(a) for a reason other than your status as an area source under this subpart. Notwithstanding the previous sentence, you must continue to comply with the provisions of this subpart as applicable.

(e) If you are an owner or operator of a stationary RICE used for national security purposes, you may be eligible to request an exemption from the requirements of this subpart as described in 40 CFR part 1068,

subpart C.

[69 FR 33506, June 15, 2004, as amended at 73 FR 3603, Jan. 18, 2008]

§ 63.6590 What parts of my plant does this subpart cover?

This subpart applies to each affected source.

(a) *Affected source.* An affected source is any existing, new, or reconstructed stationary RICE located at a major or area source of HAP emissions, excluding stationary RICE being tested at a stationary RICE test cell/stand.

(1) *Existing stationary RICE.*

(i) For stationary RICE with a site rating of more than 500 brake horsepower (HP) located at a major source of HAP emissions, a stationary RICE is existing if you commenced construction or reconstruction of the stationary RICE before December 19, 2002.

(ii) For stationary RICE with a site rating of less than or equal to 500 brake HP located at a major source of HAP emissions, a stationary RICE is existing if you commenced construction or reconstruction of the stationary RICE before June 12, 2006.

(iii) For stationary RICE located at an area source of HAP emissions, a stationary RICE is existing if you commenced construction or reconstruction of the stationary RICE before June 12, 2006.

(iv) A change in ownership of an existing stationary RICE does not make that stationary RICE a new or reconstructed stationary RICE.

(2) *New stationary RICE.* (i) A stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions is new if you commenced construction of the stationary RICE on or after December 19, 2002.

(ii) A stationary RICE with a site rating of equal to or less than 500 brake HP located at a major source of HAP emissions is new if you commenced construction of the stationary RICE on or after June 12, 2006.

(iii) A stationary RICE located at an area source of HAP emissions is new if you commenced construction of the stationary RICE on or after June 12, 2006.

(3) *Reconstructed stationary RICE.* (i) A stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions is reconstructed if you meet the definition of reconstruction in §63.2 and reconstruction is commenced on or after December 19, 2002.

(ii) A stationary RICE with a site rating of equal to or less than 500 brake HP located at a major source of HAP emissions is reconstructed if you meet the definition of reconstruction in §63.2 and reconstruction is commenced on or after June 12, 2006.

(iii) A stationary RICE located at an area source of HAP emissions is reconstructed if you meet the definition of reconstruction in §63.2 and reconstruction is commenced on or after June 12, 2006.

(b) *Stationary RICE subject to limited requirements.* (1) An affected source which meets either of the criteria in paragraphs (b)(1)(i) through (ii) of this section does not have to meet the requirements of this subpart and of subpart A of this part except for the initial notification requirements of §63.6645(f).

(i) The stationary RICE is a new or reconstructed emergency stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions.

(ii) The stationary RICE is a new or reconstructed limited use stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions.

(2) A new or reconstructed stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions which combusts landfill or digester gas equivalent to 10 percent or more of the gross heat input on an annual basis must meet the initial notification requirements of §63.6645(f)

and the requirements of §§63.6625(c), 63.6650(g), and 63.6655(c). These stationary RICE do not have to meet the emission limitations and operating limitations of this subpart.

(3) The following stationary RICE do not have to meet the requirements of this subpart and of subpart A of this part, including initial notification requirements:

(i) Existing spark ignition 2 stroke leanburn (2SLB) stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions;

(ii) Existing spark ignition 4 stroke leanburn (4SLB) stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions;

(iii) Existing emergency stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions;

(iv) Existing limited use stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions;

(v) Existing stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions that combusts landfill gas or digester gas equivalent to 10 percent or more of the gross heat input on an annual basis;

(vi) Existing residential emergency stationary RICE located at an area source of HAP emissions;

(vii) Existing commercial emergency stationary RICE located at an area source of HAP emissions; or

(viii) Existing institutional emergency stationary RICE located at an area source of HAP emissions.

(c) *Stationary RICE subject to Regulations under 40 CFR Part 60.* An affected source that meets any of the criteria in paragraphs (c)(1) through (7) of this section must meet the requirements of this part by meeting the requirements of 40 CFR part 60 subpart IIII, for compression ignition engines or 40 CFR part 60 subpart JJJJ, for spark ignition engines. No further requirements apply for such engines under this part.

(1) A new or reconstructed stationary RICE located at an area source;

(2) A new or reconstructed 2SLB stationary RICE with a site rating of less than or equal to 500 brake HP located at a major source of HAP emissions;

(3) A new or reconstructed 4SLB stationary RICE with a site rating of less than 250 brake HP located at a major source of HAP emissions;

(4) A new or reconstructed spark ignition 4 stroke rich burn (4SRB) stationary RICE with a site rating of less than or equal to 500 brake HP located at a major source of HAP emissions;

(5) A new or reconstructed stationary RICE with a site rating of less than or equal to 500 brake HP located at a major source of HAP emissions which combusts landfill or digester gas equivalent to 10 percent or more of the gross heat input on an annual basis;

(6) A new or reconstructed emergency or limited use stationary RICE with a site rating of less than or equal to 500 brake HP located at a major source of HAP emissions;

(7) A new or reconstructed compression ignition (CI) stationary RICE with a site rating of less than or equal to 500 brake HP located at a major source of HAP emissions.

[69 FR 33506, June 15, 2004, as amended at 73 FR 3604, Jan. 18, 2008; 75 FR 9674, Mar. 3, 2010; 75 FR 37733, June 30, 2010; 75 FR 51588, Aug. 20, 2010]

§ 63.6595 When do I have to comply with this subpart?

(a) *Affected sources.* (1) If you have an existing stationary RICE, excluding existing non-emergency CI

stationary RICE, with a site rating of more than 500 brake HP located at a major source of HAP emissions, you must comply with the applicable emission limitations and operating limitations no later than June 15, 2007. If you have an existing non-emergency CI stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions, an existing stationary CI RICE with a site rating of less than or equal to 500 brake HP located at a major source of HAP emissions, or an existing stationary CI RICE located at an area source of HAP emissions, you must comply with the applicable emission limitations and operating limitations no later than May 3, 2013. If you have an existing stationary SI RICE with a site rating of less than or equal to 500 brake HP locatedat a major source of HAP emissions, or an existing stationary SI RICE located at an area source ofHAP emissions, you must comply with the applicable emission limitations and operating limitations no later than October 19, 2013.

(2) If you start up your new or reconstructed stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions before August 16, 2004, you must comply with the applicable emission limitations and operating limitations in this subpart no later than August 16, 2004.

(3) If you start up your new or reconstructed stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions after August 16, 2004, you must comply with the applicable emission limitations and operating limitations in this subpart upon startup of your affected source.

(4) If you start up your new or reconstructed stationary RICE with a site rating of less than or equal to 500 brake HP located at a major source of HAP emissions before January 18, 2008, you must comply with the applicable emission limitations and operating limitations in this subpart no later than January 18, 2008.

(5) If you start up your new or reconstructed stationary RICE with a site rating of less than or equal to 500 brake HP located at a major source of HAP emissions after January 18, 2008, you must comply with the applicable emission limitations and operating limitations in this subpart upon startup of your affected source.

(6) If you start up your new or reconstructed stationary RICE located at an area source ofHAP emissions before January 18, 2008, you must comply with the applicable emission limitations and operating limitations in this subpart no later than January 18, 2008.

(7) If you start up your new or reconstructed stationary RICE located at an area source ofHAP emissions after January 18, 2008, you must comply with the applicable emission limitations and operating limitations in this subpart upon startup of your affected source.

(b) *Area sources that become major sources.* If you have an area source that increases its emissions or its potential to emit such that it becomes a major source of HAP, the compliance dates in paragraphs (b) (1) and (2) of this section apply to you.

(1) Any stationary RICE for which construction or reconstruction is commenced after the date when your area source becomes a major source of HAP must be in compliance with this subpart upon startup of your affected source.

(2) Any stationary RICE for which construction or reconstruction is commenced before your area source becomes a major source of HAP must be in compliance with the provisions of this subpart that are applicable to RICE located at major sources within 3 years after your area source becomes a major source of HAP.

(c) If you own or operate an affected source, you must meet the applicable notification requirements in §63.6645 and in 40 CFR part 63, subpart A.

[69 FR 33506, June 15, 2004, as amended at 73 FR 3604, Jan. 18, 2008; 75 FR 9675, Mar. 3, 2010; 75 FR 51589, Aug. 20, 2010]

Emission and Operating Limitations

§ 63.6600 What emission limitations and operating limitations must I meet if I own or operate a stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions?

Compliance with the numerical emission limitations established in this subpart is based on theresults of testing the average of three 1-hour runs using the testing requirements and procedures in §63.6620 and Table 4 to this subpart.

(a) If you own or operate an existing, new, or reconstructed spark ignition 4SRB stationaryRICE with a site rating of more than 500 brake HP located at a major source of HAP emissions, you must comply with the emission limitations in Table 1a to this subpart and the operating limitations in Table 1b to this subpart which apply to you.

(b) If you own or operate a new or reconstructed 2SLB stationaryRICE with a site rating of more than 500 brake HP located at major source of HAP emissions, a new or reconstructed 4SLB stationary RICE with a site rating of more than 500 brake HP located at major source of HAP emissions, or a new or reconstructed CI stationaryRICE with a site rating of more than 500 brake HP located at a major source of HAP emissions, you must comply with the emission limitations in Table 2a to this subpart and the operating limitations in Table 2b to this subpart which apply to you.

(c) If you own or operate any of the following stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions, you do not need to comply with the emission limitations in Tables 1a, 2a, 2c, and2d to this subpart or operating limitations in Tables 1b and 2b to this subpart: an existing 2SLB stationary RICE; an existing 4SLB stationary RICE; a stationary RICE that combusts landfill gas or digester gas equivalent to 10 percent or more of the gross heat input on an annual basis; an emergency stationary RICE; or a limited use stationary RICE.

(d) If you own or operate an existing non-emergency stationary CI RICE with a site rating of more than 500 brake HP located at amajor source of HAP emissions, you must comply with the emission limitations in Table 2c to this subpart and the operating limitations in Table 2b to this subpart which apply to you.

[73 FR 3605, Jan. 18, 2008, as amended at 75 FR 9675, Mar. 3, 2010]

§ 63.6601 What emission limitations must I meet if I own or operate a new or reconstructed 4SLB stationary RICE with a site rating of greater than or equal to 250 brake HP and less than or equal to 500 brake HP located at a major source of HAP emissions?

Compliance with the numerical emission limitations established in this subpart is based on theresults of testing the average of three 1-hour runs using the testing requirements and procedures in §63.6620 and Table 4 to this subpart. Ifyou own or operate a new or reconstructed 4SLB stationary RICE with a site rating of greater than or equal to 250 and less than or equal to 500brake HP located at major source of HAP emissions manufactured on or after January 1, 2008, you must comply with the emission limitations in Table 2a to this subpart and the operating limitations in Table 2b to this subpart which apply to you.

[73 FR 3605, Jan. 18, 2008, as amended at 75 FR 9675, Mar. 3, 2010; 75 FR 51589, Aug. 20, 2010]

§ 63.6602 What emission limitations must I meet if I own or operate an existing stationary RICE with a site rating of equal to or less than 500 brake HP located at a major source of HAP emissions?

If you own or operate an existing stationary RICE with a site rating of equal to or less than 500 brake HP located at a major source of HAP emissions, you must comply with the emission limitations in Table 2c to this subpart which apply to you. Compliance with the numerical emission limitations established in this subpart is based on theresults of testing the average of three 1-hour runs using the testing requirements and procedures in §636620 and Table 4 to this subpart.

[75 FR 51589, Aug. 20, 2010]

§ 63.6603 What emission limitations and operating limitations must I meet if I own or operate an existing stationary RICE located at an area source of HAP emissions?

Compliance with the numerical emission limitations established in this subpart is based on theresults of testing the average of three 1-hour runs using the testing requirements and procedures in §63.6620 and Table 4 to this subpart.

(a) If you own or operate an existing stationary RICE located at an area source ofHAP emissions, you must comply with the requirements in Table 2d to this subpart and the operating limitations in Table 1b and Table 2b to this subpart that apply to you.

(b) If you own or operate an existing stationary non-emergency CI RICE greater than 300 HPlocated at area sources in areas ofAlaska not accessible by the Federal Aid Highway System (FAHS) you do not have to meet the numerical CO emission limitations specified in Table 2d to this subpart. Existing stationary non-emergency CI RICE greater than 300 HP located at area sources in areas of Alaska not accessible by the FAHS must meet the management practices that are shown for stationary non-emergency CI RICE less than or equal to 300 HP in Table 2d to this subpart.

[75 FR 9675, Mar. 3, 2010, as amended at 75 FR 51589, Aug. 20, 2010; 76 FR 12866, Mar. 9, 2011]

§ 63.6604 What fuel requirements must I meet if I own or operate an existing stationary CI RICE?

If you own or operate an existing non-emergency, non-black start CI stationary RICE with a site rating of more than 300 brake HP with a displacement of less than 30 liters per cylinder that uses diesel fuel, you must use diesel fuel that meets the requirements in 40 CFR 80.510(b) for nonroad diesel fuel. Existing non-emergency CI stationary RICE located in Guam, American Samoa, the Commonwealth of the Northern Mariana Islands, or at area sources in areas ofAlaska not accessible bythe FAHS are exempt from the requirements of this section.

[75 FR 51589, Aug. 20, 2010]

General Compliance Requirements

§ 63.6605 What are my general requirements for complying with this subpart?

(a) You must be in compliance with the emission limitations and operating limitations in this subpart that apply to you at all times.

(b) At all times you must operate and maintain any affected source, including associatedair pollution control equipment and monitoring equipment, in a manner consistent with safety and good air pollution control practices for minimizing emissions. The general duty to minimize emissions does not require you to make any further efforts to reduce emissions if levels required by this standard have been achieved. Determination of whether such operation and maintenance procedures are being used will be based on information available to the Administrator which may include, but is not limited to, monitoring results, review of operation and maintenance procedures, review of operation and maintenance records, and inspection of the source.

[75 FR 9675, Mar. 3, 2010]

Testing and Initial Compliance Requirements

§ 63.6610 By what date must I conduct the initial performance tests or other initial compliance demonstrations if I own or operate a stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions?

If you own or operate a stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions you are subject to the requirements of this section.

(a) You must conduct the initial performance test or other initial compliance demonstrations in Table 4 to this subpart that apply to you within 180 days after the compliance date that is specified for your stationary RICE in §63.6595 and according to the provisions in §63.7(a)(2).

(b) If you commenced construction or reconstruction between December 19, 2002 and June 15, 2004 and own or operate stationary RICE with a site rating of more than 500 brake HP locatedat a major source of HAP emissions, you must demonstrate initial compliance with either the proposed emission limitations or the promulgated emission limitations no later than February10, 2005 or no later than 180 days after startup of the source, whichever is later, according to §63.7(a)(2)(ix).

(c) If you commenced construction or reconstruction between December 19, 2002 and June 15, 2004 and own or operate stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions, and you chose to comply with the proposed emission limitations when demonstrating initial compliance, you must conduct a second performance test to demonstrate compliance with the promulgated emission limitations by December 13, 2007 or after startup of the source, whichever is later, according to §63.7(a)(2)(ix).

(d) An owner or operator is not required to conduct an initial performance test on units for which a performance test has been previously conducted, but the test must meet all of the conditions described in paragraphs (d)(1) through (5) of this section.

(1) The test must have been conducted using the same methods specified in this subpart, and these methods must have been followed correctly.

(2) The test must not be older than 2 years.

(3) The test must be reviewed and accepted by the Administrator.

(4) Either no process or equipment changes must have been made since the test was performed, or the owner or operator must be able to demonstrate that the results of the performance test, with or without adjustments, reliably demonstrate compliance despite process or equipment changes.

(5) The test must be conducted at any load condition within plus or minus 10 percent of 100 percent load.

[69 FR 33506, June 15, 2004, as amended at 73 FR 3605, Jan. 18, 2008]

§ 63.6611 By what date must I conduct the initial performance tests or other initial compliance demonstrations if I own or operate a new or reconstructed 4SLB SI stationary RICE with a site rating of greater than or equal to 250 and less than or equal to 500 brake HP located at a major source of HAP emissions?

If you own or operate a new or reconstructed 4SLB stationary RICE with a site rating of greater than or equal to 250 and less than or equal to 500 brake HP located at a major source of HAP emissions, you must conduct an initial performance test within 240 days after the compliance date that is specified for your stationary RICE in §63.6595 and according to the provisions specified in Table 4 to this subpart, as appropriate.

[73 FR 3605, Jan. 18, 2008, as amended at 75 FR 51589, Aug. 20, 2010]

§ 63.6612 By what date must I conduct the initial performance tests or other initial compliance demonstrations if I own or operate an existing stationary RICE with a site rating of less than or equal to 500 brake HP located at a major source of HAP emissions or an existing stationary RICE located at an area source of HAP emissions?

If you own or operate an existing stationary RICE with a site rating of less than or equal to 500 brake HP located at a major source of HAP emissions or an existing stationary RICE located at an area source of HAP emissions you are subject to the requirements of this section.

(a) You must conduct any initial performance test or other initial compliance demonstration according to Tables 4 and 5 to this subpart that apply to you within 180 days after the compliance date that is specified for your stationary RICE in §63.6595 and according to the provisions in §63.7(a)(2).

(b) An owner or operator is not required to conduct an initial performance test on a unit for which a performance test has been previously conducted, but the test must meet all of the conditions described in paragraphs (b)(1) through (4) of this section.

(1) The test must have been conducted using the same methods specified in this subpart, and these methods must have been followed correctly.

(2) The test must not be older than 2 years.

(3) The test must be reviewed and accepted by the Administrator.

(4) Either no process or equipment changes must have been made since the test was performed, or the owner or operator must be able to demonstrate that the results of the performance test, with or without adjustments, reliably demonstrate compliance despite process or equipment changes.

[75 FR 9676, Mar. 3, 2010, as amended at 75 FR 51589, Aug. 20, 2010]

§ 63.6615 When must I conduct subsequent performance tests?

If you must comply with the emission limitations and operating limitations, you must conduct subsequent performance tests as specified in Table 3 of this subpart.

§ 63.6620 What performance tests and other procedures must I use?

(a) You must conduct each performance test in Tables 3 and 4 of this subpart that applies to you.

(b) Each performance test must be conducted according to the requirements that this subpart specifies in Table 4 to this subpart. If you own or operate a non-operational stationary RICE that is subject to performance testing, you do not need to start up the engine solely to conduct the performance test. Owners and operators of a non-operational engine can conduct the performance test when the engine is started up again.

(c) [Reserved]

(d) You must conduct three separate test runs for each performance test required in this section, as specified in §63.7(e)(3). Each test run must last at least 1 hour.

(e)(1) You must use Equation 1 of this section to determine compliance with the percent reduction requirement:

$$\frac{C_i - C_o}{C_i} \times 100 = R \qquad \text{(Eq. 1)}$$

Where:

C_i = concentration of CO or formaldehyde at the control device inlet,

C_o = concentration of CO or formaldehyde at the control device outlet, and

R = percent reduction of CO or formaldehyde emissions.

(2) You must normalize the carbon monoxide (CO) or formaldehyde concentrations at the inlet and outlet of the control device to a dry basis and to 15 percent oxygen, or an equivalent percent carbon dioxide (CO_2). If pollutant concentrations are to be corrected to 15 percent oxygen and CO_2 concentration is measured in lieu of oxygen concentration measurement, a CO_2 correction factor is needed. Calculate the CO_2 correction factor as described in paragraphs (e)(2)(i) through (iii) of this section.

(i) Calculate the fuel-specific F_o value for the fuel burned during the test using values obtained from Method 19, section 5.2, and the following equation:

$$F_o = \frac{0.209\, F_d}{F_c} \qquad \text{(Eq. 2)}$$

Where:

F_o= Fuel factor based on the ratio of oxygen volume to the ultimate CO_2volume produced by the fuel at zero percent excess air.

0.209 = Fraction of air that is oxygen, percent/100.

F_d= Ratio of the volume of dry effluent gas to the gross calorific value of the fuel from Method 19, dsm^3 /J (dscf/10^6 Btu).

F_c= Ratio of the volume of CO_2produced to the gross calorific value of the fuel from Method 19, dsm^3 /J (dscf/10^6 Btu).

(ii) Calculate the CO_2correction factor for correcting measurement data to 15 percent oxygen, as follows:

$$X_{co_2} = \frac{5.9}{F_o} \qquad \text{(Eq. 3)}$$

Where:

X_{co2}= CO_2correction factor, percent.

5.9 = 20.9 percent O_2−15 percent O_2, the defined O_2correction value, percent.

(iii) Calculate the $NO_X$and SO_2gas concentrations adjusted to 15 percent O_2using CO_2as follows:

$$C_{adj} = C_d \frac{X_{co_2}}{\%CO_2} \qquad \text{(Eq. 4)}$$

Where:

$\%CO_2$= Measured CO_2concentration measured, dry basis, percent.

(f) If you comply with the emission limitation to reduce CO and you are not using an oxidation catalyst, if you comply with the emission limitation to reduce formaldehyde and you are not using NSCR, or if you comply with the emission limitation to limit the concentration of formaldehyde in the stationary RICE exhaust and you are not using an oxidation catalyst or NSCR, you must petition the Administrator for operating limitations to be established during the initial performance test and continuously monitored thereafter; or for approval of no operating limitations. You must not conduct the initial performance test until after the petition has been approved by the Administrator.

(g) If you petition the Administrator for approval of operating limitations, your petition must include the information described in paragraphs (g)(1) through (5) of this section.

(1) Identification of the specific parameters you propose to use as operating limitations;

(2) A discussion of the relationship between these parameters and HAP emissions, identifying how HAP emissions change with changes in these parameters, and how limitations on these parameters will serve to limit HAP emissions;

(3) A discussion of how you will establish the upper and/or lower values for these parameters which will establish the limits on these parameters in the operating limitations;

(4) A discussion identifying the methods you will use to measure and the instruments you will use to monitor these parameters, as well as the relative accuracy and precision of these methods and instruments; and

(5) A discussion identifying the frequency and methods for recalibrating the instruments you will use for monitoring these parameters.

(h) If you petition the Administrator for approval of no operating limitations, your petition must include the information described in paragraphs (h)(1) through (7) ofthis section.

(1) Identification of the parameters associated with operation of the stationary RICE and any emission control device which could change intentionally (*e.g.,* operator adjustment, automatic controller adjustment, etc.) or unintentionally (*e.g.,* wear and tear, error, etc.) on a routine basis or over time;

(2) A discussion ofthe relationship, if any, between changes in the parameters and changes in HAP emissions;

(3) For the parameters which could change in such a way as to increase HAP emissions, a discussion of whether establishing limitations on the parameters would serve to limit HAP emissions;

(4) For the parameters which could change in such a way as to increase HAP emissions, a discussion of how you could establish upper and/or lower values for the parameters which would establish limits on the parameters in operating limitations;

(5) For the parameters, a discussion identifying the methods you could use to measure them and the instruments you could use to monitor them, as well as the relative accuracy and precision ofthe methods and instruments;

(6) For the parameters, a discussion identifying the frequency and methods for recalibrating the instruments you could use to monitor them; and

(7) A discussion ofwhy, from your point of view, it is infeasible or unreasonable to adopt theparameters as operating limitations.

(i) The engine percent load during a performance test must be determined by documenting the calculations, assumptions, and measurement devices used to measure or estimate the percent load in a specific application. A written report of the average percent load determination must be included in the notification of compliance status. The following information must be included in the written report: the engine model number, the engine manufacturer, the year of purchase, the manufacturer's site-rated brake horsepower, the ambient temperature, pressure, and humidity during the performance test, and all assumptions that were made to estimate or calculate percent load during the performance test must be clearly explained. If measurement devices such as flow meters, kilowatt meters, beta analyzers, stain gauges, etc. are used, the model number of the measurement device, and an estimate of its accurate in percentage oftrue value must be provided.

[69 FR 33506, June 15, 2004, as amended at 75 FR 9676, Mar. 3, 2010]

§ 63.6625 What are my monitoring, installation, collection, operation, and maintenance requirements?

(a) If you elect to install a CEMS as specified in Table 5 of this subpart, you must install, operate, and maintain a CEMS to monitor CO and either oxygen or CO_2 at both the inlet and the outlet of the control device according to the requirements in paragraphs (a)(1) through (4) ofthis section.

(1) Each CEMS must be installed, operated, and maintained according to the applicable performance specifications of 40 CFR part 60, appendix B.

(2) You must conduct an initial performance evaluation and an annual relative accuracy test audit (RATA) of each CEMS according to the requirements in §63.8 and according to the applicable performance specifications of 40 CFR part 60, appendix B as well as daily and periodic data quality checks in accordance with 40 CFR part 60, appendix F, procedure 1.

(3) As specified in §63.8(c)(4)(ii), each CEMS must complete a minimum of one cycle of operation (sampling, analyzing, and data recording) for each successive 15-minute period. You must have at least two data points, with each representing a different 15-minute period, to have a valid hour of data.

(4) The CEMS data must be reduced as specified in §63.8(g)(2) and recorded in parts per million or parts per billion (as appropriate for the applicable limitation) at 15 percent oxygen or the equivalent CO_2 concentration.

(b) If you are required to install a continuous parameter monitoring system (CPMS) as specified in Table 5 of this subpart, you must install, operate, and maintain each CPMS according to the requirements in paragraphs (b)(1) through (5) of this section. For an affected source that is complying with the emission limitations and operating limitations on March 9, 2011, the requirements in paragraph (b) of this section are applicable September 6, 2011.

(1) You must prepare a site-specific monitoring plan that addresses the monitoring system design, data collection, and the quality assurance and quality control elements outlined in paragraphs (b)(1)(i) through (v) of this section and in §63.8(d). As specified in §63.8(f)(4), you may request approval of monitoring system quality assurance and quality control procedures alternative to those specified in paragraphs (b)(1) through (5) of this section in your site-specific monitoring plan.

(i) The performance criteria and design specifications for the monitoring system equipment, including the sample interface, detector signal analyzer, and data acquisition and calculations;

(ii) Sampling interface (*e.g.,* thermocouple) location such that the monitoring system will provide representative measurements;

(iii) Equipment performance evaluations, system accuracy audits, or other audit procedures;

(iv) Ongoing operation and maintenance procedures in accordance with provisions in §63.8(c)(1) and (c)(3); and

(v) Ongoing reporting and recordkeeping procedures in accordance with provisions in §63.10(c), (e)(1), and (e)(2)(i).

(2) You must install, operate, and maintain each CPMS in continuous operation according to the procedures in your site-specific monitoring plan.

(3) The CPMS must collect data at least once every 15 minutes (see also §63.6635).

(4) For a CPMS for measuring temperature range, the temperature sensor must have a minimum tolerance of 2.8 degrees Celsius (5 degrees Fahrenheit) or 1 percent of the measurement range, whichever is larger.

(5) You must conduct the CPMS equipment performance evaluation, system accuracy audits, or other audit procedures specifed in your site-specific monitoring plan at least annually.

(6) You must conduct a performance evaluation of each CPMS in accordance with your site-specific monitoring plan.

(c) If you are operating a new or reconstructed stationary RICE which fires landfill gas or digester gas equivalent to 10 percent or more of the gross heat input on an annual basis, you must monitor and record your fuel usage daily with separate fuel meters to measure the volumetric flow rate of each fuel. In addition, you must operate your stationary RICE in a manner which reasonably minimizes HAP emissions.

(d) If you are operating a new or reconstructed emergency 4SLB stationary RICE with a site rating of greater than or equal to 250 and less than or equal to 500 brake HP located at a major source of HAP emissions, you must install a non-resettable hour meter prior to the startup of the engine.

(e) If you own or operate any of the following stationary RICE, you must operate and maintain the stationary RICE and after-treatment control device (if any) according to the manufacturer's emission-related written instructions or develop your own maintenance plan which must provide to the extent practicable for the maintenance and operation of the engine in a manner consistent with good air pollution control practice for minimizing emissions:

(1) An existing stationary RICE with a site rating of less than 100 HP located at a major source of HAP emissions;

(2) An existing emergency or black start stationary RICE with a site rating of less than or equal to 500 HP located at a major source of HAP emissions;

(3) An existing emergency or black start stationary RICE located at an area source of HAP emissions;

(4) An existing non-emergency, non-black start stationary CI RICE with a site rating less than or equal to 300 HP located at an area source of HAP emissions;

(5) An existing non-emergency, non-black start 2SLB stationary RICE located at an area source of HAP emissions;

(6) An existing non-emergency, non-black start landfill or digester gas stationary RICE located at an area source of HAP emissions;

(7) An existing non-emergency, non-black start 4SLB stationary RICE with a site rating less than or equal to 500 HP located at an area source of HAP emissions;

(8) An existing non-emergency, non-black start 4SRB stationary RICE with a site rating less than or equal to 500 HP located at an area source of HAP emissions;

(9) An existing, non-emergency, non-black start 4SLB stationary RICE with a site rating greater than 500 HP located at an area source of HAP emissions that is operated 24 hours or less per calendar year; and

(10) An existing, non-emergency, non-black start 4SRB stationary RICE with a site rating greater than 500 HP located at an area source of HAP emissions that is operated 24 hours or less per calendar year.

(f) If you own or operate an existing emergency stationary RICE with a site rating of less than or equal to 500 brake HP located at a major source of HAP emissions or an existing emergency stationary RICE located at an area source of HAP emissions, you must install a non-resettable hour meter if one is not already installed.

(g) If you own or operate an existing non-emergency, non-black start CI engine greater than or equal to 300 HP that is not equipped with a closed crankcase ventilation system, you must comply with either paragraph (g)(1) or paragraph (g)(2) of this section. Owners and operators must follow the manufacturer's specified maintenance requirements for operating and maintaining the open or closed crankcase ventilation systems and replacing the crankcase filters, or can request the Administrator to approve different maintenance requirements that are as protective as manufacturer requirements. Existing CI engines located at area sources in areas of Alaska not accessible by the FAHS do not have to meet the requirements of paragraph (g) of this section.

(1) Install a closed crankcase ventilation system that prevents crankcase emissions from being emitted to the atmosphere, or

(2) Install an open crankcase filtration emission control system that reduces emissions from the crankcase by filtering the exhaust stream to remove oil mist, particulates, and metals.

(h) If you operate a new, reconstructed, or existing stationary engine, you must minimize the engine's time spent at idle during startup and minimize the engine's startup time to a period needed for appropriate and safe loading of the engine, not to exceed 30 minutes, after which time the emission standards applicable to all times other than startup in Tables 1a, 2a, 2c, and 2d to this subpart apply.

(i) If you own or operate a stationary CI engine that is subject to the work, operation or management practices in items 1 or 2 of Table 2c to this subpart or in items 1 or 4 of Table 2d to this subpart, you have the option of utilizing an oil analysis program in order to extend the specified oil change requirement in Tables 2c and 2d to this subpart. The oil analysis must be performed at the same frequency specified for changing the oil in Table 2c or 2d to this subpart. The analysis program must at a minimum analyze the following three parameters: Total Base Number, viscosity, and percent water content. The condemning limits for these parameters are as follows: Total Base Number is less than 30 percent of the Total Base Number of the oil when new; viscosity of the oil has changed by more than 20 percent from the viscosity of the oil when new; or percent water content (by volume) is greater than 0.5. If all of these condemning limits are not exceeded, the engine owner or operator is not required to change the oil. If any of the limits are exceeded, the engine owner or operator must change the oil within 2 days of receiving the results of the analysis; if the engine is not in operation when the results of the analysis are received, the engine owner or operator must change the oil within 2 days or before

commencing operation, whichever is later. The owner or operator must keep records of the parameters that are analyzed as part of the program, the results of the analysis, and the oil changes for the engine. The analysis program must be part of the maintenance plan for the engine.

(j) If you own or operate a stationary SI engine that is subject to the work, operation or management practices in items 6, 7, or 8 of Table 2c to this subpart or in items 5, 6, 7, 9, or 11 of Table 2d to this subpart, you have the option of utilizing an oil analysis program in order to extend the specified oil change requirement in Tables 2c and 2d to this subpart. The oil analysis must be performed at the same frequency specified for changing the oil in Table 2c or 2d to this subpart. The analysis program must at a minimum analyze the following three parameters: Total Acid Number, viscosity, and percent water content. The condemning limits for these parameters are as follows: Total Acid Number increases by more than 3.0 milligrams of potassium hydroxide (KOH) per gram from Total Acid Number of the oil when new; viscosity of the oil has changed by more than 20 percent from the viscosity of the oil when new; or percent water content (by volume) is greater than 0.5. If all of these condemning limits are not exceeded, the engine owner or operator is not required to change the oil. If any of the limits are exceeded, the engine owner or operator must change the oil within 2 days of receiving the results of the analysis; if the engine is not in operation when the results of the analysis are received, the engine owner or operator must change the oil within 2 days or before commencing operation, whichever is later. The owner or operator must keep records of the parameters that are analyzed as part of the program, the results of the analysis, and the oil changes for the engine. The analysis program must be part of the maintenance plan for the engine.

[69 FR 33506, June 15, 2004, as amended at 73 FR 3606, Jan. 18, 2008; 75 FR 9676, Mar. 3, 2010; 75 FR 51589, Aug. 20, 2010; 76 FR 12866, Mar. 9, 2011]

§ 63.6630 How do I demonstrate initial compliance with the emission limitations and operating limitations?

(a) You must demonstrate initial compliance with each emission and operating limitation that applies to you according to Table 5 of this subpart.

(b) During the initial performance test, you must establish each operating limitation in Tables 1b and 2b of this subpart that applies to you.

(c) You must submit the Notification of Compliance Status containing the results of the initial compliance demonstration according to the requirements in §63.6645.

Continuous Compliance Requirements

§ 63.6635 How do I monitor and collect data to demonstrate continuous compliance?

(a) If you must comply with emission and operating limitations, you must monitor and collect data according to this section.

(b) Except for monitor malfunctions, associated repairs, required performance evaluations, and required quality assurance or control activities, you must monitor continuously at all times that the stationary RICE is operating. A monitoring malfunction is any sudden, infrequent, not reasonably preventable failure of the monitoring to provide valid data. Monitoring failures that are caused in part by poor maintenance or careless operation are not malfunctions.

(c) You may not use data recorded during monitoring malfunctions, associated repairs, and required quality assurance or control activities in data averages and calculations used to report emission or operating levels. You must, however, use all the valid data collected during all other periods.

[69 FR 33506, June 15, 2004, as amended at 76 FR 12867, Mar. 9, 2011]

§ 63.6640 How do I demonstrate continuous compliance with the emission limitations and operating limitations?

(a) You must demonstrate continuous compliance with each emission limitation and operating limitation in Tables 1a and 1b, Tables 2a and 2b, Table 2c, and Table 2d to this subpart that apply to you according to methods specified in Table 6 to this subpart.

(b) You must report each instance in which you did not meet each emission limitation or operating limitation in Tables 1a and 1b, Tables 2a and 2b, Table 2c, and Table 2d to this subpart that apply to you. These instances are deviations from the emission and operating limitations in this subpart. These deviations must be reported according to the requirements in §63.6650. If you change your catalyst, you must reestablish the values of the operating parameters measured during the initial performance test. When you reestablish the values of your operating parameters, you must also conduct a performance test to demonstrate that you are meeting the required emission limitation applicable to your stationary RICE.

(c) [Reserved]

(d) For new, reconstructed, and rebuilt stationary RICE, deviations from the emission or operating limitations that occur during the first 200 hours of operation from engine startup (engine burn-in period) are not violations. Rebuilt stationary RICE means a stationary RICE that has been rebuilt as that term is defined in 40 CFR 94.11(a).

(e) You must also report each instance in which you did not meet the requirements in Table 8 to this subpart that apply to you. If you own or operate a new or reconstructed stationary RICE with a site rating of less than or equal to 500 brake HP located at a major source of HAP emissions (except new or reconstructed 4SLB engines greater than or equal to 250 and less than or equal to 500 brake HP), a new or reconstructed stationary RICE located at an area source of HAP emissions, or any of the following RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions, you do not need to comply with the requirements in Table 8 to this subpart: An existing 2SLB stationary RICE, an existing 4SLB stationary RICE, an existing emergency stationary RICE, an existing limited use stationary RICE, or an existing stationary RICE which fires landfill gas or digester gas equivalent to 10 percent or more of the gross heat input on an annual basis. If you own or operate any of the following RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions, you do not need to comply with the requirements in Table 8 to this subpart, except for the initial notification requirements: a new or reconstructed stationary RICE that combusts landfill gas or digester gas equivalent to 10 percent or more of the gross heat input on an annual basis, a new or reconstructed emergency stationary RICE, or a new or reconstructed limited use stationary RICE.

(f) *Requirements for emergency stationary RICE.* (1) If you own or operate an existing emergency stationary RICE with a site rating of less than or equal to 500 brake HP located at a major source of HAP emissions, a new or reconstructed emergency stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions that was installed on or after June 12, 2006, or an existing emergency stationary RICE located at an area source of HAP emissions, you must operate the emergency stationary RICE according to the requirements in paragraphs (f)(1)(i) through (iii) of this section. Any operation other than emergency operation, maintenance and testing, and operation in non-emergency situations for 50 hours per year, as described in paragraphs (f)(1)(i) through (iii) of this section, is prohibited. If you do not operate the engine according to the requirements in paragraphs (f)(1)(i) through (iii) of this section, the engine will not be considered an emergency engine under this subpart and will need to meet all requirements for non-emergency engines.

(i) There is no time limit on the use of emergency stationary RICE in emergency situations.

(ii) You may operate your emergency stationary RICE for the purpose of maintenance checks and readiness testing, provided that the tests are recommended by Federal, State or local government, the manufacturer, the vendor, or the insurance company associated with the engine. Maintenance checks and readiness testing of such units is limited to 100 hours per year. The owner or operator may petition the Administrator for approval of additional hours to be used for maintenance checks and readiness testing, but a petition is not required if the owner or operator maintains records indicating that Federal, State, or local standards require maintenance and testing of emergency RICE beyond 100 hours per year.

(iii) You may operate your emergency stationary RICE up to 50 hours per year in non-emergency situations, but those 50 hours are counted towards the 100 hours per year provided for maintenance and testing. The 50 hours per year for non-emergency situations cannot be used for peak shaving or to generate income for a facility to supply power to an electric grid or otherwise supply power as part of a financial arrangement with another entity; except that owners and operators may operate the emergency engine for a maximum of 15 hours per year as part of a demand response program if the regional transmission organization or equivalent balancing authority and transmission operator has determined there are emergency conditions that could lead to a potential electrical blackout, such as unusually low frequency, equipment overload, capacity or energy deficiency, or unacceptable voltage level. The engine may not be operated for more than 30 minutes prior to the time when the emergency condition is expected to occur, and the engine operation must be terminated immediately after the facility is notified

that the emergency condition is no longer imminent. The 15 hours per year of demand response operation are counted as part of the 50 hours of operation per year provided for non-emergency situations. The supply of emergency power to another entity or entities pursuant to financial arrangement is not limited by this paragraph (f)(1)(iii), as long as the power provided by the financial arrangement is limited to emergency power.

(2) If you own or operate an emergency stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions that was installed prior to June 12, 2006, you must operate the engine according to the conditions described in paragraphs (f)(2)(i) through (iii) of this section. If you do not operate the engine according to the requirements in paragraphs (f)(2)(i) through (iii) of this section, the engine will not be considered an emergency engine under this subpart and will need to meet all requirements for non-emergency engines.

(i) There is no time limit on the use of emergency stationary RICE in emergency situations.

(ii) You may operate your emergency stationary RICE for the purpose of maintenance checks and readiness testing, provided that the tests are recommended by the manufacturer, the vendor, or the insurance company associated with the engine. Required testing of such units should be minimized, but there is no time limit on the use of emergency stationary RICE in emergency situations and for routine testing and maintenance.

(iii) You may operate your emergency stationary RICE for an additional 50 hours per year in non-emergency situations. The 50 hours per year for non-emergency situations cannot be used for peak shaving or to generate income for a facility to supply power to an electric grid or otherwise supply power as part of a financial arrangement with another entity.

[69 FR 33506, June 15, 2004, as amended at 71 FR 20467, Apr. 20, 2006; 73 FR 3606, Jan. 18, 2008; 75 FR 9676, Mar. 3, 2010; 75 FR 51591, Aug. 20, 2010]

Notifications, Reports, and Records

§ 63.6645 What notifications must I submit and when?

(a) You must submit all of the notifications in §§63.7(b) and (c), 63.8(e), (f)(4) and (f)(6), 63.9(b) through (e), and (g) and (h) that apply to you by the dates specified if you own or operate any of the following;

(1) An existing stationary RICE with a site rating of less than or equal to 500 brake HP located at a major source of HAP emissions.

(2) An existing stationary RICE located at an area source of HAP emissions.

(3) A stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions.

(4) A new or reconstructed 4SLB stationary RICE with a site rating of greater than or equal to 250 HP located at a major source of HAP emissions.

(5) This requirement does not apply if you own or operate an existing stationary RICE less than 100 HP, an existing stationary emergency RICE, or an existing stationary RICE that is not subject to any numerical emission standards.

(b) As specified in §63.9(b)(2), if you start up your stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions before the effective date of this subpart, you must submit an Initial Notification not later than December 13, 2004.

(c) If you start up your new or reconstructed stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions on or after August 16, 2004, you must submit an Initial Notification not later than 120 days after you become subject to this subpart.

(d) As specified in §63.9(b)(2), if you start up your stationary RICE with a site rating of equal to or less than 500 brake HP located at a major source of HAP emissions before the effective date of this subpart and you are required to submit an initial notification, you must submit an Initial Notification not later than July 16, 2008.

(e) If you start up your new or reconstructed stationary RICE with a site rating of equal to or less than 500 brake HP located at a major source of HAP emissions on or after March 18, 2008 and you are required to submit an initial notification, you must submit an Initial Notification not later than 120 days after you become subject to this subpart.

(f) If you are required to submit an Initial Notification but are otherwise not affected by the requirements of this subpart, in accordance with §63.6590(b), your notification should include the information in §63.9 (b)(2)(i) through (v), and a statement that your stationary RICE has no additional requirements and explain the basis of the exclusion (for example, that it operates exclusively as an emergency stationary RICE if it has a site rating of more than 500 brake HP located at a major source of HAP emissions).

(g) If you are required to conduct a performance test, you must submit a Notification of Intent to conduct a performance test at least 60 days before the performance test is scheduled to begin as required in §63.7(b)(1).

(h) If you are required to conduct a performance test or other initial compliance demonstration as specified in Tables 4 and 5 to this subpart, you must submit a Notification of Compliance Status according to §63.9(h)(2)(ii).

(1) For each initial compliance demonstration required in Table 5 to this subpart that does not include a performance test, you must submit the Notification of Compliance Status before the close of business on the 30th day following the completion of the initial compliance demonstration.

(2) For each initial compliance demonstration required in Table 5 to this subpart that includes a performance test conducted according to the requirements in Table 3 to this subpart, you must submit the Notification of Compliance Status, including the performance test results, before the close of business on the 60th day following the completion of the performance test according to §63.10(d)(2).

[73 FR 3606, Jan. 18, 2008, as amended at 75 FR 9677, Mar. 3, 2010; 75 FR 51591, Aug. 20, 2010]

§ 63.6650 What reports must I submit and when?

(a) You must submit each report in Table 7 of this subpart that applies to you.

(b) Unless the Administrator has approved a different schedule for submission of reports under §63.10 (a), you must submit each report by the date in Table 7 of this subpart and according to the requirements in paragraphs (b)(1) through (b)(9) of this section.

(1) For semiannual Compliance reports, the first Compliance report must cover the period beginning on the compliance date that is specified for your affected source in §63.6595 and ending on June 30 or December 31, whichever date is the first date following the end of the first calendar half after the compliance date that is specified for your source in §63.6595.

(2) For semiannual Compliance reports, the first Compliance report must be postmarked or delivered no later than July 31 or January 31, whichever date follows the end of the first calendar half after the compliance date that is specified for your affected source in §63.6595.

(3) For semiannual Compliance reports, each subsequent Compliance report must cover the semiannual reporting period from January 1 through June 30 or the semiannual reporting period from July 1 through December 31.

(4) For semiannual Compliance reports, each subsequent Compliance report must be postmarked or delivered no later than July 31 or January 31, whichever date is the first date following the end of the semiannual reporting period.

(5) For each stationary RICE that is subject to permitting regulations pursuant to 40 CFR part 70 or 71, and if the permitting authority has established dates for submitting semiannual reports pursuant to 40 CFR 70.6(a)(3)(iii)(A) or 40 CFR 71.6 (a)(3)(iii)(A), you may submit the first and subsequent Compliance reports according to the dates the permitting authority has established instead of according to the dates in paragraphs (b)(1) through (b)(4) of this section.

(6) For annual Compliance reports, the first Compliance report must cover the period beginning on the compliance date that is specified for your affected source in §63.6595 and ending on December 31.

(7) For annual Compliance reports, the first Compliance report must be postmarked or delivered no later than January 31 following the end of the first calendar year after the compliance date that is specified for your affected source in §63.6595.

(8) For annual Compliance reports, each subsequent Compliance report must cover the annual reporting period from January 1 through December 31.

(9) For annual Compliance reports, each subsequent Compliance report must be postmarked or delivered no later than January 31.

(c) The Compliance report must contain the information in paragraphs (c)(1) through (6) of this section.

(1) Company name and address.

(2) Statement by a responsible official, with that official's name, title, and signature, certifying the accuracy of the content of the report.

(3) Date of report and beginning and ending dates of the reporting period.

(4) If you had a malfunction during the reporting period, the compliance report must include the number, duration, and a brief description for each type of malfunction which occurred during the reporting period and which caused or may have caused any applicable emission limitation to be exceeded. The report must also include a description of actions taken by an owner or operator during a malfunction of an affected source to minimize emissions in accordance with §63.6605(b), including actions taken to correct a malfunction.

(5) If there are no deviations from any emission or operating limitations that apply to you, a statement that there were no deviations from the emission or operating limitations during the reporting period.

(6) If there were no periods during which the continuous monitoring system (CMS), including CEMS and CPMS, was out-of-control, as specified in §63.8(c)(7), a statement that there were no periods during which the CMS was out-of-control during the reporting period.

(d) For each deviation from an emission or operating limitation that occurs for a stationary RICE where you are not using a CMS to comply with the emission or operating limitations in this subpart, the Compliance report must contain the information in paragraphs (c)(1) through (4) of this section and the information in paragraphs (d)(1) and (2) of this section.

(1) The total operating time of the stationary RICE at which the deviation occurred during the reporting period.

(2) Information on the number, duration, and cause of deviations (including unknown cause, if applicable), as applicable, and the corrective action taken.

(e) For each deviation from an emission or operating limitation occurring for a stationary RICE where you are using a CMS to comply with the emission and operating limitations in this subpart, you must include information in paragraphs (c)(1) through (4) and (e)(1) through (12) of this section.

(1) The date and time that each malfunction started and stopped.

(2) The date, time, and duration that each CMS was inoperative, except for zero (low-level) and high-level checks.

(3) The date, time, and duration that each CMS was out-of-control, including the information in §63.8(c)(8).

(4) The date and time that each deviation started and stopped, and whether each deviation occurred during a period of malfunction or during another period.

(5) A summary of the total duration of the deviation during the reporting period, and the total duration as a percent of the total source operating time during that reporting period.

(6) A breakdown of the total duration of the deviations during the reporting period into those that are due to control equipment problems, process problems, other known causes, and other unknown causes.

(7) A summary of the total duration of CMS downtime during the reporting period, and the total duration of CMS downtime as a percent of the total operating time of the stationary RICE at which the CMS downtime occurred during that reporting period.

(8) An identification of each parameter and pollutant (CO or formaldehyde) that was monitored at the stationary RICE.

(9) A brief description of the stationary RICE.

(10) A brief description of the CMS.

(11) The date of the latest CMS certification or audit.

(12) A description of any changes in CMS, processes, or controls since the last reporting period

(f) Each affected source that has obtained a title V operating permit pursuant to 40 CFR part 70 or 71 must report all deviations as defined in this subpart in the semiannual monitoring report required by 40 CFR 70.6 (a)(3)(iii)(A) or 40 CFR 71.6(a)(3)(iii)(A). If an affected source submits a Compliance report pursuant to Table 7 of this subpart along with, or as part of, the semiannual monitoring report required by 40 CFR 70.6(a)(3)(iii)(A) or 40 CFR 71.6(a)(3)(iii)(A), and the Compliance report includes all required information concerning deviations from any emission or operating limitation in this subpart, submission of the Compliance report shall be deemed to satisfy any obligation to report the same deviations in the semiannual monitoring report. However, submission of a Compliance report shall not otherwise affect any obligation the affected source may have to report deviations from permit requirements to the permit authority.

(g) If you are operating as a new or reconstructed stationary RICE which fires landfill gas or digester gas equivalent to 10 percent or more of the gross heat input on an annual basis, you must submit an annual report according to Table 7 of this subpart by the date specified unless the Administrator has approved a different schedule, according to the information described in paragraphs (b)(1) through (b)(5) of this section. You must report the data specified in (g)(1) through (g)(3) of this section.

(1) Fuel flow rate of each fuel and the heating values that were used in your calculations. You must also demonstrate that the percentage of heat input provided by landfill gas or digester gas is equivalent to 10 percent or more of the total fuel consumption on an annual basis.

(2) The operating limits provided in your federally enforceable permit, and any deviations from these limits.

(3) Any problems or errors suspected with the meters.

[69 FR 33506, June 15, 2004, as amended at 75 FR 9677, Mar. 3, 2010]

§ 63.6655 What records must I keep?

(a) If you must comply with the emission and operating limitations, you must keep the records described in paragraphs (a)(1) through (a)(5), (b)(1) through (b)(3) and (c) of this section.

(1) A copy of each notification and report that you submitted to comply with this subpart, including all documentation supporting any Initial Notification or Notification of Compliance Status that you submitted, according to the requirement in §63.10(b)(2)(xiv).

(2) Records of the occurrence and duration of each malfunction of operation (*i.e.,* process equipment) or the air pollution control and monitoring equipment.

(3) Records of performance tests and performance evaluations as required in §63.10(b)(2)(viii).

(4) Records of all required maintenance performed on the air pollution control and monitoring equipment.

(5) Records of actions taken during periods of malfunction to minimize emissions in accordance with §63.6605(b), including corrective actions to restore malfunctioning process and air pollution control and monitoring equipment to its normal or usual manner of operation.

(b) For each CEMS or CPMS, you must keep the records listed in paragraphs (b)(1) through (3) of this section.

(1) Records described in §63.10(b)(2)(vi) through (xi).

(2) Previous (*i.e.*, superseded) versions of the performance evaluation plan as required in §63.8(d)(3).

(3) Requests for alternatives to the relative accuracy test for CEMS or CPMS as required in §63.8(f)(6)(i), if applicable.

(c) If you are operating a new or reconstructed stationary RICE which fires landfill gas or digester gas equivalent to 10 percent or more of the gross heat input on an annual basis, you must keep the records of your daily fuel usage monitors.

(d) You must keep the records required in Table 6 of this subpart to show continuous compliance with each emission or operating limitation that applies to you.

(e) You must keep records of the maintenance conducted on the stationary RICE in order to demonstrate that you operated and maintained the stationary RICE and after-treatment control device (if any) according to your own maintenance plan if you own or operate any of the following stationary RICE;

(1) An existing stationary RICE with a site rating of less than 100 brake HP located at a major source of HAP emissions.

(2) An existing stationary emergency RICE.

(3) An existing stationary RICE located at an area source of HAP emissions subject to management practices as shown in Table 2d to this subpart.

(f) If you own or operate any of the stationary RICE in paragraphs (f)(1) or (2) of this section, you must keep records of the hours of operation of the engine that is recorded through the non-resettable hour meter. The owner or operator must document how many hours are spent for emergency operation, including what classified the operation as emergency and how many hours are spent for non-emergency operation. If the engines are used for demand response operation, the owner or operator must keep records of the notification of the emergency situation, and the time the engine was operated as part of demand response.

(1) An existing emergency stationary RICE with a site rating of less than or equal to 500 brake HP located at a major source of HAP emissions that does not meet the standards applicable to non-emergency engines.

(2) An existing emergency stationary RICE located at an area source of HAP emissions that does not meet the standards applicable to non-emergency engines.

[69 FR 33506, June 15, 2004, as amended at 75 FR 9678, Mar. 3, 2010; 75 FR 51592, Aug. 20, 2010]

§ 63.6660 In what form and how long must I keep my records?

(a) Your records must be in a form suitable and readily available for expeditious review according to §63.10(b)(1).

(b) As specified in §63.10(b)(1), you must keep each record for 5 years following the date of each occurrence, measurement, maintenance, corrective action, report, or record.

(c) You must keep each record readily accessible in hard copy or electronic form for at least 5 years after the date of each occurrence, measurement, maintenance, corrective action, report, or record, according to §63.10(b)(1).

[69 FR 33506, June 15, 2004, as amended at 75 FR 9678, Mar. 3, 2010]

Other Requirements and Information

§ 63.6665 What parts of the General Provisions apply to me?

Table 8 to this subpart shows which parts of the General Provisions in §§63.1 through 63.15 apply to you. If you own or operate a new or reconstructed stationary RICE with a site rating of less than or equal to 500 brake HP located at a major source of HAP emissions (except new or reconstructed 4SLB engines greater than or equal to 250 and less than or equal to 500 brake HP), a new or reconstructed stationary RICE located at an area source of HAP emissions, or any of the following RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions, you do not need to comply with any of the requirements of the General Provisions specified in Table 8: An existing 2SLB stationary RICE, an existing 4SLB stationary RICE, an existing stationary RICE that combusts landfill or digester gas equivalent to 10 percent or more of the gross heat input on an annual basis, an existing emergency stationary RICE, or an existing limited use stationary RICE. If you own or operate any of the following RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions, you do not need to comply with the requirements in the General Provisions specified in Table 8 except for the initial notification requirements: A new stationary RICE that combusts landfill gas or digester gas equivalent to 10 percent or more of the gross heat input on an annual basis, a new emergency stationary RICE, or a new limited use stationary RICE.

[75 FR 9678, Mar. 3, 2010]

§ 63.6670 Who implements and enforces this subpart?

(a) This subpart is implemented and enforced by the U.S. EPA, or a delegated authority such as your State, local, or tribal agency. If the U.S. EPA Administrator has delegated authority to your State, local, or tribal agency, then that agency (as well as the U.S. EPA) has the authority to implement and enforce this subpart. You should contact your U.S. EPA Regional Office to find out whether this subpart is delegated to your State, local, or tribal agency.

(b) In delegating implementation and enforcement authority of this subpart to a State, local, or tribal agency under 40 CFR part 63, subpart E, the authorities contained in paragraph (c) of this section are retained by the Administrator of the U.S. EPA and are not transferred to the State, local, or tribal agency.

(c) The authorities that will not be delegated to State, local, or tribal agencies are:

(1) Approval of alternatives to the non-opacity emission limitations and operating limitations in §63.6600 under §63.6(g).

(2) Approval of major alternatives to test methods under §63.7(e)(2)(ii) and (f), and as defined in §63.90.

(3) Approval of major alternatives to monitoring under §63.8(f), and as defined in §63.90.

(4) Approval of major alternatives to recordkeeping and reporting under §63.10(f), and as defined in §63.90.

(5) Approval of a performance test which was conducted prior to the effective date of the rule, as specified in §63.6610(b).

§ 63.6675 What definitions apply to this subpart?

Terms used in this subpart are defined in the Clean Air Act (CAA); in 40 CFR 63.2, the General Provisions of this part; and in this section as follows:

Area source means any stationary source of HAP that is not a major source as defined in part 63.

Associated equipment as used in this subpart and as referred to in section 112(n)(4) of the CAA, means equipment associated with an oil or natural gas exploration or production well, and includes all equipment from the well bore to the point of custody transfer, except glycol dehydration units, storage vessels with potential for flash emissions, combustion turbines, and stationary RICE.

Black start engine means an engine whose only purpose is to start up a combustion turbine.

CAA means the Clean Air Act (42 U.S.C. 7401 *et seq.*, as amended by Public Law 101–549, 104 Stat. 2399).

Commercial emergency stationary RICE means an emergency stationary RICE used in commercial establishments such as office buildings, hotels, stores, telecommunications facilities, restaurants, financial institutions such as banks, doctor's offices, and sports and performing arts facilities.

Compression ignition means relating to a type of stationary internal combustion engine that is not a spark ignition engine.

Custody transfer means the transfer of hydrocarbon liquids or natural gas: After processing and/or treatment in the producing operations, or from storage vessels or automatic transfer facilities or other such equipment, including product loading racks, to pipelines or anyother forms of transportation. For the purposes of this subpart, the point at which such liquids or natural gas enters a natural gas processing plant is a point of custody transfer.

Deviation means any instance in which an affected source subject to this subpart, or an owner or operator of such a source:

(1) Fails to meet any requirement or obligation established by this subpart, including but not limited to any emission limitation or operating limitation;

(2) Fails to meet any term or condition that is adopted to implement an applicable requirement in this subpart and that is included in the operating permit for any affected source required to obtain such a permit; or

(3) Fails to meet any emission limitation or operating limitation in this subpart during malfunction, regardless or whether or not such failure is permitted by this subpart.

(4) Fails to satisfy the general duty to minimize emissions established by §63.6(e)(1)(i).

Diesel engine means any stationary RICE in which a high boiling point liquid fuel injected into the combustion chamber ignites when the air charge has been compressed to a temperature sufficiently high for auto-ignition. This process is also known as compression ignition.

Diesel fuel means any liquid obtained from the distillation of petroleum with a boiling point of approximately 150 to 360 degrees Celsius. One commonly used form is fuel oil number 2. Diesel fuel also includes any non-distillate fuel with comparable physical and chemical properties (*e.g.* biodiesel) that is suitable for use in compression ignition engines.

Digester gas means any gaseous by-product of wastewater treatment typically formed through the anaerobic decomposition of organic waste materials and composed principally of methane and CO_2.

Dual-fuel engine means any stationary RICE in which a liquid fuel (typically diesel fuel) is used for compression ignition and gaseous fuel (typically natural gas) is used as the primary fuel.

Emergency stationary RICE means any stationary internal combustion engine whose operation is limited to emergency situations and required testing and maintenance. Examples include stationary RICE used to produce power for critical networks or equipment (including power supplied to portions of a facility) when electric power from the local utility (or the normal power source, if the facility runs on its own power production) is interrupted, or stationary RICE used to pump water in the case of fire or flood, *etc.* Stationary RICE used for peak shaving are not considered emergency stationary RICE. Stationary RICE used to supply power to an electric grid or that supply non-emergency power as part of a financial arrangement with another entity are not considered to be emergency engines, except as permitted under §63.6640(f). All emergency stationary RICE must comply with the requirements specified in §63.6640(f) in order to be considered emergency stationary RICE. If the engine does not comply with the requirements specified in §63.6640(f), then it is not considered to be an emergency stationary RICE under this subpart.

Engine startup means the time from initial start until applied load and engine and associated equipment reaches steady state or normal operation. For stationary engine with catalytic controls, engine startup

means the time from initial start until applied load and engine and associated equipment, including the catalyst, reaches steady state or normal operation.

Four-stroke engine means any type of engine which completes the power cycle in two crankshaft revolutions, with intake and compression strokes in the first revolution and power and exhaust strokes in the second revolution.

Gaseous fuel means a material used for combustion which is in the gaseous state at standard atmospheric temperature and pressure conditions.

Gasoline means any fuel sold in any State for use in motor vehicles and motor vehicle engines, or nonroad or stationary engines, and commonly or commercially known or sold as gasoline.

Glycol dehydration unit means a device in which a liquid glycol (including, but not limited to, ethylene glycol, diethylene glycol, or triethylene glycol) absorbent directly contacts a natural gas stream and absorbs water in a contact tower or absorption column (absorber). The glycol contacts and absorbs water vapor and other gas stream constituents from the natural gas and becomes "rich" glycol. This glycol is then regenerated in the glycol dehydration unit reboiler. The "lean" glycol is then recycled.

Hazardous air pollutants (HAP) means any air pollutants listed in or pursuant to section 112(b) of the CAA.

Institutional emergency stationary RICE means an emergency stationary RICE used in institutional establishments such as medical centers, nursing homes, research centers, institutions of higher education, correctional facilities, elementary and secondary schools, libraries, religious establishments, police stations, and fire stations.

ISO standard day conditions means 288 degrees Kelvin (15 degrees Celsius), 60 percent relative humidity and 101.3 kilopascals pressure.

Landfill gas means a gaseous by-product of the land application of municipal refuse typically formed through the anaerobic decomposition of waste materials and composed principally of methane and CO_2.

Lean burn engine means any two-stroke or four-stroke spark ignited engine that does not meet the definition of a rich burn engine.

Limited use stationary RICE means any stationary RICE that operates less than 100 hours per year.

Liquefied petroleum gas means any liquefied hydrocarbon gas obtained as a by-product in petroleum refining of natural gas production.

Liquid fuel means any fuel in liquid form at standard temperature and pressure, including but not limited to diesel, residual/crude oil, kerosene/naphtha (jet fuel), and gasoline.

Major Source, as used in this subpart, shall have the same meaning as in §63.2, except that:

(1) Emissions from any oil or gas exploration or production well (with its associated equipment (as defined in this section)) and emissions from any pipeline compressor station or pump station shall not be aggregated with emissions from other similar units, to determine whether such emission points or stations are major sources, even when emission points are in a contiguous area or under common control;

(2) For oil and gas production facilities, emissions from processes, operations, or equipment that are not part of the same oil and gas production facility, as defined in §63.1271 of subpart HHH of this part, shall not be aggregated;

(3) For production field facilities, only HAP emissions from glycol dehydration units, storage vessel with the potential for flash emissions, combustion turbines and reciprocating internal combustion engines shall be aggregated for a major source determination; and

(4) Emissions from processes, operations, and equipment that are not part of the same natural gas transmission and storage facility, as defined in §63.1271 of subpart HHH of this part, shall not be

aggregated.

Malfunction means any sudden, infrequent, and not reasonably preventable failure of air pollution control equipment, process equipment, or a process to operate in a normal or usual manner which causes, or has the potential to cause, the emission limitations in an applicable standard to be exceeded. Failures that are caused in part by poor maintenance or careless operation are not malfunctions.

Natural gas means a naturally occurring mixture of hydrocarbon and non-hydrocarbon gases found in geologic formations beneath the Earth's surface, of which the principal constituent is methane. Natural gas may be field or pipeline quality.

Non-selective catalytic reduction (NSCR) means an add-on catalytic nitrogen oxides (NO_X) control device for rich burn engines that, in a two-step reaction, promotes the conversion of excess oxygen, NO_X, CO, and volatile organic compounds (VOC) into CO_2, nitrogen, and water.

Oil and gas production facility as used in this subpart means any grouping of equipment where hydrocarbon liquids are processed, upgraded (*i.e.,* remove impurities or other constituents to meet contract specifications), or stored prior to the point of custody transfer; or where natural gas is processed, upgraded, or stored prior to entering the natural gas transmission and storage source category. For purposes of a major source determination, facility (including a building, structure, or installation) means oil and natural gas production and processing equipment that is located within the boundaries of an individual surface site as defined in this section. Equipment that is part of a facility will typically be located within close proximity to other equipment located at the same facility. Pieces of production equipment or groupings of equipment located on different oil and gas leases, mineral fee tracts, lease tracts, subsurface or surface unit areas, surface fee tracts, surface lease tracts, or separate surface sites, whether or not connected by a road, waterway, power line or pipeline, shall not be considered part of the same facility. Examples of facilities in the oil and natural gas production source category include, but are not limited to, well sites, satellite tank batteries, central tank batteries, a compressor station that transports natural gas to a natural gas processing plant, and natural gas processing plants.

Oxidation catalyst means an add-on catalytic control device that controls CO and VOC by oxidation.

Peaking unit or engine means any standby engine intended for use during periods of high demand that are not emergencies.

Percent load means the fractional power of an engine compared to its maximum manufacturer's design capacity at engine site conditions. Percent load may range between 0 percent to above 100 percent.

Potential to emit means the maximum capacity of a stationary source to emit a pollutant under its physical and operational design. Any physical or operational limitation on the capacity of the stationary source to emit a pollutant, including air pollution control equipment and restrictions on hours of operation or on the type or amount of material combusted, stored, or processed, shall be treated as part of its design if the limitation or the effect it would have on emissions is federally enforceable. For oil and natural gas production facilities subject to subpart HH of this part, the potential to emit provisions in §63.760(a) may be used. For natural gas transmission and storage facilities subject to subpart HHH of this part, the maximum annual facility gas throughput for storage facilities may be determined according to §63.1270(a)(1) and the maximum annual throughput for transmission facilities may be determined according to §63.1270(a)(2).

Production field facility means those oil and gas production facilities located prior to the point of custody transfer.

Production well means any hole drilled in the earth from which crude oil, condensate, or field natural gas is extracted.

Propane means a colorless gas derived from petroleum and natural gas, with the molecular structure C_3H_8.

Residential emergency stationary RICE means an emergency stationary RICE used in residential establishments such as homes or apartment buildings.

Responsible official means responsible official as defined in 40 CFR 70.2.

Rich burn engine means any four-stroke spark ignited engine where the manufacturer's recommended operating air/fuel ratio divided by the stoichiometric air/fuel ratio at full load conditions is less than or equal to 1.1. Engines originally manufactured as rich burn engines, but modified prior to December 19, 2002 with passive emission control technology for NO_X (such as pre-combustion chambers) will be considered lean burn engines. Also, existing engines where there are no manufacturer's recommendations regarding air/fuel ratio will be considered a rich burn engine if the excess oxygen content of the exhaust at full load conditions is less than or equal to 2 percent.

Site-rated HP means the maximum manufacturer's design capacity at engine site conditions.

Spark ignition means relating to either: A gasoline-fueled engine; or any other type of engine with a spark plug (or other sparking device) and with operating characteristics significantly similar to the theoretical Otto combustion cycle. Spark ignition engines usually use a throttle to regulate intake air flow to control power during normal operation. Dual-fuel engines in which a liquid fuel (typically diesel fuel) is used for CI and gaseous fuel (typically natural gas) is used as the primary fuel at an annual average ratio of less than 2 parts diesel fuel to 100 parts total fuel on an energy equivalent basis are spark ignition engines.

Stationary reciprocating internal combustion engine (RICE) means any reciprocating internal combustion engine which uses reciprocating motion to convert heat energy into mechanical work and which is not mobile. Stationary RICE differ from mobile RICE in that a stationary RICE is not a non-road engine as defined at 40 CFR 1068.30, and is not used to propel a motor vehicle or a vehicle used solely for competition.

Stationary RICE test cell/stand means an engine test cell/stand, as defined in subpart PPPPP of this part, that tests stationary RICE.

Stoichiometric means the theoretical air-to-fuel ratio required for complete combustion.

Storage vessel with the potential for flash emissions means any storage vessel that contains a hydrocarbon liquid with a stock tank gas-to-oil ratio equal to or greater than 0.31 cubic meters per liter and an American Petroleum Institute gravity equal to or greater than 40 degrees and an actual annual average hydrocarbon liquid throughput equal to or greater than 79,500 liters per day. Flash emissions occur when dissolved hydrocarbons in the fluid evolve from solution when the fluid pressure is reduced.

Subpart means 40 CFR part 63, subpart ZZZZ.

Surface site means any combination of one or more graded pad sites, gravel pad sites, foundations, platforms, or the immediate physical location upon which equipment is physically affixed.

Two-stroke engine means a type of engine which completes the power cycle in single crankshaft revolution by combining the intake and compression operations into one stroke and the power and exhaust operations into a second stroke. This system requires auxiliary scavenging and inherently runs lean of stoichiometric.

[69 FR 33506, June 15, 2004, as amended at 71 FR 20467, Apr. 20, 2006; 73 FR 3607, Jan. 18, 2008; 75 FR 9679, Mar. 3, 2010; 75 FR 51592, Aug. 20, 2010; 76 FR 12867, Mar. 9, 2011]

Table 1a to Subpart ZZZZ of Part 63— Emission Limitations for Existing, New, and Reconstructed Spark Ignition, 4SRB Stationary RICE >500 HP Located at a Major Source of HAP Emissions

As stated in §§63.6600 and 63.6640, you must comply with the following emission limitations at 100 percent load plus or minus 10 percent for existing, new and reconstructed 4SRB stationary RICE >500 HP located at a major source of HAP emissions:

For each . . .	You must meet the following emission limitation, except during periods of startup . . .	During periods of startup you must . . .
1. 4SRB stationary	a. Reduce formaldehyde emissions by 76 percent or more.	Minimize the engine's time spent at idle and minimize the

RICE	If you commenced construction or reconstruction between December 19, 2002 and June 15, 2004, you may reduce formaldehyde emissions by 75 percent or more until June 15, 2007 or	engine's startup time at startup to a period needed for appropriate and safe loading of the engine, not to exceed 30 minutes, after which time the non-startup emission limitations apply.[1]
	b. Limit the concentration of formaldehyde in the stationary RICE exhaust to 350 ppbvd or less at 15 percent O_2	

[1]Sources can petition the Administrator pursuant to the requirements of 40 CFR 63.6(g) for alternative work practices.

[75 FR 9679, Mar. 3, 2010, as amended at 75 FR 51592, Aug. 20, 2010]

Table 1bto Subpart ZZZZ of Part 63—Operating Limitations for Existing, New, and Reconstructed Spark Ignition 4SRB Stationary RICE >500 HP Located at a Major Source of HAP Emissions and Existing Spark Ignition 4SRB Stationary RICE >500 HP Located at an Area Source of HAP Emissions

As stated in §§63.6600, 63.6603, 63.6630 and 63.6640,you must comply with the following operating limitations for existing, new and reconstructed 4SRB stationaryRICE >500 HP located at a major source of HAP emissions and existing 4SRB stationary RICE >500 HP located at an area source of HAP emissions that operate more than 24 hours per calendar year:

For each . . .	You must meet the following operating limitation . . .
1. 4SRB stationary RICE complying with the requirement to reduce formaldehyde emissions by 76 percent or more (or by 75 percent or more, if applicable) and using NSCR; or 4SRB stationary RICE complying with the requirement to limit the concentration of formaldehyde in the stationary RICE exhaust to 350 ppbvd or less at 15 percent O2 and using NSCR; or 4SRB stationary RICE complying with the requirement to limit the concentration of formaldehyde in the stationary RICE exhaust to 2.7 ppmvd or less at 15 percent O2 and using NSCR.	a. Maintain your catalyst so that the pressure drop across the catalyst does not change by more than 2 inches of water at 100 percent load plus or minus 10 percent from the pressure drop across the catalyst measured during the initial performance test; and b. Maintain the temperature of your stationary RICE exhaust so that the catalyst inlet temperature is greater than or equal to 750 °F and less than or equal to 1250 °F.
2. 4SRB stationary RICE complying with the requirement to reduce formaldehyde emissions by 76 percent or more (or by 75 percent or more, if applicable) and	Comply with any operating limitations approved by the Administrator.

not using NSCR; or 4SRB stationary RICE complying with the requirement to limit the concentration of formaldehyde in the stationary RICE exhaust to 350 ppbvd or less at 15 percent O2 and not using NSCR; or 4SRB stationary RICE complying with the requirement to limit the concentration of formaldehyde in the stationary RICE exhaust to 2.7 ppmvd or less at 15 percent O2 and not using NSCR.	

[76 FR 12867, Mar. 9, 2011]

Table 2ato Subpart ZZZZ of Part 63—Emission Limitations for New and Reconstructed 2SLB and Compression Ignition Stationary RICE >500 HP and New and Reconstructed 4SLB Stationary RICE ≥250 HP Located at a Major Source of HAP Emissions

As stated in §§63.6600 and 63.6640, you must comply with the following emission limitations for new and reconstructed lean burn and new and reconstructed compression ignition stationary RICE at 100 percent load plus or minus 10 percent:

For each . . .	You must meet the following emission limitation, except during periods of startup . . .	During periods of startup you must . . .
1. 2SLB stationary RICE	a. Reduce CO emissions by 58 percent or more; or b. Limit concentration of formaldehyde in the stationary RICE exhaust to 12 ppmvd or less at 15 percent O_2. If you commenced construction or reconstruction between December 19, 2002 and June 15, 2004, you may limit concentration of formaldehyde to 17 ppmvd or less at 15 percent O_2until June 15, 2007	Minimize the engine's time spent at idle and minimize the engine's startup time at startup to a period needed for appropriate and safe loading of the engine, not to exceed 30 minutes, after which time the non-startup emission limitations apply.[1]
2. 4SLB stationary RICE	a. Reduce CO emissions by 93 percent or more; or	
	b. Limit concentration of formaldehyde in the stationary RICE exhaust to 14 ppmvd or less at 15 percent O_2	
3. CI stationary RICE	a. Reduce CO emissions by 70 percent or more; or	
	b. Limit concentration of	

	formaldehyde in the stationary RICE exhaust to 580 ppbvd or less at 15 percent O_2	

[1]Sources can petition the Administrator pursuant to the requirements of 40 CFR 63.6(g) for alternative work practices.

[75 FR 9680, Mar. 3, 2010]

Table 2bto Subpart ZZZZ of Part 63— Operating Limitations for New and Reconstructed 2SLB and Compression Ignition Stationary RICE >500 HP Located at a Major Source of HAP Emissions, New and Reconstructed 4SLB Stationary RICE ≥250 HP Located at a Major Source of HAP Emissions, Existing Compression Ignition Stationary RICE >500 HP, and Existing 4SLB Stationary RICE >500 HP Located at an Area Source of HAP Emissions

As stated in §§63.6600, 63.6601, 63.6603, 63.6630, and63.6640, you must comply with the following operating limitations for new and reconstructed 2SLB and compression ignition stationary RICE located at a major source of HAP emissions; new and reconstructed 4SLB stationaryRICE ≥250 HP located at a major source of HAP emissions; existing compression ignition stationaryRICE >500 HP; and existing 4SLB stationary RICE >500 HP located at an area source ofHAP emissions that operate more than 24 hours per calendar year:

For each . . .	You must meet the following operating limitation . . .
1. 2SLB and 4SLB stationary RICE and CI stationary RICE complying with the requirement to reduce CO emissions and using an oxidation catalyst; or 2SLB and 4SLB stationary RICE and CI stationary RICE complying with the requirement to limit the concentration of formaldehyde in the stationary RICE exhaust and using an oxidation catalyst; or 4SLB stationary RICE and CI stationary RICE complying with the requirement to limit the concentration of CO in the stationary RICE exhaust and using an oxidation catalyst	a. maintain your catalyst so that the pressure drop across the catalyst does not change by more than 2 inches of water at 100 percent load plus or minus 10 percent from the pressure drop across the catalyst that was measured during the initial performance test; and b. maintain the temperature of your stationary RICE exhaust so that the catalyst inlet temperature is greater than or equal to 450 °F and less than or equal to 1350 ° F.[1]
2. 2SLB and 4SLB stationary RICE and CI stationary RICE complying with the requirement to reduce CO emissions and not using an oxidation catalyst; or 2SLB and 4SLB stationary RICE and CI stationary RICE complying with the requirement to limit the concentration of formaldehyde in the stationary RICE exhaust and not using an oxidation catalyst; or 4SLB stationary RICE and CI stationary RICE complying with the	Comply with any operating limitations approved by the Administrator.

requirement to limit the concentration of CO in the stationary RICE exhaust and not using an oxidation catalyst	

[1]Sources can petition the Administrator pursuant to the requirements of 40 CFR 63.8(g) for a different temperature range.

[75 FR 51593, Aug. 20, 2010, as amended at 76 FR 12867, Mar. 9, 2011]

Table 2cto Subpart ZZZZ of Part 63—Requirements for Existing Compression Ignition Stationary RICE Located at a Major Source of HAP Emissions and Existing Spark Ignition Stationary RICE ≤500 HP Located at a Major Source of HAP Emissions

As stated in §§63.6600, 63.6602, and 63.6640, you must comply with the following requirements for existing compression ignition stationary RICE located at a major source of HAP emissions and existing spark ignition stationary RICE ≤500 HP located at a major source of HAP emissions:

For each . . .	You must meet the following requirement, except during periods of startup . . .	During periods of startup you must . . .
1. Emergency stationary CI RICE and black start stationary CI RICE.[1]	a. Change oil and filter every 500 hours of operation or annually, whichever comes first;[2] b. Inspect air cleaner every 1,000 hours of operation or annually, whichever comes first; c. Inspect all hoses and belts every 500 hours of operation or annually, whichever comes first, and replace as necessary.[3]	Minimize the engine's time spent at idle and minimize the engine's startup time at startup to a period needed for appropriate and safe loading of the engine, not to exceed 30 minutes, after which time the non-startup emission limitations apply.[3]
2. Non-Emergency, non-black start stationary CI RICE <100 HP	a. Change oil and filter every 1,000 hours of operation or annually, whichever comes first;[2]	
	b. Inspect air cleaner every 1,000 hours of operation or annually, whichever comes first;	
	c. Inspect all hoses and belts every 500 hours of operation or annually, whichever comes first, and replace as necessary.[3]	
3. Non-Emergency,	Limit concentration of	

non-black start CI stationary RICE 100≤HP≤300 HP	CO in the stationary RICE exhaust to 230 ppmvd or less at 15 percent O_2	
4. Non-Emergency, non-black start CI stationary RICE 300<HP≤500	a. Limit concentration of CO in the stationary RICE exhaust to 49 ppmvd or less at 15 percent O_2; or	
	b. Reduce CO emissions by 70 percent or more.	
5. Non-Emergency, non-black start stationary CI RICE >500 HP	a. Limit concentration of CO in the stationary RICE exhaust to 23 ppmvd or less at 15 percent O_2; or	
	b. Reduce CO emissions by 70 percent or more.	
6. Emergency stationary SI RICE and black start stationary SI RICE.[1]	a. Change oil and filter every 500 hours of operation or annually, whichever comes first;[2]	
	b. Inspect spark plugs every 1,000 hours of operation or annually, whichever comes first;	
	c. Inspect all hoses and belts every 500 hours of operation or annually, whichever comes first, and replace as necessary.[3]	
7. Non-Emergency, non-black start stationary SI RICE <100 HP that are not 2SLB stationary RICE	a. Change oil and filter every 1,440 hours of operation or annually, whichever comes first;[2]	
	b. Inspect spark plugs every 1,440 hours of operation or annually, whichever comes first;	
	c. Inspect all hoses and belts every 1,440 hours of operation or annually, whichever	

	comes first, and replace as necessary.[3]	
8. Non-Emergency, non-black start 2SLB stationary SI RICE <100 HP	a. Change oil and filter every 4,320 hours of operation or annually, whichever comes first;[2]	
	b. Inspect spark plugs every 4,320 hours of operation or annually, whichever comes first;	
	c. Inspect all hoses and belts every 4,320 hours of operation or annually, whichever comes first, and replace as necessary.[3]	
9. Non-emergency, non-black start 2SLB stationary RICE 100≤HP≤500	Limit concentration of CO in the stationary RICE exhaust to 225 ppmvd or less at 15 percent O_2	
10. Non-emergency, non-black start 4SLB stationary RICE 100≤HP≤500	Limit concentration of CO in the stationary RICE exhaust to 47 ppmvd or less at 15 percent O_2	
11. Non-emergency, non-black start 4SRB stationary RICE 100≤HP≤500	Limit concentration of formaldehyde in the stationary RICE exhaust to 10.3 ppmvd or less at 15 percent O_2	
12. Non-emergency, non-black start landfill or digester gas-fired stationary RICE 100≤HP≤500	Limit concentration of CO in the stationary RICE exhaust to 177 ppmvd or less at 15 percent O_2	

[1]If an emergency engine is operating during an emergency and it is not possible to shut down the engine in order to perform the work practice requirements on the schedule required in Table 2c of this subpart, or if performing the work practice on the required schedule would otherwise pose an unacceptable risk under Federal, State, or local law, the work practice can be delayed until the emergency is over or the unacceptable risk under Federal, State, or local law has abated. The work practice should be performed as soon as practicable after the emergency has ended or the unacceptable risk under Federal, State, or local law has abated. Sources must report any failure to perform the work practice on the schedule required and the Federal, State or local law under which the risk was deemed unacceptable.

[2]Sources have the option to utilize an oil analysis program as described in §63.6625(i) in order to extend the specified oil change requirement in Table 2c of this subpart.

[3]Sources can petition the Administrator pursuant to the requirements of 40 CFR 63.6(g) for alternative work practices.

[75 FR 51593, Aug. 20, 2010]

Table 2dto Subpart ZZZZ of Part 63— Requirements for Existing Stationary RICE Located at Area Sources of HAP Emissions

As stated in §§63.6603 and 63.6640, you must comply with the following requirements for existing stationary RICE located at area sources of HAP emissions:

For each . . .	You must meet the following requirement, except during periods of startup . . .	During periods of startup you must . . .
1. Non-Emergency, non-black start CI stationary RICE ≤300 HP	a. Change oil and filter every 1,000 hours of operation or annually, whichever comes first;[1]	Minimize the engine's time spent at idle and minimize the engine's startup time at startup to a period needed for appropriate and safe loading of the engine, not to exceed 30 minutes, after which time the non-startup emission limitations apply.
	b. Inspect air cleaner every 1,000 hours of operation or annually, whichever comes first; c. Inspect all hoses and belts every 500 hours of operation or annually, whichever comes first, and replace as necessary.	
2. Non-Emergency, non-black start CI stationary RICE 300<HP≤500	a. Limit concentration of CO in the stationary RICE exhaust to 49 ppmvd at 15 percent O_2; or	
	b. Reduce CO emissions by 70 percent or more.	
3. Non-Emergency, non-black	a. Limit	

start CI stationary RICE >500 HP	concentration of CO in the stationary RICE exhaust to 23 ppmvd at 15 percent O_2; or	
	b. Reduce CO emissions by 70 percent or more.	
4. Emergency stationary CI RICE and black start stationary CI RICE.[2]	a. Change oil and filter every 500 hours of operation or annually, whichever comes first;[1]	
	b. Inspect air cleaner every 1,000 hours of operation or annually, whichever comes first; and	
	c. Inspect all hoses and belts every 500 hours of operation or annually, whichever comes first, and replace as necessary.	
5. Emergency stationary SI RICE; black start stationary SI RICE; non-emergency, non-black start 4SLB stationary RICE >500 HP that operate 24 hours or less per calendar year; non-emergency, non-black start 4SRB stationary RICE >500 HP that operate 24 hours or less per calendar year.[2]	a. Change oil and filter every 500 hours of operation or annually, whichever comes first;[1] b. Inspect spark plugs every 1,000 hours of operation or annually, whichever comes first; and c. Inspect all hoses and belts every 500 hours of operation or annually, whichever comes first, and replace as necessary.	
6. Non-emergency, non-black start 2SLB stationary RICE	a. Change oil and filter every 4,320 hours of operation	

	or annually, whichever comes first;[1]	
	b. Inspect spark plugs every 4,320 hours of operation or annually, whichever comes first; and	
	c. Inspect all hoses and belts every 4,320 hours of operation or annually, whichever comes first, and replace as necessary.	
7. Non-emergency, non-black start 4SLB stationary RICE ≤500 HP	a. Change oil and filter every 1,440 hours of operation or annually, whichever comes first;[1]	
	b. Inspect spark plugs every 1,440 hours of operation or annually, whichever comes first; and	
	c. Inspect all hoses and belts every 1,440 hours of operation or annually, whichever comes first, and replace as necessary.	
8. Non-emergency, non-black start 4SLB stationary RICE >500 HP	a. Limit concentration of CO in the stationary RICE exhaust to 47 ppmvd at 15 percent O_2; or	
	b. Reduce CO emissions by 93 percent or more.	
9. Non-emergency, non-black start 4SRB stationary RICE ≤500 HP	a. Change oil and filter every 1,440 hours of operation	

	or annually, whichever comes first;[1]	
	b. Inspect spark plugs every 1,440 hours of operation or annually, whichever comes first; and	
	c. Inspect all hoses and belts every 1,440 hours of operation or annually, whichever comes first, and replace as necessary.	
10. Non-emergency, non-black start 4SRB stationary RICE >500 HP	a. Limit concentration of formaldehyde in the stationary RICE exhaust to 2.7 ppmvd at 15 percent O_2; or	
	b. Reduce formaldehyde emissions by 76 percent or more.	
11. Non-emergency, non-black start landfill or digester gas-fired stationary RICE	a. Change oil and filter every 1,440 hours of operation or annually, whichever comes first;[1]	
	b. Inspect spark plugs every 1,440 hours of operation or annually, whichever comes first; and	
	c. Inspect all hoses and belts every 1,440 hours of operation or annually, whichever comes first, and replace as necessary.	

[1]Sources have the option to utilize an oil analysis program as described in §63.6625(i) in order to extend the specified oil change requirement in Table 2d of this subpart.

[2]If an emergency engine is operating during an emergency and it is not possible to shut down the engine in order to perform the management practice requirements on the schedule required in Table 2d of this subpart, or if performing the management practice on the required schedule would otherwise pose an unacceptable risk under Federal, State, or local law, the management practice can be delayed until the emergency is over or the unacceptable risk under Federal, State, or local law has abated. The management practice should be performed as soon as practicable after the emergency has ended or the unacceptable risk under Federal, State, or local law has abated. Sources must report any failure to perform the management practice on the schedule required and the Federal, State or local law under which the risk was deemed unacceptable.

[75 FR 51595, Aug. 20, 2010]

Table 3 to Subpart ZZZZ of Part 63—Subsequent Performance Tests

As stated in §§63.6615 and 63.6620, you must comply with the following subsequent performance test requirements:

For each . . .	Complying with the requirement to . . .	You must . . .
1. New or reconstructed 2SLB stationary RICE with a brake horsepower >500 located at major sources; new or reconstructed 4SLB stationary RICE with a brake horsepower ≥250 located at major sources; and new or reconstructed CI stationary RICE with a brake horsepower >500 located at major sources	Reduce CO emissions and not using a CEMS	Conduct subsequent performance tests semiannually.[1]
2. 4SRB stationary RICE with a brake horsepower ≥5,000 located at major sources	Reduce formaldehyde emissions	Conduct subsequent performance tests semiannually.[1]
3. Stationary RICE with a brake horsepower >500 located at major sources and new or reconstructed 4SLB stationary RICE with a brake horsepower 250≤HP≤500 located at major sources	Limit the concentration of formaldehyde in the stationary RICE exhaust	Conduct subsequent performance tests semiannually.[1]
4. Existing non-emergency, non-black start CI stationary RICE with a brake horsepower >500 that are not limited use stationary RICE; existing non-emergency, non-black start 4SLB and 4SRB stationary RICE located at an area source of HAP emissions with a brake horsepower >500 that are operated more than 24 hours per calendar year that are not limited use stationary RICE	Limit or reduce CO or formaldehyde emissions	Conduct subsequent performance tests every 8,760 hrs. or 3 years, whichever comes first.

5. Existing non-emergency, non-black start CI stationary RICE with a brake horsepower >500 that are limited use stationary RICE; existing non-emergency, non-black start 4SLB and 4SRB stationary RICE located at an area source of HAP emissions with a brake horsepower >500 that are operated more than 24 hours per calendar year and are limited use stationary RICE	Limit or reduce CO or formaldehyde emissions	Conduct subsequent performance tests every 8,760 hrs. or 5 years, whichever comes first.

[1]After you have demonstrated compliance for two consecutive tests, you may reduce the frequency of subsequent performance tests to annually. If the results of any subsequent annual performance test indicate the stationary RICE is not in compliance with the CO or formaldehyde emission limitation, or you deviate from any of your operating limitations, you must resume semiannual performance tests.

[75 FR 51596, Aug. 20, 2010]

Table 4 to Subpart ZZZZ of Part 63—Requirements for Performance Tests

As stated in §§63.6610, 63.6611, 63.6612, 63.6620, and63.6640, you must comply with the following requirements for performance tests for stationary RICE:

For each . . .	Complying with the requirement to . . .	You must . . .	Using . . .	According to the following requirements . . .
1. 2SLB, 4SLB, and CI stationary RICE	a. Reduce CO emissions	i. Measure the O_2 at the inlet and outlet of the control device; and	(1) Portable CO and O_2 analyzer	(a) Using ASTM D6522–00 (2005)[a] (incorporated by reference, see §63.14). Measurements to determine O_2 must be made at the same time as the measurements for CO concentration.
		ii. Measure the CO at the inlet and the outlet of the control device	(1) Portable CO and O_2 analyzer	(a) Using ASTM D6522–00 (2005)[ab] (incorporated by reference, see §63.14) or Method 10 of 40 CFR appendix A. The CO

				concentration must be at 15 percent O_2, dry basis.
2. 4SRB stationary RICE	a. Reduce formaldehyde emissions	i. Select the sampling port location and the number of traverse points; and	(1) Method 1 or 1A of 40 CFR part 60, appendix A §63.7(d)(1)(i)	(a) Sampling sites must be located at the inlet and outlet of the control device.
		ii. Measure O_2 at the inlet and outlet of the control device; and	(1) Method 3 or 3A or 3B of 40 CFR part 60, appendix A, or ASTM Method D6522–00m (2005)	(a) Measurements to determine O_2 concentration must be made at the same time as the measurements for formaldehyde concentration.
		iii. Measure moisture content at the inlet and outlet of the control device; and	(1) Method 4 of 40 CFR part 60, appendix A, or Test Method 320 of 40 CFR part 63, appendix A, or ASTM D 6348–03	(a) Measurements to determine moisture content must be made at the same time and location as the measurements for formaldehyde concentration.
		iv. Measure formaldehyde at the inlet and the outlet of the control device	(1) Method 320 or 323 of 40 CFR part 63, appendix A; or ASTM D6348–03,[c] provided in ASTM D6348–03 Annex A5 (Analyte Spiking Technique), the percent R must be greater than or equal to 70 and less than or equal to 130	(a) Formaldehyde concentration must be at 15 percent O_2, dry basis. Results of this test consist of the average of the three 1-hour or longer runs.
3. Stationary RICE	a. Limit the concentration of formaldehyde	i. Select the sampling port location and the number of	(1) Method 1 or 1A of 40 CFR part 60, appendix A	(a) If using a control device, the sampling site must be located

	or CO in the stationary RICE exhaust	traverse points; and	§63.7(d)(1)(i)	at the outlet of the control device.
		ii. Determine the O_2concentration of the stationary RICE exhaust at the sampling port location; and	(1) Method 3 or 3A or 3B of 40 CFR part 60, appendix A, or ASTM Method D6522–00 (2005)	(a) Measurements to determine O_2concentration must be made at the same time and location as the measurements for formaldehyde concentration.
		iii. Measure moisture content of the stationary RICE exhaust at the sampling port location; and	(1) Method 4 of 40 CFR part 60, appendix A, or Test Method 320 of 40 CFR part 63, appendix A, or ASTM D 6348–03	(a) Measurements to determine moisture content must be made at the same time and location as the measurements for formaldehyde concentration.
		iv. Measure formaldehyde at the exhaust of the stationary RICE; or	(1) Method 320 or 323 of 40 CFR part 63, appendix A; or ASTM D6348–03,[c]provided in ASTM D6348–03 Annex A5 (Analyte Spiking Technique), the percent R must be greater than or equal to 70 and less than or equal to 130	(a) Formaldehyde concentration must be at 15 percent O_2, dry basis. Results of this test consist of the average of the three 1-hour or longer runs.
		v. Measure CO at the exhaust of the stationary RICE	(1) Method 10 of 40 CFR part 60, appendix A, ASTM Method D6522–00 (2005),[a]Method 320 of 40 CFR part 63, appendix A, or ASTM D6348–	(a) CO Concentration must be at 15 percent O_2, dry basis. Results of this test consist of the average of the three 1-hour longer runs.

			03	

[a]You may also use Methods 3A and 10 as options to ASTM–D6522–00 (2005). You may obtain a copy of ASTM–D6522–00 (2005) from at least one of the following addresses: American Society for Testing and Materials, 100 Barr Harbor Drive, West Conshohocken, PA 19428-2959, or University Microfilms International, 300 North Zeeb Road, Ann Arbor, MI 48106. ASTM–D6522–00 (2005) may be used to test both CI and SI stationary RICE.

[b]You may also use Method 320 of 40 CFR part 63, appendx A, or ASTM D6348–03.

[c]You may obtain a copy of ASTM–D6348–03 from at least one of the following addresses: American Society for Testing and Materials, 100 Barr Harbor Drive, West Conshohocken, PA 19428-2959, or University Microfilms International, 300 North Zeeb Road, Ann Arbor, MI 48106.

[75 FR 51597, Aug. 20, 2010]

Table 5 to Subpart ZZZZ of Part 63—Initial Compliance With Emission Limitations and Operating Limitations

As stated in §§63.6612, 63.6625 and 63.6630, you must initially comply with the emission and operating limitations as required by the following:

For each . . .	Complying with the requirement to . . .	You have demonstrated initial compliance if. . .
1. New or reconstructed non-emergency 2SLB stationary RICE >500 HP located at a major source of HAP, new or reconstructed non-emergency 4SLB stationary RICE ≥250 HP located at a major source of HAP, non-emergency stationary CI RICE >500 HP located at a major source of HAP, existing non-emergency stationary CI RICE >500 HP located at an area source of HAP, and existing non-emergency 4SLB stationary RICE >500 HP located at an area source of HAP that are operated more than 24 hours per calendar year	a. Reduce CO emissions and using oxidation catalyst, and using a CPMS	i. The average reduction of emissions of CO determined from the initial performance test achieves the required CO percent reduction; and ii. You have installed a CPMS to continuously monitor catalyst inlet temperature according to the requirements in §63.6625(b); and iii. You have recorded the catalyst pressure drop and catalyst inlet temperature during the initial performance test.
2. Non-emergency stationary CI RICE >500 HP located at a major source of HAP, existing non-emergency stationary CI RICE >500 HP located at an area source of HAP, and existing non-emergency 4SLB stationary RICE >500 HP located at an area source of HAP that are operated more than 24 hours per	a. Limit the concentration of CO, using oxidation catalyst, and using a CPMS	i. The average CO concentration determined from the initial performance test is less than or equal to the CO emission limitation; and ii. You have installed a CPMS to continuously monitor catalyst inlet

calendar year		temperature according to the requirements in §63.6625(b); and iii. You have recorded the catalyst pressure drop and catalyst inlet temperature during the initial performance test.
3. New or reconstructed non-emergency 2SLB stationary RICE >500 HP located at a major source of HAP, new or reconstructed non-emergency 4SLB stationary RICE ≥250 HP located at a major source of HAP, non-emergency stationary CI RICE >500 HP located at a major source of HAP, existing non-emergency stationary CI RICE >500 HP located at an area source of HAP, and existing non-emergency 4SLB stationary RICE >500 HP located at an area source of HAP that are operated more than 24 hours per calendar year	a. Reduce CO emissions and not using oxidation catalyst	i. The average reduction of emissions of CO determined from the initial performance test achieves the required CO percent reduction; and ii. You have installed a CPMS to continuously monitor operating parameters approved by the Administrator (if any) according to the requirements in §63.6625(b); and iii. You have recorded the approved operating parameters (if any) during the initial performance test.
4. Non-emergency stationary CI RICE >500 HP located at a major source of HAP, existing non-emergency stationary CI RICE >500 HP located at an area source of HAP, and existing non-emergency 4SLB stationary RICE >500 HP located at an area source of HAP that are operated more than 24 hours per calendar year	a. Limit the concentration of CO, and not using oxidation catalyst	i. The average CO concentration determined from the initial performance test is less than or equal to the CO emission limitation; and ii. You have installed a CPMS to continuously monitor operating parameters approved by the Administrator (if any) according to the requirements in §63.6625(b); and iii. You have recorded the approved operating parameters (if any) during the initial performance test.
5. New or reconstructed non-emergency 2SLB stationary RICE >500 HP located at a	a. Reduce CO emissions, and using a CEMS	i. You have installed a CEMS to continuously monitor CO and either

major source of HAP, new or reconstructed non-emergency 4SLB stationary RICE ≥250 HP located at a major source of HAP, non-emergency stationary CI RICE >500 HP located at a major source of HAP, existing non-emergency stationary CI RICE >500 HP located at an area source of HAP, and existing non-emergency 4SLB stationary RICE >500 HP located at an area source of HAP that are operated more than 24 hours per calendar year		O_2or CO_2at both the inlet and outlet of the oxidation catalyst according to the requirements in §63.6625(a); and ii. You have conducted a performance evaluation of your CEMS using PS 3 and 4A of 40 CFR part 60, appendix B; and iii. The average reduction of CO calculated using §63.6620 equals or exceeds the required percent reduction. The initial test comprises the first 4-hour period after successful validation of the CEMS. Compliance is based on the average percent reduction achieved during the 4-hour period.
6. Non-emergency stationary CI RICE >500 HP located at a major source of HAP, existing non-emergency stationary CI RICE >500 HP located at an area source of HAP, and existing non-emergency 4SLB stationary RICE >500 HP located at an area source of HAP that are operated more than 24 hours per calendar year	a. Limit the concentration of CO, and using a CEMS	i. You have installed a CEMS to continuously monitor CO and either O_2or CO_2at the outlet of the oxidation catalyst according to the requirements in §63.6625(a); and ii. You have conducted a performance evaluation of your CEMS using PS 3 and 4A of 40 CFR part 60, appendix B; and
		iii. The average concentration of CO calculated using §63.6620 is less than or equal to the CO emission limitation. The initial test comprises the first 4-hour period after successful validation of the CEMS. Compliance is based on the average concentration measured during the 4-hour period.

7. Non-emergency 4SRB stationary RICE >500 HP located at a major source of HAP, and existing non-emergency 4SRB stationary RICE >500 HP located at an area source of HAP that are operated more than 24 hours per calendar year	a. Reduce formaldehyde emissions and using NSCR	i. The average reduction of emissions of formaldehyde determined from the initial performance test is equal to or greater than the required formaldehyde percent reduction; and ii. You have installed a CPMS to continuously monitor catalyst inlet temperature according to the requirements in §63.6625(b); and
		iii. You have recorded the catalyst pressure drop and catalyst inlet temperature during the initial performance test.
8. Non-emergency 4SRB stationary RICE >500 HP located at a major source of HAP, and existing non-emergency 4SRB stationary RICE >500 HP located at an area source of HAP that are operated more than 24 hours per calendar year	a. Reduce formaldehyde emissions and not using NSCR	i. The average reduction of emissions of formaldehyde determined from the initial performance test is equal to or greater than the required formaldehyde percent reduction; and ii. You have installed a CPMS to continuously monitor operating parameters approved by the Administrator (if any) according to the requirements in §63.6625(b); and
		iii. You have recorded the approved operating parameters (if any) during the initial performance test.
9. Existing non-emergency 4SRB stationary RICE >500 HP located at an area source of HAP that are operated more than 24 hours per calendar year	a. Limit the concentration of formaldehyde and not using NSCR	i. The average formaldehyde concentration determined from the initial performance test is less than or equal to the formaldehyde emission limitation; and

		ii. You have installed a CPMS to continuously monitor operating parameters approved by the Administrator (if any) according to the requirements in §63.6625(b); and
		iii. You have recorded the approved operating parameters (if any) during the initial performance test.
10. New or reconstructed non-emergency stationary RICE >500 HP located at a major source of HAP, new or reconstructed non-emergency 4SLB stationary RICE 250≤HP≤500 located at a major source of HAP, and existing non-emergency 4SRB stationary RICE >500 HP	a. Limit the concentration of formaldehyde in the stationary RICE exhaust and using oxidation catalyst or NSCR	i. The average formaldehyde concentration, corrected to 15 percent O_2, dry basis, from the three test runs is less than or equal to the formaldehyde emission limitation; and ii. You have installed a CPMS to continuously monitor catalyst inlet temperature according to the requirements in §63.6625(b); and
		iii. You have recorded the catalyst pressure drop and catalyst inlet temperature during the initial performance test.
11. New or reconstructed non-emergency stationary RICE >500 HP located at a major source of HAP, new or reconstructed non-emergency 4SLB stationary RICE 250≤HP≤500 located at a major source of HAP, and existing non-emergency 4SRB stationary RICE >500 HP	a. Limit the concentration of formaldehyde in the stationary RICE exhaust and not using oxidation catalyst or NSCR	i. The average formaldehyde concentration, corrected to 15 percent O_2, dry basis, from the three test runs is less than or equal to the formaldehyde emission limitation; and ii. You have installed a CPMS to continuously monitor operating parameters approved by the Administrator (if any) according to the requirements in §63.6625(b); and
		iii. You have recorded the approved operating

		parameters (if any) during the initial performance test.
12. Existing non-emergency stationary RICE 100≤HP≤500 located at a major source of HAP, and existing non-emergency stationary CI RICE 300<HP≤500 located at an area source of HAP	a. Reduce CO or formaldehyde emissions	i. The average reduction of emissions of CO or formaldehyde, as applicable determined from the initial performance test is equal to or greater than the required CO or formaldehyde, as applicable, percent reduction.
13. Existing non-emergency stationary RICE 100≤HP≤500 located at a major source of HAP, and existing non-emergency stationary CI RICE 300<HP≤500 located at an area source of HAP	a. Limit the concentration of formaldehyde or CO in the stationary RICE exhaust	i. The average formaldehyde or CO concentration, as applicable, corrected to 15 percent O_2, dry basis, from the three test runs is less than or equal to the formaldehyde or CO emission limitation, as applicable.

[76 FR 12867, Mar. 9, 2011]

Table 6 to Subpart ZZZZ of Part 63—Continuous Compliance With Emission Limitations, Operating Limitations, Work Practices, and Management Practices

As stated in §63.6640, you must continuously comply with the emissions and operating limitations and work or management practices as required by the following:

For each . . .	Complying with the requirement to . . .	You must demonstrate continuous compliance by . . .
1. New or reconstructed non-emergency 2SLB stationary RICE >500 HP located at a major source of HAP, new or reconstructed non-emergency 4SLB stationary RICE ≥250 HP located at a major source of HAP, and new or reconstructed non-emergency CI stationary RICE >500 HP located at a major source of HAP	a. Reduce CO emissions and using an oxidation catalyst, and using a CPMS	i. Conducting semiannual performance tests for CO to demonstrate that the required CO percent reduction is achieved;[a] and ii. Collecting the catalyst inlet temperature data according to §63.6625(b); and iii. Reducing these data to 4-hour rolling

		averages; and iv. Maintaining the 4-hour rolling averages within the operating limitations for the catalyst inlet temperature; and
		v. Measuring the pressure drop across the catalyst once per month and demonstrating that the pressure drop across the catalyst is within the operating limitation established during the performance test.
2. New or reconstructed non-emergency 2SLB stationary RICE >500 HP located at a major source of HAP, new or reconstructed non-emergency 4SLB stationary RICE ≥250 HP located at a major source of HAP, and new or reconstructed non-emergency CI stationary RICE >500 HP located at a major source of HAP	a. Reduce CO emissions and not using an oxidation catalyst, and using a CPMS	i. Conducting semiannual performance tests for CO to demonstrate that the required CO percent reduction is achieved;[a]and ii. Collecting the approved operating parameter (if any) data according to §63.6625 (b); and iii. Reducing these data to 4-hour rolling averages; and
		iv. Maintaining the 4-hour rolling averages within the operating limitations for the operating parameters established during the performance test.
3. New or reconstructed non-emergency 2SLB stationary RICE >500 HP located at a major source of HAP, new or reconstructed non-emergency 4SLB stationary RICE ≥250 HP located at a major source of HAP, new or reconstructed non-emergency stationary CI RICE >500 HP located at a major source of HAP, existing non-emergency stationary CI RICE >500 HP,	a. Reduce CO emissions or limit the concentration of CO in the stationary RICE exhaust, and using a CEMS	i. Collecting the monitoring data according to §63.6625 (a), reducing the measurements to 1-hour averages, calculating the percent reduction or concentration of CO emissions according to §63.6620; and

existing non-emergency 4SLB stationary RICE >500 HP located at an area source of HAP that are operated more than 24 hours per calendar year		ii. Demonstrating that the catalyst achieves the required percent reduction of CO emissions over the 4-hour averaging period, or that the emission remain at or below the CO concentration limit; and iii. Conducting an annual RATA of your CEMS using PS 3 and 4A of 40 CFR part 60, appendix B, as well as daily and periodic data quality checks in accordance with 40 CFR part 60, appendix F, procedure 1.
4. Non-emergency 4SRB stationary RICE >500 HP located at a major source of HAP	a. Reduce formaldehyde emissions and using NSCR	i. Collecting the catalyst inlet temperature data according to §63.6625 (b); and
		ii. Reducing these data to 4-hour rolling averages; and
		iii. Maintaining the 4-hour rolling averages within the operating limitations for the catalyst inlet temperature; and
		iv. Measuring the pressure drop across the catalyst once per month and demonstrating that the pressure drop across the catalyst is within the operating limitation established during the performance test.
5. Non-emergency 4SRB stationary RICE >500 HP located at a major source of HAP	a. Reduce formaldehyde emissions and not using NSCR	i. Collecting the approved operating parameter (if any) data according to §63.6625 (b); and ii. Reducing these data

		to 4-hour rolling averages; and
		iii. Maintaining the 4-hour rolling averages within the operating limitations for the operating parameters established during the performance test.
6. Non-emergency 4SRB stationary RICE with a brake HP ≥5,000 located at a major source of HAP	a. Reduce formaldehyde emissions	Conducting semiannual performance tests for formaldehyde to demonstrate that the required formaldehyde percent reduction is achieved.[a]
7. New or reconstructed non-emergency stationary RICE >500 HP located at a major source of HAP and new or reconstructed non-emergency 4SLB stationary RICE 250 ≤HP≤500 located at a major source of HAP	a. Limit the concentration of formaldehyde in the stationary RICE exhaust and using oxidation catalyst or NSCR	i. Conducting semiannual performance tests for formaldehyde to demonstrate that your emissions remain at or below the formaldehyde concentration limit;[a]and ii. Collecting the catalyst inlet temperature data according to §63.6625 (b); and
		iii. Reducing these data to 4-hour rolling averages; and
		iv. Maintaining the 4-hour rolling averages within the operating limitations for the catalyst inlet temperature; and
		v. Measuring the pressure drop across the catalyst once per month and demonstrating that the pressure drop across the catalyst is within the operating limitation established during the

		performance test.
8. New or reconstructed non-emergency stationary RICE >500 HP located at a major source of HAP and new or reconstructed non-emergency 4SLB stationary RICE 250 ≤HP≤500 located at a major source of HAP	a. Limit the concentration of formaldehyde in the stationary RICE exhaust and not using oxidation catalyst or NSCR	i. Conducting semiannual performance tests for formaldehyde to demonstrate that your emissions remain at or below the formaldehyde concentration limit;[a]and ii. Collecting the approved operating parameter (if any) data according to §63.6625 (b); and
		iii. Reducing these data to 4-hour rolling averages; and
		iv. Maintaining the 4-hour rolling averages within the operating limitations for the operating parameters established during the performance test.
9. Existing emergency and black start stationary RICE ≤500 HP located at a major source of HAP, existing non-emergency stationary RICE <100 HP located at a major source of HAP, existing emergency and black start stationary RICE located at an area source of HAP, existing non-emergency stationary CI RICE ≤300 HP located at an area source of HAP, existing non-emergency 2SLB stationary RICE located at an area source of HAP, existing non-emergency landfill or digester gas stationary SI RICE located at an area source of HAP, existing non-emergency 4SLB and 4SRB stationary RICE ≤500 HP located at an area source of HAP, existing non-emergency 4SLB and 4SRB stationary RICE >500 HP located at an area source of HAP that operate 24 hours or less per	a. Work or Management practices	i. Operating and maintaining the stationary RICE according to the manufacturer's emission-related operation and maintenance instructions; or ii. Develop and follow your own maintenance plan which must provide to the extent practicable for the maintenance and operation of the engine in a manner consistent with good air pollution control practice for minimizing emissions.

calendar year		
10. Existing stationary CI RICE >500 HP that are not limited use stationary RICE, and existing 4SLB and 4SRB stationary RICE >500 HP located at an area source of HAP that operate more than 24 hours per calendar year and are not limited use stationary RICE	a. Reduce CO or formaldehyde emissions, or limit the concentration of formaldehyde or CO in the stationary RICE exhaust, and using oxidation catalyst or NSCR	i. Conducting performance tests every 8,760 hours or 3 years, whichever comes first, for CO or formaldehyde, as appropriate, to demonstrate that the required CO or formaldehyde, as appropriate, percent reduction is achieved or that your emissions remain at or below the CO or formaldehyde concentration limit; and
		ii. Collecting the catalyst inlet temperature data according to §63.6625 (b); and
		iii. Reducing these data to 4-hour rolling averages; and
		iv. Maintaining the 4-hour rolling averages within the operating limitations for the catalyst inlet temperature; and
		v. Measuring the pressure drop across the catalyst once per month and demonstrating that the pressure drop across the catalyst is within the operating limitation established during the performance test.
11. Existing stationary CI RICE >500 HP that are not limited use stationary RICE, and existing 4SLB and 4SRB stationary RICE >500 HP located at an area source of HAP that operate more than 24 hours per calendar year and are not limited use stationary RICE	a. Reduce CO or formaldehyde emissions, or limit the concentration of formaldehyde or CO in the stationary RICE exhaust, and not	i. Conducting performance tests every 8,760 hours or 3 years, whichever comes first, for CO or formaldehyde, as appropriate, to demonstrate that the required CO or

	using oxidation catalyst or NSCR	formaldehyde, as appropriate, percent reduction is achieved or that your emissions remain at or below the CO or formaldehyde concentration limit; and
		ii. Collecting the approved operating parameter (if any) data according to §63.6625 (b); and
		iii. Reducing these data to 4-hour rolling averages; and
		iv. Maintaining the 4-hour rolling averages within the operating limitations for the operating parameters established during the performance test.
12. Existing limited use CI stationary RICE >500 HP and existing limited use 4SLB and 4SRB stationary RICE >500 HP located at an area source of HAP that operate more than 24 hours per calendar year	a. Reduce CO or formaldehyde emissions or limit the concentration of formaldehyde or CO in the stationary RICE exhaust, and using an oxidation catalyst or NSCR	i. Conducting performance tests every 8,760 hours or 5 years, whichever comes first, for CO or formaldehyde, as appropriate, to demonstrate that the required CO or formaldehyde, as appropriate, percent reduction is achieved or that your emissions remain at or below the CO or formaldehyde concentration limit; and
		ii. Collecting the catalyst inlet temperature data according to §63.6625 (b); and
		iii. Reducing these data to 4-hour rolling averages; and
		iv. Maintaining the 4-hour rolling averages within the operating limitations for the

		catalyst inlet temperature; and
		v. Measuring the pressure drop across the catalyst once per month and demonstrating that the pressure drop across the catalyst is within the operating limitation established during the performance test.
13. Existing limited use CI stationary RICE >500 HP and existing limited use 4SLB and 4SRB stationary RICE >500 HP located at an area source of HAP that operate more than 24 hours per calendar year	a. Reduce CO or formaldehyde emissions or limit the concentration of formaldehyde or CO in the stationary RICE exhaust, and not using an oxidation catalyst or NSCR	i. Conducting performance tests every 8,760 hours or 5 years, whichever comes first, for CO or formaldehyde, as appropriate, to demonstrate that the required CO or formaldehyde, as appropriate, percent reduction is achieved or that your emissions remain at or below the CO or formaldehyde concentration limit; and
		ii. Collecting the approved operating parameter (if any) data according to §63.6625 (b); and
		iii. Reducing these data to 4-hour rolling averages; and
		iv. Maintaining the 4-hour rolling averages within the operating limitations for the operating parameters established during the performance test.

[a]After you have demonstrated compliance for two consecutive tests, you may reduce the frequency of subsequent performance tests to annually. If the results of any subsequent annual performance test indicate the stationary RICE is not in compliance with the CO or formaldehyde emission limitation, or you deviate from any of your operating limitations, you must resume semiannual performance tests.

[76 FR 12870, Mar. 9, 2011]

Table 7 to Subpart ZZZZ of Part 63—Requirements for Reports

As stated in §63.6650, you must comply with the following requirements for reports:

For each ...	You must submit a ...	The report must contain ...	You must submit the report ...
1. Existing non-emergency, non-black start stationary RICE 100≤HP≤500 located at a major source of HAP; existing non-emergency, non-black start stationary CI RICE >500 HP located at a major source of HAP; existing non-emergency 4SRB stationary RICE >500 HP located at a major source of HAP; existing non-emergency, non-black start stationary CI RICE >300 HP located at an area source of HAP; existing non-emergency, non-black start 4SLB and 4SRB stationary RICE >500 HP located at an area source of HAP and operated more than 24 hours per calendar year; new or reconstructed non-emergency stationary RICE >500 HP located at a major source of HAP; and new or reconstructed non-emergency 4SLB stationary RICE 250≤HP≤500 located at a major source of HAP	Compliance report	a. If there are no deviations from any emission limitations or operating limitations that apply to you, a statement that there were no deviations from the emission limitations or operating limitations during the reporting period. If there were no periods during which the CMS, including CEMS and CPMS, was out-of-control, as specified in §63.8(c)(7), a statement that there were not periods during which the CMS was out-of-control during the reporting period; or b. If you had a deviation from any emission limitation or operating limitation during the reporting period, the information in §63.6650(d). If there were periods during which the CMS, including CEMS and CPMS, was out-of-control, as specified in §63.8(c)(7), the information in §63.6650(e); or c. If you had a malfunction during	i. Semiannually according to the requirements in §63.6650(b)(1)–(5) for engines that are not limited use stationary RICE subject to numerical emission limitations; and ii. Annually according to the requirements in §63.6650(b)(6)–(9) for engines that are limited use stationary RICE subject to numerical emission limitations. i. Semiannually according to the requirements in §63.6650(b). i. Semiannually according to the requirements in §63.6650(b).

		the reporting period, the information in §63.6650(c)(4)	
2. New or reconstructed non-emergency stationary RICE that combusts landfill gas or digester gas equivalent to 10 percent or more of the gross heat input on an annual basis	Report	a. The fuel flow rate of each fuel and the heating values that were used in your calculations, and you must demonstrate that the percentage of heat input provided by landfill gas or digester gas, is equivalent to 10 percent or more of the gross heat input on an annual basis; and	i. Annually, according to the requirements in §63.6650.
		b. The operating limits provided in your federally enforceable permit, and any deviations from these limits; and	i. See item 2.a.i.
		c. Any problems or errors suspected with the meters.	i. See item 2.a.i.

[75 FR 51603, Aug. 20, 2010]

Table 8 to Subpart ZZZZ of Part 63—Applicability of General Provisions to Subpart ZZZZ.

As stated in §63.6665, you must comply with the following applicable general provisions.

General provisions citation	Subject of citation	Applies to subpart	Explanation
§63.1	General applicability of the General Provisions	Yes.	
§63.2	Definitions	Yes	Additional terms defined in §63.6675.
§63.3	Units and abbreviations	Yes.	
§63.4	Prohibited activities and circumvention	Yes.	
§63.5	Construction and reconstruction	Yes.	
§63.6(a)	Applicability	Yes.	

§63.6(b)(1)–(4)	Compliance dates for new and reconstructed sources	Yes.	
§63.6(b)(5)	Notification	Yes.	
§63.6(b)(6)	[Reserved]		
§63.6(b)(7)	Compliance dates for new and reconstructed area sources that become major sources	Yes.	
§63.6(c)(1)–(2)	Compliance dates for existing sources	Yes.	
§63.6(c)(3)–(4)	[Reserved]		
§63.6(c)(5)	Compliance dates for existing area sources that become major sources	Yes.	
§63.6(d)	[Reserved]		
§63.6(e)	Operation and maintenance	No.	
§63.6(f)(1)	Applicability of standards	No.	
§63.6(f)(2)	Methods for determining compliance	Yes.	
§63.6(f)(3)	Finding of compliance	Yes.	
§63.6(g)(1)–(3)	Use of alternate standard	Yes.	
§63.6(h)	Opacity and visible emission standards	No	Subpart ZZZZ does not contain opacity or visible emission standards.
§63.6(i)	Compliance extension procedures and criteria	Yes.	
§63.6(j)	Presidential compliance exemption	Yes.	
§63.7(a)(1)–(2)	Performance test dates	Yes	Subpart ZZZZ contains performance test dates at §§63.6610, 63.6611, and 63.6612.
§63.7(a)(3)	CAA section 114 authority	Yes.	
§63.7(b)(1)	Notification of performance test	Yes	Except that §63.7(b)(1) only applies as specified in §63.6645.
§63.7(b)(2)	Notification of rescheduling	Yes	Except that §63.7(b)(2) only applies as specified in §63.6645.
§63.7(c)	Quality assurance/test plan	Yes	Except that §63.7(c) only applies as specified in §63.6645.

§63.7(d)	Testing facilities	Yes.	
§63.7(e)(1)	Conditions for conducting performance tests	No.	Subpart ZZZZ specifies conditions for conducting performance tests at §63.6620.
§63.7(e)(2)	Conduct of performance tests and reduction of data	Yes	Subpart ZZZZ specifies test methods at §63.6620.
§63.7(e)(3)	Test run duration	Yes.	
§63.7(e)(4)	Administrator may require other testing under section 114 of the CAA	Yes.	
§63.7(f)	Alternative test method provisions	Yes.	
§63.7(g)	Performance test data analysis, recordkeeping, and reporting	Yes.	
§63.7(h)	Waiver of tests	Yes.	
§63.8(a)(1)	Applicability of monitoring requirements	Yes	Subpart ZZZZ contains specific requirements for monitoring at §63.6625.
§63.8(a)(2)	Performance specifications	Yes.	
§63.8(a)(3)	[Reserved]		
§63.8(a)(4)	Monitoring for control devices	No.	
§63.8(b)(1)	Monitoring	Yes.	
§63.8(b)(2)–(3)	Multiple effluents and multiple monitoring systems	Yes.	
§63.8(c)(1)	Monitoring system operation and maintenance	Yes.	
§63.8(c)(1)(i)	Routine and predictable SSM	Yes.	
§63.8(c)(1)(ii)	SSM not in Startup Shutdown Malfunction Plan	Yes.	
§63.8(c)(1)(iii)	Compliance with operation and maintenance requirements	Yes.	
§63.8(c)(2)–(3)	Monitoring system installation	Yes.	
§63.8(c)(4)	Continuous monitoring system (CMS) requirements	Yes	Except that subpart ZZZZ does not require Continuous Opacity Monitoring

			System (COMS).
§63.8(c)(5)	COMS minimum procedures	No	Subpart ZZZZ does not require COMS.
§63.8(c)(6)–(8)	CMS requirements	Yes	Except that subpart ZZZZ does not require COMS.
§63.8(d)	CMS quality control	Yes.	
§63.8(e)	CMS performance evaluation	Yes	Except for §63.8(e)(5)(ii), which applies to COMS.
		Except that §63.8(e) only applies as specified in §63.6645.	
§63.8(f)(1)–(5)	Alternative monitoring method	Yes	Except that §63.8(f)(4) only applies as specified in §63.6645.
§63.8(f)(6)	Alternative to relative accuracy test	Yes	Except that §63.8(f)(6) only applies as specified in §63.6645.
§63.8(g)	Data reduction	Yes	Except that provisions for COMS are not applicable. Averaging periods for demonstrating compliance are specified at §§63.6635 and 63.6640.
§63.9(a)	Applicability and State delegation of notification requirements	Yes.	
§63.9(b)(1)–(5)	Initial notifications	Yes	Except that §63.9(b)(3) is reserved.
		Except that §63.9(b) only applies as specified in §63.6645.	
§63.9(c)	Request for compliance extension	Yes	Except that §63.9(c) only applies as specified in §63.6645.
§63.9(d)	Notification of special compliance requirements for new sources	Yes	Except that §63.9(d) only applies as specified in §63.6645.
§63.9(e)	Notification of performance test	Yes	Except that §63.9(e) only applies as

			specified in §63.6645.
§63.9(f)	Notification of visible emission (VE)/opacity test	No	Subpart ZZZZ does not contain opacity or VE standards.
§63.9(g)(1)	Notification of performance evaluation	Yes	Except that §63.9(g) only applies as specified in §63.6645.
§63.9(g)(2)	Notification of use of COMS data	No	Subpart ZZZZ does not contain opacity or VE standards.
§63.9(g)(3)	Notification that criterion for alternative to RATA is exceeded	Yes	If alternative is in use.
		Except that §63.9(g) only applies as specified in §63.6645.	
§63.9(h)(1)–(6)	Notification of compliance status	Yes	Except that notifications for sources using a CEMS are due 30 days after completion of performance evaluations. §63.9(h)(4) is reserved.
			Except that §63.9(h) only applies as specified in §63.6645.
§63.9(i)	Adjustment of submittal deadlines	Yes.	
§63.9(j)	Change in previous information	Yes.	
§63.10(a)	Administrative provisions for recordkeeping/reporting	Yes.	
§63.10(b)(1)	Record retention	Yes.	
§63.10(b)(2)(i)–(v)	Records related to SSM	No.	
§63.10(b)(2)(vi)–(xi)	Records	Yes.	
§63.10(b)(2)(xii)	Record when under waiver	Yes.	
§63.10(b)(2)(xiii)	Records when using alternative to RATA	Yes	For CO standard if using RATA alternative.
§63.10(b)(2)(xiv)	Records of supporting documentation	Yes.	
§63.10(b)(3)	Records of applicability	Yes.	

	determination		
§63.10(c)	Additional records for sources using CEMS	Yes	Except that §63.10(c) (2)–(4) and (9) are reserved.
§63.10(d)(1)	General reporting requirements	Yes.	
§63.10(d)(2)	Report of performance test results	Yes.	
§63.10(d)(3)	Reporting opacity or VE observations	No	Subpart ZZZZ does not contain opacity or VE standards.
§63.10(d)(4)	Progress reports	Yes.	
§63.10(d)(5)	Startup, shutdown, and malfunction reports	No.	
§63.10(e)(1) and (2)(i)	Additional CMS Reports	Yes.	
§63.10(e)(2)(ii)	COMS-related report	No	Subpart ZZZZ does not require COMS.
§63.10(e)(3)	Excess emission and parameter exceedances reports	Yes.	Except that §63.10(e)(3)(i) (C) is reserved.
§63.10(e)(4)	Reporting COMS data	No	Subpart ZZZZ does not require COMS.
§63.10(f)	Waiver for recordkeeping/reporting	Yes.	
§63.11	Flares	No.	
§63.12	State authority and delegations	Yes.	
§63.13	Addresses	Yes.	
§63.14	Incorporation by reference	Yes.	
§63.15	Availability of information	Yes.	

[75 FR 9688, Mar. 3, 2010]

Browse Next

For questions or comments regarding e-CFR editorial content, features, or design, email ecfr@nara.gov.

For questions concerning e-CFR programming and delivery issues, email webteam@gpo.gov.

Section 508 / Accessibility

		moisture content of the stationary internal combustion engine exhaust at the sampling port location; and	part 60, appendix A	moisture content must be made at the same time as the measurements for PM concentration.
		iv. Measure PM at the exhaust of the stationary internal combustion engine	(4) Method 5 of 40 CFR part 60, appendix A	(d) PM concentration must be at 15 percent O_2, dry basis. Results of this test consist of the average of the three 1-hour or longer runs.

Table 8 to Subpart IIII of Part 60—Applicability of General Provisions to Subpart IIII

[As stated in §60.4218, you must comply with the following applicable General Provisions:]

General Provisions citation	Subject of citation	Applies to subpart	Explanation
§60.1	General applicability of the General Provisions	Yes	
§60.2	Definitions	Yes	Additional terms defined in §60.4219.
§60.3	Units and abbreviations	Yes	
§60.4	Address	Yes	
§60.5	Determination of construction or modification	Yes	
§60.6	Review of plans	Yes	
§60.7	Notification and Recordkeeping	Yes	Except that §60.7 only applies as specified in §60.4214(a).
§60.8	Performance tests	Yes	Except that §60.8 only applies to stationary CI ICE with a displacement of (≥30 liters per cylinder and engines that are not certified.
§60.9	Availability of information	Yes	
§60.10	State Authority	Yes	

§60.11	Compliance with standards and maintenance requirements	No	Requirements are specified in subpart IIII.
§60.12	Circumvention	Yes	
§60.13	Monitoring requirements	Yes	Except that §60.13 only applies to stationary CI ICE with a displacement of (≥30 liters per cylinder.
§60.14	Modification	Yes	
§60.15	Reconstruction	Yes	
§60.16	Priority list	Yes	
§60.17	Incorporations by reference	Yes	
§60.18	General control device requirements	No	
§60.19	General notification and reporting requirements	Yes	

Browse Previous | Browse Next

For questions or comments regarding e-CFR editorial content, features, or design, email ecfr@nara.gov.

For questions concerning e-CFR programming and delivery issues, email webteam@gpo.gov.

Section 508 / Accessibility

CERTIFICATE OF SERVICE

I, Pam Owen, hereby certify that a copy of this permit has been mailed by first class mail to Georgia-Pacific LLC - Crossett Paper Operations, P.O. Box 3333, Crossett, AR, 71635-3333, on this 4th day of August, 2011.

Pam Owen

Pam Owen, AAII, Air Division