ADEQ OPERATING AIR PERMIT

Pursuant to the Regulations of the Arkansas Operating Air Permit Program, Regulation No. 26:

Permit No.: 868-AOP-R3

IS ISSUED TO:

Lion Oil Co. El Dorado, AR 71730 Union County AFIN: 70-00016

THIS PERMIT AUTHORIZES THE ABOVE REFERENCED PERMITTEE TO INSTALL, OPERATE, AND MAINTAIN THE EQUIPMENT AND EMISSION UNITS DESCRIBED IN THE PERMIT APPLICATION AND ON THE FOLLOWING PAGES. THIS PERMIT IS VALID BETWEEN:

And

IS SUBJECT TO ALL LIMITS AND CONDITIONS CONTAINED HEREIN.

Signed:

Mike Bates Chief, Air Division

Table of Contents	
SECTION I: FACILITY INFORMATION	8
SECTION II: INTRODUCTION	9
SUMMARY OF PERMIT ACTIVITY	9
PROCESS DESCRIPTION	
SECTION III: PERMIT HISTORY	43
SECTION IV: EMISSION UNIT INFORMATION	49
SN-803 - #4 Pre-flash Column Reboiler	
SN-804 - #4 Atmospheric Topping Furnace	
SN-805 - #4 Vacuum Furnace	
SN-806 - #6 Hydrotreater Furnace/Reboiler	
SN - 808-#7 FCCU FURNACE	
SN-810 - #9 Hydrotreater Furnace/Reboiler	
SN-811 - #9 Reformer Furnace	
SN-812 - #9 Stabilizer Reboiler	
SN-813a - #10 Hydrotreater Furnace/Reboiler	
SN-814 - #11 DEASPHALTING FURNACE	
SN-825 - #16 Asphalt Blowing Furnaces	
SN-828 - Asphalt Rack Steam Heater	
SN-830 - Regenerant Furnace	
SN-842 - #12 UNIT DISTILLATE HYDROTREATER	
SN-850 - Asphalt Hot Oil Heater	
SN-857 - NAPTHA SPLITTER REBOILER	49
SN-860 - ULSD Hydrotreater Heater	
SN-861 - Hydrogen Plant Heater	
SN-862 - HOT OIL HEATER	
SN-809 - #7 FCCU CATALYST REGENERATOR STACK	
SN-848 - #7 FCCU CATALYST HOPPER VENTS	
SN-844 - SRP SULFUR RECOVERY PLANT INCINERATOR	
SN-816 - #10 BOILER	
SN-817 - #11 BOILER	
SN-818 - #12 BOILER	
SN-819 - #13 BOILER	
SN-820 - #14 BOILER	
SN-821A, 821B, 821C - KEFINERY BOILERS (1HREE BOILERS)	
SN-822 - HIGH PRESSURE FLARE	
SN-823 - LOW PRESSURE FLARES	
SN-824 - FUME INCINERATOR.	
SN 822 47 AGRIANT TANK UDATEDS	
SN 824 NODTH KVC COMPRESSOR	
SIN-854 - NORTH KVC COMPRESSOR	
SN 826 PCTL COMPRESSOR	
SN 827 NODTH SSVG 440 HD COMPRESSOR	
S13-057 - 130K10 05 Y 0 440 NF CONFRESSOR SN-838 - Solith 10 SVG 550 hd Comddessod	
SN-839 – FAST IVG COMPRESSOR	
SN-840 – WEST IVG COMPRESSOR	01
SN-841 – G398TA AIR COMPRESSOR	
SN-846 - Gasol Inf/Diesei I oading Rack	
SN-847 - HEAVY OIL LOADING RACKS	۹۵ ۵۶
SN-849 - STANDRY DIESEL CRUDE PUMP	90

SIN-851 - WASTEWATER TREATMENT	99
SN-851A - WASTEWATER COLLECTION	99
SN-853 - Cooling Towers	103
SN-853A - #5 Cooling Tower	103
SN-859 – NO. 8 COOLING TOWER.	103
SN-858F – TIER 2 FUGITIVES AND TANKS VOC BUBBLE	104
SN-856 - FACILITY TANKS – PLANTWIDE APPLICABILITY LIMIT (PAL)	112
SN-858T – TIER 2 FUGITIVES AND TANKS VOC BUBBLE	112
SN-85 / – NAPTHA SPLITTER KEBOILER HEATER.	139
SN-800 ULSD HYDROTREATER HEATER.	139
SIN-803 - BOILER FEEDWATER PUMP	141
PLANTWIDE APPLICABILITY LIMIT (PAL) FOR OTHER AIR EMISSIONS	143
SECTION V: PLANT WIDE CONDITIONS	146
TITLE VI PROVISIONS	159
Permit Shield	160
CONSENT DECREE (CIV. No. 03-1028) REQUIREMENTS	164
Additional Requirements	169
SECTION VI: INSIGNIFICANT ACTIVITIES	170
SECTION VII: GENERAL PROVISIONS	172
APPENDIX A SUBPART KA – STANDARDS OF PERFORMANCE FOR STORAGE VESSELS FOR PETROLEUM LIQUIDS FOR WHICH CONSTRUCTION, RECONSTRUCTION, OR MODIFICATION COMMENCED AFTER MAY 18, 1978 AND PRIOR TO JULY 23, 1984	
APPENDIX A SUBPART KA – STANDARDS OF PERFORMANCE FOR STORAGE VESSELS FOR PETROLEUM LIQUIDS FOR WHICH CONSTRUCTION, RECONSTRUCTION, OR MODIFICATION COMMENCED AFTER MAY 18, 1978 AND PRIOR TO JULY 23, 1984 APPENDIX B SUBPART KB – STANDARDS OF PERFORMANCE FOR VOLATILE ORGANIC LIQUI STORAGE VESSELS (INCLUDING PETROLEUM LIQUID STORAGE VESSELS) FOR WHICH CONSTRUCTION, RECONSTRUCTION, OR MODIFICATION COMMENCED AFTER JULY 23, 1984	D
APPENDIX A SUBPART KA – STANDARDS OF PERFORMANCE FOR STORAGE VESSELS FOR PETROLEUM LIQUIDS FOR WHICH CONSTRUCTION, RECONSTRUCTION, OR MODIFICATION COMMENCED AFTER MAY 18, 1978 AND PRIOR TO JULY 23, 1984 APPENDIX B SUBPART KB – STANDARDS OF PERFORMANCE FOR VOLATILE ORGANIC LIQUI STORAGE VESSELS (INCLUDING PETROLEUM LIQUID STORAGE VESSELS) FOR WHICH CONSTRUCTION, RECONSTRUCTION, OR MODIFICATION COMMENCED AFTER JULY 23, 1984 APPENDIX C SUBPART J – STANDARDS OF PERFORMANCE FOR PETROLEUM REFINERIES	D
APPENDIX A SUBPART KA – STANDARDS OF PERFORMANCE FOR STORAGE VESSELS FOR PETROLEUM LIQUIDS FOR WHICH CONSTRUCTION, RECONSTRUCTION, OR MODIFICATION COMMENCED AFTER MAY 18, 1978 AND PRIOR TO JULY 23, 1984 APPENDIX B SUBPART KB – STANDARDS OF PERFORMANCE FOR VOLATILE ORGANIC LIQUI STORAGE VESSELS (INCLUDING PETROLEUM LIQUID STORAGE VESSELS) FOR WHICH CONSTRUCTION, RECONSTRUCTION, OR MODIFICATION COMMENCED AFTER JULY 23, 1984 APPENDIX C SUBPART J – STANDARDS OF PERFORMANCE FOR PETROLEUM REFINERIES APPENDIX D SUBPART DC – STANDARDS OF PERFORMANCE FOR SMALL INDUSTRIAL- COMMERCIAL-INSTITUTIONAL STEAM GENERATING UNITS	D
APPENDIX A SUBPART KA – STANDARDS OF PERFORMANCE FOR STORAGE VESSELS FOR PETROLEUM LIQUIDS FOR WHICH CONSTRUCTION, RECONSTRUCTION, OR MODIFICATION COMMENCED AFTER MAY 18, 1978 AND PRIOR TO JULY 23, 1984 APPENDIX B SUBPART KB – STANDARDS OF PERFORMANCE FOR VOLATILE ORGANIC LIQUI STORAGE VESSELS (INCLUDING PETROLEUM LIQUID STORAGE VESSELS) FOR WHICH CONSTRUCTION, RECONSTRUCTION, OR MODIFICATION COMMENCED AFTER JULY 23, 1984 APPENDIX C SUBPART J – STANDARDS OF PERFORMANCE FOR PETROLEUM REFINERIES APPENDIX D SUBPART DC – STANDARDS OF PERFORMANCE FOR SMALL INDUSTRIAL- COMMERCIAL-INSTITUTIONAL STEAM GENERATING UNITS APPENDIX E SUBPART FF – NATIONAL EMISSION STANDARDS FOR BENZENE OPERATIONS	D
APPENDIX A SUBPART KA – STANDARDS OF PERFORMANCE FOR STORAGE VESSELS FOR PETROLEUM LIQUIDS FOR WHICH CONSTRUCTION, RECONSTRUCTION, OR MODIFICATION COMMENCED AFTER MAY 18, 1978 AND PRIOR TO JULY 23, 1984 APPENDIX B SUBPART KB – STANDARDS OF PERFORMANCE FOR VOLATILE ORGANIC LIQUI STORAGE VESSELS (INCLUDING PETROLEUM LIQUID STORAGE VESSELS) FOR WHICH CONSTRUCTION, RECONSTRUCTION, OR MODIFICATION COMMENCED AFTER JULY 23, 1984 APPENDIX C SUBPART J – STANDARDS OF PERFORMANCE FOR PETROLEUM REFINERIES APPENDIX D SUBPART DC – STANDARDS OF PERFORMANCE FOR SMALL INDUSTRIAL- COMMERCIAL-INSTITUTIONAL STEAM GENERATING UNITS APPENDIX E SUBPART FF – NATIONAL EMISSION STANDARDS FOR BENZENE OPERATIONS APPENDIX F SUBPART GGG – STANDARDS OF PERFORMANCE FOR EQUIPMENT LEAKS OF V PETROLEUM REFINERIES	D OC IN

APPENDIX H SUBPART UUU – STANDARDS OF PERFORMANCE FOR ASPHALT PROCESSING AND ASPHALT ROOFING MANUFACTURE

APPENDIX I SUBPART CC - NATIONAL EMISSION STANDARDS FOR HAZARDOUS AIR POLLUTANTS FROM PETROLEUM REFINERIES

APPENDIX J SUBPART QQQ - STANDARDS OF PERFORMANCE FOR VOC EMISSIONS FROM PETROLEUM REFINERY WASTEWATER SYSTEMS

APPENDIX K ARKANSAS DEPARTMENT OF ENVIRONMENTAL QUALITY CONTINUOUS EMISSION MONITORING SYSTEMS CONDITIONS

APPENDIX L SOURCE NUMBER COMPARISON

APPENDIX M SUBPART UUU - NATIONAL EMISSION STANDARDS FOR HAZARDOUS AIR POLLUTANTS FROM PETROLEUM REFINERIES: CATALYTIC CRACKING UNITS, CATALYTIC REFORMING UNITS, AND SULFUR RECOVERY UNITS

APPENDIX N SUBPART DDDDD - NATIONAL EMISSION STANDARDS FOR HAZARDOUS AIR POLLUTANTS FOR INDUSTRIAL, COMMERCIAL, AND INSTITUTIONAL BOILERS AND PROCESS HEATERS

APPENDIX O SUBPART DB – STANDARDS OF PERFORMANCE FOR INDUSTRIAL-COMMERCIAL-INSTITUTIONAL STEAM GENERATING UNITS

TABLE OF TABLES

Table 1 - List of Acronyms	7
Table 2- Boiler Replacement Project – PM ₁₀ Emission Changes	10
Table 3 - Boiler Replacement Project – SO2 Emission Changes	11
Table 4- Boiler Replacement Project – VOC Emission Changes	12
Table 5 - Boiler Replacement Project – CO Emission Changes	12
Table 6 - Boiler Replacement Project – NOx Emission Changes	13
Table 7 - PSD Review History Summary:	21
Table 8 - Sources Installed After the Effective Date of PSD	27
Table 9 – Applicable Regulations	33
Table 10 – Emission Summary	35
Table 11 – Subpart J Units Criteria Emissions	51
Table 12 Subpart J Units Annual BTU Limits	54
Table 13 - #7 FCCU Catalyst Regenerator Stack Criteria Emissions	58
Table 14 - #7 FCCU Catalyst Hopper Vents Criteria Emissions	63
Table 15 - SRP Sulfur Recovery Plant Incinerator Criteria Emissions	65
Table 16 - SRP Sulfur Recovery Plant Incinerator SO2 Concentration	65
Table 17 – Old Boilers Criteria Emissions	67
Table 18 – Old Boilers Annual BTU	68
Table 19 - Refinery Boilers Criteria Emissions	70
Table 20 – Flares Criteria Pollutant Emissions	82
Table 21 - Fume Incinerator Criteria Emission Rate	84
Table 22 - #9 Continuous Catalyst Regenerator Criteria Pollutant Emissions	88
Table 23 - Asphalt Tank Heaters	89
Table 24 - Asphalt Tank Heaters Criteria Emissions	90

Table 25 - Compressors	91
Table 26 – Compressors Criteria Emissions	92
Table 27 - Gasoline/Diesel Loading Rack VOC Emissions	95
Table 28 - Heavy Oil Loading Racks	96
Table 29 - Heavy Oil Loading Racks VOC Emissions	96
Table 30 - Standby Diesel Crude Pump Criteria Emissions	98
Table 31 – Old Wastewater Voc Emissions	99
Table 32 – New Wastewater Voc Emissions	100
Table 33 - Cooling Towers Criteria Emissions	103
Table 34 – Fugitive VOC Emissions	104
Table 35 – Tank Type Key	112
Table 36 – Tank Description	112
Table 37 – Tank Criteria Emissions	123
Table 38 – Tank Vapor Pressure	124
Table 39 – Interim Criteria Emissions for Tier 2 Heaters	139
Table 40 - Boiler Feedwater Pump Criteria Emissions	141
Table 41 - Plantwide Applicability Limit (PAL) for Other Air Emissions	143
Table 42 - Overlap with Existing Federal Regulations - Storage Vessels	149
Table 43 - Overlap with Existing Federal Regulations - Wastewater	149
Table 44 – Fuel Gas Sulfur Limits	154
Table 45 - Permit Shield Applicable Regulations	160
Table 46 - Permit Shield Inapplicable Regulations	162
Table 47- Insignificant Activities	170

Table 1 - List of Acronyms

A.C.A.	Arkansas Code Annotated
CFR	Code of Federal Regulations
СО	Carbon Monoxide
CSN	County Serial Number
HAP	Hazardous Air Pollutant
lb/hr	Pound per hour
MVAC	Motor Vehicle Air Conditioner
No.	Number
NO _x	Nitrogen Oxide
PM	Particulate matter
PM ₁₀	Particulate matter smaller than ten microns
SNAP	Significant New Alternatives Program (SNAP)
SO_2	Sulfur dioxide
SSM	Startup, Shutdown, and Malfunction Plan
Тру	Ton per year
UTM	Universal Transverse Mercator
VOC	Volatile Organic Compound

Section I: FACILITY INFORMATION

PERMITTEE:	Lion Oil Co.
AFIN:	70-00016
PERMIT NUMBER:	868-AOP-R3
FACILITY ADDRESS:	1000 McHenry Avenue
	El Dorado, AR 71730
MAILING ADDRESS	1000 McHenry Avenue
	El Dorado, AR 71730
COUNTY:	Union
CONTACT POSITION:	Mr. Chuck Hammock, Environmental Manager
TELEPHONE NUMBER:	(870) 864-1289
REVIEWING ENGINEER:	Bryan Leamons
UTM Zone	15
UTM North - South (Y):	3655.1
UTM East - West (X):	531.0

Section II: INTRODUCTION

Summary of Permit Activity

Lion Oil Co. owns and operates a petroleum refinery located in El Dorado, Union County, Arkansas. This permit action serves to complete the renewal requirement of Regulation 26 and 40 CFR Part 70. As with all initial renewals, 40 CFR Part 64, *Compliance Assurance Monitoring* (CAM) is addressed. There are no CAM affected units at this facility; see the renewal application, Section 5 for a full analysis of potential CAM affected units.

This action also incorporates several modifications and minor modifications to the Title V Operating Air Permit for this facility. These modifications include the following changes.

- a. The replacement of the five existing refinery boilers (SN-816 through SN-820) with three new boilers (SN-821a, b, c);
- b. The incorporation of the requirements of 40 CFR Pat 60, Subparts Db and J and 40 CFR Part 63, Subpart DDDDD as they apply to the new boilers;
- c. The incorporation of the requirements of 40 CFR Part 63, Subpart UUU as they apply to the Fluid Catalytic Cracking Unit (FCCU) and the Sulfur Recovery Unit (SRU), and the Catalytic Cracking Unit (CCR).
- d. The removal of SN-843, the #12 Stripper Reboiler Heater;
- e. The installation of drift eliminators in the #5 Cooling Tower (SN-853a);
- f. The installation of a new 150,000 bbl asphalt storage tank (T-112) to be incorporated into the existing tank plantwide applicability limit (SN-856). This tank will be heated by a hot oil heater system (SN-862). This heater will be added to the existing tank heater bubble (SN-832);
- g. The replacement of the #10 Furnace/Reboiler (40 MMBtu/hr, SN-813) with a new process heater (17.9 MMBtu/hr, to be designated as SN-813a);
- h. An increase in the allowable cooling water flow rate through the #8 Cooling Tower (SN-859). There is no increase in the permitted emissions from the cooling tower with this change because past emissions were significantly over-estimated for this source.
- i. The replacement of 3,341 bbl asphalt storage tank with a new tank of equal dimensions. Emissions are not affected; 40 CFR Part 60, Subpart UU is triggered for the new tank; and,
- j. Increased annual emissions and annual heat input capacity permitted at the #9 Reformer Furnace (SN-811). Installation of a new Hydrogen Plant Heater (SN-861). These changes are an extension of the previously permitted and approved Tier II Fuels Project. The total project still meets minor modification applicability.

The primary change associated with this modification is the boiler replacement project. This project is required under the terms of the Consent Decree (CIV. No. 03-1028) reached by Lion Oil, ADEQ, and the US EPA. Under the terms of this agreement the new boilers must be in operation by January 1, 2007, and the five old boilers must be permanently shutdown prior to this date. The old boilers remain permitted for operation until December 31, 2006.

Other changes result from the renewal application. Various emission rates have been re-evaluated using updated emission factors for renewal purposes. Most changes are trivial, however; changes to the tanks PAL (SN-856) and fugitive PAL (SN-854) cause for a decrease in VOC emissions by several thousand tons per year. As a result of all the modifications and renewal updates, facility-wide permitted emission limitations have changed as follows: PM 0 tpy; PM_{10} -295.6 tpy; SO₂ 1.6 tpy; VOC -5,138.7 tpy; CO 61.9 tpy; NO_x -7.7 tpy.

The boiler replacement project was reviewed in order to determine if the associated emission increases exceeded the definition of a "significant net increase" as defined by the Federal Prevention of Significant Deterioration (PSD) regulations. In order to make this determination all creditable emission changes at the facility over the 5-year contemporaneous period were considered. This analysis demonstrated that there was no significant net emission increase for any regulated air pollutant. A brief summary of the contemporaneous emission changes for each pollutant is provided below.

Source Description	Emissions Change (tpy)	Notes
New Refinery Boilers	31.1	
Boiler Feedwater Pumps	0.1	
Tier 2 Project Change	14.1	See Update Tier 2 Calcs.
Shutdown Old Boilers	-7.3	Removed from Service
New Tank Heater	0.1	Installed 2001
(0.68 MMBtu/hr)		
New 150,000 bbl Asphalt Tank w/Heater	1.3	T-112
New No. 10 Unit Heater	2.0	
Removal of Old No. 10 Unit Heater	-1.4	Avg. of 2001/2002 actual emissions
JVG Compressors	-0.2	Converted to Electrical Power

Table 2- Doner Replacement Froject – Fivin Emission Changes	Table 2- Boiler Re	placement Project	- PM ₁₀ Emission	1 Changes
---	--------------------	-------------------	-----------------------------	-----------

Source Description	Emissions Change (tpy)	Notes
#12 Stripper Reboiler Heater Shutdown	-0.9	
Drift Eliminators in Cooling Tower #5	-26.3	
Total	12.5	Net Emissions Increase

Table 3 - Boiler Replacement Project – SO₂ Emission Changes

Source Description	Emissions Change (tpy)	Notes
New Refinery Boilers	81.3	
Boiler Feedwater Pumps	0.1	
Tier 2 Project Change	23.7	See Update Tier 2 Calcs.
Shutdown Old Boilers	-1.6	Removed from Service
Flare Gas Recovery System	-252.2 ¹	
New Tank Heater	0.2	Installed 2001
(0.68 MMBtu/hr)		
New 150,000 bbl Asphalt Tank w/Heater	5.3	T-112
Removal of Old No. 10 Unit Heater	-0.8	Avg. of 2001/2002 actual emissions
New No. 10 Unit Heater	3.0	
#12 Stripper Reboiler Heater Shutdown	-0.5	Removed from service
Total	-141.5	Net Emissions Decrease

¹ The creditable emission reduction from the installation of the flare gas recovery system is limited to the previously permitted emission limit of 271.8 tpy from the refinery flare system minus the current (post flare gas recovery system) limit of 19.6 tpy. Past actual emissions from the flare system exceeded the then-allowable emission level of 271.8 tpy, but these excess emissions are not creditable for the purposes of this netting analysis.

	- •	-
Source Description	Emissions Change (tpy)	Notes
New Refinery Boilers	39.1	
Boiler Feedwater Pumps	0.2	
Total	39.3	No Netting Required

Table 4- Boiler Replacement Project – VOC Emission Changes

Table 5 - Boiler Replacement Project – CO Emission Changes

Source Description	Emissions Change (tpy)	Notes
New Refinery Boilers	123.2	
Boiler Feedwater Pumps	0.5	
Tier 2 Project Change	59.3	See Update Tier 2 Calcs.
Shutdown Old Boilers	-80.5	Removed from Service Avg. of 2002/2003 actual emissions
New Tank Heater (0.68 MMBtu/hr)	0.4	Installed 2001
New 150,000 bbl Asphalt Tank w/Heater	14.2	T-112
Removal of Old No. 10 Unit Heater	-11.6	Avg. of 2002/2003 actual emissions
New No. 10 Unit Heater	7.2	
JVG Compressors	-7.0 ¹	Converted to Electrical Power
#12 Stripper Reboiler Heater Shutdown	-7.0	Removed from service Avg. of 2002/2003 actual emissions
Total	98.7	Net Emissions Increase

¹ The creditable emission reduction from the conversion of the JVG Compressors is limited to the most recently permitted emission level of 7.0 tpy. This level is lower than the average past emissions from these units.

Source Description	Emissions Change (tpy)	Notes
New Refinery Boilers	58.0	
Boiler Feedwater Pumps	5.7	
Tier 2 Project Change	35.6	See Update Tier 2 Calcs.
Shutdown Old Boilers	-58.6 ¹	Removed from Service
CD-allowed NO _x decrease for Tier 2 Project	-10.0 ¹	Consent Decree (CIV. No. 03-1028)
New Tank Heater (0.68 MMBtu/hr)	0.5	Installed 2001
New 150,000 bbl Asphalt Tank w/Heaters	11.0	T-112
JVG Compressors	-4.6 ²	Converted to Electrical Power
#12 Stripper Reboiler Heater Shutdown	-6.1	
Total	31.5	Net Emissions Increase

Table 6 - Boiler Replacement Project – NOx Emission Changes

¹Per an agreement between Lion Oil, ADEQ, and the US EPA, the creditable NOx emissions decrease from the shutdown of the old boilers is based on an emission rate of 0.06 lb/MMBtu rather than the actual emission rate of approximately 0.24 lb/MMBtu. Creditable decrease for Tier 2 Project is 10.0 tpy per Consent Decree (CIV. No. 03-1028).

 2 The creditable emission reduction from the conversion of the JVG Compressors is limited to the most recently permitted emission level of 4.6 tpy. This level is lower than the average past emissions from these units.

Process Description

#1 Crude Unit:

This unit, which included the #1 Crude Topping Furnace (SN-801) and the #1 Crude Vacuum Furnace (SN-802) was removed from service.

#4 Crude Unit:

This unit is designed to separate approximately 65,000 BPD of light straight run gasoline and crude oil into various components of naphtha, gasoline, kerosene, diesel, gas oils and asphalt. Crude entering the

unit is preheated using heat exchangers and hot rundown streams from the unit and flashed in the Preflash Column to produce gasoline and naphtha. The Pre-flash Column Reboiler (SN-803) is a NSPS Subpart J quality gas fired furnace used to maintain the temperature in the column. Bottoms from the column are heated in the fuel gas fired Atmospheric Topping Furnace (SN-804) prior to distillation at atmospheric pressure. The Atmospheric Column further separates the crude into naphtha, kerosene, diesel, and gas oil. Bottoms from the column are heated in the fuel gas fired Vacuum Furnace (SN-805) prior to vacuum distillation. The Vacuum Column separates the bottoms into gas oil and asphalt products.

#7 Fluid Catalytic Cracking Unit:

This unit is designed to convert approximately 20,000 BPD of gas oil from the refinery crude units and other sources into more useful products. Gas oil entering the unit is first heated to 675° F in the #7 FCCU Furnace (SN-808) which is fired with NSPS Subpart J quality gas and equipped with low NO_X burners. The hot oil is then contacted with a hot (approximately 1350°F) fluidized catalyst which causes the gas oil to crack into lighter products. The catalyst is then separated from the products in the Reactor and returned to the Regenerator. In the Regenerator, coke which has deposited on the catalyst is burned off and the catalyst is recycled. The hot flue gas leaving the Regenerator passes through two (2) sets of cyclones to remove any catalyst fines and is then used to produce steam in the waste heat boiler. The hot gases are then cooled to less than 500°F before exiting the #7 Catalyst Regenerator Stack (SN-809). The light products produced in the reactor are separated in the Fractionator Tower and used for various purposes. The FCCU Catalyst Regenerator Stack (SN-809) is equipped with a wet gas scrubber (WGS) for the control of SO₂ and PM₁₀ emissions.

#8 ULSD Hydrotreater:

The new #8 unit is designed to process diesel, kerosene, gas oil, or light cycle oil. This unit makes ultra low sulfur diesel quality fuel from diesel feedstock by reducing the sulfur content to 15 ppm as mandated by the Tier II diesel sulfur regulations. Light cycle oil, diesel, kerosene, or gas oil is heated in the new Tier II heater (SN-860) and then reacted with hydrogen in the reactor. Bottoms from the reactor flow through a high and low pressure product separator where the unreacted hydrogen is separated from the product and recycled to the reactor. The high pressure hydrogen gas stream is passed through an amine absorber to remove hydrogen sulfide gases from the system for sulfur removal in the sulfur recovery plant and/or NaHS unit. The liquid from the low pressure separator is passed through a stripper to remove any residual hydrogen sulfide before the desulfurized product is sent to storage.

<u>#9 Unit:</u>

This unit is designed to process approximately 16,000 BPD of naphtha from the crude unit and upgrade it into higher octane products. The process is divided into the Unifiner and Platformer sections.

In the Unifiner section, naphtha is heated in the #9 Hydrotreater Furnace/Reboiler (SN-810) and reacted with hydrogen over a cobalt/molybdenum catalyst to convert the sulfur in the naphtha stream to hydrogen sulfide. The Reactor effluent is passed through the Separator and Stripper to remove the hydrogen and hydrogen sulfide. The Stripper bottoms are sent to the Platformer section for further processing.

In the Platformer section, the Stripper bottoms are heated in the #9 Reformer Furnace (SN-811) and passed over a platinum/iridium catalyst in the Reactor where the naphtha molecules are restructured to form high octane compounds. The Reactor effluent is sent to two (2) Separators where hydrogen is separated from the platformate and recycled. The platformate is then sent to the Stabilizer, heated by the #9 Stabilizer Reboiler (SN-812), where the low molecular weight gases are removed and sent to the Reformer fuel gas system. The bottoms from the Stabilizer are sent to gasoline storage.

The Continuous Catalyst Regeneration (CCR) section of the Platformer allows the unit to increase its yield of high octane product due to increased activity from the catalyst. During a normal operating cycle, platforming catalyst deactivates due to coke laydown. The CCR is a continuous regeneration process that allows the coked catalyst to be continuously regenerated, therefore decreasing downtime required to maintain efficient operation. The #9 Continuous Catalyst Regenerator (SN-831) continuously burns off the coke deposit and restores catalyst activity, selectivity, and stability to essentially fresh catalyst levels.

As a result of the catalytic reforming process, high carbon content coke is deposited on the catalyst. This catalyst is then pneumatically conveyed from the reactor section to the regeneration section of the unit. Coke content on the spent catalyst is typically 4-5%, but at times may be as high as 12%. The catalyst is regenerated with a recirculated gas stream that is typically controlled between 0.9% and 1.1% oxygen. The coke on the catalyst is oxidized and the regenerated catalyst leaves the regeneration zone at less than 0.2% coke. The catalyst then passes to subsequent zones in the regenerator to further condition the catalyst for use in the reactors. This gas leaving the regenerator is approximately 0.35% oxygen. Stoichiometrically, this equates to using approximately 50% excess oxygen in the regeneration process.

#10 Diesel Desulfurization Unit:

Upon completion of the Tier II Clean Fuels Project at the El Dorado Refinery, Lion Oil will utilize the #10 to desulfurize FCC gasoline. This unit will use a heavy cut of FCC gasoline as feed and will remove sulfur to levels that will yield overall concentrations of sulfur in Lion Oil's gasoline pool to 30 ppm to meet the Tier II Gasoline sulfur regulations. Heavy FCC gasoline is heated in the #10 hydrotreater furnace/reboiler (SN-813a) and then reacted with hydrogen in the reactor. Bottoms from the reactor flow to the product separator where the unreacted hydrogen is separated from the product and recycled to the reactor. The product then flows to a flash drum where most of the hydrogen sulfide that was formed in the reactor is flashed off and sent to the #17 and #18 units for treatment. The liquid from the flash drum is passed through a stripper to remove any residual hydrogen sulfide before the desulfurized product is sent to storage.

#11 Deasphaltizing Unit:

Asphalt produced directly from the #4 Crude Unit is processed through this unit to separate light hydrocarbons from the asphalt to yield a product suitable for catalytic cracking and at the same time, produce an asphalt with desirable properties. The #11 Unit is designed to process approximately 7,000 BPD of asphalt. Flux from the Crude Units is pumped into the top of the Extraction Tower and a propane/butane solvent is pumped into the bottom of the Extraction Tower. The two materials flow countercurrent to each other in the Extraction Tower. The solvent and deasphalted oil are then sent through a series of Evaporators and a Stripper where the solvent is distilled and condensed for recycle to the Extraction Tower. The deasphalted oil is used as feed to the Catalytic Cracker. Asphalt from the

bottom of the Extraction Tower is heated in the #11 Deasphaltating Furnace (SN-814) and is passed through the Flash Tower and Asphalt Stripper to remove any residual solvent. The asphalt product is then sent to the Asphalt Plant where it is blended with other products.

Asphalt Plant Blowing Stills:

The asphalt plant stores, blends, and loads various grades of asphalt, primarily for roofing and paving uses. In addition, the plant has three (3) "blowing stills" where air is blown through asphalt to give it properties which are beneficial for producing specialty asphalts and roofing asphalts. Associated with these stills are three (3) NSPS Subpart J quality gas fired #16 Asphalt Blowing Furnaces (SN-825) which are used to maintain required temperatures during the blowing operation. The flue gas from the blowing stills is mostly air, mixed with some hydrocarbons. The flue gas is passed through a water scrubber to remove any globules of asphalt. Flue gas from the Scrubber enters the Fume Incinerator (SN-824) and any remaining hydrocarbons are destroyed. The hot flue gases from the Fume Incinerator are used to generate steam before being discharged to atmosphere.

<u>#12 Distillate Hydrotreater:</u>

This unit is a diesel and gas oil desulfurization unit with a design capacity to process 24,000 BPD. Its purpose is to produce on-road diesel quality fuel to meet the Clean Air Act standards. The light cycle oil from the #7 FCCU and the kerosene and diesel from the #4 Crude Unit is processed to reduce the sulfur content from approximately 2.0 weight percent to less than 0.05 weight percent. The unit is also used to hydrotreat gas oils to remove sulfur from the feed to the #7 FCCU.

The mixed feed flows through the heat exchange train and the #12 Distillate Hydrotreater Furnace (SN-842) before being reacted with hydrogen in the Reactor. The Reactor effluent flows through the heat exchange train with final cooling by an air fin cooler before flowing into the High Pressure Separator where the unreacted hydrogen is separated from the product and recycled to the Reactor. A small portion of the unreacted hydrogen stream is vented to the sour fuel gas system for treatment in the #17 Sulfur Recovery Unit and the #18 Sodium Hydrosulfide Unit.

The liquid product is then flowed to the Low Pressure Separator where some of the hydrogen sulfide which was formed in the Reactor is flashed off and sent to the #17 Sulfur Recovery Unit and the #18 Sodium Hydrosulfide Unit for treatment. The liquid from the Low Pressure Separator then flows through heat exchangers to the Stripper to remove any residual hydrogen sulfide. The liquid from the bottom of the Stripper is then cooled in the heat exchangers and the product air fin cooler before being sent to storage. The Stripper off gas is cooled in an air fin cooler and compressed before being mixed with the High Pressure Separator vent stream and the off gas from the Low Pressure Separator. This combined off gas stream is sent to the #17 Sulfur Recovery Unit and the #18 Sodium Hydrosulfide Unit for treatment. The makeup hydrogen to the unit is supplied from two (2) compressors which also compress the recycled hydrogen and the Stripper off gas. These compressors are driven by electric motors. All emergency releases are routed to the existing refinery flare system.

Boilers:

Lion Oil has six (6) fuel gas fired boilers which produce steam for the refinery. Boilers #9 (currently out of service), #10, and #11 (SN-816, SN-817) are low pressure boilers each of which produce 60,000 pounds per hour of 150 psig steam. Boilers #12, #13, and #14 (SN-818, SN-819, and SN-820) are high

pressure boilers each of which produce 100,000 pounds per hour of 275 psig steam. All of the boilers are normally fired with refinery fuel gas. However, in the event that fuel gas is unavailable, the boilers can be fired with fuel oil. Each of the existing boilers must be shut down by December 31, 2006. These existing boilers will be replaced by the new boilers permitted with this modification.

Lion is constructing three new boilers (SN-821a, SN-821b, SN-821c) to replace the existing boilers. The combined heat rating for the three new boilers will be 605 MMBtu/hr. These boilers will be fired with NSPS Subpart J quality gas. The boilers may burn fuel oil if fuel gas and natural gas are unavailable.

Sour Water Stripper:

The refinery generates numerous water streams from storage tanks and accumulators that contain high concentrations of hydrogen sulfide and ammonia. The Sour Water Stripper (SWS) is a trayed column which is used to steam strip the hydrogen sulfide and ammonia from the sour water streams before the water is discharged into the refinery waste water treatment system. The sour gases that are stripped from the water are directed to a Claus combustor/thermal reactor to recover sulfur in the form of hydrogen sulfide from sour water stripper offgas.

#18 Sodium Hydrosulfide Unit:

Several processes in the refinery produce gases which cannot be reprocessed and sold as liquid propane gas (LPG) or gasoline. These gases are generally methane, ethane, and hydrogen produced from catalytic cracking and the reforming of petroleum fractions. As these light fractions are separated from other heavier gases, hydrogen sulfide is separated with the light gases, making the gas sour. In order to use this gas as fuel for refinery furnaces and boilers, the hydrogen sulfide must be removed to prevent excess SO₂ emissions as the fuel is burned.

The #18 Sodium Hydrosulfide Unit is used to remove the hydrogen sulfide from the fuel gas. The unit removes hydrogen sulfide by contacting the gas with caustic soda to form sodium hydrosulfide which is sold to paper mills to be used as a delignifying agent. The fuel gas leaving the unit then flows to the #17 Unit where it is contacted with amine. This unit removes hydrogen sulfide to below the levels of 40 C.F.R. 60, Subpart J. The fuel gas is used as fuel in refinery furnaces and boilers. Any SO₂ emissions to the atmosphere are accounted for in the individual emissions for the boilers and furnaces and the Sodium Hydrosulfide Unit is not itself an emission source.

#17 Sulfur Recovery Plant:

The purpose of the Sulfur Recovery Plant is to recover sulfur, up to 100 LTD (long tons per day), as hydrogen sulfide from fuel gas and off-site natural gases from Great Lakes Chemical to meet refinery New Source Performance Standards (NSPS - Subpart J) for process fuel gases (less than 0.1 grains H_2S). In addition, Sour Water Stripper (SWS) off gas can be treated in the Sulfur Recovery Plant. The hydrogen sulfide is converted to a salable elemental sulfur product. The Sulfur Recovery Plant is also used to convert ammonia from SWS off gas to diatomic nitrogen and water. The Sulfur Recovery Plant can be divided into three (3) process units:

a. Amine Unit consisting of two (2) amine contactors

- b. Sulfur Recovery Unit (SRU) (Claus)
- c. Tail Gas Treating Unit (TGTU)

Sour gas enters the primary amine unit where it is contacted with amine. The amine removes hydrogen sulfide and some carbon dioxide from the sour fuel gas stream. The sweetened gas exits the primary amine unit for distribution throughout the refinery. Hydrogen sulfide and carbon dioxide are stripped from the amine which creates a hydrogen sulfide rich gas (acid gas) stream. The acid gas is then sent to the SRU.

Acid gas from the primary amine unit and recirculated gas from the TGTU, along with SWS off gas, enter the SRU and go directly to the Claus Combustor/Thermal reactor. This is where approximately one-third of the hydrogen sulfide is converted to sulfur dioxide. Ammonia in the SWS off gas is converted to diatomic nitrogen and water at the Claus reactor. The hot vapor products leaving the thermal reactor make several passes through the sulfur condenser and the catalytic reactors. The sulfur condenser separates the condensed sulfur from the vapor and removes it to storage. The catalytic reactors further promote the reaction of hydrogen sulfide and sulfur dioxide to sulfur and water vapor. The remaining gas exits the SRU to the TGTU. The purpose of the TGTU is to recover sulfur from the SRU tail gas. The sulfur compounds are hydrogenated to hydrogen sulfide in the TGTU reactor. The vapor products from the reactor are then cooled and directed to the TGTU amine unit which operates much like the primary amine unit. The amine stripper off gas is recirculated to the SRU feed and the amine absorber off gas is directed to the Sulfur Recovery Plant catalytic incinerator (SN-844). The remaining low concentrations of hydrogen sulfide, carbon monoxide, and hydrogen are combusted in the incinerator.

Flares:

The refinery operates a High Pressure Flare (SN-822) and a Low Pressure Flare (SN-823) for disposing of excess combustible gases. These gases result from undetected leaks in operating equipment, upset conditions in the normal operation of a refinery where gases must be vented to avoid dangerously high pressure in operating equipment, plant start-ups, and emergency shutdowns. The flares are identical John Zink "smokeless" flares which use steam aspiration to control visible emissions. In addition to excess refinery gases, each flare burns approximately 1,406 scf/hr of natural gas for the pilot burners.

In conjunction with the flares, the refinery operates a flare gas recovery system (FGRS). The FGRS draws excess flare gases from the flare gas header upstream of a liquid seal vessel and recovers gas that would otherwise be burned in the flares. The capacity of the FGRS is automatically varied to maintain a positive pressure on the flare header upstream from the liquid seal vessel. Maintaining a positive pressure ensures that the air is not drawn into either the flare system or the flare gas recovery system. If the volume of the gas in the flare header exceeds the capacity of the FGRS, the excess gas will vent through the water seal on the FGRS to the flares.

Cellulose Fiber Baghouse:

The refinery operates an asphalt protective coatings unit. Cellulose fibers are received in bags and added to the system via a negative pressure hood and conveyor system. Any exhaust from the system is filtered through the Asphalt Protective Coating Baghouse (SN-807). Based on information submitted by Lion Oil in a letter dated July 25, 2002, this source has been moved to the insignificant activities list.

Truck Loading Racks:

The refinery operates several truck and rail loading racks. Products loaded range from asphalt to propane. The main truck loading rack is an automated bottom loading rack (SN-846) for loading transport trucks with all grades of gasoline and diesel. Emissions from all other loading racks are accounted for in the Heavy Oil Loading Racks (SN-847). Vapors generated at the gasoline/diesel loading rack during the loading operations are routed through a knock-out pot where any free liquids are recovered and the vapors are vented to a vapor recovery unit.

Gas Engine Compressors:

The refinery operates six (6) internal combustion gas compressor engines (SN-834 through SN-838 and SN-841). The compressors operate on natural gas and are utilized in moving gases within refinery applications. The two JVG compressors (SN-839 and SN-840) have been converted from internal combustion to electrical power, and no longer generate any air emissions.

Hydrocarbon Storage Tanks:

The refinery operates numerous hydrocarbon storage tanks which store products ranging from asphalt to propane.

Steam Superheater Furnace:

The refinery operates two (2) steam turbine driven gas compressors which consume 25,000 pounds per hour of superheated steam. The furnace operates on NSPS Subpart J quality gas and has a design heat input of 10.0 MMBtu/hr.

#5 Alkylation Unit:

There are two (2) 1,500 barrel (BBL) steel tanks which are used for storing 99% sulfuric acid which is used as a catalyst in this unit. The charge to this unit is approximately 6,000 BPD. The acid is diluted to 90% and then pumped to two (2) 2,000 barrel (BBL) spent acid tanks. Two (2) Acid Fume Scrubbers (SN-826 and SN-827) packed with polypropylene saddles are used to scrub any vapors which may be generated from the tanks during loading and transfer operations. These sources (SN-826 and SN-827) have been moved to the insignificant activities list.

Asphalt Rack Steam Heater:

Various grades of asphalt which are used for paving are produced at the refinery. A NSPS Subpart J quality gas fired package boiler rated at 10 MMBtu/hr (SN-828) is used to heat asphalt products during the truck loading operation.

<u>#6 Hydrotreater/Isomerization Unit:</u>

This unit has been installed due to EPA's lead phase down regulation. The unit upgrades light straight run naphtha from the crude unit into a higher octane gasoline. It consists of a hydrotreater section and a penex isomerization section. In the hydrotreater, light straight run naphtha from the crude units is heated

in the #6 Hydrotreater Furnace/Reboiler (SN-806) and reacted with hydrogen over a nickel/molybdenum catalyst to convert the sulfur in the light straight run naphtha stream to hydrogen sulfide.

The reactor effluent is passed through the separator and stripper to remove hydrogen and hydrogen sulfide. The stripper bottoms are sent to the penex isomerization section for further processing. Here, the stripper bottoms are heated in the isomerization heater and passed over a platinum catalyst in the reactor where the light straight run naphtha molecules are restructured to form higher octane compounds. The reactor effluent is sent to a separator where hydrogen is separated from the isomerate and recycled. The isomerate is then sent to the stabilizer where the low molecular weight gases are removed through a caustic scrubber and sent to the refinery fuel gas system. The bottoms from the stabilizer are sent to gasoline storage.

Asphalt Tank Heaters:

The refinery operates forty-seven (47) asphalt tank heaters (SN-832) which are fired by NSPS Subpart J quality gas.

Wastewater Treatment Plant:

This unit uses a combination of chemical, biochemical, and physical processes to remove pollutants from refinery wastewater before discharging into DeLoutre Creek. The main components of the unit are dual API separators, two (2) equalization tanks and pond, a dissolved air flotation (DAF) unit, a cooling tower, two (2) activated sludge bio-reactors, two (2) clarification tanks, sludge recycle equipment, an aerobic digester, and a sludge thickener. Final effluent filters assure a minimum level of suspended matter in the effluent discharged to DeLoutre Creek.

Final effluent cooling towers cool the effluent prior to discharge. Sludges generated at the Waste Water Treatment Plant are dewatered at the Sludge Management Facilities (SMF) prior to effluent disposal.

The facility is currently in the process of constructing a new system for the handling and treatment of process wastewater. This new system will allow for the segregation of process wastewater from refinery stormwater. VOC emissions from wastewater treatment at the facility should be greatly reduced once the new system is completed and operational. Once the new system is completed, the existing system will be converted to stormwater-only use.

Lime Silo:

Lime used in the SMF is stored in a lime silo. This silo is equipped with a baghouse (SN-845) which controls emissions during periods of filling. Based on information submitted by Lion Oil in a letter dated July 25, 2002, the Lime Silo Baghouse (SN-845) has been moved to the insignificant activities list.

Polymer Asphalt Letdown Facility:

This unit, which includes SN-850, is designed to produce a performance graded polymer modified asphalt binder for the asphalt paving industry. The unit consists of a refinery fuel gas-fired heater with a design nominal firing rate of 20 MMBtu/hr based on the HHV, a hot oil circulating pump, a heat exchanger, storage tanks, and loading racks. The hot oil circulates through coils in the storage tanks to

maintain the final product in a fluid and transportable state. The heat exchanger is included in the hot oil system to keep the neat asphalt in a fluid state during the PMA blending operations.

Fugitive Emissions from Equipment Leaks:

Fugitive emission sources include leaks of hydrocarbon vapors from process equipment and evaporation of hydrocarbons from open areas, rather than a stack or vent. Fugitive emission sources include valves of all types, flanges, pump and compressor seals, wastewater collection, cooling towers, and oil/water separators.

Miscellaneous Operations:

Catalyst used in the #7 FCCU is stored in two hoppers, which exhaust through the #7 FCCU Catalyst Hopper Vent (SN-848). The hoppers are filled by "sucking" the catalyst into the hoppers. Each of the hoppers is equipped with eductors which reduce the pressure in the hoppers during the filling operation.

	PSD Review					
Source in	Existence Prior to PS	D Effective				
	Date					
Old Source	Old Source New Source Year					
Numbers*	Numbers	Installed				
*Sources wi	thout old source num	bers were				
previously u	npermitted.					
37	T-3	1950				
38	T-4	1953				
40	T-11	1959				
41	T-12	1955				
42	T-14	1942				
43	T-15 1942					
44	T-16 1950					
45	T-17	1940				
46	T-18	1949				
47	T-20	1945				
	scheduled for	2004				
	removal					
48	T-21	1945				
	scheduled for	2004				
	removal					
49	T-22	1953				
50	T-23	1953				
52	T-25	1940				
54	T-27	1950				
55	T-36	1953				
56	T-39	1958				

Fable 7 - PSE	Review	History	Summary:
---------------	--------	---------	----------

PSD Review			
Source in	Existence Prior to PS	D Effective	
	Date		
Old Source	New Source	Year	
Numbers*	Numbers	Installed	
57	T-40	1940	
58	T-41	2005	
59	T-46	1933	
60	T-48	1923	
61	T-49	1923	
62	T-50	1937	
63	T-51	1940	
65	T-54	1922	
66	T-55	1923	
67	T-56	1923	
68	T-57	1949	
69	T-58	1952	
70	T-60	1923	
71	T-61	1949	
72	T-62	1949	
73	T-63	1957	
74	T-64	1957	
75	T-65	1954	
76	T-70	1935	
77	T-71	1935	
78	T-72	1950	
79	T-73	1950	
80	T-74	1950	
81	T-76	1938	
82	T-77	1945	
84	T-81	1936	
86	T-83	1938	
87	T-84	1953	
88	T-85	1954	
90	T-89	1948	
91	T-96	1940	
92	T-97	1940	
93	T-98	1940	
94	T-99	1940	
95	T-101	1922	
96	T-102	1922	
98	T-104	1923	
99	T-105	1923	
100	T-107	1923	

PSD Review			
Source in	Existence Prior to PS	D Effective	
	Date		
Old Source	New Source	Year	
Numbers*	Numbers	Installed	
103	T-110	1928	
104	T-111	1936	
105	T-112	2005	
107	T-114	1923	
108	T-115	1923	
109	T-116	1923	
110	T-117	1923	
111	T-118	1944	
112	T-119	1940	
	T-120	1949	
113	T-121	1949	
114	T-122	1953	
	T-123	1949	
115	T-124	1959	
116	T-125	1953	
117	T-126	1953	
118	T-128	1959	
119	T-129	1937	
120	T-145	1950	
121	T-162	1951	
122	T-165	1923	
123	T-166	1923	
124	T-167	1940	
125	T-168	1940	
126	T-170	1950	
127	T-171	1950	
128	T-173	1945	
129	T-175	1940	
130	T-176	1940	
	T-180	1959	
131	T-190	1940	
	T-199	1957	
132	T-200	1936	
133	T-217	1964	
134	T-219	1967	
135	T-226	1936	
136	T-228	1936	
137	T-240	1953	
138	T-241	1953	

PSD Review			
Source in	Existence Prior to PS	D Effective	
	Date		
Old Source	New Source	Year	
Numbers*	Numbers	Installed	
139	T-242	1953	
140	T-243	1953	
141	T-244	1953	
142	T-245	1953	
143	T-246	1953	
144	T-247	1959	
145	T-262	1938	
146	T-263	1938	
147	T-264	1938	
148	T-265	1938	
149	T-270	1941	
150	T-271	1941	
154	T-306	1952	
155	T-310	1950	
	T-311	1950	
	T-312	1950	
	T-313	1950	
	T-314	1950	
	T-315	1950	
156	T-319	1950	
157	T-320	1950	
158	T-321	1950	
159	T-322	1950	
160	T-323	1950	
162	T-325	1950	
163	T-326	1950	
164	T-327	1950	
165	T-328	1950	
166	T-329	1950	
167	T-330	1950	
168	T-331	1950	
169	T-332 1950		
170	T-333	1950	
171	T-335	1950	
	T-336	1950	
172	T-337	1950	
173	T-338	1950	
174	T-339	1950	
175	T-340	1961	

PSD Review				
Source in	Existence Prior to PS	D Effective		
	Date	1		
Old Source	New Source	Year		
Numbers*	Numbers	Installed		
176	T-348	1968		
177	T-349	1968		
178	T-350	1954		
179	T-351	1954		
180	T-352	1954		
181	T-353	1954		
182	T-354	1954		
183	T-355	1959		
184	T-356	1961		
185	T-360	1957		
186	T-361	1957		
187	T-368	1966		
188	T-371	1959		
189	T-372	1959		
191	T-410	1945		
192	T-411 1945			
193	T-412 1945			
194	T-413	1945		
	T-414	1945		
195	T-429	1945		
	demolished	1999		
	T-520	1950		
	T-521	1950		
196	T-524	1951		
	T-525	1951		
197	T-530	1951		
	T-570	1959		
01	801	1930		
	shutdown	1986		
02	802	1960		
	shutdown	1986		
07	807	1977		
09	809	1973		
13	813a	2005		
16	816**	1945		
17	817**	1945		
18	818**	1952		

	PSD Review				
Source in	Existence Prior to PS	D Effective			
	Date				
Old Source	New Source Year				
Numbers*	Numbers	Installed			
19	819**	1952			
20	820**	1958			
23	823	1974			
24	824	1977			
25	825	1945/1946			
	833	1959			
	834	1942			
	835	1942			
	837	1958			
	838	1958			
	839	1959			
	840	1959			
	847	Pre-1950 ¹			
		Pre-1950 ²			
		1975 ³			
		Pre-1950 ⁴			
		Pre-1950 ⁵			
848 1973					

**The previously permitted emissions for the #10, #11, #12, #13, and #14 Boilers, (SNs 816-820) were based upon the emission factors reported in the 1975 Second Edition of AP-42. An average emission factor of 175 lbs/10⁶ ft³ was used from the reported range of emission factors given for NO_X. The emission factor used to permit NO_X in this permit was based upon emission factors reported in the 1995 Fifth Edition of AP-42. The emission factor used for permitting NO_X is 280 lbs/10⁶ ft³.

¹ 111/219 West Truck Rack

² South Asphalt Plant Truck Rack

³ PMA Plant Truck Rack (formerly known as the Emulsion Plant Truck Rack)

⁴ Pumphouse Truck Rack

⁵ E & W Rail Car Rack

The following sources were installed or modified after the effective date of the PSD regulations; however, the emission increases did not exceed the significance levels and PSD review would not have been required.

Table 8 - Sources Ins	stalled After the	Effective Date of PSD
------------------------------	-------------------	------------------------------

PSD Review			
Sources Installed After	r the Effective	Date of PSD	
Old Source Numbers	New Source	Year Installed	Associated Emission Increase
	Numbers		
*Sources without old s	source numbers	s were previously no	ot permitted.
**Emission increase w	as determined	by multiplying the	lb/hr by 4.38.
***These were the em	issions permit	ed in Permit #868-A	AR-5.
83	T-78	installed 1950	
		replaced 1999	5.0 tpy VOC
89	T-88	1987	1.21 tpy VOC
97	T-103	1995	22.78 tpy VOC**
101	T-108	1934	4.38 tpy VOC**
	modified	1982	
102	T-109	1934	4.38 tpy VOC**
	modified	1982	
106	T-113	1923	4.38 tpy VOC**
	modified	1995	
	T-142	1982	4.38 tpy VOC**
	T-143	1982	4.38 tpy VOC**
151	T-272	1986	0.25 tpy VOC
152	T-273	1986	0.25 tpy VOC
153	T-274	1986	5.29 tpy VOC
161	T-324	1992	0.97 tpy VOC
190	T-384	1974	1.9 tpy VOC**
	modified	1999	
	T-432	1978	28.03 tpy VOC**
198	T-532	1981	35.98 tpy VOC
199	T-538	1989	0.25 tpy VOC
200	T-539	1989	0.25 tpy VOC
201	T-540	1987	0.25 tpy VOC
202	T-544	1991	1.11 tpy VOC
203	T-548	1993	19.01 tpy VOC
	T-549	1994	4.38 tpy VOC**
	T-550	1985	4.38 tpy VOC**
	T-551	1994	4.38 tpy VOC**
	T-552	1996	16.0 tpy VOC
	T-600	1994	4.38 tpy VOC**
	T-601	1994	4.38 tpy VOC**
	T-602	1994	4.38 tpy VOC**
	T-603	1995	4.38 tpy VOC**
	T-604	1994	4.38 tpy VOC**
	T-605	1996	4.38 tpy VOC**

PSD Review				
Sources Install	led After the Effective	e Date of PSD		
	T-606	1996	4.38 tpy VOC**	
	T-607	1990	4.38 tpy VOC**	
	T-608	1987	4.38 tpy VOC**	
	T-609	1995	4.38 tpy VOC**	
	T-610	1980	4.38 tpy VOC**	
	T-611	1995	4.38 tpy VOC**	
	T-612	1995	4.38 tpy VOC**	
03	803	1979	2.2 tpy PM***	
			4.4 tpy SO_2	
			30.7 tpy NO_{X}	
			0.5 tpy VOC	
			3.1 tpy CO	
04	804	1991	9.2 tpy PM	
			24.5 tpy SO_2	
			39.42 tpy NOX	
			2.63 tpy VOC	
			15.77 tpy CO	
05	805	1996	2.2 tpy PM	
			39.5 SO ₂	
			1.3 tpy VOC	
			29.5 tpy CO	
			39.5 tpy NO _X	
06	806	1958	25.4 tpy SO_2	
	modified	1988	7.88 tpy PM	
			17.52 tpy NO _X	
			1.75 tpy CO	
08	808	1979	2.2 tpy PM/PM ₁₀ ***	
			5.7 tpy SO_2	
			25.0 tpy NO_{X}	
			0.9 tpy VOC	
			4.0 tpy CO	
11	811	1980	6.1 tpy PM/PM ₁₀ ***	
			0.5 tpy SO_2	
			1.8 tpy VOC	
			10.1 tpy CO	
			59.6 tpy NO_X^1	
22	822	1979	0.5 tpy PM/PM ₁₀ ***	
			117.8 tpy SO_2^2	
			3.5 tpy VOC	
			18.8 tpy CO	
			83.7 tpy NO_X^2	
26	826	1982	0.5 tpy SO ₂ ***	
27	827	1982	0.5 tpy SO ₂ ***	

PSD Review			
Sources Install	ed After the Effective D	ate of PSD	
28	828 1	987	0.5 tpy PM/PM ₁₀ ***
			0.5 tpy SO_2
			0.5 tpy VOC
			0.9 tpy CO
			7.9 tpy NO_X
29	829 1	987	0.5 tpy PM/PM ₁₀ ***
			0.9 tpy SO_2
			0.5 tpy VOC
			0.9 tpy CO
			7.5 tpy NO_X
30	830 1	987	0.5 tpy PM/PM ₁₀ ***
			0.5 tpy SO_2
			0.5 tpy VOC
			0.5 tpy CO
			1.8 tpy NO _X
31	831 1	991	1.75 tpy SO ₂
			1.75 tpy NO_{X}
			4.82 tpy CO
			48.2 tpy HCl
34	842 1	993	$2.2 \text{ tpy PM/PM}_{10}$
			5.3 tpy SO_2
			0.5 tpy VOC
			3.5 tpy CO
			17.5 tpy NO _X
35	843 1	993	1.3 tpy PM
			3.5 tpy SO_2
			11.8 tpy NOX
			0.5 tpy VOC
			2.2 tpy CO
36	844 1	994	$13.2 \text{ tpy PM/PM}_{10}^{3}$
			39.4 tpy SO ₂
			250 ppm SO_2
			26.3 tpy NOX
			6.6 tpy VOC
			35.5 tpy CO
			$2.2 \text{ tpy H}_2\text{S}$
32	832 (47) Aspł	nalt Tank Heaters	15.8 tpy VOC
	Heats		
	Tank SN		

PSD Review			
Sources Installed	After the Effecti	ve Date of PSD	
	T-24	1975	
	T-39	pre-1981	
	T-40	1988	
	T-41	1991	
	T-56	1989	
	T-78	1999	
	T-99	1991	
	T-107	1987	
	T-111	pre-1981	
	T-118	1987	
	T-219	1968	
	T-348	1968	
Continued	T-354	1956	
	T-384	1975	
	T-524	1986	
	T-530	1986	
	T-544	1991	
	T-548	1993	
33	836	1986	$1.0 \text{ tpy PM/PM}_{10}$
			$1.0 \text{ tpy } SO_2$
			1.0 tpy VOC
			34.2 tpy CO
			$39.6 \text{ tpy NO}_{\text{X}}$
			Note: These are based on numbers in Permit
			#868-AOP-R0.
33	841	1981	1.0 tpy PM/PM ₁₀
			1.0 tpy SO_2
			1.0 tpy VOC
			58.3 tpy CO
			79.7 tpy NO_x^4
			Note: These are based on numbers in Permit
			#868-AOP-R0.
	845	1994	1.0 tpy PM/PM ₁₀
204	846	1980	Increase 727 tpv VOC
			Decrease 947 tpy VOC
			Net Change -220 tpv VOC
			The increase in emissions from the installation
			of the loading rack was offset by the removal
			of another loading rack. The modification
			took place while EPA Region VI was
			responsible for PSD review in the State of
			Arkansas.

PSD Review		
Sources Installed After the Effective	Date of PSD	
847	1987	$1.8 \text{ tpy VOC}^5, 10$
	1989	1.0 tpy VOC^6
	1986	1.0 tpy VOC^7
849	1998	1.4 tpy PM ₁₀
		1.2 tpy SO_2
		1.6 tpy VOC
		11.6 tpy CO
		19.2 tpy NO _x
Polymer Asphalt Let-Down Facility	All Sources	$1.8 \text{ tpy PM}_{10}^{8}$
	Modified 1999	3.2 tpy SO_2
		15.8 tpv VOC
		4.6 tpv CO
		18.4 tpv NO _x
Т-24		1.8 tpy VOC
Т-384		1.8 tpy VOC
Т-385		1.8 tpy VOC
Т-386		1.8 tpy VOC
Т-387		1.8 tpy VOC
Т-553		1.5 tpy VOC
Т-554		Inorganics
847		4.3 tpy VOC
850		1.0 tpy VOC
Sour Water Stripper Project	2000	1.1 tpy PM_{10}
11 5		1.1 tpy SO_2
		1.4 tpy VOC
		12 tpy CO
		27.2 tpy NO_{X}
Т-7		
816		
817		
818		
819		
820		
844		
#4 Crude Unit Turnaround	2000	0.4 tpy PM ₁₀
Improvements		1.9 tpy SO_2
		17.1 tpy VOC
		6.5 tpy CO
		3.9 tpy NO _X
T-39		
T-40		
T-41		
T-55		

PSD Review				
Sources Installed After the Effective Date of PSD				
T-84				
T-121				
T-122				
T-219				
T-368				
803				
804				
805				
814				
847				

1. Construction commenced before the effective date of PSD. Additionally, subsequent increases in emissions were below PSD trigger limits.

- 2. Construction commenced before the effective date of PSD. This flare replaced two other high pressure flares.
- 3. This compressor engine replaced three existing gas air compressors.
- 4. 111/219 East Truck Rack
- 5. North Asphalt Plant Truck Rack
- 6. Lube Oil Truck Rack
- 7. The facility added a Polymer Asphalt Let-Down facility in 1999. Equipment affected by this project included the modification of tanks T-24, and T-384 through T-387, the installation of tanks T-553 and T-554, the increased use of the PMA Asphalt Truck Rack (SN-847) and the installation of the asphalt hot oil heater (SN-850). Tanks T-385 through T-386 were removed from service and permanently classified as out-of service during the early 1980's, but were put back into service for this project. The total permitted emissions for these sources is 1.8 tpy PM/PM₁₀, 3.2 tpy SO₂, 15.8 tpy VOC, 4.6 tpy CO, and 18.4 tpy NO_X (no netting performed). In order to process the PMA project as a minor modification, the north and south PMA racks were limited to a total throughput of 1.2 million bbl/year. Emissions from the North and South PMA Racks are included in the heavy oil loading rack PAL.
- 8. The Sour Water Stripper Project was reviewed to ensure that it did not trigger PSD at the Sulfur Recovery Plant. The actual increase in emissions that would affect the Sulfur Recovery Plant was less than 1.0 tpy SO₂. The Sulfur Recovery Plant is monitored by a CEMS unit which is used to demonstrate compliance with the NSPS standards and to demonstrate that the facility does not exceed the SO₂ emissions for SN-844.
- 9. There is a 99.1 tpy increase in permitted VOC emissions at the Heavy Oil Loading Rack (SN-847) from Permit #868-AR-7 to the Title V. This increase is not subject to PSD review. During the comment period for Permit #868-AR-5, was issued in 1996, the facility had attempted to update the emissions from this source based on updated information. No revisions or physical changes had occurred. A decision was made by the Department at that time to wait until the issuance of the Title V permit to make any updates to the emissions. The throughput limit for this loading rack has increased by 900 Mgal/yr from the previous permits. The only other change has been the methods of calculation.

Regulations

The following table contains the regulations applicable to this permit.

Table 9 – Applicable Regulations

Regulation

Regulation 18 – The Arkansas Air Pollution Control Code, effective February 15, 1999

Regulation 19 – *The Arkansas Plan of Implementation for Air Pollution Control*, effective May 28, 2006

Regulation 26 – *Regulations of the Arkansas Operating Air Permit Program*, effective September 26, 2002

40 CFR Part 60 Subpart Db – *Standards of Performance for Industrial-Commercial-Institutional Steam Generating Units (Appendix M)*

40 CFR Part 60 Subpart Dc – *Standards of Performance for Small Industrial-Commercial-Institutional Steam Generating Units** (Appendix D)

40 CFR Part 60 Subpart J – Standards of Performance for Petroleum Refineries* (Appendix C)

40 CFR Part 60 Subpart Ka – *Standards of Performance for Storage Vessels for Petroleum Liquids for Which Construction, Reconstruction, or Modification Commenced After May 18, 1978, and Prior to July 23, 1984** (Appendix A)

40 CFR Part 60 Subpart Kb – Standards of Performance for Volatile Organic Liquid Storage Vessels (Including Petroleum Liquid Storage Vessels) for Which Construction, Reconstruction, or Modification Commenced After July 23, 1984* (Appendix B)

40 CFR Part 60 Subpart QQQ – *Standards of Performance for Petroleum Refinery Wastewater Systems** (Appendix J)

40 CFR Part 60 Subpart UU – *Standards of Performance for Asphalt Processing and Asphalt Roofing Manufacture** (Appendix H)

40 CFR Part 60 Subpart VV – Standards of Performance for Equipment Leaks of VOC in the Synthetic Organic Chemicals Manufacturing Industry* (Appendix G)

40 CFR Part 60 Subpart GGG – *Standards of Performance for Equipment Leaks of VOC in Petroleum Refineries** (Appendix F)

40 CFR Part 61 Subpart FF – *National Emission Standards for Benzene Waste Operations** (Appendix E)

Regulation

40 CFR Part 63 Subpart CC – National Emission Standards for Hazardous Air Pollutants from Petroleum Refineries* (Appendix I)

40 CFR Part 63 Subpart UUU – National Emission Standards for Hazardous Air Pollutants for Petroleum Refineries: Catalytic Cracking Units, Catalytic Reforming Units, and Sulfur Recovery Units (Appendix O)

40 CFR Part 63 Subpart DDDDD – National Emission Standards for Hazardous Air Pollutants for Industrial, Commercial, and Institutional Boilers and Process Heaters (Appendix N)

40 CFR Part 63 Subpart LLLLL – National Emission Standards for Hazardous Air Pollutants: Asphalt Processing and Asphalt Roofing (Appendix P), effective May 1, 2006

* The Requirements of this permit are not intended to alter any applicable federal requirements.

The following table is a summary of emissions from the facility. The following table contains cross-references to the pages containing specific conditions and emissions for each source. This table, in itself, is not an enforceable condition of the permit.

		EMISSION SUMMARY			
Source Description		Pollutant	Emission Rates		Cross Reference Page
			lb/hr	tpy	U
		PM_{10}	114.3	296.5	
		SO_2	252.6	789.1	
Total Allowable Emissions		VOC	15542.6	10,996.0	
		СО	887.7	1582.1	
		NO _x	569.9	1624.0	
		Benzene*		67.9	N/A
		Biphenyl*		9.5	
		1,3 Butadiene*		5.1	
		Carbon Disulfide		4.4	
		Carbonyl Sulfide		4.5	
		Cresol (mixed isomers)*		14.0	
		Cumene*		10.2	
		Diethanolamine*		4.4	
		Ethyl benzene*		43.6	
		Hexane*		314.5	
	ПАРЗ	Naphthalene*		6.6	
		Phenol*		9.8	
		Toluene*		148.7	
		2,2,4 Trimethylpentane*		56.2	
		Xylene (mixed isomers)*		341.8	
		Chlorine		26.7	
		Hydrogen Chloride		48.6	
		Formaldehyde*		4.9	
		Perchloroethylene*		7.1	
		(tetrachloroethylene)			
		Ammonia		62.1	
٨	ir Contominanta	H ₂ SO ₄ (Sulfuric Acid)		88.3	
Air Contaminants		H_2S		364.3	
		Particulate Matter		884.3	
801	#1 Crude Topping	Remov	ved from Ser	rvice	
	Furnace				
802	#1 Crude Vacuum	Removed from Service			
	Furnace				

Table 10 – Emission Summary

EMISSION SUMMARY						
Source No. Description		Pollutant	Emission Rates		Cross Reference Page	
			lb/hr	tpy		
803	Pre-flash Column	PM_{10}	1.0	4.4	49	
	Reboiler	SO_2	1.7	5.9		
		VOC	1.0	4.4		
		CO	4.3	14.5		
		NO _x	7.3	24.6		
804	#4 Atmospheric	PM_{10}	2.2	7.3	49	
	Furnace (Topping)	SO_2	9.7	32.6		
		VOC	1.6	5.2		
		СО	23.7	80.1		
		NO _x	12.9	43.7		
805	#4 Vacuum Furnace	PM ₁₀	1.0	4.4	49	
		SO_2	3.3	11.1		
		VOC	1.0	4.4		
		CO	8.0	27.1		
		NO _x	7.9	26.7		
806	#6 Hydrotreater	PM ₁₀	1.0	4.4	49	
	Furnace/Reboiler	SO_2	1.3	4.4		
		VOC	1.0	4.4		
		CO	3.2	10.9		
		NO_x	5.5	18.4		
807	Asphalt Protective Coatings Baghouse	Moved to Insi	Moved to Insignificant Activities List			
808	#7 FCCU Furnace	PM_{10}	1.0	4.4	49	
		SO_2	2.4	8.3		
		VOC	1.0	4.4		
		CO	6.0	20.3		
		NO _x	8.0	27.1		
809	#7 Catalyst	PM_{10}	7.5	32.9	58	
	Regenerator Stack	SO_2	26.5	58.3		
	C	VOC	183.3	805.2		
		СО	116.0	101.9		
		NO _x	59.2	259.9		
810	#9 Hydrotreater	PM_{10}	1.0	4.4	49	
	Furnace/Reboiler	SO ₂	3.1	10.3		
		VOC	1.0	4.4		
		CO	7.5	25.3		
		NO _x	12.7	43.0		
EMISSION SUMMARY						
------------------	------------------------	------------------	----------------	------	----------------------------	--
Source No.	Description	Pollutant	Emission Rates		Cross Reference Page	
			lb/hr	tpv	8.	
811	#9 Reformer Furnace	PM ₁₀	1.5	5.6	49	
011		SO ₂	6.8	25.2	15	
		VOC	1.1	4.4		
		CO	16.6	61.6		
		NOx	20.2	74.7		
812	#9 Stabilizer Reboiler	PM ₁₀	1.0	4.4	49	
012		SO ₂	1.1	4.4		
		VOC	1.0	4.4		
		CO	2.7	9.0		
		NO _x	4.6	15.4		
813a	#10 Hydrotreater	PM ₁₀	0.6	2.0	49	
	Furnace/Reboiler	SO ₂	0.8	3.0	-	
		VOC	0.4	1.4		
		CO	2.0	7.2		
		NO _x	0.9	3.1		
814	#11 Deasphalting	PM ₁₀	1.0	4.4	49	
	Furnace	SO ₂	1.4	4.7		
		VOČ	1.0	4.4		
		CO	3.4	11.6		
		NO _x	5.8	19.7		
816	#10 Boiler	PM ₁₀	1.1		67	
		SO ₂	46.9			
		VOČ	1.0			
		CO	12.2			
		NO _x	40.7			
817	#11 Boiler	PM ₁₀	1.1		67	
		SO_2	46.9			
		VOC	1.0			
		CO	12.2			
		NO _x	40.7			
818	#12 Boiler	PM_{10}	1.3		67	
		SO_2	5.7			
		VOC	1.0			
		CO	13.9			
		NO _x	46.4			
819	#13 Boiler	PM_{10}	1.3		67	
		SO_2	5.7			
		VOC	1.0			
		CO	13.9			
		NO _x	46.4			

	EMISSION SUMMARY						
Source No.	Description	Pollutant	Emission Rates		Cross Reference Page		
			lb/hr	tpy	-		
820	#14 Boiler	PM_{10}	1.3		67		
		SO_2	5.7				
		VOC	1.0				
		СО	13.9				
		NO _x	46.4				
816-820	#10-#14 Boilers –	PM_{10}		22.0	67		
	Annual Emissions	SO_2		374.5			
	Bubble	VOC		22.0			
		CO		223.4			
		NO _x		744.9			
821	Refinery Boilers	PM_{10}	7.8		70		
(a,b,c	(fuel gas/natural gas	SO_2	22.4				
total)	firing)	VOC	9.8				
		CO	474.2				
		NO_x	20.0				
821	Refinery Boilers	PM ₁₀	15.7		70		
(a,b,c	(fuel oil firing)	SO_2	37.3				
total)	_	VOC	20.0				
		CO	474.2				
		NO_x	66.6				
821	Refinery Boilers	PM ₁₀		31.1	70		
(a,b,c	(annual limits)	SO_2		81.3			
total)		VOC		39.1			
		СО		123.2			
		NO_x		58.0			
822	High and Low	PM_{10}	99 ¹	4.0	82		
823	Pressure Flares	SO_2	484 ¹	19.6			
		VOC	842 ¹	34.1			
		CO	$2,220^{1}$	89.9			
		NO _x	612 ¹	24.8			
824	#16 Fume Incinerator	\mathbf{PM}_{10}	2.0	8.8	84		
		SO_2	23.1	101.5			
		VOC	4.1	18.0			
		CO	123.3	541.5			
		NO _x	2.0	8.8			
825	#16 Asphalt Blowing	\mathbf{PM}_{10}	1.0	4.4	49		
	Furnaces	SO_2	1.3	4.4			
		VOC	1.0	4.4			
		CO	3.2	10.9			
		NO _x	5.5	18.4			
826	Acid Fume Scrubber	Moved to Insi	gnificant Ac	ctivities Lis	t		

EMISSION SUMMARY						
Source No.	Description	Pollutant	Emissio	on Rates	Cross Reference Page	
			lb/hr	tpy		
827	Acid Fume Scrubber	Moved to Insi	gnificant Ac	ctivities Lis	t	
828	Asphalt Rack Steam	\mathbf{PM}_{10}	1.0	4.4	49	
	Heater	SO_2	1.0	4.4		
		VOC	1.0	4.4		
		CO	1.1	4.4		
		NO _x	1.8	6.1		
830	Regenerant Furnace	\mathbf{PM}_{10}	1.0	4.4	49	
		SO_2	1.0	4.4		
		VOC	1.0	4.4		
		CO	1.0	4.4		
		NO _x	1.0	4.4		
831	#9 Continuous	\mathbf{PM}_{10}	2.0	8.8	88	
	Catalyst Regenerator	SO_2	2.0	8.8		
		VOC	2.0	8.8		
		CO	2.6	11.4		
		NO _x	2.0	8.8		
832	47 Asphalt Tank	\mathbf{PM}_{10}	1.0	4.4	89	
	Heaters	SO_2	4.3	14.7		
		VOC	1.0	4.4		
		CO	10.6	35.9		
		NO _x	12.9	43.6		
833	South XVG	Source Rep	moved from	Service		
	Compressor					
834	North KVG	CO	23.6		91	
	Compressor	NO _x	28.7			
835	South KVG	CO	23.6		91	
	Compressor	NO _x	28.7			
834	North KVG	CO		21.2	91	
	Compressor	NO _x		25.8		
835	South KVG					
	Compressor –					
	Annual Emissions					
	Bubble					
836	8GTL Compressor	Source Rep	moved from	Service		
837	North 8SVG	СО	2.9	12.8	91	
	Compressor	NO _x	1.9	8.5		
838	South 10 SVG	CO	3.6	16.0	91	
	Compressor	NO _x	2.4	10.7		
839	East JVG Compressor	Converted to electric por	wer (no emi	ssions)	91	
840	West JVG	Converted to electric po	wer (no emi	ssions)	91	
	Compressor	•	-	,		

		EMISSION SUMMARY			
Source No.	Description	Pollutant	Emission Rates		Cross Reference Page
			lb/hr	tpy	
841	G398TA Air	CO	3.1	13.6	91
	Compressor	NO _x	3.1	13.6	
842	#12 Unit Distillate	PM_{10}	1.0	4.4	49
	Hydrotreater	SO_2	2.2	7.4	
		VOC	1.0	4.4	
		CO	5.4	18.1	
		NO_x	5.3	17.8	
843	#12 Unit Stripper Reboiler Furnace	Removed from Se	ervice - 200	5	49
844	Sulfur Recovery Plant	PM_{10}	12.0	52.7	49
	Incinerator	SO_2	19.1	53.4	
		VOC	1.5	6.6	
		CO	8.1	35.6	
		NO _x	6.0	26.4	
845	Sludge Management Facility (Lime Silo Baghouse)	Moved to Ins	ignificant A	ctivities Lis	t
846	Gasoline/Diesel Loading Rack	VOC	20.2	17.1	95
847	Heavy Oil Loading Racks	VOC	647.2	281.1	96
848	#7 FCCU Catalyst Hopper Vents	PM ₁₀	25.0	1.8	63
849	Standby Diesel Crude	PM_{10}	1.4	1.4	98
	Pump	SO_2	1.2	1.2	
	Ĩ	VOC	1.6	1.5	
		CO	12.2	11.6	
		NO _x	20.2	19.1	
850	Asphalt Hot Oil	PM_{10}	1.0	4.4	49
	Heater	SO_2	1.0	4.4	
		VOC	1.0	4.4	
		СО	2.1	7.2	
		NO _x	3.6	12.3	
851	Wastewater	VOC	900.0	3294.0	99
	Collection, Treatment, and Storage - old				
851a	Wastewater Collection, Treatment, and Storage - new	VOC	26.1	85.9	99
852	Vacuum Distillation Unit	Emissions routed to fuel gas recovery system with 2003 Tier 2 facility modifications			

	EMISSION SUMMARY					
Source No.	Description	Pollutant	Emission Rates		Cross Reference Page	
			lb/hr	tpy	, C	
853	Cooling Towers	VOC	15.5	67.9		
		\mathbf{PM}_{10}	18.4	75.7	103	
853a	#5 Cooling Tower	PM ₁₀	2.3	5.1		
854	Fugitive Equipment Leaks	VOC	676.4 ²	2962.0	103	
856	Tank Plantwide	PM_{10}	13.9	3.4	112	
	Applicability Limit	VOC	$13.651.3^2$	3308.6		
		CO	273.3	66.3		
857	Naptha Splitter	PM_{10}	1.2	4.4	139	
	Reboiler Heater	SO ₂	2.1	7.9		
		VOČ	0.9	3.2		
		СО	5.2	19.3		
		NO _x	2.2	8.2		
858f	Tier 2 Fugitives Annual VOC Bubble	VOC		41.3	103	
858t	Tier 2 Tanks Annual VOC Bubble	VOC		322.5	112	
859	#8 Cooling Tower	PM_{10}	2.9	12.8	103	
	(replaces #1 Cooling Tower)	VOC	5.3	22.9		
860	ULSD Hydrotreater	PM_{10}	1.0	3.6	49	
	Heater	SO ₂	1.7	6.5		
		VOC	0.7	2.6		
		CO	4.2	15.8		
		NO _x	1.8	6.7		
861	Hydrogen Plant	PM ₁₀	0.4	1.4	49	
	Heater(s)	SO ₂	0.7	2.4		
		VOC	0.3	1.0		
		СО	1.7	5.8		
		NO _x	0.7	2.5		
862	Hot Oil Heater	PM ₁₀	0.4	1.2	49	
		SO ₂	1.6	5.3		
		VOC	0.3	0.9		
		СО	3.8	12.8		
		NO _x	3.3	11.0		
863	Boiler Feedwater	PM_{10}	0.1	0.1	141	
	Pump	SO_2	0.1	0.1		
		VOC	0.5	0.2		
		СО	1.8	0.5		
		NO _x	22.8	5.7		

EMISSION SUMMARY							
Source No.	Description	Pollutant	Emission Rates		Cross Reference Page		
			lb/hr	tpy			
*HAPs i	*HAPs included in the VOC totals. Other HAPs are not included in any other totals unless						
		specifically stated.					
**Air C	Contaminants such as ammor	nia, acetone, and certain halogen	ated solvents	are not VOC	Cs or HAPs.		
¹ This figure	¹ This figure represents a lb/day limit rather than a lb/hr limit. For the purposes of summarizing plantwide lb/hr						
emissions i	emissions in this table, the lb/day limit for these sources was divided by 24 hours of operation. This figure is for						
	illustrative purposes of	nly, and these sources are not lin	nited on an ho	ourly basis.			
² The Tier	² The Tier 2 fugitives and tanks are subject to and included in all emission limits given for SN-854 and SN-856.						

42

Section III: PERMIT HISTORY

Permit #82-A was issued on November 19, 1971. This permit was for the construction of a sodium hydrosulfide plant to replace the existing sulfur recovery plant.

Permit #167-A was issued September 28, 1973. This permit approved a catalytic cracking facility by combining two catalytic cracking units into one.

Permit #252-A was issued in July 1974. This permit allowed the replacement of three uncontrolled flares with one John Zink STF-SA-24S smokeless flare.

Permit #167-A (modification) was issued on September 27, 1974. This permit allowed the continued operation of the #3 fluid catalytic cracking unit beyond the period designated in the original permit in order to allow time to increase the capacity of the #7 unit.

Permit #337-A was issued on May 28, 1976. This permit allowed the installation of a stripper to remove H_2S from the refinery wastewater stream with the off gas being treated by the existing sodium hydrosulfide unit.

Permit #338-A was issued on May 28, 1976. This permit allowed the installation of a scrubber-incinerator-waste heat boiler to control emissions from the Asphalt Plant.

Permit #423-A was issued on August 18, 1977. In this permit, the facility proposed to install a baghouse to control asbestos emissions from the protective coatings plant.

Permit #438-A was issued on November 18, 1977. This permit allowed the installation of a pre-flash column reboiler heater in order for the facility to meet the EPA's requirement to reduce lead in gasoline.

Permit #454-A was issued on March 24, 1978. This permit allowed the facility to replace the existing truck loading dock with a new truck transport terminal for gasolines, distillates, and LPGs.

Permit #337-A (modification) was issued in March 1978. There had been a delay in the modification of the hydrosulfide unit. This permit allowed the facility to operate the stripper prior to the upgrade.

Permit #520-A was issued on September 29, 1978. This permit allowed the installation of new and revamped platforming and unifying furnaces in order for the facility to meet the second part of the lead phasedown as required by the EPA.

Permit #252-A (modification) was issued in June, 1979. This permit allowed the replacement of two 16 inch flares with one 24 inch high pressure flare.

Permit #252-A (modification) was issued on November 20, 1981. This permit allowed the facility to replace a gasoline blending storage tank that had been condemned by increasing the use of the remaining tanks and reactivating out of service tanks. In order to comply with NSPS requirements Tank #124 was fitted with a secondary seal to the external floating roof. Tanks #108 and #109 were fitted with internal floating roofs.

Permit #868-A was issued on January 4, 1988. This permit served to consolidate all of the active permits held by this facility into one permit. It also permitted an asphalt loading heater and Isomerization Project as part of the lead phasedown required by the EPA.

Permit #868-AR-1 was issued on December 26, 1990. This modification allowed the installation of a topping furnace on the #4 crude unit.

Permit #868-AR-2 was issued on June 7, 1991. This modification allowed the installation of a continuous catalyst regeneration unit of a platforming unit.

Permit #868-AR-3 was issued on January 5, 1993. This modification permitted the installation of a 100,000 barrel asphalt storage tank.

Permit #868-AR-4 was issued on May 27, 1993. This modification permitted the installation of a distillate hydrotreater with a capacity of 20,000 barrels per day. The purpose of this modification was to make on-road diesel quality fuel to meet the Clean Air Act Standards.

Permit #1596-A was issued on January 31, 1995. This permit allowed the installation of a Sulfur Recovery Plant to produce elemental sulfur.

Permit #868-AR-5 was issued on August 12, 1996. This modification dealt with the installation of a new 50,000 barrel storage tank to replace an existing tank, installation of a 25,000 BPD vacuum furnace to replace an existing furnace, installation of a Sulfur Recovery Plant to replace the existing Sodium Hydrosulfide Unit, and documented the emissions from on-site storage tanks, product loading racks, and process fugitive emissions. Permits #868-AR-4 and #1596-A were consolidated.

Permit #868-AR-6 was issued on February 6, 1998. This minor modification was to install a standby diesel fueled crude pump in order for Tank #63 (SN T-63 for this permit, SN-73 of the old permit) to meet the standards of 40 C.F.R. 63, Subpart CC- *National Emission Standards for Hazardous Air Pollutants from Petroleum Refineries*. The installation of the new pumping system allowed the tank to be taken out of crude oil storage service, and to be classified as a Group II storage vessel. This minor modification also allowed the facility to reduce VOC emissions from the tank, reduce crude oil inventories, and provide full emergency standby crude capacity in the event of a power failure.

Permit #868-AR-7 was issued on June 3, 1998. The purpose of this minor modification was to install an above ground storage tank (SN T-552) to replace an underground storage tank used to store gasoline for the company's motor fuel demands. The underground tank was owned by a company which provided fuel to Lion Oil.

Permit #868-AOP-R0 was issued on December 12, 2000 as the first operating permit for this facility as per the requirements of Regulation #26 and 40 C.F.R. § 70. In this permit, all of the tanks at the facility were bubbled under a PAL such that the facility has to comply with one VOC limit for the tank farm instead of a limit for each tank. Under this permit, the facility has permitted several sources that were previously unpermitted and increased several throughputs. The following minor modification and de minimis changes that were previously allowed were also included.

Minor modification submitted in September 1998: Permitted the Polymer Asphalt Let-Down Facility. The project consisted of installing a new gas fired hot oil system (SN-850), installation of two new tanks (SN's T-553 and T-554), modification of tanks (SN's T-24, T-384 through T-387)

De minimis change submitted May 1999: Allowed the facility to replace the existing Sour Water Stripper with a new 400 gal/min Sour Water Stripper to minimize odors at the refinery. A new 20,000 barrel storage tank for the storage of sour water was also installed as part of the project.

De minimis change submitted October 1999: Allowed the facility to upgrade the #4 Crude Unit with new and refurbished equipment. The improvements included the installation of seven pumps and approximately 236 hydrocarbon valves with associated flanging and the removal of two pumps, 198 hydrocarbon valves and associated flanging. The improvements to the #4 Crude Unit also allowed the facility to produce intermediates that were previously purchased from outside sources. Associated equipment that will be affected by the changes at the facility are the #4 Pre-flash Column Reboiler (SN-03), #4 Atmospheric Furnace (SN-04), the #4 Vacuum Furnace (SN-05), the #11 Deasphalting Furnace (SN-14), the Asphalt Loading Racks (SN's 205-208), Asphalt Storage Tanks #39, #40, #41, #55, #84, #219, and #368, and Diesel Storage Tanks #121 and #122.

De minimis change submitted February 1999: Allowed the facility to construct a new 5,000 barrel asphalt storage tank (SN T-78) to replace the existing 2,500 barrel storage tank.

In previous permitting actions, the tank numbers did not coincide with the source numbers. In order to eliminate confusion and correct the problem, the source numbers for the facility were changed in this permitting action. Source numbers 01-700 are reserved for tank purposes. Source numbers for the other sources start at 801. See Appendix L.

Permit No. 868-AOP-R1 was issued to Lion Oil Co. on Dec. 5, 2003. This permit was the first modification to Permit #868-AOP-R0. It was issued as a part of the Permit Appeal Resolution between the Department and the facility. The following changes were made in this permit:

- a. The method of demonstrating compliance with the emission limits for the facility's tanks was changed to allow the facility to track refinery crude feed rate instead of conducting a monthly emissions inventory.
- b. A plantwide applicability limit was established for various other air pollutants in lieu of individual source emission limits.
- c. The effective dates of several of the testing conditions and opacity readings were modified or changed.
- d. Several equipment capacities were corrected or modified.
- e. The Plantwide Conditions were modified to clarify the difference between refinery fuel gas and desulfurized refinery fuel gas and which sources were able to burn which fuels.
- f. Clarifications were made regarding applicability of various regulations. Various wording changes and typographical and error corrections were made throughout the Permit.

- g. Various alternate operating scenarios were added to allow the facility flexibility in its operations. The frequency of monitoring the Btu content of the NSPS J quality gas was clarified. The Cooling Towers section (SN-853) was changed to include two cooling towers that were omitted from the previous permit. The emissions were updated to include particulate emissions.
- h. The Insignificant Activities List was updated.
- i. The Permit was updated to reflect the installation of a flare gas recovery system to recover refinery gases. The Permit was updated to reflect the installation of two additional 5,000 barrel storage tanks (T-382 and T-383) and one additional loading rack (PMA #2 Loading Rack).
- j. Two new gas oil tanks, one 2,000 bbl storage tank (T-19), and one 8,200 bbl storage tank (T-59) were added to the permit. These tanks were constructed to replace two older existing tanks (T-20 and T-21) which were removed from service. These two new tanks were incorporated into the facility-wide PAL for VOC emissions from tanks.
- k. One additional gas fired tank heater was permitted for installation in asphalt storage tank No. 78 (T-78). This new heater is rated at 0.68 MMBtu/hr.
- 1. The installation of a new, enclosed process wastewater treatment system was permitted with this modification. This new system allows for the segregation of process wastewater from refinery stormwater. The existing wastewater treatment system will be converted to stormwater-only usage once the new system is completed. This change should result in significant decreases in VOC emissions from the wastewater treatment systems at the refinery.

Permit No. 868-AOP-R2 was issued to Lion Oil Co. on January 3, 2005. With this modification, the facility modified, or will be modifying several units, and installing new equipment in order to produce low-sulfur diesel fuel and gasoline to meet the new US EPA "Tier II" fuel sulfur requirements. The changes which occurred at the plant which are associated with the Tier II project are as follows:

- a. A new naphtha splitter was installed in the refining process following the #7 Fluid Catalytic Cracking Unit (FCCU).
- b. The existing #10 Diesel Hydrotreater was converted to treat FCC heavy naphtha.
- c. The #12 Unit Distillate Hydrotreater Stripper Reboiler Furnace (SN-843) was retrofitted with new piping to allow it to serve as the #10 unit Stripper Reboiler Furnace. After further evaluation, this heater will remain in its present service. There was no emissions change with this modification.
- d. New non-fired heat exchangers were installed in the #12 Unit to supply heat previously supplied by the #12 Distallate Hydrotreater Stripper Reboiler Furnace.
- e. A new diesel hydrotreater was installed (No. 8 ULSD Hydrotreater) to replace the #10 Diesel Hydrotreater and to produce Ultra-Low Sulfur Diesel (ULSD).

- f. A wet gas scrubber (WGS) was installed on the #7 FCCU Catalyst Regenerator Stack (SN-809) in order to reduce emissions of sulfur dioxide (SO₂) and particulate matter (PM/PM₁₀).
- g. New equipment and piping was installed to handle wastewater from the No. 8 Unit and the WGS and to comply with NSPS QQQ where applicable.
- h. The catalyst utilized in the #9 CCR (SN-831) was changed to improve hydrogen production.
- i. The sulfur recovery capacity of the Sulfur Recovery Plant (SN-844) was increased to handle the increased sulfur removed from the fuel oil and gasoline.
- j. Three existing tanks (T-113, T-247, and T-372) were converted from diesel to FCC gasoline and heavy naphtha service. SN-113 was retrofitted with an external floating roof, and SN-247 and SN-372 were retrofitted with internal floating roofs.
- k. The diesel throughput of the following tanks increased: T-54, T-108, T-109, T-119, T-121, and T-122. No other changes have occurred at any of these tanks.
- 1. Two new process heaters were installed. One at the #7 FCC Naphtha Splitter Reboiler, and one at the No. 8 ULSD Hydrotreater. These two heaters have been permitted as SN-857 and SN-860.
- m. A new emission bubble was added to the permit to simplify tracking of emissions associated with the Tier II clean fuels project. This bubble includes all emissions from fugitive sources associated with the Tier II project, as well as emissions from the tanks which were either modified, or experienced a throughput increase associated with the project. This source has been assigned SN-858. The tanks associated with the Tier II project were previously included in the refinery tanks bubble (SN-856). Permitted VOC emissions from SN-856 were decreased by the amount of the most recent available data for past actual emissions from the Tier II tanks.
- n. The No. 1 Cooling Tower was replaced with the new No. 8 Cooling Tower (SN-859). This change was necessary to provide for the increased process cooling water demands due to the new equipment associated with the Tier II changes. Although the No. 8 Cooling Tower has a higher cooling water handling capacity, permitted emissions will decrease with this change due to the use of drift eliminators for emissions control in the No. 8 tower.

Additionally, the following changes were made to the permit. These changes are not specifically associated with the tier II project, but were included in the permit at this time.

Lion Oil proposed to lower permitted CO emissions from the No. 7 FCCU Catalyst
 Regenerator Stack (SN-809) to comply with provisions of the Consent Decree (CIV. No. 03-1028) between Lion Oil, the US EPA, and ADEQ. CO emissions from this source were required to comply with limits of 500 ppmvd at 0% O₂ (1-hour average) and 100

ppmvd at 0% O_2 (365-day rolling average). This resulted in a very substantial decrease in permitted CO emissions from this source (10,463.1 tpy decrease).

- b. A new non-contact condenser was installed on the Vacuum Distillation Unit (VDU). This change virtually eliminated VOC emissions from the VDU. These VOC emissions were previously routed through the No. 1 cooling tower, and included in SN-852. This changes resulted in a decrease in permitted VOC emissions of 242.1 tpy. Small quantities of VOC may continue to be emitted from the VDU in the form of fugitive equipment leaks. Such emissions are covered by SN-858, the Tier II fugitives and tanks emissions bubble.
- c. Catalytic converters and air/fuel ratio controllers were installed on the North 8 and South 10 SVG compressors (SN-837 and SN-838) and the East and West JVG compressors (SN-839 and SN-840). These controls were installed as a "supplemental environmental project" pursuant to paragraph 32(A) of the Consent Decree (CIV. No. 03-1028) between Lion Oil, the US EPA, and ADEQ. These controls were not installed pursuant to "BACT" or any portion of the NSR or PSD programs. The installation of these controls reduced emissions of NO_x and CO from these four compressor engines.
- d. A catalytic converter and air/fuel ratio controller was installed on the air compressor (SN-841) pursuant to BACT requirements and paragraph 16(B)(ii) of the Consent Decree (CIV. No. 03-1028). The installation of these controls reduced emissions of NO_x and CO from this compressor engine.
- e. A continuous emissions monitor (CEM) system was installed on the #4 Atmospheric Furnace (SN-804). This system was installed in order to demonstrate compliance with an emission limit of 0.045 lb $NO_x/MMBtu$ which was established pursuant to the Consent Decree (CIV. No. 03-1028) between Lion Oil Co., the US EPA, and ADEQ.
- f. Several new requirements were added to the permit to clarify regulatory applicability and other administrative issues as required by the Consent Decree (CIV. No. 03-1028) between Lion Oil, the US EPA, and ADEQ. No emissions changes resulted from these new permit conditions.
- g. As a result of the Consent Decree (CIV. No. 03-1028), three of the existing boilers (SN-818, 819, 820) were now identified as subject to the provisions of 40 CFR Part 60
 Subpart J. Compliance with the NSPS requirements for H₂S concentration in the fuel gas resulted in a decrease in SO₂ emissions from these sources.

As a result of all of the modifications performed at the plant with this permit revision, overall permitted annual emissions limitations for the facility changed as follows: PM_{10} decreased by 273.0 tpy, SO_2 decreased by 2,338.8 tpy, VOC decreased by 299.7 tpy, CO decreased by 10,620.0 tpy, and NO_x decreased by 89.2 tpy. There were no changes to any limits contained in the existing non-criteria pollutants bubble limits contained in this permit. The facility was required to continue to demonstrate compliance with these limits.

> Section IV: Emission Unit Information SN-803 - #4 Pre-flash Column Reboiler **SN-804 - #4 Atmospheric Topping Furnace** SN-805 - #4 Vacuum Furnace SN-806 - #6 Hydrotreater Furnace/Reboiler SN - 808-#7 FCCU Furnace SN-810 - #9 Hydrotreater Furnace/Reboiler SN-811 - #9 Reformer Furnace SN-812 - #9 Stabilizer Reboiler SN-813a - #10 Hvdrotreater Furnace/Reboiler **SN-814 - #11 Deasphalting Furnace** SN-825 - #16 Asphalt Blowing Furnaces **SN-828 - Asphalt Rack Steam Heater SN-830 - Regenerant Furnace** SN-842 - #12 Unit Distillate Hydrotreater SN-850 - Asphalt Hot Oil Heater SN-857 - Naptha Splitter Reboiler **SN-860 - ULSD Hydrotreater Heater SN-861 - Hydrogen Plant Heater** SN-862 - Hot Oil Heater

> > **Source Descriptions**

All sources in this grouping are subject to 40 C.F.R., Part 60, Subpart J-Standards of Performance for Petroleum Refineries.

SN-813a, SN-857, SN-860, SN-861, and SN-862 are subject to 40 CFR Part 63 Subpart DDDDD – *National Emission Standards for Hazardous Air Pollutants for Industrial, Commercial, and Institutional Boilers and Process Heaters.*

SN-850 and SN-862 are subject to 40 C.F.R. 60, Subpart Dc-Standards of Performance for Small Industrial Commercial Institutional Steam Generating Units.

SN-803 is a 40 MMBtu/hr reboiler (nominal design) used to maintain the temperature in the pre-flash column in order to separate crude oil into gasoline and naphtha. The reboiler is fueled by NSPS Subpart J quality gas. It was installed in 1979.

SN-804 is a 221.2 MMBtu/hr furnace (nominal design) used to heat the bottoms from the pre-flash column in order to separate them into naphtha, kerosene, diesel, and gas oil. The furnace is fueled by NSPS Subpart J quality gas. It was installed in 1991. On May 22, 2001 and September 12, 2002, this source was tested for NO_x emissions using EPA Reference Method 7E pursuant to §19.702 of Regulation 19, and 40 C.F.R., Part 52, Subpart E.

SN-805 is a 75 MM Btu/hr furnace (nominal design) used to heat the bottoms from the Atmospheric Column in order to separate them into gas oil and asphalt products in the Vacuum Column. The furnace is fueled by NSPS Subpart J quality gas. It was installed in 1996. On May 17, 2000, this source was

tested for NO_x emissions using EPA Reference Method 7E pursuant to §19.702 of Regulation 19, and 40 C.F.R., Part 52, Subpart E. The test results submitted to the Department demonstrated compliance.

SN-806 is a 20 MMBtu/hr furnace (nominal design) used to raise the temperature of light straight run (LSR) to reaction. It is fueled with NSPS Subpart J quality gas. It was installed in 1958. This source was declared subject to NSPS Subpart J as a result of the Consent Decree (CIV. No. 03-1028) between Lion Oil, ADEQ, and the US EPA.

SN-808 is a 56 MMBtu/hr furnace (nominal design) used to heat gas oil. It is fueled by NSPS Subpart J quality gas. It was installed in 1979.

SN-810 is a 70 MMBtu/hr furnace (nominal design) used to heat naphtha. It is fueled NSPS Subpart J quality gas. It was installed in 1958. This source was declared subject to NSPS Subpart J as a result of the Consent Decree (CIV. No. 03-1028) between Lion Oil, ADEQ, and the US EPA.

SN-811 is a 170 MMBtu/hr furnace (nominal design) used to heat the #9 Unit Stripper bottoms. It is fueled by NSPS Subpart J quality gas. It was installed in 1980.

SN-812 is a 25 MMBtu/hr furnace/reboiler (nominal design) used to heat platformate in order to remove low molecular weight gases. It is fueled by NSPS Subpart J quality gas. It was installed in 1958. This source was declared subject to NSPS Subpart J as a result of the Consent Decree (CIV. No. 03-1028) between Lion Oil, ADEQ, and the US EPA.

SN-813a is a 17.9 MMBtu/hr furnace (nominal design) used to heat light cycle oil, diesel, kerosene, and gas oil. It is fueled by NSPS Subpart J quality gas. It was installed in 2005. This source utilizes ultra-low-NO_x burners for NO_x emissions control.

SN-814 is a 32 MMBtu/hr furnace (nominal design) used to heat asphalt from the bottom of the extraction tower. It is fueled by NSPS Subpart J quality gas. It was installed in 1958. This source was declared subject to NSPS Subpart J as a result of the Consent Decree (CIV. No. 03-1028) between Lion Oil, ADEQ, and the US EPA.

SN-825 is the combined emissions of three furnaces used to maintain the required temperature during the blowing operation. They have a combined heat input of 30 MMBtu/hr (nominal design) and are fueled by NSPS J quality gas. Two of the furnaces were installed in 1945. The other was installed in 1946. The blowing stills associated with the furnaces are not subject to 40 C.F.R., Subpart UU-*Standards of Performance for Standards of Performance for Asphalt Processing and Asphalt Roofing Manufacture* because they were constructed prior to the effective date.

SN-828 is a 10 MMBtu/hr boiler (nominal design) used to heat asphalt products during truck loading. It is fueled by NSPS Subpart J quality gas. It was installed in 1987.

SN-830 is a 1.8 MMBtu/hr furnace (nominal design). It is fueled by NSPS Subpart J quality gas. It was installed in 1987.

SN-842 is a 50.0 MMBtu/hr furnace (nominal design). It is fueled by NSPS Subpart J quality gas. It was installed in 1993.

SN-843 was a 34.0 MMBtu furnace (nominal design). It was removed from service in 2005.

SN-850 is a 20.0 MMBtu/hr heater (nominal design) used to supply heat to the hot oil system which maintains the elevated temperatures of stored asphalt products so that the material will flow without solidifying. This source was installed in 1998. It is fueled by NSPS Subpart J quality gas. This source is subject to 40 C.F.R. 60, Subpart Dc-Standards of Performance for Small Industrial Commercial Institutional Steam Generating Units.

SN-857 is rated at 53.4 MMBtu/hr. It is fueled by NSPS Subpart J quality gas.

SN-860 is rated at 43.6 MMBtu/hr. It is fueled by NSPS Subpart J quality gas.

SN-861 is rated at 20.0 MMBtu/hr. It is fueled by NSPS Subpart J quality gas.

SN-862 is a 35.2 MMBtu/hr fuel gas-fired hot oil heater (nominal design) and associated hot oil system for temperature control of asphalt tank T-112.

Specific Conditions

1. The permittee shall not exceed the emission rates set forth in the following table. Compliance with the limits for the following sources shall be demonstrated by compliance with Subpart J and the fuel and Btu limits or with other available emissions data for these sources. [Regulation No. 19 §19.501 *et seq.* effective May 28, 2006, and 40 CFR Part 52, Subpart E]

SN	Source Description	Pollutant	lb/hr	tpy
802		PM_{10}	1.0	4.4
803		SO_2	1.7	5.9
	#4 Pre-flash Column Reboiler	VOC	1.0	4.4
		CO	4.3	14.5
		NO_X	7.3	24.6
804		PM_{10}	2.2	7.3
004		SO_2	9.7	32.6
	#4 Atmospheric Topping Furnace	VOC	1.6	5.2
		CO	23.7	80.1
		NO_X	12.9	43.7
805		PM_{10}	1.0	4.4
805		SO_2	3.3	11.1
	#4 Vacuum Furnace	VOC	1.0	4.4
		CO	8.0	27.1
		NO _X	7.9	26.7
806		PM_{10}	1.0	4.4
800		SO_2	1.3	4.4
	#6 Hydrotreater Furnace/Reboiler	VOC	1.0	4.4
		CO	3.2	10.9
		NO _x	5.5	18.4

 Table 11 – Subpart J Units Criteria Emissions

SN	Source Description	Pollutant	lb/hr	tpy
808		PM ₁₀	1.0	4.4
000		SO_2	2.4	8.3
	#7 FCCU Furnace	VOC	1.0	4.4
		CO	6.0	20.3
		NO _X	8.0	27.1
810		PM_{10}	1.0	4.4
810		SO_2	3.1	10.3
	#9 Hydrotreater Furnace/Reboiler	VOC	1.0	4.4
		CO	7.5	25.3
		NO _X	12.7	43.0
		PM_{10}	1.5	5.6
		SO_2	6.8	25.2
811	#9 Reformer Furnace	VOC	1.1	4.4
		CO	16.6	61.6
		NO _X	20.2	74.7
		PM_{10}	1.0	4.4
		SO_2	1.1	4.4
812	#9 Stabilizer Reboiler	VOC	1.0	4.4
		CO	2.7	9.0
		NO _x	4.6	15.4
		PM_{10}	0.6	2.0
		SO_2	0.8	3.0
813a	#10 Hydrotreater Furnace/Reboiler	VOC	0.4	1.4
		CO	2.0	7.2
		NO _x	0.9	3.1
		PM_{10}	1.0	4.4
		SO_2	1.4	4.7
814	#11 Deasphalting Furnace	VOC	1.0	4.4
		CO	3.4	11.6
		NO _x	5.8	19.7
		PM_{10}	1.0	4.4
		SO_2	1.3	4.4
825	#16 Asphalt Blowing Furnaces	VOC	1.0	4.4
		CO	3.2	10.9
		NO _x	5.5	18.4
		PM_{10}	1.0	4.4
		SO_2	1.0	4.4
828	Asphalt Rack Steam Heater	VOC	1.0	4.4
		CO	1.1	4.4
		NO _x	1.8	6.1

SN	Source Description	Pollutant	lb/hr	tpy
		PM ₁₀	1.0	4.4
		SO_2	1.0	4.4
830	Regenerant Furnace	VOC	1.0	4.4
		CO	1.0	4.4
		NO _X	1.0	4.4
		PM_{10}	1.0	4.4
		SO_2	2.2	7.4
842	#12 Distillate Hydrotreater Furnace	VOC	1.0	4.4
		CO	5.4	18.1
		NO _X	5.3	17.8
843	#10 Stripper Reboiler Furnace	Removed Fr	om Servi	ice
		PM ₁₀	1.0	4.4
		SO_2	1.0	4.4
850	Asphalt Hot Oil Heater	VOC	1.0	4.4
		CO	2.1	7.2
		NO _X	3.6	12.3
		PM ₁₀	1.2	4.4
		SO_2	2.1	7.9
857	Naphtha Splitter Reboiler	VOC	0.9	3.2
		CO	5.2	19.3
		NO _X	2.2	8.2
		PM_{10}	1.0	3.6
		SO_2	1.7	6.5
860	ULSD Hydrotreater Heater	VOC	0.7	2.6
		CO	4.2	15.8
		NO _X	1.8	6.7
		PM_{10}	0.4	1.4
		SO_2	0.7	2.4
861	Hydrogen Plant Heater(s)	VOC	0.3	1.0
		CO	1.7	5.8
		NO _X	0.7	2.5
		PM ₁₀	0.4	1.2
		SO_2	1.6	5.3
862	Hot Oil Heater	VOC	0.3	0.9
		CO	3.8	12.8
		NO _X	3.3	11.0

 The facility shall not exceed the annual Btu limits for the sources set forth in the following table. Compliance with this condition shall be demonstrated by compliance with Specific Condition #1. [§19.705 of Regulation 19, A.C.A. §8-4-203 as referenced by §8-4-304 and §8-4-311, and 40 C.F.R. §70.6]

SN	Annual Limit
	(MMBtu/12 months)
803	351,360
804	1,943,021
805	658,800
806	263,520
808	491,904
810	614,880
811	1,493,280
812	219,600
813a	173,045
814	281,088
830	15,811
842	439,200
843	298,656
850	175,680
857	469,066
860	382,982
861	140,544

Table 12 Subpart J Units Annual BTU Limits

- 3. Records of Btus shall be maintained on a twelve-month rolling basis for the sources listed in Specific Condition #2. These records shall be updated monthly. These records shall include the fuel combusted (natural gas or NSPS J quality gas) and heat duty (amount of gas x heating value). The permittee shall analyze the BTU content of the fuel gas on a monthly basis. The records of BTU usages shall be maintained on site and submitted in accordance with General Provision #7. [§19.705 of Regulation 19, and 40 C.F.R., Part 52, Subpart E]
- 4. The facility shall not exceed 5% opacity from the sources in this section. Compliance with this limit shall be demonstrated by burning pipeline natural gas or other gaseous fuel with an H₂S concentration less than 1,500 ppmvd. If the H₂S concentration exceeds 1500 ppmvd, then the facility shall comply with Specific Condition #5. [§18.501 of Regulation 18, and A.C.A. §8-4-203 as referenced by §8-4-304 and §8-4-311]
- 5. During those times in which the H₂S content of the refinery fuel gas combusted on-site exceeds 1500 ppmvd, the facility shall conduct an opacity observation for those sources which are permitted to combust NSPS Subpart J quality gas. These observations shall be conducted by someone who is familiar with the visible emissions from these sources. Any sources which

generate visible emissions during these periods shall be considered to be in violation of the 5% opacity standard for that source. Records of these observations shall be maintained on-site, and shall be made available to the Department upon request These records shall indicate the date and time of the observation, the name of the person making the observation, whether or not any visible emissions are detected, and a list of any sources (by SN) for which visible emissions were noted. [§18.501 of Regulation 18 and A.C.A. §8-4-203 as referenced by §8-4-304 and §8-4-311]

6. Under the terms of 40 C.F.R. Part 60 Subpart Dc-Standards of Performance for Small Industrial-Commercial-Institutional Steam Generating Units, SN-850 and 862 are affected facilities (see Appendices D and E). [§19.304 of Regulation 19 and 40 C.F.R. §60.40c]

In lieu of §60.48c(g), in which the owner or operator of each facility shall record and maintain records of the amounts of each fuel combusted during each day, the facility through a letter of approval from John R. Hepola, Chief, Air/Toxics and Inspection Coordination Branch, EPA to Thomas Rheaume of the Arkansas Department of Environmental Quality dated February 9, 1999, may record and maintain records of the amounts of each fuel combusted during each month.

- 7. All sources listed in Specific Condition 1 are affected facilities under the provisions of 40 C.F.R. 60, Subpart J-Standards of Performance for Petroleum Refineries. As such, these heaters shall burn either pipeline quality natural gas and/or NSPS J quality gas. They are defined in the subpart as fuel gas combustion devices subject to the Subpart J requirements summarized in Plantwide Condition 11 (for the full regulation, see Appendix C). [§19.304 of Regulation 19 and 40 CFR §60.100]
- 8. The permittee shall operate the #4 Atmospheric Furnace (SN-804) such that NO_x emissions to the atmosphere do not exceed 0.045 lb/mmBtu based on a 3-hour average. [§19.501 of Regulation 19, 40 CFR Part 52 Subpart E, and Paragraph 16(D) of the consent agreement between Lion Oil, the US EPA, and ADEQ]
- 9. The permittee shall operate a CEM system in the #4 Atmospheric Furnace (SN-804) exhaust stack for the purposes of monitoring NO_x emissions. The data from this monitor shall be recorded and compiled in order to demonstrate compliance with the 3 hour average 0.045 lb/mmBtu NO_x limit contained in Specific Condition #8. [§19.501 of Regulation 19, 40 CFR Part 52 Subpart E, and Paragraph 16(D) of the Consent Decree (CIV. No. 03-1028) between Lion Oil, the US EPA, and ADEQ]
- 10. The fuel combusted in the #4 atmospheric furnace shall be sampled at least three times per calendar week in order to determine the higher heating value (HHV) and F-factor for the purposes of calculating the lb/mmBtu NO_x emissions using US EPA Method 19 as required by Specific Conditions #8 and #11. Records of the sample results shall be maintained on-site, and shall be made available to Department personnel upon request. [§19.705 of Regulation 19 and 40 CFR Part 52 Subpart E]
- 11. All CEMs in use at the facility shall be operated in accordance with the Department's CEM Conditions (see Appendix K). The facility shall submit CEM data in accordance with the Department's conditions. CEM data shall be submitted in ppm for the refinery gas H₂S analyzers for SN's 803-806, 808, 810-814, 828-830, 842, and 850. The NO_X CEM data for SN-804 shall be submitted in lb NO_x/mmBtu. [§19.705 of Regulation 19, and 40 C.F.R., Part 52, Subpart E]

- 12. The new #10 Furnace/Reboiler (SN-813a), Naphtha Splitter Reboiler Heater (SN-857), ULSD Hydrotreater Heater (SN-860), and the new Hot Oil Heater (SN-862) is subject to and shall comply with all applicable provisions of 40 CFR Part 63 Subpart DDDDD National Emission Standards for Hazardous Air Pollutants for Industrial, Commercial, and Institutional Boilers and Process Heaters (Appendix N). Each of these sources is considered a "large gaseous fuel process heater." The initial compliance requirements of this subpart as they apply to these sources are summarized below. [§19.304 of Regulation 19 and 40 CFR §63.7485]
 - a. Each source shall meet the work practice standard for CO of 400 ppmvd corrected to 3% oxygen (3-run average). [§63.7500(a)(1)]
 - b. Each source shall comply with the work practice standard at all times, except during periods of startup, shutdown, and malfunction. Initial compliance with the work practice standard shall be demonstrated no later than 180 days after startup of the source. [§63.7505(a) and §63.7510(g)]
 - c. Each source shall be operated and maintained in accordance with the provisions of §63.6(1)(i). [§63.7505(b)]
 - d. The permittee shall develop and implement a written startup, shutdown, and malfunction (SSM) plan for operations at each source. [§63.7505(e)]
 - e. The permittee shall conduct an initial performance test for CO from each source in accordance with Table 5 of Subpart DDDDD. This test shall be performed at the maximum operating load, and shall meet the following requirements: [§63.7510(c) and §63.7520(d)]
 - i. All testing shall be conducted in accordance with §63.7(c), (d), (f), and (h). [§63.7520(a)]
 - ii. A site-specific test plan shall be developed in accordance with §63.7(c).[§63.7520(a)]
 - iii. Performance testing shall not be conducted during periods of startup, shutdown, or malfunction. [§63.7520(e)]
 - iv. Three separate runs shall be conducted for each performance test, as specified in §63.7(e)(3). Each run must last at least one (1) hour. [§63.7520(f)]
 - f. The permittee shall submit all applicable notifications in §63.7(b) and (c), §63.8(e), (f)(4), and (6), and §63.9(b) through (h) by the dates specified. [§63.7545(a)]
 - g. The permittee shall submit an initial notification to the Department not later than 15 days after the actual date of startup of each source. [§63.7545(c)]
 - h. The permittee shall submit a notification of intent to conduct performance testing at least fifteen (15) days prior to the date the testing is scheduled to begin. [§63.7545(d)]

The permittee shall submit a notification of compliance status according to \$63.9(h)(2)(ii). This notification shall include all performance test results, and shall be submitted by the close of business on the 60th day following the completion of the performance tests according to \$63.10(d)(2). The notification of compliance must contain all of the information specified in \$63.7545(e)(1) through (9) as applicable. [\$63.7545(e)]

SN-809 - #7 FCCU Catalyst Regenerator Stack

Source Description

SN-809 is the exhaust stack from the catalyst regenerator. Hot flue gas leaving the regenerator passes through three sets of cyclones to remove catalyst fines and then is used to produce steam in the waste heat boiler before exiting the stack. This source was installed in 1973.

The #7 FCCU was modified in 2004 to install a wet gas scrubber for the control of PM_{10} and SO_2 emissions. Simultaneous with the installation of the scrubber, the facility also accepted a limit of 500 ppmdv (1-hour average) and 100 ppmdv (365-day rolling average) as required by the Consent Decree (CIV. No. 03-1028) reached between Lion Oil, the US EPA, and ADEQ. CEMs were installed to monitor the stack concentrations of SO_2 , CO, and O_2 .

Regulations

As of December 31, 2004, the Fluid Catalytic Cracking Unit (FCCU) is subject to 40 C.F.R., Part 60, Subpart J-Standards of Performance for Petroleum Refineries.

The Fluid Catalytic Cracking Unit (FCCU) is subject to 40 C.F.R., Part 63, Subpart UUU-National Emission Standards for Hazardous Air Pollutants for Petroleum Refineries: Catalytic Cracking Units, Catalytic Reforming Units, and Sulfur Recovery Units.

CAM (40 CFR Part 64) parametric monitoring is not required for this unit at this time due to its status as an existing unit, as well as the presence of CEM systems in the FCCU exhaust stack.

Specific Conditions

13. The permittee shall not exceed the emission rates set forth in the following tables. The permittee shall comply with the emission limits contained in the table below. Compliance with these limits shall be demonstrated by compliance with the throughput limits, monitoring requirements for this source or with other available emissions data for these sources. [§19.501 of Regulation 19 et seq., and 40 C.F.R., Part 52, Subpart E]

SN #	Source Description	Pollutant	lb/hr	Тру
800	#7 Catalyst Pagaparator Stack	PM_{10}	7.5	32.9
809	#7 Catalyst Regenerator Stack	SO_2	26.5	58.3
		VOC	183.3	805.2
		СО	116.0	101.9
		NO _X	59.2	259.9

Table 13 - #7 FCCU Catalyst Regenerator Stack Criteria Emissions

14. The facility shall not exceed 20% opacity from this source. Compliance with this condition will be demonstrated by compliance with 40 CFR Part 60 Subpart J, the operation of the wet gas scrubber (WGS), and compliance with any alternative monitoring provision approved for this source by the US EPA. [§18.501 of Regulation 18, and A.C.A. §8-4-203 as referenced by §8-4-304 and §8-4-311]

- 15. On and after December 31, 2004, the FCCU exhaust shall meet the following outlet emissions limitations. [§19.501 et seq., 40 CFR Part 52 Subpart E, and Paragraphs 12(B), 13(B), and 14(B) of the Consent Decree (CIV. No. 03-1028)between Lion Oil, ADEQ, and the US EPA]
 - a. For SO_2 :
 - i. No more than 25 ppmvd based on a 365-day rolling average, corrected to 0% oxygen.
 - ii. No more than 50 ppmvd based on a 7-day rolling average, corrected to 0% oxygen
 - iii. Exceptions to the SO₂ limits above occur during periods of startup and shutdown of the FCCU, and Malfunction of the WGS, provided that good air pollution control practices are instituted during such events.
 - b. For PM:
 - i. No more than 0.5 pounds of particulate matter (PM) per 1000 pounds of coke burned, on a 3-hour average basis except during periods of startup and shutdown of the FCCU, and Malfunction of the WGS, provided that good air pollution control practices are instituted during such events.
 - c. For CO:
 - i. 500 ppmvd corrected to $0\% O_2$, over a 1-hour averaging period.
 - ii. 100 ppmvd corrected to 0% O₂ as a rolling 365-day average.
 - iii. Exceptions to the CO limits above occur during periods of startup, shutdown, and Malfunction of the FCCU, provided that good air pollution control practices are instituted during such events.
- 16. On and after December 31, 2004, the permittee shall use a NOx CEMS to monitor performance of the FCCU, and subsequently, the Lo Tox System, and to report compliance with the terms and conditions of the Consent Decree (CIV. No. 03-1028). [§19.702, A.C.A. §8-4-203 as referenced by §8-4-304 and §8-4-311, 40 CFR §70.6, and Paragraph 11(F) of the Consent Decree (CIV. No. 03-1028) between Lion Oil, ADEQ, and the US EPA]
- 17. The permittee shall perform stack testing during the next turn down event after the installation of the WGS in order to examine the capability of the WGS to meet the limit of 0.5 lb PM per 1000 lb coke (3-hr average). The permittee shall perform this stack testing under two scenarios, at 90% (max) capacity and at a low throughput rate. Based on the low throughput testing, this emission limitation may be modified during turn down events. Any such modification in the emission limit must first be approved by the Department in writing. This testing shall be performed according to EPA Reference Method 5B. This testing shall be performed no later than December 31, 2004. The permittee shall submit a report of the results of this testing to the Department no later than 90 days after the scheduled turn down event. This testing was

successfully completed on December 17, 2004. [§19.702 of Regulation 19, 40 CFR Part 52 Subpart E, and Paragraph 13 of the Consent Decree (CIV. No. 03-1028)]

- 18. On December 31, 2004, the FCCU became an affected facility under the terms of 40 CFR Part 60 Subpart J Standards of Performance for Petroleum Refineries. The requirements of this subpart as they apply to this source are summarized below. [§19.304 of Regulation 19 and 40 CFR §60.100 and Paragraph 15 of the Consent Decree (CIV. No. 03-1028)]
 - a. The permittee shall not discharge from the #7 FCCU Catalyst Regenerator Stack (SN-809) any gases which contain particulate matter (PM) in excess of 2.0 lb/ton of coke burn-off in the catalyst regenerator. [§60.102(a)(1)]
 - b. The permittee shall not discharge from the #7 FCCU Catalyst Regenerator Stack (SN-809) any gases which exhibit an opacity greater than 30% except for one six-minute average opacity reading in any one hour period. [§60.102(a)(2)]
 - c. The permittee shall not discharge from the #7 FCCU Catalyst Regenerator Stack (SN-809) any gases which contain carbon monoxide (CO) in excess of 500 ppmvd.
 [§60.103(a)]
 - d. The permittee shall operate an add-on control device (WGS) to reduce SO₂ emissions to the atmosphere from the #7 FCCU Catalyst Regenerator Stack (SN-809) to a level below 50 ppmvd. Compliance with this limit shall be determined daily on a rolling 7-day basis. A minimum of 22 valid days of data shall be obtained every 30 rolling successive calendar days. [§60.104(b)(1), 60.104(c), and §60.104(d)]
 - e. Continuous emission monitoring (CEM) systems shall be installed, certified, calibrated, maintained, and operated in the #7 FCCU Catalyst Regenerator Stack (SN-809) by the permittee as summarized below.
 - i. Lion Oil shall make CEMS data available to EPA upon demand as soon as practicable.:
 - ii. The permittee has applied for approval from the US EPA for an alternative monitoring plan to demonstrate compliance with particulate matter control pursuant to Subpart J. If the administrator grants approval of this request, then the facility shall operate in compliance with the plan at all times, and a copy of the approval letter, as well as the alternative monitoring plan, shall be maintained along with this permit at the facility. If approval of the alternative monitoring plan is not granted, then the facility shall install a continuous opacity monitoring (COM) system in accordance with the requirements of Subpart J. [§60.105(a)(1)]
 - A CEM system shall be installed for the continuous monitoring and recording of the concentration by volume (dry basis) of CO emissions to the atmosphere from the #7 FCCU Catalyst Regenerator Stack. The span value for this system shall be 1,000 ppm CO. [§60.105(a)(2)]

- iv. A CEM system shall be installed for the continuous monitoring and recording of the concentration by volume (dry basis) of SO₂ emissions to the atmosphere from the #7 FCCU Catalyst Regenerator Stack (SN-809). The span value for this system shall be 100 ppm SO₂. [§60.105(a)(9)]
- v. A CEM system shall be installed for the continuous monitoring and recording of the concentration by volume of oxygen (O₂) in the #7 FCCU Catalyst Regenerator Stack (SN-809). The span value for this system shall be 10 percent. [§60.105(a)(10)]
- vi. The SO₂ and O₂ CEM systems operated in the #7 FCCU Catalyst Regenerator Stack (SN-809) shall be operated and data recorded during all periods of operation of the FCCU including periods of startup, shutdown, or malfunction, except for CEM system breakdowns, repairs, calibration checks, and zero and span adjustments [§60.105(a)(11)]
- vii. The permittee shall use the following procedures to evaluate the SO₂ and O₂ CEM systems operated in the #7 FCCU Catalyst Regenerator Stack (SN-809).
 - 1. Method 3 or 3A and Method 6 or 6C for the relative accuracy evaluations under the §60.13(e) performance evaluation. [§60.105(a)(12)(i)]
 - 2. Appendix F, Procedure 1, including quarterly accuracy determinations and daily calibration drifts. [§60.105(a)(12)(ii)]
- viii. For the purposes of complying with the 50 ppmvd SO₂ emission limit, when emission data are not obtained because of CEM system breakdowns, repairs, calibration checks, and zero and span adjustments, emission data will be obtained by using one of the following methods to provide emission data for a minimum of 18 hours per day in a least 22 out of 30 rolling successive calendar days. [§60.105(a)(13)]
 - 1. The test methods as described in §60.106(k);
 - 2. A spare CEM system; or
 - 3. Other monitoring systems as approved by the Administrator.
- ix. The average coke burn-off rate (tons per hour) shall be recorded daily for the #7 FCCU Catalyst Regenerator. [§60.105(c)]
- x. For the purpose of reports under §60.7(c), periods of excess emissions that shall be determined and reported are defined as follows: [§60.105(e)]
 - 1. For Opacity (only applies if COM is used): All 1-hour periods that contain two or more 6-minute periods during which the average opacity as measured by the COM system exceeds 30 percent.

- 2. For CO: All 1-hour periods during which the average CO concentration measured by the CEM system exceeds 500 ppmvd corrected to zero percent O₂.
- f. The permittee shall record and maintain the following information pertaining to the SO₂ monitoring requirements for the #7 FCCU Catalyst Regenerator Stack (SN-809). [§60.107(b)]
 - i. All data and calibrations from the SO₂ CEM system, including the results of the daily drift tests and quarterly accuracy assessments required under Appendix F, Procedure 1;
 - ii. Measurements obtained by supplemental sampling for meeting minimum data requirements; and
 - iii. The written procedures for the quality control program required by Appendix F, Procedure 1.
- g. The permittee shall submit a report on the SO₂ CEM system which contains all of the information required by §§60.107(c) and (d). This report shall be submitted to the Department in accordance with the Department CEM Conditions (Appendix K). [§§60.107(c), (d), and (e)]
- h. The owner or operator of the facility shall submit a signed statement certifying the accuracy and completeness of the information contained in the report. [§60.107(f)]
- 19. All CEMS shall be operated in accordance with the Department's CEM Conditions. The facility shall submit CEM data in accordance with the Department's standards. A copy of these standards has been attached as Appendix K. [§19.703 of Regulation 19, 40 CFR Part 52 Subpart E, and A.C.A. §8-4-203 as referenced by §8-4-304 and §8-4-311
- 20. SN-809 (the FCCU) is an affected facility under the terms of 40 C.F.R., Part 63, Subpart UUU-National Emission Standards for Hazardous Air Pollutants for Petroleum Refineries: Catalytic Cracking Units, Catalytic Reforming Units, and Sulfur Recovery Units. The applicable requirements of this subpart are summarized in Plantwide Condition 12. [§19.304 of Regulation 19 and 40 CFR §63.1561]

SN-848 - #7 FCCU Catalyst Hopper Vents

Source Description

SN-848 is the vent system for two storage bins used to store catalyst in the catalytic cracking process. It was installed in 1973.

Specific Conditions

21. The permittee shall not exceed the emission rates set forth in the following table. Compliance with these limits shall be demonstrated by compliance with the throughput limits of this section. [Regulation No. 19 §19.501 and A.C.A. §8-4-203 as referenced by §8-4-304 and §8-4-311]

Table 14 - #7 FCCU Catalyst Hopper Vents Criteria Emissions

SN#	Source Description	Pollutant	lb/hr	Тру
848	#7 FCCU Catalyst Hopper Vents	PM ₁₀	25.0	1.8

- 22. The total throughput of catalyst at this source shall be limited to 3,650 tons per consecutive twelve month period. [§19.705 of Regulation 19, A.C.A. §8-4-203 as referenced by §8-4-304 and §8-4-311, and 40 C.F.R. §70.6]
- 23. Records of the amount of catalyst shall be maintained on a twelve month rolling basis, updated monthly. Records of the catalyst throughput shall be maintained on site and submitted in accordance with General Provision #7. [§19.705 of Regulation 19, and 40 C.F.R., Part 52, Subpart E]

ALTERNATE OPERATING SCENARIO - FCCU PORTABLE AIR COMPRESSORS

During periods of startup, shutdown and/or malfunction, or for purposes of conducting scheduled or emergency maintenance on the fluid catalytic cracking unit when the electric air compressors are not operating, Lion Oil may utilize portable, diesel-fired air compressors.

Specific Conditions

- 24. The permittee shall not operate the portable compressors for more than 1,560,000 horsepowerhours on an annual basis. [§19.501 of Regulation 19, et seq., and 40 C.F.R., Part 52, Subpart E]
- 25. Lion Oil will record the hours of operation of the air compressors, on a twelve-month rolling basis, updated monthly. Such records shall be maintained on-site and submitted in accordance with General Provision #7. [§19.705 of Regulation 19, and 40 C.F.R., Part 52, Subpart E]

SN-844 - SRP Sulfur Recovery Plant Incinerator

Source Description

The Sulfur Recovery Plant Incinerator is a 20.0 MMBtu/hr incinerator used to incinerate gases from the sulfur recovery plant. It is fueled by pipeline quality natural gas. It was installed in 1994. The incinerator is used to control emissions from the 3 stage sulfur recovery unit (SRU) which is also subject to Subpart J. The SRP is rated at 120 long tons per day (LTD).

Specific Conditions

26. The permittee shall not exceed the emission rates set forth in the following table. Compliance with the limits for SN-844 shall be demonstrated by compliance with Subpart J, the fuel and Btu limits for these sources or with other available emissions data for these sources. [Regulation No. 19 §19.501 and 40 CFR Part 52, Subpart E]

Table 15 - SRP Sulfur Recovery Plant Incinerator Criteria Emissions

SN #	Source Description	Pollutant	lb/hr	Тру
		PM_{10}	12.0	52.7
		SO_2	19.1	53.4
844	Sulfur Recovery Plant Incinerator	VOC 1.5	1.5	6.6
		СО	8.1	35.6
		NO _X	6.0	26.4

27. Any emissions to the atmosphere from any Claus sulfur recovery plant using an oxidation control system or a reduction control system followed by incineration shall not exceed the emission rates set forth in the following table. Compliance with this condition shall be demonstrated by SO₂ emissions data recorded per Subpart J (see Appendix C). [§19.304 of Regulation 19 and 40 C.F.R. §60.104(a)(2)(i)]

Table 16 - SRP Sulfur Recovery Plant Incinerator SO2 Concentration

SN#	Source Description	Pollutant	ppm by volume
844	Sulfur Recovery Plant Incinerator	SO ₂ dry basis	250 (Rolling 12-hour)

28. The facility shall use only pipeline quality natural gas as fuel for SN-844. [§19.705 of Regulation 19, A.C.A. §8-4-203 as referenced by §8-4-304 and §8-4-311, and 40 C.F.R. §70.6]

- 29. The SO₂ and O₂ CEMs in use at SN-844 shall be operated in accordance with the Department's CEM Conditions (see Appendix K). The facility shall submit CEM data in accordance with the Department's conditions. CEM data shall be submitted in ppm, lb/hr, and tpy for SN-844. [§19.705 of Regulation 19, and 40 C.F.R., Part 52, Subpart E]
- 30. SN-844 is an affected facility under the provision of 40 CFR 63, Subpart UUU National Emission Standards for Hazardous Air Pollutants for Petroleum Refineries: Catalytic Cracking

Units, Catalytic Reforming Units, and Sulfur Recovery Units. The UUU requirements are summarize in Plantwide Condition 12. (for the full regulation, see Appendix M)

- 31. The Sulfur Recovery Unit (SRU) is an affected facility under the provision of 40 CFR 60, Subpart J – Standards of Performance for Petroleum Refineries. The applicable Subpart J requirements are summarized below. (for the full regulation, see Appendix C)
 - a. The permittee shall install, calibrate, maintain, and operate an instrument for continuously monitoring and recording the concentration (dry basis, zero percent excess air) of SO_2 emissions into the atmosphere. The monitor shall include an oxygen monitor for correcting the data for excess air. The monitor shall be operated as follows: [\$60.105(a)(5)]
 - i. The span values for this monitor are 500 ppm SO₂ and 25 percent O₂. [60.105(a)(5)(i)]
 - ii. The performance evaluations for this SO₂ monitor under §60.13(c) shall use Performance Specification 2. Methods 6 or 6C and 3 or 3A shall be used for conducting the relative accuracy evaluations. [§60.105(a)(5)(ii)]
 - b. The permittee shall report excess emissions for all 12-hour periods during which the average concentration of SO₂ as measured by the SO₂ continuous monitoring system under §60.105(a)(5) exceeds 250 ppm (dry basis, zero percent excess air). [§60.105(e)(4)(i)]
 - c. For any periods for which sulfur dioxide or oxides emissions data are not available, the permittee shall submit a signed statement indicating if any changes were made in operation of the emission control system during the period of data unavailability which could affect the ability of the system to meet the applicable emission limit. Operations of the control system and affected facility during periods of data unavailability are to be compared with operation of the control system and affected facility before and following the period of data unavailability. [§60.107(d)]
 - d. The permittee shall submit a report on the SO_2 CEM system which contains all of the information required by §§60.107(d). This report shall be submitted to the Department in accordance with the Department CEM Conditions (Appendix K). [§60.107(e)]
 - e. The owner or operator of the facility shall submit a signed statement certifying the accuracy and completeness of the information contained in the report. [§60.107(f)]

> SN-816 - #10 Boiler SN-817 - #11 Boiler SN-818 - #12 Boiler SN-819 - #13 Boiler SN-820 - #14 Boiler

Source Description

SN-816 has been retired from service.

SN-817 has been retired from service.

SN-818 is a 130 MMBtu/hr high pressure boiler (nominal design). The boiler is fueled by pipeline quality natural gas or refinery fuel gas. It was installed in 1952.

SN-819 is a 130 MMBtu/hr high pressure boiler (nominal design). The boiler is fueled by pipeline quality natural gas or refinery fuel gas. It was installed in 1952.

SN-820 is a 130 MMBtu/hr high pressure boiler (nominal design). The boiler is fueled by pipeline quality natural gas or refinery fuel gas. It was installed in 1958.

All five of these boilers are required to be permanently shut down by no later than December 31, 2006. As the units are shut down the conditions in this section expire. The conditions for the replacement boilers become applicable as they come on-line.

Regulations

SN's 816-820 are not subject to 40 C.F.R. 60, Subpart Db-Standards of Performance for Industrial-Commercial-Institutional Steam Generating Units or Subpart Dc-Standards of Performance for Small Industrial-Commercial-Institutional Steam Generating Units because they were installed prior to the effective date of the Subparts.

As a result of the Consent Decree reached between Lion Oil, ADEQ, and the US EPA, SN's 818-820 are currently subject to 40 CFR Part 60, Subpart J.

Specific Conditions

32. The listed sources shall not exceed the emission rates set forth in the following table. Compliance with these limits shall be demonstrated by compliance with the Btu and fuel limits for these sources or with other available emissions data for these sources. [§19.501 of Regulation 19 et seq., and 40 C.F.R., Part 52, Subpart E]

SN#	Source Description	Pollutant	lb/hr	Тру
816	#10 Boiler	Removed from Service		

Table 17 – Old Boilers Criteria Emissions

SN #	Source Description	Pollutant	lb/hr	Тру
817	#11 Boiler	Removed from Service		·
		PM_{10}	1.3	
		SO_2	5.7	
818	#12 Boiler	VOC	1.0	
		СО	13.9	
		NO_X	46.4	
		PM_{10}	1.3	
		SO_2	5.7	
819	#13 Boiler	VOC	1.0	
		СО	13.9	
		NO_X	46.4	
		PM_{10}	1.3	
		SO_2	5.7	
820	#14 Boiler	VOC	1.0	
		СО	13.9	
		NO_X	46.4	
		PM_{10}		22.0
		SO_2		374.5
816-820	#10-#14 Boilers Annual Emissions	VOC		22.0
		СО		223.4
		NO_X		744.9

*Based on the lower range of the gross heating value of the fuel (800 Btu/scf).

33. These sources shall not exceed the annual Btu limit in the following table. [\$19.705 of Regulation 19, A.C.A. \$ 8-4-203 as referenced by \$8-4-304 and \$8-4-311, and 40 C.F.R. \$70.6]

SN # Combined Annual Lin (MMBtu/12 months	
816-820	5,428,512

Table 18 – Old Boilers Annual BTU

- 34. Records of Btus shall be maintained on a twelve-month rolling basis for the sources listed in Specific Condition #33, updated monthly. These records shall include the fuel combusted (natural gas or NSPS J quality gas) and heat duty (amount of gas x heating value). The permittee shall analyze the heating value of the fuel gas on a monthly basis. The records of the BTU usage shall be maintained on site and submitted in accordance with General Provision #7. [§19.705 of Regulation 19, and 40 C.F.R., Part 52, Subpart E]
- 35. The facility shall not exceed 5% opacity from the sources in this section. Compliance with this limit shall be demonstrated by burning pipeline natural gas or other gaseous fuel with an H₂S concentration less than 1,500 ppmvd. If the H₂S concentration exceeds 1500 ppmvd, then the facility shall comply with Plantwide Condition #1. [§18.501 of Regulation 18, and A.C.A. §8-4-203 as referenced by §8-4-304 and §8-4-311]

- 36. During those times in which the H₂S content of the refinery fuel gas combusted on-site exceeds 1500 ppmvd, the facility shall conduct an opacity observation for those sources which are permitted to combust NSPS Subpart J quality gas. These observations shall be conducted by someone who is familiar with the visible emissions from these sources. Any sources which generate visible emissions during these periods shall be considered to be in violation of the 5% opacity standard for that source. Records of these observations shall be maintained on-site, and shall be made available to the Department upon request These records shall indicate the date and time of the observation, the name of the person making the observation, whether or not any visible emissions are detected, and a list of any sources (by SN) for which visible emissions were noted. [§18.501 of Regulation 18 and A.C.A. §8-4-203 as referenced by §8-4-304 and §8-4-311]
- 37. In the event that fuel oil is used at this source, the facility shall maintain records of fuel oil usage including the amount of fuel oil used and the sulfur content of the fuel oil. Records shall be maintained on site and submitted in accordance with Chapter 6 of Regulation 19. [§19.705 of Regulation 19, and 40 C.F.R., Part 52, Subpart E]
- 38. The refinery fuel gas shall be sampled for H₂S concentration no less than twice per month only when the facility is utilizing refinery fuel gas. Otherwise, the facility's CEM system will be used to demonstrate compliance with the H₂S concentration in Specific Condition #34. Records shall be maintained on site and submitted to the Department in accordance with General Provision #7. [§19.705 of Regulation 19, and 40 C.F.R., Part 52, Subpart E]
- 39. The following sources are affected facilities under the provisions of 40 C.F.R. 60, Subpart J-Standards of Performance for Petroleum Refineries: SN's 818, 819, and 820. They are defined in the subpart as fuel gas combustion devices. These sources are all subject to the Subpart J requirements, which are summarized in Specific Condition #35 and Plantwide Condition 11 (for the full regulation, see Appendix C). [§19.304 of Regulation 19 and 40 CFR 60, Subpart J]
- 40. The permittee shall shutdown the five boilers (SN-816, SN-817, SN-818, SN-819, and SN-820) by no later than December 31, 2006. These boilers shall be permanently removed from service and no longer operated beyond this date. [§19.705 of Regulation 19, A.C.A. §8-4-203 as referenced by §8-4-304 and §8-4-311, 40 CFR §70.6, and the terms of the Consent Decree (CIV. No. 03-1028)reached between Lion Oil, ADEQ, and the US EPA]

SN-821a, 821b, 821c - Refinery Boilers (Three Boilers)

Source Description

This source consists of the three new refinery boilers to be installed at the facility as part of the boiler replacement project required by the Consent Decree (CIV. No. 03-1028)reached between Lion Oil, ADEQ, and the US EPA. The total rated heat input capacity for all three boilers will be 605 MMBtu/hr on an annual average basis. Individually the boilers each operate at a maximum of 221.8 MMBtu/hr for a total maximum heat input capacity of 665.5 MM Btu/hr. These boilers are being permitted to burn NSPS Subpart J quality gas, or #2 fuel oil. Each of the boilers will utilize next-generation ultra-low-NO_x burners for NO_x emission control.

Regulations

All three of the refinery boilers are subject to each of the following regulations: 40 CFR Part 60 Subpart Db – Standards of Performance for Industrial-Commercial-Institutional Steam Generating Units, 40 CFR Part 60 Subpart J – Standards of Performance for Petroleum Refineries, and 40 CFR Part 63 Subpart DDDDD – National Emission Standards for Hazardous Air Pollutants for Industrial, Commercial, and Institutional Boilers and Process Heaters.

The emission limitations established for this source were relied upon in a PSD netting analysis. Future increases in these permitted levels may trigger PSD review for these sources.

Specific Conditions

41. The listed sources shall not exceed the emission rates set forth in the following table. The limits given in this table represent the combined emissions from all three boiler exhaust stacks. Compliance with these limits shall be demonstrated by compliance with Specific Conditions #42, #45, #47, #49, #51, #55, #56, #57 or with other available emissions data for these sources. [§19.501 of Regulation 19 *et seq.*, and 40 C.F.R., Part 52, Subpart E]

SN	Source Description	Pollutant	lb/hr	tpy	lb/MMBtu	
821	Three Boilers - burning NSPS Subpart J quality gas	PM_{10}	7.8		0.0117	
		SO_2	22.4		0.0336	
		VOC	9.8		0.0147	
		СО	474.2		0.7126	
		NO_X	20.0		0.0300	
821		PM_{10}	15.7		0.0236	
		SO_2	37.3		0.0561	
	821	Three boilers – burning #2 fuel oil	VOC	20.0		0.0300
		СО	474.2		0.7126	
		NO_X	66.6		0.1000	

Table 19 - Refinery Boilers Criteria Emissions

SN	Source Description	Pollutant	lb/hr	tpy	lb/MMBtu
		PM_{10}		31.1	
	Refinery Boilers - Annual	SO_2		81.3	
821	Emission Limitations (regardless	VOC		39.1	
	of fuel)	СО		123.2	
		NO_X		58.0	

- 42. The facility shall not exceed a total combined annual firing rate of 5,314,320 MMBtu during any consecutive 12-month period at the refinery boilers (SN-821a, 821b, and 821c combined). [§19.705 of Regulation 19 and 40 CFR Part 52 Subpart E]
- 43. Total maximum heat input capacity of the boilers (SN-821a, b, and c) shall not exceed 665.5 MMBtu/hr. Compliance shall be verified by totaling nameplate heat input capacity. [§19.705 of Regulation 19 and 40 CFR Part 52 Subpart E]
- 44. The facility shall analyze the Btu content of all fuels fired in the refinery boilers on a monthly basis. These records shall include the fuel combusted and heat duty (amount of fuel x heating value). The records of Btu content shall be maintained on site and submitted in accordance with General Provision #7. [§19.705 of Regulation 19, and 40 C.F.R., Part 52, Subpart E]
- 45. The facility shall not exceed 5% opacity from the sources in this section. Compliance with this limit shall be demonstrated by burning pipeline natural gas or other gaseous fuel with an H₂S concentration less than 1,500 ppmvd. If the H₂S concentration exceeds 1500 ppmvd, then the facility shall comply with Plantwide Condition #1. [§18.501 of Regulation 18, and A.C.A. §8-4-203 as referenced by §8-4-304 and §8-4-311]
- 46. During those times in which the H₂S content of the refinery fuel gas combusted on-site exceeds 1500 ppmvd, the facility shall conduct an opacity observation for those sources which are permitted to combust NSPS Subpart J quality gas. These observations shall be conducted by someone who is familiar with the visible emissions from these sources. Any sources which generate visible emissions during these periods shall be considered to be in violation of the 5% opacity standard for that source. Records of these observations shall be maintained on-site, and shall be made available to the Department upon request These records shall indicate the date and time of the observation, the name of the person making the observation, whether or not any visible emissions are detected, and a list of any sources (by SN) for which visible emissions were noted. [§18.501 of Regulation 18 and A.C.A. §8-4-203 as referenced by §8-4-304 and §8-4-311]
- 47. The facility shall not exceed 20% opacity from the refinery boilers (SN-821a, b, or c) when burning fuel oil. Compliance with this condition shall be demonstrated by compliance with Specific Condition #48. [§19.503 of Regulation 19 and 40 CFR Part 52 Subpart E]
- 48. During periods of natural gas curtailment when fuel oil is burned as a fuel in the refinery boilers (SN-821), daily observations of the opacity from each of the three refinery boilers shall be performed in accordance with US EPA Reference Method #9. Records of these recordings shall be maintained on-site and made available to Department personnel upon request. [§19.503 of Regulation 19 and 40 CFR Part 52 Subpart E]

- 49. The facility shall use only pipeline quality natural gas or NSPS Subpart J quality gas as fuel for the refinery boilers (SN-821). In the event of pipeline quality natural gas curtailment, emergency, or upset conditions as set forth in Chapter 6 of Regulation 19, the boilers may be fired with fuel oil if fuel gas is unavailable. [§19.705 of Regulation 19, A.C.A. §8-4-203 as referenced by §8-4-304 and §8-4-311, and 40 C.F.R. §70.6]
- 50. In the event that fuel oil is used at this source, the facility shall maintain records of fuel oil usage including the amount of fuel oil used and the sulfur content of the fuel oil. Records shall be maintained on site and submitted in accordance with Chapter 6 of Regulation 19. [§19.705 of Regulation 19, and 40 C.F.R., Part 52, Subpart E]
- 51. The permittee shall not exceed an interim NO_x emission rate of 0.03 lb/MMBtu based on a rolling 3-hour average from any of the three refinery boilers (SN-821a, 821b and 821c).
 [§19.501 et seq. of Regulation 19, 40 CFR Part 52 Subpart E, and the Consent Decree (CIV. No. 03-1028) between Lion Oil, ADEQ, and the US EPA]
- 52. Within 120 days of start-up of the last of the three refinery boilers (SN-821a, 821b, 821c) or within 120 days of December 31, 2006, whichever is sooner, the permittee shall submit a permit application which proposes final NO_x emission limits in lb/MMBtu on a 3-hr average basis. The proposed final emission limits shall be based on actual performance of the boilers as demonstrated by the CEMs and performance tests and shall be low enough to ensure proper operation of the NO_x control technology and high enough to ensure a reasonable certainty of compliance. [Paragraph 16(D) of the Consent Decree (CIV. No. 03-1028)agreement between Lion Oil, ADEQ, and the US EPA]
- 53. The permittee shall not exceed a rolling 12-month average CO emission rate of 0.0570 lb/MMBtu or 123.2 tpy as calculated from the CEM systems. [§19.405(B) and A.C.A. §8-4-203 as referenced by §8-4-304 and §8-4-311]
- 54. The permittee shall install, operate, and maintain continuous emission monitoring (CEM) systems on each of the refinery boiler stacks (SN-821a, 821b, 821c) to monitor stack gas concentrations of CO and NO_x. These CEM systems shall comply with the Department's CEM Conditions (Appendix K). [§19.703 of Regulation 19, 40 CFR Part 52 Subpart E, and A.C.A. §8-4-203 as referenced by §8-4-304 and §8-4-311]
- 55. The refinery boilers (SN-821a, 821b, 821c) are subject to and shall comply with all applicable provisions of 40 C.F.R. 60, Subpart J-Standards of Performance for Petroleum Refineries. They are defined in the subpart as fuel gas combustion devices. The applicable requirements are summarized in Specific Condition #49 and Plantwide Condition #11. (for the full regulation, see Appendix C) [§19.304 of Regulation 19 and 40 CFR §60.100]
- 56. The refinery boilers (SN-821a, 821b, 821c) are subject to and shall comply with all applicable requirements of 40 CFR Part 60 Subpart Db Standards of Performance for Industrial-Commercial-Institutional Steam Generating Units. The applicable requirements are summarized below, for the full text of the regulation see Appendix O. [§19.304 of Regulation 19 and 40 CFR §60.40b]
- a. Affected facilities which also meet the applicability requirements under Subpart J (Standards of performance for petroleum refineries; §60.104) are subject to the particulate matter and nitrogen oxides standards under this subpart and the sulfur dioxide standards under subpart J (§60.104). [§60.40b(c)]
- b. On and after the date on which the initial performance test is completed or is required to be completed under 60.8 of this part, whichever date comes first, no owner or operator of an affected facility that combusts coal, oil, wood, or mixtures of these fuels with any other fuels shall cause to be discharged into the atmosphere any gases that exhibit greater than 20 percent opacity (6-minute average), except for one 6-minute period per hour of not more than 27 percent opacity. [§60.43b(f)]
- c. The owner or operator of an affected facility subject to the opacity standard under §60.43b shall install, calibrate, maintain, and operate a continuous monitoring system for measuring the opacity of emissions discharged to the atmosphere and record the output of the system. [§60.48b(a)]
- d. Except as provided under §60.44b(k) and (l), on and after the date on which the initial performance test is completed or is required to be completed under §60.8 of this part, whichever date comes first, no owner or operator of an affected facility that is subject to the provisions of this section and that combusts oil or natural gas shall cause to be discharged into the atmosphere from that affected facility any gases that contain nitrogen oxides (expressed as NO₂) in excess of 0.1 lb/MMBtu for distillate oil or gas-fired low heat release rate boilers or 0.2 lb/MMBtu for distillate oil or gas-fired high heat release rate boilers. [§§60.44b(a), (l)(1), and (l)(2)]
- e. The nitrogen oxide standards under this section apply at all times including periods of startup, shutdown, or malfunction. [§60.44b(h)]
- f. Compliance with the emission limits under this section is determined on a 30-day rolling average basis. Compliance shall be demonstrated by using the data collected to demonstrate compliance with Specific Condition 51. If the data collected to demonstrate compliance with Specific Condition 51 does not meet the requirements of this section, then Lion may be required to produce records to demonstrate compliance on a 30-day rolling average basis. [§60.44b(i)]
- g. Compliance with the NO_x standard under 60.44b shall be determined through performance testing as specified by 60.46b(e). [60.46b(e)]
- h. To determine compliance with the emission limits for nitrogen oxides required under \$60.44b, the owner or operator of an affected facility shall conduct the performance test as required under \$60.8 using the continuous system for monitoring nitrogen oxides under \$60.48(b). [\$60.46b(e)]
- i. The permittee shall install, calibrate, maintain, and operate a continuous monitoring system, and record the output of the system, for measuring nitrogen oxides emissions discharged to the atmosphere. [§60.48b(b)(1)

- j. The continuous monitoring systems required under paragraph (b) of this section shall be operated and data recorded during all periods of operation of the affected facility except for continuous monitoring system breakdowns and repairs. Data is recorded during calibration checks, and zero and span adjustments. [§60.48b(c)]
- k. The 1-hour average nitrogen oxides emission rates measured by the continuous nitrogen oxides monitor required by paragraph (b) of this section and required under §60.13(h) shall be expressed in ng/J or lb/million Btu heat input and shall be used to calculate the average emission rates under §60.44b. The 1-hour averages shall be calculated using the data points required under §60.13(b). At least 2 data points must be used to calculate each 1-hour average. [§60.48b(d)]
- 1. The procedures under §60.13 shall be followed for installation, evaluation, and operation of the continuous monitoring systems. [§60.48b(e)]
- m. The span value for NO_x must be determined according to 60.48b(e)(2). All span values are rounded to the nearest 500 ppm. Alternatively ADEQ has approved a span value of 100 ppm for the boiler NO_x CEMS. [60.48b(e)(2 and (3)]
- n. When nitrogen oxides emission data are not obtained because of continuous monitoring system breakdowns, repairs, calibration checks and zero and span adjustments, emission data will be obtained by using standby monitoring systems, Method 7, Method 7A, or other approved reference methods to provide emission data for a minimum of 75 percent of the operating hours in each steam generating unit operating day, in at least 22 out of 30 successive steam generating unit operating days. [§60.48b(f)]
- o. The permittee shall submit notification of the date of initial startup, as provided by §60.7. The notification shall include:
 - i. The design heat input capacity of the affected facility and identification of the fuels to be combusted in the facility, and [§60.49b(a)(1)]
 - ii. The annual capacity factor at which the owner or operator anticipates operating the facility based on all fuels fired and based on each individual fuel fired. [§60.49b(a)(2)]
- p. The owner or operator of each affected facility subject to the sulfur dioxide, particulate matter, and/or nitrogen oxides emission limits under §§60.42b, 60.43b, and 60.44b shall submit to the Administrator the performance test data from the initial performance test and the performance evaluation of the CEMS using the applicable performance specifications in appendix B. [§60.49b(b)]
- q. The owner or operator of an affected facility shall record and maintain records of the amounts of each fuel combusted during each day and calculate the annual capacity factor individually for coal, distillate oil, residual oil, natural gas, wood, and municipal-type solid waste for the reporting period. The annual capacity factor is determined on a 12-month rolling average basis with a new annual capacity factor calculated at the end of each calendar month. [§60.49b(d)]

- r. The owner or operator of an affected facility subject to the nitrogen oxides standards under §60.44b shall maintain records of the following information and submit the following in required semi-annual reports for each steam generating unit operating day: [§60.49b(g) and (i)]
 - i. Calendar date
 - ii. The average hourly nitrogen oxides emission rates (expressed as NO₂) (ng/J or lb/million Btu heat input) measured or predicted.
 - The 30-day average nitrogen oxides emission rates (ng/J or lb/million Btu heat input) calculated at the end of each steam generating unit operating day from the measured or predicted hourly nitrogen oxide emission rates for the preceding 30 steam generating unit operating days. Compliance with the 0.1 lb/MMBtu NO_x emission limit shall be demonstrated by using the data collected to verify compliance with Specific Condition 51. If the data collected to demonstrate compliance with Specific Condition 51 does not meet the 0.1 lb/MMBtu NO_x limit, then Lion may be required to produce records to demonstrate compliance with the NSPS 30-day average requirement for NO_x.
 - iv. If compliance with Specific Condition 51 is not met, then Lion may be required to produce records to demonstrate compliance with the NSPS 30-day average requirement for NO_x .
 - v. Identification of the steam generating unit operating days when the calculated 30day average nitrogen oxides emission rates are in excess of the nitrogen oxides emissions standards under §60.44b, with the reasons for such excess emissions as well as a description of corrective actions taken.
 - vi. Identification of the steam generating unit operating days for which pollutant data have not been obtained, including reasons for not obtaining sufficient data and a description of corrective actions taken.
 - vii. Identification of the times when emission data have been excluded from the calculation of average emission rates and the reasons for excluding data.
 - viii. Identification of "F" factor used for calculations, method of determination, and type of fuel combusted.
 - ix. Identification of the times when the pollutant concentration exceeded full span of the continuous monitoring system.
 - x. Description of any modifications to the continuous monitoring system that could affect the ability of the continuous monitoring system to comply with Performance Specification 2 or 3.
 - xi. Results of daily CEMS drift tests and quarterly accuracy assessments as required under appendix F, Procedure 1.

- s. The permittee shall submit excess emission reports for any excess emissions that occurred during the reporting period. For purposes of 60.48b(g)(1), excess emissions are defined as any calculated 30-day rolling average NO_x emission rate, as determined under 60.46b(e), which exceeds the applicable emission limit in 60.44b. [60.49b(h)]
- t. All records required under this section shall be maintained by the owner or operator of the affected facility for a period of 2 years following the date of such record. [§60.49b(o)]
- u. The reporting period for the reports required under this subpart is each 6 month period. All reports shall be submitted to the Administrator and shall be postmarked by the 30th day following the end of the reporting period. The 6 month period may coincide with Lion's current semi-annual monitoring reporting (January 1st – June 30th and July 1st – December 31st). [§60.49b(w)]
- 57. The refinery boilers (SN-821a, 821b, 821c) are subject to and shall comply with all applicable requirements of 40 CFR Part 63 Subpart DDDDD National Emission Standards for Hazardous Air Pollutants for Industrial-Commercial-Institutional Boilers and Process Heaters. The applicable requirements are summarized below, for the full text of the regulation see Appendix N). [§19.304 of Regulation 19 and 40 CFR §63.7485]
 - a. Each boiler shall comply upon startup. [§63.7495]
 - b. CO emissions must meet the work practice standard of 400 ppm on a dry basis at 3% O₂ (3-run average). [§63.7500(a)(1)]
 - c. Compliance with the work practice standards must be met at all times, except periods of startup, shutdown, and malfunction. [§63.7505(a)]
 - d. The source shall be operated and maintained, including air pollution control and monitoring equipment, according to the provisions in §63.6(e)(1)(i). [§63.7505(b)]
 - e. If you demonstrate compliance with any applicable emission limit through performance testing, you must develop a site-specific monitoring plan according to the requirements in paragraphs (d)(1) through (4) of this section. This requirement also applies to you if you petition the EPA Administrator for alternative monitoring parameters under §63.8(f). [§63.7505(d)]
 - f. For each CMS required, the permittee must develop and submit to the EPA Administrator for approval a site specific monitoring plan (SSMP) at least 60 days before the initial performance test. The site specific monitoring plan must address the following: [§63.7505(d)(1)]
 - i. Installation of the CMS sampling probe or other interface at a measurement location relative to each affected process unit such that the measurement is representative of control of the exhaust emissions (*e.g.*, on or downstream of the last control device);

- ii. Performance and equipment specifications for the sample interface, the pollutant concentration or parametric signal analyzer, and the data collection and reduction systems; and
- iii. Performance evaluation procedures and acceptance criteria (*e.g.*, calibrations).
- g. In the site specific monitoring plan, the permittee must address the following: [§63.7505(d)(2)]
 - i. Ongoing operation and maintenance procedures in accordance with the general requirements of (c)(1), (c)(3), and (c)(4)(ii);
 - ii. Ongoing data quality assurance procedures in accordance with the general requirements of §63.8(d); and
 - iii. Ongoing recordkeeping and reporting procedures in accordance with the general requirements of (0, (e)), (e)(1), and (e)(2)(i).
- h. The permittee shall perform a performance evaluation of each CMS in accordance with the site specific monitoring plan. [§63.7505(d)(3)]
- i. The permittee shall operate and maintain the CMS in continuous operation according to the site specific monitoring plan. [§63.7505(d)(4)]
- j. The permittee shall develop and implement a written startup, shutdown, and malfunction plan (SSMP) according to §63.6(e)(3). [40 CFR §63.7505(e)]
- k. For affected sources that have an applicable work practice standard, the initial compliance requirements depend on the subcategory and rated capacity of the boiler or process heater. If the boiler or process heater is in any of the large subcategories and has a heat input capacity of 100 MMBtu per hour or greater, the initial compliance demonstration is conducting a performance evaluation of the continuous emission monitoring system for carbon monoxide according to §63.7525(a). [§63.7510(c)]
- 1. The permittee shall demonstrate compliance with the work practice standard no later than 180 days after startup of the source. [§63.7510(g)]
- m. If you have an applicable work practice standard for carbon monoxide, and your boiler or process heater is in any of the large subcategories and has a heat input capacity of 100 MMBtu per hour or greater, you must install, operate, and maintain a continuous emission monitoring system (CEMS) for carbon monoxide according to the following by the compliance date specified in §63.7495: [§63.7525(a)]
 - i. Each CEMS must be installed, operated, and maintained according to Performance Specification (PS) 4A of 40 CFR part 60, appendix B, and according to the site-specific monitoring plan developed according to §63.7505(d).

- ii. The permittee must conduct a performance evaluation of each CEMS according to the requirements in §63.8 and according to PS 4A of 40 CFR part 60, appendix B.
- iii. Each CEMS must complete a minimum of one cycle of operation (sampling, analyzing, and data recording) for each successive 15-minute period.
- iv. The CEMS data must be reduced as specified in 63.8(g)(2).
- v. The permittee must calculate and record a 30-day rolling average emission rate on a daily basis. A new 30-day rolling average emission rate is calculated as the average of all of the hourly CO emission data for the preceding 30 operating days.
- vi. For purposes of calculating data averages, the permittee must not use data recorded during periods of monitoring malfunctions, associated repairs, out-of-control periods, required quality assurance or control activities, or when the boiler or process heater is operating at less than 50 percent of its rated capacity. The permittee must use all the data collected during all other periods in assessing compliance. Any period for which the monitoring system is out of control and data are not available for required calculations constitutes a deviation from the monitoring requirements.
- n. The permittee must monitor and collect data according to this section and the site-specific monitoring plan required by §63.7505(d). [§63.7535(a)]
- o. Except for monitor malfunctions, associated repairs, and required quality assurance or control activities (including, as applicable, calibration checks and required zero and span adjustments), the permittee must monitor continuously (or collect data at all required intervals) at all times that the affected source is operating. [§63.7535(b)]
- p. The permittee may not use data recorded during monitoring malfunctions, associated repairs, or required quality assurance or control activities in data averages and calculations used to report emission or operating levels. The permittee must use all the data collected during all other periods in assessing the operation of the control device and associated control system. Boilers and process heaters that have an applicable carbon monoxide work practice standard and are required to install and operate a CEMS, may not use data recorded during periods when the boiler or process heater is operating at less than 50 percent of its rated capacity. [§63.7535(c)]
- q. The permittee must meet the following requirements: [§63.7540(a)(10)]
 - i. Continuously monitor carbon monoxide according to §§63.7525(a) and 63.7535.
 - Maintain a carbon monoxide emission level below your applicable carbon monoxide work practice standard in Table 1 to this subpart at all times except during periods of startup, shutdown, malfunction, and when your boiler or process heater is operating at less than 50 percent of rated capacity.
 - iii. Keep records of carbon monoxide levels according to §63.7555(b).

- r. The permittee shall report each instance in which each emission limit, operating limit, and work practice standard in Tables 1 through 4 that apply was not met. The permittee shall also report each instance during a startup, shutdown, or malfunction when each applicable emission limit, operating limit, and work practice standard was not met. These instances are deviations from the emission limits and work practice standards. These deviations must be reported according to the requirements in §63.7550. [§63.7540(b)]
- s. During periods of startup, shutdown, and malfunction, the permittee shall operate in accordance with the SSMP as required in §63.7505(e). [§63.7540(c)]
- Consistent with §§63.6(e)and 63.7(e)(1), deviations that occur during a period of startup, shutdown, or malfunction are not violations if permittee demonstrates to the EPA Administrator's satisfaction that permittee was operating in accordance with the SSMP. The Administrator will determine whether deviations that occur during a period of startup, shutdown, or malfunction are violations, according to the provisions in §63.6(e). [§63.7540(d)]
- u. The permittee shall submit all of the notifications in §§63.7(b) and (c), 63.8 (e), (f)(4) and (6), and 63.9 (b) through (h) that apply by the dates specified. [40 CFR §63.7545(a)]
- v. The permittee shall submit an Initial Notification not later than 15 days after the actual date of startup of the affected source. [§63.7545(c)]
- w. The permittee shall submit each applicable report in Table 9 by the date in Table 9 and according to the requirements in paragraph §63.7550(b)(1) through (5) unless the Administrator has approved a different schedule for submission of reports under §63.10(a). [§63.7550(a) and (b)]
- x. The compliance report must contain the information required in paragraphs \$63.7550(c)(1) through (11), as applicable. [\$62.7550(c)]
- y. For each deviation from an emission limit or operating limit in the subpart and for each deviation from the requirements for work practice standards in the subpart that occurs at an affected source where a CMS is not used to comply with that emission limit, operating limit, or work practice standard, the compliance report must contain the information in paragraphs §63.7550(c)(1) through (10) and the information required in paragraphs §63.7550(d)(1) through (4). This includes periods of startup, shutdown, and malfunction. [§63.7550(d)]
- z. For each deviation from an emission limitation and operating limit or work practice standard in this subpart occurring at an affected source where you are using a CMS to comply with that emission limit, operating limit, or work practice standard, you must include the information in paragraphs (c)(1) through (10) of this section and the information required in paragraphs (e)(1) through (12) of this section. This includes periods of startup, shutdown, and malfunction and any deviations from your site-specific monitoring plan as required in §63.7505(d). [§63.7550(e)]

- aa. Each affected source that has obtained a Title V operating permit pursuant to 40 CFR part 70 or 40 CFR part 71 must report all deviations as defined in this subpart in the semiannual monitoring report required by 40 CFR 70.6(a)(3)(iii)(A) or 40 CFR 71.6(a)(3)(iii)(A). If an affected source submits a compliance report pursuant to Table 9 to this subpart along with, or as part of, the semiannual monitoring report required by 40 CFR 70.6(a)(3)(iii)(A) or 40 CFR 70.6(a)(3)(iii)(A) or 40 CFR 71.6(a)(3)(iii)(A) or 40 CFR 71.6(a)(3)(iii)(A), and the compliance report includes all required information concerning deviations from any emission limit, operating limit, or work practice requirement in this subpart, submission of the compliance report satisfies any obligation to report the same deviations in the semiannual monitoring report. However, submission of a compliance report does not otherwise affect any obligation the affected source may have to report deviations from permit requirements to the permit authority. [§63.7550(f)]
- bb. If the permittee intends to use a fuel other than natural gas or equivalent to fire the affected unit, a notification of alternative fuel use is required within 48 hours of the declaration of a period of natural gas curtailment or supply interruption, as defined in \$63.7575. The notification must include the information specified in paragraphs \$63.7550(g)(1) through (5). [\$63.7550(g)]
- cc. The following records are required. [§63.7555(a)]
 - i. A copy of each notification and report submitted to comply with the subpart, including all documentation supporting any Initial Notification or Notification of Compliance Status or semiannual compliance report submitted, according to the requirements in §63.10(b)(2)(xiv).
 - ii. The records in §63.6(e)(3)(iii) through (v) related to startup, shutdown, and malfunction.
 - Records of performance tests, fuel analyses, or other compliance demonstrations, performance evaluations, and opacity observations as required in §63.10(b)(2)(viii).
- dd. For each CMS, CPMS, an COMS, the permittee shall keep the following: [§63.7555(b)]
 - i. Records described in §63.10(b)(2)(vi) through (xi).
 - ii. Previous (*i.e.*, superseded) versions of the performance evaluation plan as required in §63.8(d)(3).
 - iii. Request for alternatives to relative accuracy test for CEMS as required in §63.8(f)(6)(i).
 - iv. Records of the date and time that each deviation started and stopped, and whether the deviation occurred during a period of startup, shutdown, or malfunction or during another period.

- ee. The permittee must keep the records required in Table 8 to the subpart including records of all monitoring data and calculated averages for applicable operating limits such as opacity, pressure drop, carbon monoxide, and pH to show continuous compliance with each emission limit, operating limit, and work practice standard that applies to you. [§63.7555(c)]
- ff. The permittee shall keep records in a form suitable and readily available for expeditious review, according to §63.10(b)(1). [§63.7560(a)]
- gg. As specified in §63.10(b)(1), the permittee shall keep each record for 5 years following the date of each occurrence, measurement, maintenance, corrective action, report, or record. [§63.7560(b)]
- hh. The permittee shall keep each record on site for at least 2 years after the date of each occurrence, measurement, maintenance, corrective action, report, or record, according to \$63.10(b)(1). The permittee can keep the records off site for the remaining 3 years. [\$63.7560(c)]

SN-822 - High Pressure Flare SN-823 - Low Pressure Flares

Source Description

SN-822 and SN-823 are steam assisted flares used to provide for the safe disposal of hydrocarbonvapors discharged from refinery process units from upset conditions, startups, shutdowns and malfunctions. The gases that will be routinely combusted in the flares are pilot gas, purge gas, and NSPS Subpart J quality gas from the fuel gas system.

SN-822 maintains a pilot light designed at 1.5 MM Btu/hr and is known as the high pressure flare. It was installed in 1979.

SN-823 maintains a pilot light designed at 1.5 MM Btu/hr and is known as the low pressure flare. It was installed in 1974.

A Flare Gas Recovery System (FGRS) has been installed at the facility. The purpose of the FGRS is to recover refinery gases. The FGRS compresses the flare gases and allows them to be processed either in the fuel gas system or through the gas plant. When the fuel gas produced exceeds refinery demand, excess gas meeting the requirements of 40 C.F.R., Part 60, Subpart J, may be routed to the flares. The FGRS is not a source of emissions.

Regulations

The flares are both subject to 40 C.F.R., Part 60, Subpart J-Standards of Performance for Petroleum Refineries.

Specific Conditions

58. The permittee shall not exceed the emission rates set forth in the following table. Compliance with these limits shall be demonstrated by operation of the flare gas recovery system and by compliance with the fuel and flow rate limits of this section. [§19.501 of Regulation 19 *et seq.*, and 40 C.F.R., Part 52, Subpart E]

SN #	Source Description	Pollutant	lb/day	tpy
		PM_{10}	99	4.0
		SO_2	484	19.6
822, 823	Both Flares	VOC	842	34.1
		CO	2,220	89.9
		NO _X	612	24.8

^{59.} The flare gas recovery system shall be in operation at all times. If the flare gas recovery system is not in operation, Lion Oil is in compliance with this condition provided that the flare is operated and the emission limits in Specific Condition 58 are not exceeded. [§19.705 of Regulation 19, and A.C.A. §8-4-203 as referenced by §8-4-304 and §8-4-311]

- 60. The flares shall be operated as required in § 60.18. These requirements are summarized below. [§19.304 of Regulation 19, A.C.A. §8-4-203 as referenced by §8-4-304 and §8-4-311, and 40 C.F.R. § 60.18]
 - a. The flares shall be operated with a flame present at all times as required by 60.18(c)(2).
 - b. The facility shall monitor the flares to ensure they are operated and maintained in conformance with their designs in accordance with § 60.18(d).
 - c. The flares shall be operated at all times when emissions may be vented to them as required by § 60.18(e).
- 61. The flares shall be operated with no visible emissions, except for periods not to exceed a total of five minutes during any consecutive two hour period, when the flares may have emissions not to exceed 60% opacity. [§19.304 and §19.503 of Regulation 19 and 40 C.F.R. § 60.18(c)(1)]
- 62. The high and low pressure flares (SN-822 and SN-823) are affected facilities under the terms of 40 CFR Part 60 Subpart J Standards of Performance for Petroleum Refineries. These sources are subject to the Subpart J requirements, which are summarized in Plantwide Condition 11. (for the full regulation, see Appendix C). Pipeline quality natural gas meets the requirements of Subpart J. [§19.304 of Regulation 19 and 40 CFR §60.100]
- 63. The total flow of pilot gas, purge gas and excess NSPS J quality gas to the flares shall be limited to 6 MM scf/day and a total limit of 486 MM scf per consecutive twelve month period. [§19.705 of Regulation 19, A.C.A. §8-4-203 as referenced by §8-4-304 and §8-4-311, and 40 C.F.R. §70.6]
- 64. Records for the rolling annual flow rate in Specific Condition #63 shall be maintained on a twelve-month rolling basis, updated monthly. Records shall be maintained to demonstrate compliance with the daily limit in Specific Condition #63. Such records shall be maintained on-site and the 12-month rolling totals shall be submitted in accordance with General Provision #7. [§19.705 of Regulation 19, and 40 C.F.R., Part 52, Subpart E]
- 65. The flares and flare gas recovery system shall be operated as described in this section at all times. In the event of an upset, emergency condition, startup, shutdown, or malfunction, the Department will forego enforcement action if the permittee complies with the requirements of Regulation 19, Chapter 6, Upset and Emergency Conditions and 40 C.F.R. § 60.11 for federally regulated air pollutant emissions and Regulation 18, Chapter 11, § 18.1101, Upsets, for other air emissions. Permittee shall submit the reports as referenced in §§19.601(C) and 18.1101(B) within 30 days of the upset, emergency condition, startup, shutdown and malfunction. [§19.601 and §19.602 of Regulation 19, and 40 C.F.R., Part 52, Subpart E, and 40 C.F.R., Part 60]

SN-824 - Fume Incinerator

Source Description

SN-824 is a 15 MMBtu/hr incinerator (nominal design) used to incinerate hydrocarbon vapors emitted from the asphalt blowing process subsequent to vapor scrubbing. It is fueled by NSPS Subpart J quality gas. It was installed in 1977.

On May 23 – 24, 2001, this source was tested for SO_2 emissions using EPA Reference Method 6C pursuant to §19.702 of Regulation 19, and 40 C.F.R., Part 52, Subpart E.

Regulations

Pursuant to 40 C.F.R. 60, Subpart J-Standards of Performance for Petroleum Refineries, the Asphalt Blowing Incinerator is an affected facility. The provisions of 40 C.F.R. 60, Subpart J do not apply to emissions from asphalt processing facilities.

Pursuant to 40 CFR Part 63 Subpart LLLLL – National Emission Standards for Hazardous Air Pollutants: Asphalt Processing and Asphalt Roofing, the Asphalt Blowing Incinerator is an affected facility.

Specific Conditions

66. The permittee shall not exceed the emission rates set forth in the following table. Compliance with these limits shall be demonstrated by compliance with the operational limits for this source. [§19.501 of Regulation 19 *et seq.*, and 40 C.F.R., Part 52, Subpart E]

SN#	Source Description	Pollutant	lb/day	tpy
824	Fume Incinerator	PM_{10}	2.0	8.8
024	Fume memerator	SO_2	23.1	101.5
		VOC	4.1	18.0
		CO	123.3	541.5
		NO _X	2.0	8.8

Table 21 - Fume Incinerator Criteria Emission Rate

- 67. The facility shall use only pipeline quality natural gas or NSPS Subpart J quality gas as fuel to aid in combustion of emissions from the blowing stills. [§19.705 of Regulation 19, A.C.A. §8-4-203 as referenced by §8-4-304 and §8-4-311, and 40 C.F.R. §70.6]
- 68. The facility shall not exceed 5% opacity from the sources in this section. Compliance with this limit shall be demonstrated by burning pipeline natural gas or other gaseous fuel with an H2S concentration less than 1,500 ppmvd. If the H2S concentration exceeds 1500 ppmvd, then the facility shall comply with Plantwide Condition #1. [§18.501 of Regulation 18, and A.C.A. §8-4-203 as referenced by §8-4-304 and §8-4-311]

- 69. During those times in which the H₂S content of the refinery fuel gas combusted on-site exceeds 1500 ppmvd, the facility shall conduct an opacity observation for those sources which are permitted to combust NSPS Subpart J quality gas. These observations shall be conducted by someone who is familiar with the visible emissions from these sources. Any sources which generate visible emissions during these periods shall be considered to be in violation of the 5% opacity standard for that source. Records of these observations shall be maintained on-site, and shall be made available to the Department upon request These records shall indicate the date and time of the observation, the name of the person making the observation, whether or not any visible emissions are detected, and a list of any sources (by SN) for which visible emissions were noted. [§18.501 of Regulation 18 and A.C.A. §8-4-203 as referenced by §8-4-304 and §8-4-311]
- 70. The Fume Incinerator (SN-824) is subject to and shall comply with all applicable provisions of 40 CFR Part 63 Subpart LLLLL – National Emission Standards for Hazardous Air Pollutants: Asphalt Processing and Asphalt Roofing Manufacturing. The compliance requirements of this subpart as they apply to these sources are summarized below. [§19.304 of Regulation 19 and 40 CFR §63.8681]
 - a. SN-824 shall maintain the 3-hour combustion zone temperature at or above the operating limit established during performance testing (1523°F). [§63.8684(b)]
 - b. SN-824 shall comply with the emission limitations (including operating limits) in this subpart at all times, except during periods of startup, shutdown, and malfunction. [§63.8685(a)]
 - c. The permittee must always operate and maintain the affected source, including air pollution control and monitoring equipment, according to the provisions in §63.6(e)(1)(i). [§63.8685(b)]
 - d. The permittee shall develop and implement a written startup, shutdown, and malfunction plan (SSMP) according to the provisions in §63.6(e)(3). [§63.8685(c)]
 - e. The permittee shall develop and implement a written site-specific monitoring plan according to the provisions in §63.8688(g) and (h). [§63.8685(d)]
 - f. The permittee shall conduct performance tests no later than 180 days after the compliance date that is specified for your source in §63.8683 and according to the provisions in §63.7(a)(2). As an alternative, the permittee may use the results of a previously-conducted emission test to demonstrate compliance with the emission limitations in this subpart if you demonstrate to the Administrator's satisfaction that: [§63.8686(a) and (b)]
 - i. 40cfr63.8686(b)(1) No changes have been made to the process since the time of the emission test; and
 - ii. 40cfr63.8686(b)(2)

The operating conditions and test methods used during testing conform to the requirements of this subpart; and

- iii. The control device and process parameter values established during the previously-conducted emission test are used to demonstrate continuous compliance with this subpart.
- g. The permittee shall conduct each performance test in accordance with Table 3 of Subpart LLLLL. Each performance test must be conducted as follows: [§63.8687(a) through (e)]
 - i. Each performance test must be conducted under normal operating conditions and under the conditions specified in Table 3 to Subpart LLLLL.
 - ii. Performance testing shall not be conducted during periods of startup, shutdown, or malfunction, as specified in §63.7(e)(1).
 - iii. Except for opacity and visible emission observations, three separate test runs shall be conducted for each performance test required in this section, as specified in §63.7(e)(3). Each test run must last at least 1 hour.
 - iv. The permittee must use the equations of §63.8687(e) to determine compliance with the emission limitations.
- h. The permittee shall install, operate, and maintain each continuous parameter monitoring system (CPMS) according to the requirements of §63.8688(a) and (b).
- i. For each monitoring system required in this section, the permittee must develop and make available for inspection by the permitting authority, upon request, a site-specific monitoring plan. The site-specific monitoring plan must address the following: [§63.8688(g) and (h)]
 - i. Ongoing operation and maintenance procedures in accordance with the general requirements of (c)(1), (c)(3), (c)(4)(ii), (c)(7), and (c)(8);
 - ii. Ongoing data quality assurance procedures in accordance with the general requirements of §63.8(d); and
 - iii. Ongoing recordkeeping and reporting procedures in accordance with the general requirements of 63.10(c), (e)(1), and (e)(2)(i).
- j. The permittee must conduct a performance evaluation of each CPMS, CEMS, or COMS in accordance with your site-specific monitoring plan. [§63.8688(i)]
- k. The permittee must operate and maintain the CPMS, CEMS, or COMS in continuous operation according to the site-specific monitoring plan. [§63.8688(j)]
- The permittee shall submit all of the notifications in §§63.6(h)(4) and (5), 63.7(b) and (c), 63.8(f), and 63.9(b) through (f) and (h) that apply to you by the dates specified. [§63.8692(a)]
- m. As specified in §63.9(b)(2), the permittee must submit an Initial Notification not later than 120 calendar days after April 29, 2003. [§63.8692(b)]

- n. The permittee shall submit a notification of intent to conduct performance testing at least fifteen (15) days prior to the date the testing is scheduled to begin.
- o. The permittee shall submit a notification of compliance status according to \$63.9(h)(2)(ii). This notification shall include all performance test results, and shall be submitted by the close of business on the 60th calendar day following the completion of the performance tests according to \$63.10(d)(2). If you are using data from a previously-conducted emission test to serve as documentation of conformance with the emission standards and operating limits of this subpart, you must submit the test data in lieu of the initial performance test results with the Notification of Compliance Status. [\$63.8692(e) and (f)]

SN-831 -#9 Continuous Catalyst Regenerator (CCR)

Source Description

SN-831 is a regenerator used to continuously burn off the coke deposit from the catalyst, and restore catalyst activity, selectivity, and stability. This source was installed in 1991. Usage of a new catalyst was implemented in 2003/2004 in order to produce additional hydrogen for the No. 8 and No. 10 hydrotreating processes.

Specific Conditions

- 71. The permittee shall not exceed the emission rates set forth in the following table. Compliance with these limits shall be demonstrated by compliance with the throughput limit for this source. [§19.501 of Regulation 19 et seq., and 40 C.F.R., Part 52, Subpart E]
- 72. Temp reserve
- 73. a Temp reserve
- 74. a Temp reserve
- 75. Temp reserve

Table 22 - #9 Continuous Catalyst Regenerator Criteria Pollutant Emissions

SN #	Source Description	Pollutant	lb/day	tpy
	#9 Continuous Catalyst Regenerator	PM_{10}	2.0	8.8
		\mathbf{SO}_2	2.0	8.8
831		VOC	2.0	8.8
		CO	2.6	11.4
		NO _x	2.0	8.8

- 76. The total amount of catalyst recirculated at this source shall be limited to 13.2 million pounds per consecutive twelve month period. [§19.705 of Regulation 19, A.C.A. §8-4-203 as referenced by §8-4-304 and §8-4-311, and 40 C.F.R. §70.6]
- 77. Records for the recirculation rate shall be maintained on a twelve month rolling basis, updated monthly. Such records shall be maintained on site and submitted in accordance with General Provision #7. [§19.705 of Regulation 19, and 40 C.F.R., Part 52, Subpart E]
- 78. SN-831 (the CCR) is an affected facility under the terms of 40 C.F.R., Part 63, Subpart UUU-National Emission Standards for Hazardous Air Pollutants for Petroleum Refineries: Catalytic Cracking Units, Catalytic Reforming Units, and Sulfur Recovery Units. The applicable requirements of this subpart are summarized in Plantwide Condition 12. [§19.304 of Regulation 19 and 40 CFR §63.1561]

SN-832 - 47 Asphalt Tank Heaters

Source Description

SN-832 is comprised of 47 tank heaters with a total heat input capacity of 99.3 MMBtu/hr (nominal design). The heaters are used to maintain elevated temperatures of stored asphalt products so that the material will flow and not solidify. The heaters included in this source grouping are described in the following table.

Tank SN	Year Installed	# of Heaters	MMBtu/hr per heater	total MMBtu/hr per tank
T-39	pre-1981	2	3.0	6.0
T-40	1988	1	2.3	2.3
T-41	1991	1	2.3	2.3
T-56	1989	2	1.5	3.0
T-78	1999	3	0.68	2.1
T-99	1991	2	0.15	0.3
T-107	1987	4	2.75	11.0
T-111	pre-1981	4	1.8	7.2
T-118	1987	4	2.75	11.0
T-219	1968	4	1.8	7.2
T-348	1968	2	2.3	4.6
T-354	2001	2	1.5	3.0
T-524	1986	4	2.3	9.2
T-530	1986	4	2.3	9.2
T-544	1991	2	0.5	1.0
T-548	1993	6	3.33	20

Table 23 - Asphalt Tank Heaters

Because the combined emissions from these sources emit more than 10 tpy of a single criteria pollutant, they cannot be classified as insignificant emission sources. These sources have been permitted at full capacity and fire only NSPS Subpart J quality gas.

Regulations

These sources are subject to 40 C.F.R., Subpart J- Standards of Performance for Petroleum Refineries as fuel gas combustion devices.

Specific Conditions

79. The permittee shall not exceed the emission rates set forth in the following table. Compliance with these limits shall be demonstrated by permitting these sources at full capacity and compliance with NSPS Subpart J. [§19.501 of Regulation 19 *et seq.*, and 40 C.F.R., Part 52, Subpart E]

SN #	Source Description	Pollutant	lb/day	tpy
		PM_{10}	1.0	4.4
832	47 Asphalt Tank Heaters	SO_2	4.3	14.7
		VOC	1.0	4.4
		CO	10.6	35.9
		NO_X	12.9	43.6

Table 24 - Asphalt Tank Heaters Criteria Emissions

- 80. The facility shall not exceed 5% opacity from the sources in this section. Compliance with this limit shall be demonstrated by burning pipeline natural gas or other gaseous fuel with an H₂S concentration less than 1,500 ppmvd. If the H₂S concentration exceeds 1500 ppmvd, then the facility shall comply with Specific Condition #81. [§18.501 of Regulation 18, and A.C.A. §8-4-203 as referenced by §8-4-304 and §8-4-311]
- 81. During those times in which the H₂S content of the refinery fuel gas combusted on-site exceeds 1500 ppmvd, the facility shall conduct an opacity observation for those sources which are permitted to combust NSPS Subpart J quality gas. These observations shall be conducted by someone who is familiar with the visible emissions from these sources. Any sources which generate visible emissions during these periods shall be considered to be in violation of the 5% opacity standard for that source. Records of these observations shall be maintained on-site, and shall be made available to the Department upon request These records shall indicate the date and time of the observation, the name of the person making the observation, whether or not any visible emissions are detected, and a list of any sources (by SN) for which visible emissions were noted. [§18.501 of Regulation 18 and A.C.A. §8-4-203 as referenced by §8-4-304 and §8-4-311]
- 82. The facility shall burn only pipeline quality natural gas or NSPS Subpart J quality gas at the sources included in SN-832. [§19.705 of Regulation 19, A.C.A. §8-4-203 as referenced by §8-4-304 and §8-4-311, and 40 C.F.R. §70.6]
- 83. The Asphalt Heaters (SN-832) is an affected facility under the provisions of 40 C.F.R. 60, Subpart J-Standards of Performance for Petroleum Refineries. It is defined in the subpart as a fuel gas combustion device. This source is subject to the Subpart J requirements, which are summarized in Specific Condition # 82 and Plantwide Condition #11 (for the full regulation, see Appendix C). [§19.304 of Regulation 19 and 40 CFR §60.100]

> SN-834 - North KVG Compressor SN-835 - South KVG Compressor SN-836 – 8GTL Compressor SN-837 - North 8SVG 440 hp Compressor SN-838 - South 10 SVG 550 hp Compressor SN-839 – East JVG Compressor SN-840 – West JVG Compressor SN-841 – G398TA Air Compressor

Source Description

All of the following described sources are pipeline quality natural gas compressor engines used to move gases within refinery plant operations. They are all fueled by pipeline quality natural gas.

The Consent Decree (CIV. No. 03-1028)reached between Lion Oil, the US EPA, and ADEQ required that Lion install and operate controls on SN-837, SN-838, SN-839, and SN-840 as an "environmentally beneficial project". Additionally, a BACT analysis was performed for CO emissions from the Air Compressor (SN-841), and BACT was proposed to be the installation of non-selective catalytic reduction (NSCR) with air/fuel ratio controls. EPA has not yet granted final approval of the proposed BACT for SN-841, and the unit will operate under an interim CO emission limit of 2.0 g/hp-hr until such time as a final BACT limit is established.

The installation of these control devices will result in decreases in both actual and permitted emissions of CO and NO_x from these engines.

Compressor SN	Year Installed	rated		
51	Instancu	power (np)		
833*	1959			
834	1942	650		
835	1942	650		
836*	1986	959		
837	1958	440		
838	1958	550		
839*	1959	240		
840*	1959	240		
841	1959	700		
* Sources removed from Service.				

Table 25 - Compressors

The facility has bubbled the emissions of the North KVG Compressor (SN-834) and South KVG Compressor (SN-835) and has taken the emission limits listed in the tables in this section. The emission limits for SN-834 and SN-835 may not be increased unless the permit is modified.

In order to comply with the NAAQS, the facility has chosen to limit emissions from several of the sources in this section. These limits are specified in the following Specific Conditions.

The South XVG compressor (SN-833), the 8GTL compressor (SN-836), the East JVG Compressor (SN-839), and the West JVG compressor (SN-840) have been removed from service.

Specific Conditions

84. The permittee shall not exceed the emission rates set forth in the following tables. The permittee shall comply with the emission limits contained in the table below. Compliance with these limits shall be demonstrated by compliance with the operation and testing limits of this section. [§19.501 of Regulation 19 *et seq.*, and 40 C.F.R., Part 52, Subpart E]

SN #	Source Description	Pollutant	lb/day	tpy
833	South XVG Compressor		Source Removed from Service	
834	North KVG Compressor	СО	23.6	_
034	North KVO Compressor	NO _X	28.7	
025	South KVC Compressor	CO	23.6	—
033	South K VO Compressor	NO _X	28.7	
834 and 835		CO		21.2
(combined)		NO _X		25.8
836	8GTL Compressor	Removed from service		
027	North 8SVG Compressor	CO	2.9	12.8
037	w/Catalytic Converter	NO _X	1.9	8.5
020	South 10 SVG Compressor	CO	3.6	16.0
030	w/Catalytic Converter	NO _X	2.4	10.7
839 East JVG Compressor			Removed from se	ervice
840	West JVG Compressor	Removed from service		ervice
8/1	C308TA Air Compressor	CO	3.1	13.6
041	G5981A All Compressor	NO _X	3.1	13.6

Table 26 – Compressors Criteria Emissions

85. Negligible amounts of particulate matter and sulfur dioxide may be emitted by these sources. Due to extremely low potential emissions of these pollutants, numerical limits have not been included for these sources, but such emissions are not prohibited.

- 86. The facility shall not exceed 5% opacity from SN's 834, 835, 837, 838, and 841. Compliance with this limit shall be demonstrated by burning only pipeline quality natural gas. [§18.501 of Regulation 18, and A.C.A. §8-4-203 as referenced by §8-4-304 and §8-4-311]
- 87. The combined operation of SN's 834 and 835 shall be limited to a total of 1,800 hours of operation per consecutive twelve month period. [§19.705 of Regulation 19, A.C.A. §8-4-203 as referenced by §8-4-304 and §8-4-311, and 40 C.F.R. §70.6]

- 88. Meters shall record the hours of operation of SN-834 and SN-835, and records of hours of operation shall be kept on a monthly basis. Such records shall be maintained on site and submitted in accordance with General Provision #7. [§19.705 of Regulation 19, and 40 C.F.R., Part 52, Subpart E]
- 89. The facility shall use only pipeline quality natural gas as fuel for the compressors within this section. [§19.705 of Regulation 19, A.C.A. §8-4-203 as referenced by §8-4-304 and §8-4-311, and 40 C.F.R. §70.6]
- 90. Every five years beginning in June 2006, the permittee shall simultaneously conduct tests for CO and NO_x on one-half of each type of compressor engine (except SN-836 or electric powered engines) in accordance with Plantwide Condition #3. EPA Reference Method 7E (or other approved method) shall be used to test NO_x for the reciprocating engines and EPA reference Method 10 (or other approved method) shall be used to determine CO. The permittee shall test the engines within 90% of their rated capacity. If the tests are not performed within this range, the permittee shall be limited to operating within 10% above the tested rate. The Department reserves the right to select the engine(s) to be tested. The engine(s) tested shall be rotated so that no engine(s) is tested twice before an engine of equal HP is tested once. If the tested emission rate for any pollutant is in excess of the permitted emission rate, all similar engines shall be tested for both pollutants. This condition shall not apply to the air compressor (SN-841). [§19.702 of Regulation 19 and 40 C.F.R., Part 52, Subpart E]
- 91. Test results shall be furnished in lbs/hr and converted to tpy. EPA Reference Method 19 shall be used to convert test results to lbs/hr and tpy. All written reports shall be submitted to the following address:

Arkansas Department of Environmental Quality Air Division Attn.: Air Enforcement Section PO Box 8913 Little Rock, Arkansas 72219

- 92. The permittee shall install, operate, and properly maintain catalytic converters with air-to-fuel ratio controls on SN-837 and SN-838 for the purpose of reducing emissions of NO_x and CO to the atmosphere. These controls shall be installed and operational no later than December 31, 2004. [§19.303 of Regulation 19, A.C.A. §8-4-203 as referenced by §8-4-304 and §8-4-311, and Section VIII(A) of the Consent Decree (CIV. No. 03-1028)]
- 93. The permittee shall install, operate, and properly maintain a catalytic converter with air-to-fuel ratio controls on the Air Compressor (SN-841) for the purpose of reducing CO emissions to the atmosphere. These controls shall be installed and operational no later than December 31, 2004. [§19.303 of Regulation 19 and A.C.A. §8-4-203 as referenced by §8-4-304 and §8-4-311]
- 94. On and after December 31, 2004, until such time as a final BACT limit for CO is established by the US EPA, the permittee shall operate the Air Compressor (SN-841) such that CO emissions to the atmosphere do not exceed 2.0 g/hp-hr based on a 3-hour average. Once a final BACT limit is established by the US EPA, then the permittee shall comply with that limit. [§19.501 et seq. and 40 CFR Part 52 Subpart E]

- 95. Within 60 days after the installation of controls on the air compressor (SN-841) the permittee shall test the compressor exhaust stack for emissions of CO and NO_x. CO testing shall be performed in accordance with US EPA Reference Method 10, and NO_x testing shall be performed in accordance with US EPA Reference Method 7E. EPA Reference Method 19 shall be used to convert test results to mass emission rates. The results of this testing shall be maintained on-site, and shall be submitted to the Department in accordance with General Provision #7. [§19.702 of Regulation 19 and 40 CFR Part 52 Subpart E]
- 96. The permittee shall continue to test the CO emissions from the Air Compressor (SN-841) according to the following schedule. All CO testing shall be performed in accordance with US EPA Reference Method 10. EPA Reference Method 19 shall be used to convert test results to mass emission rates. All test results shall be maintained on-site, and shall be submitted to the Department in accordance with General Provision #7. [§19.702 of Regulation 19 and 40 CFR Part 52 Subpart E]
 - a. A test shall be performed within 30 days prior to the beginning of the first scheduled semi-annual maintenance of the compressor (SN-841). During the maintenance downtime, the catalytic converter shall be serviced in accordance with the manufacturer's directives.
 - b. An additional test shall be performed within 30 days following the end of the first scheduled semi-annual maintenance of the compressor (SN-841).
 - c. The testing procedures outlined in (a) and (b) above shall be repeated for the second scheduled semi-annual maintenance of the air compressor (SN-841). During the maintenance downtime, the catalytic converter shall be serviced in accordance with the manufacturer's directives.
 - d. The testing shall be repeated again within 30 days prior to the beginning of the fourth scheduled semi-annual maintenance of the air compressor (after the catalytic converter is installed).
 - e. All of the above testing shall be completed no later than 30 months after the date that the air compressor is installed and first operated.
 - f. The air compressor (SN-841) shall continue to be tested for CO on an annual basis from the date that the test required in section (d) above is completed.
- 97. Each catalytic converter system operated on a stationary engine at the Lion Oil facility shall be operated and maintained in accordance with the manufacturer's specifications and directives at all times. [§19.303 of Regulation 19 and A.C.A. §8-4-203 as referenced by §8-4-304 and §8-4-311]

SN-846 - Gasoline/Diesel Loading Rack

Source Description

SN-846 is gasoline and diesel loading rack. It was installed in 1980. A John Zink Carbon Adsorption Vapor Recovery Unit (VRU) was placed into operation on June 18, 1998, in order to comply with the requirements of 40 C.F.R. 63, Subpart CC-National Emission Standards for Hazardous Air Pollutants from Petroleum Refineries. The requirements of Subpart CC are outlined in the Plantwide Conditions of this permit.

Regulations

This source is not subject to 40 C.F.R. 60, Subpart XX-Standards of Performance for Bulk Gasoline Terminals because it was constructed prior to the effective date of Subpart XX.

Specific Conditions

98. The permittee shall not exceed the emission rates set forth in the following table. Compliance with these limits shall be demonstrated by compliance with 40 C.F.R. 63, Subpart CC and the throughput and loading requirements for this source. [§19.501 of Regulation 19 *et seq.*, and 40 C.F.R., Part 52, Subpart E]

 Table 27 - Gasoline/Diesel Loading Rack VOC Emissions

SN	Pollutant	lb/hr	tpy
846	VOC	20.2	17.1

- 99. The total annual throughput of gasoline/diesel products through this source is limited to 9,761,905 bbl per consecutive twelve month period. [§19.705, A.C.A. §8-4-203 as referenced by §8-4-304 and §8-4-311, and 40 C.F.R. §70.6]
- 100. Records for the annual throughput shall be maintained on a twelve month rolling basis, updated monthly. Such records shall be maintained on-site and submitted in accordance with General Provision #7. [§19.705 of Regulation 19 and 40 CFR Part 52 Subpart E]
- 101. The facility shall only load gasoline and diesel products at this loading rack. [\$19.705 of Regulation 19, A.C.A. \$8-4-203 as referenced by \$8-4-304 and \$8-4-311, and 40 C.F.R. \$70.6]
- 102. TOC emissions concentration shall be less than or equal to 1.1 volume percent. [§19.304 of Regulation 19 and 40 CFR §63.427(a) and (b)]
- 103. The facility shall operate a TOC CEM system on the gasoline/diesel loading rack in order to demonstrate compliance with 40 CFR Part 63 Subpart CC. All CEMs shall be operated in accordance with the Department's CEM Conditions. The facility shall submit CEM data in accordance with the Department's CEMS Conditions. CEM data shall be submitted to demonstrate that the TOC concentration is less than or equal to 1.1 volume percent. [§19.304 of Regulation 19 and 40 CFR §63.427(a) and (b)]

SN-847 - Heavy Oil Loading Racks

Source Description

SN-847 is the aggregate emissions of twelve asphalt plant loading racks. The loading racks are described in the following table.

Year Installed	Product Loaded		
1987	111/219 East Asphalt Truck Rack		
Pre-1950	111/219 West Asphalt Truck Rack		
Pre-1950	South Asphalt Plant Truck Rack		
1975	North PMA Truck Rack*		
1989	North Asphalt Plant Truck Rack		
Pre-1950	Pumphouse Truck Rack		
1986	Lube Oil Truck Rack		
Pre-1950	E & W Rail Car Rack		
1968	56 Rack		
Pre-1950	Protective Coatings Dock		
Pre-1950	Asphalt Dock		
2000	South PMA Truck Rack		
*The PMA Truck Rack was previously known as the Emulsion Plant Truck Rack.			

Table 28 - Heavy Oil Loading Racks

Specific Conditions

104. The permittee shall not exceed the emission rates set forth in the following table. Compliance with these limits shall be demonstrated by compliance with the Plantwide Applicability Limit (PAL) for these sources. [§19.501 of Regulation 19 *et seq.*, and 40 C.F.R., Part 52, Subpart E]

Table 29 - Heavy Oil Loading Racks VOC Emissions

SN	Pollutant	lb/hr	tpy
947	Heavy Oil Loading Racks		
047	VOC	647.2	281.1

105. The facility shall load only asphalt, solvents, and lube oil-type products at these loading racks. [§19.705 of Regulation 19, A.C.A. § 8 -4-203 as referenced by §8-4-304 and §8-4-311, and 40 C.F.R. §70.6]

- 106. The facility has elected to demonstrate compliance for the loading racks through a PAL. To demonstrate compliance with the PAL, the facility shall maintain a monthly inventory of the emissions from each loading rack in this section. This inventory shall be calculated by the methods and equations used in AP-42, 5th Edition, Chapter 5.2, "Transportation and Marketing of Petroleum Liquids." Records for the monthly inventory of emissions from each loading rack shall include the source name, products loaded, monthly throughput, and monthly emissions in pounds and tons. The emissions from this inventory shall be summed to determine the total amount of emissions from the combined loading racks. [§19.705 of Regulation 19, and 40 C.F.R., Part 52, Subpart E]
- 107. Records for the annual VOC emission rate shall be maintained on a twelve month rolling basis, updated monthly. The annual VOC emissions records shall be maintained on-site and submitted in accordance with General Provision #7. [§19.705 of Regulation 19, and 40 C.F.R., Part 52, Subpart E]
- 108. In order to maintain the emissions from the PMA project below the PSD significance threshold for VOC, the throughput through the two PMA Asphalt Truck Racks shall be limited to an annual throughput of 1.2 MM bbl. [§19.901 of Regulation 19 et seq., and 40 C.F.R., Part 52, Subpart E]
- 109. Records for the PGPMA throughput shall be maintained on a daily basis, updated monthly. Such records shall be maintained on site and submitted in accordance with General Provision #7. [§19.705 of Regulation 19, and 40 C.F.R., Part 52, Subpart E]

SN-849 - Standby Diesel Crude Pump

Source Description

SN-849 is a Standby Diesel Crude Pump to be used as a backup to the primary charge pump (electrical) in the event of power failure or other related operational emergencies. This unit is rated at 325 hp and is fueled by diesel oil. This unit is fueled by low-sulfur diesel fuel provided from the low-sulfur diesel storage tank. The Standby Diesel Crude Pump was installed in 1997.

Specific Conditions

110. The facility shall not exceed the emission rates set forth in the following table. Compliance with these limits shall be demonstrated by compliance with the operating limits of this section. [§19.501 of Regulation 19 *et seq.*, and 40 C.F.R., Part 52, Subpart E]

SN #	Source Description	Pollutant	lb/day	tpy
	Standby Diesel Crude Pump	PM_{10}	1.4	1.4
849		SO_2	1.2	1.2
		VOC	1.6	1.5
		CO	12.2	11.6
		NO _X	20.2	19.1

 Table 30 - Standby Diesel Crude Pump Criteria Emissions

- 111. The facility shall not exceed 20% opacity from this source. As this source operates for only a short period of time each year, a regular compliance demonstration is not necessary. [§18.501 of Regulation 18, and A.C.A. §8-4-203 as referenced by §8-4-304 and §8-4-311]
- 112. The total hours of operation for this source shall be limited to 1900 hours per consecutive twelve month period. [§19.705 of Regulation 19, A.C.A. §8-4-203 as referenced by §8-4-304 and §8-4-311, and 40 C.F.R. §70.6]
- 113. A meter shall be operated to record the hours of operation of SN-849. Records of the hours of operation shall be maintained on a twelve month rolling basis, updated monthly. Such records shall be maintained on site and submitted in accordance with General Provision #7. [§19.705 of Regulation 19, and 40 C.F.R., Part 52, Subpart E]
- 114. This source shall only be fired on fuel which contains less than 0.5 percent sulfur. [§19.705 of Regulation 19, A.C.A. §8-4-203 as referenced by §8-4-304 and §8-4-311, and 40 C.F.R. §70.6]
- 115. The facility shall keep records demonstrating the sulfur content of the fuel used at the Standby Diesel Crude Pump (SN-849). These records may be in the form of laboratory analyses performed on the fuel stored in the low-sulfur diesel storage tank which supplies fuel to this unit. If any alternative source of fuel is used to fire this unit, the alternative source and the sulfur content of the alternative fuel shall be documented. These records shall be maintained on-site and shall be made available to Department personnel upon request. [§19.705 of Regulation 19, and 40 C.F.R., Part 52, Subpart E]

SN-851 - Wastewater Treatment SN-851a - Wastewater Collection

Source Description

SN-851, the waste water treatment facility, is used to remove pollutants from refinery waste water. It was installed in the 1970's. This unit has a maximum design capacity of 2500 gallons per minute (GPM), which corresponds to an annual capacity of 1,317.6 MM gal. In order to account for any short-term operational variances at this source, a safety factor of 20% has been included in the lb/hr emission limitation (corresponding to a short-term throughput of 3000 GPM).

Lion Oil has begun a complete redesign of the water collection systems at the facility. This redesign, once completed, will completely segregate the process wastewater from the stormwater at the facility. As part of the new wastewater systems, 6 new tanks will be installed at the facility to hold all process wastewater until it can be processed at the wastewater treatment facility. These tanks have been designated T-275, T-276, T-277, T-278, T-279, and T-280. The existing system will continue to be used for the treatment of facility stormwater. Since the process wastewater will be held in a closed system until treatment, this redesign will greatly reduce emissions from the wastewater processes at the facility.

Until the new wastewater collection system is fully operational, the existing system will continue to be operated as indicated in this permit. In order to allow for the operation of the new wastewater collection system once it is constructed, a separate set of specific conditions which are applicable to the new system have been added to this permit. The facility will be required to comply with both sets of specific conditions until such time as the permit is formally amended to modify the requirements for the "old" wastewater collection system.

Specific Conditions

"Old" Wastewater Collection System

116. The permittee shall not exceed the emission rates set forth in the following table. Compliance with these limits shall be demonstrated by compliance with the throughput limits of this section.

SN #	Source Description	Pollutant	lb/day	tpy
851	Wastewater Treatment	VOC	900.0	3294.0

Table 31 – Old Wastewater Voc Emissions

117. The total throughput of wastewater at this source shall be limited to 1,317.6 MM gallons per consecutive twelve month period. [§19.705 of Regulation 19, A.C.A. §8-4-203 as referenced by §8-4-304 and §8-4-311, and 40 C.F.R. §70.6]

118. Records of the wastewater throughput shall be maintained on a twelve month rolling basis, updated monthly. Such records shall be maintained on site and submitted in accordance with General Provision #7. [§19.705 of Regulation 19, and 40 C.F.R., Part 52, Subpart E]

"New" Wastewater Collection System

119. The permittee shall not exceed the emission rates set forth in the following table. Compliance with these limits shall be demonstrated by compliance with the throughput limits of this section. [§19.501 of Regulation 19 *et seq.*, and 40 C.F.R., Part 52, Subpart E]

SN#	Source Description	Pollutant	lb/day	tpy
851a	Wastewater Collection	VOC	26.1	85.9

 Table 32 – New Wastewater Voc Emissions

- 120. The total throughput of wastewater at this source shall be limited to 1,064.6 MM gallons per consecutive twelve month period. [§19.705 of Regulation 19, A.C.A. §8-4-203 as referenced by §8-4-304 and §8-4-311, and 40 C.F.R. §70.6]
- 121. Records of the wastewater throughput shall be maintained on a twelve month rolling basis, updated monthly. Such records shall be maintained on site and submitted in accordance with General Provision #7. [§19.705 of Regulation 19, and 40 C.F.R., Part 52, Subpart E]
- 122. The "new" process wastewater collection system shall be designed, installed, and operated in compliance with the applicable provisions of 40 CFR Part 60 Subpart QQQ Standards of Performance for VOC Emissions from Petroleum Refinery Wastewater Systems (Appendix J). The record keeping and reporting requirements of this subpart are summarized below. [§19.304 of Regulation 19 and 40 CFR §60.090]
 - a. For each individual drain system or junction box subject to the requirements of \$60.692 2, the location, date, and corrective action shall be recorded for each drain when a problem is identified that could result in VOC emissions as determined in the initial and periodic visual or physical inspections.
 - b. For each junction box subject to the requirements of §60.692-2, the location, date, and corrective action shall be recorded for inspections required by §60.692-2(b) when a problem is identified that could result in VOC emissions.
 - c. For each sewer line subject to the requirements of \$60.692-2 and \$60.693-1(e), the location, date, and corrective action shall be recorded for inspections required by \$\$60.692-2(c) and 60.693-1(e) when a problem is identified that could result in VOC emissions.
 - d. For oil-water separators subject to \$60.692-3 the location, date, and corrective action shall be recorded for inspections required by \$60.692-3(a) when a problem is identified that could result in VOC emissions.
 - e. For closed vent systems subject to §60.692-5 and completely closed drain systems subject to §60.693-1, the location, date, and corrective action shall be recorded for inspections required by §60.692-5(e) during which detectable emissions are measured or a problem is identified that could result in VOC emissions.

- f. If an emission point cannot be repaired or corrected without a process unit shutdown, the expected date of a successful repair shall be recorded.
- g. If an emission point is not repaired in the specified amount of time, the reason for the delay as specified in §60.692-6 shall be recorded, along with the signature of the owner or operator whose decision it was that repair could not be effected without a refinery or process shutdown, and the date that the repair or corrective action was successfully completed.
- h. A copy of the design specifications for all equipment used to comply with the provisions of Subpart QQQ shall be kept for the life of the source in a readily accessible location. These records shall include the following information:
 - i. Detailed schematics and piping and instrumentation diagrams.
 - ii. The dates and descriptions of any changes in the design specifications.
- j. If the permittee elects to install a tightly sealed cap or plug over a drain that is out of active service, the permittee shall keep for the life of the facility in a readily accessible location, plans or specifications which indicate the location of such drains.
- k. For stormwater sewer systems subject to the exclusion in §60.692-1(d)(1), the permittee shall keep for the life of the facility in a readily accessible location, plans or specifications which demonstrate that no wastewater from any process units or equipment is directly discharged to the stormwater sewer system.
- 1. For ancillary equipment subject to the exclusion in §60.692-1(d)(2), the permittee shall keep for the life of the facility in a readily accessible location, plans or specifications which demonstrate that the ancillary equipment does not come in contact with or store oily wastewater.
- m. For non-contact cooling water systems subject to the exclusion in §60.692-1(d)(3), the permittee shall keep for the life of the facility in a readily accessible location, plans or specifications which demonstrate that the cooling water does not contact hydrocarbons or oily wastewater and is not recirculated through a cooling tower.
- n. The permittee shall submit to the Department within 60 days after initial startup of the "new" wastewater collection system a certification that the equipment necessary to comply with the standards of Subpart QQQ has been installed and that all necessary initial inspections have been conducted in accordance with these standards.
- o. After the initial certification, the permittee shall submit semiannually a certification that all of the required inspections have been carried out in accordance with the standards of Subpart QQQ.

- 123. The permittee shall notify the Air Division Permit Section no later than 60 days prior to beginning operation of the "new" wastewater collection system. [A.C.A. §8-4-203 as referenced by §8-4-304 and §8-4-311]
- 124. The permittee shall submit an annual report to the Department which details the progress of the installation of the "new" wastewater collection system. This report shall indicate the degree of completion of the "new" wastewater collection system, as well as an up-to-date emission estimate for the "old" wastewater collection system based on the current operating conditions at the refinery. The Department shall reserve the right to modify the permitted emission limitations for the "old" wastewater collection system based on the information contained in this report. This report shall be submitted by August 1 of each calendar year. [Regulation No. 19 §19.705 and 40 CFR Part 52, Subpart E]

SN-853 - Cooling Towers SN-853a - #5 Cooling Tower SN-859 – No. 8 Cooling Tower

Source Description

The #3, 5, 6, 7, and 17 Sulfur Plant cooling towers are used to transfer waste heat from the cooling water to the atmosphere. They were installed in the 1970's. The #1 Cooling Tower was removed from service in 2003 and replaced with the new #8 cooling tower, which has been designated as SN-859.

The #5 cooling tower was modified in 2005 to install drift eliminators for PM_{10} control. SN-853a was added to account for the particulate emissions from the modified #5 tower. Since this PM_{10} limit was relied upon in the PSD netting analysis for the boiler replacement project, future changes to this limit may trigger PSD review for the boiler project.

Emissions from all six cooling towers (3, 5, 6, 7, 8, and 17) are bubbled together under SN-853. Cooling Tower #5 retains SN-853a and Cooling Tower #8 retains SN-859 for PSD purposes although the emissions from these towers are included in the SN-853 bubble.

Specific Conditions

125. The permittee shall not exceed the emission rates set forth in the following table. Compliance with these limits shall be demonstrated by compliance with the throughput limits of this section. [§19.501 of Regulation 19 *et seq.*, and 40 C.F.R., Part 52, Subpart E]

SN #	Source Description	Pollutant	lb/day	tpy
853	Cooling Towers	VOC	15.5	67.9
		PM_{10}	18.4	75.7
* SN-853 limits include emissions from all six cooling towers (3, 5, 6, 7, 8, and 17)				

- 126. The total amount of water circulated at the #3, 5, 6, 7, 8, and 17 Sulfur Plant cooling towers shall be limited to 45.25 billion gallons per consecutive twelve month period. [§19.705 of Regulation 19, A.C.A. §8-4-203 as referenced by §8-4-304 and §8-4-311, and 40 C.F.R. §70.6]
- 127. The total amount of water circulated at the #5 cooling tower shall be limited to 10.1 billion gallons per consecutive twelve month period. [§19.705 of Regulation 19, A.C.A. §8-4-203 as referenced by §8-4-304 and §8-4-311, and 40 C.F.R. §70.6]
- 128. The total amount of water circulated at the #8 Sulfur Plant cooling tower shall be limited to 10.5 billion gallons per consecutive twelve month period. [§19.705 of Regulation 19, A.C.A. §8-4-203 as referenced by §8-4-304 and §8-4-311, and 40 C.F.R. §70.6]
- 129. Records of the water circulated shall be maintained on a twelve month rolling basis, updated monthly. Such records shall be maintained on site and submitted in accordance with General Provision #7. [§19.705 of Regulation 19, and 40 C.F.R., Part 52, Subpart E, beginning April 2, 2001]SN-854 Fugitive Equipment Leaks

SN-858f – Tier 2 Fugitives and Tanks VOC Bubble

Source Description

The fugitive emissions not quantified with the other sources are included in this grouping. This bubble also includes emissions listed in the Tier II Fugitive Bubble (SN-858f). All fugitive emissions from the facility (Including Tier II fugitives) continue to be subject to the 676.4 lb/hr emission limit for SN-854.

Regulations

All fugitive equipment leak sources associated with the Tier II project are subject to 40 CFR Part 60 Subpart GGG – Standards of Performance for Equipment Leaks of VOC from Petroleum Refineries.

All sources of VOC equipment leaks associated with the Tier II project are subject to 40 CFR Part 60 Subpart VV – Standards of Performance for Equipment Leaks of VOC in the Synthetic Organic Chemicals Manufacturing Industry as referenced by Subpart GGG (see Appendix G).

Specific Conditions

130. The facility shall not exceed the emission rates set forth in the following table. Compliance with these limits shall be demonstrated by an annual emissions inventory and the conditions of 40 C.F.R.60, Subparts GGG and VV, as referenced by Subpart GGG and 40 C.F.R. 63, Subpart CC, for those components subject to the requirements of Subparts GGG, VV or CC (respectively). [§19.501 of Regulation 19 et seq., and 40 C.F.R., Part 52, Subpart E]

SN #	Source Description	Pollutant	lb/day	tpy
854	Fugitive Equipment Leaks	VOC	676.4	2962.0
858f	Tier II fugitive Equipment Leaks	VOC	*	41.3

*Short term emissions from Tier II fugitives are subject to the short- term limit for all facility fugitives found under SN-854.

- 131. The facility shall conduct an annual emission inventory to demonstrate compliance with the emission limits of Specific Condition #130. This inventory shall be calculated by the methods and equations used in AP-42, Chapter 5.1 (5th Edition or later version) or Protocol for Equipment Leak Emission Estimates, EPA-453/R-95-017 (November 1995 or later version), or other ADEQ-approved method. [§19.705 of Regulation 19, A.C.A. §8-4-203 as referenced by §8-4-304 and §8-4-311, and 40 C.F.R.70.6]
- 132. Records for the emission inventory required in Specific Condition #131 shall be maintained on an annual basis. The emissions inventory shall be conducted each year, for the preceding calendar year (January 1-December 31), beginning in year 2003, and shall be submitted to the Department at the following address no later than August 1 of each year. [§19.705 of Regulation 19 and 40 C.F.R. Part 52, Subpart E]

Arkansas Department of Environmental Quality

Air Division Attn: Compliance Inspector Supervisor Post Office Box 8913 Little Rock, AR 72219

- 133. The equipment, including each valve, pump, pressure relief device, sampling connection system, open-ended valve or line, and flange or other connector in VOC service in the #4 Crude Unit, #6 Hydrotreater/Isomerization Unit, #12 Distillate Hydrotreater, #17 Sulfur Recovery Plant, the Polymer Asphalt Letdown Facility, and the equipment associated with the Tier II clean fuels project, are affected facilities under the terms of 40 CFR Part 60 Subpart GGG Standards of Performance for Equipment Leaks of VOC in Petroleum Refineries. For the purposes of recordkeeping and reporting only, compressors are also considered affected facilities (see Appendix F). The facility is subject to the Subpart GGG requirements, which are summarized below. [§19.304 of Regulation 19, and 40 CFR §60.590(a)(1) and (3)]
 - a. The facility shall comply with the standards for specific equipment found in §§ 60.482-1 to 60.482-10 of 40 C.F.R. 60, Subpart VV. [§60.592(a)]
 - b. An owner or operator may elect to comply with the alternative standards for valves in §§ 60.483-1 and 60.483-2. [§60.592(b)]
 - c. An owner or operator may apply to the Administrator for a permit modification for a determination of equivalency for any means of emission limitation that achieves a reduction in emissions of VOC at least equivalent to the reduction in emissions of VOC achieved by the controls required in this subpart. In doing so, the owner or operator shall comply with requirements of § 60.484. [§60.592(c)]
 - d. Each owner or operator subject to the provisions of this subpart shall comply with the testing provisions of § 60.485 except as provided in § 60.593. [§60.592(d)]
 - e. Each owner or operator subject to the provisions of this subpart shall comply with the recordkeeping and reporting provisions of §§ 60.486 and 60.487. [§60.592(e)]
 - f. Each owner or operator subject to the provisions of this subpart may comply with the allowable exceptions to the provisions of subpart VV. [§60.593(a)]
- 134. This facility is subject to 40 CFR Part 60 Subpart VV-Standards of Performance for Equipment Leaks of VOC in the Synthetic Organic Chemicals Manufacturing Industry as referenced by Subpart GGG (see Appendix G). The facility is subject to the requirements of Subpart VV which are summarized below. [§19.304 of Regulation 19, and 40 CFR §§60.590 and 60.592]
 - a. The facility shall demonstrate compliance with the requirements of §§60.482-1 to 60.482-10 for all equipment within 180 days of initial startup. [§60.482-1(a)]
 - b. Compliance with §§60.482-1 to 60.482-10 will be determined by review of records and reports, review of performance test results, and inspection using the methods and procedures specified in §60.485. [§60.482-1(b)]

- c. The facility may request a determination of equivalence of a means of emission limitation to the requirements of §§60.482-2, 60.482-3, 60.482-5, 60.482-6, 60.482-7, 60.482-8, and 60.482-10 as provided in § 60.484. (Note: This will require a permit modification.) [§60.482-1(c)(1)]
- d. If the Administrator makes a determination that a means of emission limitation is at least equivalent to the requirements of §§60.482-2, 60.482-3, 60.482-5, 60.482-6, 60.482-7, 60.482-8, or 60.482-10, the facility shall comply with the requirements of that determination. (Note: This will require a permit modification.) [§60.482-1(c)(2)]
- e. The compressors in hydrogen service are not subject to this subpart as per the exemption of § 60.593(b)(1). [§60.482-3(a)]
- f. The facility has no pressure relief devices in gas/vapor service and is not subject to this section. [§60.482-4]
- g. Each open-ended valve or line shall be equipped with a cap, blind flange, plug, or a second valve, except as provided in § 60.482-1(c). [§60.482-6(a)(1)]
- h. The cap, blind flange, plug, or second valve shall seal the open end at all times except during operations requiring process fluid flow through the open-ended valve or line. [§60.482-6(a)(2)]
- i. Each open-ended valve or line equipped with a second valve shall be operated in a manner such that the valve on the process fluid end is closed before the second valve is closed. [§60.482-6(b)]
- j. When a double block-and-bleed system is being used, the bleed valve or line may remain open during operations that require venting the line between the block valves but shall comply with paragraph (a) at all other times. [§60.482-6(c)]
- k. The facility shall comply with the requirements for valves in gas/vapor service or in light liquid service. [§60.482-7]
- 1. The facility shall comply with the requirements for closed vent systems and control devices. [§60.482-10]
- m. The facility has elected to comply with the alternative work practice specified in paragraphs (b)(3) of this section. [§60.483-2]
- n. The facility has notified the Administrator before implementing these alternative work practices, as specified in §60.487(d). [§60.483-2(2)]
- o. The facility has initially complied with the requirements for valves in gas/vapor service and valves in light liquid service, as described in §60.482-7. [§60.483-2(b)(1)]

- p. After 5 consecutive quarterly leak detection periods with the percent of valves leaking equal to or less than 2.0, an owner or operator may begin to skip 3 of the quarterly leak detection periods for the valves in gas/vapor and light liquid service. [§60.483-2(b)(3)]
- q. If the percent of valves leaking is greater than 2.0, the owner or operator shall comply with the requirements as described in § 60.482-7 but can again elect to use this section. [§60.483-2(b)(4)]
- r. In conducting the performance tests required in §60.8, the facility shall use as reference methods and procedures the test methods in Appendix A of this part or other methods and procedures as specified in this section, except as provided in §60.8(b). [§60.485(a)]
- s. The facility shall determine compliance with the standards in §§60.482 and 60.483 as follows: [§60.485(b)]
 - i. Method 21 (or other approved method) shall be used to determine the presence of leaking sources. The instrument shall be calibrated before use each day of its use by the procedures specified in Method 21 (or other approved method). The following calibration gases shall be used:
 - 1. Zero air (less than 10 ppm of hydrocarbon in air); and
 - 2. A mixture of methane or n-hexane and air at a concentration of about, but less than, 10,000 ppm methane or n-hexane.
- t. The facility shall determine compliance with the no detectable emission standards in §§60.482-2(e), and 60.482-3(i) as follows: [§60.485(c)]
 - i. The requirements of paragraph (b) shall apply.
 - Method 21 (or other approved method) shall be used to determine the background level. All potential leak interfaces shall be traversed as close to the interface as possible. The arithmetic difference between the maximum concentration indicated by the instrument and the background level is compared with 500 ppm for determining compliance.
 - iii. Samples used in conjunction with paragraphs (d), (e), and (g) shall be representative of the process fluid that is contained in or contacts the equipment or the gas being combusted in the flare. [§60.485(f)]
- u. The facility shall comply with the recordkeeping requirements of this section. [§60.486(a)(1)]
- An owner or operator of more than one affected facility subject to the provisions of this subpart may comply with the recordkeeping requirements for these facilities in one recordkeeping system if the system identifies each record by each facility. [§60.486(a)(2)]

- w. When each leak is detected as specified in §§60.482-2, 60.482-3, 60.482-7, 60.482-8, and 60.483-2, the following requirements apply: [§60.486(b)]
 - i. A weatherproof and readily visible identification, marked with the equipment identification number, shall be attached to the leaking equipment.
 - ii. The identification on a valve may be removed after it has been monitored for 2 successive months as specified in §60.482-7(c) and no leak has been detected during those 2 months.
 - iii. The identification on equipment except on a valve, may be removed after it has been repaired.
- x. The provisions of §60.7 (b) and (d) do not apply to affected facilities subject to this subpart. [§60.486(k)]
- y. The facility shall submit semiannual reports to the Administrator beginning six months after the initial start up date. [§60.487(a)]
- z. The initial semiannual report to the Administrator shall include the following information: [§60.487(b)]
 - i. Process unit identification.
 - 1. Number of valves subject to the requirements of §60.482-7, excluding those valves designated for no detectable emissions under the provisions of §60.482-7(f).
 - 2. Number of pumps subject to the requirements of §60.482-2, excluding those pumps designated for no detectable emissions under the provisions of §60.482-2(e) and those pumps complying with §60.482-2(f).
 - 3. Number of compressors subject to the requirements of §60.482-3, excluding those compressors designated for no detectable emissions under the provisions of §60.482-3(i) and those compressors complying with §60.482-3(h).
- aa. All semiannual reports to the Administrator shall include the following information, summarized from the information in §60.486: [§60.487(c)]
 - i. Process unit identification.
 - ii. For each month during the semiannual reporting period,
 - 1. Number of valves for which leaks were detected as described in §60.482(7)(b) or §60.483-2,
 - 2. Number of valves for which leaks were not repaired as required in §60.482-7(d)(1),
- 3. Number of pumps for which leaks were detected as described in §60.482-2(b) and (d)(6)(i),
- 4. Number of pumps for which leaks were not repaired as required in §60.482-2(c)(1) and (d)(6)(ii),
- 5. Number of compressors for which leaks were detected as described in \$60.482-3(f),
- 6. Number of compressors for which leaks were not repaired as required in §60.482-3(g)(1), and
- 7. The facts that explain each delay of repair and, where appropriate, why a process unit shutdown was technically infeasible.
- iii. Dates of process unit shutdowns which occurred within the semiannual reporting period.
- iv. Revisions to items reported according to paragraph (b) if changes have occurred since the initial report or subsequent revisions to the initial report.
- bb. The facility has elected to comply with the provisions of §60.483-2 and has notified the Administrator of the alternative standard selected 90 days before implementing the provision. If the facility decides to comply with the provisions of §60.483-1, the facility shall notify the Administrator 90 days in advance before implementing the provisions. [§60.487(d)]
- cc. The facility shall report the results of all performance tests in accordance with §60.8 of the General Provisions. The provisions of §60.8(d) do not apply to affected facilities subject to the provisions of this subpart except that the facility must notify the Administrator of the schedule for the initial performance tests at least 30 days before the initial performance tests. [§60.487(e)]
- 135. In order to demonstrate compliance with Subparts GGG and VV the facility shall maintain a log of the following. [§19.304 of Regulation 19, and 40 C.F.R. 60, Subparts GGG and VV]
 - a. Compliance with testing provisions as required by §60.592(d).
 - b. Any exemptions for compressors considered to be in hydrogen service.
 - c. Any exemptions for equipment that is in vacuum service as provided by §60.482-1(d).
 - d. Monthly monitoring results of §60.482-2(a)(1).
 - e. Weekly visual inspection checks of liquids dripping of §60.482-2(a)(2).
 - f. Record of instrument reading of §60.482-2(b)(1).
 - g. Record of leaks from pump seal in §60.482-2(b)(2).

- h. Attempts to repair leak within 15 days as provided by 60.482-2(c)(1).
- i. Attempts to repair leak within 5 days as provided by 60.482-2(c)(2).
- j. Records of exemption for each pump equipped with a dual mechanical seal system as provided by §60.482-2(d).
- k. Records of exemption for any pump designated for no detectable emission as provided by §60.482-2(e).
- 1. Records of exemption for any pump equipped with a closed vent system as provided by \$60.482-2(f).
- m. Records that each sampling connection system is equipped with a closed purge system or closed vent system in §60.482-5(a) and (b) or qualifies for the exemptions.
- n. All in-situ sampling systems that are exempt in §60.482-5(c).
- o. Record of monitoring of potential leaks within 5 days as required by §60.482-8(a).
- p. Record of leaks detected in §60.482-8(b).
- q. Attempts to repair leak within 15 days as provided by §60.482-8(c)(1).
- r. Attempts to repair leak within 5 days as provided by 60.482-8(c)(2).
- s. Record of delay of repair of equipment as allowed in §60.482-9(a) or (b).
- t. Record of delay of repair of equipment as allowed in §60.482-9(c).
- u. Record of delay of repair of equipment as allowed in §60.482-9(d).
- v. Delays of repair beyond a process unit shutdown as allowed in §60.482-9(e).
- w. Record of the percent of valves leaking as required in §60.483-2(5) and (6).
- x. Records of the tests and results of §60.485(d).
- y. Results of §60.485.
- z. Records of §60.485(g).
- aa. Information required by §60.486(c) for leaks.
- bb. Information required by \$60.486(d) for the design requirements for closed vent system/control device.
- cc. Information required by §60.486(e) for the equipment.
- dd. Information required by §60.486(f) for the valves.

- ee. Information required by §60.486(g) for the valves.
- ff. Information required by §60.486(h).
- gg. Requirements to show that equipment is not in VOC service as provided by §60.486(j).

SN-856 - Facility Tanks – Plantwide Applicability Limit (PAL) SN-858t – Tier 2 Fugitives and Tanks VOC Bubble

Source Description

In order to demonstrate compliance with the emission limits for the tanks, the facility has decided to operate under a Plantwide Applicability Limit (PAL). The PAL is meant to allow the facility flexibility in operation and production while at the same time limiting the aggregate emissions from the tanks. The following is a summary of all tanks (including Tier II tanks, SN-858t) included in the PAL and the applicable regulations.

One new asphalt storage tank is added to the tank PAL with this modification. This tank will be a 150,000 bbl (nominal) tank.

For simplicity, all of the tanks are described in the following table.

FCR	Fixed Cone Roof			
FDR	Fixed Dome Roof			
FFR	Fixed Flat Roof			
EFR	External Floating Roof			
IFR	Internal Floating Roof			
OR	Open Roof Tank			
HOR	Horizontal Tank			

Table 35 – Tank Type Key

Table 36 – Tank Description

SN	Tank Design	Year	Storage Capacity (barrels)	NSPS Regulation
T-3	FCR	1950	3,320	
T-4	FCR	1953	4,890	
T-7	EFR	1999	20,000	Kb
T-11	FCR	1959	4,930	
T-12	FCR	1955	4,930	
T-14	FCR	1942	2,997	

SN	Tank Design	Year	Storage Capacity (barrels)	NSPS Regulation
T-15	FCR	1942	2,997	
T-16	FCR	1950	4,412	
T-17	FCR	1940	3,672	
T-18	FCR	1949	3,160	
T-19	FCR	2002	2,000	Kb
T-22	FCR	1953	1,930	
T-23	FCR	1953	1,930	
T-24	FCR	1999	3,059	UU see notes ⁱⁱⁱ
T-25	FCR	1940	14,940	
T-27	FCR	1950	3,553	
T-36	IFR	1953	4,890	
T-39	FCR	1958	4,890	
T-40	FCR	1940	3,672	
T-41	FCR	2005	3,672	UU
T-46	HOR	1933	752	
T-48	FCR	1923	1,120	
T-49	FCR	1923	1,120	
T-50	FCR	1937	9,984	
T-51	FCR	1940	11,748	
T-54*	FDR	1922	15,090	
T-55	FFR	1923	15,090	
T-56	FCR	1923	15,090	

SN	Tank Design	Year	Storage Capacity (barrels)	NSPS Regulation
T-57	FCR	1949	10,330	
T-58	FFR	1952	10,120	
T-59	FCR	2002	8,200	Kb
T-60	FCR	1923	15,090	
T-61	EFR	1949	20,160	
T-62	EFR	1949	20,140	
T-63	FCR	1957	8,602	
T-64	IFR	1957	10,120	
T-65	EFR	1954	10,120	
T-70	FCR	1935	976	
T-71	FCR	1935	976	
T-72	FCR	1950	900	
T-73	FCR	1950	900	
T-74	FCR	1950	900	
T-76	FCR	1938	36,293	
T-77	FCR	1945	100	
T-78	FCR	1999	5,000	UU
T-81	FFR	1936	5,079	
T-82	FCR	2004	20,081	
T-83	FCR	1938	20,039	
T-84	FCR	1953	10,120	
T-85	IFR	1954	10,120	

SN	Tank Design	Year	Storage Capacity (barrels)	NSPS Regulation
T-88	EFR	1987	20,120	Kb
T-89	EFR	1948	20,120	
T-96	FCR	1940	990	
T-97	FCR	1940	990	
T-98	FCR	1940	990	
T-99	FCR	1940	1,008	
T-101	FCR	1922	54,990	
T-102	FCR	1922	55,236	
T-103	EFR	1995	50,000	Kb
T-104	FCR	1923	55,500	
T-105	FCR	1923	64,310	
T-107	FCR	1923	55,140	
T-108*	IFR	1982	55,447	Ka
T-109*	IFR	1982	55,367	Ka
T-110	FCR	1928	55,628	
T-111	FCR	1936	55,755	
T-112*	FCR	2005	151,065	UU
				see notes ⁱⁱⁱ
T-113*	EFR	2003	50,000	Kb
T-114	FCR	1923	54,720	
T-115	FCR	1923	54,601	
T-116	FCR	1923	55,050	

SN	Tank Design	Year	Storage Capacity (barrels)	NSPS Regulation
T-117	FCR	1923	55,000	
T-118	FCR	1944	54,813	
T-119*	FCR	1940	55,140	
T-120	IFR	1949	80,419	
T-121*	FCR	1949	80,440	
T-122*	FCR	2953	80,440	
T-123	EFR	1949	80,377	
T-124	EFR	1959	54,432	
T-125	EFR	1953	55,960	
T-126	EFR	1953	55,960	
T-128	EFR	1959	81,216	
T-129	FCR	1937	2,546	
T-142	FCR	1982	2,000	see notes ^{iv}
T-143	FCR	1982	2,000	see notes ^{iv}
T-145	FCR	1950	241	
T-162	FCR	1951	2,050	
T-165	HOR	1923	1,120	
T-166	HOR	1923	1,120	
T-167	FCR	1940	1,120	
T-168	FCR	1940	1,331	
T-170	FCR	1950	644	
T-171	FCR	1950	644	

SN	Tank Design	Year	Storage Capacity (barrels)	NSPS Regulation
T-173	HOR	1945	420	
T-175	FCR	1940	5,128	
T-176	FCR	1940	5,128	
T-180	FCR	1959	300	
T-188	FCR	1981	5,060	Ka
T-190	HOR	1940	158	
T-199	FCR	1957	1,893	
T-200	FCR	1936	2,180	
T-201	HOR	2004	500	
T-217	HOR	1964	52	
T-219	FCR	1967	56,000	
T-226	FCR	1936	273	
T-228	FCR	1936	273	
T-240	FCR	1953	3,036	
T-241	FCR	1953	2,775	
T-242	FCR	1953	2,688	
T-243	FCR	1953	3,279	
T-244	FCR	1953	2,088	
T-245	IFR	1953	3,132	
T-246	IFR	1953	3,107	
T-247*	IFR	2003	5,130	Kb
T-262	FCR	1938	5,061	

SN	Tank Design	Year	Storage Capacity (barrels)	NSPS Regulation
T-263	FCR	1938	5,061	
T-264	FCR	1938	5,061	
T-265	FCR	1938	5,061	
T-270	FCR	1941	9,384	
T-271	FCR	1941	9,240	
T-272	FCR	1986	1,000	see notes ⁱⁱⁱ
T-273	FCR	1986	1,000	see notes ⁱⁱⁱ
T-274	FCR	1986	1,000	see notes ⁱⁱⁱ
T-306	FCR	1952	133	
T-310	FCR	1950	992	
T-311	FCR	1950	54	
T-312	FCR	1950	54	
T-313	FCR	1950	54	
T-314	FCR	1950	52	
T-315	FCR	1950	52	
T-319	FCR	1950	286	
T-320	FCR	1950	286	
T-321	FCR	1950	286	
T-322	FCR	1950	286	
T-323	FCR	1950	286	
T-324	FCR	1992	286	see notes ^v
T-325	FCR	1950	286	

SN	Tank Design	Year	Storage Capacity (barrels)	NSPS Regulation
T-326	FCR	1950	286	
T-327*	FCR	1950	286	
T-328	FCR	1950	286	
T-329	FCR	1950	286	
T-330	FCR	1950	286	
T-331	FCR	1950	286	
T-332	FCR	1950	286	
T-333	FCR	1950	286	
T-335	FCR	1950	95	
T-336	FCR	1950	95	
T-337	FCR	1950	95	
T-338	FCR	1950	95	
T-339	FCR	1950	95	
T-340	FCR	1961	504	
T-348	FCR	1968	5,275	
T-349	FCR	1968	5,279	
T-350	FCR	1954	1,382	
T-351	FCR	1954	1,382	
T-352	FCR	1954	1,382	
T-353	FCR	1954	1,382	
T-354	FCR	1954	1,386	
T-355	FCR	1959	1,006	

SN	Tank Design	Year	Storage Capacity (barrels)	NSPS Regulation
T-356	FCR	1961	285	
T-360	IFR	1957	15,120	
T-361	IFR	1957	15,120	
T-368	FCR	1966	10,120	
T-371	IFR	1959	10,120	
T-372	IFR	2003	10,120	Kb
T-382	FCR	2000	5,000	UU
				see notes ⁱⁱⁱ
T-383	FCR	2000	5,000	UU
				see notes ⁱⁱⁱ
T-384	FCR	1999	3,060	UU
				see notes ⁱⁱⁱ
T-385	FCR	1999	3,060	UU
				see notes ⁱⁱⁱ
T-386	FCR	1999	3,060	UU
				see notes ⁱⁱⁱ
T-387	FCR	1999	3,060	UU
				see notes ⁱⁱⁱ
T-410	FCR	circa-194 5	80,760	
T-411	FCR	circa-194 5	80,760	
T-412	FCR	circa-194 5	80,760	

SN	Tank Design	Year	Storage Capacity (barrels)	NSPS Regulation
T-413	FCR	circa-194 5	80,760	
T-414	FCR	circa-194 5	80,760	
T-432	FCR	1978	2,025	see notes ^{iv}
T-520	FCR	1950	55,000	
T-521	EFR	1950	55,000	
T-524	FCR	1951	55,000	
T-525	EFR	1951	55,000	
T-530	FCR	1951	55,000	
T-532	IFR	1981	32,784	Ka
T-538	FCR	1989	24	see notes ^{vi}
T-539	FCR	1989	24	see notes ^{vi}
T-540	HOR	1987	242	
T-544	FCR	1991	5,250	see notes ⁱⁱⁱ
T-548	FCR	1993	100,000	see notes ⁱⁱⁱ
T-549	FCR	1994	143	see notes ^{vi}
T-550	HOR	1985	48	see notes ^{vi}
T-551	HOR	1994	24	see notes ^{vi}
T-552	HOR	1996	242	see notes ^{vi}
T-553	FCR	1999	1,500	see notes ⁱⁱⁱ
T-570	EFR	1959	125,000	
T-600	HOR	1994	48	see notes ^{vi}

SN	Tank Design	Year	Storage Capacity (barrels)	NSPS Regulation	
T-601	HOR	1994	24	see notes ^{vi}	
T-602	HOR	1994	24	see notes ^{vi}	
T-603	HOR	1995	24	see notes ^{vi}	
T-604	HOR	1994	13	see notes ^{vi}	
T-605	HOR	1996	13	see notes ^{vi}	
T-606	HOR	1996	13	see notes ^{vi}	
T-607	HOR	1990	36	see notes ^{vi}	
T-608	HOR	1987	190	see notes ^{vi}	
T-609	HOR	1995	143	see notes ^{vi}	
T-610	FCR	1980	8	see notes ⁱⁱ	
T-611	FCR	1995	190	see notes ^{vi}	
T-612	FCR	1995	71	see notes ^{vi}	
T-613	HOR	2000	75	see notes ^{vi}	
T-616	FCR	2000	48	see notes ^{vi}	
T-618	FCR	2001	24	see notes ^{vi}	
T-619	HOR	2001	48	see notes ^{vi}	
T-620	HOR	2001	24	see notes ^{vi}	
T-621	HOR	2001	13	see notes ^{vi}	
T-622	HOR	2001	24	see notes ^{vi}	
*Denotes a ta	*Denotes a tank associated with the Tier II project.				

NSPS Regulation Notes

i. Reserved

- Pursuant to 40 C.F.R. 60, Subpart Ka-Standards of Performance for Storage Vessels for Petroleum Liquids for Which Construction, Reconstruction, or Modification Commenced after May 18, 1978, and Prior to July 23, 1984, Tank T-610 is not an affected source because it is smaller than 40,000 gallons.
- iii. Pursuant to 40 C.F.R. 60, Subpart Kb- Standards of Performance for Volatile Organic Liquid Storage Vessels (Including Petroleum Liquid Storage Vessels) for Which Construction, Reconstruction, or Modification Commenced after July 23, 1984, tanks T-24, T-113, T-272 through T-274, T-382 through T-387, T-544, T-548, and T-553 are exempt from the control requirements of Subpart Kb by §60.112b(a) because they store a liquid with a maximum true vapor pressure less than 5.2 kPa (0.75 psia) (see Appendix B).
- iv. Pursuant to 40 C.F.R. 60, Subpart Ka-Standards of Performance for Storage Vessels for Petroleum Liquids for Which Construction, Reconstruction, or Modification Commenced after May 18, 1978, and Prior to July 23, 1984, T-142, T-143, T-188 and T-432 are not affected facilities because they do not store volatile organic liquids with vapor pressure greater than 1.5 psia (10.3 kPa) (see Appendix A).
- v. Pursuant to 40 C.F.R. 60, Subpart Kb-Standards of Performance for Volatile Organic Liquid Storage Vessels (Including Petroleum Liquid Storage Vessels) for Which Construction, Reconstruction, or Modification Commenced after July 23, 1984, tank T-324 is not an affected source under §60.110(a) because it does not contain a VOL (see Appendix B).
- vi. Pursuant to 40 C.F.R. 60, Subpart Kb-Standards of Performance for Volatile Organic Liquid Storage Vessels (Including Petroleum Liquid Storage Vessels) for Which Construction, Reconstruction, or Modification Commenced after July 23, 1984, tank's T-538, T-539, T-549 to T-552, T-600 to T-609, T-611, T-612, T-613, T-616, T-618, T-619, T-620, T-621, and T-622 are not affected sources because they are smaller than 75 m³.
- vii. All other tanks, which are not listed above except tanks T-7, T-19, T-59, T-88, T-103, T-108, T-109, T-113, T-188, T-247, T-372, and T-532, are not subject to 40 C.F.R. 60, Subparts K, Ka, or Kb. The NSPS requirements for tanks these tanks are outlined in the Specific Conditions.
- viii. All tanks have been classified as a Group I or Group II storage vessel in accordance with the provisions of 40 C.F.R. 63, Subpart CC-*National Emission Standards for Hazardous Air Pollutants from Petroleum Refineries*. Subpart CC is outlined in the Plantwide Conditions of this permit.

Specific Conditions

136. The facility shall not exceed the emission rates set forth in the following table. Compliance with these limits shall be demonstrated by completing an annual emissions inventory, refinery crude feed rate limits, and maximum vapor pressure restrictions. [§19.501 of Regulation 19 *et seq.*, and 40 C.F.R., Part 52, Subpart E]

Table 37 – Tank Criteria Emissions

SN	Pollutant	lb/hr	tpy	
856	PM_{10}	13.9	3.4	
	VOC	13,651.3	3308.6	
	CO	273.3	66.3	
858t	VOC	*	322.5	
* Short term emissions from Tier II tanks (SN-858t)				

are subject to the short-term limit for all facility tanks found under SN-856.

137. The facility shall store only products with calendar month average true vapor pressure equal to or less than the vapor pressure listed for each tank in the following table. [§19.501 of Regulation 19 and 40 C.F.R. §70.6]

SN	Maximum Vapor
	Pressure
PAL	
T-3	14.7 ^D
T-4	14.7 ^D
T-7	11.1 ^{FR}
T-11	14.7 ^D
T-12	14.7 ^D
T-14	14.7 ^D
T-15	14.7 ^D
T-16	14.7 ^D
T-17	14.7 ^D
T-18	14.7 ^D
T-19	0.75 ^{NC}
T-20	removed from
	service, 2004
T-21	removed from
	service, 2004
T-22	14.7 ^D
T-23	14.7 ^D
T-24	0.75 ^{NC}
T-25	14.7 ^D
T-27	14.7 ^D

Table 38 – Tank Vapor Pressure

SN	Maximum Vapor
	Pressure
T-36	11.1 **
T-39	14.7 ^D
T-40	14.7 ^D
T-41	14.7 ^C
T-46	14.7 ^D
T-48	14.7 ^D
T-49	14.7 ^D
T-50	14.7 ^D
T-51	14.7 ^D
T-54	14.7 ^D
T-55	14.7 ^D
T-56	14.7 ^D
T-57	14.7 ^D
T-58	14.7 ^D
T-59	0.75 ^{NC}
T-60	14.7 ^D
T-61	11.1 ^{FR}
T-62	11.1 ^{FR}
T-63	14.7 ^D
T-64	11.1 ^{FR}
T-65	11.1 ^{FR}
T-70	14.7 ^D
T-71	14.7 ^D
T-72	14.7 ^D
T-73	14.7 ^D
T-74	14.7 ^D
T-76	14.7 ^D
T-77	14.7 ^D
T-78	14.7 ^D
T-81	14.7 ^D

SN	Maximum Vapor
T 0 2	Pressure
T-82	0.75***
T-83	14.7 ^D
T-84	14.7 ^D
T-85	11.1 ^{FR}
T-88	11.1 ^{FR}
T-89	11.1 ^{FR}
T-96	14.7 ^D
T-97	14.7 ^D
T-98	14.7 ^D
T-99	14.7 ^D
T-101	14.7 ^D
T-102	14.7 ^D
T-103	11.1 ^{FR}
T-104	14.7 ^D
T-105	14.7 ^D
T-107	14.7 ^D
T-108	1.5 ^{NC}
T-109	1.5 ^{NC}
T-110	14.7 ^D
T-111	14.7 ^D
T-112	0.75 ^{NC}
T-113	11.1 ^{FR}
T-114	14.7 ^D
T-115	14.7 ^D
T-116	14.7 ^D
T-117	14.7 ^D
T-118	14.7 ^D
T-119	14.7 ^D
T-120	11.1 ^{FR}
T-121	14.7 ^D

SN	Maximum Vapor
T_122	Pressure
T 122	14.7
T-125	11.1 FR
1-124	11.1 FR
T-125	
T-126	11.1 ^{гк}
T-128	11.1 ^{FK}
T-129	14.7 ^D
T-142	1.5 ^{NC}
T-143	1.5 ^{NC}
T-145	14.7 ^D
T-162	14.7 ^D
T-165	14.7 ^D
T-166	14.7 ^D
T-167	14.7 ^D
T-168	14.7 ^D
T-170	14.7 ^D
T-171	14.7 ^D
T-173	14.7 ^D
T-175	14.7 ^D
T-176	14.7 ^D
T-180	14.7 ^D
T-188	1.5 ^{NC}
T-190	14.7 ^D
T-199	14.7 ^D
T-200	14.7 ^D
T-201	14.7 ^C
T-217	14.7 ^D
T-219	14.7 ^D
T-226	14.7 ^D
T-228	14.7 ^D

SN	Maximum Vapor
T 2 40	Pressure
T-240	14.75
T-241	14.7 ^D
T-242	14.7 ^D
T-243	14.7 ^D
T-244	14.7 ^D
T-245	11.1 ^{FR}
T-246	11.1 ^{FR}
T-247	11.1 ^{FR}
T-262	14.7 ^D
T-263	14.7 ^D
T-264	14.7 ^D
T-265	14.7 ^D
T-270	14.7 ^D
T-271	14.7 ^D
T-272	0.75 ^{NC}
T-273	0.75 ^{NC}
T-274	0.75 ^{NC}
T-306	14.7 ^D
T-310	14.7 ^D
T-311	14.7 ^D
T-312	14.7 ^D
T-313	14.7 ^D
T-314	14.7 ^D
T-315	14.7 ^D
T-319	14.7 ^D
T-320	14.7 ^D
T-321	14.7 ^D
T-322	14.7 ^D
T-323	14.7 ^D
T-324	4.0 ^{NC}

SN	Maximum Vapor
	Pressure
T-325	14.75
T-326	14.7 ^D
T-327	14.7 ^D
T-328	14.7 ^D
T-329	14.7 ^D
T-330	14.7 ^D
T-331	14.7 ^D
T-332	14.7 ^D
T-333	14.7 ^D
T-335	14.7 ^D
T-336	14.7 ^D
T-337	14.7 ^D
T-338	14.7 ^D
T-339	14.7 ^D
T-340	14.7 ^D
T-348	14.7 ^D
T-349	14.7 ^D
T-350	14.7 ^D
T-351	14.7 ^D
T-352	14.7 ^D
T-353	14.7 ^D
T-354	14.7 ^D
T-355	14.7 ^D
T-356	14.7 ^D
T-360	11.1 ^{FR}
T-361	11.1 ^{FR}
T-368	14.7 ^D
T-371	11.1 ^{FR}
T-372	11.1 ^{FR}
T-382	0.75 ^{NC}

SN	Maximum Vapor
T-383	0.75 ^{NC}
T-384	0.75 ^{NC}
T_385	0.75 ^{NC}
T_386	0.75 ^{NC}
T-387	0.75 NC
T 410	14 7 ^D
T-410	14.7
T-411	14.72
T-412	14.7 ^b
T-413	14.7 ^D
T-414	14.7 ^D
T-432	1.5 ^{NC}
T-520	14.7 ^D
T-521	14.7 ^D
T-524	14.7 ^D
T-525	14.7 ^D
T-530	14.7 ^D
T-532	11.1 ^{FR}
T-538	14.7 ^C
T-539	14.7 ^C
T-540	14.7 ^C
T-544	0.75 ^{NC}
T-548	0.75 ^{NC}
T-549	14.7 ^C
T-550	14.7 ^C
T-551	14.7 ^C
T-552	14.7 ^C
T-553	0.75 ^{NC}
T-570	14.7 ^D
T-600	14.7 ^C
T-601	14.7 ^C

SN	Maximum Vapor		
	Pressure		
T-602	14.7 ^C		
T-603	14.7 ^C		
T-604	14.7 ^C		
T-605	14.7 ^C		
T-606	14.7 ^C		
T-607	14.7 ^C		
T-608	14.7 ^C		
T-609	14.7 ^C		
T-610	14.7 ^C		
T-611	14.7 ^C		
T-612	14.7 ^C		
T-613	14.7 ^C		
T-616	14.7 ^C		
T-618	14.7 ^C		
T-619	14.7 ^C		
T-620	14.7 ^C		
T-621	14.7 ^C		
T-622	14.7 ^C		

- 14.7^D No limit or restriction on v.p. the construction date is prior to the NSPS date. Reference to 14.7 psi is not intended to be a limitation on the maximum v.p. stored, but is included as a representative pressure of materials that might be stored at atmospheric conditions.
- 14.7^C No limit or restriction on v.p. capacity of tank is below the NSPS applicability capacity of 19,800 gals for NSPS Kb or 40,000 gals for NSPS K & Ka. Reference to 14.7 psi is not intended to be a limitation on the maximum v.p. stored, but is included as a representative pressure of materials that might be stored at atmospheric conditions.
- 14.7^V No limit or restriction on v.p. the product stored does not meet the definition of a VOL under NSPS Kb. Reference to 14.7 psi is not intended to be a limitation on the maximum v.p. stored,

but is included as a representative pressure of materials that might be stored at atmospheric conditions.

- 14.7^P No limit or restriction on v.p. the product does not meet the definition of a petroleum liquid under NSPS Ka. Reference to 14.7 psi is not intended to be a limitation on the maximum v.p. stored, but is included as a representative pressure of materials that might be stored at atmospheric conditions.
- x^{NC} V. P. restricted or limited No Controls required; v.p. of product is below the limit that requires controls : 0.75 psia (5.2 kPa) for NSPS Kb (for tanks > 40,000 gal.); 4.0 psia (27.6 kPa) for NSPS Kb (for tanks with capacities between 20,000 and 40,000 gallons); or 1.5 psia (10.3 kPa) for NSPS K & Ka. See 40 C.F.R. §60.112b(a) and 60.112a(a).
- x^{FR} V. P. restricted or limited v.p. of the product cannot exceed 11.1 psia (76.6 kPa) based on using a Floating Roof as the control standard as required by the NSPS and/or MACT standard.
- 138. Solely for purposes of demonstrating compliance with the Tank PAL emission limits, the facility shall not exceed a total refinery crude feed rate of 100,000 barrels per day and a total of 36.6 MM bbls per consecutive twelve-month period. This limit is solely to demonstrate compliance with the emission limits in Specific Condition 136 and does not establish any production rate, design capacity or other limitation. [§19.705 of Regulation 19 and 40 C.F.R. §70.6]
- 139. The facility shall maintain records of the total refinery crude feed rate to the facility on a daily basis and on a twelve-month rolling basis, both updated monthly. Such records shall be maintained on-site and submitted in accordance with General Provision #7. [§19.705 of Regulation 19, and 40 C.F.R., Part 52, Subpart E]
- 140. The facility shall conduct an annual inventory of emissions of the pollutants listed in Specific Condition 136. The emissions inventory shall be conducted each year, for the preceding calendar year (January 1-December 31), and shall be submitted to the Department at the following address no later than August 1 of each year. If the annual emissions inventory demonstrates that the permittee has exceeded any permit limit, it shall not be a violation of the permit provided that the exceedance is due to a change in a published emission factor upon which the permittee relied in setting the permitted limit or new published emission factors. [§19.705 of Regulation 19, and 40 C.F.R., Part 52, Subpart E]

Arkansas Department of Environmental Quality Air Division Attn: Compliance Inspector Supervisor Post Office Box 8913 Little Rock, AR 72219

141. Under the terms of 40 CFR, Part 60, Subpart Ka-Standards of Performance for Storage Vessels for Petroleum Liquids for Which Construction, Reconstruction, or Modification Commenced

after May 18, 1978, and Prior to July 23, 1984, tanks T-108, T-109, 142, 143, 188, and 432 do not store a petroleum liquid with a true vapor pressure of 10.3 kPa (1.5 psia) or greater; and therefore are exempt from control requirements of Subpart Ka pursuant to 60.112a(a) (see Appendix A). Therefore, any petroleum liquid stored in these tanks shall have a vapor pressure less than 10.3 kPa (1.5 psia). Pursuant to 60.115a(a), the facility must maintain a record of the petroleum liquid stored, the period of storage, and the maximum true vapor pressure of that liquid during the respective storage period. [19.304 of Regulation 19 and 40 CFR 60.112a]

- 142. Tank T-532 is an affected facility under the terms of 40 CFR 60, Subpart Ka- Standards of Performance for Storage Vessels for Petroleum Liquids for Which Construction, Reconstruction, or Modification Commenced After May 18, 1978, and Prior to July 23, 1984. However, in accordance with 40 C.F.R., Part 63, Subpart CC- National Emission Standards for Hazardous Air Pollutants From Petroleum Refineries, §63.640(n), the facility is only required to comply with the provisions of Subpart CC (see Appendix A). [19.304 of Regulation 19 and 40 CFR 63.640(n)]
- 143. Under the terms of 40 CFR Part 60 Subpart Kb-Standards of Performance for Volatile Organic Liquid Storage Vessels (Including Petroleum Liquid Storage Vessels) for Which Construction, Reconstruction, or Modification Commenced after July 23, 1984, tanks T-7, T-88, T-103, T-113, T-247, and T-372 are affected facilities. The tanks are subject to the Subpart Kb requirements, which are summarized below (for the full regulation, see Appendix B). [§19.304 of Regulation 19, and 40 CFR §60.110b]
 - a. Tank T-7, T-88, T-103, and T-113 have been equipped with external floating roofs as described in §60.112b(a)(2). [§60.112b(a)]
 - b. Tanks T-247 and T-372 have been equipped with internal floating roofs as described in §60.112b(a)(1). [§60.112b(a)]
 - c. Tank T-7, T-88, T-103, and T-113 have a mechanical shoe seal. Except as provided in §60.113b(b)(4), the seals shall completely cover the annular space between the edge of the floating roof and the tank wall. [§60.112b(a)(2)(i)(A)]
 - d. The secondary seals shall completely cover the annular space between the external floating roof and the wall of the storage vessel in a continuous fashion except as allowed by §60.113b(b)(4). [§60.112b(a)(2)(i)(B)]
 - e. Except for automatic bleeder vents and rim space vents, each opening in the floating roofs provides a projection below the liquid surface. Except for automatic bleeder vents, rim space vents, roof drains, and leg sleeves, each opening in the roof is equipped with a gasketed cover, seal, or lid that is to be maintained in a closed position at all times (i.e., no visible gap) except when the device is in actual use. Automatic bleeder vents are closed at all times when the roof is floating except when the roof is being floated off or is being landed on the roof leg supports. Rim vents are set to open when the roof is being floated off the roof legs supports or at the manufacturer's recommended setting. Automatic bleeder vents and rim space vents are gasketed. Each emergency roof drain is provided with a slotted membrane fabric cover that covers at least 90 percent of the opening of the area. [§60.112b(a)(2)(ii)]

- f. The roof shall be floating on the liquid at all times (i.e., off the roof leg supports) except during initial fill until the roof is lifted off leg supports and when the tank is completely emptied and subsequently refilled. The process of filling, emptying, or refilling when the roof is resting on the leg supports shall be continuous and shall be accomplished as rapidly as possible. [§60.112b(a)(2)(ii)]
- g. Tanks T-7, T-88, T-103, T-113, T-247 and T-372 shall meet the testing requirements of §60.113b(b). [§60.113b]
- h. The facility has determined and will continue to determine the gap areas and maximum gap widths, between the primary seal and the wall of the storage vessel and between the secondary seal and the wall of the storage vessel as prescribed by §60.113b(b)(1)(i). [§60.113b(b)(1)]
- i. Measurements of gaps between the tank wall and the primary seal (seal gaps) shall be performed at least once every 5 years after the date of the initial fill. [§60.113b(b)(1)(i)]
- j. Measurements of gaps between the tank wall and the secondary seal shall be performed at least once per year after the date of the initial fill. [§60.113b(b)(1)(ii)]
- k. If these sources cease to store a VOL for a period of one year or more, subsequent introduction of VOL into the vessels shall be considered an initial fill for the purposes of paragraphs (b)(1)(i) and (b)(1)(ii) of this section. [§60.113b(b)(1)(iii)]
- 1. The facility shall determine gap widths and areas in the primary and secondary seals individually by the procedures outlined in (i), (ii), and (iii) as follows: [§60.113b(b)(2)]
 - i. The facility shall measure seal gaps, if any, at one or more floating roof levels when the roof is floating off the roof leg supports. [§60.113b(b)(2)(i)]
 - ii. The facility shall measure seal gaps around the entire circumference of the tank in each place where a 0.32-cm diameter uniform probe passes freely (without forcing or binding against seal) between the seal and the wall of the storage vessel and measure the circumferential distance of each such location. [§60.113b(b)(2)(ii)]
 - iii. The total surface area of each gap described in paragraph (b)(2)(ii) of this section shall be determined by using probes of various widths to measure accurately the actual distance from the tank wall to the seal and multiplying each such width by its respective circumferential distance. [§60.113b(b)(2)(ii)]
- m. The facility shall add the gap surface area of each gap location for the primary seal and the secondary seal individually and divide the sum for each seal by the nominal diameter of the tank and compare each ratio to the respective standards in paragraph (b)(4). [§60.113b(b)(3)]
- n. The facility shall make necessary repairs or empty the storage vessels within 45 days of identification in any inspection for seals not meeting the requirements listed in (b)(4)(i) and (ii). [§60.113b(b)(4)]

- o. The accumulated area of gaps between the tank wall and the mechanical shoe or liquid mounted primary seal shall not exceed 212 cm2 per meter of tank diameter, and the width of any portion of any gap shall not exceed 3.81 cm. [§60.113b(b)(4)(i)]
- p. One end of the mechanical shoe is to extend into the stored liquid, and the other end is to extend a minimum vertical distance of 61 cm above the stored liquid surface.
 [§60.113b(b)(4)(i)(A)]
- q. There are to be no holes, tears, or other openings in the shoe, seal fabric, or seal envelope. [§60.113b(b)(4)(i)(B)]
- r. The secondary seal is to meet the requirements of the following: [§60.113b(b)(4)(ii)]
 - i. The secondary seal is to be installed above the primary seal so that it completely covers the space between the roof edge and the tank wall except as provided in (b)(2)(iii). [§60.113b(b)(4)(ii)(A)]
 - ii. The accumulated area of gaps between the tank wall and the secondary seal shall not exceed 21.2 cm2 per meter of tank diameter, and the width of any portion of any gap shall not exceed 1.27 cm. [§60.113b(b)(4)(ii)(B)]
 - iii. There are to be no holes, tears, or other openings in the seal or seal fabric. [§60.113b(b)(4)(ii)(C)]
- s. If a failure that is detected during inspections required by paragraph (b)(1), of §60.113b(b) cannot be repaired within 45 days and if the vessel cannot be emptied within 45 days, a 30-day extension may be requested from the Administrator in the inspection report required by §60.115b(b)(4). Such extension request must include a demonstration of unavailability of alternate storage capacity and a specification of a schedule that will assure that the control equipment will be repaired or the vessel will be emptied as soon as possible. [§60.113b(b)(4)(iii)]
- t. The facility shall notify the Administrator 30 days in advance of any gap measurements required by paragraph (b)(1) of this section to afford the Administrator the opportunity to have an observer present. The Department has exercised its authority to grant permission for the 30-day notification period to be shortened to 5 days as indicated by Plantwide Condition #10 (FF) and (GG). [§60.113b(b)(5)]
- u. The facility shall visibly inspect the external floating roof, the primary seal, secondary seal, and fittings each time the vessel is emptied and degassed. [§60.113b(b)(6)]
- v. If an external floating roof has holes, tears, or other openings in the seal or the seal fabric, or the secondary seal has holes, tears, or other openings in the seal or the seal fabric, the facility shall repair the items as necessary so that none of the conditions specified in this paragraph exist before filling or refilling the storage vessel with VOL. [§60.113b(b)(6)(i)]
- w. For all inspections required by (b)(6), the facility shall notify the Administrator in writing at least 30 days prior to the filling or refilling of each storage vessel to afford the

Administrator the opportunity to inspect the storage vessel prior to refilling. If the inspection required by paragraph (b)(6) of this section is not planned and the facility could not have known about the inspection 30 days in advance of refilling the tank, the facility should notify the Administrator at least 7 days prior to the refilling of the storage vessel. Notification shall be made by telephone immediately followed by written documentation demonstrating why the inspection was unplanned. Alternatively, this notification including the written documentation may be made in writing and sent by express mail so that it is received at least 7 days prior to the refilling. The Department has exercised its authority to grant permission for the 30-day and 7-day notification periods to be shortened to 5 days as indicated by Plantwide Condition #10 (FF) and (GG). [§60.113b(b)(6)(ii)]

- x. The facility shall keep records of tanks T-7, T-88, T-103, T-113, T-247 and T-372 as specified in § 60.115b(b)(3). The facility shall keep copies of all reports and records required by this section for at least 2 years. [§60.115b(b)]
- y. The facility has or shall furnish the Administrator with a report that describes the control equipment and certifies that the control equipment meets the specifications of § 60.112b(a)(2) and § 60.113b(a)(2), (b)(3), and (b)(4). [§60.115b(1)]
- z. Within 60 days of performing the seal gap measurements required by §60.113b(b)(1), the facility shall furnish the Administrator with a report that contains: [§60.115b(b)(2)]
 - i. The date of measurement.
 - ii. The raw data obtained in the measurement.
 - iii. The calculations described in § 60.113b(b)(2) and (b)(3).
- aa. The facility shall keep a record of each gap measurement performed as required by §60.113b(b). Each record shall identify the storage vessel in which the measurement was performed and shall contain: [§60.115b(b)(3)]
 - i. The date of measurement.
 - ii. The raw data obtained in the measurement.
 - iii. The calculations described in § 60.113b(b)(2) and (b)(3).
- bb. After each seal gap measurement that detects gaps exceeding the limitations specified by §60.113b(b), submit a report to the Administrator within 30 days of the inspection. The report will identify the vessel and contain the information specified in (b)(2) and the date the vessel was emptied or the repairs made and date of repair. [§60.115b(b)(4)]
- cc. The facility shall keep copies of all records of tanks T-7, T-88, T-103, T-113, T-247 and T-372 as required by §60.116b for at least 2 years. As an exception, the record required by §60.116b(b) shall be kept for the lives of the sources. [§60.116b(a)]

- dd. The facility shall keep readily accessible records showing the dimensions of each vessel and an analysis showing the capacity of each vessel. [§60.116b(b)]
- ee. The facility shall maintain for each tank a record of the VOL stored, the period of storage, and the maximum true vapor pressure of that VOL during the respective storage period. [§60.116b(c)]
- ff. The facility may determine the maximum true vapor pressure as described in \$60.116b(e)(1), (e)(2) and (e)(3). [\$60.116b(e)]
- 144. Tanks T-19, T-24, T-59, T-272 through T-274, T-382 through T-387, T-544, T-548, and T-553 are exempted from the control requirements of Subpart Kb pursuant to 40 C.F.R. 60.112b(a) because they have capacities greater than 151 m³ and store a liquid with a maximum true vapor pressure less than 5.2 kPa (0.75 psia). Therefore, any volatile organic liquid stored in these tanks shall have a vapor pressure less than 5.2 kPa (0.75 psia). These tanks are also subject to the following subpart Kb requirements, which are summarized below (for the full regulation, see Appendix B). [§19.304 of Regulation 19 and 40 CFR §60.112b(a)]
 - a. The facility shall as specified in §60.116b(a) keep the records as required by §60.116b(b) for the lives of the facilities.
 - b. In accordance with §60.116b(b), the facility shall keep readily accessible records showing the dimension of the storage vessel and an analysis showing the capacity of the storage vessel.
 - c. In accordance with \$60.116b(d), the facility shall notify the Department within 30 days when the maximum true vapor pressure exceeds 5.2 kPa (0.75 psia).
 - d. Pursuant to 60.116b(e), the facility may determine the maximum true vapor pressure as described in 60.116b(e)(1), (e)(2) and (e)(3).
- 145. Tank T-324 does not store a volatile organic liquid with a vapor pressure of 15.0 kPa (4.0 psia); and, therefore is exempt from the control requirements of Subpart Kb. As such, any volatile organic liquid stored in this tank shall have a vapor pressure less than 15.0 kPa (4.0 psia). This tank is also subject to the Subpart Kb requirements, which are summarized below (for the full regulation, see Appendix B). [§19.304 of Regulation 19 and 40 CFR §60.110b(c)]
 - a. The facility shall as specified in §60.116b(a) keep the records as required by § 60.116b(b) for the lives of the facilities.
 - b. In accordance with \$60.116b(b), the facility shall keep readily accessible records showing the dimension of the storage vessel and an analysis showing the capacity of the storage vessel.
 - c. In accordance with §60.116b(d), the facility shall notify the Department within 30 days when the maximum true vapor pressure exceeds 15 kPa (4.0 psia).

- d. Pursuant to \$60.116b(e), the facility may determine the maximum true vapor pressure as described in \$60.116b(e)(1), (e)(2) and (e)(3).
- 146. Under the terms of 40 CFR Part 60 Subpart UU- Standards of Performance for Asphalt Processing and Asphalt Roofing Manufacture, tanks T-24, T-41, T-112, T-382, T-383, T-384, T-385, T-386, and T-387 are affected facilities. As such, in accordance with 60.472(c), the tank(s) shall not exhaust gases with an opacity greater than 0 percent, except for one consecutive 15minute period in any 24-hour period when the transfer lines are being cleared. [§19.304 of Regulation 19, and 40 CFR §60.470]
- 147. Under the terms of 40 CFR Part 63 Subpart LLLLL- National Emission Standard for Hazardous Air Pollutants: Asphalt Processing and Asphalt Roofing, tanks T-23, T-78, T-96, T-98, T-99, T-162, T-175, T-176, T-348, T-354 and T-544 are affected facilities. Each of the listed tanks is considered Group 2, and as such, in accordance with Table 1 to Subpart LLLLL, the tank(s) shall not exhaust gases with an opacity greater than 0 percent, except for one consecutive 15-minute period in any 24-hour period when the transfer lines are being cleared. [§19.304 of Regulation 19, and 40 CFR §63.8684(a)]
- 148. Records shall be kept onsite of any activity related to construction, reconstruction, or modification of any of the tanks listed in this section. [§19.705 of Regulation 19, and 40 C.F.R., Part 52, Subpart E]

SN-857 – Naptha Splitter Reboiler Heater SN-860 ULSD Hydrotreater Heater

Source Description

This source consists of the new refinery heaters which were installed as part of the Tier II low-sulfur fuels project completed in 2003/2004. Each of these heaters is being permitted to burn NSPS Subpart J quality gas. SN-857 is the Naptha Splitter Reboiler Heater, and SN-860 is the ULSD Hydrotreater Heater. SN-857 is rated at 53.4 MMBtu/hr, and SN-860 is rated at 43.6 Btu/hr. SN-861 is rated at 20 MMBtu/hr.

Regulations

The Tier II Heaters are subject to 40 CFR Part 60 Subpart J – Standards of Performance for Petroleum Refineries as fuel gas combustion devices.

Interim Conditions

The permittee has requested that interim emission and heat input limits be applied to the Tier 2 Heaters (SN-857, SN-860, and SN-861) in order to keep the total Tier 2 Fuels project below PSD significant emission rate. The interim limits will be valid until another project, the Boiler replacement project, is complete. At that time, when the boilers come on-line with the ultra low-NO_x burners, the emission decreases will be used as a net offset, allowing the Tier 2 heater emissions to run at higher capacity and keeping the project below the PSD significant emission rate. The interim limits will then expire and the permanent limits for these sources will apply. Those permanent conditions are already in place (See Specific Conditions 1 through 1 and7). The following are the interim limits:

Int. 1. The permittee shall not exceed the emission rates set forth in the following table. Compliance with these limits shall be demonstrated by compliance with the throughput limits of this section. [§19.501 of Regulation 19 *et seq.*, and 40 C.F.R., Part 52, Subpart E]

SN #	Source Description	Pollutant	lb/day	tpy
	Naptha Splitter Reboiler Heater	PM ₁₀	1.2	-
		SO_2	2.1	-
857		VOC	0.9	-
		CO	5.2	-
		NO _X	2.2	
		PM ₁₀	1.0	-
860	ULSD Hydrotreater Heater	SO_2	1.7	-
		VOC	0.7	-
		CO	4.2	-
		NO _X	1.8	-

 Table 39 – Interim Criteria Emissions for Tier 2 Heaters

SN #	Source Description	Pollutant	lb/day	tpy
	Hydrogen Plant Heater(s)	PM ₁₀	0.4	-
	Trydrogen Flant Treater(s)	SO_2	0.7	-
861		VOC	0.3	-
		CO	1.7	-
		NO _X	0.7	-
957 960	PM_{10}	-	5.5	
857,860,	SO_2	-	10.0	
861	VOC	-	4.0	
(tpy bubble)	CO	-	24.3	
	NO_X	-	10.3	

- Int. 2. The maximum heat duty for SN-857, SN-860, and SN-861 combined shall not exceed a total heat capacity of 590,000 MMBtu during any consecutive 12-month period. This condition is temporary and expires after completion of the Boiler Replacement Project. [§19.705 of Regulation 19, A.C.A. §8-4-203 as referenced by §8-4-304 and §8-4-311, and 40 CFR §70.6]
- Int. 3. The permittee shall maintain monthly records of the total Btu throughput of the Tier II Heaters (SN-857, SN-860, and SN-861). These records shall be maintained on-site and shall be made available to Department personnel upon request. These records shall be submitted in accordance with General Provision #7. This condition is temporary and expires after completion of the Boiler Replacement Project. [§19.705 of Regulation 19 and 40 CFR Part 52 Subpart E]

SN-863 - Boiler Feedwater Pump

Source Description

One additional diesel-fired Boiler feed water pump rated at 475 hp-hr is permitted in association with the boiler replacement project.

Specific Conditions

149. The permittee shall not exceed the emission rates set forth in the following table. Compliance with these limits shall be demonstrated by compliance with the operating limits of this section. [§19.501 of Regulation 19 *et seq.*, and 40 C.F.R., Part 52, Subpart E]

SN #	Source Description	Pollutant	lb/day	tpy
863	Boiler feedwater pump	PM ₁₀	0.1	0.1
		SO_2	0.1	0.1
		VOC	0.5	0.2
		CO	1.8	0.5
		NO _x	22.8	5.7

Table 40 - Boiler Feedwater Pump Criteria Emissions

- 150. The permittee shall not operate the Boiler feedwater pump more than 500 hours per 12 consecutive months. [§19.705 of Regulation 19, A.C.A. §8-4-203 as referenced by §8-4-304 and §8-4-311, and 40 C.F.R. §70.6]
- 151. The facility shall not exceed 5% opacity from the sources in this section while burning pipeline quality natural gas or NSPS Subpart J quality gas. Compliance with this limit shall be demonstrated by burning pipeline natural gas or other gaseous fuel with an H₂S concentration less than 1,500 ppmvd. If the H₂S concentration exceeds 1500 ppmvd, then the facility shall comply with Specific Condition #152. [§18.501 and A.C.A. §8-4-203 as referenced by §8-4-304 and §8-4-311]
- 152. During those times in which the H₂S content of the refinery fuel gas combusted on-site exceeds 1500 ppmvd, the facility shall conduct an opacity observation for those sources which are permitted to combust NSPS Subpart J quality gas. These observations shall be conducted by someone who is familiar with the visible emissions from these sources. Any sources which generate visible emissions during these periods shall be considered to be in violation of the 5% opacity standard for that source. Records of these observations shall be maintained on-site, and shall be made available to the Department upon request These records shall indicate the date and time of the observation, the name of the person making the observation, whether or not any visible emissions are detected, and a list of any sources (by SN) for which visible emissions were noted. [§18.501 of Regulation 18 and A.C.A. §8-4-203 as referenced by §8-4-304 and §8-4-311]
- 153. The permittee shall maintain records of the number of hours of operation of SN-862. Records shall be maintained on a twelve month rolling basis, updated monthly. Such records shall be maintained on site and submitted in accordance with General Provision #7. A 12-month rolling

total shall be kept with these records. [\$19.705 of Regulation 19, and 40 C.F.R., Part 52, Subpart E]

Plantwide Applicability Limit (PAL) for Other Air Emissions

In order to demonstrate compliance with Regulation 18, § 18.801, the facility will operate under a Plantwide Applicability Limit (PAL) for other air emissions. The Department reviewed the emissions and determined that compliance with these emission limitations will constitute compliance with the terms of §18.801 of Regulation 18 for the sources identified in this permit. This PAL is meant to allow the facility flexibility in operation and production while at the same time limiting the total amount of air emissions from the facility.

Specific Conditions

154. The facility shall not exceed the emission rates set forth in the following table. Compliance with these limits shall be demonstrated by an annual emissions inventory and compliance with the feed rate, physical and operational limits in this Permit. [§18.801 of Regulation 18, and A.C.A. §8-4-203 as referenced by §8-4-304 and §8-4-311]

Description	Pollutant*	Allowable Emission Rate TPY
Plantwide Applicability Limit ¹	Benzene	67.9
	Biphenyl	9.5
	1,3 Butadiene	5.1
	Carbon Disulfide	4.4
	Carbonyl Sulfide	4.5
	Cresol (mixed isomers)	14.0
	Cumene	10.2
	Diethanolamine	4.4
	Ethyl benzene	43.6
	Hexane	314.5
	Naphthalene	6.6
	Phenol	9.8
	Toluene	148.7
	2,2,4 Trimethylpentane	56.2

Table 41 - Plantwide Applicability Limit (PAL) for Other Air Emissions

	Xylene (mixed isomers)	341.8
	Ammonia	62.1
	Chlorine	26.7
	Hydrogen Chloride	48.6
	Sulfuric Acid	88.3
	Hydrogen Sulfide	364.3
	Perchloroethylene (tetrachloroethylene)	7.1
	Formaldehyde	4.9
	Particulate matter	884.3

*Other air contaminants may be emitted from the facility in very small quantities, which would be difficult to measure and report. No significant levels of unlisted air contaminants are allowable under this permit.

¹The PAL does not include volatile organic compound (VOC) air emissions that are not hazardous air pollutants (HAP), as defined in 42 U.S.C. § 7412(b). The emissions of these non-HAP organic pollutants are captured and regulated by the VOC emission limits for the individual sources in this Permit.

155. The facility shall conduct an annual inventory of emissions of the pollutants listed in Specific Condition #154. The emissions inventory shall be calculated using methods relied upon in establishing the emission limits in Specific Condition #154. The facility may use different methodologies than those relied upon in establishing the limits; however, any change in a methodology shall be submitted to the Department and approved in advance of submission of the annual emission inventory. The emissions inventory shall be conducted each year, for the preceding calendar year (January 1-December 31), beginning in year 2003, and shall be submitted to the Department at the following address no later than August 1 of each year. If an annual emissions inventory is requested by the Department before August 1, the permittee shall have until August 1 to submit the requested information. This condition does not apply to emissions inventories requested by the Department pursuant to \$19.705(c) and 40 CFR \$51.321. [\$18.1004 of Regulation 18, and A.C.A. \$8-4-203 as referenced by \$8-4-304 and \$8-4-311]

Arkansas Department of Environmental Quality Air Division Attn: Compliance Inspector Supervisor Post Office Box 8913 Little Rock, AR 72219
Facility: Lion Oil Co. Permit No.: 868-AOP-R3 AFIN: 70-00016

156. If the annual emissions inventory demonstrates that the permittee has exceeded any PAL limit, it shall not be considered a violation of the permit provided that the exceedance is due to either a change in a published emission factor upon which permittee relied in setting the permitted limit, new emissions factors or the development of other emissions data (including site specific test data), which could affect the estimated emission rates. [§18.1004 of Regulation 18 and A.C.A. §8-4-203 as referenced by §8-4-304 and §8-4-311]

Section V: PLANT WIDE CONDITIONS

- 1. The permittee will notify the Administrator in writing within thirty (30) days after commencing construction, completing construction, first placing the equipment and/or facility in operation, and reaching the equipment and/or facility target production rate. [Regulation No. 19 §19.704, 40 CFR Part 52, Subpart E, and A.C.A. §8-4-203 as referenced by §8-4-304 and §8-4-311]
- 2. If the permittee fails to start construction within eighteen months or suspends construction for eighteen months or more, the Administrator may cancel all or part of this permit. [Regulation No.19 §19.410(B) and 40 CFR Part 52, Subpart E]
- 3. The permittee must test any equipment scheduled for testing, unless stated in the Specific Conditions of this permit or by any federally regulated requirements, within the following time frames: (1) New Equipment or newly modified equipment within sixty (60) days of achieving the maximum production rate, but no later than 180 days after initial start-up of the permitted source or (2) operating equipment according to the time frames set forth by the Department or within 180 days of permit issuance if no date is specified. The permittee must notify the Department of the scheduled date of compliance testing at least fifteen (15) days in advance of such test. The permittee will submit the compliance test results to the Department within thirty (30) days after completing the testing. [Regulation No.19 §19.702 and/or Regulation No. 18 §18.1002 and A.C.A. §8-4-203 as referenced by A.C.A. §8-4-304 and §8-4-311]
- 4. The permittee must provide: [Regulation No.19 §19.702 and/or Regulation No.18 §18.1002 and A.C.A. §8-4-203 as referenced by A.C.A. §8-4-304 and §8-4-311]
 - a. Sampling ports adequate for applicable test methods
 - b. Safe sampling platforms
 - c. Safe access to sampling platforms
 - d. Utilities for sampling and testing equipment.
- 5. The permittee must operate the equipment, control apparatus and emission monitoring equipment within the design limitations. The permittee will maintain the equipment in good condition at all times. [Regulation No.19 §19.303 and A.C.A. §8-4-203 as referenced by A.C.A. §8-4-304 and §8-4-311]
- 6. This permit subsumes and incorporates all previously issued air permits for this facility. [Regulation No. 26 and A.C.A. §8-4-203 as referenced by §8-4-304 and §8-4-311]
- 7. The Director prohibits the permittee to cause any emissions exceeding any allowances the source lawfully holds under Title IV of the Act or the regulations promulgated under the Act. No permit revision is required for increases in emissions allowed by allowances acquired pursuant to the acid rain program, if such increases do not require a permit revision under any other applicable requirement. This permit establishes no limit on the number of allowances held by the permittee. However, the source may not use allowances as a defense for noncompliance with any other applicable requirement of this permit or the Act. The permittee will account for any such

allowance according to the procedures established in regulations promulgated under Title IV of the Act. [Regulation No. 26 §26.701 and 40 CFR 70.6(a)(4)]

- 8. Pipeline quality natural gas is that which meets the tariff requirements of any major transmission company. [§19.705 of Regulation 19, A.C.A. §8-4-203 as referenced by §8-4-304 and §8-4-311, and 40 C.F.R. §70.6]
- 9. The facility is subject to 40 CFR Part 61 Subpart FF *National Emission Standards for Benzene Waste Operations* because it is a petroleum refinery (see Appendix E). [§19.304 of Regulation 19 and 40 CFR §61.340(a)]
 - a. The facility has identified itself as having total annual benzene emissions of less than 10 Mg/yr. The facility shall follow any applicable requirements of § 61.342(a).
 - b. The facility shall keep the records required by § 61.356(a) and (b).
 - c. The facility shall follow the reporting requirements of § 61.357(c).
- 10. The facility is subject to the provisions of 40 CFR Part 63 Subpart CC-*National Emission Standards for Hazardous Air Pollutants from Petroleum Refineries*, which are summarized below (for the full regulation, see Appendix I).
 - a. For the purpose of this subpart, the affected source shall comprise all emission points, in combination, listed in § 63.640(c)(1) through (c)(7) that are located at a single refinery plant site. *Note:* (c)(6) *does not apply*.
 - i. All miscellaneous process vents from petroleum refining process units meeting the criteria in § 63.640 (a);
 - ii. All storage vessels associated with petroleum refining process units meeting the criteria in § 63.640(a);
 - iii. All wastewater streams and treatment operations associated with petroleum refining process units meeting the criteria in § 63.640(a);
 - iv. All equipment leaks from petroleum refining process units meeting the criteria in § 63.640(a);
 - v. All gasoline loading racks classified under Standard Industrial Classification code 2911 meeting the criteria in § 63.640(a);
 - vi. All storage vessels and equipment leaks associated with a bulk gasoline terminal or pipeline breakout station classified under Standard Industrial Classification code 2911 located within a contiguous area and under common control with a refinery meeting the criteria in § 63.640(a).
 - b. Pursuant to 63.640(d), the affected source does not include the emission points listed in paragraphs (d)(1) through (d)(5).

- i. Stormwater from segregated stormwater sewers;
- ii. Spills;
- iii. Any pump, compressor, pressure relief device, sampling connection system, openended valve or line, valve or instrumentation system that is intended to operate in organic hazardous air pollutant service, as defined in § 63.641 of this subpart, for less than 300 hours during the calendar year.
- iv. Catalytic cracking unit and catalytic reformer catalyst regeneration vents, and sulfur plant vents.
- v. Emission points routed to a fuel gas system, as defined in § 63.641 of this subpart. No testing, monitoring record keeping, or reporting is required for refinery fuel gas systems or emission points routed to refinery fuel gas systems.
- c. The owner or operator shall keep a log of the storage vessels in § 63.640(e)(1) and (e)(2) that are subject to Subpart CC.
- d. The owner or operator shall keep a log of the miscellaneous process vents from distillation units in 63.640(f)(1) through (f)(5) that are subject to Subpart CC.
- e. The facility shall keep a log of the processes specified in paragraphs 63.646(g)(1) through (g)(7) that are exempt from Subpart CC.
- f. Sources subject to Subpart CC shall achieve compliance with the subpart by the dates specified in § 63.640(h).
- g. Sources that are added, reconstructed, have additions, or are otherwise modified shall achieve compliance in accordance with § 63.640(i), (j), and (k).
- h. If an additional petroleum refining process unit is added to a plant site or if a miscellaneous process vent, storage vessel, or gasoline loading rack that meets the criteria in § 63.640 (c)(1) through (c)(7) is added to an existing petroleum refinery or if another deliberate operational process change creating an additional Group 1 emission point(s) (as defined in § 63.641) is made to an existing petroleum refining process unit, and if the addition or process change is not subject to the new source requirements as determined according to § 63.640 (i) or (j), the requirements in § 63.640 (l)(1) through (l)(3) shall apply. The facility shall keep a log to show that it has complied with the provisions of this section.
- i. If a change that does not meet the criteria in § 63.640(1) is made to a petroleum refining process unit subject to this subpart, and the change causes a Group 2 emission point to become a Group 1 emission point (as defined in § 63.641), then the owner or operator shall comply with the requirements of this subpart for existing sources for the Group 1 emission point as expeditiously as practicable, but in no event later than 3 years after the emission point becomes Group 1. A compliance schedule for the change shall be submitted to the Administrator in accordance with § 63.640(m)(1) through (3).

Г

j. The following shall apply to the facility for the overlap of subpart CC with other regulations for storage vessels in 63.640(n)(1) through (7).

Existing	Source	Group	Comply with	Comments
Regulation				
40 C.F.R. 60,	Existing	Group 1	40 C.F.R. 60, Subpart	
Subpart Kb		Group 2	Kb	
40 C.F.R. 60,	New	Group 1	40 C.F.R. 63, Subpart	
Subpart Kb		_	CC	
40 C.F.R. 60,	New	Group 2	40 C.F.R. 60, Subpart	If source is subject to control
Subpart Kb (see			Kb	requirements in Subpart Kb,
comment)				comply with Kb instead of
				CC.
40 C.F.R. 60,	New	Group 2	40 C.F.R. 63, Subpart	If source is not required to
Subpart Kb (see		_	CC	apply controls by Subpart
comment)				Kb, comply with CC instead
				of Kb.
40 C.F.R. 60,	New and	Group 1	40 C.F.R. 63, Subpart	
Subpart K or Ka	Existing	_	CC	
40 C.F.R. 60,	New and	Group 2	40 C.F.R. 60, Subpart	If source is subject to control
Subpart K or Ka	Existing	_	K or Ka	requirements in Subparts K
				or Ka, comply with K or Ka
				instead of CC.
40 C.F.R. 60,	New and	Group 2	40 C.F.R. 63, Subpart	If source is not required to
Subpart K	Existing		CC	apply controls by Subparts K
or Ka				or Ka, comply with CC
				instead of K or Ka.

 Table 42 - Overlap with Existing Federal Regulations - Storage Vessels

k. The following shall apply to the facility for the overlap of subpart CC with other regulations for wastewater in § 63.640(o)(1) and (2).

Table 43 -	Overlap with	Existing	Federal	Regulations -	Wastewater
-------------------	---------------------	----------	---------	----------------------	------------

Existing	Source	Group	Comply with	Comments
Regulation		-		
40 C.F.R. 60,	New and	Group 1	40 C.F.R. 63,	
Subpart QQQ	Existing		Subpart CC	
40 C.F.R. 61,	New and	Group 1	40 C.F.R. 61,	
Subpart FF	Existing		Subpart FF	
40 C.F.R. 63,	New and	Group 1	40 C.F.R. 63,	Applies to equipment used in storage
Subpart G	Existing	Group 2	Subpart G,	and conveyance of wastewater
			§§ 63.133-63.137,	streams.
			63.140	

40 C.F.R. 61, Applies to treatment and control of
Subpart FF, and 40 wastewater streams.
C.F.R. 63, Subpart
G, §§ 63.138,
63.139
40 C.F.R. 63, Applies to monitoring and inspections
Subpart G, of equipment and recordkeeping and
§§ 63.143-63.148 reporting requirements.

- 1. After the compliance dates specified in § 63.640(h) equipment leaks that are also subject to the provisions of 40 C.F.R. 60 and 61 are required to comply only with the provisions of this subpart.
- m. The facility shall refer to Table 6 of Subpart CC in accordance with § 63.642(c) for in order to reference specific provisions of Subpart A of Part 63 that apply and those that do not apply.
- n. Pursuant to § 63.642(d), initial performance tests and initial compliance determinations shall be required only as specified in this subpart. A log showing compliance with §§ 63.642(d)(1) through (4) shall be kept.
- o. Pursuant to §63.642(e), each owner or operator of a source subject to this subpart shall keep copies of all applicable reports and records required by this subpart for at least 5 years except as otherwise specified in this subpart. All applicable records shall be maintained in such a manner that they can be readily accessed. Records for the most recent 2 years shall be retained onsite at the source or shall be accessible from a central location by computer. The remaining 3 years of records may be retained offsite. Records may be maintained in hard copy or computer- readable form including, but not limited to, on paper, microfilm, computer, floppy disk, magnetic tape, or microfiche.
- p. Pursuant to \$63.642(f), all reports required under this subpart shall be sent to the Administrator at the addresses listed in \$ 63.13 of subpart A of this part. If acceptable to both the Administrator and the owner or operator of a source, reports may be submitted on electronic media.
- q. Pursuant to §63.642(h), the owner or operator of a new source subject to the requirements of this subpart shall control emissions of organic HAP's to the level represented by the equation in paragraph (g) of this section.
- r. Pursuant to \$63.642(i), the owner or operator of an existing source shall demonstrate compliance with the emission standard in \$63.642(g) by following the procedures specified in \$63.642(k) for all emission points, or by following the emissions averaging compliance approach specified in \$63.642(l) for specified emission points and the procedures specified in \$63.642(k) for all other emission points within the source. The facility shall keep a log to demonstrate compliance with this provision.

- s. Pursuant to \$63.642(j), the owner or operator of a new source shall demonstrate compliance with the emission standard in \$63.642(h) only by following the procedures in \$63.642(k). The owner or operator of a new source may not use the emissions averaging compliance approach. The facility shall keep a log to demonstrate compliance with this provision.
- t. The owner or operator of a Group 1 miscellaneous process vent as defined in § 63.641 shall comply with the requirements of either § 63.643(a)(1) or (a)(2). A log shall be kept to demonstrate compliance with these provisions.
- u. The facility shall keep a log to demonstrate compliance with the provisions of § 63.644(a) for Group 1 miscellaneous process vent that uses a combustion device to comply with the requirements in § 63.643(a).
- v. The facility shall keep a log to demonstrate how it has complied with § 63.644(c) which requires the owner or operator of a Group 1 miscellaneous process vent using a vent system that contains bypass lines that could divert a vent stream away from the control device used to comply with § 63.644(a) to follow additional constraints outlined in § 63.644(c).
- w. Pursuant to § 63.644(d), the owner or operator shall establish a range that ensures compliance with the emissions standard for each parameter monitored under paragraphs (a) and (b) of this section. In order to establish the range, the information required in §63.654(f)(1)(3) shall be submitted in the Notification of Compliance Status report.
- x. Pursuant to § 63.644(e) Each owner or operator of a control device subject to the monitoring provisions of this section shall operate the control device in a manner consistent with the minimum and/or maximum operating parameter value or procedure required to be monitored under paragraphs (a) and (b) of this section. Operation of the control device in a manner that constitutes a period of excess emissions, as defined in §63.654(g)(6), or failure to perform procedures required by this section shall constitute a violation of the applicable emission standard of this subpart.
- y. The facility shall comply with the test measures and procedures for miscellaneous process vents in § 63.645.
- z. Pursuant to § 63.645(h), the owner or operator of a Group 2 process vent shall recalculate the TOC emission rate for each process vent, as necessary, whenever process changes are made to determine whether the vent is in Group 1 or Group 2. A log of these calculations and supporting assumptions shall be kept to demonstrate compliance with § 63.645.
- aa. The facility shall keep a log to demonstrate that the compliance determination for § 63.645(i) has been meet.
- bb. The facility shall comply with the storage vessel provisions of § 63.646. Notices of Compliance Status Report shall be submitted to the Administrator as required by this section.

- cc. Pursuant to§63.646(e), when complying with the inspection requirements of § 63.120 of subpart G of this part, owners and operators of storage vessels at existing sources subject to this subpart are not required to comply with the provisions for gaskets, slotted membranes, and sleeve seals.
- dd. Pursuant to 63.646(f), the paragraphs (f)(1), (f)(2), and (f)(3) of this section apply to Group 1 storage vessels at existing sources:
 - i. If a cover or lid is installed on an opening on a floating roof, the cover or lid shall remain closed except when the cover or lid must be open for access.
 - ii. Rim space vents are to be set to open only when the floating roof is not floating or when the pressure beneath the rim seal exceeds the manufacturer's recommended setting.
 - iii. Automatic bleeder vents are to be closed at all times when the roof is floating except when the roof is being floated off or is being landed on the roof leg supports.
- ee. Pursuant to\$63.646(g), failure to perform inspections and monitoring required by this section shall constitute a violation of the applicable standard of this subpart.
- ff. The provisions of 40 CFR 63.646(1) provide state permitting agencies with the authority to waive or modify the notification requirements of 40 CFR §§ 63.120(a)(5), 63.120(a)(6), 63.120(b)(10)(ii), and 63.120(b)(10)(iii). The notification requirements of these sections are hereby modified as follows: Lion Oil shall provide notice, as required herein, by facsimile transmittal five (5) business days prior to the scheduled event in lieu of providing 30 days prior written notice to the Department. This written notice may be submitted electronically to the local district air inspector and the ADEQ Air Division Enforcement Branch Technical Assistance Manager.
- gg. The provisions of 40 CFR §63.654(h)(2)(C)(ii) provide state permitting agencies with the authority to waive or modify the notification requirements of 40 CFR §63.120(b)(1) or §63.120(b)(2) of Subpart G of part 63. The notification requirements of these sections are hereby modified as follows: Lion Oil shall provide notice, as required herein, by facsimile transmittal five (5) business days prior to the scheduled event in lieu of providing 30 days prior written notice to the Department. This written notice may be submitted electronically to the local district air inspector and the ADEQ Air Division Enforcement Branch Technical Assistance Manager.
- hh. The facility shall comply with the wastewater provisions of §63.647 where applicable. The facility shall maintain a log to demonstrate that it has complied with the requirements of this section.
- The facility shall comply with the equipment leak standards of § 63.648. Portions of this section overlap with the requirements already listed for Subpart VV in the Fugitive Emissions (SN- 854) section of this permit. The facility may combine the requirements

of that section with this section and keep all necessary reports in one log. In any case, the facility shall keep a log to demonstrate compliance with this section.

- jj. Pursuant to § 63.648(h), each owner or operator of a source subject to the provisions of this subpart must maintain all records for a minimum of 5 years.
- kk. The facility shall comply with the gasoline loading rack provisions of § 63.650(a). The facility shall keep a log to demonstrate that all requirements of this section have been met.
- II. The facility shall keep in a log, methods used and affected equipment for any of the emissions averaging provisions that are used in § 63.652. The facility shall also follow the requirements for § 65.653. Records for monitoring, recordkeeping, and implementation plans shall also be kept in the same log.
- mm. The facility shall comply with the provisions of § 63.654(a) and keep a log of how it has complied with those provisions.
- nn. The facility shall comply with the provisions of § 63.654(b) and keep a log of how it has complied with those provisions.
- oo. The facility shall comply with the provisions of 63.654(d)(1) through (6) and keep a log of how it has complied with those provisions.
- pp. Pursuant to § 63.654(e), the facility shall submit the reports listed in paragraphs (e)(1) through (e)(3) except as provided in paragraph (h)(5) of this section, and shall keep records as described in paragraph (i) of this section.
 - i. A Notification of Compliance Status report as described in paragraph (f) of this section.
 - ii. Periodic Reports as described in paragraph (g) of this section.
 - iii. Other reports as described in paragraph (h) of this section.
- qq. The facility shall keep a log to show that it has complied with 63.654(f)(1) through (6).
- rr. The facility shall keep a log to show that it has complied with the requirements of \$ 63.654(g)(1) through (g)(8).
- ss. The facility shall keep a log demonstrating that it has complied with the submittal requirements of § 63.654(h).
- tt. The facility shall keep a log of the records required by § 63.654(i).
- uu. All other information required to be reported under paragraphs § 63.654(a) through (h) shall be retained for 5 years.

- vv. Compliance demonstrations begin on the first of the next calendar month following the beginning of the permit requirement. For those sources not subject to a rolling average requirement in the permits preceding AR-868-R0, rolling average requirements do not begin until twelve months after the issuance of this permit. Although on-going compliance with annual limits will be demonstrated with twelve-month rolling averages, violation of annual limits can only occur once per calendar year.
- 11. All sources specified as fuel gas combustion devices (See Specific Condition 1) under the provisions of 40 C.F.R. 60, Subpart J-*Standards of Performance for Petroleum Refineries* in the specific conditions of this permit are subject to the requirements outlined below (for the full regulation, see Appendix C): [§19.304 of Regulation 19 and 40 CFR §60.100]
 - a. The permittee shall not burn fuel gas that exceeds the concentration set forth in the following table. Compliance with this condition shall be demonstrated by compliance with Subpart J.

Sources	Pollutant	mg/dscm	gr/dscf	ppmvd
All refinery Fuel Gas	H_2S	230	0.10	162
Combustion Devices	SO_2	-	-	20

Table 44 – Fuel Gas Sulfur Limits

- b. The facility shall monitor emissions and operations by installing one of the following:
 - i. An SO₂ CEMs on the fuel gas combustion exhaust [60.105(a)(3)], or
 - ii. An H_2S CEMS on the fuel gas before being combusted. [§60.105(a)(4)]
- c. Excess emissions that shall be determined and reported are defined as follows: [60.105(e)]
 - i. All rolling 3-hour periods during which the average concentration of SO₂ as measured by the SO₂ continuous monitoring system under §60.105(a)(3) exceeds 20 ppm (dry basis, zero percent excess air); or
 - ii. All rolling 3-hour periods during which the average concentration of H_2S as measured by the H_2S continuous monitoring system under 60.105(a)(4) exceeds 230 mg/dscm (0.10 gr/dscf).
- d. The test methods shall be conducted according to 60.106(e)(1) for H₂S CEMs or 60.106(e)(2) and 60.106(f)(1) for SO₂ CEMs. [60.106]
- e. The reporting and recordkeeping requirements shall be kept as required in §60.107(d), (e), and (f). [§60.107]

- f. The combustion in a flare of a process upset gas or fuel gas that is released to the flares as a result of relief valve leakage or other emergency malfunctions is exempt from this paragraph. [§60.104(a)(1)]
- 12. The facility is subject to the provisions of 40 CFR Part 63, Subpart UUU National Emission Standards for Hazardous Air Pollutants for Petroleum Refineries: Catalytic Cracking Units, Catalytic Reforming Units, and Sulfur Recovery Units, which are summarized below (for the full regulation, see Appendix I). [§19.304 and 40 CFR §63.1561]
 - a. The permittee shall meet each applicable emission limitation in Table 1 of subpart UUU. If the catalytic cracking unit is subject to the NSPS for PM in §60.102 of, the permittee must meet the emission limitations for NSPS units. [§63.1564(a)(1)]
 - b. The permittee shall meet each applicable emission limitation in Table 8 of subpart UUU. If the catalytic cracking unit is subject to the NSPS for carbon monoxide (CO) in §60.103 of this chapter, the permittee must meet the emission limitations for NSPS units. [§63.1565(a)(1)]
 - c. The permittee shall meet each applicable operating limit in Table 2 and Table 9 of Subpart UUU. [§63.1564(a)(2), §63.1565(a)(2)]
 - d. The permittee shall prepare an operation, maintenance, and monitoring plan according to the requirements in §63.1574(f) and operate at all times according to the procedures of the plan. [§63.1564(a)(3), §63.1565(a)(3)]
 - e. As applicable, the permittee shall demonstrate initial compliance with the work practice standards by the methods referenced in §63.1564(b) and §63.1565(b). [§63.1564(b), §63.1565(b)]
 - f. As applicable, the permittee shall demonstrate continuous compliance with the work practice standards by the methods referenced in §63.1564(c) and §63.1565(c). [§63.1564(c), §63.1565(c)]
 - g. The permittee shall meet each applicable emission limitation in Table 15 and Table 22 of Subpart UUU. [§63.1566(a)(1), §63.1567(a)(1)]
 - h. The permittee shall meet each applicable operating limit in Table 16 and Table 23 of Subpart UUU. [§63.1566(a)(2), §63.1567(a)(2)]
 - i. The permittee shall prepare an operation, maintenance, and monitoring plan according to the requirements in §63.1574(f) and operate at all times according to the procedures of the plan. [§63.1566(a)(3), §63.1567(a)(3)]
 - j. As applicable, the permittee shall demonstrate initial compliance with the work practice standards by the methods referenced in §63.1566(b) and §63.1567(b). [§63.1566(b), §63.1567(b)]

- k. As applicable, the permittee shall demonstrate continuous compliance with the work practice standards by the methods referenced in §63.1566(c) and §63.1567(c).
 [§63.1566(c), §63.1567(c)]
- The permittee shall meet each applicable emission limitation in Table 29 of subpart UUU. If the sulfur recovery unit is subject to the NSPS for sulfur oxides in <u>\$60.104</u> of this chapter, the permittee must meet the emission limitations for NSPS units. [\$63.1568(a)(1)]
- m. The permittee shall meet each applicable operating limit in Table 30 of Subpart UUU. [§63.1568(a)(2)]
- n. The permittee shall prepare an operation, maintenance, and monitoring plan according to the requirements in §63.1574(f) and operate at all times according to the procedures of the plan. [§63.1568(a)(3), §63.1569(a)(3)]
- o. As applicable, the permittee shall demonstrate initial compliance with the work practice standards by the methods referenced in §63.1568(b). [§63.1568(b)]
- p. As applicable, the permittee shall demonstrate continuous compliance with the work practice standards by the methods referenced in §63.1568(c). [§63.1568(c)]
- q. For each bypass line, the permittee shall select and comply with one of the options given in §63.1569(a)(1) and meet applicable work practice standards given in Table 36 of Subpart UUU. [§63.1569(a)(1)]
- r. As applicable, the permittee shall demonstrate initial compliance with the work practice standards by the methods listed in §63.1569(b). [§63.1569(b)]
- s. As applicable, the permittee shall demonstrate continuous compliance with the work practice standards by the methods referenced in §63.1569(c). [§63.1569(c)]
- t. The permittee shall comply with all of the non-opacity standards in Subpart UUU during the times specified in §63.6(f)(1). [§63.1570(a)]
- u. The permittee shall comply with the opacity and visible emission limits of Subpart UUU during the times specified in §63.6(h)(1). [§63.1570(b)]
- v. The permittee shall always operate and maintain affected sources, including air pollution control and monitoring equipment, according to the provisions in §63.6(e)(1)(i). During the period between the compliance date specified and the date upon which continuous monitoring systems have been installed and validated and any applicable operating limits have been set, the permittee must maintain a log detailing the operation and maintenance of the process and emissions control equipment. [§63.1570(c)]
- w. The permittee must develop and implement a written startup, shutdown, and malfunction plan (SSMP) according to the provisions in §63.6(e)(3). [§63.1570(d)]

- x. During periods of startup, shutdown, and malfunction, the permittee shall operate in accordance with the SSMP. [§63.1570(e)]
- y. The permittee shall report each instance in which it did not meet each emission limitation and each operating limit in this subpart that applies to you. This includes periods of startup, shutdown, and malfunction. The permittee also must report each instance in which it did not meet the work practice standards in this subpart that apply. These instances are deviations from the emission limitations and work practice standards in this subpart. These deviations must be reported according to the requirements in §63.1575. [§63.1570(f)]
- z. Consistent with §§63.6(e) and 63.7(e)(1), deviations that occur during a period of startup, shutdown, or malfunction are not violations if the permittee demonstrates to the Administrator's satisfaction that it was operating in accordance with the SSMP. The SSMP must require that good air pollution control practices are used during those periods. The plan must also include elements designed to minimize the frequency of such periods (i.e., root cause analysis). The Administrator will determine whether deviations that occur during a period of startup, shutdown, or malfunction are violations, according to the provisions in §63.6(e) and the contents of the SSMP. [§63.1570(g)]
- aa. The permittee shall comply with the applicable portions of §63.1571 Performance Tests and Initial Compliance Demonstration. [§63.1571]
- bb. As applicable, the permittee shall install, operate, and maintain each continuous emission monitoring system according to the following: [§63.1572(a)]
 - i. The permittee must install, operate, and maintain each continuous emission monitoring system according to the requirements in Table 40 of Subpart UUU.
 - ii. If the permittee uses a continuous emission monitoring system to meet the NSPS CO or SO_2 limit, you must conduct a performance evaluation of each continuous emission monitoring system according to the requirements in §63.8 and Table 40 of Subpart UUU. This requirement does not apply to an affected source subject to the NSPS that has already demonstrated initial compliance with the applicable performance specification.
 - iii. As specified in §63.8(c)(4)(ii), each continuous emission monitoring system must complete a minimum of one cycle of operation (sampling, analyzing, and data recording) for each successive 15-minute period.
 - iv. Data must be reduced as specified in 63.8(g)(2).
- cc. As applicable, the permittee shall install, operate, and maintain each continuous parameter monitoring system according to the following: [§63.1572(c)]
- dd. The permittee shall install, operate, and maintain each continuous parameter monitoring system in a manner consistent with the manufacturer's specifications or other written procedures that provide adequate assurance that the equipment will monitor accurately.

The permittee shall also meet the equipment specifications in Table 41 of Subpart UUU if pH strips or colormetric tube sampling systems are used.

- ee. The continuous parameter monitoring system must complete a minimum of one cycle of operation for each successive 15-minute period. The permittee must have a minimum of four successive cycles of operation to have a valid hour of data (or at least two if a calibration check is performed during that hour or if the continuous parameter monitoring system is out-of-control).
- ff. Each continuous parameter monitoring system must have valid hourly average data from at least 75 percent of the hours during which the process operated.
- gg. Each continuous parameter monitoring system must determine and record the hourly average of all recorded readings and if applicable, the daily average of all recorded readings for each operating day. The daily average must cover a 24-hour period if operation is continuous or the number of hours of operation per day if operation is not continuous.
- hh. Each continuous parameter monitoring system must record the results of each inspection, calibration, and validation check.
- ii. The permittee shall monitor and collect data according to the following: [§63.1572(d)]
 - i. Except for monitoring malfunctions, associated repairs, and required quality assurance or control activities (including as applicable, calibration checks and required zero and span adjustments), the permittee must conduct all monitoring in continuous operation (or collect data at all required intervals) at all times the affected source is operating.
 - The permittee may not use data recorded during monitoring malfunctions, associated repairs, and required quality assurance or control activities for purposes of Subpart UUU, including data averages and calculations, for fulfilling a minimum data availability requirement, if applicable. The permittee must use all the data collected during all other periods in assessing the operation of the control device and associated control system.
- jj. The permittee shall identify any specifically applicable requirements related to the monitoring alternatives as necessary. [§63.1573]
- kk. The permittee shall comply with the applicable notification requirements, reporting requirements, and record keeping requirements. [§63.1574, §63.1575, §63.1576]
- II. The permittee shall identify applicable requirements pertaining to Subpart UUU as the information becomes available. The latest updates to applicable requirements shall be submitted to ADEQ along with future application materials. The information will be used to update this permit condition to more specifically list applicable requirements. [19.304 of Regulation]

13. This facility is subject to the federal regulations identified herein at the time of permit issuance. The source(s) affected by these regulations must comply with the most recent version as published in the Code of Federal Regulations. The source(s) must comply with all applicable federal regulations, whether or not accurately and specifically identified in this permit or its appendices. Regulations attached to this permit are for illustrative purposes only and are not deemed to be enforceable as attached unless the attached version is the most current and effective revision as cited and published in the CFR. Regardless of the form of the attached subparts, the source(s) are always subject to the most recent version of the subparts. In addition, subsequent changes to the subparts do not necessarily exempt the source from existing requirements contained in this air permit. [§19.304 of Regulation 19 and 40 CFR Part 52 Subpart E]

Title VI Provisions

- 14. The permittee must comply with the standards for labeling of products using ozone-depleting substances. [40 CFR Part 82, Subpart E]
 - a. All containers containing a class I or class II substance stored or transported, all products containing a class I substance, and all products directly manufactured with a class I substance must bear the required warning statement if it is being introduced to interstate commerce pursuant to §82.106.
 - b. The placement of the required warning statement must comply with the requirements pursuant to §82.108.
 - c. The form of the label bearing the required warning must comply with the requirements pursuant to \$82.110.
 - d. No person may modify, remove, or interfere with the required warning statement except as described in §82.112.
- 15. The permittee must comply with the standards for recycling and emissions reduction, except as provided for MVACs in Subpart B. [40 CFR Part 82, Subpart F]
 - a. Persons opening appliances for maintenance, service, repair, or disposal must comply with the required practices pursuant to \$82.156.
 - b. Equipment used during the maintenance, service, repair, or disposal of appliances must comply with the standards for recycling and recovery equipment pursuant to §82.158.
 - c. Persons performing maintenance, service repair, or disposal of appliances must be certified by an approved technician certification program pursuant to §82.161.
 - d. Persons disposing of small appliances, MVACs, and MVAC-like appliances must comply with record keeping requirements pursuant to §82.166. ("MVAC-like appliance" as defined at §82.152.)
 - e. Persons owning commercial or industrial process refrigeration equipment must comply with leak repair requirements pursuant to §82.156.

- f. Owners/operators of appliances normally containing 50 or more pounds of refrigerant must keep records of refrigerant purchased and added to such appliances pursuant to \$82.166.
- 16. If the permittee manufactures, transforms, destroys, imports, or exports a class I or class II substance, the permittee is subject to all requirements as specified in 40 CFR Part 82, Subpart A, Production and Consumption Controls.
- 17. If the permittee performs a service on motor (fleet) vehicles when this service involves ozone-depleting substance refrigerant (or regulated substitute substance) in the motor vehicle air conditioner (MVAC), the permittee is subject to all the applicable requirements as specified in 40 CFR part 82, Subpart B, Servicing of Motor Vehicle Air Conditioners.
 - a. The term "motor vehicle" as used in Subpart B does not include a vehicle in which final assembly of the vehicle has not been completed. The term "MVAC" as used in Subpart B does not include the air-tight sealed refrigeration system used as refrigerated cargo, or the system used on passenger buses using HCFC-22 refrigerant.
- 18. The permittee can switch from any ozone-depleting substance to any alternative listed in the Significant New Alternatives Program (SNAP) promulgated pursuant to 40 CFR Part 82, Subpart G, "Significant New Alternatives Policy Program".

Permit Shield

19. Compliance with the conditions of this permit shall be deemed compliance with all applicable requirements, as of the date of permit issuance, included in and specifically identified in Table 7
Applicable Regulations of this condition. The permit specifically identifies the following as applicable requirements based upon the information submitted by the permittee in an application dated June 10, 2005.

SN	Regulation	Description
Facility	Ark. Pollution Control and	Compilation of Regulation of
	Ecology Commission	the Arkansas State
	Regulation 19	Implementation Plan for Air
		Pollution Control
Facility	Ark. Pollution Control and	Regulations of the Arkansas
	Ecology Commission	Operating Air Permit Program
	Regulation 26	
SN-850, SN-862	40 CFR Part 60, Subpart Dc	Standards of Performance for
		Small Industrial-Commercial
		Steam Generating Units

 Table 45 - Permit Shield Applicable Regulations

SN	Regulation	Description
SN-803, SN-804, SN-805, SN- 806, SN-808, SN-809, SN-810, SN-811, SN-812, SN-813a, SN-814, SN-816-820, SN-821 (a,b,c), SN-822,SN-823, SN- 824,SN-825,SN-828, SN-830, SN-832, SN-842, ,SN-844, SN-850,SN-857,SN-860,SN- 861,SN-862	40 CFR Part 60, Subpart J	Standards of Performance for Petroleum Refineries
T-532, T-108, T-109, T-188	40 CFR Part 60 Subpart Ka	Standards of Performance for Storage Vessels for Petroleum Liquids for which Construction, Reconstruction, or Modification commenced after May18, 1978 and prior to July 23, 1984
T-7, T-88, T-103, T-24, T-113, T-272, T-273, T-274, T-382 through T-387, T-544, T-548, T-553, T-19,T-59,T-247,T-372	40 CFR Part 60, Subpart Kb	Standards of Performance for Volatile Organic Liquid Storage Vessels (Including Petroleum Storage Vessels) for which Construction, Reconstruction, or Modification commenced after July 23, 1984
T-382, T-383,T-24, T-41, T- 78, T-112, T-382 through T- 387	40 CFR Part 60, Subpart UU	Standards of Performance for Asphalt Processing and Asphalt Roofing Manufacture
Equipment Leaks*	40 CFR Part 60 Subpart VV	Standards of Performance for Equipment Leaks of VOC in the Synthetic Organic Chemicals Manufacturing Industry
#4 Crude Unit, #6 Hydrotreater/Isomerization Unit, #12 Distillate Hydrotreater, #17 Sulfur Recovery Plant*, and #19 PMA Plant	40 CFR Part 60, Subpart GGG	Standards of Performance for Equipment Leaks of VOC in Petroleum Refineries
Facility	40 CFR Part 61 Subpart FF	National Emission Standard for Benzene Waste Operations

SN	Regulation	Description
Facility*, T-36, T-61, T-62, T-	40 CFR Part 63, Subpart CC	National Emission Standard
64, T-65, T-66, T-67, T-85, T-		for Hazardous Air Pollutants
89, T-120, T-123, T-124, T-		from Petroleum Refineries
125,T-126, T-128, T-245, T-		
246, T-360, T-361, T-371, T-		
532, T-536		
SN-813a, SN-857, SN-860,	40 CFR Part 63, Subpart	National Emission Standard
SN-861, SN-862	DDDDD	for Hazardous Air Pollutants
		for Industrial, Commercial,
		and Institutional Boilers and
		Process Heaters
SN-824, SN-824A	40 CFR Part 63, Subpart	National Emission Standard
	LLLL	for Hazardous Air Pollutants:
		Asphalt Processing and
		Asphalt Roofing
*Equipment leak provisions a	oply only to those components	s that are subject to Subpart

GGG (incorporating the provisions of Subpart VV) and 40 C.F.R. 63, Subpart CC.

The permit specifically identifies the following as inapplicable based upon information submitted by the permittee in an application dated June 10, 2005.

Description of Regulation	Regulatory	Affected Source	Basis for Determination
	Citation		
Standards of Performance for	40 C.F.R.60	SN-816 to SN-820	Units were installed before
Small Industrial-Commercial-	Subpart Db		1984.
Institutional Steam Generating			
Units			
Standards of Performance for	40 C.F.R. 60	SN-828	Units were installed before
Small Industrial-Commercial-	Subpart Dc		1989.
Institutional Steam Generating			
Units			
Standards of Performance for	40 C.F.R. 60,	SN-809, SN-810,	Constructed prior to the
Petroleum Refineries	Subpart J	SN-816 to SN-820	effective dates of Subpart
			J.
Standards of Performance for	40 C.F.R. 60,	T-610, T-108, T-	Smaller than 40,000
Storage Vessels for Petroleum	Subpart Ka	109, T-142, T-	gallons.
Liquids for Which Construction,		143, and T-432	Exempt from controls
Reconstruction, or Modification			because these tanks store a
Commenced After May 18, 1978,			petroleum liquid with a
and Prior to July 23, 1984.			maximum true vapor
			pressure less than 10.3 kPa
			(1.5 psia).

Table 46 - Permit Shield Inapplicable Regulations

Description of Regulation	Regulatory	Affected Source	Basis for Determination
Standards of Darformanas for		Т 94 Т 112 Т	Exampt because they store
Standards of Performance for Volatila Organia Liquid Storage	40 C.F.K. 00, Subport Vh	$1-24, 1-113, 1-272 t_0 T 274 T$	e liquid with a maximum
Voiathe Organic Liquid Storage	Subpart Ko	272 10 1-274, 1-202 207 T 552	
Vessels (including Petroleum		502-507, 1-555,	the vapor pressure less
Liquid Storage Vessels) for		1-544, and 1-548,	than 5.2 kPa (.75 psia).
which Construction,		1-555	
Reconstruction, or Modification			
Commenced After July 23, 1984.			
		T-324	Exempt because capacity
			greater than or equal to 75
			m ³ , but less than 151 m ³
			storing a liquid with a
			maximum true vapor
			pressure less than 15.0 kPa
			(4.0 psia).
		T-538, T-539, T-	Smaller than 40 m ³ .
		540, T-549 to T-	
		552, T-600 to T-	
		609, T-611, and	
		T-612	
	40 C.F.R. 60,	All tanks not	Constructed prior to June
	Subpart K,	previously	11, 1973; Constructed
	Ka, and Kb	identified	prior to May 19, 1978;
			Constructed prior to July
			23, 1984 (as applicable); or
			do not exceed size
			requirements for the
			subparts.
Standards of Performance for	40 C.F.R. 60.	Blowing Stills	Constructed prior to
Asphalt Roofing Manufacture	Subpart UU	(associated with	November 18, 1980.
		SN-825)	
		,	

Description of Regulation	Regulatory	Affected Source	Basis for Determination
	Citation		
National Emission Standard for	40 C.F.R. 61,	Pumps,	There are no affected
Equipment Leaks (Fugitive	Subpart J	compressors,	facilities in benzene
Emission Sources) of Benzene		pressure relief	service (greater than 10%
		devices, sampling	benzene by weight).
		connections,	
		systems, open-	
		ended valves or	
		lines, valves,	
		flanges and other	
		connectors,	
		product	
		accumulator	
		vessels, and	
		control devices or	
		systems	
National Emission Standard for	40 C.F.R. 61,	Storage Vessels	None of the storage vessels
Benzene Emissions From	Subpart Y		contain benzene products.
Benzene Storage Vessels			
National Emission Standards for	40 C.F.R. 63,	Cooling Tower	Cooling towers have not
Hazardous Air Pollutants for	Subpart Q		operated with chromium-
Industrial Process Cooling			based water treatment
Towers			chemicals on or after
			September 8, 1994.

Consent Decree (CIV. No. 03-1028) Requirements

The following conditions are required to be added to this permit by Paragraph 24 of the Consent Decree (CIV. No. 03-1028) reached between Lion Oil, the US EPA, and ADEQ. In many instances, these conditions are restatements of requirements which appear elsewhere in the Specific and/or Plantwide Conditions of this permit.

- 20. The following heaters and boilers should be identified as affected facilities and subject to and required to comply with all applicable requirements of the New Source Performance Standards, Subparts A and J: #6 Hydrotreater/Reboiler (SN-806), #9 Stabilizer Reboiler (SN-812), #11 Deasphalting Furnace (SN-814), #16 Asphalt Blowing Furnaces (SN-825), Asphalt Rack Steam Heater (SN-828), Asphalt Hot Regenerate Furnace (SN-830), and the Asphalt Hot Oil Heater (SN-850). Provided however that if there is a future revision of NSPS Subpart J which excludes either certain fuel gas combustion devices or fuel gas streams from NSPS Subpart J, then that exemption, as applicable, shall apply to the foregoing heaters and boilers. [§19.304 of Regulation 19 and 40 CFR Part 60 Subparts A and J]
- 21. The permittee shall not burn fuel oil in any combustion unit except under the following circumstances. [§19.304 of Regulation 19 and 40 CFR §60.11(d)]

- a. The permittee shall be permitted to burn torch oil in the FCCU regenerator during FCCU start-ups;
- b. Lion Oil shall be permitted to burn Fuel Oil in combustion units after the establishment of FCCU NO_x emission limits pursuant to Paragraph 11.E. of this Consent Decree, provided that emissions from any such combustion units are routed through the FCCU Wet Gas Scrubber and Lion Oil demonstrates, with the approval of EPA, that the NO_x emission limits established therein and the SO₂ emissions limits set forth in Paragraph 12.B. of this Consent Decree will continue to be met.
- c. During periods of natural gas curtailment where the permittee shall burn only LPG or low sulfur distillate (e.g. No. 2 oil at less than 0.5% sulfur by wt.).
- 22. The Sulfur Recovery Plant (SN-844) is subject to and required to comply with all applicable provisions of 40 CFR Part 60 (NSPS) Subparts A and J. [§19.304 of Regulation 19 and 40 CFR Part 60 Subparts A and J]
- 23. The permittee shall route all sulfur pit emissions from the sulfur recovery plant (SN-844) such that sulfur pit emissions to the atmosphere are either eliminated or are included and monitored as part of the applicable sulfur recovery plant tail gas emissions that meet the NSPS Subpart J limit for SO₂: a 12-hour rolling average of 250 ppmvd SO₂ corrected to 0% oxygen. [§19.304 of Regulation 19 and 40 CFR §60.104(a)(2)]
- 24. The permittee shall comply with the Preventive Maintenance and Operation Plan for the Sulfur Recovery Plant, including any modifications thereto, at all times, including periods of start up, shut down, and malfunction. [§19.304 of Regulation 19 and 40 CFR §60.11(d)]
- 25. The High and Low Pressure Flares (SN-822 and SN-823) are subject to and shall comply with all applicable requirements of 40 CFR Part 60 Subparts A and J. The following conditions apply to facility compliance with the Subpart J. [§19.304 of Regulation 19 and 40 CFR Part 60 Subparts A and J]
 - a. For continuous or intermittent, routinely-generated refinery fuel gases that are combusted in the high or low pressure flare (SN-822 or SN-823), the permittee shall either take the flare that is associated with such a gas stream out of service, or comply with the emission limit of 40 CFR §60.104(a)(1).
 - b. The combustion of gases generated by the start-up, shut-down, or malfunction of a refinery process unit or released to a flaring device as a result of relief valve leakage or other emergency malfunction are exempt from the requirement to comply with 40 CFR §60.104(a)(1).
 - c. The permittee shall comply with the NSPS obligation to implement good air pollution control practices as required by 40 CFR §60.11(d) to minimize HC and AG flaring incidents (as defined below).
 - d. The permittee shall ensure that all continuous or intermittent, routinely-generated refinery fuel gases that are combusted in any flaring device are monitored by a CEM system as

required by 40 CFR §60.105(a)(4) or with a parametric monitoring system approved by EPA as an alternative monitoring system under 40 CFR §60.13(i). The permittee shall comply with the reporting requirements of 40 CFR Part 60 Subpart J for all such flaring devices.

- 26. These definitions shall apply to the following requirements.
 - a. **AG Flaring Incident** shall mean the continuous or intermittent combustion of Acid Gas and/or Sour Water Stripper Gas which results in the emission of sulfur dioxide equal to, or in excess of, 500 pounds in any 24-hour period in excess of the permitted limit; provided, however, that if 500 pounds or more of sulfur dioxide have been emitted in a 24-hour period and flaring continues into subsequent, contiguous, non-overlapping 24-hour periods, each period which results in emissions equal to, or in excess of 500 pounds of sulfur dioxide in excess of the permitted limit, then only one AG flaring incident shall have occurred. Subsequent, contiguous, non-overlapping periods are measured from the initial commencement of flaring within the AG flaring incident.
 - b. **Tail Gas Incident** shall mean the combustion of tail gas that either is: (i.) combusted in a flare and results in 500 pounds or more of SO₂ emissions in any 24-hour period, or (ii.) combusted in a thermal incinerator and results in excess emissions of 500 pounds or more of SO₂ emissions in any 24-hour period. Only those time periods which are in excess of an SO₂ concentration of 250 ppm (rolling 12-hour average) shall be used to determine the amount of excess SO₂ emissions from the incinerator. Lion Oil shall use engineering judgment and/or other monitoring data during periods in which the SO₂ CEM system has exceeded the range of the instrument or is out of service.
 - c. Hydrocarbon (HC) Flaring Incident shall mean continuous or intermittent hydrocarbon flaring, except for acid gas or sour water stripper gas, or tail gas, at a hydrocarbon flaring device that results in the emission of sulfur dioxide equal to or greater than 500 pounds in a 24-hour period; provided, however, that if 500 pounds or more of SO₂ have been emitted in a 24-hour period and flaring continues into subsequent, contiguous, non-overlapping 24-hour periods, each period of which results in emissions equal to or in excess of 500 pounds of SO₂, then only one HC flaring incident shall have occurred. Subsequent contiguous, non-overlapping periods are measured from the initial commencement of flaring within the HC flaring incident.
- 27. The permittee shall comply with the following requirements as they relate to AG flaring incidents, tail gas incidents, and HC flaring incidents. [§19.304 of Regulation 19 and 40 CFR §60.11(d)]
 - a. For tail gas incidents, the investigative and corrective action procedures shall be applied to TGU shutdowns, bypasses of a TGU, unscheduled shutdowns of a sulfur recovery plant, or other miscellaneous unscheduled sulfur recovery plant events which result in a tail gas incident.
 - b. The permittee shall investigate the root cause and all contributing causes of all AG flaring incidents, tail gas incidents, and HC flaring incidents. The permittee shall take

reasonable steps to correct the conditions that have caused or contributed to such incidents, and to minimize such incidents. The permittee shall evaluate whether AG flaring incidents, tail gas incidents, and HC flaring incidents are due to malfunctions.

- c. In response to any AG flaring incident, tail gas incident, or HC flaring incident, the permittee shall take, as expeditiously as practicable, such interim and/or long-term corrective actions, if any, as are consistent with good engineering practice to minimize the likelihood of a recurrence of the root cause and all contributing causes of the AG flaring incident, tail gas incident, or HC flaring incident.
- 28. The permittee is prohibited from using the emissions reductions that result from the installation and operation of the controls required by the Consent Decree (CIV. No. 03-1028) ("CD Emissions Reductions") for the purpose of emissions netting or emissions offsets, while still allowing the permittee to use a fraction of the CD emissions reductions if: (1) the emission unit for which the permittee seeks to use the CD emissions reductions are modified or constructed for the purposes of compliance with Tier II gasoline or low-sulfur diesel requirements; and (2) the emissions from those modified or newly-constructed units are below the levels outlined in paragraph 27.C.ii of the Consent Decree (CIV. No. 03-1028) prior to the commencement of operations of the emissions units for which the permittee seeks to use the CD emistice seeks to use the CD emissions reductions.
 - a. **General Prohibition** The permittee shall not generate or use any NO_x, SO₂, PM, VOC, or CO emissions reductions that result from any projects conducted or controls required pursuant to the Consent Decree (CIV. No. 03-1028) as netting reductions or emissions offsets in any PSD, major non-attainment, and/or minor New Source Review (NSR) permit or permit proceeding.

b. **Exception to General Prohibition**:

- Utilization of the exception set forth in paragraph 27.C.ii of the Consent Decree (CIV. No. 03-1028) to the general prohibition against the generation or utilization of CD emissions reductions set forth in paragraph 27.B of the Consent Decree (CIV. No. 03-1028) is subject to the following conditions:
 - 1. Under no circumstances shall the permittee use CD emissions reductions for netting and/or offsets prior to the time that actual CD emissions reductions have occurred.
 - 2. CD emissions reductions may only be used at the El Dorado refinery that generated them.
 - 3. The CD emissions reductions provisions of the Consent Decree (CIV. No. 03-1028)are for the purposes of the Consent Decree (CIV. No. 03-1028) only and neither the permittee nor any other entity may use CD emissions reductions for any purpose, including in any subsequent permitting or enforcement proceeding, except as provided herein.

- 4. The permittee shall remain subject to all federal and state regulations applicable to the PSD, major non-attainment, and/or minor NSR permitting processes.
- ii. Notwithstanding the general prohibition set forth in Paragraph 27.B of the Consent Decree (CIV. No. 03-1028), the permittee may use 10 tons per year of NO_x , 10 tpy of PM, and 35 tpy of SO_2 from the CD emissions reductions as credits or offsets in any PSD, major non-attainment, and/or minor NSR permit or permit proceeding occurring after the date of lodging of the Consent Decree (CIV. No. 03-1028) (March 11, 2003), provided that the new or modified emissions unit: (1) is being constructed of modified for the purposes of compliance with Tier II gasoline or low-sulfur diesel requirements; and (2) has a federally enforceable permit that reflects:
 - 1. For heaters and boilers, that next-generation ultra low-NO_x burners are installed and the limit is established pursuant to Paragraph 16.D of the Consent Decree (CIV. No. 03-1028).
 - 2. For heaters and boilers, a limit of 0.10 grains of hydrogen sulfide per dry standard cubic foot (dscf) of fuel gas or 20 ppmvd SO₂ corrected to 0% oxygen both on a 3-hour rolling average.
 - 3. For heaters and boilers, no liquid or solid fuel firing authorization.
 - 4. For the FCCU, a limit of 20 ppmvd NO_x or less corrected to 0% oxygen on a 365-day rolling average basis.
 - 5. For the FCCU, a limit of 25 ppmvd SO₂ corrected to 0% oxygen on a 365day rolling average basis.
 - 6. For SRP's, NSPS Subpart J emission limits.
- 29. None of the conditions of this permit are intended to prohibit the permittee from seeking to: (1) utilize or generate emissions credits or reductions from refinery units that are covered by the Consent Decree (CIV. No. 03-1028) to the extent that the proposed credits or reductions represent the difference between the emissions limitations set forth in the Consent Decree (CIV. No. 03-1028) for these refinery units and the more stringent emissions limitations that the permittee may elect to accept for those refinery units in a permitting process; or (2) utilize or generate or generate emission credits or reductions on refinery units that are not covered by the Consent Decree (CIV. No. 03-1028).
- 30. By no later than December 31, 2004, Lion Oil shall install a VDU overhead recovery system on the Vacuum Distillation Tower pursuant to the terms and conditions in its October 9, 2002 submission to the Agencies. Lion has complied with this requirement by routing emissions to the Flare Gas Recovery system.

Additional Requirements

- 31. The permittee must prepare and implement a Startup, Shutdown, and Malfunction Plan (SSM). If the Department requests a review of the SSM, the permittee will make the SSM available for review. The permittee must keep a copy of the SSM at the source's location and retain all previous versions of the SSM plan for five years. [Regulation No. 19 §19.304 and 40 CFR 63.6(e)(3)]
- By no later than June 30, 2003, Lion Oil shall, for the El Dorado SRP, submit to EPA and 32. ADEQ, a summary of a plan, implemented or to be implemented, for enhanced maintenance and operation of the El Dorado SRP, any supplemental control devices, and the appropriate Upstream Process Units. This plan shall be termed a Preventive Maintenance and Operation Plan ("PMO Plan"). The PMO Plan shall be a compilation of Lion Oil's approaches for exercising good air pollution control practices for minimizing SO₂ emissions at the El Dorado Refinery. The PMO Plan shall provide for continuous operation of the El Dorado SRP between scheduled maintenance turnarounds with minimization of emissions from the El Dorado SRP. The PMO Plan shall include, but not be limited to, sulfur shedding procedures, new startup and shutdown procedures, emergency procedures and schedules to coordinate maintenance turnarounds of the El Dorado SRP Claus trains and any supplemental control device to coincide with scheduled turnarounds of major Upstream Process Units. The PMO Plan shall have as a goal the elimination of Acid Gas Flaring. Lion Oil shall comply with the PMO Plan at all times, including periods of start up, shut down, and Malfunction of the El Dorado SRP through and after termination of the Consent Decree (CIV. No. 03-1028). Modifications related to minimizing Acid Gas Flaring and/or SO₂ emissions made by Lion Oil to the PMO Plan shall be summarized in an annual submission to EPA and the ADEQ until termination of the Consent Decree (CIV. No. 03-1028). [Paragraph 18(D)(i) of the Consent Decree (CIV. No. 03-1028) between Lion Oil, ADEO, and the US EPA]

Section VI: INSIGNIFICANT ACTIVITIES

The following sources are insignificant activities. Any activity that has a state or federal applicable requirement is a significant activity even if this activity meets the criteria of §304 of Regulation 26 or listed in the table below. Insignificant activity determinations rely upon the information submitted by the permittee in an application dated February 21, 2003.

	Category
Fire suppression systems, emissions from fire or emergency response equipment and training, including but not limited to, use of fire control equipment and pumps powered by internal combustion engines, equipment testing, and training.	A-13
Repair of electrical generators.	A-13
Equipment used for surface coating, painting, dipping, or spraying operations that do not emit any VOC or HAP.	A-9
Up to 93 storage tanks each of which is less than or equal to 250 gallons and stores a liquid having a true vapor pressure less than or equal to 3.5 psia (24.2 kPa).	A-2
Up to 34 fuel additive and treatment chemical storage tanks each of which is less than or equal to 10,000 gallons and stores a liquid having a true vapor pressure less than or equal to 0.5 psia (3.5 kPa).	A-3
Caustic storage tanks that contain no VOCs.	A-4
Natural gas or distillate oil fired fuel burning equipment used to regenerate the facility's amine and having a design firing rate less than 10 million Btu per hour.	A-1

Table 47- Insignificant Activities

	Category
Operation of the OCC Emergency Use Generator (with a maximum capacity of 100 kW fired with diesel fuel) and other Emergency use portable pumps, generators, compressors and boilers not otherwise specifically listed by name or application in this permit or insignificant activities list, provided that the units are less than 10,000,000 Btu/hr and used for back-up power generation during times when the primary source of power is unavailable to the facility.	A-1
Operation of Emergency Use fuel-fired compressors in lieu of the East Instrument Air Compressor, West Instrument Air Compressor, East Utility Air Compressor, West Utility Air Compressor, North ESVG Compressor, South ESVG Compressor and the CCR Air Compressor, provided that the operation of the fuel-fired equipment does not operate in conjunction with the facility's primary compressors.	A-12
Operation of Emergency Use portable pumps, generators, compressors and boilers not otherwise specifically listed by name or application in this permit or insignificant activities list that are used for emergency purposes provided that the units areless than 10,000,000 Btu/hr.	A-1
Asphalt Protective Coatings Baghouse (former SN- 807)	A-13
Acid Fume Scrubbers (former SN-826 and SN-827)	A-13
Lime Silo Baghouse (former SN-845)	A-13

Pursuant to §26.304 of Regulation 26, the Department determined the emission units, operations, or activities contained in Regulation 19, Appendix A, Group B, to be insignificant activities. Activities included in this list are allowable under this permit and need not be specifically identified.

Section VII: GENERAL PROVISIONS

- 1. Any terms or conditions included in this permit which specify and reference Arkansas Pollution Control & Ecology Commission Regulation No. 18 or the Arkansas Water and Air Pollution Control Act (A.C.A. §8-4-101 *et seq.*) as the sole origin of and authority for the terms or conditions are not required under the Clean Air Act or any of its applicable requirements, and are not federally enforceable under the Clean Air Act. Arkansas Pollution Control & Ecology Commission Regulation 18 was adopted pursuant to the Arkansas Water and Air Pollution Control Act (A.C.A. §8-4-101 *et seq.*). Any terms or conditions included in this permit which specify and reference Arkansas Pollution Control & Ecology Commission Regulation 18 or the Arkansas Water and Air Pollution Control Act (A.C.A. §8-4-101 *et seq.*) as the origin of and authority for the terms or conditions are enforceable under this Arkansas statute.[40 CFR 70.6(b)(2)]
- 2. This permit shall be valid for a period of five (5) years beginning on the date this permit becomes effective and ending five (5) years later. [40 CFR 70.6(a)(2) and §26.701(B) of the Regulations of the Arkansas Operating Air Permit Program (Regulation 26), effective August 10, 2000]
- 3. The permittee must submit a complete application for permit renewal at least six (6) months before permit expiration. Permit expiration terminates the permittee's right to operate unless the permittee submitted a complete renewal application at least six (6) months before permit expiration. If the permittee submits a complete application, the existing permit will remain in effect until the Department takes final action on the renewal application. The Department will not necessarily notify the permittee when the permit renewal application is due. [Regulation No. 26 §26.406]
- 4. Where an applicable requirement of the Clean Air Act, as amended, 42 U.S.C. 7401, *et seq.* (Act) is more stringent than an applicable requirement of regulations promulgated under Title IV of the Act, the permit incorporates both provisions into the permit, and the Director or the Administrator can enforce both provisions. [40 CFR 70.6(a)(1)(ii) and Regulation No. 26 §26.701(A)(2)]
- 5. The permittee must maintain the following records of monitoring information as required by this permit. [40 CFR 70.6(a)(3)(ii)(A) and Regulation No. 26 §26.701(C)(2)]
 - a. The date, place as defined in this permit, and time of sampling or measurements;
 - b. The date(s) analyses performed;
 - c. The company or entity performing the analyses;
 - d. The analytical techniques or methods used;
 - e. The results of such analyses; and
 - f. The operating conditions existing at the time of sampling or measurement.

- 6. The permittee must retain the records of all required monitoring data and support information for at least 5 years from the date of the monitoring sample, measurement, report, or application. Support information includes all calibration and maintenance records and all original strip-chart recordings for continuous monitoring instrumentation, and copies of all reports required by this permit. [40 CFR 70.6(a)(3)(ii)(B) and Regulation No. 26 §26.701(C)(2)(b)]
- 7. The permittee must submit reports of all required monitoring every 6 months. If permit establishes no other reporting period, the reporting period shall end on the last day of the anniversary month of the initial Title V permit. The report is due within 30 days of the end of the reporting period. Although the reports are due every six months, each report shall contain a full year of data. The report must clearly identify all instances of deviations from permit requirements. A responsible official as defined in Regulation No. 26 §26.2 must certify all required reports. The permittee will send the reports to the address below: [40 C.F.R. 70.6(a)(3)(iii)(A) and §26.701(C)(3)(a) of Regulation #26]

Arkansas Department of Environmental Quality Air Division ATTN: Compliance Inspector Supervisor Post Office Box 8913 Little Rock, AR 72219

- 8. The permittee shall report to the Department all deviations from permit requirements, including those attributable to upset conditions as defined in the permit.
 - a. For all upset conditions (as defined in Regulation19, §19.601), the permittee will make an initial report to the Department by the next business day after the discovery of the occurrence. The initial report my be made by telephone and shall include:
 - i. The facility name and location
 - ii. The process unit or emission source deviating from the permit limit,
 - iii. The permit limit, including the identification of pollutants, from which deviation occurs,
 - iv. The date and time the deviation started,
 - v. The duration of the deviation,
 - vi. The average emissions during the deviation,
 - vii. The probable cause of such deviations,
 - viii. Any corrective actions or preventive measures taken or being taken to prevent such deviations in the future, and
 - ix. The name of the person submitting the report.

The permittee shall make a full report in writing to the Department within five (5) business days of discovery of the occurrence. The report must include, in addition to the information required by the initial report, a schedule of actions taken or planned to eliminate future occurrences and/or to minimize the amount the permit's limits were exceeded and to reduce the length of time the limits were exceeded. The permittee may submit a full report in writing (by facsimile, overnight courier, or other means) by the next business day after discovery of the occurrence, and the report will serve as both the initial report and full report.

- b. For all deviations, the permittee shall report such events in semi-annual reporting and annual certifications required in this permit. This includes all upset conditions reported in 8a above. The semi-annual report must include all the information as required by the initial and full reports required in 8a. [Regulation 19, §19.601 and §19.602, Regulation 26, §26.701(C)(3)(b), and 40 CFR 70.6(a)(3)(iii)(B)]
- 9. If any provision of the permit or the application thereof to any person or circumstance is held invalid, such invalidity will not affect other provisions or applications hereof which can be given effect without the invalid provision or application, and to this end, provisions of this Regulation are declared to be separable and severable. [40 CFR 70.6(a)(5), §26.701(E) of Regulation No. 26, and A.C.A. §8-4-203, as referenced by §8-4-304 and §8-4-311]
- 10. The permittee must comply with all conditions of this Part 70 permit. Any permit noncompliance with applicable requirements as defined in Regulation No. 26 constitutes a violation of the Clean Air Act, as amended, 42 U.S.C. §7401, *et seq.* and is grounds for enforcement action; for permit termination, revocation and reissuance, for permit modification; or for denial of a permit renewal application. [40 CFR 70.6(a)(6)(i) and Regulation No. 26 §26.701(F)(1)]
- 11. It shall not be a defense for a permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity to maintain compliance with the conditions of this permit. [40 CFR 70.6(a)(6)(ii) and Regulation No. 26 §26.701(F)(2)]
- 12. The Department may modify, revoke, reopen and reissue the permit or terminate the permit for cause. The filing of a request by the permittee for a permit modification, revocation and reissuance, termination, or of a notification of planned changes or anticipated noncompliance does not stay any permit condition. [40 CFR 70.6(a)(6)(iii) and Regulation No. 26 §26.701(F)(3)]
- 13. This permit does not convey any property rights of any sort, or any exclusive privilege. [40 CFR 70.6(a)(6)(iv) and Regulation No. 26 §26.701(F)(4)]
- 14. The permittee must furnish to the Director, within the time specified by the Director, any information that the Director may request in writing to determine whether cause exists for modifying, revoking and reissuing, or terminating the permit or to determine compliance with the permit. Upon request, the permittee must also furnish to the Director copies of records required by the permit. For information the permittee claims confidentiality, the Department may require the permittee to furnish such records directly to the Director along with a claim of confidentiality. [40 CFR 70.6(a)(6)(v) and Regulation No. 26 §26.701(F)(5)]

- 15. The permittee must pay all permit fees in accordance with the procedures established in Regulation No. 9. [40 CFR 70.6(a)(7) and Regulation No. 26 §26.701(G)]
- 16. No permit revision shall be required, under any approved economic incentives, marketable permits, emissions trading and other similar programs or processes for changes provided for elsewhere in this permit. [40 CFR 70.6(a)(8) and Regulation No. 26 §26.701(H)]
- 17. If the permit allows different operating scenarios, the permittee will, contemporaneously with making a change from one operating scenario to another, record in a log at the permitted facility a record of the operational scenario. [40 CFR 70.6(a)(9)(i) and Regulation No. 26 §26.701(I)(1)]
- 18. The Administrator and citizens may enforce under the Act all terms and conditions in this permit, including any provisions designed to limit a source's potential to emit, unless the Department specifically designates terms and conditions of the permit as being federally unenforceable under the Act or under any of its applicable requirements. [40 CFR 70.6(b) and Regulation No. 26 §26.702(A) and (B)]
- 19. Any document (including reports) required by this permit must contain a certification by a responsible official as defined in Regulation No. 26 §26.2. [40 CFR 70.6(c)(1) and Regulation No. 26 §26.703(A)]
- 20. The permittee must allow an authorized representative of the Department, upon presentation of credentials, to perform the following: [40 CFR 70.6(c)(2) and Regulation No. 26 §26.703(B)]
 - a. Enter upon the permittee's premises where the permitted source is located or emissions-related activity is conducted, or where records must be kept under the conditions of this permit;
 - b. Have access to and copy, at reasonable times, any records required under the conditions of this permit;
 - c. Inspect at reasonable times any facilities, equipment (including monitoring and air pollution control equipment), practices, or operations regulated or required under this permit; and
 - d. As authorized by the Act, sample or monitor at reasonable times substances or parameters for assuring compliance with this permit or applicable requirements.
- 21. The permittee will submit a compliance certification with the terms and conditions contained in the permit, including emission limitations, standards, or work practices. The permittee must submit the compliance certification annually within 30 days following the last day of the anniversary month of the initial Title V permit. The permittee must also submit the compliance certification as well as to the Department. All compliance certifications required by this permit must include the following: [40 CFR 70.6(c)(5) and Regulation No. 26 §26.703(E)(3)]
 - a. The identification of each term or condition of the permit that is the basis of the certification;

- b. The compliance status;
- c. Whether compliance was continuous or intermittent;
- d. The method(s) used for determining the compliance status of the source, currently and over the reporting period established by the monitoring requirements of this permit; and
- e. Such other facts as the Department may require elsewhere in this permit or by \$114(a)(3) and \$504(b) of the Act.
- 22. Nothing in this permit will alter or affect the following: [Regulation No. 26 §26.704(C)]
 - a. The provisions of Section 303 of the Act (emergency orders), including the authority of the Administrator under that section;
 - b. The liability of the permittee for any violation of applicable requirements prior to or at the time of permit issuance;
 - c. The applicable requirements of the acid rain program, consistent with \$408(a) of the Act or,
 - d. The ability of EPA to obtain information from a source pursuant to §114 of the Act.
- 23. This permit authorizes only those pollutant-emitting activities addressed in this permit. [A.C.A. \$8-4-203 as referenced by \$8-4-304 and \$8-4-311]

Facility: Lion Oil Co. Permit No.: 868-AOP-R3 AFIN: 70-00016

Appendix A Subpart Ka – Standards of Performance for Storage Vessels for Petroleum Liquids for Which Construction, Reconstruction, or Modification Commenced After May 18, 1978 and Prior to July 23, 1984

Facility: Lion Oil Co. Permit No.: 868-AOP-R3 AFIN: 70-00016

Appendix BSubpart Kb – Standards of Performance for Volatile Organic Liquid Storage
Vessels (Including Petroleum Liquid Storage Vessels) for Which Construction,
Reconstruction, or Modification Commenced After July 23, 1984

Appendix C Subpart J – Standards of Performance for Petroleum Refineries

Facility: Lion Oil Co. Permit No.: 868-AOP-R3 AFIN: 70-00016

Appendix D Subpart Dc – Standards of Performance for Small Industrial-Commercial-Institutional Steam Generating Units
Appendix E Subpart FF – National Emission Standards for Benzene Operations

Appendix F Subpart GGG – Standards of Performance for Equipment Leaks of VOC in Petroleum Refineries

Appendix G Subpart VV - Standards of Performance for Equipment Leaks of VOC in the Synthetic Organic Chemicals Manufacturing Industry

Appendix H Subpart UUU – Standards of Performance for Asphalt Processing and Asphalt Roofing Manufacture

Appendix I Subpart CC - National Emission Standards for Hazardous Air Pollutants From Petroleum Refineries

Appendix J Subpart QQQ - Standards of Performance for VOC Emissions From Petroleum Refinery Wastewater Systems

Appendix K Arkansas Department of Environmental Quality Continuous Emission Monitoring Systems Conditions

Appendix L Source Number Comparison

Appendix M Subpart UUU - National Emission Standards for Hazardous Air Pollutants From Petroleum Refineries: Catalytic Cracking Units, Catalytic Reforming Units, and Sulfur Recovery Units

Appendix N Subpart DDDDD - National Emission Standards for Hazardous Air Pollutants for Industrial, Commercial, and Institutional Boilers and Process Heaters

Appendix O Subpart Db – Standards of Performance for Industrial-Commercial-Institutional Steam Generating Units