



**DIVISION OF ENVIRONMENTAL QUALITY**

**DRAFT OPERATING AIR PERMIT**

**PERMIT NUMBER:** 0492-AOP-R15

**IS ISSUED TO:**

Covia ISP, Inc. - Fort Smith Plant  
5300 Gerber Road  
Fort Smith, AR 72904-1699  
Sebastian County  
**AFIN:** 66-00219

PURSUANT TO THE RULES OF THE ARKANSAS OPERATING AIR PERMIT PROGRAM, RULE 26: THIS PERMIT AUTHORIZES THE ABOVE REFERENCED PERMITTEE TO INSTALL, OPERATE, AND MAINTAIN THE EQUIPMENT AND EMISSION UNITS DESCRIBED IN THE PERMIT APPLICATION AND ON THE FOLLOWING PAGES. THIS PERMIT IS VALID BETWEEN:

AND

THE PERMITTEE IS SUBJECT TO ALL LIMITS AND CONDITIONS CONTAINED HEREIN.

**Signed:**

---

Demetria Kimbrough  
Associate Director, Office of Air Quality  
Division of Environmental Quality

---

Date

Covia ISP, Inc. - Fort Smith Plant  
Permit #: 0492-AOP-R15  
AFIN: 66-00219

Table of Contents

<b>SECTION I: FACILITY INFORMATION .....</b>	<b>4</b>
<b>SECTION II: INTRODUCTION .....</b>	<b>5</b>
<b>Summary of Permit Activity .....</b>	<b>5</b>
<b>Process Description .....</b>	<b>5</b>
<b>Rules and Regulations .....</b>	<b>6</b>
<b>Emission Summary .....</b>	<b>7</b>
<b>SECTION III: PERMIT HISTORY .....</b>	<b>12</b>
<b>SECTION IV: SPECIFIC CONDITIONS .....</b>	<b>17</b>
<b>SECTION V: COMPLIANCE PLAN AND SCHEDULE .....</b>	<b>36</b>
<b>SECTION VI: PLANTWIDE CONDITIONS .....</b>	<b>37</b>
<b>SECTION VII: INSIGNIFICANT ACTIVITIES .....</b>	<b>40</b>
<b>SECTION VIII: GENERAL PROVISIONS .....</b>	<b>41</b>
Appendix A – 40 C.F.R. § 63, Subpart ZZZZ	

Covia ISP, Inc. - Fort Smith Plant  
Permit #: 0492-AOP-R15  
AFIN: 66-00219

#### List of Acronyms and Abbreviations

Ark. Code Ann.	Arkansas Code Annotated
AFIN	Arkansas DEQ Facility Identification Number
C.F.R.	Code of Federal Regulations
CO	Carbon Monoxide
COMS	Continuous Opacity Monitoring System
HAP	Hazardous Air Pollutant
Hp	Horsepower
lb/hr	Pound Per Hour
NESHAP	National Emission Standards (for) Hazardous Air Pollutants
MVAC	Motor Vehicle Air Conditioner
No.	Number
NO <sub>x</sub>	Nitrogen Oxide
NSPS	New Source Performance Standards
PM	Particulate Matter
PM <sub>10</sub>	Particulate Matter Equal To Or Smaller Than Ten Microns
PM <sub>2.5</sub>	Particulate Matter Equal To Or Smaller Than 2.5 Microns
SNAP	Significant New Alternatives Program (SNAP)
SO <sub>2</sub>	Sulfur Dioxide
SSM	Startup, Shutdown, and Malfunction Plan
Tpy	Tons Per Year
UTM	Universal Transverse Mercator
VOC	Volatile Organic Compound

Covia ISP, Inc. - Fort Smith Plant  
Permit #: 0492-AOP-R15  
AFIN: 66-00219

## **SECTION I: FACILITY INFORMATION**

PERMITTEE: Covia ISP, Inc. - Fort Smith Plant

AFIN: 66-00219

PERMIT NUMBER: 0492-AOP-R15

FACILITY ADDRESS: 5300 Gerber Road  
Fort Smith, AR 72904-1699

MAILING ADDRESS: 3 Summit Park Drive Suite 700  
Independence, OH 44131

COUNTY: Sebastian County

CONTACT NAME: William Blackmore

CONTACT POSITION: Plant Manager

TELEPHONE NUMBER: (479) 629-5262

REVIEWING ENGINEER: Skylar Redman

UTM North South (Y): Zone 15: 3921643.83 m

UTM East West (X): Zone 15: 374920.79 m

## **SECTION II: INTRODUCTION**

### **Summary of Permit Activity**

With this renewal, Covia ISP, Inc. Fort Smith Plant requests the following: update capacity of SN-73 A, B, C to match generator sizes on tags; remove the following sources and insignificant activities from the permit: SN-05, SN-C12, SN-C26, SN-C27, SN-C28, two (2) 0.6 MMBtu/hr hot water heaters, four (4) 0.38 MMBtu/hr hot water heaters for binder process, one 550-gal diesel storage tank, and Aerosol can puncture operation; add three (3) insignificant activities: 1500-gallon diesel tank for mobile equipment (A3), welding booth (A13), heat exchanger at Plant 2 (A13); and add a permit shield to the permit. Emission changes are as follows: a decrease in 17.1 tpy of PM, 8.5 tpy of PM<sub>10</sub>, 0.1 tpy of SO<sub>2</sub>, 0.2 tpy of VOC, 3.0 tpy of CO, 3.7 tpy of NO<sub>x</sub>, 0.02 tpy of single HAPs, and 0.06 tpy of total HAPs.

### **Process Description**

#### ***Silica Sand Receiving, Silica Manufacturing and Product Shipping Processes***

The Covia Fort Smith facility will have distinct processes to receive silica sand as well as for Manufacturing, packaging and shipping of various silica products.

Washed and dried silica sand will be delivered to the facility via bulk bags, trucks and rail cars. The sand will be unloaded and transferred into bins designed to store this mineral for eventual manufacturing. Concentrated inorganic fluxing agent will also be received via bulk shipments and stored in dedicated vessels at the facility.

For initial manufacturing, the sand will be fed into one of two natural gas fired rotary kilns after being wetted by the fluxing agent. The Plant 1, Kiln No. 1 kiln has a 7.7 mmBtu/hr. rated burner while the Plant 1, Kiln No. 2 kiln has a 30 mmBtu/hr. rated burner. The Plant 1, Kiln No. 2 process and control device is referenced as SN-C01. The SN-C18 Plant 2 Kiln has a 68 mmBtu/hr. rated burner and is controlled by cyclones and a wet scrubber (SN-C18A) and flows to a cooler and scrubber (SN-18B)

The fluxing agent is designed to enhance the reflective quality of this mineral. The sand will travel through the kilns at a rate and temperature which will allow the fluxing agent to have the desired result. Sand exiting the kiln will be routed through a rotary cooler to lower product temperatures to acceptable levels prior to the sand being stored in other bins.

The second stage of manufacturing includes feeding the sand through mineral screens used to separate the sand into different sized fractions. The sorted sand will then be transferred and stored in bins designated to hold unique size fractions of that mineral. At this point, silica is a saleable product to some customers. That saleable whole grain silica product will move through transfer, storage and packaging or loading systems designed to efficiently fill bulk bags, bulk trucks or bulk rail cars.

Covia ISP, Inc. - Fort Smith Plant  
Permit #: 0492-AOP-R15  
AFIN: 66-00219

A third stage of manufacturing will include sending whole grain sand through milling and classification systems to reduce the sand sized silica into finely divided powder. The size reduction is needed to serve the needs of other customers. Finely divided silica products will move through transfer, storage and packaging or loading systems designed to efficiently fill bulk bags, bulk trucks or bulk rail cars.

Two Transload conveyors will be used at this facility for two situations. First, a transloader would typically be sparingly used to unload a truck or rail car that either arrived with the wrong product or a truck or rail car that was loaded at the plant with the wrong product. Second, the transloader may also be used for truck or rail car unloading and loading if the normal loading/unloading systems are down. It is contemplated that this alternative transloader operational scenario would be needed for a minor percentage of the total yearly rail loading/unloading throughput. Note that the site may have other transloaders stationed at the site but held as back-up or for spare parts. Only two transloaders will be in operation at any time.

Note that most mineral transfers will be done pneumatically, via covered conveyors, through sealed bucket elevators or gravity fed enclosed chute systems. Input, intermediate and final mineral products will be stored in a variety of covered bins. Covia has a commitment to have mineral handling, process and storage equipment subject to this and previous minor modifications under some sort of PM/PM<sub>10</sub> control (i.e. sealed transfer, choke feed transfer, wetted product, bin vents, dust collection or wet scrubbers). This is being done for both environmental and worker comfort considerations.

Most facility receiving, manufacturing and shipping will take place in and around Plant 2. Plant 1 is primarily used for product storage, with some shipping activity and periodic use of milling. Ancillary support operations and areas at Fort Smith are typical for those commonly found in the mineral processing industry. These operations and areas include (but are not limited to) back-up power generation, petroleum/chemical storage and use, maintenance shops, quality control labs, warehousing, shipping, receiving, traffic management, housekeeping, landscaping, worker welfare and administrative areas.

### **Rules and Regulations**

The following table contains the rules and regulations applicable to this permit.

Rules and Regulations
Arkansas Air Pollution Control Code, Rule 18, effective March 14, 2016
Rules of the Arkansas Plan of Implementation for Air Pollution Control, Rule 19, effective May 6, 2022
Rules of the Arkansas Operating Air Permit Program, Rule 26, effective March 14, 2016
40 C.F.R. § 63 Subpart ZZZZ – <i>National Emission Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines</i>

### Emission Summary

The following table is a summary of emissions from the facility. This table, in itself, is not an enforceable condition of the permit.

EMISSION SUMMARY				
Source Number	Description	Pollutant	Emission Rates	
			lb/hr	tpy
Total Allowable Emissions		PM	37.9	141.6
		PM <sub>10</sub>	28.8	101.0
		PM <sub>2.5</sub>	See Note*	
		SO <sub>2</sub>	1.2	0.6
		VOC	10.2	4.4
		CO	26.9	37.3
		NO <sub>x</sub>	80.9	46.6
HAPs		Single HAP**	0.22	0.81
		Total HAPs**	0.22	0.85
SN-02	Plant #1 Ore Dump	PM	0.6	0.9
		PM <sub>10</sub>	0.1	0.1
SN-06	Plant #1 North & South Tanks	PM	0.1	0.4
		PM <sub>10</sub>	0.1	0.2
SN-14	Plant #1 DCF Tank	PM	0.1	0.1
		PM <sub>10</sub>	0.1	0.1
SN-21A	Plant #2 Fuller Mill Filter #1	PM	0.8	3.2
		PM <sub>10</sub>	0.5	2.0
SN-23	Plant #2 Supply Feed Tank	PM	0.1	0.2
		PM <sub>10</sub>	0.1	0.1
SN-25	Plant #2 Binder Storage	PM	0.1	0.4
		PM <sub>10</sub>	0.1	0.2
SN-28	Forming Area Baghouse	PM	2.6	11.1
		PM <sub>10</sub>	1.7	7.1
SN-34	Plant #2 Shipping Area Vent	PM	0.2	0.2
		PM <sub>10</sub>	0.1	0.2
SN-40	Plant #1 Side #1 R/W Blower	PM	0.2	0.8
		PM <sub>10</sub>	0.1	0.3
SN-41	Plant 31 Side #2 R/W Blower	PM	0.2	0.8
		PM <sub>10</sub>	0.1	0.2
SN-42	Plant #1 DCF Blower	PM	0.1	0.1

Covia ISP, Inc. - Fort Smith Plant  
 Permit #: 0492-AOP-R15  
 AFIN: 66-00219

EMISSION SUMMARY				
Source Number	Description	Pollutant	Emission Rates	
			lb/hr	tpy
		PM <sub>10</sub>	0.1	0.1
SN-43	Plant #2 R/W Blower	PM	0.3	1.0
		PM <sub>10</sub>	0.1	0.3
SN-44	Plant #2 R/W Blower	PM	0.3	1.0
		PM <sub>10</sub>	0.1	0.3
SN-46	360 Baghouse	PM	0.8	3.2
		PM <sub>10</sub>	0.6	2.1
SN-49	Plant/Plant Product Conveyance	PM	0.1	0.1
		PM <sub>10</sub>	0.1	0.1
SN-50	Plant #2 Mill Conveyor	PM	0.3	1.0
		PM <sub>10</sub>	0.1	0.1
SN-51	Factory Wide Fugitives	PM	3.5	15.4
		PM <sub>10</sub>	0.3	1.3
SN-53	Plant #2 Ball Mill Area – DC 221 Filter	PM	0.3	1.0
		PM <sub>10</sub>	0.1	0.1
SN-54	Plant #2 400 Area – DC 440 Filter	PM	1.9	8.4
		PM <sub>10</sub>	1.3	5.3
SN-55	Plant #1 Bin Vent Mixer 6 - Baghouse	PM	0.1	0.5
		PM <sub>10</sub>	1.3	0.3
SN-62	Line #3 Rework Feed Vessel Filter	PM	0.1	0.2
		PM <sub>10</sub>	0.1	0.1
SN-63	Line #3 Rework Feed Vessel Filter	PM	0.1	0.1
		PM <sub>10</sub>	0.1	0.1
SN-64	Bin Vent for Binder Silo	PM	0.2	0.5
		PM <sub>10</sub>	0.1	0.2
SN-65	Iron Ore Storage Vessel Vent Filter	PM	0.1	0.1
		PM <sub>10</sub>	0.1	0.1
SN-70	New Mixer	PM	1.9	13.2
		PM <sub>10</sub>	1.2	8.4
SN-71/72	New Rotary Mill	PM	0.6	0.9
		PM <sub>10</sub>	0.2	0.3
SN-73A	Emergency Generator A (2.135 MMBtu/hr)	PM	0.8	0.1
		PM <sub>10</sub>	0.8	0.1
		SO <sub>2</sub>	0.8	0.1
		VOC	1.0	0.1
		CO	2.5	0.2
		NO <sub>x</sub>	11.2	0.6
		Single HAP	0.01	0.01
		Total HAP	0.01	0.01



Covia ISP, Inc. - Fort Smith Plant  
 Permit #: 0492-AOP-R15  
 AFIN: 66-00219

EMISSION SUMMARY				
Source Number	Description	Pollutant	Emission Rates	
			lb/hr	tpy
SN-73B	Emergency Generator B (4.9 MMBtu/hr)	PM	0.4	0.1
		PM <sub>10</sub>	0.4	0.1
		SO <sub>2</sub>	0.1	0.1
		VOC	0.5	0.1
		CO	4.8	0.3
		NO <sub>x</sub>	17.8	0.9
		Single HAP	0.01	0.01
		Total HAP	0.01	0.01
SN-73C	Emergency Generator C (14.203 MMBtu/hr)	PM	1.0	0.1
		PM <sub>10</sub>	0.8	0.1
		SO <sub>2</sub>	0.1	0.1
		VOC	1.2	0.1
		CO	11.2	0.6
		NO <sub>x</sub>	42.1	2.1
		Single HAP	0.01	0.01
		Total HAP	0.01	0.01
SN-74	Three Parts Washers	VOC	6.9	1.6
SN-C01	Plant No. 1, Kiln No. 2 (30 MMBtu/hr w/baghouse or scrubber)	PM	3.0	13.1
		PM <sub>10</sub>	3.0	13.1
		SO <sub>2</sub>	0.1	0.1
		VOC	0.2	0.8
		CO	2.6	11.1
		NO <sub>x</sub>	3.0	13.2
		Single HAP	0.06	0.24
		Total HAP	0.06	0.25
SN-C02	Cooler DC	PM	2.6	11.3
		PM <sub>10</sub>	2.6	11.3
SN-C03	Screen DC	PM	0.4	1.5
		PM <sub>10</sub>	0.4	1.5
SN-C04	Loadout DC	PM	0.3	1.2
		PM <sub>10</sub>	0.3	1.2
SN-C05	Storage Bin DC	PM	0.3	1.2
		PM <sub>10</sub>	0.3	1.2
SN-C06	Mill Feed Silo DC	PM	0.5	2.1
		PM <sub>10</sub>	0.5	2.1
SN-C07	Classifier DC	PM	1.9	8.3
		PM <sub>10</sub>	1.9	8.3
SN-C08	Product Bin DC	PM	1.0	4.2
		PM <sub>10</sub>	1.0	4.2

EMISSION SUMMARY				
Source Number	Description	Pollutant	Emission Rates	
			lb/hr	tpy
SN-C09	Rail Car Pneumatic Transfer Filter	PM	0.2	0.6
		PM <sub>10</sub>	0.2	0.6
SN-C10	Transload Conveyor Filter	PM	0.1	0.4
		PM <sub>10</sub>	0.1	0.4
SN-C11	Transload Conveyor Filter	PM	0.1	0.4
		PM <sub>10</sub>	0.1	0.4
SN-C13	Bagging Area DC	PM	0.3	1.2
		PM <sub>10</sub>	0.3	1.2
SN-C14	Silo Loadout Baghouse	PM	1.2	5.0
		PM <sub>10</sub>	1.2	5.0
SN-C15	Mobile Conveyor	PM	0.1	0.1
		PM <sub>10</sub>	0.1	0.1
SN-C16	Mill Feed Conveyors DC	PM	0.1	0.1
		PM <sub>10</sub>	0.1	0.1
SN-C17	Grinding Mill and Mill Area DC	PM	0.1	0.1
		PM <sub>10</sub>	0.1	0.1
SN-C18A	Plant No. 2 68.0 MMBtu/hr (combustion emissions) Kiln Cyclone and Scrubber	PM	1.8	7.5
		PM <sub>10</sub>	1.8	7.5
		SO <sub>2</sub>	0.1	0.2
		VOC	0.4	1.7
		CO	5.8	25.1
		NO <sub>x</sub>	6.8	29.8
		Single HAP	0.13	0.54
		Total HAP	0.13	0.57
SN-C18B	Plant No. 2 Kiln Cooler and Scrubber	PM	1.2	5.2
		PM <sub>10</sub>	1.2	5.2
SN-C19	Rail Unloading (DC - 21010)	PM	0.6	1.0
		PM <sub>10</sub>	0.1	0.1
SN-C20	Silo 21010 (DC 201020)	PM	0.9	3.6
		PM <sub>10</sub>	0.1	0.3
SN-C21	Kiln Area Equipment (DC-22010)	PM	1.8	3.2
		PM <sub>10</sub>	1.1	2.1
SN-C22	Screening (DC-22020)	PM	0.2	0.4
		PM <sub>10</sub>	0.1	0.2
SN-C23	Silo-25080 (BV-25010)	PM	0.3	1.1
		PM <sub>10</sub>	0.3	1.1
SN-C24	Silo-25090 (BV-25020)	PM	0.3	1.1
		PM <sub>10</sub>	0.3	1.1
SN-C25	Loading Spout (LS-25010)	PM	0.1	0.4
		PM <sub>10</sub>	0.1	0.4

Covia ISP, Inc. - Fort Smith Plant  
 Permit #: 0492-AOP-R15  
 AFIN: 66-00219

EMISSION SUMMARY				
Source Number	Description	Pollutant	Emission Rates	
			lb/hr	tpy
SN-C29	BN-23010 (BV-23010)	PM	0.2	0.6
		PM <sub>10</sub>	0.2	0.6
SN-C30	BN-23020 (BV-23020)	PM	0.2	0.8
		PM <sub>10</sub>	0.2	0.8
SN-C31	BN-23030 (BV-23040)	PM	0.2	0.8
		PM <sub>10</sub>	0.2	0.8

\*PM<sub>2.5</sub> limits are source specific, if required. Not all sources have PM<sub>2.5</sub> limits.

\*\*HAPs included in the VOC totals. Other HAPs are not included in any other totals unless specifically stated.

### **SECTION III: PERMIT HISTORY**

492-A was issued to Norton Company on May 26, 1978. 492-A permitted Norton to construct and operate a sintered aluminum oxide manufacturing plant at the present location with an annual production capacity of 20,000 tons per year.

492-AR-1 was issued to the Norton Company on May 22, 1981. 492-AR-1 permitted the installation and operation of a new sintering kiln (SN-10), a new ball mill (SN-11), mixing and sizing equipment (SN-16), and a product cooler system.

492-AR-2 was issued to the Norton Company on January 22, 1982. 492-AR-2 permitted the installation and operation of a new dryer (SN-13) with associated baghouse.

492-AR-3 was issued to Norton-Alcoa Proppants on July 24, 1985. 492-AR-3 permitted the construction and operation of new expanded facilities (SN-18 through SN-34). The permit also recognized the facility's name change from Norton Company to Norton-Alcoa Proppants.

492-AR-4 was issued to Norton-Alcoa Proppants on September 30, 1998 to reclassify the facility as a synthetic minor with annual PM<sub>10</sub> emissions of 91.3 tons per year. The permit also included two previously unlisted sources, the railcar loadout (SN-08), and the truck loadout (SN-17). The permit also includes the plant to plant pneumatic conveyor (SN-38) as a new source.

492-AR-5 was issued to Norton-Alcoa Proppants on September 30, 1999. The permit was issued to allow the installation of a backup bucket elevator which increased the operating efficiency of the facility, but with no increase in emissions. A new baghouse (SN-39) was added with this permit modification. Several sources were also listed for the first time as being subject to 40 CFR 60 Subpart OOO - Standards of Performance for Nonmetallic Mineral Processing Plants.

492-AR-6 was issued to Norton Alcoa Proppants on February 16, 2000. The permit was issued to allow the manufacture of an alternate product at the facility. Permit limits were: PM - 135.7 tpy, PM<sub>10</sub> - 91.3 tpy, SO<sub>2</sub> - 0.8 tpy, VOC - 25.0 tpy, CO - 18.8 tpy, NO<sub>x</sub> - 75.1 tpy, Formaldehyde - 4.61 tpy, Ethylene Glycol - 7.86 tpy, and Phenol 9.40 tpy.

An administrative amendment was issued to the above permit on March 10, 2000. It was determined during testing for the above permit that SN-24 did not vent to atmosphere and was not an emission source. Its emission limits were removed from the permit. Permit limits were: PM - 134.4 tpy, PM<sub>10</sub> - 90.1 tpy, SO<sub>2</sub> - 0.8 tpy, VOC - 25.0 tpy, CO - 18.8 tpy, NO<sub>x</sub> - 75.1 tpy, Formaldehyde - 4.61 tpy, Ethylene Glycol - 7.86 tpy, and Phenol 9.40 tpy.

492-AR-7 was issued to Norton Alcoa Proppants on July 12, 2000. The permit was issued to allow the manufacture to revise cycle times to increase throughput. Permit limits were: PM - 139.8 tpy, PM<sub>10</sub> - 94.3 tpy, SO<sub>2</sub> - 0.8 tpy, VOC - 25.0 tpy, CO - 18.8 tpy, NO<sub>x</sub> - 75.1 tpy, Formaldehyde - 4.61 tpy, Ethylene Glycol - 7.86 tpy, and Phenol 9.40 tpy.

Covia ISP, Inc. - Fort Smith Plant  
Permit #: 0492-AOP-R15  
AFIN: 66-00219

492-AR-8 was issued to Norton Alcoa Proppants on September 15, 2001. The permit was issued to allow seven minor changes to the previous permit. The primary changes were to allow diesel fuel as a fully permitted fuel and to remove the HAPS containing materials from the process. Permit limits were: PM - 144.9 tpy, PM<sub>10</sub> - 95.3 tpy, SO<sub>2</sub> - 90.0 tpy, VOC - 3.6 tpy, CO - 54.2 tpy, and NO<sub>x</sub> - 98.5 tpy.

492-AOP-R0 was issued to Norton Proppants, Inc. on August 5, 2002. The permit allowed several changes to the previous permit including recalculating several of the emission sources. Permit limits were: PM - 178.1 tpy, PM<sub>10</sub> - 178.1 tpy, SO<sub>2</sub> - 90.0 tpy, VOC - 5.6 tpy, CO - 84.2 tpy, and NO<sub>x</sub> - 153.1 tpy.

Permit No. 0492-AOP-R1 was issued to Norton Proppants, a Division of Saint-Gobain Ceramics and Plastics on November 27, 2003. This modification was issued to allow several minor process changes. Permit limits were: PM - 208.5 tpy, PM<sub>10</sub> - 208.5 tpy, SO<sub>2</sub> - 90.0 tpy, VOC - 5.6 tpy, CO - 84.2 tpy, and NO<sub>x</sub> - 153.1 tpy.

Permit No. 0492-AOP-R2 was issued to Norton Proppants, a Division of Saint-Gobain Ceramics and Plastics on July 13, 2004. This modification was issued to allow the installation of a third forming line. Permit limits were: PM - 235.2 tpy, PM<sub>10</sub> - 235.2 tpy, SO<sub>2</sub> - 90.0 tpy, VOC - 7.1 tpy, CO - 105.2 tpy, and NO<sub>x</sub> - 191.0 tpy.

Permit No. 0492-AOP-R3 was issued to Saint-Gobain Proppants on November 18, 2004. Two pneumatic conveyances (SN-62 & SN-63) are added to the permit on this modification. Permit limits were: PM - 235.5 tpy, PM<sub>10</sub> - 235.5 tpy, SO<sub>2</sub> - 90.0 tpy, VOC - 7.1 tpy, CO - 105.2 tpy, and NO<sub>x</sub> - 153.1 tpy.

Permit No. 0492-AOP-R4 was issued April 7, 2007. This permit modification allowed the facility to add 3 small new sources to the facility. A binder tank vent filter (SN-64), an iron ore tank vent filter (SN-66) and a dust collector for a plant-to-plant conveyance (SN-66) will be added to the facility. Several other changes will be made to existing sources. A supplemental dust collector will be added at the Plant #2 Kiln/cooler so it will then be controlled by 2 dust collectors. Two baghouses will be improved or replaced (SN-09 & SN-11). Two sources will be removed from the permit (SN-48 & SN-52) which were never installed. Two sources (SN-59 & SN-60) will be moved to the Insignificant Activities List since they vent inside the building. Three sources (SN-61, SN-62 & SN-63) will be combined to exhaust through a single stack.

Permit No. 0492-AOP-R5 was issued February 21, 2008. Issuance of this permit was prompted by the submittal of the facility's renewal Title V air permit application. Included in the renewal was the removal of SN-64 and SN-65 as affected sources for 40 CFR Part 60, Subpart OOO. Basis for the removal of these sources from the affected source list was because SN-64 is a bulk storage tank for cornstarch and SN-65 is a bulk storage tank for iron ore (hematite). An affected facility storage bin is defined as a facility for storage of nonmetallic minerals prior to further processing or loading. Cornstarch and hematite are not defined as nonmetallic minerals by 40 CFR Part 60, Subpart OOO. Also included is the installation of a new baghouse (Plant #2 Fuller Mill filter #2).

Covia ISP, Inc. - Fort Smith Plant  
Permit #: 0492-AOP-R15  
AFIN: 66-00219

Permit No. 0492-AOP-R6 was issued September 16, 2008. This minor permit modification replaced a baghouse (SN-38), installed additional ductwork and pickup points to supplement the dust collection system for SN-38 and SN-39, and increased the annual throughput for SN-38 to 31,200 tons per year. This minor permit modification increased annual PM and PM<sub>10</sub> emissions by 0.1 tons per year to 245.25 tons.

Permit No. 0492-AOP-R7 was issued May 29, 2012. This permit action modified the plant to plant finished product pneumatic conveying system, allowed the installation of a new scrubber system (SN-67) to control emissions from Plant #1 Kiln#2 (SN-10) and the Plant #2 Kiln (SN-29). Finally, this action allowed the installation and operation of SN-68 (Waste Lime Silo Bin Vent), a new Ball Mill (SN-70), and Plant #1 Ore Receiving Bins (SN-71/SN-72).

Permit No. 0492-AOP-R8 was issued July 19, 2012. This permit amendment revised Specific Condition 8, and corrected Specific Conditions 13, 14, and 16.

Permit No. 0492-AOP-R9 was issued June 14, 2013. This permit action replaced a baghouse, and increased the hourly and annual throughput of SN-08/38.

Permit No. 0492-AOP-R10 was issued May 22, 2015. This permit incorporated the facility's renewal permit application. This modification included three emergency generators (SN-73A, SN-73B, and SN-73C), three parts washers (SN-74), and updated the facility's insignificant activity list. This modification also included an increase in throughput and emissions at SN-08/38. Permitted emissions increases were 0.3 tpy of SO<sub>2</sub>, 1.9 tpy of VOC, 1.2 tpy of CO, and 3.9 tpy of NO<sub>x</sub>.

Permit No. 0492-AOP-R11 was issued October 6, 2020. This modification included the facility's renewal permit application. Emissions were revised for SN-02, and SN-08/38. Also, SN-26 and SN-26P were designated as Dryer No. 1, and SN-27 and SN-27P were designated as Dryer No. 2. Criteria permitted emissions were 230.8 tpy of PM, 160.2 tpy of PM<sub>10</sub>, 244.3 tpy of SO<sub>2</sub>, 8.1 tpy of VOC, 191.5 tpy of CO and various HAPs.

Permit No. 0492-AOP-R12 was issued August 4, 2021. Covia ISP, Inc. had used bauxite to manufacturer proppants when owned by a different company. Covia ISP, Inc. now utilizes portions of the facility to manufacturer silica sand-based products. With this modification the facility removes sources: SN-09 & 09P, SN-13 & 13P, SN-26 & 26P, SN-27 & 27P, SN-56, SN-57, SN-58, SN-61, SN-67, SN-68, and SN-69. Facility reactivates SN-04 Plant #1, Kiln #1, 7.7 MMbtu/hr and SN-04P Plant #1, Kiln #1 DC and is renaming sources as follows: SN-C01: Kiln DC (Former SN-10), SN-C02 Cooler DC (Former SN-12), SN-C03 Screen DC (Former SN-07), SN-C04 Loadout DC (Former SN-13), SN-C05 Storage Bin DC (Former SN-01), SN-C06 Mill Feed Silo (Former SN-01), SN-C07 Classifier DC (Former SN-11), and SN-C08 Product Bin DC (Former SN-32/33). Finally, the facility is permitting new source SN-C05, a Storage Bin DC, SN-C09 a pneumatic sand transfer filter, SN-10 a mobile transload conveyor filter, SN-C11 a second mobile transload conveyor filter as well as adding additional insignificant activities of a chopping mill, mixer, grinding mill with classifier and two (2) screening units at the pilot plant as A-13 activities. This modification decreases permitted emissions by 85.8 tpy of PM, 62.2 tpy

Covia ISP, Inc. - Fort Smith Plant  
Permit #: 0492-AOP-R15  
AFIN: 66-00219

of PM<sub>10</sub>, 243.6 tpy of SO<sub>2</sub>, 4.0 tpy of VOC, 157.9 tpy of CO, and 206.5 tpy of NO<sub>x</sub>. Facility HAP emissions decreased as well.

Permit No. 0492-AOP-R13 was issued September 21, 2023. This modification added a 32,000 acfm wet scrubber to SN-C01, this kiln will be controlled by the already permitted baghouse or the scrubber. This modification removed SN-08/38, SN-21B, adds SN-C16 Mill Feed Conveyor and SN-C17 Grinding Mill and Mill Area DC; also SN-29 Plant #2 Kiln Burner capacity is increasing (by replacing the burner) from 60 MMBtu to 68 MMBtu/hr. The facility renamed SN-29 as SN-C18A and SN-C18B. SN-C18A added a scrubber and will control particulate emissions from Plant #2 Kiln. SN-C18B added a scrubber and will control particulate emissions from the Plant #2 Kiln Cooler. The facility added two (2) 15,000 acfm wet scrubbers to control emissions from SN-04 and changed the name of SN-04 to SN-C12. This modification added a New Storage Bin (BN-1517), two New Bagging Stations (BA-1516 and BA-1517) and a New Baghouse (SN-C13). SN-C13 will control emissions from the New Storage Bin (BN-1517), two New Bagging Stations (BA-1516 and BA-1517) as well as routed emissions from an existing Storage Bin (BN-1516) which was routed to SN-C06. Finally, this modification re-purposed existing SN-20 to store silica sand and rename it SN-C14 and added a relocatable Project Conveyor (SN-15). This modification increased permitted emissions by 8.3 tpy of PM, 5.9 tpy of PM<sub>10</sub>, 0.2 tpy of VOC, 3.0 tpy of CO, and 3.5 tpy of NO<sub>x</sub>.

Permit No. 0492-AOP-R13 was issued May 22, 2024. This modification, contained the following changes:

- Re-named SN-18 as SN-C19 Rail Unloading (DC -21010), replaced two hoppers and feeders with a new hopper and feeder, modified the conveyor, replaced filters, added blower speed control, and installed a pressure meter;
- Re-named SN-19 as SN-C20 Silo 21010 (DC 201020), modified collection piping, installed new collection piping, replaced filters, and installed a pressure meter;
- Re-named SN-47 as SN-C21 Kiln Area Equipment (DC-22010), removed old processors, installed two new conveyors, modified collection pipings, replaced filters, added blower speed controls, installed a pressure meter;
- Re-named SN-31 as SN-C22 Screening (DC-22020), replaced material screening units, installed new bucket elevators and conveyors, installed bagging stations, modified collection piping, replaced filters, added blower speed controls, installed a pressure meter;
- Re-named SN-22 as SN-C29 BN-23010 (BV-23010), redeployed the bin vent (previously SN-22) onto a different bin, replaced filters, installed a pressure meter;
- Added new source SN-C23 Silo-25080 (BV-25010);
- Added new source SN-C24 Silo-25090 (BV-25020);
- Added new source SN-C25 Loading Spout (LS-25010);
- Added new source SN-C26 Loading Spout (LS-25020);
- Added new source SN-C27 Loading Spout (LS-25030);
- Added new source SN-C28 Loading Spout (LS-25040);
- Added new source SN-C30 BN-23020 (BV-23020);
- Added new source SN-C31 BN-23030 (BV-23040)

Covia ISP, Inc. - Fort Smith Plant

Permit #: 0492-AOP-R15

AFIN: 66-00219

- Increased the burner capacity of SN-C01 Kiln DC, Plant #1 from 20 to 30 MMBtu/hr.

Permitted emissions increased/decreased by 5.4 tpy PM, 8.7 tpy PM<sub>10</sub>, 0.3 tpy VOC, 3.7 tpy CO, 4.4 tpy NO<sub>x</sub>, 0.11 tpy single HAPs, and -0.01 tpy of total HAPs.



## SECTION IV: SPECIFIC CONDITIONS

### SN-C01, SN-C18A, SN-C18B Kilns

#### Source Description

There are three kilns (SN-C01, SN-C18A and SN-C18B) operating in the process at the facility. SN-C01 emissions are controlled by either a 32,000 acfm wet scrubber or baghouse.

#### Specific Conditions

- The permittee shall not exceed the emission rates set forth in the following table. The permittee shall demonstrate compliance with this condition by Specific Conditions #6, 7, 9, and 10. [Rule 19.501 *et seq.* and 40 C.F.R. § 52 Subpart E]

SN	Description	Pollutant	lb/hr	tpy
C01	Plant No. 1, Kiln No. 2 30 MMBtu/hr w/baghouse or scrubber	PM <sub>10</sub>	3.0	13.1
		SO <sub>2</sub>	0.1	0.1
		VOC	0.2	0.8
		CO	2.6	11.1
		NO <sub>x</sub>	3.0	13.2
C18A	Plant No. 2, 68.0 MMBtu/hr (combustion emissions) Kiln cyclone and Scrubber	PM <sub>10</sub>	1.8	7.5
		SO <sub>2</sub>	0.1	0.2
		VOC	0.4	1.7
		CO	5.8	25.1
		NO <sub>x</sub>	6.8	29.8
C18B	Plant No. 2 Kiln Cooler and Scrubber	PM <sub>10</sub>	1.2	5.2

- The permittee shall not exceed the emission rates set forth in the following table. The permittee shall demonstrate compliance with this condition by Specific Conditions #6, 7, 9, and 10. [Rule 18.801 and Ark. Code Ann. § 8-4-203 as referenced by Ark. Code Ann. §§ 8-4-304 and 8-4-311]

SN	Description	Pollutant	lb/hr	tpy
C01	Plant No. 1, Kiln No. 2 30 MMBtu/hr w/baghouse or scrubber	PM	3.0	13.1
		Single HAP	0.06	0.24
		Total HAP	0.06	0.25
C18A	Plant No. 2, 68.0 MMBtu/hr (combustion emissions) Kiln cyclone and Scrubber	PM	1.8	7.5
		Single HAP	0.13	0.54
		Total HAP	0.13	0.57

SN	Description	Pollutant	lb/hr	tpy
C18B	Plant No. 2 Kiln Cooler and Scrubber	PM	1.2	5.2

3. Visible emissions may not exceed the limits specified in the following table of this permit as measured by EPA Reference Method 9.

SN	Limit	Regulatory Citation
C01, C18A, and C18B	5%	Rule 18.501 and Ark. Code Ann. § 8-4-203 as referenced by Ark. Code Ann. §§ 8-4-304 and 8-4-311
C01*	20%	Rule 19.503 and 40 C.F.R. § 52 Subpart E

\*With Scrubber.

4. The permittee shall use only pipeline quality natural gas at SN-C01 and SN-18A. [Rule.19.705, Ark. Code Ann. § 8-4-203 as referenced by Ark. Code Ann. §§ 8-4-304 and 8-4-311, and 40 C.F.R. § 70.6]
5. The permittee shall not process more than 262,800,000 cubic feet of natural gas at SN-C01, and 595,680,000 cubic feet of natural gas at SN-C18 (A & B) per consecutive 12-month period. [Rule.19.705, Ark. Code Ann. § 8-4-203 as referenced by Ark. Code Ann. §§ 8-4-304 and 8-4-311, and 40 C.F.R. § 70.6]
6. The permittee shall maintain monthly records to demonstrate compliance with Specific Condition #5. The permittee shall update these records by the fifteenth day of the month following the month to which the records pertain. The twelve-month rolling totals and each individual month's data shall be maintained on-site, made available to Division personnel upon request, and submitted in accordance with General Provision #7. [Rule.19.705 and 40 C.F.R. § 52 Subpart E]
7. The permittee shall conduct weekly observations of the opacity from sources SN-C01, SN-C18A and SN-C18B. If visible emissions in excess of the permitted levels are detected, the permittee shall immediately take action to identify the cause of the visible emissions in excess of the permit limit, implement corrective action, and document that visible emissions did not appear to be in excess of the permitted opacity following the corrective action. The permittee shall maintain records which contain the following items in order to demonstrate compliance with this specific condition. These records shall be updated weekly, kept on site, and made available to Department personnel upon request.
- The date and time of the observation.
  - If visible emissions which appeared to be above the permitted limit were detected.
  - If visible emissions which appeared to be above the permitted limit were detected, the cause of the exceedance of the opacity limit, the corrective action taken, and if

the visible emissions appeared to be below the permitted limit after the corrective action was taken.

- d. The name of the person conducting the opacity observations.

[Rule.19.503 and 40 C.F.R. § 52, Subpart E]

8. The permittee shall maintain and measure, once per day (when sources are operating), the pressure drop across the scrubbers at source SN-C01. The pressure drop across the unit shall be between 1.0 and 6.0 inches of water (H<sub>2</sub>O). [Rule.19.705, Ark. Code Ann. § 8-4-203 as referenced by Ark. Code Ann. §§ 8-4-304 and 8-4-311, and 40 C.F.R. § 70.6]
9. The permittee shall maintain daily records to demonstrate compliance with Specific Condition #8. The permittee shall update these records by the fifteenth day of the month following the month to which the records pertain. The twelve month rolling totals and each individual month's data shall be maintained on-site, made available to Division of Environmental Quality personnel upon request, and submitted in accordance with General Provision #7. [Rule.19.705 and 40 C.F.R. § 52 Subpart E]
10. The permittee shall test SN-C01 with Wet Scrubber for particulate matter using EPA Method 5. This test shall take place no later than 180 days after start-up of SN-C01 w/Wet Scrubber and in accordance with Plantwide Condition #3. Testing shall be conducted with the source operating at least 90% of its permitted capacity. Emission testing results shall be extrapolated to correlate with 100% of the permitted capacity to demonstrate compliance. Failure to test within this range shall limit the permittee to operating within 10% above the tested rate. The permittee shall measure the operation rate during the test and if testing is conducted below 90% of the permitted capacity, records shall be maintained at all times to demonstrate that the source does not exceed operation at 10% above the tested rate. [Rule.19.702 and/or Rule.18.1002 and Ark. Code Ann. § 8-4-203 as referenced by Ark. Code Ann. §§ 8-4-304 and 8-4-311]
11. While SN-C18 (A & B) are in operation, the associated scrubbers shall operate as provided below.
  - a. The differential pressure of gas across each scrubber shall be maintained between 1 and 6 inches of water (hourly average).
  - b. A liquid flow rate of at least 60 gallons per minute shall be maintained at each scrubber (hourly average).

The permittee shall continuously monitor these parameters in order to demonstrate compliance with permitted emission limits. [Rule 19.730, Rule 19.705, 40 C.F.R. § 52 Subpart E, and Ark. Code Ann. § 8-4-203 as referenced by Ark. Code Ann. §§ 8-4-304 and 8-4-311, 40 C.F.R. § 70.6, and Rule 19.304 and 40 C.F.R. § 64]

12. The permittee shall maintain monthly records to demonstrate compliance with Specific Condition 11. The permittee shall update these records by the fifteenth day of the month

Covia ISP, Inc. - Fort Smith Plant

Permit #: 0492-AOP-R15

AFIN: 66-00219

following the month to which the records pertain. Each individual month's data shall be maintained on-site, made available to Division of Environmental Quality personnel upon request, and submitted in accordance with General Provision #7. [Rule 19.705 and 40 C.F.R. § 52 Subpart E]

Covia ISP, Inc. - Fort Smith Plant  
 Permit #: 0492-AOP-R15  
 AFIN: 66-00219

SN-02, SN-06, SN-14, SN-21A, SN-23, SN-25, SN-28, SN-34, SN-40 through SN-44, SN-46, SN-49 through SN-51, SN-53 through SN-55, SN-62 through SN-65, SN-70, SN-71/72, SN-C02 through SN-C11, SN-C13 through SNC-25, and SN-C29 through SN-C31

### Particulate Sources

### Source Description

Particulate sources will mill and classify the silica to reduce the silica to finely divided powder.

### Specific Conditions

13. The permittee shall not exceed the emission rates set forth in the following table. The permittee shall demonstrate compliance with this condition by each source being permitted at its maximum capacity for pound per hour emission rates and limited annually by fuel usage. [Rule 19.501 *et seq.* and 40 C.F.R. § 52 Subpart E]

SN	Description	Pollutant	lb/hr	tpy
SN-02	Plant #1 Ore Dump Station Filter	PM <sub>10</sub>	0.1	0.1
SN-06	Plant #1 North/South Tank Bin Vents Filter	PM <sub>10</sub>	0.1	0.2
SN-14	Plant #1 DCF Tank Filter	PM <sub>10</sub>	0.1	0.1
SN-15	South Tank Bin Vent	Rerouted to SN-06		
SN-17	Truck Loadout	Rerouted to SN-08		
SN-21A	Plant #2 Fuller Ball Mill Filter #1	PM <sub>10</sub>	0.5	2.0
SN-23	Plant #2 Ball Mill Feed Vent No.2 Filter	PM <sub>10</sub>	0.1	0.1
SN-25	Plant #2 Binder Storage Vessel Vent Filter	PM <sub>10</sub>	0.1	0.2
SN-28	Forming Area Dust Collection Baghouse	PM <sub>10</sub>	1.7	7.1
SN-34	Plant #2 Shipping Area Vent (Truck Loadout)/Deduster Filter	PM <sub>10</sub>	0.2	0.2
SN-40	Plant #1 Side #1 R/W Blower	PM <sub>10</sub>	0.1	0.3
SN-41	Plant #1 Side #2 R/W Blower	PM <sub>10</sub>	0.1	0.2
SN-42	Plant #1 DCF Blower	PM <sub>10</sub>	0.1	0.1
SN-43	Plant #2 R/W Blower	PM <sub>10</sub>	0.1	0.3
SN-44	Plant #2 R/W Blower	PM <sub>10</sub>	0.1	0.3

Covia ISP, Inc. - Fort Smith Plant  
 Permit #: 0492-AOP-R15  
 AFIN: 66-00219

SN	Description	Pollutant	lb/hr	tpy
SN-46	360 Baghouse	PM <sub>10</sub>	0.6	2.1
SN-49	Plant to Plant Finished Product Conveyor Filter & Cleaning Booth	PM <sub>10</sub>	0.1	0.1
SN-50	Plant No. 2 Mill Conveyor Filter	PM <sub>10</sub>	0.1	0.1
SN-51	Non-point Source Emissions	PM <sub>10</sub>	0.3	1.3
SN-53	Plant #2 Ball Mill Area – DC 221 Filter	PM <sub>10</sub>	0.1	0.1
SN-54	Plant #2 400 Area – DC 440 Filter	PM <sub>10</sub>	1.3	5.3
SN-55	Plant #1 Bin Vent Mixer 6 – Baghouse	PM <sub>10</sub>	1.3	0.3
SN-62	Line #3 Rework Feed Vessel Filter	PM <sub>10</sub>	0.1	0.1
SN-63	Line #3 Rework Feed Vessel Filter	PM <sub>10</sub>	0.1	0.1
SN-64	Bin Vent for Binder Silo	PM <sub>10</sub>	0.1	0.2
SN-65	Iron Ore Storage Vessel Vent Filter	PM <sub>10</sub>	0.1	0.1
SN-70	Rotary Mill Baghouse	PM <sub>10</sub>	1.2	8.4
SN-71 /SN-72	Plant #1 Ore Receiving and Storage Bins	PM <sub>10</sub>	0.2	0.3
SN-C02	Cooler DC	PM <sub>10</sub>	2.6	11.3
SN-C03	Screen DC	PM <sub>10</sub>	0.4	1.5
SN-C04	Loadout DC	PM <sub>10</sub>	0.3	1.2
SN-C05	Storage Bin DC	PM <sub>10</sub>	0.3	1.2
SN-C06	Mill Feed Silo DC	PM <sub>10</sub>	0.5	2.1
SN-C07	Classifier DC	PM <sub>10</sub>	1.9	8.3
SN-C08	Product Bin Vent DC	PM <sub>10</sub>	1.0	4.2
SN-C09	Rail Car Pneumatic Transfer Filter	PM <sub>10</sub>	0.2	0.6
SN-C10	Transload Conveyor Filter	PM <sub>10</sub>	0.1	0.4
SN-C11	Transload Conveyor Filter	PM <sub>10</sub>	0.1	0.4
SN-C13	Bagging Area	PM <sub>10</sub>	0.3	1.2
SN-C14	Silo Loadout Baghouse	PM <sub>10</sub>	1.2	5.0
SN-C15	Mobile Conveyor	PM <sub>10</sub>	0.1	0.1

SN	Description	Pollutant	lb/hr	tpy
SN-C16	Mill Feed Conveyors DC	PM <sub>10</sub>	0.1	0.1
SN-C17	Grinding Mill and Mill Area DC	PM <sub>10</sub>	0.1	0.1
SN-C19	Rail Unloading (DC -21010)	PM <sub>10</sub>	0.1	0.1
SN-C20	Silo 21010 (DC 201020)	PM <sub>10</sub>	0.1	0.3
SN-C21	Kiln Area Equipment (DC-22010)	PM <sub>10</sub>	1.1	2.1
SN-C22	Screening (DC-22020)	PM <sub>10</sub>	0.1	0.2
SN-C23	Silo-25080 (BV-25010)	PM <sub>10</sub>	0.3	1.1
SN-C24	Silo-25090 (BV-25020)	PM <sub>10</sub>	0.3	1.1
SN-C25	Loading Spout (LS-25010)	PM <sub>10</sub>	0.1	0.4
SN-C29	BN-23010 (BV-23010)	PM <sub>10</sub>	0.2	0.6
SN-C30	BN-23020 (BV-23020)	PM <sub>10</sub>	0.2	0.8
SN-C31	BN-23030 (BV-23040)	PM <sub>10</sub>	0.2	0.8

14. The permittee shall not exceed the emission rates set forth in the following table. The permittee shall demonstrate compliance with this condition by each source being permitted at its maximum capacity for pound per hour emission rates and limited annually by fuel usage. [Rule 18.801 and Ark. Code Ann. § 8-4-203 as referenced by Ark. Code Ann. §§ 8-4-304 and 8-4-311]

SN	Description	Pollutant	lb/hr	tpy
SN-02	Plant #1 Ore Dump Station Filter	PM	0.6	0.9
SN-06	Plant #1 North/South Tank Bin Vents Filter	PM	0.1	0.4
SN-14	Plant #1 DCF Tank Filter	PM	0.1	0.1
SN-15	South Tank Bin Vent	Rerouted to SN-06		
SN-17	Truck Loadout PM <sub>10</sub>	Rerouted to SN-08		
SN-21A	Plant #2 Fuller Ball Mill Filter #1	PM	0.8	3.2
SN-23	Plant #2 Ball Mill Feed Vent No.2 Filter	PM	0.1	0.2
SN-25	Plant #2 Binder Storage Vessel Vent Filter	PM	0.1	0.4
SN-28	Forming Area Dust Collection Baghouse	PM	2.6	11.1

Covia ISP, Inc. - Fort Smith Plant  
 Permit #: 0492-AOP-R15  
 AFIN: 66-00219

SN	Description	Pollutant	lb/hr	tpy
SN-34	Plant #2 Shipping Area Vent (Truck Loadout)/Deduster Filter	PM	0.2	0.2
SN-40	Plant #1 Side #1 R/W Blower	PM	0.2	0.8
SN-41	Plant #1 Side #2 R/W Blower	PM	0.2	0.8
SN-42	Plant No. 1 DCF Blower	PM	0.1	0.1
SN-43	Plant #2 R/W Blower	PM	0.3	1.0
SN-44	Plant #2 R/W Blower	PM	0.3	1.0
SN-46	360 Baghouse	PM	0.8	3.2
SN-49	Plant to Plant Finished Product Conveyor Filter & Cleaning Booth	PM	0.1	0.1
SN-50	Plant #2 Mill Conveyor Filter	PM	0.3	1.0
SN-51	Non-point Source Emissions	PM	3.5	15.4
SN-53	Plant #2 Ball Mill Area – DC 221 Filter	PM	0.3	1.0
SN-54	Plant #2 400 Area – DC 440 Filter	PM	1.9	8.4
SN-55	Plant #1 Bin Vent Mixer 6 – Baghouse	PM	0.1	0.5
SN-62	Line #3 Pneumatic Conveyance	PM	0.1	0.2
SN-63	Line #3 Pneumatic Conveyance	PM	0.1	0.1
SN-64	Binder Storage Vessel Vent Filter	PM	0.2	0.5
SN-65	Iron Ore Storage Vessel Vent Filter	PM	0.1	0.1
SN-70	Rotary Mill Baghouse	PM	1.9	13.2
SN-71 /SN-72	Plant #1 Ore receiving and Storage Bins	PM	0.6	0.9
SN-C02	Cooler DC	PM	2.6	11.3
SN-C03	Screen DC	PM	0.4	1.5
SN-C04	Loadout DC	PM	0.3	1.2
SN-C05	Storage Bin DC	PM	0.3	1.2
SN-C06	Mill Feed Silo DC	PM	0.5	2.1
SN-C07	Classifier DC	PM	1.9	8.3
SN-C08	Product Bin Vent DC	PM	1.0	4.2



Covia ISP, Inc. - Fort Smith Plant  
 Permit #: 0492-AOP-R15  
 AFIN: 66-00219

SN	Description	Pollutant	lb/hr	tpy
SN-C09	Rail Car Pneumatic Transfer Filter	PM	0.2	0.6
SN-C10	Transload Conveyor Filter	PM	0.1	0.4
SN-C11	Transload Conveyor Filter	PM	0.1	0.4
SN-C13	Bagging Area DC	PM	0.3	1.2
SN-C14	Silo Loadout Baghouse	PM	1.2	5.0
SN-C15	Mobile Conveyor	PM	0.1	0.1
SN-C16	Mill Feed Conveyors DC	PM	0.1	0.1
SN-C17	Grinding Mill and Mill Area DC	PM	0.1	0.1
SN-C19	Rail Unloading (DC -21010)	PM	0.6	1.0
SN-C20	Silo 21010 (DC 201020)	PM	0.9	3.6
SN-C21	Kiln Area Equipment (DC-22010)	PM	1.8	3.2
SN-C22	Screening (DC-22020)	PM	0.2	0.4
SN-C23	Silo-25080 (BV-25010)	PM	0.3	1.1
SN-C24	Silo-25090 (BV-25020)	PM	0.3	1.1
SN-C25	Loading Spout (LS-25010)	PM	0.1	0.4
SN-C29	BN-23010 (BV-23010)	PM	0.2	0.6
SN-C30	BN-23020 (BV-23020)	PM	0.2	0.8
SN-C31	BN-23030 (BV-23040)	PM	0.2	0.8

15. Visible emissions may not exceed the limits specified in the following table of this permit as measured by EPA Reference Method 9.

SN	Limit	Regulatory Citation
SN-02, SN-06, SN-21A, SN-23, SN-25, SN-28, SN-34, SN-40 through SN-44, SN-46, SN-49 through SN-51, SN-53 through SN-55, SN-62 through SN-65, SN-70, SN-71/72, SN-C02 through SN-C04, SN-C06 through SN-C11, SN-C13 through SN-C17, and SN-C19 through SN-C25, SN-C29 through SN-C31	5%	Rule 18.501 and Ark. Code Ann. § 8-4-203 as referenced by Ark. Code Ann. §§ 8-4-304 and 8-4-311

16. Weekly observations of the opacity from SN-02, SN-06, SN-14, SN-15, SN-17, SN-21A, SN-23, SN-25, SN-28, SN-34, SN-40 through SN-44, SN-46, SN-49 through SN-51, SN-53 through SN-55, SN-62 through SN-65, SN-70, SN-71/72, SN-C02 through SN-C04, SN-C06 through SN-C11, SN-C13 through SN-C17, and SN-C19 through SN-C25, SN-C29 through SN-C31 shall be conducted by a person trained but not necessarily certified in EPA Reference Method 9. If visible emissions are detected at the particulate sources listed in Specific Condition 15, an observation of opacity shall be conducted by a person trained but not necessarily certified in EPA Reference Method 9. If visible emissions in excess of the permitted levels are detected, the permittee shall immediately take action to identify the cause of the visible emissions in excess of the permit limit, implement corrective action, and document that visible emissions did not appear to be in excess of the permitted opacity following the corrective action. The permittee shall maintain records which contain the following items in order to demonstrate compliance with this specific condition. These records shall be updated daily, kept on site, and made available to Department personnel upon request.
- The date and time of the observation.
  - If visible emissions which appeared to be above the permitted limit were detected.
  - If visible emissions which appeared to be above the permitted limit were detected, the cause of the exceedance of the opacity limit, the corrective action taken, and if the visible emissions appeared to be below the permitted limit after the corrective action was taken.
  - The name of the person conducting the opacity observations.

[Rule.18.501 and Ark. Code Ann. § 8-4-203 as referenced by Ark. Code Ann. §§ 8-4-304 and 8-4-311]

17. The permittee shall not receive more than 350,000 tons of ore at SN-70 per consecutive twelve month period. [Rule.19.705, Ark. Code Ann. § 8-4-203 as referenced by Ark. Code Ann. §§ 8-4-304 and 8-4-311, and 40 C.F.R. § 70.6]

18. The permittee shall not receive more than 150,000 tons of ore at SN-02 per consecutive twelve month period. [Rule.19.705, Ark. Code Ann. § 8-4-203 as referenced by Ark. Code Ann. §§ 8-4-304 and 8-4-311, and 40 C.F.R. § 70.6]
19. The permittee shall maintain monthly records which demonstrate compliance with Specific Conditions 17 and 18. Records shall be updated by the fifteenth day of the month following the month for which the records pertain. These records shall be kept on site, and shall be made available to Department personnel upon request. A copy of the results of these records shall be submitted with the semi-annual report required in General Provision #7. [Rule.19.705 and 40 C.F.R. § 52 Subpart E]
20. The permittee shall not exceed a throughput of 876,000 tons of silica sand at SN-C15 per rolling 12 month period. [Rule.19.705, Ark. Code Ann. § 8-4-203 as referenced by Ark. Code Ann. §§ 8-4-304 and 8-4-311, and 40 C.F.R. § 70.6]
21. The permittee shall maintain monthly records to demonstrate compliance with Specific Condition 20. The permittee shall update these records by the fifteenth day of the month following the month to which the records pertain. The twelve month rolling totals and each individual month's data shall be maintained on-site, made available to Division of Environmental Quality personnel upon request, and submitted in accordance with General Provision #7. [Rule.19.705 and 40 C.F.R. § 52 Subpart E]

SN-73A, SN-73B, SN-73C  
 Emergency Generators

Source Description

The facility operates three (3) diesel fired internal combustion emergency generators.

Specific Conditions

22. The permittee shall not exceed the emission rates set forth in the following table. The permittee shall demonstrate compliance with this condition by Specific Condition 26. [Rule 19.501 *et seq.* and 40 C.F.R. § 52 Subpart E]

SN	Description	Pollutant	lb/hr	tpy
73A	Emergency Generator, 305 Hp (3406 Cat)	PM <sub>10</sub>	0.8	0.1
		SO <sub>2</sub>	0.8	0.1
		VOC	1.0	0.1
		CO	2.5	0.2
		NO <sub>x</sub>	11.2	0.6
73B	Emergency Generator, 700 Hp (V171- Cummins)	PM <sub>10</sub>	0.4	0.1
		SO <sub>2</sub>	0.1	0.1
		VOC	0.5	0.1
		CO	4.8	0.3
		NO <sub>x</sub>	17.8	0.9
73C	Emergency Generator, 2029 Hp (3516 Cat)	PM <sub>10</sub>	0.8	0.1
		SO <sub>2</sub>	0.1	0.1
		VOC	1.2	0.1
		CO	11.2	0.6
		NO <sub>x</sub>	45.1	2.1

23. The permittee shall not exceed the emission rates set forth in the following table. The permittee shall demonstrate compliance with this condition by Specific Condition 26. [Rule 18.801 and Ark. Code Ann. § 8-4-203 as referenced by Ark. Code Ann. §§ 8-4-304 and 8-4-311]

SN	Description	Pollutant	lb/hr	tpy
73A	Emergency Generator, 305 Hp (3406 Cat)	PM	0.8	0.1
		Single HAP	0.01	0.01
		Total HAP	0.01	0.01
73B	Emergency Generator, 700 Hp (V171- Cummins)	PM	0.4	0.1
		Single HAP	0.01	0.01
		Total HAP	0.01	0.01

SN	Description	Pollutant	lb/hr	tpy
73C	Emergency Generator, 2029 Hp (3516 Cat)	PM	1.0	0.1
		Single HAP	0.01	0.01
		Total HAP	0.01	0.01

24. Visible emissions from SN-73A, SN-73B, and SN-73C shall not exceed 20% as measured by EPA Method 9. [Rule 19.503 and 40 C.F.R. § 52 Subpart E]
25. The permittee shall not operate the emergency generators SN-73A, SN-73B, nor SN-73C in excess of 100 total hours (emergency and non-emergency) each per calendar year in order to demonstrate compliance with the annual emission rate limits. Emergency operation in excess of these hours may be allowable but shall be reported and will be evaluated in accordance with Rule 19.602 and other applicable regulations. [Rule 19.705, Ark. Code Ann. § 8-4-203 as referenced by Ark. Code Ann. §§ 8-4-304 and 8-4-311, and 40 C.F.R. § 70.6]
26. The permittee shall maintain monthly records to demonstrate compliance with Specific Condition 25. The permittee shall update these records by the fifteenth day of the month following the month to which the records pertain. The calendar year totals and each individual month's data shall be maintained on-site, made available to Department personnel upon request, and submitted in accordance with General Provision #7. [Rule 19.705 and 40 C.F.R. § 52 Subpart E]

#### 40 CFR Part 63, Subpart ZZZZ Requirements

27. The permittee must, for SN-73A, during periods of start-up, minimize the engine's time spent at idle and minimize the engine's startup time at startup to a period needed for appropriate and safe loading of the engine, not to exceed 30 minutes, after which time the non-startup emission limitations apply. [Rule 19.304 and 40 C.F.R. § 63.6625(h)]
28. Except during periods of start-up, the permittee must, for SN-73A, change oil and filter every 500 hours of operation annually, whichever comes first; inspect air cleaner every 1,000 hours of operation or annually, whichever comes first, and replace as necessary; inspect all hoses and belts every 500 hours of operation or annually, whichever comes first, and replace as necessary. [Rule 19.304 and 40 C.F.R. § 63.6602, Table 2c]
29. The permittee must, for SN-73A, install a non-resettable hour meter if one is not already installed at SN-73A. [Rule 19.304 and 40 C.F.R. § 63.6625(f)]
30. The permittee must, for SN-73A, minimize the engine's time spent at idle during startup and minimize the engine's startup time to a period needed for appropriate and safe loading of the engine, not to exceed 30 minutes, after which time the emission standards applicable to all times other than startup in Tables 1a, 2a, 2c, and 2d to this subpart apply. [Rule 19.304 and 40 C.F.R. § 63.6625(h)]

31. The permittee, for SN-73A, has the option of utilizing an oil analysis program in order to extend the specified oil change requirement in Tables 2c and 2d to this subpart. The oil analysis must be performed at the same frequency specified for changing the oil in Table 2c or 2d to this subpart. The analysis program must at a minimum analyze the following three parameters: Total Base Number, viscosity, and percent water content. The condemning limits for these parameters are as follows: Total Base Number is less than 30 percent of the Total Base Number of the oil when new; viscosity of the oil has changed by more than 20 percent from the viscosity of the oil when new; or percent water content (by volume) is greater than 0.5. If all of these condemning limits are not exceeded, the engine owner or operator is not required to change the oil. If any of the limits are exceeded, the engine owner or operator must change the oil within 2 business days of receiving the results of the analysis; if the engine is not in operation when the results of the analysis are received, the engine owner or operator must change the oil within 2 business days or before commencing operation, whichever is later. The owner or operator must keep records of the parameters that are analyzed as part of the program, the results of the analysis, and the oil changes for the engine. [Rule 19.304 and 40 C.F.R. § 63.6625(i)]
32. The permittee must, for SN-73A, be in compliance with the emission limitations, operating limitations, and other requirements in this subpart that apply to them at all times. [Rule 19.304 and 40 C.F.R. § 63.6605(a)]
33. The permittee must operate and maintain SN-73A, including associated air pollution control equipment and monitoring equipment, in a manner consistent with safety and good air pollution control practices for minimizing emissions. The general duty to minimize emissions does not require the permittee to make any further efforts to reduce emissions if levels required by this standard have been achieved. Determination of whether such operation and maintenance procedures are being used will be based on information available to the Department which may include, but is not limited to, monitoring results, review of operation and maintenance procedures, review of operation and maintenance records, and inspection of the source. [Rule 19.304 and 40 C.F.R. § 63.6605(b)]
34. The permittee must operate and maintain SN-73A according to the manufacturer's emission-related operation and maintenance instructions; or develop and follow your own maintenance plan which must provide to the extent practicable for the maintenance and operation of the engine in a manner consistent with good air pollution control practice or minimizing emissions. [Rule 19.304 and 40 C.F.R. § 6640(a)]
35. The permittee must report each instance in which you did not meet each emission limitation or operating limitation in Tables 1a and 1b, Tables 2a and 2b, Table 2c, and Table 2d to this subpart that apply to you for SN-73A. These instances are deviations from the emission and operating limitations in this subpart. These deviations must be reported according to the requirements in § 63.6650. If you change your catalyst, you

must reestablish the values of the operating parameters measured during the initial performance test. When you reestablish the values of your operating parameters, you must also conduct a performance test to demonstrate that you are meeting the required emission limitation applicable to your stationary RICE. [Rule 19.304 and 40 C.F.R. § 63.6640(b)]

36. The permittee must operate the SN-73A, SN-73B, and SN-73C according to the requirements in paragraphs (f)(1) through (4) of this section. In order for the engine to be considered an emergency stationary RICE under this subpart, any operation other than emergency operation, maintenance and testing, emergency demand response, and operation in non-emergency situations for 50 hours per year, as described in paragraphs (f)(1) through (4) of this section, is prohibited. If you do not operate the engine according to the requirements in paragraphs (f)(1) through (4) of this section, the engine will not be considered an emergency engine under this subpart and must meet all requirements for non-emergency engines.
- a. There is no time limit on the use of emergency stationary RICE in emergency situations.
  - b. You may operate your emergency stationary RICE for any combination of the purposes specified in paragraphs (b)(2)(i) through (iii) of this section for a maximum of 100 hours per calendar year. Any operation for non-emergency situations as allowed by paragraphs (f)(3) and (4) of this section counts as part of the 100 hours per calendar year allowed by this paragraph (f)(2).
    - i. Emergency stationary RICE may be operated for maintenance checks and readiness testing, provided that the tests are recommended by federal, state or local government, the manufacturer, the vendor, the regional transmission organization or equivalent balancing authority and transmission operator, or the insurance company associated with the engine. The owner or operator may petition the Administrator for approval of additional hours to be used for maintenance checks and readiness testing, but a petition is not required if the owner or operator maintains records indicating that federal, state, or local standards require maintenance and testing of emergency RICE beyond 100 hours per calendar year.
    - ii. Emergency stationary RICE may be operated for emergency demand response for periods in which the Reliability Coordinator under the North American Electric Reliability Corporation (NERC) Reliability Standard EOP-002-3, Capacity and Energy Emergencies (incorporated by reference, see §63.14), or other authorized entity as determined by the Reliability Coordinator, has declared an Energy Emergency Alert Level 2 as defined in the NERC Reliability Standard EOP-002-3.
    - iii. Emergency stationary RICE may be operated for periods where there is a deviation of voltage or frequency of 5 percent or greater below standard voltage or frequency.

- c. Emergency stationary RICE located at major sources of HAP may be operated for up to 50 hours per calendar year in non-emergency situations. The 50 hours of operation in non-emergency situations are counted as part of the 100 hours per calendar year for maintenance and testing and emergency demand response provided in paragraph (f)(2) of this section. The 50 hours per year for non-emergency situations cannot be used for peak shaving or non-emergency demand response, or to generate income for a facility to supply power to an electric grid or otherwise supply power as part of a financial arrangement with another entity.

[Rule 19.304 and 40 C.F.R. § 63.6640(f)]

- 37. If you must comply with the emission and operating limitations, you must keep the records described in paragraphs (a)(1) through (a)(5), (b)(1) through (b)(3) and (c) of this section.
  - a. A copy of each notification and report that you submitted to comply with this subpart, including all documentation supporting any Initial Notification or Notification of Compliance Status that you submitted, according to the requirement in §63.10(b)(2)(xiv).
  - b. Records of the occurrence and duration of each malfunction of operation (i.e., process equipment) or the air pollution control and monitoring equipment.
  - c. Records of performance tests and performance evaluations as required in §63.10(b)(2)(viii).
  - d. Records of actions taken during periods of malfunction to minimize emissions in accordance with §63.6605(b), including corrective actions to restore malfunctioning process and air pollution control and monitoring equipment to its normal or usual manner of operation.

[Rule 19.304 and 40 C.F.R. § 63.6655(a)]

- 38. The permittee must keep records of the maintenance conducted on the stationary RICE in order to demonstrate that you operated and maintained the stationary RICE and after-treatment control device (if any) according to your own maintenance plan. [Rule 19.304 and 40 C.F.R. § 63.6655(e)]
- 39. The permittee must keep records of the hours of operation of the engine that is recorded through the non-resettable hour meter. The owner or operator must document how many hours are spent for emergency operation, including what classified the operation as emergency and how many hours are spent for non-emergency operation. If the engine is used for the purposes specified in §63.6640(f)(2)(ii) or (iii) or §63.6640(f)(4)(ii), the owner or operator must keep records of the notification of the emergency situation, and the date, start time, and end time of engine operation for these purposes. [Rule 19.304 and 40 C.F.R. § 63.6655(f)]
- 40. If an emergency engine is operating during an emergency and it is not possible to shut down the engine in order to perform the work practice requirements on the schedule



required in Table 2c of this subpart, or if performing the work practice standard on the required schedule would otherwise pose an unacceptable risk under federal, state, or local law, the work practice can be delayed until the emergency is over or the unacceptable risk under federal state, or local law is abated. The work practice should be performed as soon as practicable after the emergency has ended or the unacceptable risk under federal, state, or local law has abated. Sources must report any failure to perform the work practice on the schedule required and the federal, state or local law under which the risk was deemed unacceptable. [Rule 19.304 and 40 C.F.R. § 63, Table 2c Footnote 1 to Subpart ZZZZ]

41. If you own or operate an emergency stationary RICE with a site rating of more than 100 brake HP that operates or is contractually obligated to be available for more than 15 hours per calendar year for the purposes specified in § 63.6640(f)(2)(ii) and (iii) or that operates for the purpose specified in § 63.6640(f)(4)(ii), you must submit an annual report according to the requirements in paragraphs (h)(1) through (3) of this section.
  - a. The report must contain the following information:
    - i. Company name and address where the engine is located.
    - ii. Date of the report and beginning and ending dates of the reporting period.
    - iii. Engine site rating and model year.
    - iv. Latitude and longitude of the engine in decimal degrees reported to the fifth decimal place.
    - v. Hours operated for the purposes specified in § 63.6640(f)(2)(ii) and (iii), including the date, start time, and end time for engine operation for the purposes specified in § 63.6640(f)(2)(ii) and (iii).
    - vi. Number of hours the engine is contractually obligated to be available for the purposes specified in § 63.6640(f)(2)(ii) and (iii).
    - vii. Hours spent for operation for the purpose specified in § 63.6640(f)(4)(ii), including the date, start time, and end time for engine operation for the purposes specified in § 63.6640(f)(4)(ii). The report must also identify the entity that dispatched the engine and the situation that necessitated the dispatch of the engine.
    - viii. If there were no deviations from the fuel requirements in § 63.6604 that apply to the engine (if any), a statement that there were no deviations from the fuel requirements during the reporting period.
    - ix. If there were deviations from the fuel requirements in § 63.6604 that apply to the engine (if any), information on the number, duration, and cause of deviations, and the corrective action taken.
  - b. The first annual report must cover the calendar year 2015 and must be submitted no later than March 31, 2016. Subsequent annual reports for each calendar year must be submitted no later than March 31 of the following calendar year.
  - c. The annual report must be submitted electronically using the subpart specific reporting form in the Compliance and Emissions Data Reporting Interface (CEDRI) that is accessed through EPA's Central Data Exchange (CDX) ([www.epa.gov/cdx](http://www.epa.gov/cdx)). However, if the reporting form specific to this subpart is not

Covia ISP, Inc. - Fort Smith Plant

Permit #: 0492-AOP-R15

AFIN: 66-00219

available in CEDRI at the time that the report is due, the written report must be submitted to the Administrator at the appropriate address listed in § 63.13.

SN-74  
Three (3) Parts Washers

Source Description

The facility uses three (3) parts washers at Plant #1 maintenance shop, Plant #2 maintenance shop and machine shop. Each unit is serviced every 60 days. Annual usage of solvent is 2000 gallons total. The parts washer solvent does not contain any HAP. The worst case emissions are assumed that parts washer is 100% VOC and all become air emissions.

Specific Conditions

42. The permittee shall not exceed the emission rates set forth in the following table. The permittee shall demonstrate compliance with this condition by Specific Condition 44. [Rule 19.501 *et seq.* and 40 C.F.R. § 52 Subpart E]

SN	Description	Pollutant	lb/hr	tpy
SN-74	Three Parts Washers	VOC	6.9	1.6

43. The permittee shall not use more than 2,000 gallons of solvent per year at SN-74. [Rule 19.705, Ark. Code Ann. § 8-4-203 as referenced by Ark. Code Ann. §§ 8-4-304 and 8-4-311, and 40 C.F.R. § 70.6]
44. The permittee shall maintain monthly records which demonstrate compliance with Specific Condition 43. Records shall be updated by the fifteenth day of the month following the month for which the records pertain. These records shall be kept on site, and shall be made available to Department personnel upon request. A copy of the results of these records shall be maintained onsite, and shall be made available to Department personnel upon request. [Rule 19.705 and 40 C.F.R. § 52 Subpart E]

Covia ISP, Inc. - Fort Smith Plant  
Permit #: 0492-AOP-R15  
AFIN: 66-00219

## **SECTION V: COMPLIANCE PLAN AND SCHEDULE**

Covia ISP, Inc. - Fort Smith Plant will continue to operate in compliance with those identified regulatory provisions. The facility will examine and analyze future rules and regulations that may apply and determine their applicability with any necessary action taken on a timely basis.

## SECTION VI: PLANTWIDE CONDITIONS

1. The permittee shall notify the Director in writing within thirty (30) days after commencing construction, completing construction, first placing the equipment and/or facility in operation, and reaching the equipment and/or facility target production rate. [Rule 19.704, 40 C.F.R. § 52 Subpart E, and Ark. Code Ann. § 8-4-203 as referenced by Ark. Code Ann. §§ 8-4-304 and 8-4-311]
2. If the permittee fails to start construction within eighteen months or suspends construction for eighteen months or more, the Director may cancel all or part of this permit. [Rule 19.410(B) and 40 C.F.R. § 52 Subpart E]
3. The permittee must test any equipment scheduled for testing, unless otherwise stated in the Specific Conditions of this permit or by any federally regulated requirements, within the following time frames: (1) new equipment or newly modified equipment within sixty (60) days of achieving the maximum production rate, but no later than 180 days after initial start up of the permitted source or (2) operating equipment according to the time frames set forth by the Division of Environmental Quality or within 180 days of permit issuance if no date is specified. The permittee must notify the Division of Environmental Quality of the scheduled date of compliance testing at least fifteen (15) business days in advance of such test. The permittee shall submit the compliance test results to the Division of Environmental Quality within sixty (60) calendar days after completing the testing. [Rule 19.702 and/or Rule 18.1002 and Ark. Code Ann. § 8-4-203 as referenced by Ark. Code Ann. §§ 8-4-304 and 8-4-311]
4. The permittee must provide:
  - a. Sampling ports adequate for applicable test methods;
  - b. Safe sampling platforms;
  - c. Safe access to sampling platforms; and
  - d. Utilities for sampling and testing equipment.

[Rule 19.702 and/or Rule 18.1002 and Ark. Code Ann. § 8-4-203 as referenced by Ark. Code Ann. §§ 8-4-304 and 8-4-311]
5. The permittee must operate the equipment, control apparatus and emission monitoring equipment within the design limitations. The permittee shall maintain the equipment in good condition at all times. [Rule 19.303 and Ark. Code Ann. § 8-4-203 as referenced by Ark. Code Ann. §§ 8-4-304 and 8-4-311]
6. This permit subsumes and incorporates all previously issued air permits for this facility. [Rule 26 and Ark. Code Ann. § 8-4-203 as referenced by Ark. Code Ann. §§ 8-4-304 and 8-4-311]

7. Unless otherwise specified in the permit, approval to construct any new major stationary source or a major modification subject to 40 C.F.R. § 52.21 shall become invalid if construction is not commenced within 18 months after receipt of such approval, if construction is discontinued for a period of 18 months or more, or if construction is not completed within a reasonable time. The Division of Environmental Quality may extend the 18-month period upon a satisfactory showing that an extension is justified. [Rule 19.901 *et seq.* and 40 C.F.R. § 52 Subpart E]
8. The operation of any SN-C source which is idled or shut down for an entire calendar week need only note the source had been idled and not make the visual inspection that week. Should certain SN-C sources be designated to part of an extended idled or shut down period, the Operator may alternatively choose to document this on a monthly basis. Such monthly documentation would include notations at the start of the month of specific SN-C's that are likely to not be operated for the month with follow-up notation at the end of the month indicating if the projected non-operational status of the SN-C was achieved.

The Operator of any SN source that has been idled or shut down for a day need only note the source has been idled and not make the visual inspection that specific day. Should the operator plan on keeping a specific SN source or group of SNs sources idled or shut down for an extended period of time, then the Operator may also choose to note the idled non-operating status of those SN(s) sources on a monthly basis as previously described.

Should applicable required performance testing of any SN-C or SN source coincide with the idle or shutdown of that source, then the source need not be tested within sixty (60) days of achieving the maximum production rate, but no later than 180 days after start-up of the source in accordance with Plantwide Condition **#Error! Reference source not found.** as well as continuing with any applicable repeat testing schedule. [Ark. Code Ann. § 8-4-203 as referenced by Ark. Code Ann. §§ 8-4-304 and 8-4-311]

#### Permit Shield

9. Compliance with the conditions of this permit shall be deemed compliance with all applicable requirements, as of the date of permit issuance, included in and specifically identified in the following table of this condition. The permit specifically identifies the following as applicable requirements based upon the information submitted by the permittee in an application dated March 13, 2025.

#### Applicable Regulations

Source No.	Regulation	Description
SN-73A, B, & C	NSPS Subpart ZZZZ	Due to installation dates (before 2006) after the Subpart IIII applicability dates (before June 12, 2006),

Covia ISP, Inc. - Fort Smith Plant  
 Permit #: 0492-AOP-R15  
 AFIN: 66-00219

Source No.	Regulation	Description
		these units are subject to this regulation.

The permit specifically identifies the following as inapplicable based upon information submitted by the permittee in an application dated March 13, 2025.

#### Inapplicable Regulations

Source No.	Regulation	Description
SN-23, 25, 28, 34, 46, 50, 51, 53, and 54	40 CFR Part 60 Subpart OOO	Due to the combined capacity of less than 25 tons per hour, the facility claims exemption from this subpart.

## SECTION VII: INSIGNIFICANT ACTIVITIES

The Division of Environmental Quality deems the following types of activities or emissions as insignificant on the basis of size, emission rate, production rate, or activity in accordance with Group A of the Insignificant Activities list found in Rule 18 and Rule 19 Appendix A. Group B insignificant activities may be listed but are not required to be listed in permits. Insignificant activity emission determinations rely upon the information submitted by the permittee in an application dated March 13, 2025. [Rule 26.304 and Ark. Code Ann. § 8-4-203 as referenced by Ark. Code Ann. §§ 8-4-304 and 8-4-311]

Description	Category
Plant 2 R & D Pilot Plant (0.65 MMBtu/hr) Combustion Emissions	A-1
Plant 1 R & D Pilot Plant (1.5 MMBtu/hr) Combustion Emissions	A-1
One (1) 115 gallon diesel storage tank	A-3
One (1) 30 gallon diesel storage tank	A-3
One (1) 102 gallon diesel storage tank	A-3
One (1) 1500 gallon diesel storage tank	A-3
Three Heat Exchangers	A-13
Two (2) 15,000 gallon diesel storage tanks	A-13
Two (2) line #3 feed vessel filters	A-13
Material Bin Vent (BV-1102)	A-13
Bin Vent for BN-18 (BV-1218)	A-13
Bin Vent for Hopper HO-1513 (BV-1514)	A-13
Bin Vent for bulk bagging hopper and loadout spout (BV-2702)	A-13
Particulate emissions from a pilot plant kiln	A-13
Chopping mill, mixer, grinding mill with classifier and screening units A&B at pilot plant	A-13
Plant 1 R & D Pilot Plant Kiln & Baghouse Process Emissions	A-13
Plant 1 R & D Pilot Plant Material Handling Baghouse	A-13
Plant 2 R & D Grinding Mill #2 with Classifier (Cyclone/DC)	A-13
Welding Booth	A-13



## SECTION VIII: GENERAL PROVISIONS

1. Any terms or conditions included in this permit which specify and reference Arkansas Pollution Control & Ecology Commission Rule 18 or the Arkansas Water and Air Pollution Control Act (Ark. Code Ann. § 8-4-101 *et seq.*) as the sole origin of and authority for the terms or conditions are not required under the Clean Air Act or any of its applicable requirements, and are not federally enforceable under the Clean Air Act. Arkansas Pollution Control & Ecology Commission Rule 18 was adopted pursuant to the Arkansas Water and Air Pollution Control Act (Ark. Code Ann. § 8-4-101 *et seq.*). Any terms or conditions included in this permit which specify and reference Arkansas Pollution Control & Ecology Commission Rule 18 or the Arkansas Water and Air Pollution Control Act (Ark. Code Ann. § 8-4-101 *et seq.*) as the origin of and authority for the terms or conditions are enforceable under this Arkansas statute. [40 C.F.R. § 70.6(b)(2)]
2. This permit shall be valid for a period of five (5) years beginning on the date this permit becomes effective and ending five (5) years later. [40 C.F.R. § 70.6(a)(2) and Rule 26.701(B)]
3. The permittee must submit a complete application for permit renewal at least six (6) months before permit expiration. Permit expiration terminates the permittee's right to operate unless the permittee submitted a complete renewal application at least six (6) months before permit expiration. If the permittee submits a complete application, the existing permit will remain in effect until the Division of Environmental Quality takes final action on the renewal application. The Division of Environmental Quality will not necessarily notify the permittee when the permit renewal application is due. [Rule 26.406]
4. Where an applicable requirement of the Clean Air Act, as amended, 42 U.S.C. 7401, *et seq.* (Act) is more stringent than an applicable requirement of regulations promulgated under Title IV of the Act, the permit incorporates both provisions into the permit, and the Director or the Administrator can enforce both provisions. [40 C.F.R. § 70.6(a)(1)(ii) and Rule 26.701(A)(2)]
5. The permittee must maintain the following records of monitoring information as required by this permit.
  - a. The date, place as defined in this permit, and time of sampling or measurements;
  - b. The date(s) analyses performed;
  - c. The company or entity performing the analyses;
  - d. The analytical techniques or methods used;
  - e. The results of such analyses; and
  - f. The operating conditions existing at the time of sampling or measurement.

[40 C.F.R. § 70.6(a)(3)(ii)(A) and Rule 26.701(C)(2)]

6. The permittee must retain the records of all required monitoring data and support information for at least five (5) years from the date of the monitoring sample, measurement, report, or application. Support information includes all calibration and maintenance records and all original strip chart recordings for continuous monitoring instrumentation, and copies of all reports required by this permit. [40 C.F.R. § 70.6(a)(3)(ii)(B) and Rule 26.701(C)(2)(b)]
7. The permittee must submit reports of all required monitoring every six (6) months. If the permit establishes no other reporting period, the reporting period shall end on the last day of the month six months after the issuance of the initial Title V permit and every six months thereafter. The report is due on the first day of the second month after the end of the reporting period. The first report due after issuance of the initial Title V permit shall contain six months of data and each report thereafter shall contain 12 months of data. The report shall contain data for all monitoring requirements in effect during the reporting period. If a monitoring requirement is not in effect for the entire reporting period, only those months of data in which the monitoring requirement was in effect are required to be reported. The report must clearly identify all instances of deviations from permit requirements. A responsible official as defined in Rule 26.2 must certify all required reports. The permittee will send the reports electronically using <https://portal.adeq.state.ar.us> or mail them to the address below:

Division of Environmental Quality  
Office of Air Quality  
ATTN: Compliance Inspector Supervisor  
5301 Northshore Drive  
North Little Rock, AR 72118-5317

[40 C.F.R. § 70.6(a)(3)(iii)(A) and Rule 26.701(C)(3)(a)]

8. The permittee shall report to the Division of Environmental Quality all deviations from permit requirements, including those attributable to upset conditions as defined in the permit.
  - a. For all upset conditions (as defined in Rule 19.601), the permittee will make an initial report to the Division of Environmental Quality by the next business day after the discovery of the occurrence. The initial report may be made by telephone and shall include:
    - i. The facility name and location;
    - ii. The process unit or emission source deviating from the permit limit;
    - iii. The permit limit, including the identification of pollutants, from which deviation occurs;
    - iv. The date and time the deviation started;
    - v. The duration of the deviation;

- vi. The emissions during the deviation;
- vii. The probable cause of such deviations;
- viii. Any corrective actions or preventive measures taken or being taken to prevent such deviations in the future; and
- ix. The name of the person submitting the report.

The permittee shall make a full report in writing to the Division of Environmental Quality within five (5) business days of discovery of the occurrence. The report must include, in addition to the information required by the initial report, a schedule of actions taken or planned to eliminate future occurrences and/or to minimize the amount the permit's limits were exceeded and to reduce the length of time the limits were exceeded. The permittee may submit a full report in writing (by facsimile, overnight courier, or other means) by the next business day after discovery of the occurrence, and the report will serve as both the initial report and full report.

- b. For all deviations, the permittee shall report such events in semi-annual reporting and annual certifications required in this permit. This includes all upset conditions reported in 8a above. The semi-annual report must include all the information as required by the initial and full reports required in 8a.

[Rule 19.601, Rule 19.602, Rule 26.701(C)(3)(b), and 40 C.F.R. § 70.6(a)(3)(iii)(B)]

- 9. If any provision of the permit or the application thereof to any person or circumstance is held invalid, such invalidity will not affect other provisions or applications hereof which can be given effect without the invalid provision or application, and to this end, provisions of this Rule are declared to be separable and severable. [40 C.F.R. § 70.6(a)(5), Rule 26.701(E), and Ark. Code Ann. § 8-4-203 as referenced by Ark. Code Ann. §§ 8-4-304 and 8-4-311]
- 10. The permittee must comply with all conditions of this Part 70 permit. Any permit noncompliance with applicable requirements as defined in Rule 26 constitutes a violation of the Clean Air Act, as amended, 42 U.S.C. § 7401, *et seq.* and is grounds for enforcement action; for permit termination, revocation and reissuance, for permit modification; or for denial of a permit renewal application. [40 C.F.R. § 70.6(a)(6)(i) and Rule 26.701(F)(1)]
- 11. It shall not be a defense for a permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity to maintain compliance with the conditions of this permit. [40 C.F.R. § 70.6(a)(6)(ii) and Rule 26.701(F)(2)]
- 12. The Division of Environmental Quality may modify, revoke, reopen and reissue the permit or terminate the permit for cause. The filing of a request by the permittee for a permit modification, revocation and reissuance, termination, or of a notification of planned changes or anticipated noncompliance does not stay any permit condition. [40 C.F.R. § 70.6(a)(6)(iii) and Rule 26.701(F)(3)]

13. This permit does not convey any property rights of any sort, or any exclusive privilege. [40 C.F.R. § 70.6(a)(6)(iv) and Rule 26.701(F)(4)]
14. The permittee must furnish to the Director, within the time specified by the Director, any information that the Director may request in writing to determine whether cause exists for modifying, revoking and reissuing, or terminating the permit or to determine compliance with the permit. Upon request, the permittee must also furnish to the Director copies of records required by the permit. For information the permittee claims confidentiality, the Division of Environmental Quality may require the permittee to furnish such records directly to the Director along with a claim of confidentiality. [40 C.F.R. § 70.6(a)(6)(v) and Rule 26.701(F)(5)]
15. The permittee must pay all permit fees in accordance with the procedures established in Rule 9. [40 C.F.R. § 70.6(a)(7) and Rule 26.701(G)]
16. No permit revision shall be required, under any approved economic incentives, marketable permits, emissions trading and other similar programs or processes for changes provided for elsewhere in this permit. [40 C.F.R. § 70.6(a)(8) and Rule 26.701(H)]
17. If the permit allows different operating scenarios, the permittee shall, contemporaneously with making a change from one operating scenario to another, record in a log at the permitted facility a record of the operational scenario. [40 C.F.R. § 70.6(a)(9)(i) and Rule 26.701(I)(1)]
18. The Administrator and citizens may enforce under the Act all terms and conditions in this permit, including any provisions designed to limit a source's potential to emit, unless the Division of Environmental Quality specifically designates terms and conditions of the permit as being federally unenforceable under the Act or under any of its applicable requirements. [40 C.F.R. § 70.6(b) and Rule 26.702(A) and (B)]
19. Any document (including reports) required by this permit pursuant to 40 C.F.R. § 70 must contain a certification by a responsible official as defined in Rule 26.2. [40 C.F.R. § 70.6(c)(1) and Rule 26.703(A)]
20. The permittee must allow an authorized representative of the Division of Environmental Quality, upon presentation of credentials, to perform the following: [40 C.F.R. § 70.6(c)(2) and Rule 26.703(B)]
  - a. Enter upon the permittee's premises where the permitted source is located or emissions related activity is conducted, or where records must be kept under the conditions of this permit;
  - b. Have access to and copy, at reasonable times, any records required under the conditions of this permit;

- c. Inspect at reasonable times any facilities, equipment (including monitoring and air pollution control equipment), practices, or operations regulated or required under this permit; and
  - d. As authorized by the Act, sample or monitor at reasonable times substances or parameters for assuring compliance with this permit or applicable requirements.
- 21. The permittee shall submit a compliance certification with the terms and conditions contained in the permit, including emission limitations, standards, or work practices. The permittee must submit the compliance certification annually. If the permit establishes no other reporting period, the reporting period shall end on the last day of the anniversary month of the initial Title V permit. The report is due on the first day of the second month after the end of the reporting period. The permittee must also submit the compliance certification to the Administrator as well as to the Division of Environmental Quality. All compliance certifications required by this permit must include the following: [40 C.F.R. § 70.6(c)(5) and Rule 26.703(E)(3)]
  - a. The identification of each term or condition of the permit that is the basis of the certification;
  - b. The compliance status;
  - c. Whether compliance was continuous or intermittent;
  - d. The method(s) used for determining the compliance status of the source, currently and over the reporting period established by the monitoring requirements of this permit; and
  - e. Such other facts as the Division of Environmental Quality may require elsewhere in this permit or by § 114(a)(3) and § 504(b) of the Act.
- 22. Nothing in this permit will alter or affect the following: [Rule 26.704(C)]
  - a. The provisions of Section 303 of the Act (emergency orders), including the authority of the Administrator under that section;
  - b. The liability of the permittee for any violation of applicable requirements prior to or at the time of permit issuance;
  - c. The applicable requirements of the acid rain program, consistent with § 408(a) of the Act; or
  - d. The ability of EPA to obtain information from a source pursuant to § 114 of the Act.
- 23. This permit authorizes only those pollutant emitting activities addressed in this permit. [Ark. Code Ann. § 8-4-203 as referenced by Ark. Code Ann. §§ 8-4-304 and 8-4-311]

24. The permittee may request in writing and at least 15 days in advance of the deadline, an extension to any testing, compliance or other dates in this permit. No such extensions are authorized until the permittee receives written Division of Environmental Quality approval. The Division of Environmental Quality may grant such a request, at its discretion in the following circumstances:

- a. Such an extension does not violate a federal requirement;
- b. The permittee demonstrates the need for the extension; and
- c. The permittee documents that all reasonable measures have been taken to meet the current deadline and documents reasons it cannot be met.

[Rule 18.314(A), Rule 19.416(A), Rule 26.1013(A), Ark. Code Ann. § 8-4-203 as referenced by Ark. Code Ann. §§ 8-4-304 and 8-4-311, and 40 C.F.R. § 52 Subpart E]

25. The permittee may request in writing and at least 30 days in advance, temporary emissions and/or testing that would otherwise exceed an emission rate, throughput requirement, or other limit in this permit. No such activities are authorized until the permittee receives written Division of Environmental Quality approval. Any such emissions shall be included in the facility's total emissions and reported as such. The Division of Environmental Quality may grant such a request, at its discretion under the following conditions:

- a. Such a request does not violate a federal requirement;
- b. Such a request is temporary in nature;
- c. Such a request will not result in a condition of air pollution;
- d. The request contains such information necessary for the Division of Environmental Quality to evaluate the request, including but not limited to, quantification of such emissions and the date/time such emission will occur;
- e. Such a request will result in increased emissions less than five tons of any individual criteria pollutant, one ton of any single HAP and 2.5 tons of total HAPs; and
- f. The permittee maintains records of the dates and results of such temporary emissions/testing.

[Rule 18.314(B), Rule 19.416(B), Rule 26.1013(B), Ark. Code Ann. § 8-4-203 as referenced by Ark. Code Ann. §§ 8-4-304 and 8-4-311, and 40 C.F.R. § 52 Subpart E]

26. The permittee may request in writing and at least 30 days in advance, an alternative to the specified monitoring in this permit. No such alternatives are authorized until the permittee receives written Division of Environmental Quality approval. The Division of Environmental Quality may grant such a request, at its discretion under the following conditions:

- a. The request does not violate a federal requirement;

Covia ISP, Inc. - Fort Smith Plant  
Permit #: 0492-AOP-R15  
AFIN: 66-00219

- b. The request provides an equivalent or greater degree of actual monitoring to the current requirements; and
- c. Any such request, if approved, is incorporated in the next permit modification application by the permittee.

[Rule 18.314(C), Rule 19.416(C), Rule 26.1013(C), Ark. Code Ann. § 8-4-203 as referenced by Ark. Code Ann. §§ 8-4-304 and 8-4-311, and 40 C.F.R. § 52 Subpart E]

- 27. Any credible evidence based on sampling, monitoring, and reporting may be used to determine violations of applicable emission limitations. [Rule 18.1001, Rule 19.701, Ark. Code Ann. § 8-4-203 as referenced by Ark. Code Ann. §§ 8-4-304 and 8-4-311, and 40 C.F.R. § 52 Subpart E]

## Appendix A

40 CFR Part 63 Subpart ZZZZ — *National Emissions Standards for Hazardous Air Pollutants  
for Stationary Reciprocating Internal Combustion Engines*



---

This content is from the eCFR and is authoritative but unofficial.

---

## Title 40 —Protection of Environment

### Chapter I —Environmental Protection Agency

#### Subchapter C —Air Programs

#### Part 63 —National Emission Standards for Hazardous Air Pollutants for Source Categories

**Authority:** 42 U.S.C. 7401 *et seq.*

**Source:** 57 FR 61992, Dec. 29, 1992, unless otherwise noted.

#### Subpart ZZZZ National Emissions Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines

##### What This Subpart Covers

§ 63.6580 What is the purpose of subpart ZZZZ?

§ 63.6585 Am I subject to this subpart?

§ 63.6590 What parts of my plant does this subpart cover?

§ 63.6595 When do I have to comply with this subpart?

##### Emission and Operating Limitations

§ 63.6600 What emission limitations and operating limitations must I meet if I own or operate a stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions?

§ 63.6601 What emission limitations must I meet if I own or operate a new or reconstructed 4SLB stationary RICE with a site rating of greater than or equal to 250 brake HP and less than or equal to 500 brake HP located at a major source of HAP emissions?

§ 63.6602 What emission limitations and other requirements must I meet if I own or operate an existing stationary RICE with a site rating of equal to or less than 500 brake HP located at a major source of HAP emissions?

§ 63.6603 What emission limitations, operating limitations, and other requirements must I meet if I own or operate an existing stationary RICE located at an area source of HAP emissions?

§ 63.6604 What fuel requirements must I meet if I own or operate a stationary CI RICE?

##### General Compliance Requirements

§ 63.6605 What are my general requirements for complying with this subpart?

##### Testing and Initial Compliance Requirements

§ 63.6610 By what date must I conduct the initial performance tests or other initial compliance demonstrations if I own or operate a stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions?

§ 63.6611 By what date must I conduct the initial performance tests or other initial compliance demonstrations if I own or operate a new or reconstructed 4SLB SI stationary RICE with a site rating of greater than or equal to 250 and less than or equal to 500 brake HP located at a major source of HAP emissions?

**§ 63.6612** By what date must I conduct the initial performance tests or other initial compliance demonstrations if I own or operate an existing stationary RICE with a site rating of less than or equal to 500 brake HP located at a major source of HAP emissions or an existing stationary RICE located at an area source of HAP emissions?

**§ 63.6615** When must I conduct subsequent performance tests?

**§ 63.6620** What performance tests and other procedures must I use?

**§ 63.6625** What are my monitoring, installation, collection, operation, and maintenance requirements?

**§ 63.6630** How do I demonstrate initial compliance with the emission limitations, operating limitations, and other requirements?

#### Continuous Compliance Requirements

**§ 63.6635** How do I monitor and collect data to demonstrate continuous compliance?

**§ 63.6640** How do I demonstrate continuous compliance with the emission limitations, operating limitations, and other requirements?

#### Notifications, Reports, and Records

**§ 63.6645** What notifications must I submit and when?

**§ 63.6650** What reports must I submit and when?

**§ 63.6655** What records must I keep?

**§ 63.6660** In what form and how long must I keep my records?

#### Other Requirements and Information

**§ 63.6665** What parts of the General Provisions apply to me?

**§ 63.6670** Who implements and enforces this subpart?

**§ 63.6675** What definitions apply to this subpart?

#### Table 1a to Subpart ZZZZ of Part 63

Emission Limitations for Existing, New, and Reconstructed  
Spark Ignition, 4SRB Stationary RICE >500 HP Located at a  
Major Source of HAP Emissions

#### Table 1b to Subpart ZZZZ of Part 63

Operating Limitations for Existing, New, and Reconstructed SI  
4SRB Stationary RICE >500 HP Located at a Major Source of  
HAP Emissions

#### Table 2a to Subpart ZZZZ of Part 63

Emission Limitations for New and Reconstructed 2SLB and  
Compression Ignition Stationary RICE >500 HP and New and  
Reconstructed 4SLB Stationary RICE  $\geq$ 250 HP Located at a  
Major Source of HAP Emissions

#### Table 2b to Subpart ZZZZ of Part 63

Operating Limitations for New and Reconstructed 2SLB and CI

Stationary RICE >500 HP Located at a Major Source of HAP  
Emissions, New and Reconstructed 4SLB Stationary RICE  $\geq$ 250  
HP Located at a Major Source of HAP Emissions, Existing CI  
Stationary RICE >500 HP

**Table 2c to Subpart ZZZZ of Part 63**

Requirements for Existing Compression Ignition Stationary  
RICE Located at a Major Source of HAP Emissions and Existing  
Spark Ignition Stationary RICE  $\leq$ 500 HP Located at a Major  
Source of HAP Emissions

**Table 2d to Subpart ZZZZ of Part 63**

Requirements for Existing Stationary RICE Located at Area  
Sources of HAP Emissions

**Table 3 to Subpart ZZZZ of Part 63**

Subsequent Performance Tests

**Table 4 to Subpart ZZZZ of Part 63**

Requirements for Performance Tests

**Table 5 to Subpart ZZZZ of Part 63**

Initial Compliance With Emission Limitations, Operating  
Limitations, and Other Requirements

**Table 6 to Subpart ZZZZ of Part 63**

Continuous Compliance With Emission Limitations, and Other  
Requirements

**Table 7 to Subpart ZZZZ of Part 63**

Requirements for Reports

**Table 8 to Subpart ZZZZ of Part 63**

Applicability of General Provisions to Subpart ZZZZ

**Appendix A to Subpart ZZZZ of Part 63**

Protocol for Using an Electrochemical Analyzer to Determine  
Oxygen and Carbon Monoxide Concentrations From Certain  
Engines

**Subpart ZZZZ—National Emissions Standards for Hazardous Air Pollutants for Stationary  
Reciprocating Internal Combustion Engines**

**Source:** 69 FR 33506, June 15, 2004, unless otherwise noted.

WHAT THIS SUBPART COVERS

## § 63.6580 What is the purpose of subpart ZZZZ?

Subpart ZZZZ establishes national emission limitations and operating limitations for hazardous air pollutants (HAP) emitted from stationary reciprocating internal combustion engines (RICE) located at major and area sources of HAP emissions. This subpart also establishes requirements to demonstrate initial and continuous compliance with the emission limitations and operating limitations.

[73 FR 3603, Jan. 18, 2008]

## § 63.6585 Am I subject to this subpart?

You are subject to this subpart if you own or operate a stationary RICE at a major or area source of HAP emissions, except if the stationary RICE is being tested at a stationary RICE test cell/stand.

- (a) A stationary RICE is any internal combustion engine which uses reciprocating motion to convert heat energy into mechanical work and which is not mobile. Stationary RICE differ from mobile RICE in that a stationary RICE is not a non-road engine as defined at 40 CFR 1068.30, and is not used to propel a motor vehicle or a vehicle used solely for competition.
- (b) A major source of HAP emissions is a plant site that emits or has the potential to emit any single HAP at a rate of 10 tons (9.07 megagrams) or more per year or any combination of HAP at a rate of 25 tons (22.68 megagrams) or more per year, except that for oil and gas production facilities, a major source of HAP emissions is determined for each surface site.
- (c) An area source of HAP emissions is a source that is not a major source.
- (d) If you are an owner or operator of an area source subject to this subpart, your status as an entity subject to a standard or other requirements under this subpart does not subject you to the obligation to obtain a permit under 40 CFR part 70 or 71, provided you are not required to obtain a permit under 40 CFR 70.3(a) or 40 CFR 71.3(a) for a reason other than your status as an area source under this subpart. Notwithstanding the previous sentence, you must continue to comply with the provisions of this subpart as applicable.
- (e) If you are an owner or operator of a stationary RICE used for national security purposes, you may be eligible to request an exemption from the requirements of this subpart as described in 40 CFR part 1068, subpart C.
- (f) The emergency stationary RICE listed in paragraphs (f)(1) through (3) of this section are not subject to this subpart. The stationary RICE must meet the definition of an emergency stationary RICE in § 63.6675, which includes operating according to the provisions specified in § 63.6640(f).
  - (1) Existing residential emergency stationary RICE located at an area source of HAP emissions that do not operate for the purpose specified in § 63.6640(f)(4)(ii).
  - (2) Existing commercial emergency stationary RICE located at an area source of HAP emissions that do not operate for the purpose specified in § 63.6640(f)(4)(ii).
  - (3) Existing institutional emergency stationary RICE located at an area source of HAP emissions that do not operate for the purpose specified in § 63.6640(f)(4)(ii).

[69 FR 33506, June 15, 2004, as amended at 73 FR 3603, Jan. 18, 2008; 78 FR 6700, Jan. 30, 2013; 87 FR 48607, Aug. 10, 2022]

## § 63.6590 What parts of my plant does this subpart cover?

This subpart applies to each affected source.

- (a) **Affected source.** An affected source is any existing, new, or reconstructed stationary RICE located at a major or area source of HAP emissions, excluding stationary RICE being tested at a stationary RICE test cell/stand.

- (1) **Existing stationary RICE.**

- (i) For stationary RICE with a site rating of more than 500 brake horsepower (HP) located at a major source of HAP emissions, a stationary RICE is existing if you commenced construction or reconstruction of the stationary RICE before December 19, 2002.
- (ii) For stationary RICE with a site rating of less than or equal to 500 brake HP located at a major source of HAP emissions, a stationary RICE is existing if you commenced construction or reconstruction of the stationary RICE before June 12, 2006.
- (iii) For stationary RICE located at an area source of HAP emissions, a stationary RICE is existing if you commenced construction or reconstruction of the stationary RICE before June 12, 2006.
- (iv) A change in ownership of an existing stationary RICE does not make that stationary RICE a new or reconstructed stationary RICE.

- (2) **New stationary RICE.**

- (i) A stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions is new if you commenced construction of the stationary RICE on or after December 19, 2002.
- (ii) A stationary RICE with a site rating of equal to or less than 500 brake HP located at a major source of HAP emissions is new if you commenced construction of the stationary RICE on or after June 12, 2006.
- (iii) A stationary RICE located at an area source of HAP emissions is new if you commenced construction of the stationary RICE on or after June 12, 2006.

- (3) **Reconstructed stationary RICE.**

- (i) A stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions is reconstructed if you meet the definition of reconstruction in § 63.2 and reconstruction is commenced on or after December 19, 2002.
- (ii) A stationary RICE with a site rating of equal to or less than 500 brake HP located at a major source of HAP emissions is reconstructed if you meet the definition of reconstruction in § 63.2 and reconstruction is commenced on or after June 12, 2006.
- (iii) A stationary RICE located at an area source of HAP emissions is reconstructed if you meet the definition of reconstruction in § 63.2 and reconstruction is commenced on or after June 12, 2006.

- (b) **Stationary RICE subject to limited requirements.**

- (1) An affected source which meets either of the criteria in paragraphs (b)(1)(i) through (ii) of this section does not have to meet the requirements of this subpart and of subpart A of this part except for the initial notification requirements of § 63.6645(f).
  - (i) The stationary RICE is a new or reconstructed emergency stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions.
  - (ii) The stationary RICE is a new or reconstructed limited use stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions.
- (2) A new or reconstructed stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions which combusts landfill or digester gas equivalent to 10 percent or more of the gross heat input on an annual basis must meet the initial notification requirements of § 63.6645(f) and the requirements of §§ 63.6625(c), 63.6650(g), and 63.6655(c). These stationary RICE do not have to meet the emission limitations and operating limitations of this subpart.
- (3) The following stationary RICE do not have to meet the requirements of this subpart and of subpart A of this part, including initial notification requirements:
  - (i) Existing spark ignition 2 stroke lean burn (2SLB) stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions;
  - (ii) Existing spark ignition 4 stroke lean burn (4SLB) stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions;
  - (iii) Existing emergency stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions.
  - (iv) Existing limited use stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions;
  - (v) Existing stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions that combusts landfill gas or digester gas equivalent to 10 percent or more of the gross heat input on an annual basis;
- (c) **Stationary RICE subject to Regulations under 40 CFR Part 60.** An affected source that meets any of the criteria in paragraphs (c)(1) through (7) of this section must meet the requirements of this part by meeting the requirements of 40 CFR part 60 subpart IIII, for compression ignition engines or 40 CFR part 60 subpart JJJJ, for spark ignition engines. No further requirements apply for such engines under this part.
  - (1) A new or reconstructed stationary RICE located at an area source;
  - (2) A new or reconstructed 2SLB stationary RICE with a site rating of less than or equal to 500 brake HP located at a major source of HAP emissions;
  - (3) A new or reconstructed 4SLB stationary RICE with a site rating of less than 250 brake HP located at a major source of HAP emissions;
  - (4) A new or reconstructed spark ignition 4 stroke rich burn (4SRB) stationary RICE with a site rating of less than or equal to 500 brake HP located at a major source of HAP emissions;
  - (5) A new or reconstructed stationary RICE with a site rating of less than or equal to 500 brake HP located at a major source of HAP emissions which combusts landfill or digester gas equivalent to 10 percent or more of the gross heat input on an annual basis;

- (6) A new or reconstructed emergency or limited use stationary RICE with a site rating of less than or equal to 500 brake HP located at a major source of HAP emissions;
- (7) A new or reconstructed compression ignition (CI) stationary RICE with a site rating of less than or equal to 500 brake HP located at a major source of HAP emissions.

[69 FR 33506, June 15, 2004, as amended at 73 FR 3604, Jan. 18, 2008; 75 FR 9674, Mar. 3, 2010; 75 FR 37733, June 30, 2010; 75 FR 51588, Aug. 20, 2010; 78 FR 6700, Jan. 30, 2013; 87 FR 48607, Aug. 10, 2022]

## § 63.6595 When do I have to comply with this subpart?

### (a) Affected sources.

- (1) If you have an existing stationary RICE, excluding existing non-emergency CI stationary RICE, with a site rating of more than 500 brake HP located at a major source of HAP emissions, you must comply with the applicable emission limitations, operating limitations and other requirements no later than June 15, 2007. If you have an existing non-emergency CI stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions, an existing stationary CI RICE with a site rating of less than or equal to 500 brake HP located at a major source of HAP emissions, or an existing stationary CI RICE located at an area source of HAP emissions, you must comply with the applicable emission limitations, operating limitations, and other requirements no later than May 3, 2013. If you have an existing stationary SI RICE with a site rating of less than or equal to 500 brake HP located at a major source of HAP emissions, or an existing stationary SI RICE located at an area source of HAP emissions, you must comply with the applicable emission limitations, operating limitations, and other requirements no later than October 19, 2013.
- (2) If you start up your new or reconstructed stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions before August 16, 2004, you must comply with the applicable emission limitations and operating limitations in this subpart no later than August 16, 2004.
- (3) If you start up your new or reconstructed stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions after August 16, 2004, you must comply with the applicable emission limitations and operating limitations in this subpart upon startup of your affected source.
- (4) If you start up your new or reconstructed stationary RICE with a site rating of less than or equal to 500 brake HP located at a major source of HAP emissions before January 18, 2008, you must comply with the applicable emission limitations and operating limitations in this subpart no later than January 18, 2008.
- (5) If you start up your new or reconstructed stationary RICE with a site rating of less than or equal to 500 brake HP located at a major source of HAP emissions after January 18, 2008, you must comply with the applicable emission limitations and operating limitations in this subpart upon startup of your affected source.
- (6) If you start up your new or reconstructed stationary RICE located at an area source of HAP emissions before January 18, 2008, you must comply with the applicable emission limitations and operating limitations in this subpart no later than January 18, 2008.

- (7) If you start up your new or reconstructed stationary RICE located at an area source of HAP emissions after January 18, 2008, you must comply with the applicable emission limitations and operating limitations in this subpart upon startup of your affected source.
- (b) **Area sources that become major sources.** If you have an area source that increases its emissions or its potential to emit such that it becomes a major source of HAP, the compliance dates in paragraphs (b)(1) and (2) of this section apply to you.
  - (1) Any stationary RICE for which construction or reconstruction is commenced after the date when your area source becomes a major source of HAP must be in compliance with this subpart upon startup of your affected source.
  - (2) Any stationary RICE for which construction or reconstruction is commenced before your area source becomes a major source of HAP must be in compliance with the provisions of this subpart that are applicable to RICE located at major sources within 3 years after your area source becomes a major source of HAP.
- (c) If you own or operate an affected source, you must meet the applicable notification requirements in § 63.6645 and in 40 CFR part 63, subpart A.

[69 FR 33506, June 15, 2004, as amended at 73 FR 3604, Jan. 18, 2008; 75 FR 9675, Mar. 3, 2010; 75 FR 51589, Aug. 20, 2010; 78 FR 6701, Jan. 30, 2013]

#### EMISSION AND OPERATING LIMITATIONS

### **§ 63.6600 What emission limitations and operating limitations must I meet if I own or operate a stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions?**

Compliance with the numerical emission limitations established in this subpart is based on the results of testing the average of three 1-hour runs using the testing requirements and procedures in § 63.6620 and Table 4 to this subpart.

- (a) If you own or operate an existing, new, or reconstructed spark ignition 4SRB stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions, you must comply with the emission limitations in Table 1a to this subpart and the operating limitations in Table 1b to this subpart which apply to you.
- (b) If you own or operate a new or reconstructed 2SLB stationary RICE with a site rating of more than 500 brake HP located at major source of HAP emissions, a new or reconstructed 4SLB stationary RICE with a site rating of more than 500 brake HP located at major source of HAP emissions, or a new or reconstructed CI stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions, you must comply with the emission limitations in Table 2a to this subpart and the operating limitations in Table 2b to this subpart which apply to you.
- (c) If you own or operate any of the following stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions, you do not need to comply with the emission limitations in Tables 1a, 2a, 2c, and 2d to this subpart or operating limitations in Tables 1b and 2b to this subpart: an



existing 2SLB stationary RICE; an existing 4SLB stationary RICE; a stationary RICE that combusts landfill gas or digester gas equivalent to 10 percent or more of the gross heat input on an annual basis; an emergency stationary RICE; or a limited use stationary RICE.

- (d) If you own or operate an existing non-emergency stationary CI RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions, you must comply with the emission limitations in Table 2c to this subpart and the operating limitations in Table 2b to this subpart which apply to you.

[73 FR 3605, Jan. 18, 2008, as amended at 75 FR 9675, Mar. 3, 2010]

**§ 63.6601 What emission limitations must I meet if I own or operate a new or reconstructed 4SLB stationary RICE with a site rating of greater than or equal to 250 brake HP and less than or equal to 500 brake HP located at a major source of HAP emissions?**

Compliance with the numerical emission limitations established in this subpart is based on the results of testing the average of three 1-hour runs using the testing requirements and procedures in § 63.6620 and Table 4 to this subpart. If you own or operate a new or reconstructed 4SLB stationary RICE with a site rating of greater than or equal to 250 and less than or equal to 500 brake HP located at major source of HAP emissions manufactured on or after January 1, 2008, you must comply with the emission limitations in Table 2a to this subpart and the operating limitations in Table 2b to this subpart which apply to you.

[73 FR 3605, Jan. 18, 2008, as amended at 75 FR 9675, Mar. 3, 2010; 75 FR 51589, Aug. 20, 2010]

**§ 63.6602 What emission limitations and other requirements must I meet if I own or operate an existing stationary RICE with a site rating of equal to or less than 500 brake HP located at a major source of HAP emissions?**

If you own or operate an existing stationary RICE with a site rating of equal to or less than 500 brake HP located at a major source of HAP emissions, you must comply with the emission limitations and other requirements in Table 2c to this subpart which apply to you. Compliance with the numerical emission limitations established in this subpart is based on the results of testing the average of three 1-hour runs using the testing requirements and procedures in § 63.6620 and Table 4 to this subpart.

[78 FR 6701, Jan. 30, 2013]

**§ 63.6603 What emission limitations, operating limitations, and other requirements must I meet if I own or operate an existing stationary RICE located at an area source of HAP emissions?**

Compliance with the numerical emission limitations established in this subpart is based on the results of testing the average of three 1-hour runs using the testing requirements and procedures in § 63.6620 and Table 4 to this subpart.

- (a) If you own or operate an existing stationary RICE located at an area source of HAP emissions, you must comply with the requirements in Table 2d to this subpart and the operating limitations in Table 2b to this subpart that apply to you.
- (b) If you own or operate an existing stationary non-emergency CI RICE with a site rating of more than 300 HP located at an area source of HAP that meets either paragraph (b)(1) or (2) of this section, you do not have to meet the numerical CO emission limitations specified in Table 2d of this subpart. Existing stationary

non-emergency CI RICE with a site rating of more than 300 HP located at an area source of HAP that meet either paragraph (b)(1) or (2) of this section must meet the management practices that are shown for stationary non-emergency CI RICE with a site rating of less than or equal to 300 HP in Table 2d of this subpart.

- (1) The area source is located in an area of Alaska that is not accessible by the Federal Aid Highway System (FAHS).
- (2) The stationary RICE is located at an area source that meets paragraphs (b)(2)(i), (ii), and (iii) of this section.
  - (i) The only connection to the FAHS is through the Alaska Marine Highway System (AMHS), or the stationary RICE operation is within an isolated grid in Alaska that is not connected to the statewide electrical grid referred to as the Alaska Railbelt Grid.
  - (ii) At least 10 percent of the power generated by the stationary RICE on an annual basis is used for residential purposes.
  - (iii) The generating capacity of the area source is less than 12 megawatts, or the stationary RICE is used exclusively for backup power for renewable energy.
- (c) If you own or operate an existing stationary non-emergency CI RICE with a site rating of more than 300 HP located on an offshore vessel that is an area source of HAP and is a nonroad vehicle that is an Outer Continental Shelf (OCS) source as defined in 40 CFR 55.2, you do not have to meet the numerical CO emission limitations specified in Table 2d of this subpart. You must meet all of the following management practices:
  - (1) Change oil every 1,000 hours of operation or within 1 year + 30 days of the previous change, whichever comes first. Sources have the option to utilize an oil analysis program as described in § 63.6625(i) in order to extend the specified oil change requirement.
  - (2) Inspect and clean air filters every 750 hours of operation or within 1 year + 30 days of the previous inspection, whichever comes first, and replace as necessary.
  - (3) Inspect fuel filters and belts, if installed, every 750 hours of operation or within 1 year + 30 days of the previous inspection, whichever comes first, and replace as necessary.
  - (4) Inspect all flexible hoses every 1,000 hours of operation or within 1 year + 30 days of the previous inspection, whichever comes first, and replace as necessary.
- (d) If you own or operate an existing non-emergency CI RICE with a site rating of more than 300 HP located at an area source of HAP emissions that is certified to the Tier 1 or Tier 2 emission standards in Table 1 of 40 CFR 89.112 and that is subject to an enforceable state or local standard that requires the engine to be replaced no later than June 1, 2018, you may until January 1, 2015, or 12 years after the installation date of the engine (whichever is later), but not later than June 1, 2018, choose to comply with the management practices that are shown for stationary non-emergency CI RICE with a site rating of less than or equal to 300 HP in Table 2d of this subpart instead of the applicable emission limitations in Table 2d, operating limitations in Table 2b, and crankcase ventilation system requirements in § 63.6625(g). You must comply with the emission limitations in Table 2d and operating limitations in Table 2b that apply for non-emergency CI RICE with a site rating of more than 300 HP located at an area source of HAP emissions by January 1, 2015, or 12 years after the installation date of the engine (whichever is later), but not later than

June 1, 2018. You must also comply with the crankcase ventilation system requirements in § 63.6625(g) by January 1, 2015, or 12 years after the installation date of the engine (whichever is later), but not later than June 1, 2018.

- (e) If you own or operate an existing non-emergency CI RICE with a site rating of more than 300 HP located at an area source of HAP emissions that is certified to the Tier 3 (Tier 2 for engines above 560 kilowatt (kW)) emission standards in Table 1 of 40 CFR 89.112, you may comply with the requirements under this part by meeting the requirements for Tier 3 engines (Tier 2 for engines above 560 kW) in 40 CFR part 60 subpart IIII instead of the emission limitations and other requirements that would otherwise apply under this part for existing non-emergency CI RICE with a site rating of more than 300 HP located at an area source of HAP emissions.
- (f) An existing non-emergency SI 4SLB and 4SRB stationary RICE with a site rating of more than 500 HP located at area sources of HAP must meet the definition of remote stationary RICE in § 63.6675 on the initial compliance date for the engine, October 19, 2013, in order to be considered a remote stationary RICE under this subpart. Owners and operators of existing non-emergency SI 4SLB and 4SRB stationary RICE with a site rating of more than 500 HP located at area sources of HAP that meet the definition of remote stationary RICE in § 63.6675 of this subpart as of October 19, 2013 must evaluate the status of their stationary RICE every 12 months. Owners and operators must keep records of the initial and annual evaluation of the status of the engine. If the evaluation indicates that the stationary RICE no longer meets the definition of remote stationary RICE in § 63.6675 of this subpart, the owner or operator must comply with all of the requirements for existing non-emergency SI 4SLB and 4SRB stationary RICE with a site rating of more than 500 HP located at area sources of HAP that are not remote stationary RICE within 1 year of the evaluation.

[75 FR 9675, Mar. 3, 2010, as amended at 75 FR 51589, Aug. 20, 2010; 76 FR 12866, Mar. 9, 2011; 78 FR 6701, Jan. 30, 2013; 89 FR 70515, Aug. 30, 2024]

#### § 63.6604 What fuel requirements must I meet if I own or operate a stationary CI RICE?

- (a) If you own or operate an existing non-emergency, non-black start CI stationary RICE with a site rating of more than 300 brake HP with a displacement of less than 30 liters per cylinder that uses diesel fuel, you must use diesel fuel that meets the requirements in 40 CFR 1090.305 for nonroad diesel fuel.
- (b) Beginning January 1, 2015, if you own or operate an existing emergency CI stationary RICE with a site rating of more than 100 brake HP and a displacement of less than 30 liters per cylinder that uses diesel fuel and operates for the purpose specified in § 63.6640(f)(4)(ii), you must use diesel fuel that meets the requirements in 40 CFR 1090.305 for nonroad diesel fuel, except that any existing diesel fuel purchased (or otherwise obtained) prior to January 1, 2015, may be used until depleted.
- (c) [Reserved]
- (d) Existing CI stationary RICE located in Guam, American Samoa, the Commonwealth of the Northern Mariana Islands, at area sources in areas of Alaska that meet either § 63.6603(b)(1) or § 63.6603(b)(2), or are on offshore vessels that meet § 63.6603(c) are exempt from the requirements of this section.

[78 FR 6702, Jan. 30, 2013, as amended at 85 FR 78463, Dec. 4, 2020; 87 FR 48607, Aug. 10, 2022]

#### GENERAL COMPLIANCE REQUIREMENTS

### § 63.6605 What are my general requirements for complying with this subpart?

- (a) You must be in compliance with the emission limitations, operating limitations, and other requirements in this subpart that apply to you at all times.
- (b) At all times you must operate and maintain any affected source, including associated air pollution control equipment and monitoring equipment, in a manner consistent with safety and good air pollution control practices for minimizing emissions. The general duty to minimize emissions does not require you to make any further efforts to reduce emissions if levels required by this standard have been achieved. Determination of whether such operation and maintenance procedures are being used will be based on information available to the Administrator which may include, but is not limited to, monitoring results, review of operation and maintenance procedures, review of operation and maintenance records, and inspection of the source.

[75 FR 9675, Mar. 3, 2010, as amended at 78 FR 6702, Jan. 30, 2013]

#### TESTING AND INITIAL COMPLIANCE REQUIREMENTS

### § 63.6610 By what date must I conduct the initial performance tests or other initial compliance demonstrations if I own or operate a stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions?

If you own or operate a stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions you are subject to the requirements of this section.

- (a) You must conduct the initial performance test or other initial compliance demonstrations in Table 4 to this subpart that apply to you within 180 days after the compliance date that is specified for your stationary RICE in § 63.6595 and according to the provisions in § 63.7(a)(2).
- (b) If you commenced construction or reconstruction between December 19, 2002 and June 15, 2004 and own or operate stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions, you must demonstrate initial compliance with either the proposed emission limitations or the promulgated emission limitations no later than February 10, 2005 or no later than 180 days after startup of the source, whichever is later, according to § 63.7(a)(2)(ix).
- (c) If you commenced construction or reconstruction between December 19, 2002 and June 15, 2004 and own or operate stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions, and you chose to comply with the proposed emission limitations when demonstrating initial compliance, you must conduct a second performance test to demonstrate compliance with the promulgated emission limitations by December 13, 2007 or after startup of the source, whichever is later, according to § 63.7(a)(2)(ix).
- (d) An owner or operator is not required to conduct an initial performance test on units for which a performance test has been previously conducted, but the test must meet all of the conditions described in paragraphs (d)(1) through (5) of this section.
  - (1) The test must have been conducted using the same methods specified in this subpart, and these methods must have been followed correctly.
  - (2) The test must not be older than 2 years.

- (3) The test must be reviewed and accepted by the Administrator.
- (4) Either no process or equipment changes must have been made since the test was performed, or the owner or operator must be able to demonstrate that the results of the performance test, with or without adjustments, reliably demonstrate compliance despite process or equipment changes.
- (5) The test must be conducted at any load condition within plus or minus 10 percent of 100 percent load.

[69 FR 33506, June 15, 2004, as amended at 73 FR 3605, Jan. 18, 2008]

**§ 63.6611 By what date must I conduct the initial performance tests or other initial compliance demonstrations if I own or operate a new or reconstructed 4SLB SI stationary RICE with a site rating of greater than or equal to 250 and less than or equal to 500 brake HP located at a major source of HAP emissions?**

If you own or operate a new or reconstructed 4SLB stationary RICE with a site rating of greater than or equal to 250 and less than or equal to 500 brake HP located at a major source of HAP emissions, you must conduct an initial performance test within 240 days after the compliance date that is specified for your stationary RICE in § 63.6595 and according to the provisions specified in Table 4 to this subpart, as appropriate.

[73 FR 3605, Jan. 18, 2008, as amended at 75 FR 51589, Aug. 20, 2010]

**§ 63.6612 By what date must I conduct the initial performance tests or other initial compliance demonstrations if I own or operate an existing stationary RICE with a site rating of less than or equal to 500 brake HP located at a major source of HAP emissions or an existing stationary RICE located at an area source of HAP emissions?**

If you own or operate an existing stationary RICE with a site rating of less than or equal to 500 brake HP located at a major source of HAP emissions or an existing stationary RICE located at an area source of HAP emissions you are subject to the requirements of this section.

- (a) You must conduct any initial performance test or other initial compliance demonstration according to Tables 4 and 5 to this subpart that apply to you within 180 days after the compliance date that is specified for your stationary RICE in § 63.6595 and according to the provisions in § 63.7(a)(2).
- (b) An owner or operator is not required to conduct an initial performance test on a unit for which a performance test has been previously conducted, but the test must meet all of the conditions described in paragraphs (b)(1) through (4) of this section.
  - (1) The test must have been conducted using the same methods specified in this subpart, and these methods must have been followed correctly.
  - (2) The test must not be older than 2 years.
  - (3) The test must be reviewed and accepted by the Administrator.
  - (4) Either no process or equipment changes must have been made since the test was performed, or the owner or operator must be able to demonstrate that the results of the performance test, with or without adjustments, reliably demonstrate compliance despite process or equipment changes.

[75 FR 9676, Mar. 3, 2010, as amended at 75 FR 51589, Aug. 20, 2010]

### § 63.6615 When must I conduct subsequent performance tests?

If you must comply with the emission limitations and operating limitations, you must conduct subsequent performance tests as specified in Table 3 of this subpart.

### § 63.6620 What performance tests and other procedures must I use?

- (a) You must conduct each performance test in Tables 3 and 4 of this subpart that applies to you.
- (b) Each performance test must be conducted according to the requirements that this subpart specifies in Table 4 to this subpart. If you own or operate a non-operational stationary RICE that is subject to performance testing, you do not need to start up the engine solely to conduct the performance test. Owners and operators of a non-operational engine can conduct the performance test when the engine is started up again. The test must be conducted at any load condition within plus or minus 10 percent of 100 percent load for the stationary RICE listed in paragraphs (b)(1) through (4) of this section.
  - (1) Non-emergency 4SRB stationary RICE with a site rating of greater than 500 brake HP located at a major source of HAP emissions.
  - (2) New non-emergency 4SLB stationary RICE with a site rating of greater than or equal to 250 brake HP located at a major source of HAP emissions.
  - (3) New non-emergency 2SLB stationary RICE with a site rating of greater than 500 brake HP located at a major source of HAP emissions.
  - (4) New non-emergency CI stationary RICE with a site rating of greater than 500 brake HP located at a major source of HAP emissions.
- (c) [Reserved]
- (d) You must conduct three separate test runs for each performance test required in this section, as specified in § 63.7(e)(3). Each test run must last at least 1 hour, unless otherwise specified in this subpart.
- (e)
  - (1) You must use Equation 1 of this section to determine compliance with the percent reduction requirement:

$$\frac{C_i - C_o}{C_i} \times 100 = R \quad (\text{Eq. 1})$$

Where:

$C_i$  = concentration of carbon monoxide (CO), total hydrocarbons (THC), or formaldehyde at the control device inlet,

$C_o$  = concentration of CO, THC, or formaldehyde at the control device outlet, and

R = percent reduction of CO, THC, or formaldehyde emissions.

(2) You must normalize the CO, THC, or formaldehyde concentrations at the inlet and outlet of the control device to a dry basis and to 15 percent oxygen, or an equivalent percent carbon dioxide (CO<sub>2</sub>). If pollutant concentrations are to be corrected to 15 percent oxygen and CO<sub>2</sub> concentration is measured in lieu of oxygen concentration measurement, a CO<sub>2</sub> correction factor is needed. Calculate the CO<sub>2</sub> correction factor as described in paragraphs (e)(2)(i) through (iii) of this section.

(i) Calculate the fuel-specific F<sub>O</sub> value for the fuel burned during the test using values obtained from Method 19, Section 5.2, and the following equation:

$$F_O = \frac{0.209 F_d}{F_C} \quad (Eq. 2)$$

Where:

F<sub>O</sub> = Fuel factor based on the ratio of oxygen volume to the ultimate CO<sub>2</sub> volume produced by the fuel at zero percent excess air.

0.209 = Fraction of air that is oxygen, percent/100.

F<sub>d</sub> = Ratio of the volume of dry effluent gas to the gross calorific value of the fuel from Method 19, dsm<sup>3</sup>/J (dscf/10<sup>6</sup> Btu).

F<sub>C</sub> = Ratio of the volume of CO<sub>2</sub> produced to the gross calorific value of the fuel from Method 19, dsm<sup>3</sup>/J (dscf/10<sup>6</sup> Btu)

(ii) Calculate the CO<sub>2</sub> correction factor for correcting measurement data to 15 percent O<sub>2</sub>, as follows:

$$X_{CO2} = \frac{5.9}{F_O} \quad (Eq. 3)$$

Where:

X<sub>CO2</sub> = CO<sub>2</sub> correction factor, percent.

5.9 = 20.9 percent O<sub>2</sub>—15 percent O<sub>2</sub>, the defined O<sub>2</sub> correction value, percent.

(iii) Calculate the CO, THC, and formaldehyde gas concentrations adjusted to 15 percent O<sub>2</sub> using CO<sub>2</sub> as follows:

$$C_{adj} = C_d \frac{X_{CO2}}{\%CO_2} \quad (Eq. 4)$$

Where:

C<sub>adj</sub> = Calculated concentration of CO, THC, or formaldehyde adjusted to 15 percent O<sub>2</sub>.

C<sub>d</sub> = Measured concentration of CO, THC, or formaldehyde, uncorrected.

$X_{CO_2}$  = CO<sub>2</sub> correction factor, percent.

%CO<sub>2</sub> = Measured CO<sub>2</sub> concentration measured, dry basis, percent.

- (f) If you comply with the emission limitation to reduce CO and you are not using an oxidation catalyst, if you comply with the emission limitation to reduce formaldehyde and you are not using NSCR, or if you comply with the emission limitation to limit the concentration of formaldehyde in the stationary RICE exhaust and you are not using an oxidation catalyst or NSCR, you must petition the Administrator for operating limitations to be established during the initial performance test and continuously monitored thereafter; or for approval of no operating limitations. You must not conduct the initial performance test until after the petition has been approved by the Administrator.
- (g) If you petition the Administrator for approval of operating limitations, your petition must include the information described in paragraphs (g)(1) through (5) of this section.
  - (1) Identification of the specific parameters you propose to use as operating limitations;
  - (2) A discussion of the relationship between these parameters and HAP emissions, identifying how HAP emissions change with changes in these parameters, and how limitations on these parameters will serve to limit HAP emissions;
  - (3) A discussion of how you will establish the upper and/or lower values for these parameters which will establish the limits on these parameters in the operating limitations;
  - (4) A discussion identifying the methods you will use to measure and the instruments you will use to monitor these parameters, as well as the relative accuracy and precision of these methods and instruments; and
  - (5) A discussion identifying the frequency and methods for recalibrating the instruments you will use for monitoring these parameters.
- (h) If you petition the Administrator for approval of no operating limitations, your petition must include the information described in paragraphs (h)(1) through (7) of this section.
  - (1) Identification of the parameters associated with operation of the stationary RICE and any emission control device which could change intentionally (e.g., operator adjustment, automatic controller adjustment, etc.) or unintentionally (e.g., wear and tear, error, etc.) on a routine basis or over time;
  - (2) A discussion of the relationship, if any, between changes in the parameters and changes in HAP emissions;
  - (3) For the parameters which could change in such a way as to increase HAP emissions, a discussion of whether establishing limitations on the parameters would serve to limit HAP emissions;
  - (4) For the parameters which could change in such a way as to increase HAP emissions, a discussion of how you could establish upper and/or lower values for the parameters which would establish limits on the parameters in operating limitations;
  - (5) For the parameters, a discussion identifying the methods you could use to measure them and the instruments you could use to monitor them, as well as the relative accuracy and precision of the methods and instruments;
  - (6) For the parameters, a discussion identifying the frequency and methods for recalibrating the instruments you could use to monitor them; and



- (7) A discussion of why, from your point of view, it is infeasible or unreasonable to adopt the parameters as operating limitations.
- (i) The engine percent load during a performance test must be determined by documenting the calculations, assumptions, and measurement devices used to measure or estimate the percent load in a specific application. A written report of the average percent load determination must be included in the notification of compliance status. The following information must be included in the written report: the engine model number, the engine manufacturer, the year of purchase, the manufacturer's site-rated brake horsepower, the ambient temperature, pressure, and humidity during the performance test, and all assumptions that were made to estimate or calculate percent load during the performance test must be clearly explained. If measurement devices such as flow meters, kilowatt meters, beta analyzers, stain gauges, etc. are used, the model number of the measurement device, and an estimate of its accurate in percentage of true value must be provided.
- (j) Beginning on February 26, 2025, within 60 days after the date of completing each performance test required by this subpart, you must submit the results of the performance test following the procedure specified in § 63.9(k). Data collected using test methods supported by the EPA's Electronic Reporting Tool (ERT) as listed on the EPA's ERT website (<https://www.epa.gov/electronic-reporting-air-emissions/electronic-reporting-tool-ert>) at the time of the test must be submitted in a file format generated using the EPA's ERT. Alternatively, you may submit an electronic file consistent with the extensible markup language (XML) schema listed on the EPA's ERT website. Data collected using test methods that are not supported by the EPA's ERT as listed on the EPA's ERT website at the time of the test must be included as an attachment in the ERT or alternate electronic file.

[69 FR 33506, June 15, 2004, as amended at 75 FR 9676, Mar. 3, 2010; 78 FR 6702, Jan. 30, 2013; 89 FR 70516, Aug. 30, 2024]

## § 63.6625 What are my monitoring, installation, collection, operation, and maintenance requirements?

- (a) If you elect to install a CEMS as specified in Table 5 of this subpart, you must install, operate, and maintain a CEMS to monitor CO and either O<sub>2</sub> or CO<sub>2</sub> according to the requirements in paragraphs (a)(1) through (4) of this section. If you are meeting a requirement to reduce CO emissions, the CEMS must be installed at both the inlet and outlet of the control device. If you are meeting a requirement to limit the concentration of CO, the CEMS must be installed at the outlet of the control device.
  - (1) Each CEMS must be installed, operated, and maintained according to the applicable performance specifications of 40 CFR part 60, appendix B.
  - (2) You must conduct an initial performance evaluation and an annual relative accuracy test audit (RATA) of each CEMS according to the requirements in § 63.8 and according to the applicable performance specifications of 40 CFR part 60, appendix B as well as daily and periodic data quality checks in accordance with 40 CFR part 60, appendix F, procedure 1.
  - (3) As specified in § 63.8(c)(4)(ii), each CEMS must complete a minimum of one cycle of operation (sampling, analyzing, and data recording) for each successive 15-minute period. You must have at least two data points, with each representing a different 15-minute period, to have a valid hour of data.
  - (4) The CEMS data must be reduced as specified in § 63.8(g)(2) and recorded in parts per million or parts per billion (as appropriate for the applicable limitation) at 15 percent oxygen or the equivalent CO<sub>2</sub> concentration.

(5) Beginning on February 26, 2025, within 60 days after the date of completing each continuous emissions monitoring system (CEMS) performance evaluation (as defined in § 63.2) that includes a relative accuracy test audit (RATA), you must submit the results of the performance evaluation following the procedures specified in § 63.9(k). The results of performance evaluations of CEMS measuring RATA pollutants that are supported by the EPA's ERT as listed on the EPA's ERT website at the time of the evaluation must be submitted in a file format generated using the EPA's ERT. Alternatively, you may submit an electronic file consistent with the XML schema listed on the EPA's ERT website. The results of performance evaluations of CEMS measuring RATA pollutants that are not supported by the EPA's ERT as listed on the EPA's ERT website at the time of the evaluation must be included as an attachment in the ERT or alternate electronic file.

(b) If you are required to install a continuous parameter monitoring system (CPMS) as specified in Table 5 of this subpart, you must install, operate, and maintain each CPMS according to the requirements in paragraphs (b)(1) through (6) of this section. For an affected source that is complying with the emission limitations and operating limitations on March 9, 2011, the requirements in paragraph (b) of this section are applicable September 6, 2011.

(1) You must prepare a site-specific monitoring plan that addresses the monitoring system design, data collection, and the quality assurance and quality control elements outlined in paragraphs (b)(1)(i) through (v) of this section and in § 63.8(d). As specified in § 63.8(f)(4), you may request approval of monitoring system quality assurance and quality control procedures alternative to those specified in paragraphs (b)(1) through (5) of this section in your site-specific monitoring plan.

(i) The performance criteria and design specifications for the monitoring system equipment, including the sample interface, detector signal analyzer, and data acquisition and calculations;

(ii) Sampling interface (e.g., thermocouple) location such that the monitoring system will provide representative measurements;

(iii) Equipment performance evaluations, system accuracy audits, or other audit procedures;

(iv) Ongoing operation and maintenance procedures in accordance with provisions in § 63.8(c)(1)(ii) and (c)(3); and

(v) Ongoing reporting and recordkeeping procedures in accordance with provisions in § 63.10(c), (e)(1), and (e)(2)(i).

(2) You must install, operate, and maintain each CPMS in continuous operation according to the procedures in your site-specific monitoring plan.

(3) The CPMS must collect data at least once every 15 minutes (see also § 63.6635).

(4) For a CPMS for measuring temperature range, the temperature sensor must have a minimum tolerance of 2.8 degrees Celsius (5 degrees Fahrenheit) or 1 percent of the measurement range, whichever is larger.

(5) You must conduct the CPMS equipment performance evaluation, system accuracy audits, or other audit procedures specified in your site-specific monitoring plan at least annually.

(6) You must conduct a performance evaluation of each CPMS in accordance with your site-specific monitoring plan.

- (c) If you are operating a new or reconstructed stationary RICE which fires landfill gas or digester gas equivalent to 10 percent or more of the gross heat input on an annual basis, you must monitor and record your fuel usage daily with separate fuel meters to measure the volumetric flow rate of each fuel. In addition, you must operate your stationary RICE in a manner which reasonably minimizes HAP emissions.
- (d) If you are operating a new or reconstructed emergency 4SLB stationary RICE with a site rating of greater than or equal to 250 and less than or equal to 500 brake HP located at a major source of HAP emissions, you must install a non-resettable hour meter prior to the startup of the engine.
- (e) If you own or operate any of the following stationary RICE, you must operate and maintain the stationary RICE and after-treatment control device (if any) according to the manufacturer's emission-related written instructions or develop your own maintenance plan which must provide to the extent practicable for the maintenance and operation of the engine in a manner consistent with good air pollution control practice for minimizing emissions:
  - (1) An existing stationary RICE with a site rating of less than 100 HP located at a major source of HAP emissions;
  - (2) An existing emergency or black start stationary RICE with a site rating of less than or equal to 500 HP located at a major source of HAP emissions;
  - (3) An existing emergency or black start stationary RICE located at an area source of HAP emissions;
  - (4) An existing non-emergency, non-black start stationary CI RICE with a site rating less than or equal to 300 HP located at an area source of HAP emissions;
  - (5) An existing non-emergency, non-black start 2SLB stationary RICE located at an area source of HAP emissions;
  - (6) An existing non-emergency, non-black start stationary RICE located at an area source of HAP emissions which combusts landfill or digester gas equivalent to 10 percent or more of the gross heat input on an annual basis.
  - (7) An existing non-emergency, non-black start 4SLB stationary RICE with a site rating less than or equal to 500 HP located at an area source of HAP emissions;
  - (8) An existing non-emergency, non-black start 4SRB stationary RICE with a site rating less than or equal to 500 HP located at an area source of HAP emissions;
  - (9) An existing, non-emergency, non-black start 4SLB stationary RICE with a site rating greater than 500 HP located at an area source of HAP emissions that is operated 24 hours or less per calendar year; and
  - (10) An existing, non-emergency, non-black start 4SRB stationary RICE with a site rating greater than 500 HP located at an area source of HAP emissions that is operated 24 hours or less per calendar year.
- (f) If you own or operate an existing emergency stationary RICE with a site rating of less than or equal to 500 brake HP located at a major source of HAP emissions or an existing emergency stationary RICE located at an area source of HAP emissions, you must install a non-resettable hour meter if one is not already installed.
- (g) If you own or operate an existing non-emergency, non-black start CI engine greater than or equal to 300 HP that is not equipped with a closed crankcase ventilation system, you must comply with either paragraph (g)(1) or paragraph (2) of this section. Owners and operators must follow the manufacturer's

specified maintenance requirements for operating and maintaining the open or closed crankcase ventilation systems and replacing the crankcase filters, or can request the Administrator to approve different maintenance requirements that are as protective as manufacturer requirements. Existing CI engines located at area sources in areas of Alaska that meet either § 63.6603(b)(1) or § 63.6603(b)(2) do not have to meet the requirements of this paragraph (g). Existing CI engines located on offshore vessels that meet § 63.6603(c) do not have to meet the requirements of this paragraph (g).

- (1) Install a closed crankcase ventilation system that prevents crankcase emissions from being emitted to the atmosphere, or
  - (2) Install an open crankcase filtration emission control system that reduces emissions from the crankcase by filtering the exhaust stream to remove oil mist, particulates and metals.
- (h) If you operate a new, reconstructed, or existing stationary engine, you must minimize the engine's time spent at idle during startup and minimize the engine's startup time to a period needed for appropriate and safe loading of the engine, not to exceed 30 minutes, after which time the emission standards applicable to all times other than startup in Tables 1a, 2a, 2c, and 2d to this subpart apply.
- (i) If you own or operate a stationary CI engine that is subject to the work, operation or management practices in items 1 or 2 of table 2c to this subpart or in items 1 or 4 of table 2d to this subpart, you have the option of utilizing an oil analysis program in order to extend the specified oil and filter change requirement in tables 2c and 2d to this subpart. The oil analysis must be performed at the same frequency specified for changing the oil and filter in table 2c or 2d to this subpart. The analysis program must at a minimum analyze the following three parameters: Total Base Number, viscosity, and percent water content. The condemning limits for these parameters are as follows: Total Base Number is less than 30 percent of the Total Base Number of the oil when new; viscosity of the oil has changed by more than 20 percent from the viscosity of the oil when new; or percent water content (by volume) is greater than 0.5. If all of these condemning limits are not exceeded, the engine owner or operator is not required to change the oil and filter. If any of the limits are exceeded, the engine owner or operator must change the oil and filter within 2 business days of receiving the results of the analysis; if the engine is not in operation when the results of the analysis are received, the engine owner or operator must change the oil and filter within 2 business days or before commencing operation, whichever is later. The owner or operator must keep records of the parameters that are analyzed as part of the program, the results of the analysis, and the oil and filter changes for the engine. The analysis program must be part of the maintenance plan for the engine.
- (j) If you own or operate a stationary SI engine that is subject to the work, operation or management practices in items 6, 7, or 8 of table 2c to this subpart or in items 5, 6, 7, 8, 10, 11, or 13 of table 2d to this subpart, you have the option of utilizing an oil analysis program in order to extend the specified oil and filter change requirement in tables 2c and 2d to this subpart. The oil analysis must be performed at the same frequency specified for changing the oil and filter in table 2c or 2d to this subpart. The analysis program must at a minimum analyze the following three parameters: Total Acid Number, viscosity, and percent water content. The condemning limits for these parameters are as follows: Total Acid Number increases by more than 3.0 milligrams of potassium hydroxide (KOH) per gram from Total Acid Number of the oil when new; viscosity of the oil has changed by more than 20 percent from the viscosity of the oil when new; or percent water content (by volume) is greater than 0.5. If all of these condemning limits are not exceeded, the engine owner or operator is not required to change the oil and filter. If any of the limits are exceeded, the engine owner or operator must change the oil and filter within 2 business days of receiving the results of the analysis; if the engine is not in operation when the results of the analysis are received, the engine owner or operator must change the oil and filter within 2 business days or before

commencing operation, whichever is later. The owner or operator must keep records of the parameters that are analyzed as part of the program, the results of the analysis, and the oil and filter changes for the engine. The analysis program must be part of the maintenance plan for the engine.

[69 FR 33506, June 15, 2004, as amended at 73 FR 3606, Jan. 18, 2008; 75 FR 9676, Mar. 3, 2010; 75 FR 51589, Aug. 20, 2010; 76 FR 12866, Mar. 9, 2011; 78 FR 6703, Jan. 30, 2013; 89 FR 70516, Aug. 30, 2024]

### **§ 63.6630 How do I demonstrate initial compliance with the emission limitations, operating limitations, and other requirements?**

- (a) You must demonstrate initial compliance with each emission limitation, operating limitation, and other requirement that applies to you according to Table 5 of this subpart.
- (b) During the initial performance test, you must establish each operating limitation in Tables 1b and 2b of this subpart that applies to you.
- (c) You must submit the Notification of Compliance Status containing the results of the initial compliance demonstration according to the requirements in § 63.6645.
- (d) Non-emergency 4SRB stationary RICE complying with the requirement to reduce formaldehyde emissions by 76 percent or more can demonstrate initial compliance with the formaldehyde emission limit by testing for THC instead of formaldehyde. The testing must be conducted according to the requirements in Table 4 of this subpart. The average reduction of emissions of THC determined from the performance test must be equal to or greater than 30 percent.
- (e) The initial compliance demonstration required for existing non-emergency 4SLB and 4SRB stationary RICE with a site rating of more than 500 HP located at an area source of HAP that are not remote stationary RICE and that are operated more than 24 hours per calendar year must be conducted according to the following requirements:
  - (1) The compliance demonstration must consist of at least three test runs.
  - (2) Each test run must be of at least 15 minute duration, except that each test conducted using the method in appendix A to this subpart must consist of at least one measurement cycle and include at least 2 minutes of test data phase measurement.
  - (3) If you are demonstrating compliance with the CO concentration or CO percent reduction requirement, you must measure CO emissions using one of the CO measurement methods specified in Table 4 of this subpart, or using appendix A to this subpart.
  - (4) If you are demonstrating compliance with the THC percent reduction requirement, you must measure THC emissions using Method 25A, reported as propane, of 40 CFR part 60, appendix A.
  - (5) You must measure O<sub>2</sub> using one of the O<sub>2</sub> measurement methods specified in Table 4 of this subpart. Measurements to determine O<sub>2</sub> concentration must be made at the same time as the measurements for CO or THC concentration.
  - (6) If you are demonstrating compliance with the CO or THC percent reduction requirement, you must measure CO or THC emissions and O<sub>2</sub> emissions simultaneously at the inlet and outlet of the control device.

[69 FR 33506, June 15, 2004, as amended at 78 FR 6704, Jan. 30, 2013]

## CONTINUOUS COMPLIANCE REQUIREMENTS

### § 63.6635 How do I monitor and collect data to demonstrate continuous compliance?

- (a) If you must comply with emission and operating limitations, you must monitor and collect data according to this section.
- (b) Except for monitor malfunctions, associated repairs, required performance evaluations, and required quality assurance or control activities, you must monitor continuously at all times that the stationary RICE is operating. A monitoring malfunction is any sudden, infrequent, not reasonably preventable failure of the monitoring to provide valid data. Monitoring failures that are caused in part by poor maintenance or careless operation are not malfunctions.
- (c) You may not use data recorded during monitoring malfunctions, associated repairs, and required quality assurance or control activities in data averages and calculations used to report emission or operating levels. You must, however, use all the valid data collected during all other periods.

[69 FR 33506, June 15, 2004, as amended at 76 FR 12867, Mar. 9, 2011]

### § 63.6640 How do I demonstrate continuous compliance with the emission limitations, operating limitations, and other requirements?

- (a) You must demonstrate continuous compliance with each emission limitation, operating limitation, and other requirements in Tables 1a and 1b, Tables 2a and 2b, Table 2c, and Table 2d to this subpart that apply to you according to methods specified in Table 6 to this subpart.
- (b) You must report each instance in which you did not meet each emission limitation or operating limitation in Tables 1a and 1b, Tables 2a and 2b, Table 2c, and Table 2d to this subpart that apply to you. These instances are deviations from the emission and operating limitations in this subpart. These deviations must be reported according to the requirements in § 63.6650. If you change your catalyst, you must reestablish the values of the operating parameters measured during the initial performance test. When you reestablish the values of your operating parameters, you must also conduct a performance test to demonstrate that you are meeting the required emission limitation applicable to your stationary RICE.
- (c) The annual compliance demonstration required for existing non-emergency 4SLB and 4SRB stationary RICE with a site rating of more than 500 HP located at an area source of HAP that are not remote stationary RICE and that are operated more than 24 hours per calendar year must be conducted according to the following requirements:
  - (1) The compliance demonstration must consist of at least one test run.
  - (2) Each test run must be of at least 15 minute duration, except that each test conducted using the method in appendix A to this subpart must consist of at least one measurement cycle and include at least 2 minutes of test data phase measurement.
  - (3) If you are demonstrating compliance with the CO concentration or CO percent reduction requirement, you must measure CO emissions using one of the CO measurement methods specified in Table 4 of this subpart, or using appendix A to this subpart.
  - (4) If you are demonstrating compliance with the THC percent reduction requirement, you must measure THC emissions using Method 25A, reported as propane, of 40 CFR part 60, appendix A.

- (5) You must measure O<sub>2</sub> using one of the O<sub>2</sub> measurement methods specified in Table 4 of this subpart. Measurements to determine O<sub>2</sub> concentration must be made at the same time as the measurements for CO or THC concentration.
  - (6) If you are demonstrating compliance with the CO or THC percent reduction requirement, you must measure CO or THC emissions and O<sub>2</sub> emissions simultaneously at the inlet and outlet of the control device.
  - (7) If the results of the annual compliance demonstration show that the emissions exceed the levels specified in Table 6 of this subpart, the stationary RICE must be shut down as soon as safely possible, and appropriate corrective action must be taken (e.g., repairs, catalyst cleaning, catalyst replacement). The stationary RICE must be retested within 7 days of being restarted and the emissions must meet the levels specified in Table 6 of this subpart. If the retest shows that the emissions continue to exceed the specified levels, the stationary RICE must again be shut down as soon as safely possible, and the stationary RICE may not operate, except for purposes of startup and testing, until the owner/operator demonstrates through testing that the emissions do not exceed the levels specified in Table 6 of this subpart.
- (d) For new, reconstructed, and rebuilt stationary RICE, deviations from the emission or operating limitations that occur during the first 200 hours of operation from engine startup (engine burn-in period) are not violations. Rebuilt stationary RICE means a stationary RICE that has been rebuilt as that term is defined in 40 CFR 94.11(a).
- (e) You must also report each instance in which you did not meet the requirements in Table 8 to this subpart that apply to you. If you own or operate a new or reconstructed stationary RICE with a site rating of less than or equal to 500 brake HP located at a major source of HAP emissions (except new or reconstructed 4SLB engines greater than or equal to 250 and less than or equal to 500 brake HP), a new or reconstructed stationary RICE located at an area source of HAP emissions, or any of the following RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions, you do not need to comply with the requirements in Table 8 to this subpart: An existing 2SLB stationary RICE, an existing 4SLB stationary RICE, an existing emergency stationary RICE, an existing limited use stationary RICE, or an existing stationary RICE which fires landfill gas or digester gas equivalent to 10 percent or more of the gross heat input on an annual basis. If you own or operate any of the following RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions, you do not need to comply with the requirements in Table 8 to this subpart, except for the initial notification requirements: a new or reconstructed stationary RICE that combusts landfill gas or digester gas equivalent to 10 percent or more of the gross heat input on an annual basis, a new or reconstructed emergency stationary RICE, or a new or reconstructed limited use stationary RICE.
- (f) If you own or operate an emergency stationary RICE, you must operate the emergency stationary RICE according to the requirements in paragraphs (f)(1) through (4) of this section. In order for the engine to be considered an emergency stationary RICE under this subpart, any operation other than emergency operation, maintenance and testing, and operation in non-emergency situations for 50 hours per year, as described in paragraphs (f)(1) through (4), is prohibited. If you do not operate the engine according to the requirements in paragraphs (f)(1) through (4), the engine will not be considered an emergency engine under this subpart and must meet all requirements for non-emergency engines.
- (1) There is no time limit on the use of emergency stationary RICE in emergency situations.

- (2) You may operate your emergency stationary RICE for the purpose specified in paragraph (f)(2)(i) of this section for a maximum of 100 hours per calendar year. Any operation for non-emergency situations as allowed by paragraphs (f)(3) and (4) of this section counts as part of the 100 hours per calendar year allowed by this paragraph (f)(2).
  - (i) Emergency stationary RICE may be operated for maintenance checks and readiness testing, provided that the tests are recommended by federal, state or local government, the manufacturer, the vendor, the regional transmission organization or equivalent balancing authority and transmission operator, or the insurance company associated with the engine. The owner or operator may petition the Administrator for approval of additional hours to be used for maintenance checks and readiness testing, but a petition is not required if the owner or operator maintains records indicating that federal, state, or local standards require maintenance and testing of emergency RICE beyond 100 hours per calendar year.
  - (ii)-(iii) [Reserved]
- (3) Emergency stationary RICE located at major sources of HAP may be operated for up to 50 hours per calendar year in non-emergency situations. The 50 hours of operation in non-emergency situations are counted as part of the 100 hours per calendar year for maintenance and testing provided in paragraph (f)(2) of this section. The 50 hours per year for non-emergency situations cannot be used for peak shaving or non-emergency demand response, or to generate income for a facility to supply power to an electric grid or otherwise supply power as part of a financial arrangement with another entity.
- (4) Emergency stationary RICE located at area sources of HAP may be operated for up to 50 hours per calendar year in non-emergency situations. The 50 hours of operation in non-emergency situations are counted as part of the 100 hours per calendar year for maintenance and testing provided in paragraph (f)(2) of this section. Except as provided in paragraphs (f)(4)(i) and (ii) of this section, the 50 hours per year for non-emergency situations cannot be used for peak shaving or non-emergency demand response, or to generate income for a facility to an electric grid or otherwise supply power as part of a financial arrangement with another entity.
  - (i) Prior to May 3, 2014, the 50 hours per year for non-emergency situations can be used for peak shaving or non-emergency demand response to generate income for a facility, or to otherwise supply power as part of a financial arrangement with another entity if the engine is operated as part of a peak shaving (load management program) with the local distribution system operator and the power is provided only to the facility itself or to support the local distribution system.
  - (ii) The 50 hours per year for non-emergency situations can be used to supply power as part of a financial arrangement with another entity if all of the following conditions are met:
    - (A) The engine is dispatched by the local balancing authority or local transmission and distribution system operator.
    - (B) The dispatch is intended to mitigate local transmission and/or distribution limitations so as to avert potential voltage collapse or line overloads that could lead to the interruption of power supply in a local area or region.
    - (C) The dispatch follows reliability, emergency operation or similar protocols that follow specific NERC, regional, state, public utility commission or local standards or guidelines.



- (D) The power is provided only to the facility itself or to support the local transmission and distribution system.
- (E) The owner or operator identifies and records the entity that dispatches the engine and the specific NERC, regional, state, public utility commission or local standards or guidelines that are being followed for dispatching the engine. The local balancing authority or local transmission and distribution system operator may keep these records on behalf of the engine owner or operator.

[69 FR 33506, June 15, 2004, as amended at 71 FR 20467, Apr. 20, 2006; 73 FR 3606, Jan. 18, 2008; 75 FR 9676, Mar. 3, 2010; 75 FR 51591, Aug. 20, 2010; 78 FR 6704, Jan. 30, 2013; 87 FR 48607, Aug. 10, 2022]

## NOTIFICATIONS, REPORTS, AND RECORDS

### § 63.6645 What notifications must I submit and when?

- (a) You must submit all of the notifications in §§ 63.7(b) and (c), 63.8(e), (f)(4) and (f)(6), 63.9(b) through (e), and (g) and (h) that apply to you by the dates specified if you own or operate any of the following:
  - (1) An existing stationary RICE with a site rating of less than or equal to 500 brake HP located at a major source of HAP emissions.
  - (2) An existing stationary RICE located at an area source of HAP emissions.
  - (3) A stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions.
  - (4) A new or reconstructed 4SLB stationary RICE with a site rating of greater than or equal to 250 HP located at a major source of HAP emissions.
  - (5) This requirement does not apply if you own or operate an existing stationary RICE less than 100 HP, an existing stationary emergency RICE, or an existing stationary RICE that is not subject to any numerical emission standards.
- (b) As specified in § 63.9(b)(2), if you start up your stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions before the effective date of this subpart, you must submit an initial notification not later than December 13, 2004, or no later than 120 days after the source becomes subject to this subpart, whichever is later. Beginning on February 26, 2025, submit the notification electronically in portable document format (PDF) consistent with § 63.9(k).
- (c) If you start up your new or reconstructed stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions on or after August 16, 2004, you must submit an initial notification not later than 120 days after you become subject to this subpart. Beginning on February 26, 2025, submit the notification electronically in PDF consistent with § 63.9(k).
- (d) As specified in § 63.9(b)(2), if you start up your stationary RICE with a site rating of equal to or less than 500 brake HP located at a major source of HAP emissions before the effective date of this subpart and you are required to submit an initial notification, you must submit an initial notification not later than July 16, 2008, or no later than 120 days after the source becomes subject to this subpart, whichever is later. Beginning on February 26, 2025, submit the notification electronically in PDF consistent with § 63.9(k).

- (e) If you start up your new or reconstructed stationary RICE with a site rating of equal to or less than 500 brake HP located at a major source of HAP emissions on or after March 18, 2008, and you are required to submit an initial notification, you must submit an initial notification not later than 120 days after you become subject to this subpart. Beginning on February 26, 2025, submit the notification electronically in PDF consistent with § 63.9(k).
- (f) If you are required to submit an Initial Notification but are otherwise not affected by the requirements of this subpart, in accordance with § 63.6590(b), your notification should include the information in § 63.9(b)(2)(i) through (v), and a statement that your stationary RICE has no additional requirements and explain the basis of the exclusion (for example, that it operates exclusively as an emergency stationary RICE if it has a site rating of more than 500 brake HP located at a major source of HAP emissions).
- (g) If you are required to conduct a performance test, you must submit a Notification of Intent to conduct a performance test at least 60 days before the performance test is scheduled to begin as required in § 63.7(b)(1).
- (h) If you are required to conduct a performance test or other initial compliance demonstration as specified in Tables 4 and 5 to this subpart, you must submit a Notification of Compliance Status according to § 63.9(h)(2)(ii).
  - (1) For each initial compliance demonstration required in Table 5 to this subpart that does not include a performance test, you must submit the Notification of Compliance Status before the close of business on the 30th day following the completion of the initial compliance demonstration.
  - (2) Before February 26, 2025, for each initial compliance demonstration required in table 5 to this subpart that includes a performance test conducted according to the requirements in table 3 to this subpart, you must submit the Notification of Compliance Status, including the performance test results, before the close of business on the 60th day following the completion of the performance test according to § 63.10(d)(2). Beginning on February 26, 2025, for each initial compliance demonstration required in table 5 to this subpart that includes a performance test conducted according to the requirements in table 3 to this subpart, you must submit the Notification of Compliance Status, including a summary of the performance test results, in PDF to the EPA via the Compliance and Emissions Data Reporting Interface (CEDRI), before the close of business on the 60th day following the completion of the performance test following the procedure specified in § 63.9(k), except any Confidential Business Information (CBI) is to be submitted according to paragraphs (h)(2)(i) and (ii) of this section. Do not use CEDRI to submit information you claim as CBI. Although we do not expect persons to assert a claim of CBI, if you wish to assert a CBI claim for some of the information in the report, you must submit a complete file, including information claimed to be CBI, to the EPA following the procedures in paragraphs (h)(2)(i) and (ii) of this section. Clearly mark the part or all of the information that you claim to be CBI. Information not marked as CBI may be authorized for public release without prior notice. Information marked as CBI will not be disclosed except in accordance with procedures set forth in 40 CFR part 2. All CBI claims must be asserted at the time of submission. Anything submitted using CEDRI cannot later be claimed CBI. Furthermore, under CAA section 114(c), emissions data is not entitled to confidential treatment, and the EPA is required to make emissions data available to the public. Thus, emissions data will not be protected as CBI and will be made publicly available. You must submit the same file submitted to the CBI office with the CBI omitted to the EPA via the EPA's CDX as described earlier in this paragraph (h)(2).

- (i) The preferred method to receive CBI is for it to be transmitted electronically using email attachments, File Transfer Protocol, or other online file sharing services. Electronic submissions must be transmitted directly to the OAQPS CBI Office at the email address [oaqpscbi@epa.gov](mailto:oaqpscbi@epa.gov), and as described in paragraph (h)(2) of this section, should include clear CBI markings and be flagged to the attention of the Reciprocating Internal Combustion Engine Sector Lead. If assistance is needed with submitting large electronic files that exceed the file size limit for email attachments, and if you do not have your own file sharing service, please email [oaqpscbi@epa.gov](mailto:oaqpscbi@epa.gov) to request a file transfer link.
  - (ii) If you cannot transmit the file electronically, you may send CBI information through the postal service to the following address: OAQPS Document Control Officer (C404-02), OAQPS, U.S. Environmental Protection Agency, 109 T.W. Alexander Drive, P.O. Box 12055, Research Triangle Park, North Carolina 27711, Attention Reciprocating Internal Combustion Engine Sector Lead. The mailed CBI material should be double wrapped and clearly marked. Any CBI markings should not show through the outer envelope.
- (i) If you own or operate an existing non-emergency CI RICE with a site rating of more than 300 HP located at an area source of HAP emissions that is certified to the Tier 1 or Tier 2 emission standards in Table 1 of 40 CFR 89.112 and subject to an enforceable state or local standard requiring engine replacement and you intend to meet management practices rather than emission limits, as specified in § 63.6603(d), you must submit a notification by March 3, 2013, stating that you intend to use the provision in § 63.6603(d) and identifying the state or local regulation that the engine is subject to.

[73 FR 3606, Jan. 18, 2008, as amended at 75 FR 9677, Mar. 3, 2010; 75 FR 51591, Aug. 20, 2010; 78 FR 6705, Jan. 30, 2013; 85 FR 73912, Nov. 19, 2020; 89 FR 70516, Aug. 30, 2024]

## § 63.6650 What reports must I submit and when?

- (a) You must submit each report in Table 7 of this subpart that applies to you.
- (b) Unless the Administrator has approved a different schedule for submission of reports under § 63.10(a), you must submit each report by the date in Table 7 of this subpart and according to the requirements in paragraphs (b)(1) through (b)(9) of this section.
  - (1) For semiannual Compliance reports, the first Compliance report must cover the period beginning on the compliance date that is specified for your affected source in § 63.6595 and ending on June 30 or December 31, whichever date is the first date following the end of the first calendar half after the compliance date that is specified for your source in § 63.6595.
  - (2) For semiannual Compliance reports, the first Compliance report must be postmarked or delivered no later than July 31 or January 31, whichever date follows the end of the first calendar half after the compliance date that is specified for your affected source in § 63.6595.
  - (3) For semiannual Compliance reports, each subsequent Compliance report must cover the semiannual reporting period from January 1 through June 30 or the semiannual reporting period from July 1 through December 31.
  - (4) For semiannual Compliance reports, each subsequent Compliance report must be postmarked or delivered no later than July 31 or January 31, whichever date is the first date following the end of the semiannual reporting period.

- (5) For each stationary RICE that is subject to permitting regulations pursuant to 40 CFR part 70 or 71, and if the permitting authority has established dates for submitting semiannual reports pursuant to 40 CFR 70.6(a)(3)(iii)(A) or 40 CFR 71.6 (a)(3)(iii)(A), you may submit the first and subsequent Compliance reports according to the dates the permitting authority has established instead of according to the dates in paragraphs (b)(1) through (b)(4) of this section.
  - (6) For annual Compliance reports, the first Compliance report must cover the period beginning on the compliance date that is specified for your affected source in § 63.6595 and ending on December 31.
  - (7) For annual Compliance reports, the first Compliance report must be postmarked or delivered no later than January 31 following the end of the first calendar year after the compliance date that is specified for your affected source in § 63.6595.
  - (8) For annual Compliance reports, each subsequent Compliance report must cover the annual reporting period from January 1 through December 31.
  - (9) For annual Compliance reports, each subsequent Compliance report must be postmarked or delivered no later than January 31.
- (c) The Compliance report must contain the information in paragraphs (c)(1) through (8) of this section.
- (1) Company name and address.
  - (2) Statement by a responsible official, with that official's name, title, and signature, certifying the accuracy of the content of the report.
  - (3) Date of report and beginning and ending dates of the reporting period.
  - (4) If you had a malfunction during the reporting period, the compliance report must include the starting and ending date and time, the duration (in hours), and a brief description for each malfunction which occurred during the reporting period and which caused or may have caused any applicable emission limitation to be exceeded. The report must also include a description of actions taken by an owner or operator during a malfunction of an affected source to minimize emissions in accordance with § 63.6605(b), including actions taken to correct a malfunction.
  - (5) If there are no deviations from any emission or operating limitations that apply to you, a statement that there were no deviations from the emission or operating limitations during the reporting period.
  - (6) If there were no periods during which the continuous monitoring system (CMS), including CEMS and CPMS, was out-of-control, as specified in § 63.8(c)(7), a statement that there were no periods during which the CMS was out-of-control during the reporting period.
  - (7) Engine site rating in brake HP, year construction of the engine commenced (as defined in § 63.2, where the exact year is not known, provide the best estimate), and type of engine (CI, SI 2SLB, SI 4SLB, or SI 4SRB).
  - (8) Latitude and longitude of the engine in decimal degrees reported to the fifth decimal place.
  - (9) An engine can be claimed as exempt from reporting coordinates (latitude/longitude) via CEDRI if:
    - (i) During the reporting period, the engine will be owned by, or operated by or for, an agency of the Federal Government responsible for national defense; and
    - (ii) The agency determines that disclosing the coordinates to the general public would be a threat to national security.

- (d) For each deviation from an emission or operating limitation that occurs for a stationary RICE where you are not using a CMS to comply with the emission or operating limitations in this subpart, the Compliance report must contain the information in paragraphs (c)(1) through (8) of this section and the information in paragraphs (d)(1) and (2) of this section.
  - (1) The total operating time (in hours) of the stationary RICE at which the deviation occurred during the reporting period.
  - (2) Information on the number, duration (in hours), and cause of deviations (including unknown cause, if applicable), as applicable, and the corrective action taken.
  - (3) A description of any changes in processes, or controls since the last reporting period.
- (e) For each deviation from an emission or operating limitation occurring for a stationary RICE where you are using a CMS to comply with the emission and operating limitations in this subpart, you must include information in paragraphs (c)(1) through (8) and (e)(1) through (13) of this section.
  - (1) The date and time that each malfunction started and stopped.
  - (2) The start and end date and time and the duration (in hours) that each CMS was inoperative, except for zero (low-level) and high-level checks.
  - (3) The start and end date and time and the duration (in hours) that each CMS was out-of-control, including the information in § 63.8(c)(8).
  - (4) The date and time that each deviation started and stopped, and whether each deviation occurred during a period of malfunction or during another period.
  - (5) A summary of the total duration (in hours) of the deviation during the reporting period, and the total duration as a percent of the total source operating time during that reporting period.
  - (6) A breakdown of the total duration (in hours) of the deviations during the reporting period into those that are due to control equipment problems, process problems, other known causes, and other unknown causes.
  - (7) A summary of the total duration (in hours) of CMS downtime during the reporting period, and the total duration of CMS downtime as a percent of the total operating time of the stationary RICE at which the CMS downtime occurred during that reporting period.
  - (8) An identification of each parameter and pollutant (CO or formaldehyde) that was monitored at the stationary RICE.
  - (9) [Reserved]
  - (10) A brief description of the CMS.
  - (11) The date of the latest CMS certification or audit.
  - (12) A description of any changes in CMS, processes, or controls since the last reporting period.
  - (13) The total operating time of the stationary RICE at which the deviation occurred during the reporting period.
- (f) Each affected source that has obtained a title V operating permit pursuant to 40 CFR part 70 or 71 must report all deviations as defined in this subpart in the semiannual monitoring report required by 40 CFR 70.6 (a)(3)(iii)(A) or 40 CFR 71.6(a)(3)(iii)(A). If an affected source submits a Compliance report pursuant

to table 7 of this subpart along with, or as part of, the semiannual monitoring report required by 40 CFR 70.6(a)(3)(iii)(A) or 40 CFR 71.6(a)(3)(iii)(A), and the Compliance report includes all required information concerning deviations from any emission or operating limitation in this subpart, submission of the Compliance report shall be deemed to satisfy any obligation to report the same deviations in the semiannual monitoring report. However, submission of a Compliance report shall not otherwise affect any obligation the affected source may have to report deviations from permit requirements to the permit authority. Beginning on February 26, 2025, the semiannual and annual compliance report required in table 7 of this subpart must be submitted according to paragraph (i) of this section. Only those elements required under this subpart are required to be submitted according to paragraph (i) of this section.

- (g) If you are operating as a new or reconstructed stationary RICE which fires landfill gas or digester gas equivalent to 10 percent or more of the gross heat input on an annual basis, you must submit an annual report according to Table 7 of this subpart by the date specified unless the Administrator has approved a different schedule, according to the information described in paragraphs (b)(1) through (b)(5) of this section. You must report the data specified in (g)(1) through (g)(3) of this section.
  - (1) Fuel flow rate of each fuel and the heating values that were used in your calculations. You must also demonstrate that the percentage of heat input provided by landfill gas or digester gas is equivalent to 10 percent or more of the total fuel consumption on an annual basis.
  - (2) The operating limits provided in your federally enforceable permit, and any deviations from these limits.
  - (3) Any problems or errors suspected with the meters.
- (h) If you own or operate an emergency stationary RICE with a site rating of more than 100 brake HP that operates for the purpose specified in § 63.6640(f)(4)(ii), you must submit an annual report according to the requirements in paragraphs (h)(1) through (3) of this section.
  - (1) The report must contain the following information:
    - (i) Company name and address where the engine is located.
    - (ii) Date of the report and beginning and ending dates of the reporting period.
    - (iii) Engine site rating in brake HP, year construction of the engine commenced (as defined in § 63.2, where the exact year is not known, provide the best estimate), and type of engine (CI, SI 2SLB, SI 4SLB, or SI 4SRB).
    - (iv) Latitude and longitude of the engine in decimal degrees reported to the fifth decimal place.
    - (v)-(vi) [Reserved]
    - (vii) Hours spent for operation for the purpose specified in § 63.6640(f)(4)(ii), including the date, start time, and end time for engine operation for the purposes specified in § 63.6640(f)(4)(ii). The report must also identify the entity that dispatched the engine and the situation that necessitated the dispatch of the engine.
    - (viii) If there were no deviations from the fuel requirements in § 63.6604 that apply to the engine (if any), a statement that there were no deviations from the fuel requirements during the reporting period.

- (ix) If there were deviations from the fuel requirements in § 63.6604 that apply to the engine (if any), information on the number, duration (in hours), and cause of deviations, and the corrective action taken.
- (2) The first annual report must cover the calendar year 2015 and must be submitted no later than March 31, 2016. Subsequent annual reports for each calendar year must be submitted no later than March 31 of the following calendar year.
- (3) Before February 26, 2025, the annual report must be submitted electronically using the subpart specific reporting form in the Compliance and Emissions Data Reporting Interface (CEDRI) that is accessed through EPA's Central Data Exchange (CDX) (<https://cdx.epa.gov/>). However, if the reporting form specific to this subpart is not available in CEDRI at the time that the report is due, the written report must be submitted to the Administrator at the appropriate address listed in § 63.13. Beginning on February 26, 2025, the annual report must be submitted according to paragraph (i) of this section.
- (i) Beginning on February 26, 2025 for the annual report specified in § 63.6650(h) and February 26, 2025 or one year after the report becomes available in CEDRI, whichever is later for all other semiannual or annual reports, submit all semiannual and annual subsequent compliance reports using the appropriate electronic report template on the CEDRI website (<https://www.epa.gov/electronic-reporting-air-emissions/cedri>) for this subpart and following the procedure specified in § 63.9(k), except any CBI must be submitted according to the procedures in § 63.6645(h). The date report templates become available will be listed on the CEDRI website. Unless the Administrator or delegated state agency or other authority has approved a different schedule for submission of reports, the report must be submitted by the deadline specified in this subpart, regardless of the method in which the report is submitted.

[69 FR 33506, June 15, 2004, as amended at 75 FR 9677, Mar. 3, 2010; 78 FR 6705, Jan. 30, 2013; 87 FR 48607, Aug. 10, 2022; 89 FR 70517, Aug. 30, 2024]

## § 63.6655 What records must I keep?

- (a) If you must comply with the emission and operating limitations, you must keep the records described in paragraphs (a)(1) through (a)(5), (b)(1) through (b)(3) and (c) of this section.
  - (1) A copy of each notification and report that you submitted to comply with this subpart, including all documentation supporting any Initial Notification or Notification of Compliance Status that you submitted, according to the requirement in § 63.10(b)(2)(xiv).
  - (2) Records of the occurrence and duration (in hours) of each malfunction of operation (i.e., process equipment) or the air pollution control and monitoring equipment.
  - (3) Records of performance tests and performance evaluations as required in § 63.10(b)(2)(viii).
  - (4) Records of all required maintenance performed on the air pollution control and monitoring equipment.
  - (5) Records of actions taken during periods of malfunction to minimize emissions in accordance with § 63.6605(b), including corrective actions to restore malfunctioning process and air pollution control and monitoring equipment to its normal or usual manner of operation.
- (b) For each CEMS or CPMS, you must keep the records listed in paragraphs (b)(1) through (3) of this section.
  - (1) Records described in § 63.10(b)(2)(vi) through (xi).

- (2) Previous (i.e., superseded) versions of the performance evaluation plan as required in § 63.8(d)(3).
- (3) Requests for alternatives to the relative accuracy test for CEMS or CPMS as required in § 63.8(f)(6)(i), if applicable.
- (c) If you are operating a new or reconstructed stationary RICE which fires landfill gas or digester gas equivalent to 10 percent or more of the gross heat input on an annual basis, you must keep the records of your daily fuel usage monitors.
- (d) You must keep the records required in Table 6 of this subpart to show continuous compliance with each emission or operating limitation that applies to you.
- (e) You must keep records of the maintenance conducted on the stationary RICE in order to demonstrate that you operated and maintained the stationary RICE and after-treatment control device (if any) according to your own maintenance plan if you own or operate any of the following stationary RICE;
  - (1) An existing stationary RICE with a site rating of less than 100 brake HP located at a major source of HAP emissions.
  - (2) An existing stationary emergency RICE.
  - (3) An existing stationary RICE located at an area source of HAP emissions subject to management practices as shown in Table 2d to this subpart.
- (f) If you own or operate any of the stationary RICE in paragraphs (f)(1) through (2) of this section, you must keep records of the hours of operation of the engine that is recorded through the non-resettable hour meter. The owner or operator must document how many hours are spent for emergency operation, including what classified the operation as emergency and how many hours are spent for non-emergency operation. If the engine is used for the purpose specified in § 63.6640(f)(4)(ii), the owner or operator must keep records of the notification of the emergency situation, and the date, start time, and end time of engine operation for these purposes.
  - (1) An existing emergency stationary RICE with a site rating of less than or equal to 500 brake HP located at a major source of HAP emissions that does not meet the standards applicable to non-emergency engines.
  - (2) An existing emergency stationary RICE located at an area source of HAP emissions that does not meet the standards applicable to non-emergency engines.

[69 FR 33506, June 15, 2004, as amended at 75 FR 9678, Mar. 3, 2010; 75 FR 51592, Aug. 20, 2010; 78 FR 6706, Jan. 30, 2013; 87 FR 48607, Aug. 10, 2022; 89 FR 70518, Aug. 30, 2024]

### § 63.6660 In what form and how long must I keep my records?

- (a) Your records must be in a form suitable and readily available for expeditious review according to § 63.10(b)(1).
- (b) As specified in § 63.10(b)(1), you must keep each record for 5 years following the date of each occurrence, measurement, maintenance, corrective action, report, or record.
- (c) You must keep each record readily accessible in hard copy or electronic form for at least 5 years after the date of each occurrence, measurement, maintenance, corrective action, report, or record, according to § 63.10(b)(1).



[69 FR 33506, June 15, 2004, as amended at 75 FR 9678, Mar. 3, 2010]

## OTHER REQUIREMENTS AND INFORMATION

### § 63.6665 What parts of the General Provisions apply to me?

Table 8 to this subpart shows which parts of the General Provisions in §§ 63.1 through 63.15 apply to you. If you own or operate a new or reconstructed stationary RICE with a site rating of less than or equal to 500 brake HP located at a major source of HAP emissions (except new or reconstructed 4SLB engines greater than or equal to 250 and less than or equal to 500 brake HP), a new or reconstructed stationary RICE located at an area source of HAP emissions, or any of the following RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions, you do not need to comply with any of the requirements of the General Provisions specified in Table 8: An existing 2SLB stationary RICE, an existing 4SLB stationary RICE, an existing stationary RICE that combusts landfill or digester gas equivalent to 10 percent or more of the gross heat input on an annual basis, an existing emergency stationary RICE, or an existing limited use stationary RICE. If you own or operate any of the following RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions, you do not need to comply with the requirements in the General Provisions specified in Table 8 except for the initial notification requirements: A new stationary RICE that combusts landfill gas or digester gas equivalent to 10 percent or more of the gross heat input on an annual basis, a new emergency stationary RICE, or a new limited use stationary RICE.

[75 FR 9678, Mar. 3, 2010]

### § 63.6670 Who implements and enforces this subpart?

- (a) This subpart is implemented and enforced by the U.S. EPA, or a delegated authority such as your State, local, or tribal agency. If the U.S. EPA Administrator has delegated authority to your State, local, or tribal agency, then that agency (as well as the U.S. EPA) has the authority to implement and enforce this subpart. You should contact your U.S. EPA Regional Office to find out whether this subpart is delegated to your State, local, or tribal agency.
- (b) In delegating implementation and enforcement authority of this subpart to a State, local, or tribal agency under 40 CFR part 63, subpart E, the authorities contained in paragraph (c) of this section are retained by the Administrator of the U.S. EPA and are not transferred to the State, local, or tribal agency.
- (c) The authorities that will not be delegated to State, local, or tribal agencies are:
  - (1) Approval of alternatives to the non-opacity emission limitations and operating limitations in § 63.6600 under § 63.6(g).
  - (2) Approval of major alternatives to test methods under § 63.7(e)(2)(ii) and (f) and as defined in § 63.90.
  - (3) Approval of major alternatives to monitoring under § 63.8(f) and as defined in § 63.90.
  - (4) Approval of major alternatives to recordkeeping and reporting under § 63.10(f) and as defined in § 63.90.
  - (5) Approval of a performance test which was conducted prior to the effective date of the rule, as specified in § 63.6610(b).
  - (6) Approval of an alternative to any electronic reporting to the EPA required by this subpart.

[69 FR 33506, June 15, 2004, as amended at 89 FR 70518, Aug. 30, 2024]

## § 63.6675 What definitions apply to this subpart?

Terms used in this subpart are defined in the Clean Air Act (CAA); in 40 CFR 63.2, the General Provisions of this part; and in this section as follows:

**Alaska Railbelt Grid** means the service areas of the six regulated public utilities that extend from Fairbanks to Anchorage and the Kenai Peninsula. These utilities are Golden Valley Electric Association; Chugach Electric Association; Matanuska Electric Association; Homer Electric Association; Anchorage Municipal Light & Power; and the City of Seward Electric System.

**Area source** means any stationary source of HAP that is not a major source as defined in part 63.

**Associated equipment** as used in this subpart and as referred to in section 112(n)(4) of the CAA, means equipment associated with an oil or natural gas exploration or production well, and includes all equipment from the well bore to the point of custody transfer, except glycol dehydration units, storage vessels with potential for flash emissions, combustion turbines, and stationary RICE.

**Backup power for renewable energy** means an engine that provides backup power to a facility that generates electricity from renewable energy resources, as that term is defined in Alaska Statute 42.45.045(l)(5) (incorporated by reference, see § 63.14).

**Black start engine** means an engine whose only purpose is to start up a combustion turbine.

**CAA** means the Clean Air Act (42 U.S.C. 7401 *et seq.*, as amended by Public Law 101-549, 104 Stat. 2399).

**Commercial emergency stationary RICE** means an emergency stationary RICE used in commercial establishments such as office buildings, hotels, stores, telecommunications facilities, restaurants, financial institutions such as banks, doctor's offices, and sports and performing arts facilities.

**Compression ignition** means relating to a type of stationary internal combustion engine that is not a spark ignition engine.

**Custody transfer** means the transfer of hydrocarbon liquids or natural gas: After processing and/or treatment in the producing operations, or from storage vessels or automatic transfer facilities or other such equipment, including product loading racks, to pipelines or any other forms of transportation. For the purposes of this subpart, the point at which such liquids or natural gas enters a natural gas processing plant is a point of custody transfer.

**Deviation** means any instance in which an affected source subject to this subpart, or an owner or operator of such a source:

- (1) Fails to meet any requirement or obligation established by this subpart, including but not limited to any emission limitation or operating limitation;
- (2) Fails to meet any term or condition that is adopted to implement an applicable requirement in this subpart and that is included in the operating permit for any affected source required to obtain such a permit; or
- (3) Fails to meet any emission limitation or operating limitation in this subpart during malfunction, regardless or whether or not such failure is permitted by this subpart.
- (4) Fails to satisfy the general duty to minimize emissions established by § 63.6(e)(1)(i).

**Diesel engine** means any stationary RICE in which a high boiling point liquid fuel injected into the combustion chamber ignites when the air charge has been compressed to a temperature sufficiently high for auto-ignition. This process is also known as compression ignition.

**Diesel fuel** means any liquid obtained from the distillation of petroleum with a boiling point of approximately 150 to 360 degrees Celsius. One commonly used form is fuel oil number 2. Diesel fuel also includes any non-distillate fuel with comparable physical and chemical properties (e.g. biodiesel) that is suitable for use in compression ignition engines.

**Digester gas** means any gaseous by-product of wastewater treatment typically formed through the anaerobic decomposition of organic waste materials and composed principally of methane and CO<sub>2</sub>.

**Dual-fuel engine** means any stationary RICE in which a liquid fuel (typically diesel fuel) is used for compression ignition and gaseous fuel (typically natural gas) is used as the primary fuel.

**Emergency stationary RICE** means any stationary reciprocating internal combustion engine that meets all of the criteria in paragraphs (1) through (3) of this definition. All emergency stationary RICE must comply with the requirements specified in § 63.6640(f) in order to be considered emergency stationary RICE. If the engine does not comply with the requirements specified in § 63.6640(f), then it is not considered to be an emergency stationary RICE under this subpart.

- (1) The stationary RICE is operated to provide electrical power or mechanical work during an emergency situation. Examples include stationary RICE used to produce power for critical networks or equipment (including power supplied to portions of a facility) when electric power from the local utility (or the normal power source, if the facility runs on its own power production) is interrupted, or stationary RICE used to pump water in the case of fire or flood, etc.
- (2) The stationary RICE is operated under limited circumstances for situations not included in paragraph (1) of this definition, as specified in § 63.6640(f).
- (3) The stationary RICE operates as part of a financial arrangement with another entity in situations not included in paragraph (1) of this definition only as allowed in § 63.6640(f)(4)(i) or (ii).

**Engine startup** means the time from initial start until applied load and engine and associated equipment reaches steady state or normal operation. For stationary engine with catalytic controls, engine startup means the time from initial start until applied load and engine and associated equipment, including the catalyst, reaches steady state or normal operation.

**Four-stroke engine** means any type of engine which completes the power cycle in two crankshaft revolutions, with intake and compression strokes in the first revolution and power and exhaust strokes in the second revolution.

**Gaseous fuel** means a material used for combustion which is in the gaseous state at standard atmospheric temperature and pressure conditions.

**Gasoline** means any fuel sold in any State for use in motor vehicles and motor vehicle engines, or nonroad or stationary engines, and commonly or commercially known or sold as gasoline.

**Glycol dehydration unit** means a device in which a liquid glycol (including, but not limited to, ethylene glycol, diethylene glycol, or triethylene glycol) absorbent directly contacts a natural gas stream and absorbs water in a contact tower or absorption column (absorber). The glycol contacts and absorbs water vapor and other gas stream constituents from the natural gas and becomes "rich" glycol. This glycol is then regenerated in the glycol dehydration unit reboiler. The "lean" glycol is then recycled.

**Hazardous air pollutants (HAP)** means any air pollutants listed in or pursuant to section 112(b) of the CAA.

**Institutional emergency stationary RICE** means an emergency stationary RICE used in institutional establishments such as medical centers, nursing homes, research centers, institutions of higher education, correctional facilities, elementary and secondary schools, libraries, religious establishments, police stations, and fire stations.

**ISO standard day conditions** means 288 degrees Kelvin (15 degrees Celsius), 60 percent relative humidity and 101.3 kilopascals pressure.

**Landfill gas** means a gaseous by-product of the land application of municipal refuse typically formed through the anaerobic decomposition of waste materials and composed principally of methane and CO<sub>2</sub>.

**Lean burn engine** means any two-stroke or four-stroke spark ignited engine that does not meet the definition of a rich burn engine.

**Limited use stationary RICE** means any stationary RICE that operates less than 100 hours per year.

**Liquefied petroleum gas** means any liquefied hydrocarbon gas obtained as a by-product in petroleum refining of natural gas production.

**Liquid fuel** means any fuel in liquid form at standard temperature and pressure, including but not limited to diesel, residual/crude oil, kerosene/naphtha (jet fuel), and gasoline.

**Major Source**, as used in this subpart, shall have the same meaning as in § 63.2, except that:

- (1) Emissions from any oil or gas exploration or production well (with its associated equipment (as defined in this section)) and emissions from any pipeline compressor station or pump station shall not be aggregated with emissions from other similar units, to determine whether such emission points or stations are major sources, even when emission points are in a contiguous area or under common control;
- (2) For oil and gas production facilities, emissions from processes, operations, or equipment that are not part of the same oil and gas production facility, as defined in § 63.1271 of subpart HHH of this part, shall not be aggregated;
- (3) For production field facilities, only HAP emissions from glycol dehydration units, storage vessel with the potential for flash emissions, combustion turbines and reciprocating internal combustion engines shall be aggregated for a major source determination; and
- (4) Emissions from processes, operations, and equipment that are not part of the same natural gas transmission and storage facility, as defined in § 63.1271 of subpart HHH of this part, shall not be aggregated.

**Malfunction** means any sudden, infrequent, and not reasonably preventable failure of air pollution control equipment, process equipment, or a process to operate in a normal or usual manner which causes, or has the potential to cause, the emission limitations in an applicable standard to be exceeded. Failures that are caused in part by poor maintenance or careless operation are not malfunctions.

**Natural gas** means a naturally occurring mixture of hydrocarbon and non-hydrocarbon gases found in geologic formations beneath the Earth's surface, of which the principal constituent is methane. Natural gas may be field or pipeline quality.

**Non-selective catalytic reduction (NSCR)** means an add-on catalytic nitrogen oxides (NO<sub>x</sub>) control device for rich burn engines that, in a two-step reaction, promotes the conversion of excess oxygen, NO<sub>x</sub>, CO, and volatile organic compounds (VOC) into CO<sub>2</sub>, nitrogen, and water.

**Oil and gas production facility** as used in this subpart means any grouping of equipment where hydrocarbon liquids are processed, upgraded (*i.e.*, remove impurities or other constituents to meet contract specifications), or stored prior to the point of custody transfer; or where natural gas is processed, upgraded, or stored prior to entering the natural gas transmission and storage source category. For purposes of a major source determination, facility (including a building, structure, or installation) means oil and natural gas production and processing equipment that is located within the boundaries of an individual surface site as defined in this section. Equipment that is part of a facility will typically be located within close proximity to other equipment located at the same facility. Pieces of production equipment or groupings of equipment located on different oil and gas leases, mineral fee tracts, lease tracts, subsurface or surface unit areas, surface fee tracts, surface lease tracts, or separate surface sites, whether or not connected by a road, waterway, power line or pipeline, shall not be considered part of the same facility. Examples of facilities in the oil and natural gas production source category include, but are not limited to, well sites, satellite tank batteries, central tank batteries, a compressor station that transports natural gas to a natural gas processing plant, and natural gas processing plants.

**Oxidation catalyst** means an add-on catalytic control device that controls CO and VOC by oxidation.

**Peaking unit or engine** means any standby engine intended for use during periods of high demand that are not emergencies.

**Percent load** means the fractional power of an engine compared to its maximum manufacturer's design capacity at engine site conditions. Percent load may range between 0 percent to above 100 percent.

**Potential to emit** means the maximum capacity of a stationary source to emit a pollutant under its physical and operational design. Any physical or operational limitation on the capacity of the stationary source to emit a pollutant, including air pollution control equipment and restrictions on hours of operation or on the type or amount of material combusted, stored, or processed, shall be treated as part of its design if the limitation or the effect it would have on emissions is federally enforceable. For oil and natural gas production facilities subject to subpart HH of this part, the potential to emit provisions in § 63.760(a) may be used. For natural gas transmission and storage facilities subject to subpart HHH of this part, the maximum annual facility gas throughput for storage facilities may be determined according to § 63.1270(a)(1) and the maximum annual throughput for transmission facilities may be determined according to § 63.1270(a)(2).

**Production field facility** means those oil and gas production facilities located prior to the point of custody transfer.

**Production well** means any hole drilled in the earth from which crude oil, condensate, or field natural gas is extracted.

**Propane** means a colorless gas derived from petroleum and natural gas, with the molecular structure C<sub>3</sub>H<sub>8</sub>.

**Remote stationary RICE** means stationary RICE meeting any of the following criteria:

- (1) Stationary RICE located in an offshore area that is beyond the line of ordinary low water along that portion of the coast of the United States that is in direct contact with the open seas and beyond the line marking the seaward limit of inland waters.

- (2) Stationary RICE located on a pipeline segment that meets both of the criteria in paragraphs (2)(i) and (ii) of this definition.
  - (i) A pipeline segment with 10 or fewer buildings intended for human occupancy and no buildings with four or more stories within 220 yards (200 meters) on either side of the centerline of any continuous 1-mile (1.6 kilometers) length of pipeline. Each separate dwelling unit in a multiple dwelling unit building is counted as a separate building intended for human occupancy.
  - (ii) The pipeline segment does not lie within 100 yards (91 meters) of either a building or a small, well-defined outside area (such as a playground, recreation area, outdoor theater, or other place of public assembly) that is occupied by 20 or more persons on at least 5 days a week for 10 weeks in any 12-month period. The days and weeks need not be consecutive. The building or area is considered occupied for a full day if it is occupied for any portion of the day.
  - (iii) For purposes of this paragraph (2), the term pipeline segment means all parts of those physical facilities through which gas moves in transportation, including but not limited to pipe, valves, and other appurtenance attached to pipe, compressor units, metering stations, regulator stations, delivery stations, holders, and fabricated assemblies. Stationary RICE located within 50 yards (46 meters) of the pipeline segment providing power for equipment on a pipeline segment are part of the pipeline segment. Transportation of gas means the gathering, transmission, or distribution of gas by pipeline, or the storage of gas. A building is intended for human occupancy if its primary use is for a purpose involving the presence of humans.
- (3) Stationary RICE that are not located on gas pipelines and that have 5 or fewer buildings intended for human occupancy and no buildings with four or more stories within a 0.25 mile radius around the engine. A building is intended for human occupancy if its primary use is for a purpose involving the presence of humans.

**Residential emergency stationary RICE** means an emergency stationary RICE used in residential establishments such as homes or apartment buildings.

**Responsible official** means responsible official as defined in 40 CFR 70.2.

**Rich burn engine** means any four-stroke spark ignited engine where the manufacturer's recommended operating air/fuel ratio divided by the stoichiometric air/fuel ratio at full load conditions is less than or equal to 1.1. Engines originally manufactured as rich burn engines, but modified prior to December 19, 2002 with passive emission control technology for NO<sub>x</sub> (such as pre-combustion chambers) will be considered lean burn engines. Also, existing engines where there are no manufacturer's recommendations regarding air/fuel ratio will be considered a rich burn engine if the excess oxygen content of the exhaust at full load conditions is less than or equal to 2 percent.

**Site-rated HP** means the maximum manufacturer's design capacity at engine site conditions.

**Spark ignition** means relating to either: A gasoline-fueled engine; or any other type of engine with a spark plug (or other sparking device) and with operating characteristics significantly similar to the theoretical Otto combustion cycle. Spark ignition engines usually use a throttle to regulate intake air flow to control power during normal operation. Dual-fuel engines in which a liquid fuel (typically diesel fuel) is used for CI and gaseous fuel (typically natural gas) is used as the primary fuel at an annual average ratio of less than 2 parts diesel fuel to 100 parts total fuel on an energy equivalent basis are spark ignition engines.

**Stationary reciprocating internal combustion engine (RICE)** means any reciprocating internal combustion engine which uses reciprocating motion to convert heat energy into mechanical work and which is not mobile. Stationary RICE differ from mobile RICE in that a stationary RICE is not a non-road engine as defined at 40 CFR 1068.30, and is not used to propel a motor vehicle or a vehicle used solely for competition.

**Stationary RICE test cell/stand** means an engine test cell/stand, as defined in subpart PPPPP of this part, that tests stationary RICE.

**Stoichiometric** means the theoretical air-to-fuel ratio required for complete combustion.

**Storage vessel with the potential for flash emissions** means any storage vessel that contains a hydrocarbon liquid with a stock tank gas-to-oil ratio equal to or greater than 0.31 cubic meters per liter and an American Petroleum Institute gravity equal to or greater than 40 degrees and an actual annual average hydrocarbon liquid throughput equal to or greater than 79,500 liters per day. Flash emissions occur when dissolved hydrocarbons in the fluid evolve from solution when the fluid pressure is reduced.

**Subpart** means 40 CFR part 63, subpart ZZZZ.

**Surface site** means any combination of one or more graded pad sites, gravel pad sites, foundations, platforms, or the immediate physical location upon which equipment is physically affixed.

**Two-stroke engine** means a type of engine which completes the power cycle in single crankshaft revolution by combining the intake and compression operations into one stroke and the power and exhaust operations into a second stroke. This system requires auxiliary scavenging and inherently runs lean of stoichiometric.

[69 FR 33506, June 15, 2004, as amended at 71 FR 20467, Apr. 20, 2006; 73 FR 3607, Jan. 18, 2008; 75 FR 9679, Mar. 3, 2010; 75 FR 51592, Aug. 20, 2010; 76 FR 12867, Mar. 9, 2011; 78 FR 6706, Jan. 30, 2013; 87 FR 48608, Aug. 10, 2022]

### Table 1a to Subpart ZZZZ of Part 63—Emission Limitations for Existing, New, and Reconstructed Spark Ignition, 4SRB Stationary RICE >500 HP Located at a Major Source of HAP Emissions

As stated in §§ 63.6600 and 63.6640, you must comply with the following emission limitations at 100 percent load plus or minus 10 percent for existing, new and reconstructed 4SRB stationary RICE >500 HP located at a major source of HAP emissions:

For each . . .	You must meet the following emission limitation, except during periods of startup . . .	During periods of startup you must . . .
1. 4SRB stationary RICE	a. Reduce formaldehyde emissions by 76 percent or more. If you commenced construction or reconstruction between December 19, 2002 and June 15, 2004, you may reduce formaldehyde emissions by 75 percent or more until June 15, 2007 or	Minimize the engine's time spent at idle and minimize the engine's startup time at startup to a period needed for appropriate and safe loading of the engine, not to exceed 30 minutes, after which time the non-startup emission limitations apply. <sup>1</sup>

<sup>1</sup> Sources can petition the Administrator pursuant to the requirements of 40 CFR 63.6(g) for alternative work practices.

For each . . .	You must meet the following emission limitation, except during periods of startup . . .	During periods of startup you must . . .
	b. Limit the concentration of formaldehyde in the stationary RICE exhaust to 350 ppbvd or less at 15 percent O <sub>2</sub>	

<sup>1</sup> Sources can petition the Administrator pursuant to the requirements of 40 CFR 63.6(g) for alternative work practices.

[75 FR 9679, Mar. 3, 2010, as amended at 75 FR 51592, Aug. 20, 2010]

### Table 1b to Subpart ZZZZ of Part 63—Operating Limitations for Existing, New, and Reconstructed SI 4SRB Stationary RICE >500 HP Located at a Major Source of HAP Emissions

As stated in §§ 63.6600, 63.6603, 63.6630 and 63.6640, you must comply with the following operating limitations for existing, new and reconstructed 4SRB stationary RICE >500 HP located at a major source of HAP emissions:

For each . . .	You must meet the following operating limitation, except during periods of startup . . .
1. existing, new and reconstructed 4SRB stationary RICE >500 HP located at a major source of HAP emissions complying with the requirement to reduce formaldehyde emissions by 76 percent or more (or by 75 percent or more, if applicable) and using NSCR; or existing, new and reconstructed 4SRB stationary RICE >500 HP located at a major source of HAP emissions complying with the requirement to limit the concentration of formaldehyde in the stationary RICE exhaust to 350 ppbvd or less at 15 percent O <sub>2</sub> and using NSCR;	a. maintain your catalyst so that the pressure drop across the catalyst does not change by more than 2 inches of water at 100 percent load plus or minus 10 percent from the pressure drop across the catalyst measured during the initial performance test; and b. maintain the temperature of your stationary RICE exhaust so that the catalyst inlet temperature is greater than or equal to 750 °F and less than or equal to 1250 °F. <sup>1</sup>
2. existing, new and reconstructed 4SRB stationary RICE >500 HP located at a major source of HAP emissions complying with the requirement to reduce formaldehyde emissions by 76 percent or more (or by 75 percent or more, if applicable) and not using NSCR; or existing, new and reconstructed 4SRB stationary RICE >500 HP located at a major source of HAP	Comply with any operating limitations approved by the Administrator.

<sup>1</sup> Sources can petition the Administrator pursuant to the requirements of 40 CFR 63.8(f) for a different temperature range.



For each . . .	You must meet the following operating limitation, except during periods of startup . . .
emissions complying with the requirement to limit the concentration of formaldehyde in the stationary RICE exhaust to 350 ppbvd or less at 15 percent O <sub>2</sub> and not using NSCR.	

<sup>1</sup> Sources can petition the Administrator pursuant to the requirements of 40 CFR 63.8(f) for a different temperature range.

[78 FR 6706, Jan. 30, 2013]

### Table 2a to Subpart ZZZZ of Part 63—Emission Limitations for New and Reconstructed 2SLB and Compression Ignition Stationary RICE >500 HP and New and Reconstructed 4SLB Stationary RICE ≥250 HP Located at a Major Source of HAP Emissions

As stated in §§ 63.6600 and 63.6640, you must comply with the following emission limitations for new and reconstructed lean burn and new and reconstructed compression ignition stationary RICE at 100 percent load plus or minus 10 percent:

For each . . .	You must meet the following emission limitation, except during periods of startup . . .	During periods of startup you must . . .
1. 2SLB stationary RICE	a. Reduce CO emissions by 58 percent or more; or b. Limit concentration of formaldehyde in the stationary RICE exhaust to 12 ppmvd or less at 15 percent O <sub>2</sub> . If you commenced construction or reconstruction between December 19, 2002 and June 15, 2004, you may limit concentration of formaldehyde to 17 ppmvd or less at 15 percent O <sub>2</sub> until June 15, 2007	Minimize the engine's time spent at idle and minimize the engine's startup time at startup to a period needed for appropriate and safe loading of the engine, not to exceed 30 minutes, after which time the non-startup emission limitations apply. <sup>1</sup>
2. 4SLB stationary RICE	a. Reduce CO emissions by 93 percent or more; or b. Limit concentration of formaldehyde in the stationary RICE exhaust to 14 ppmvd or less at 15 percent O <sub>2</sub>	
3. CI stationary RICE	a. Reduce CO emissions by 70 percent or more; or	

<sup>1</sup> Sources can petition the Administrator pursuant to the requirements of 40 CFR 63.6(g) for alternative work practices.

For each . . .	You must meet the following emission limitation, except during periods of startup . . .	During periods of startup you must . . .
	b. Limit concentration of formaldehyde in the stationary RICE exhaust to 580 ppbvd or less at 15 percent O <sub>2</sub>	

<sup>1</sup> Sources can petition the Administrator pursuant to the requirements of 40 CFR 63.6(g) for alternative work practices.

[75 FR 9680, Mar. 3, 2010]

**Table 2b to Subpart ZZZZ of Part 63—Operating Limitations for New and Reconstructed 2SLB and CI Stationary RICE >500 HP Located at a Major Source of HAP Emissions, New and Reconstructed 4SLB Stationary RICE ≥250 HP Located at a Major Source of HAP Emissions, Existing CI Stationary RICE >500 HP**

As stated in §§ 63.6600, 63.6601, 63.6603, 63.6630, and 63.6640, you must comply with the following operating limitations for new and reconstructed 2SLB and CI stationary RICE >500 HP located at a major source of HAP emissions; new and reconstructed 4SLB stationary RICE ≥250 HP located at a major source of HAP emissions; and existing CI stationary RICE >500 HP:

For each . . .	You must meet the following operating limitation, except during periods of startup . . .
1. New and reconstructed 2SLB and CI stationary RICE >500 HP located at a major source of HAP emissions and new and reconstructed 4SLB stationary RICE ≥250 HP located at a major source of HAP emissions complying with the requirement to reduce CO emissions and using an oxidation catalyst; and New and reconstructed 2SLB and CI stationary RICE >500 HP located at a major source of HAP emissions and new and reconstructed 4SLB stationary RICE ≥250 HP located at a major source of HAP emissions complying with the requirement to limit the concentration of formaldehyde in the stationary RICE exhaust and using an oxidation catalyst.	a. maintain your catalyst so that the pressure drop across the catalyst does not change by more than 2 inches of water at 100 percent load plus or minus 10 percent from the pressure drop across the catalyst that was measured during the initial performance test; and b. maintain the temperature of your stationary RICE exhaust so that the catalyst inlet temperature is greater than or equal to 450 °F and less than or equal to 1350 °F. <sup>1</sup>
2. Existing CI stationary RICE >500 HP complying with the requirement to limit or reduce the concentration of CO in the stationary RICE exhaust and using an	a. maintain your catalyst so that the pressure drop across the catalyst does not change by more than 2 inches of

<sup>1</sup> Sources can petition the Administrator pursuant to the requirements of 40 CFR 63.8(f) for a different temperature range.

For each . . .	You must meet the following operating limitation, except during periods of startup . . .
<p>oxidation catalyst</p> <p>3. New and reconstructed 2SLB and CI stationary RICE &gt;500 HP located at a major source of HAP emissions and new and reconstructed 4SLB stationary RICE ≥250 HP located at a major source of HAP emissions complying with the requirement to reduce CO emissions and not using an oxidation catalyst; and New and reconstructed 2SLB and CI stationary RICE &gt;500 HP located at a major source of HAP emissions and new and reconstructed 4SLB stationary RICE ≥250 HP located at a major source of HAP emissions complying with the requirement to limit the concentration of formaldehyde in the stationary RICE exhaust and not using an oxidation catalyst; and existing CI stationary RICE &gt;500 HP complying with the requirement to limit or reduce the concentration of CO in the stationary RICE exhaust and not using an oxidation catalyst.</p>	<p>a. water from the pressure drop across the catalyst that was measured during the initial performance test; and</p> <p>b. maintain the temperature of your stationary RICE exhaust so that the catalyst inlet temperature is greater than or equal to 450 °F and less than or equal to 1350 °F.<sup>1</sup></p> <p>Comply with any operating limitations approved by the Administrator.</p>

<sup>1</sup> Sources can petition the Administrator pursuant to the requirements of 40 CFR 63.8(f) for a different temperature range.

[78 FR 6707, Jan. 30, 2013]

**Table 2c to Subpart ZZZZ of Part 63—Requirements for Existing Compression Ignition Stationary RICE Located at a Major Source of HAP Emissions and Existing Spark Ignition Stationary RICE ≤500 HP Located at a Major Source of HAP Emissions**

As stated in §§ 63.6600, 63.6602, and 63.6640, you must comply with the following requirements for existing compression ignition stationary RICE located at a major source of HAP emissions and existing spark ignition stationary RICE ≤500 HP located at a major source of HAP emissions

For each . . .	You must meet the following requirement, except during periods of startup . . .	During periods of startup you must . . .
1. Emergency stationary CI RICE and black start stationary CI RICE <sup>1</sup>	<p>a. Change oil and filter every 500 hours of operation or within 1 year + 30 days of the previous change, whichever comes first <sup>2</sup>.</p> <p>b. Inspect air cleaner every 1,000 hours of operation or within 1 year + 30 days of the previous inspection, whichever comes first, and replace as necessary;</p> <p>c. Inspect all hoses and belts every 500 hours of operation or within 1 year + 30 days of the previous inspection, whichever comes first, and replace as necessary <sup>3</sup></p>	Minimize the engine's time spent at idle and minimize the engine's startup time at startup to a period needed for appropriate and safe loading of the engine, not to exceed 30 minutes, after which time the non-startup emission limitations apply. <sup>3</sup>

<sup>1</sup> If an emergency engine is operating during an emergency and it is not possible to shut down the engine in order to perform the work practice requirements on the schedule required in table 2c of this subpart, or if performing the work practice on the required schedule would otherwise pose an unacceptable risk under Federal, state, or local law, the work practice can be delayed until the emergency is over or the unacceptable risk under Federal, state, or local law has abated. The work practice should be performed as soon as practicable after the emergency has ended or the unacceptable risk under Federal, state, or local law has abated. Sources must report any failure to perform the work practice on the schedule required and the Federal, state or local law under which the risk was deemed unacceptable.

<sup>2</sup> Sources have the option to utilize an oil analysis program as described in § 63.6625(i) or (j) in order to extend the specified oil change requirement in table 2c of this subpart.

<sup>3</sup> Sources can petition the Administrator pursuant to the requirements of 40 CFR 63.6(g) for alternative work practices.

For each . . .	You must meet the following requirement, except during periods of startup . . .	During periods of startup you must . . .
2. Non-Emergency, non-black start stationary CI RICE <100 HP	<p>a. Change oil and filter every 1,000 hours of operation or within 1 year + 30 days of the previous change, whichever comes first <sup>2</sup>.</p> <p>b. Inspect air cleaner every 1,000 hours of operation or within 1 year + 30 days of the previous inspection, whichever comes first, and replace as necessary;</p> <p>c. Inspect all hoses and belts every 500 hours of operation or within 1 year + 30 days of the previous inspection, whichever comes first, and replace as necessary <sup>3</sup></p>	
3. Non-Emergency, non-black start CI stationary RICE 100≤HP≤300 HP	Limit concentration of CO in the stationary RICE exhaust to 230 ppmvd or less at 15 percent O <sub>2</sub>	
4. Non-Emergency, non-black start CI stationary RICE 300<HP≤500	a. Limit concentration of CO in the stationary RICE exhaust to 49 ppmvd or less at 15 percent O <sub>2</sub> ; or	

<sup>1</sup> If an emergency engine is operating during an emergency and it is not possible to shut down the engine in order to perform the work practice requirements on the schedule required in table 2c of this subpart, or if performing the work practice on the required schedule would otherwise pose an unacceptable risk under Federal, state, or local law, the work practice can be delayed until the emergency is over or the unacceptable risk under Federal, state, or local law has abated. The work practice should be performed as soon as practicable after the emergency has ended or the unacceptable risk under Federal, state, or local law has abated. Sources must report any failure to perform the work practice on the schedule required and the Federal, state or local law under which the risk was deemed unacceptable.

<sup>2</sup> Sources have the option to utilize an oil analysis program as described in § 63.6625(i) or (j) in order to extend the specified oil change requirement in table 2c of this subpart.

<sup>3</sup> Sources can petition the Administrator pursuant to the requirements of 40 CFR 63.6(g) for alternative work practices.

For each . . .	You must meet the following requirement, except during periods of startup . . .	During periods of startup you must . . .
<p>5. Non-Emergency, non-black start stationary CI RICE &gt;500 HP</p> <p>6. Emergency stationary SI RICE and black start stationary SI RICE.<sup>1</sup></p>	<p>b. Reduce CO emissions by 70 percent or more</p> <p>a. Limit concentration of CO in the stationary RICE exhaust to 23 ppmvd or less at 15 percent O<sub>2</sub>; or</p> <p>b. Reduce CO emissions by 70 percent or more</p> <p>a. Change oil and filter every 500 hours of operation or within 1 year + 30 days of the previous change, whichever comes first;<sup>2</sup></p> <p>b. Inspect spark plugs every 1,000 hours of operation or within 1 year + 30 days of the previous inspection, whichever comes first, and replace as necessary;</p> <p>c. Inspect all hoses and belts every 500 hours of operation or within 1 year + 30 days of the previous inspection, whichever comes first, and replace as necessary<sup>3</sup></p>	

<sup>1</sup> If an emergency engine is operating during an emergency and it is not possible to shut down the engine in order to perform the work practice requirements on the schedule required in table 2c of this subpart, or if performing the work practice on the required schedule would otherwise pose an unacceptable risk under Federal, state, or local law, the work practice can be delayed until the emergency is over or the unacceptable risk under Federal, state, or local law has abated. The work practice should be performed as soon as practicable after the emergency has ended or the unacceptable risk under Federal, state, or local law has abated. Sources must report any failure to perform the work practice on the schedule required and the Federal, state or local law under which the risk was deemed unacceptable.

<sup>2</sup> Sources have the option to utilize an oil analysis program as described in § 63.6625(i) or (j) in order to extend the specified oil change requirement in table 2c of this subpart.

<sup>3</sup> Sources can petition the Administrator pursuant to the requirements of 40 CFR 63.6(g) for alternative work practices.

For each . . .	You must meet the following requirement, except during periods of startup . . .	During periods of startup you must . . .
7. Non-Emergency, non-black start stationary SI RICE <100 HP that are not 2SLB stationary RICE	<p>a. Change oil and filter every 1,440 hours of operation or within 1 year + 30 days of the previous change, whichever comes first;<sup>2</sup></p> <p>b. Inspect spark plugs every 1,440 hours of operation or within 1 year + 30 days of the previous inspection, whichever comes first, and replace as necessary</p> <p>c. Inspect all hoses and belts every 1,440 hours of operation or within 1 year + 30 days of the previous inspection, whichever comes first, and replace as necessary<sup>3</sup></p>	
8. Non-Emergency, non-black start 2SLB stationary SI RICE <100 HP	<p>a. Change oil and filter every 4,320 hours of operation or within 1 year + 30 days of the previous change, whichever comes first;<sup>2</sup></p> <p>b. Inspect spark plugs every 4,320 hours of</p>	

<sup>1</sup> If an emergency engine is operating during an emergency and it is not possible to shut down the engine in order to perform the work practice requirements on the schedule required in table 2c of this subpart, or if performing the work practice on the required schedule would otherwise pose an unacceptable risk under Federal, state, or local law, the work practice can be delayed until the emergency is over or the unacceptable risk under Federal, state, or local law has abated. The work practice should be performed as soon as practicable after the emergency has ended or the unacceptable risk under Federal, state, or local law has abated. Sources must report any failure to perform the work practice on the schedule required and the Federal, state or local law under which the risk was deemed unacceptable.

<sup>2</sup> Sources have the option to utilize an oil analysis program as described in § 63.6625(i) or (j) in order to extend the specified oil change requirement in table 2c of this subpart.

<sup>3</sup> Sources can petition the Administrator pursuant to the requirements of 40 CFR 63.6(g) for alternative work practices.

For each . . .	You must meet the following requirement, except during periods of startup . . .	During periods of startup you must . . .
	operation or within 1 year + 30 days of the previous inspection, whichever comes first, and replace as necessary; c. Inspect all hoses and belts every 4,320 hours of operation or within 1 year + 30 days of the previous inspection, whichever comes first, and replace as necessary <sup>3</sup>	
9. Non-emergency, non-black start 2SLB stationary RICE 100≤HP≤500	Limit concentration of CO in the stationary RICE exhaust to 225 ppmvd or less at 15 percent O <sub>2</sub>	
10. Non-emergency, non-black start 4SLB stationary RICE 100≤HP≤500	Limit concentration of CO in the stationary RICE exhaust to 47 ppmvd or less at 15 percent O <sub>2</sub>	
11. Non-emergency, non-black start 4SRB stationary RICE 100≤HP≤500	Limit concentration of formaldehyde in the stationary RICE exhaust to 10.3 ppmvd or less at 15 percent O <sub>2</sub>	
12. Non-emergency, non-black start stationary RICE 100≤HP≤500 which	Limit concentration of CO in the stationary RICE exhaust to 177 ppmvd or	

<sup>1</sup> If an emergency engine is operating during an emergency and it is not possible to shut down the engine in order to perform the work practice requirements on the schedule required in table 2c of this subpart, or if performing the work practice on the required schedule would otherwise pose an unacceptable risk under Federal, state, or local law, the work practice can be delayed until the emergency is over or the unacceptable risk under Federal, state, or local law has abated. The work practice should be performed as soon as practicable after the emergency has ended or the unacceptable risk under Federal, state, or local law has abated. Sources must report any failure to perform the work practice on the schedule required and the Federal, state or local law under which the risk was deemed unacceptable.

<sup>2</sup> Sources have the option to utilize an oil analysis program as described in § 63.6625(i) or (j) in order to extend the specified oil change requirement in table 2c of this subpart.

<sup>3</sup> Sources can petition the Administrator pursuant to the requirements of 40 CFR 63.6(g) for alternative work practices.



For each . . .	You must meet the following requirement, except during periods of startup . . .	During periods of startup you must . . .
combusts landfill or digester gas equivalent to 10 percent or more of the gross heat input on an annual basis	less at 15 percent O <sub>2</sub>	

<sup>1</sup> *If an emergency engine is operating during an emergency and it is not possible to shut down the engine in order to perform the work practice requirements on the schedule required in table 2c of this subpart, or if performing the work practice on the required schedule would otherwise pose an unacceptable risk under Federal, state, or local law, the work practice can be delayed until the emergency is over or the unacceptable risk under Federal, state, or local law has abated. The work practice should be performed as soon as practicable after the emergency has ended or the unacceptable risk under Federal, state, or local law has abated. Sources must report any failure to perform the work practice on the schedule required and the Federal, state or local law under which the risk was deemed unacceptable.*

<sup>2</sup> *Sources have the option to utilize an oil analysis program as described in § 63.6625(i) or (j) in order to extend the specified oil change requirement in table 2c of this subpart.*

<sup>3</sup> *Sources can petition the Administrator pursuant to the requirements of 40 CFR 63.6(g) for alternative work practices.*

[89 FR 70518, Aug. 30, 2024]

## Table 2d to Subpart ZZZZ of Part 63—Requirements for Existing Stationary RICE Located at Area Sources of HAP Emissions

As stated in §§ 63.6603 and 63.6640, you must comply with the following requirements for existing stationary RICE located at area sources of HAP emissions:

For each . . .	You must meet the following requirement, except during periods of startup . . .	During periods of startup you must . . .
1. Non-Emergency, non-black start CI stationary RICE ≤300 HP	<p>a. Change oil and filter every 1,000 hours of operation or within 1 year + 30 days of the previous change, whichever comes first;<sup>1</sup></p> <p>b. Inspect air cleaner every 1,000 hours of operation or within 1 year + 30 days of the previous inspection, whichever comes first, and replace as necessary;</p> <p>c. Inspect all hoses and belts every 500 hours of operation or within 1 year + 30 days of the previous inspection, whichever comes first, and replace as necessary</p>	Minimize the engine's time spent at idle and minimize the engine's startup time at startup to a period needed for appropriate and safe loading of the engine, not to exceed 30 minutes, after which time the non-startup emission limitations apply.

<sup>1</sup> Sources have the option to utilize an oil analysis program as described in § 63.6625(i) or (j) in order to extend the specified oil change requirement in table 2d of this subpart.

<sup>2</sup> If an emergency engine is operating during an emergency and it is not possible to shut down the engine in order to perform the management practice requirements on the schedule required in table 2d of this subpart, or if performing the management practice on the required schedule would otherwise pose an unacceptable risk under Federal, state, or local law, the management practice can be delayed until the emergency is over or the unacceptable risk under Federal, state, or local law has abated. The management practice should be performed as soon as practicable after the emergency has ended or the unacceptable risk under Federal, state, or local law has abated. Sources must report any failure to perform the management practice on the schedule required and the Federal, state or local law under which the risk was deemed unacceptable.

For each . . .	You must meet the following requirement, except during periods of startup . . .	During periods of startup you must . . .
2. Non-Emergency, non-black start CI stationary RICE 300<HP≤500	a. Limit concentration of CO in the stationary RICE exhaust to 49 ppmvd at 15 percent O <sub>2</sub> ; or b. Reduce CO emissions by 70 percent or more	
3. Non-Emergency, non-black start CI stationary RICE >500 HP	a. Limit concentration of CO in the stationary RICE exhaust to 23 ppmvd at 15 percent O <sub>2</sub> ; or b. Reduce CO emissions by 70 percent or more	
4. Emergency stationary CI RICE and black start stationary CI RICE. <sup>2</sup>	a. Change oil and filter every 500 hours of operation or within 1 year + 30 days of the previous change, whichever comes first; <sup>1</sup> b. Inspect air cleaner every 1,000 hours of operation or within 1 year + 30 days of the previous inspection, whichever comes	

<sup>1</sup> Sources have the option to utilize an oil analysis program as described in § 63.6625(i) or (j) in order to extend the specified oil change requirement in table 2d of this subpart.

<sup>2</sup> If an emergency engine is operating during an emergency and it is not possible to shut down the engine in order to perform the management practice requirements on the schedule required in table 2d of this subpart, or if performing the management practice on the required schedule would otherwise pose an unacceptable risk under Federal, state, or local law, the management practice can be delayed until the emergency is over or the unacceptable risk under Federal, state, or local law has abated. The management practice should be performed as soon as practicable after the emergency has ended or the unacceptable risk under Federal, state, or local law has abated. Sources must report any failure to perform the management practice on the schedule required and the Federal, state or local law under which the risk was deemed unacceptable.

For each . . .	You must meet the following requirement, except during periods of startup . . .	During periods of startup you must . . .
<p>5. Emergency stationary SI RICE; black start stationary SI RICE; non-emergency, non-black start 4SLB stationary RICE &gt;500 HP that operate 24 hours or less per calendar year; non-emergency, non-black start 4SRB stationary RICE &gt;500 HP that operate 24 hours or less per calendar year.<sup>2</sup></p>	<p>first, and replace as necessary; and</p> <p>c. Inspect all hoses and belts every 500 hours of operation or within 1 year + 30 days of the previous inspection, whichever comes first, and replace as necessary</p> <p>a. Change oil and filter every 500 hours of operation or within 1 year + 30 days of the previous change, whichever comes first;<sup>1</sup></p> <p>b. Inspect spark plugs every 1,000 hours of operation or within 1 year + 30 days of the previous inspection, whichever comes first, and replace as necessary; and</p> <p>c. Inspect all hoses and belts every 500 hours of operation or</p>	

<sup>1</sup> Sources have the option to utilize an oil analysis program as described in § 63.6625(i) or (j) in order to extend the specified oil change requirement in table 2d of this subpart.

<sup>2</sup> If an emergency engine is operating during an emergency and it is not possible to shut down the engine in order to perform the management practice requirements on the schedule required in table 2d of this subpart, or if performing the management practice on the required schedule would otherwise pose an unacceptable risk under Federal, state, or local law, the management practice can be delayed until the emergency is over or the unacceptable risk under Federal, state, or local law has abated. The management practice should be performed as soon as practicable after the emergency has ended or the unacceptable risk under Federal, state, or local law has abated. Sources must report any failure to perform the management practice on the schedule required and the Federal, state or local law under which the risk was deemed unacceptable.

For each . . .	You must meet the following requirement, except during periods of startup . . .	During periods of startup you must . . .
6. Non-emergency, non-black start 2SLB stationary RICE	<p>within 1 year + 30 days of the previous inspection, whichever comes first, and replace as necessary</p> <p>a. Change oil and filter every 4,320 hours of operation or within 1 year + 30 days of the previous change, whichever comes first;<sup>1</sup></p> <p>b. Inspect spark plugs every 4,320 hours of operation or within 1 year + 30 days of the previous inspection, whichever comes first, and replace as necessary; and</p> <p>c. Inspect all hoses and belts every 4,320 hours of operation or within 1 year + 30 days of the previous inspection, whichever comes first, and replace as necessary</p>	

<sup>1</sup> Sources have the option to utilize an oil analysis program as described in § 63.6625(i) or (j) in order to extend the specified oil change requirement in table 2d of this subpart.

<sup>2</sup> If an emergency engine is operating during an emergency and it is not possible to shut down the engine in order to perform the management practice requirements on the schedule required in table 2d of this subpart, or if performing the management practice on the required schedule would otherwise pose an unacceptable risk under Federal, state, or local law, the management practice can be delayed until the emergency is over or the unacceptable risk under Federal, state, or local law has abated. The management practice should be performed as soon as practicable after the emergency has ended or the unacceptable risk under Federal, state, or local law has abated. Sources must report any failure to perform the management practice on the schedule required and the Federal, state or local law under which the risk was deemed unacceptable.

For each . . .	You must meet the following requirement, except during periods of startup . . .	During periods of startup you must . . .
7. Non-emergency, non-black start 4SLB stationary RICE ≤500 HP	<p>a. Change oil and filter every 1,440 hours of operation or within 1 year + 30 days of the previous change, whichever comes first;<sup>1</sup></p> <p>b. Inspect spark plugs every 1,440 hours of operation or within 1 year + 30 days of the previous inspection, whichever comes first, and replace as necessary; and</p> <p>c. Inspect all hoses and belts every 1,440 hours of operation or within 1 year + 30 days of the previous inspection, whichever comes first, and replace as necessary</p>	
8. Non-emergency, non-black start 4SLB remote stationary RICE >500 HP	<p>a. Change oil and filter every 2,160 hours of operation or within 1 year + 30 days of the previous</p>	

<sup>1</sup> Sources have the option to utilize an oil analysis program as described in § 63.6625(i) or (j) in order to extend the specified oil change requirement in table 2d of this subpart.

<sup>2</sup> If an emergency engine is operating during an emergency and it is not possible to shut down the engine in order to perform the management practice requirements on the schedule required in table 2d of this subpart, or if performing the management practice on the required schedule would otherwise pose an unacceptable risk under Federal, state, or local law, the management practice can be delayed until the emergency is over or the unacceptable risk under Federal, state, or local law has abated. The management practice should be performed as soon as practicable after the emergency has ended or the unacceptable risk under Federal, state, or local law has abated. Sources must report any failure to perform the management practice on the schedule required and the Federal, state or local law under which the risk was deemed unacceptable.

For each . . .	You must meet the following requirement, except during periods of startup . . .	During periods of startup you must . . .
<p>9. Non-emergency, non-black start 4SLB stationary RICE &gt;500 HP that are not remote stationary RICE and that operate more than 24 hours per calendar year</p> <p>10. Non-emergency, non-black start 4SRB stationary RICE ≤500 HP</p>	<p>change, whichever comes first;<sup>1</sup></p> <p>b. Inspect spark plugs every 2,160 hours of operation or within 1 year + 30 days of the previous inspection, whichever comes first, and replace as necessary; and</p> <p>c. Inspect all hoses and belts every 2,160 hours of operation or within 1 year + 30 days of the previous inspection, whichever comes first, and replace as necessary</p> <p>Install an oxidation catalyst to reduce HAP emissions from the stationary RICE</p> <p>a. Change oil and filter every 1,440 hours of operation or within 1 year + 30 days of the previous</p>	

<sup>1</sup> Sources have the option to utilize an oil analysis program as described in § 63.6625(i) or (j) in order to extend the specified oil change requirement in table 2d of this subpart.

<sup>2</sup> If an emergency engine is operating during an emergency and it is not possible to shut down the engine in order to perform the management practice requirements on the schedule required in table 2d of this subpart, or if performing the management practice on the required schedule would otherwise pose an unacceptable risk under Federal, state, or local law, the management practice can be delayed until the emergency is over or the unacceptable risk under Federal, state, or local law has abated. The management practice should be performed as soon as practicable after the emergency has ended or the unacceptable risk under Federal, state, or local law has abated. Sources must report any failure to perform the management practice on the schedule required and the Federal, state or local law under which the risk was deemed unacceptable.

For each . . .	You must meet the following requirement, except during periods of startup . . .	During periods of startup you must . . .
11. Non-emergency, non-black start 4SRB remote stationary RICE >500 HP	<p>change, whichever comes first;<sup>1</sup></p> <p>b. Inspect spark plugs every 1,440 hours of operation or within 1 year + 30 days of the previous inspection, whichever comes first, and replace as necessary; and</p> <p>c. Inspect all hoses and belts every 1,440 hours of operation or within 1 year + 30 days of the previous inspection, whichever comes first, and replace as necessary</p> <p>a. Change oil and filter every 2,160 hours of operation or within 1 year + 30 days of the previous change, whichever comes first;<sup>1</sup></p> <p>b. Inspect spark plugs every 2,160 hours of operation or</p>	

<sup>1</sup> Sources have the option to utilize an oil analysis program as described in § 63.6625(i) or (j) in order to extend the specified oil change requirement in table 2d of this subpart.

<sup>2</sup> If an emergency engine is operating during an emergency and it is not possible to shut down the engine in order to perform the management practice requirements on the schedule required in table 2d of this subpart, or if performing the management practice on the required schedule would otherwise pose an unacceptable risk under Federal, state, or local law, the management practice can be delayed until the emergency is over or the unacceptable risk under Federal, state, or local law has abated. The management practice should be performed as soon as practicable after the emergency has ended or the unacceptable risk under Federal, state, or local law has abated. Sources must report any failure to perform the management practice on the schedule required and the Federal, state or local law under which the risk was deemed unacceptable.



For each . . .	You must meet the following requirement, except during periods of startup . . .	During periods of startup you must . . .
<p>12. Non-emergency, non-black start 4SRB stationary RICE &gt;500 HP that are not remote stationary RICE and that operate more than 24 hours per calendar year</p> <p>13. Non-emergency, non-black start stationary RICE which combusts landfill or digester gas equivalent to 10 percent or more of the gross heat input on an annual basis</p>	<p>within 1 year + 30 days of the previous inspection, whichever comes first, and replace as necessary; and</p> <p>c. Inspect all hoses and belts every 2,160 hours of operation or within 1 year + 30 days of the previous inspection, whichever comes first, and replace as necessary</p> <p>Install NSCR to reduce HAP emissions from the stationary RICE</p> <p>a. Change oil and filter every 1,440 hours of operation or within 1 year + 30 days of the previous change, whichever comes first;<sup>1</sup></p> <p>b. Inspect spark plugs every 1,440 hours of operation or</p>	

<sup>1</sup> Sources have the option to utilize an oil analysis program as described in § 63.6625(i) or (j) in order to extend the specified oil change requirement in table 2d of this subpart.

<sup>2</sup> If an emergency engine is operating during an emergency and it is not possible to shut down the engine in order to perform the management practice requirements on the schedule required in table 2d of this subpart, or if performing the management practice on the required schedule would otherwise pose an unacceptable risk under Federal, state, or local law, the management practice can be delayed until the emergency is over or the unacceptable risk under Federal, state, or local law has abated. The management practice should be performed as soon as practicable after the emergency has ended or the unacceptable risk under Federal, state, or local law has abated. Sources must report any failure to perform the management practice on the schedule required and the Federal, state or local law under which the risk was deemed unacceptable.

For each . . .	You must meet the following requirement, except during periods of startup . . .	During periods of startup you must . . .
	<p>within 1 year + 30 days of the previous inspection, whichever comes first, and replace as necessary; and</p> <p>c. Inspect all hoses and belts every 1,440 hours of operation or within 1 year + 30 days of the previous inspection, whichever comes first, and replace as necessary</p>	

<sup>1</sup> Sources have the option to utilize an oil analysis program as described in § 63.6625(i) or (j) in order to extend the specified oil change requirement in table 2d of this subpart.

<sup>2</sup> If an emergency engine is operating during an emergency and it is not possible to shut down the engine in order to perform the management practice requirements on the schedule required in table 2d of this subpart, or if performing the management practice on the required schedule would otherwise pose an unacceptable risk under Federal, state, or local law, the management practice can be delayed until the emergency is over or the unacceptable risk under Federal, state, or local law has abated. The management practice should be performed as soon as practicable after the emergency has ended or the unacceptable risk under Federal, state, or local law has abated. Sources must report any failure to perform the management practice on the schedule required and the Federal, state or local law under which the risk was deemed unacceptable.

[89 FR 70520, Aug. 30, 2024]

### Table 3 to Subpart ZZZZ of Part 63—Subsequent Performance Tests

As stated in §§ 63.6615 and 63.6620, you must comply with the following subsequent performance test requirements:

For each . . .	Complying with the requirement to . . .	You must . . .
1. New or reconstructed 2SLB stationary RICE >500 HP located at major sources; new or reconstructed 4SLB stationary RICE $\geq$ 250 HP located at major sources; and new or reconstructed CI stationary RICE >500 HP located at major sources	Reduce CO emissions and not using a CEMS	Conduct subsequent performance tests semiannually. <sup>1</sup>
2. 4SRB stationary RICE $\geq$ 5,000 HP located at major sources	Reduce formaldehyde emissions	Conduct subsequent performance tests semiannually. <sup>1</sup>
3. Stationary RICE >500 HP located at major sources and new or reconstructed 4SLB stationary RICE $250 \leq \text{HP} \leq 500$ located at major sources	Limit the concentration of formaldehyde in the stationary RICE exhaust	Conduct subsequent performance tests semiannually. <sup>1</sup>
4. Existing non-emergency, non-black start CI stationary RICE >500 HP that are not limited use stationary RICE	Limit or reduce CO emissions and not using a CEMS	Conduct subsequent performance tests every 8,760 hours or 3 years, whichever comes first.
5. Existing non-emergency, non-black start CI stationary RICE >500 HP that are limited use stationary RICE	Limit or reduce CO emissions and not using a CEMS	Conduct subsequent performance tests every 8,760 hours or 5 years, whichever comes first.

<sup>1</sup> After you have demonstrated compliance for two consecutive tests, you may reduce the frequency of subsequent performance tests to annually. If the results of any subsequent annual performance test indicate the stationary RICE is not in compliance with the CO or formaldehyde emission limitation, or you deviate from any of your operating limitations, you must resume semiannual performance tests.

[78 FR 6711, Jan. 30, 2013]

## Table 4 to Subpart ZZZZ of Part 63—Requirements for Performance Tests

As stated in §§ 63.6610, 63.6611, 63.6620, and 63.6640, you must comply with the following requirements for performance tests for stationary RICE:

For each . . .	Complying with the requirement to . . .	You must . . .	Using . . .	According to the following requirements . . .
1. 2SLB, 4SLB, and CI stationary RICE	a. Reduce CO emissions	<p>i. Select the sampling port location and the number/ location of traverse points at the inlet and outlet of the control device; and</p> <p>ii. Measure the O<sub>2</sub> at the inlet and outlet of the control device; and</p>	<p>(1) Method 3 or 3A or 3B of 40 CFR part 60, appendix A-2, or ASTM D6522-00 (Reapproved 2005)<sup>1 3</sup> (heated probe not necessary)</p>	<p>(a) For CO, O<sub>2</sub>, and moisture measurement, ducts ≤6 inches in diameter may be sampled at a single point located at the duct centroid and ducts &gt;6 and ≤12 inches in diameter may be sampled at 3 traverse points located at 16.7, 50.0, and 83.3% of the measurement line ('3-point long line'). If the duct is &gt;12 inches in diameter <i>and</i> the sampling port location meets the two and half-diameter criterion of section 11.1.1 of method 1 of 40 CFR part 60, appendix A-1, the duct may be sampled at '3-point long line'; otherwise, conduct the stratification testing and select sampling points according to section 8.1.2 of method 7E of 40 CFR part 60, appendix A-4.</p> <p>(b) Measurements to determine O<sub>2</sub> must be made at the same time as the measurements for CO concentration.</p>

<sup>1</sup> You may also use methods 3A and 10 as options to ASTM-D6522-00 (2005).

<sup>2</sup> You may obtain a copy of ASTM-D6348-03 from at least one of the following addresses: American Society for Testing and Materials, 100 Barr Harbor Drive, West Conshohocken, PA 19428-2959, or University Microfilms International, 300 North Zeeb Road, Ann Arbor, MI 48106.

<sup>3</sup> Incorporated by reference, see § 63.14.

For each . . .	Complying with the requirement to . . .	You must . . .	Using . . .	According to the following requirements . . .
2. 4SRB stationary RICE	a. Reduce formaldehyde or THC emissions	iii. Measure the CO at the inlet and the outlet of the control device; and	(2) ASTM D6522-00 (Reapproved 2005) <sup>1 2 3</sup> (heated probe not necessary) or method 10 of 40 CFR part 60, appendix A-4	(c) The CO concentration must be at 15 percent O <sub>2</sub> , dry basis.
		iv. Measure moisture content at the inlet and outlet of the control device as needed to determine CO and O <sub>2</sub> concentrations on a dry basis	(3) Method 4 of 40 CFR part 60, appendix A-3, or method 320 of 40 CFR part 63, appendix A, or ASTM D6348-03 <sup>1 3</sup>	(d) Measurements to determine moisture content must be made at the same time and location as the measurements for CO concentration.
		i. Select the sampling port location and the number/ location of traverse points at the inlet and outlet of the control device; and		(a) For formaldehyde, THC, O <sub>2</sub> , and moisture measurement, ducts ≤6 inches in diameter may be sampled at a single point located at the duct centroid and ducts >6 and ≤12 inches in diameter may be sampled at 3 traverse points located at 16.7, 50.0, and 83.3% of the measurement line ('3-point long line'). If the duct is >12 inches in diameter <i>and</i> the sampling port location meets the two and half-diameter criterion of section 11.1.1 of

<sup>1</sup> You may also use methods 3A and 10 as options to ASTM-D6522-00 (2005).

<sup>2</sup> You may obtain a copy of ASTM-D6348-03 from at least one of the following addresses: American Society for Testing and Materials, 100 Barr Harbor Drive, West Conshohocken, PA 19428-2959, or University Microfilms International, 300 North Zeeb Road, Ann Arbor, MI 48106.

<sup>3</sup> Incorporated by reference, see § 63.14.

For each . ..	Complying with the requirement to ...	You must ...	Using ...	According to the following requirements ...
		<p>ii. Measure O<sub>2</sub> at the inlet and outlet of the control device; and</p> <p>iii. Measure moisture content at the inlet and outlet of the control device as needed to determine formaldehyde or THC and O<sub>2</sub> concentrations on a dry basis; and</p> <p>iv. If demonstrating compliance</p>	<p>(1) Method 3 or 3A or 3B of 40 CFR part 60, appendix A-2, or ASTM D6522-00 (Reapproved 2005)<sup>1 3</sup> (heated probe not necessary)</p> <p>(2) Method 4 of 40 CFR part 60, appendix A-3, or method 320 of 40 CFR part 63, appendix A, or ASTM D6348-03<sup>1 3</sup></p> <p>(3) Method 320 or 323 of 40 CFR</p>	<p>method 1 of 40 CFR part 60, appendix A, the duct may be sampled at '3-point long line'; otherwise, conduct the stratification testing and select sampling points according to section 8.1.2 of method 7E of 40 CFR part 60, appendix A.</p> <p>(b) Measurements to determine O<sub>2</sub> concentration must be made at the same time as the measurements for formaldehyde or THC concentration.</p> <p>(c) Measurements to determine moisture content must be made at the same time and location as the measurements for formaldehyde or THC concentration.</p> <p>(d) Formaldehyde concentration must be at 15 percent O<sub>2</sub>, dry basis. Results of this test consist of the average of the</p>

<sup>1</sup> You may also use methods 3A and 10 as options to ASTM-D6522-00 (2005).

<sup>2</sup> You may obtain a copy of ASTM-D6348-03 from at least one of the following addresses: American Society for Testing and Materials, 100 Barr Harbor Drive, West Conshohocken, PA 19428-2959, or University Microfilms International, 300 North Zeeb Road, Ann Arbor, MI 48106.

<sup>3</sup> Incorporated by reference, see § 63.14.

For each . ..	Complying with the requirement to ...	You must ...	Using ...	According to the following requirements ...
		with the formaldehyde percent reduction requirement, measure formaldehyde at the inlet and the outlet of the control device	part 63, appendix A; or ASTM D6348-03, <sup>1 3</sup> provided in ASTM D6348-03 Annex A5 (Analyte Spiking Technique), the percent R must be greater than or equal to 70 and less than or equal to 130	three 1-hour or longer runs.
		v. If demonstrating compliance with the THC percent reduction requirement, measure THC at the inlet and the outlet of the control device	(4) (1) Method 25A, reported as propane, of 40 CFR part 60, appendix A-7	(e) THC concentration must be at 15 percent O <sub>2</sub> , dry basis. Results of this test consist of the average of the three 1-hour or longer runs.
3. Stationary RICE	a. Limit the concentration of formaldehyde or CO in the stationary	i. Select the sampling port location and the number/ location of traverse points		(a) For formaldehyde, CO, O <sub>2</sub> , and moisture measurement, ducts ≤6 inches in diameter may be sampled at a single point located at the duct centroid and ducts >6 and ≤12 inches in diameter may be sampled at 3 traverse

<sup>1</sup> You may also use methods 3A and 10 as options to ASTM-D6522-00 (2005).

<sup>2</sup> You may obtain a copy of ASTM-D6348-03 from at least one of the following addresses: American Society for Testing and Materials, 100 Barr Harbor Drive, West Conshohocken, PA 19428-2959, or University Microfilms International, 300 North Zeeb Road, Ann Arbor, MI 48106.

<sup>3</sup> Incorporated by reference, see § 63.14.

For each . .	Complying with the requirement to . . .	You must . . .	Using . . .	According to the following requirements . . .
	RICE exhaust	at the exhaust of the stationary RICE; and		points located at 16.7, 50.0, and 83.3% of the measurement line ('3-point long line'). If the duct is >12 inches in diameter <i>and</i> the sampling port location meets the two and half-diameter criterion of section 11.1.1 of method 1 of 40 CFR part 60, appendix A, the duct may be sampled at '3-point long line'; otherwise, conduct the stratification testing and select sampling points according to section 8.1.2 of method 7E of 40 CFR part 60, appendix A. If using a control device, the sampling site must be located at the outlet of the control device.
		ii. Determine the O <sub>2</sub> concentration of the stationary RICE exhaust at the sampling port location; and	(1) Method 3 or 3A or 3B of 40 CFR part 60, appendix A-2, or ASTM D6522-00 (Reapproved 2005) <sup>1 3</sup> (heated probe not necessary)	(b) Measurements to determine O <sub>2</sub> concentration must be made at the same time and location as the measurements for formaldehyde or CO concentration.
		iii. Measure moisture content of the stationary RICE exhaust at the sampling port location as	(2) Method 4 of 40 CFR part 60, appendix A-3, or method 320 of 40 CFR part 63,	(c) Measurements to determine moisture content must be made at the same time and location as the measurements for formaldehyde or CO concentration.

<sup>1</sup> You may also use methods 3A and 10 as options to ASTM-D6522-00 (2005).

<sup>2</sup> You may obtain a copy of ASTM-D6348-03 from at least one of the following addresses: American Society for Testing and Materials, 100 Barr Harbor Drive, West Conshohocken, PA 19428-2959, or University Microfilms International, 300 North Zeeb Road, Ann Arbor, MI 48106.

<sup>3</sup> Incorporated by reference, see § 63.14.



For each . .	Complying with the requirement to . . .	You must . . .	Using . . .	According to the following requirements . . .
		<p>needed to determine formaldehyde or CO and O<sub>2</sub> concentrations on a dry basis; and</p> <p>iv. Measure formaldehyde at the exhaust of the stationary RICE; or</p> <p>v. Measure CO at the exhaust of the stationary RICE</p>	<p>appendix A, or ASTM D6348-03<sup>1 3</sup></p> <p>(3) Method 320 or 323 of 40 CFR part 63, appendix A; or ASTM D6348-03,<sup>1 3</sup> provided in ASTM D6348-03 Annex A5 (Analyte Spiking Technique), the percent R must be greater than or equal to 70 and less than or equal to 130</p> <p>(4) Method 10 of 40 CFR part 60, appendix A-4, ASTM D6522-00 (2005),<sup>1 3</sup> method 320</p>	<p>(d) Formaldehyde concentration must be at 15 percent O<sub>2</sub>, dry basis. Results of this test consist of the average of the three 1-hour or longer runs.</p> <p>(e) CO concentration must be at 15 percent O<sub>2</sub>, dry basis. Results of this test consist of the average of the three 1-hour or longer runs.</p>

<sup>2</sup> You may obtain a copy of ASTM-D6348-03 from at least one of the following addresses: American Society for Testing and Materials, 100 Barr Harbor Drive, West Conshohocken, PA 19428-2959, or University Microfilms International, 300 North Zeeb Road, Ann Arbor, MI 48106.

<sup>3</sup> Incorporated by reference, see § 63.14.

For each . .	Complying with the requirement to . . .	You must . . .	Using . . .	According to the following requirements . . .
			of 40 CFR part 63, appendix A, or ASTM D6348-03 <sup>1</sup> <sub>3</sub>	

<sup>1</sup> You may also use methods 3A and 10 as options to ASTM-D6522-00 (2005).

<sup>2</sup> You may obtain a copy of ASTM-D6348-03 from at least one of the following addresses: American Society for Testing and Materials, 100 Barr Harbor Drive, West Conshohocken, PA 19428-2959, or University Microfilms International, 300 North Zeeb Road, Ann Arbor, MI 48106.

<sup>3</sup> Incorporated by reference, see § 63.14.

[88 FR 18413, Mar. 29, 2023]

**Table 5 to Subpart ZZZZ of Part 63—Initial Compliance With Emission Limitations, Operating Limitations, and Other Requirements**

As stated in §§ 63.6612, 63.6625 and 63.6630, you must initially comply with the emission and operating limitations as required by the following:

For each . . .	Complying with the requirement to . . .	You have demonstrated initial compliance if . . .
1. New or reconstructed non-emergency 2SLB stationary RICE >500 HP located at a major source of HAP, new or reconstructed non-emergency 4SLB stationary RICE ≥250 HP located at a major source of HAP, non-emergency stationary CI RICE >500 HP located at a major source of HAP, and existing non-emergency stationary CI RICE >500 HP located at an area source of HAP	a. Reduce CO emissions and using oxidation catalyst, and using a CPMS	i. The average reduction of emissions of CO determined from the initial performance test achieves the required CO percent reduction; and ii. You have installed a CPMS to continuously monitor catalyst inlet temperature according to the requirements in § 63.6625(b); and iii. You have recorded the catalyst pressure drop and catalyst inlet temperature during the initial performance test.

For each . . .	Complying with the requirement to . . .	You have demonstrated initial compliance if . . .
2. Non-emergency stationary CI RICE >500 HP located at a major source of HAP, and existing non-emergency stationary CI RICE >500 HP located at an area source of HAP	a. Limit the concentration of CO, using oxidation catalyst, and using a CPMS	i. The average CO concentration determined from the initial performance test is less than or equal to the CO emission limitation; and  ii. You have installed a CPMS to continuously monitor catalyst inlet temperature according to the requirements in § 63.6625(b); and iii. You have recorded the catalyst pressure drop and catalyst inlet temperature during the initial performance test.
3. New or reconstructed non-emergency 2SLB stationary RICE >500 HP located at a major source of HAP, new or reconstructed non-emergency 4SLB stationary RICE ≥250 HP located at a major source of HAP, non-emergency stationary CI RICE >500 HP located at a major source of HAP, and existing non-emergency stationary CI RICE >500 HP located at an area source of HAP	a. Reduce CO emissions and not using oxidation catalyst	i. The average reduction of emissions of CO determined from the initial performance test achieves the required CO percent reduction; and ii. You have installed a CPMS to continuously monitor operating parameters approved by the Administrator (if any) according to the requirements in § 63.6625(b); and iii. You have recorded the approved operating parameters (if any) during the initial performance test.
4. Non-emergency stationary CI RICE >500 HP located at a major source of HAP, and existing non-emergency stationary CI RICE >500 HP located at an area source of HAP	a. Limit the concentration of CO, and not using oxidation catalyst	i. The average CO concentration determined from the initial performance test is less than or equal to the CO emission limitation; and ii. You have installed a CPMS to continuously monitor operating parameters approved by the Administrator (if any) according to the requirements in § 63.6625(b); and iii. You have recorded the approved

For each . . .	Complying with the requirement to . . .	You have demonstrated initial compliance if . . .
<p>5. New or reconstructed non-emergency 2SLB stationary RICE &gt;500 HP located at a major source of HAP, new or reconstructed non-emergency 4SLB stationary RICE ≥250 HP located at a major source of HAP, non-emergency stationary CI RICE &gt;500 HP located at a major source of HAP, and existing non-emergency stationary CI RICE &gt;500 HP located at an area source of HAP</p>	<p>a. Reduce CO emissions, and using a CEMS</p>	<p>operating parameters (if any) during the initial performance test.</p> <p>i. You have installed a CEMS to continuously monitor CO and either O<sub>2</sub> or CO<sub>2</sub> at both the inlet and outlet of the oxidation catalyst according to the requirements in § 63.6625(a); and</p> <p>ii. You have conducted a performance evaluation of your CEMS using PS 3 and 4A of 40 CFR part 60, appendix B; and</p> <p>iii. The average reduction of CO calculated using § 63.6620 equals or exceeds the required percent reduction. The initial test comprises the first 4-hour period after successful validation of the CEMS. Compliance is based on the average percent reduction achieved during the 4-hour period.</p>
<p>6. Non-emergency stationary CI RICE &gt;500 HP located at a major source of HAP, and existing non-emergency stationary CI RICE &gt;500 HP located at an area source of HAP</p>	<p>a. Limit the concentration of CO, and using a CEMS</p>	<p>i. You have installed a CEMS to continuously monitor CO and either O<sub>2</sub> or CO<sub>2</sub> at the outlet of the oxidation catalyst according to the requirements in § 63.6625(a); and</p> <p>ii. You have conducted a performance evaluation of your CEMS using PS 3 and 4A of 40 CFR part 60, appendix B; and</p> <p>iii. The average concentration of CO calculated using § 63.6620 is less than or equal to the CO emission limitation. The initial test comprises the first 4-hour period after successful validation of the CEMS. Compliance is based on the average concentration measured during the 4-hour period.</p>
<p>7. Non-emergency 4SRB stationary RICE &gt;500 HP located at a major source of HAP</p>	<p>a. Reduce formaldehyde</p>	<p>i. The average reduction of emissions of formaldehyde</p>

For each . . .	Complying with the requirement to . . .	You have demonstrated initial compliance if . . .
	emissions and using NSCR	determined from the initial performance test is equal to or greater than the required formaldehyde percent reduction, or the average reduction of emissions of THC determined from the initial performance test is equal to or greater than 30 percent; and ii. You have installed a CPMS to continuously monitor catalyst inlet temperature according to the requirements in § 63.6625(b); and iii. You have recorded the catalyst pressure drop and catalyst inlet temperature during the initial performance test.
8. Non-emergency 4SRB stationary RICE >500 HP located at a major source of HAP	a. Reduce formaldehyde emissions and not using NSCR	i. The average reduction of emissions of formaldehyde determined from the initial performance test is equal to or greater than the required formaldehyde percent reduction or the average reduction of emissions of THC determined from the initial performance test is equal to or greater than 30 percent; and ii. You have installed a CPMS to continuously monitor operating parameters approved by the Administrator (if any) according to the requirements in § 63.6625(b); and iii. You have recorded the approved operating parameters (if any) during the initial performance test.
9. New or reconstructed non-emergency stationary RICE >500 HP located at a major source of HAP, new or reconstructed non-emergency 4SLB stationary RICE 250≤HP≤500 located at a major source of HAP, and existing non-emergency 4SRB	a. Limit the concentration of formaldehyde in the stationary	i. The average formaldehyde concentration, corrected to 15 percent O <sub>2</sub> , dry basis, from the three test runs is less than or equal to the formaldehyde emission limitation; and

For each . . .	Complying with the requirement to . . .	You have demonstrated initial compliance if . . .
stationary RICE >500 HP located at a major source of HAP	RICE exhaust and using oxidation catalyst or NSCR	<p>ii. You have installed a CPMS to continuously monitor catalyst inlet temperature according to the requirements in § 63.6625(b); and</p> <p>iii. You have recorded the catalyst pressure drop and catalyst inlet temperature during the initial performance test.</p>
10. New or reconstructed non-emergency stationary RICE >500 HP located at a major source of HAP, new or reconstructed non-emergency 4SLB stationary RICE 250≤HP≤500 located at a major source of HAP, and existing non-emergency 4SRB stationary RICE >500 HP located at a major source of HAP	a. Limit the concentration of formaldehyde in the stationary RICE exhaust and not using oxidation catalyst or NSCR	<p>i. The average formaldehyde concentration, corrected to 15 percent O<sub>2</sub>, dry basis, from the three test runs is less than or equal to the formaldehyde emission limitation; and</p> <p>ii. You have installed a CPMS to continuously monitor operating parameters approved by the Administrator (if any) according to the requirements in § 63.6625(b); and</p> <p>iii. You have recorded the approved operating parameters (if any) during the initial performance test.</p>
11. Existing non-emergency stationary RICE 100≤HP≤500 located at a major source of HAP, and existing non-emergency stationary CI RICE 300<HP≤500 located at an area source of HAP	a. Reduce CO emissions	i. The average reduction of emissions of CO or formaldehyde, as applicable determined from the initial performance test is equal to or greater than the required CO or formaldehyde, as applicable, percent reduction.
12. Existing non-emergency stationary RICE 100≤HP≤500 located at a major source of HAP, and existing non-emergency stationary CI RICE 300<HP≤500 located at an area source of HAP	a. Limit the concentration of formaldehyde or CO in the stationary RICE exhaust	i. The average formaldehyde or CO concentration, as applicable, corrected to 15 percent O <sub>2</sub> , dry basis, from the three test runs is less than or equal to the formaldehyde or CO emission limitation, as applicable.
13. Existing non-emergency 4SLB stationary RICE >500 HP located at an area source of HAP that are not remote stationary RICE and	a. Install an oxidation catalyst	i. You have conducted an initial compliance demonstration as specified in § 63.6630(e) to show

For each . . .	Complying with the requirement to . . .	You have demonstrated initial compliance if . . .
that are operated more than 24 hours per calendar year		that the average reduction of emissions of CO is 93 percent or more, or the average CO concentration is less than or equal to 47 ppmvd at 15 percent O <sub>2</sub> ; ii. You have installed a CPMS to continuously monitor catalyst inlet temperature according to the requirements in § 63.6625(b), or you have installed equipment to automatically shut down the engine if the catalyst inlet temperature exceeds 1350 °F.
14. Existing non-emergency 4SRB stationary RICE >500 HP located at an area source of HAP that are not remote stationary RICE and that are operated more than 24 hours per calendar year	a. Install NSCR	i. You have conducted an initial compliance demonstration as specified in § 63.6630(e) to show that the average reduction of emissions of CO is 75 percent or more, the average CO concentration is less than or equal to 270 ppmvd at 15 percent O <sub>2</sub> , or the average reduction of emissions of THC is 30 percent or more; ii. You have installed a CPMS to continuously monitor catalyst inlet temperature according to the requirements in § 63.6625(b), or you have installed equipment to automatically shut down the engine if the catalyst inlet temperature exceeds 1250 °F.

[78 FR 6712, Jan. 30, 2013]

## Table 6 to Subpart ZZZZ of Part 63—Continuous Compliance With Emission Limitations, and Other Requirements

As stated in § 63.6640, you must continuously comply with the emissions and operating limitations and work or management practices as required by the following:

For each . . .	Complying with the requirement to . . .	You must demonstrate continuous compliance by . . .
1. New or reconstructed non-emergency 2SLB stationary RICE >500 HP located at a major source of HAP, new or reconstructed non-emergency 4SLB stationary RICE ≥250 HP located at a major source of HAP, and new or reconstructed non-emergency CI stationary RICE >500 HP located at a major source of HAP	a. Reduce CO emissions and using an oxidation catalyst, and using a CPMS	i. Conducting semiannual performance tests for CO to demonstrate that the required CO percent reduction is achieved <sup>a</sup> ; and ii. Collecting the catalyst inlet temperature data according to § 63.6625(b); and iii. Reducing these data to 4-hour rolling averages; and iv. Maintaining the 4-hour rolling averages within the operating limitations for the catalyst inlet temperature; and v. Measuring the pressure drop across the catalyst once per month and demonstrating that the pressure

<sup>a</sup> After you have demonstrated compliance for two consecutive tests, you may reduce the frequency of subsequent performance tests to annually. If the results of any subsequent annual performance test indicate the stationary RICE is not in compliance with the CO or formaldehyde emission limitation, or you deviate from any of your operating limitations, you must resume semiannual performance tests.



For each . . .	Complying with the requirement to . . .	You must demonstrate continuous compliance by . . .
<p>2. New or reconstructed non-emergency 2SLB stationary RICE &gt;500 HP located at a major source of HAP, new or reconstructed non-emergency 4SLB stationary RICE <math>\geq</math>250 HP located at a major source of HAP, and new or reconstructed non-emergency CI stationary RICE &gt;500 HP located at a major source of HAP</p>	<p>a. Reduce CO emissions and not using an oxidation catalyst, and using a CPMS</p>	<p>drop across the catalyst is within the operating limitation established during the performance test.</p> <p>i. Conducting semiannual performance tests for CO to demonstrate that the required CO percent reduction is achieved <sup>a</sup>; and</p> <p>ii. Collecting the approved operating parameter (if any) data according to § 63.6625(b); and</p> <p>iii. Reducing these data to 4-hour rolling averages; and</p> <p>iv. Maintaining the 4-hour rolling averages within the operating limitations for the operating parameters established during the performance test.</p>
<p>3. New or reconstructed non-emergency 2SLB stationary RICE &gt;500 HP located at a major source of HAP, new or</p>	<p>a. Reduce CO emissions or</p>	<p>i. Collecting the monitoring data</p>

<sup>a</sup> After you have demonstrated compliance for two consecutive tests, you may reduce the frequency of subsequent performance tests to annually. If the results of any subsequent annual performance test indicate the stationary RICE is not in compliance with the CO or formaldehyde emission limitation, or you deviate from any of your operating limitations, you must resume semiannual performance tests.

For each . . .	Complying with the requirement to . . .	You must demonstrate continuous compliance by . . .
reconstructed non-emergency 4SLB stationary RICE ≥250 HP located at a major source of HAP, new or reconstructed non-emergency stationary CI RICE >500 HP located at a major source of HAP, and existing non-emergency stationary CI RICE >500 HP	limit the concentration of CO in the stationary RICE exhaust, and using a CEMS	according to § 63.6625(a), reducing the measurements to 1-hour averages, calculating the percent reduction or concentration of CO emissions according to § 63.6620; and ii. Demonstrating that the catalyst achieves the required percent reduction of CO emissions over the 4-hour averaging period, or that the emission remain at or below the CO concentration limit; and iii. Conducting an annual RATA of your CEMS using PS 3 and 4A of 40 CFR part 60, appendix B, as well as daily and periodic data quality checks in accordance with 40 CFR part 60, appendix F, procedure 1.

<sup>a</sup> After you have demonstrated compliance for two consecutive tests, you may reduce the frequency of subsequent performance tests to annually. If the results of any subsequent annual performance test indicate the stationary RICE is not in compliance with the CO or formaldehyde emission limitation, or you deviate from any of your operating limitations, you must resume semiannual performance tests.

For each . . .	Complying with the requirement to . . .	You must demonstrate continuous compliance by . . .
4. Non-emergency 4SRB stationary RICE >500 HP located at a major source of HAP	a. Reduce formaldehyde emissions and using NSCR	i. Collecting the catalyst inlet temperature data according to § 63.6625(b); and ii. Reducing these data to 4-hour rolling averages; and iii. Maintaining the 4-hour rolling averages within the operating limitations for the catalyst inlet temperature; and iv. Measuring the pressure drop across the catalyst once per month and demonstrating that the pressure drop across the catalyst is within the operating limitation established during the performance test.
5. Non-emergency 4SRB stationary RICE >500 HP located at a major source of HAP	a. Reduce formaldehyde emissions and not using NSCR	i. Collecting the approved operating parameter (if any) data according to § 63.6625(b); and ii. Reducing these

<sup>a</sup> After you have demonstrated compliance for two consecutive tests, you may reduce the frequency of subsequent performance tests to annually. If the results of any subsequent annual performance test indicate the stationary RICE is not in compliance with the CO or formaldehyde emission limitation, or you deviate from any of your operating limitations, you must resume semiannual performance tests.

For each . . .	Complying with the requirement to . . .	You must demonstrate continuous compliance by . . .
<p>6. Non-emergency 4SRB stationary RICE with a brake HP <math>\geq 5,000</math> located at a major source of HAP</p> <p>7. New or reconstructed non-emergency stationary RICE <math>&gt;500</math> HP located at a major source of HAP and new or reconstructed non-emergency 4SLB stationary RICE <math>250 \leq \text{HP} \leq 500</math> located at a major source of HAP</p>	<p>a. Reduce formaldehyde emissions</p> <p>a. Limit the concentration of formaldehyde in the stationary</p>	<p>data to 4-hour rolling averages; and</p> <p>iii. Maintaining the 4-hour rolling averages within the operating limitations for the operating parameters established during the performance test.</p> <p>Conducting semiannual performance tests for formaldehyde to demonstrate that the required formaldehyde percent reduction is achieved, or to demonstrate that the average reduction of emissions of THC determined from the performance test is equal to or greater than 30 percent.<sup>a</sup></p> <p>i. Conducting semiannual performance tests for formaldehyde to demonstrate that your</p>

<sup>a</sup> After you have demonstrated compliance for two consecutive tests, you may reduce the frequency of subsequent performance tests to annually. If the results of any subsequent annual performance test indicate the stationary RICE is not in compliance with the CO or formaldehyde emission limitation, or you deviate from any of your operating limitations, you must resume semiannual performance tests.

For each . . .	Complying with the requirement to . . .	You must demonstrate continuous compliance by . . .
<p>8. New or reconstructed non-emergency stationary RICE &gt;500 HP located at a major source of HAP and new or reconstructed</p> <p><sup>a</sup> After you have demonstrated compliance for two consecutive tests, you may reduce the frequency of subsequent performance tests to annually. If the results of any subsequent annual performance test indicate the stationary RICE is not in compliance with the CO or formaldehyde emission limitation, or you deviate from any of your operating limitations, you must resume semiannual performance tests.</p>	<p>RICE exhaust and using oxidation catalyst or NSCR</p> <p>a. Limit the concentration</p>	<p>emissions remain at or below the formaldehyde concentration limit <sup>a</sup>; and</p> <p>ii. Collecting the catalyst inlet temperature data according to § 63.6625(b); and</p> <p>iii. Reducing these data to 4-hour rolling averages; and</p> <p>iv. Maintaining the 4-hour rolling averages within the operating limitations for the catalyst inlet temperature; and</p> <p>v. Measuring the pressure drop across the catalyst once per month and demonstrating that the pressure drop across the catalyst is within the operating limitation established during the performance test.</p> <p>i. Conducting semiannual</p>

For each . . .	Complying with the requirement to . . .	You must demonstrate continuous compliance by . . .
non-emergency 4SLB stationary RICE $250 \leq \text{HP} \leq 500$ located at a major source of HAP	of formaldehyde in the stationary RICE exhaust and not using oxidation catalyst or NSCR	performance tests for formaldehyde to demonstrate that your emissions remain at or below the formaldehyde concentration limit <sup>a</sup> ; and ii. Collecting the approved operating parameter (if any) data according to § 63.6625(b); and iii. Reducing these data to 4-hour rolling averages; and iv. Maintaining the 4-hour rolling averages within the operating limitations for the operating parameters established during the performance test.
9. Existing emergency and black start stationary RICE $\leq 500$ HP located at a major source of HAP, existing non-emergency stationary RICE $< 100$ HP located at a major source of HAP, existing emergency and black start stationary RICE located at an area source of HAP, existing non-emergency stationary CI RICE $\leq 300$ HP located at an area source of HAP, existing non-emergency 2SLB stationary RICE located at an area source of HAP, existing non-emergency stationary SI RICE located at an	a. Work or Management practices	i. Operating and maintaining the stationary RICE according to the manufacturer's emission-related operation and maintenance

<sup>a</sup> After you have demonstrated compliance for two consecutive tests, you may reduce the frequency of subsequent performance tests to annually. If the results of any subsequent annual performance test indicate the stationary RICE is not in compliance with the CO or formaldehyde emission limitation, or you deviate from any of your operating limitations, you must resume semiannual performance tests.

For each . . .	Complying with the requirement to . . .	You must demonstrate continuous compliance by . . .
<p>area source of HAP which combusts landfill or digester gas equivalent to 10 percent or more of the gross heat input on an annual basis, existing non-emergency 4SLB and 4SRB stationary RICE ≤500 HP located at an area source of HAP, existing non-emergency 4SLB and 4SRB stationary RICE &gt;500 HP located at an area source of HAP that operate 24 hours or less per calendar year, and existing non-emergency 4SLB and 4SRB stationary RICE &gt;500 HP located at an area source of HAP that are remote stationary RICE</p> <p>10. Existing stationary CI RICE &gt;500 HP that are not limited use stationary RICE</p>	<p>a. Reduce CO emissions, or limit the concentration of CO in the stationary RICE exhaust, and using oxidation catalyst</p>	<p>instructions; or</p> <p>ii. Develop and follow your own maintenance plan which must provide to the extent practicable for the maintenance and operation of the engine in a manner consistent with good air pollution control practice for minimizing emissions.</p> <p>i. Conducting performance tests every 8,760 hours or 3 years, whichever comes first, for CO or formaldehyde, as appropriate, to demonstrate that the required CO or formaldehyde, as appropriate, percent reduction is achieved or that your emissions remain at or below the CO or formaldehyde concentration limit; and</p>

<sup>a</sup> After you have demonstrated compliance for two consecutive tests, you may reduce the frequency of subsequent performance tests to annually. If the results of any subsequent annual performance test indicate the stationary RICE is not in compliance with the CO or formaldehyde emission limitation, or you deviate from any of your operating limitations, you must resume semiannual performance tests.

For each . . .	Complying with the requirement to . . .	You must demonstrate continuous compliance by . . .
<p>11. Existing stationary CI RICE &gt;500 HP that are not limited use stationary RICE</p>	<p>a. Reduce CO emissions, or limit the concentration of CO in the stationary RICE exhaust,</p>	<p>ii. Collecting the catalyst inlet temperature data according to § 63.6625(b); and  iii. Reducing these data to 4-hour rolling averages; and  iv. Maintaining the 4-hour rolling averages within the operating limitations for the catalyst inlet temperature; and  v. Measuring the pressure drop across the catalyst once per month and demonstrating that the pressure drop across the catalyst is within the operating limitation established during the performance test.  i. Conducting performance tests every 8,760 hours or 3 years, whichever comes first, for CO or formaldehyde, as</p>

<sup>a</sup> After you have demonstrated compliance for two consecutive tests, you may reduce the frequency of subsequent performance tests to annually. If the results of any subsequent annual performance test indicate the stationary RICE is not in compliance with the CO or formaldehyde emission limitation, or you deviate from any of your operating limitations, you must resume semiannual performance tests.



For each . . .	Complying with the requirement to . . .	You must demonstrate continuous compliance by . . .
	and not using oxidation catalyst	appropriate, to demonstrate that the required CO or formaldehyde, as appropriate, percent reduction is achieved or that your emissions remain at or below the CO or formaldehyde concentration limit; and ii. Collecting the approved operating parameter (if any) data according to § 63.6625(b); and iii. Reducing these data to 4-hour rolling averages; and iv. Maintaining the 4-hour rolling averages within the operating limitations for the operating parameters established during the performance test.
12. Existing limited use CI stationary RICE >500 HP	a. Reduce CO emissions or limit the concentration	i. Conducting performance tests every 8,760 hours or 5 years,

<sup>a</sup> After you have demonstrated compliance for two consecutive tests, you may reduce the frequency of subsequent performance tests to annually. If the results of any subsequent annual performance test indicate the stationary RICE is not in compliance with the CO or formaldehyde emission limitation, or you deviate from any of your operating limitations, you must resume semiannual performance tests.

For each . . .	Complying with the requirement to . . .	You must demonstrate continuous compliance by . . .
	of CO in the stationary RICE exhaust, and using an oxidation catalyst	<p>whichever comes first, for CO or formaldehyde, as appropriate, to demonstrate that the required CO or formaldehyde, as appropriate, percent reduction is achieved or that your emissions remain at or below the CO or formaldehyde concentration limit; and</p> <p>ii. Collecting the catalyst inlet temperature data according to § 63.6625(b); and</p> <p>iii. Reducing these data to 4-hour rolling averages; and</p> <p>iv. Maintaining the 4-hour rolling averages within the operating limitations for the catalyst inlet temperature; and</p> <p>v. Measuring the pressure drop across the catalyst once per month and</p>

<sup>a</sup> After you have demonstrated compliance for two consecutive tests, you may reduce the frequency of subsequent performance tests to annually. If the results of any subsequent annual performance test indicate the stationary RICE is not in compliance with the CO or formaldehyde emission limitation, or you deviate from any of your operating limitations, you must resume semiannual performance tests.

For each . . .	Complying with the requirement to . . .	You must demonstrate continuous compliance by . . .
13. Existing limited use CI stationary RICE >500 HP	a. Reduce CO emissions or limit the concentration of CO in the stationary RICE exhaust, and not using an oxidation catalyst	<p>demonstrating that the pressure drop across the catalyst is within the operating limitation established during the performance test.</p> <p>i. Conducting performance tests every 8,760 hours or 5 years, whichever comes first, for CO or formaldehyde, as appropriate, to demonstrate that the required CO or formaldehyde, as appropriate, percent reduction is achieved or that your emissions remain at or below the CO or formaldehyde concentration limit; and</p> <p>ii. Collecting the approved operating parameter (if any) data according to § 63.6625(b); and</p> <p>iii. Reducing these data to 4-hour</p>

<sup>a</sup> After you have demonstrated compliance for two consecutive tests, you may reduce the frequency of subsequent performance tests to annually. If the results of any subsequent annual performance test indicate the stationary RICE is not in compliance with the CO or formaldehyde emission limitation, or you deviate from any of your operating limitations, you must resume semiannual performance tests.

For each . . .	Complying with the requirement to . . .	You must demonstrate continuous compliance by . . .
<p>14. Existing non-emergency 4SLB stationary RICE &gt;500 HP located at an area source of HAP that are not remote stationary RICE and that are operated more than 24 hours per calendar year</p>	<p>a. Install an oxidation catalyst</p>	<p>rolling averages; and</p> <p>iv. Maintaining the 4-hour rolling averages within the operating limitations for the operating parameters established during the performance test.</p> <p>i. Conducting annual compliance demonstrations as specified in § 63.6640(c) to show that the average reduction of emissions of CO is 93 percent or more, or the average CO concentration is less than or equal to 47 ppmvd at 15 percent O<sub>2</sub>; and either</p> <p>ii. Collecting the catalyst inlet temperature data according to § 63.6625(b), reducing these data to 4-hour rolling averages;</p>

<sup>a</sup> After you have demonstrated compliance for two consecutive tests, you may reduce the frequency of subsequent performance tests to annually. If the results of any subsequent annual performance test indicate the stationary RICE is not in compliance with the CO or formaldehyde emission limitation, or you deviate from any of your operating limitations, you must resume semiannual performance tests.

For each . . .	Complying with the requirement to . . .	You must demonstrate continuous compliance by . . .
<p>15. Existing non-emergency 4SRB stationary RICE &gt;500 HP located at an area source of HAP that are not remote stationary RICE and that are operated more than 24 hours per calendar year</p>	<p>a. Install NSCR</p>	<p>and maintaining the 4-hour rolling averages within the limitation of greater than 450 °F and less than or equal to 1350 °F for the catalyst inlet temperature; or</p> <p>iii. Immediately shutting down the engine if the catalyst inlet temperature exceeds 1350 °F.</p> <p>i. Conducting annual compliance demonstrations as specified in § 63.6640(c) to show that the average reduction of emissions of CO is 75 percent or more, the average CO concentration is less than or equal to 270 ppmvd at 15 percent O<sub>2</sub>, or the average reduction of emissions of THC is 30 percent or more; and either</p>

<sup>a</sup> After you have demonstrated compliance for two consecutive tests, you may reduce the frequency of subsequent performance tests to annually. If the results of any subsequent annual performance test indicate the stationary RICE is not in compliance with the CO or formaldehyde emission limitation, or you deviate from any of your operating limitations, you must resume semiannual performance tests.

For each . . .	Complying with the requirement to . . .	You must demonstrate continuous compliance by . . .
		<p>ii. Collecting the catalyst inlet temperature data according to § 63.6625(b), reducing these data to 4-hour rolling averages; and maintaining the 4-hour rolling averages within the limitation of greater than or equal to 750 °F and less than or equal to 1250 °F for the catalyst inlet temperature;</p> <p>or</p> <p>iii. Immediately shutting down the engine if the catalyst inlet temperature exceeds 1250 °F.</p>

<sup>a</sup> After you have demonstrated compliance for two consecutive tests, you may reduce the frequency of subsequent performance tests to annually. If the results of any subsequent annual performance test indicate the stationary RICE is not in compliance with the CO or formaldehyde emission limitation, or you deviate from any of your operating limitations, you must resume semiannual performance tests.

[78 FR 6715, Jan. 30, 2013]

## Table 7 to Subpart ZZZZ of Part 63—Requirements for Reports

As stated in § 63.6650, you must comply with the following requirements for reports:

For each . . .	You must submit a . . .	The report must contain . . .	You must submit the report . . .
1. Existing non-emergency, non-black start stationary RICE $100 \leq \text{HP} \leq 500$ located at a major source of HAP; existing non-emergency, non-black start stationary CI RICE $> 500$ HP located at a major source of HAP; existing non-emergency 4SRB stationary RICE $> 500$ HP located at a major source of HAP; existing non-emergency, non-black start stationary CI RICE $> 300$ HP located at an area source of HAP; new or reconstructed non-emergency stationary RICE $> 500$ HP located at a major source of HAP; and new or reconstructed non-emergency 4SLB stationary RICE $250 \leq \text{HP} \leq 500$ located at a major source of HAP	Compliance report	<p>a. If there are no deviations from any emission limitations or operating limitations that apply to you, a statement that there were no deviations from the emission limitations or operating limitations during the reporting period. If there were no periods during which the CMS, including CEMS and CPMS, was out-of-control, as specified in § 63.8(c)(7), a statement that there were not periods during which the CMS was out-of-control during the reporting period; or</p> <p>b. If you had a deviation from any emission limitation or operating limitation during the reporting period, the information in § 63.6650(d). If there were periods during which the CMS, including CEMS and CPMS, was out-of-control, as specified in § 63.8(c)(7), the information in § 63.6650(e); or</p> <p>c. If you had a malfunction during the reporting period, the information in § 63.6650(c)(4)</p>	<p>i. Semiannually according to the requirements in § 63.6650(b)(1)-(5) and (i) for engines that are not limited use stationary RICE subject to numerical emission limitations; and ii. Annually according to the requirements in § 63.6650(b)(6)-(9) and (i) for engines that are limited use stationary RICE subject to numerical emission limitations.</p> <p>i. Semiannually according to the requirements in § 63.6650(b) and (i).</p> <p>i. Semiannually according to the requirements in § 63.6650(b) and (i).</p>

For each . . .	You must submit a . . .	The report must contain . . .	You must submit the report . . .
2. New or reconstructed non-emergency stationary RICE that combusts landfill gas or digester gas equivalent to 10 percent or more of the gross heat input on an annual basis	Report	<p>a. The fuel flow rate of each fuel and the heating values that were used in your calculations, and you must demonstrate that the percentage of heat input provided by landfill gas or digester gas, is equivalent to 10 percent or more of the gross heat input on an annual basis; and</p> <p>b. The operating limits provided in your federally enforceable permit, and any deviations from these limits; and</p> <p>c. Any problems or errors suspected with the meters</p>	<p>i. Annually, according to the requirements in § 63.6650.</p> <p>i. See item 2.a.i.</p> <p>i. See item 2.a.i.</p>
3. Existing non-emergency, non-black start 4SLB and 4SRB stationary RICE >500 HP located at an area source of HAP that are not remote stationary RICE and that operate more than 24 hours per calendar year	Compliance report	a. The results of the annual compliance demonstration, if conducted during the reporting period	i. Semiannually according to the requirements in § 63.6650(b)(1)-(5) and (i).
4. Emergency stationary RICE that operate for the purposes specified in § 63.6640(f)(4)(ii)	Report	a. The information in § 63.6650(h)(1)	i. Annually according to the requirements in § 63.6650(h)(2)-(3) and (i).

[89 FR 70522, Aug. 30, 2024]



## Table 8 to Subpart ZZZZ of Part 63—Applicability of General Provisions to Subpart ZZZZ

As stated in § 63.6665, you must comply with the following applicable general provisions.

General provisions citation	Subject of citation	Applies to subpart	Explanation
§ 63.1	General applicability of the General Provisions	Yes	Additional terms defined in § 63.6675.
§ 63.2	Definitions	Yes	
§ 63.3	Units and abbreviations	Yes	
§ 63.4	Prohibited activities and circumvention	Yes	
§ 63.5	Construction and reconstruction	Yes	
§ 63.6(a)	Applicability	Yes	
§ 63.6(b)(1)-(4)	Compliance dates for new and reconstructed sources	Yes	
§ 63.6(b)(5)	Notification	Yes	
§ 63.6(b)(6)	[Reserved]		
§ 63.6(b)(7)	Compliance dates for new and reconstructed area sources that become major sources	Yes	
§ 63.6(c)(1)-(2)	Compliance dates for existing sources	Yes	
§ 63.6(c)(3)-(4)	[Reserved]		
§ 63.6(c)(5)	Compliance dates for existing area sources that become major sources	Yes	
§ 63.6(d)	[Reserved]		
§ 63.6(e)	Operation and maintenance	No	
§ 63.6(f)(1)	Applicability of standards	No	
§ 63.6(f)(2)	Methods for determining compliance	Yes	
§ 63.6(f)(3)	Finding of compliance	Yes	
§ 63.6(g)(1)-(3)	Use of alternate standard	Yes	Subpart ZZZZ does not contain opacity or visible emission standards.
§ 63.6(h)	Opacity and visible emission standards	No	
§ 63.6(i)	Compliance extension procedures and criteria	Yes	

General provisions citation	Subject of citation	Applies to subpart	Explanation
§ 63.6(j)	Presidential compliance exemption	Yes	
§ 63.7(a)(1)-(2)	Performance test dates	Yes	Subpart ZZZZ contains performance test dates at §§ 63.6610, 63.6611, and 63.6612.
§ 63.7(a)(3)	CAA section 114 authority	Yes	
§ 63.7(b)(1)	Notification of performance test	Yes	Except that § 63.7(b)(1) only applies as specified in § 63.6645.
§ 63.7(b)(2)	Notification of rescheduling	Yes	Except that § 63.7(b)(2) only applies as specified in § 63.6645.
§ 63.7(c)	Quality assurance/test plan	Yes	Except that § 63.7(c) only applies as specified in § 63.6645.
§ 63.7(d)	Testing facilities	Yes	
§ 63.7(e)(1)	Conditions for conducting performance tests	No	Subpart ZZZZ specifies conditions for conducting performance tests at § 63.6620.
§ 63.7(e)(2)	Conduct of performance tests and reduction of data	Yes	Subpart ZZZZ specifies test methods at § 63.6620.
§ 63.7(e)(3)	Test run duration	Yes	
§ 63.7(e)(4)	Administrator may require other testing under section 114 of the CAA	Yes	
§ 63.7(f)	Alternative test method provisions	Yes	
§ 63.7(g)	Performance test data analysis, recordkeeping, and reporting	Yes	
§ 63.7(h)	Waiver of tests	Yes	
§ 63.8(a)(1)	Applicability of monitoring requirements	Yes	Subpart ZZZZ contains specific requirements for monitoring at § 63.6625.
§ 63.8(a)(2)	Performance specifications	Yes	
§ 63.8(a)(3)	[Reserved]		
§ 63.8(a)(4)	Monitoring for control devices	No	
§ 63.8(b)(1)	Monitoring	Yes	
§ 63.8(b)(2)-(3)	Multiple effluents and multiple monitoring systems	Yes	
§ 63.8(c)(1)	Monitoring system	Yes	

General provisions citation	Subject of citation	Applies to subpart	Explanation
	operation and maintenance		
§ 63.8(c)(1)(i)	Routine and predictable SSM	No	
§ 63.8(c)(1)(ii)	SSM not in Startup Shutdown Malfunction Plan	Yes	
§ 63.8(c)(1)(iii)	Compliance with operation and maintenance requirements	No	
§ 63.8(c)(2)-(3)	Monitoring system installation	Yes	
§ 63.8(c)(4)	Continuous monitoring system (CMS) requirements	Yes	Except that subpart ZZZZ does not require Continuous Opacity Monitoring System (COMS).
§ 63.8(c)(5)	COMS minimum procedures	No	Subpart ZZZZ does not require COMS.
§ 63.8(c)(6)-(8)	CMS requirements	Yes	Except that subpart ZZZZ does not require COMS.
§ 63.8(d)	CMS quality control	Yes	
§ 63.8(e)	CMS performance evaluation	Yes	Except for § 63.8(e)(5)(ii), which applies to COMS. Except that § 63.8(e) only applies as specified in § 63.6645.
§ 63.8(f)(1)-(5)	Alternative monitoring method	Yes	Except that § 63.8(f)(4) only applies as specified in § 63.6645.
§ 63.8(f)(6)	Alternative to relative accuracy test	Yes	Except that § 63.8(f)(6) only applies as specified in § 63.6645.
§ 63.8(g)	Data reduction	Yes	Except that provisions for COMS are not applicable. Averaging periods for demonstrating compliance are specified at §§ 63.6635 and 63.6640.
§ 63.9(a)	Applicability and State delegation of notification requirements	Yes	
§ 63.9(b)(1)-(5)	Initial notifications	Yes	Except that § 63.9(b)(3) is reserved. Except that § 63.9(b) only applies as specified in § 63.6645.
§ 63.9(c)	Request for compliance	Yes	Except that § 63.9(c) only applies as

General provisions citation	Subject of citation	Applies to subpart	Explanation
§ 63.9(d)	extension Notification of special compliance requirements for new sources	Yes	specified in § 63.6645. Except that § 63.9(d) only applies as specified in § 63.6645.
§ 63.9(e)	Notification of performance test	Yes	Except that § 63.9(e) only applies as specified in § 63.6645.
§ 63.9(f)	Notification of visible emission (VE)/opacity test	No	Subpart ZZZZ does not contain opacity or VE standards.
§ 63.9(g)(1)	Notification of performance evaluation	Yes	Except that § 63.9(g) only applies as specified in § 63.6645.
§ 63.9(g)(2)	Notification of use of COMS data	No	Subpart ZZZZ does not contain opacity or VE standards.
§ 63.9(g)(3)	Notification that criterion for alternative to RATA is exceeded	Yes	If alternative is in use. Except that § 63.9(g) only applies as specified in § 63.6645.
§ 63.9(h)(1)-(6)	Notification of compliance status	Yes	Except that notifications for sources using a CEMS are due 30 days after completion of performance evaluations. § 63.9(h)(4) is reserved. Except that § 63.9(h) only applies as specified in § 63.6645.
§ 63.9(i)	Adjustment of submittal deadlines	Yes	
§ 63.9(j)	Change in previous information	Yes	
§ 63.9(k)	Electronic reporting procedures	Yes	Only as specified in §§ 63.9(j), 63.6620, 63.6625, 63.6645, and 63.6650.
§ 63.10(a)	Administrative provisions for recordkeeping/reporting	Yes	
§ 63.10(b)(1)	Record retention	Yes	Except that the most recent 2 years of data do not have to be retained on site.
§ 63.10(b)(2)(i)-(v)	Records related to SSM	No	
§ 63.10(b)(2)(vi)-(xi)	Records	Yes	
§	Record when under	Yes	

General provisions citation	Subject of citation	Applies to subpart	Explanation
63.10(b)(2)(xii)	waiver		
§ 63.10(b)(2)(xiii)	Records when using alternative to RATA	Yes	For CO standard if using RATA alternative.
§ 63.10(b)(2)(xiv)	Records of supporting documentation	Yes	
§ 63.10(b)(3)	Records of applicability determination	Yes	
§ 63.10(c)	Additional records for sources using CEMS	Yes	Except that § 63.10(c)(2)-(4) and (9) are reserved.
§ 63.10(d)(1)	General reporting requirements	Yes	
§ 63.10(d)(2)	Report of performance test results	Yes	
§ 63.10(d)(3)	Reporting opacity or VE observations	No	Subpart ZZZZ does not contain opacity or VE standards.
§ 63.10(d)(4)	Progress reports	Yes	
§ 63.10(d)(5)	Startup, shutdown, and malfunction reports	No	
§ 63.10(e)(1) and (2)(i)	Additional CMS Reports	Yes	
§ 63.10(e)(2)(ii)	COMS-related report	No	Subpart ZZZZ does not require COMS.
§ 63.10(e)(3)	Excess emission and parameter exceedances reports	No	Excess emissions and exceedance reporting is specified in § 63.6650.
§ 63.10(e)(4)	Reporting COMS data	No	Subpart ZZZZ does not require COMS.
§ 63.10(f)	Waiver for recordkeeping/reporting	Yes	
§ 63.11	Flares	No	
§ 63.12	State authority and delegations	Yes	
§ 63.13	Addresses	Yes	
§ 63.14	Incorporation by reference	Yes	
§ 63.15	Availability of information	Yes	

[89 FR 70522, Aug. 30, 2024]

## Appendix A to Subpart ZZZZ of Part 63—Protocol for Using an Electrochemical Analyzer to Determine Oxygen and Carbon Monoxide Concentrations From Certain Engines

### 1.0 Scope and Application. What is this Protocol?

This protocol is a procedure for using portable electrochemical (EC) cells for measuring carbon monoxide (CO) and oxygen (O<sub>2</sub>) concentrations in controlled and uncontrolled emissions from existing stationary 4-stroke lean burn and 4-stroke rich burn reciprocating internal combustion engines as specified in the applicable rule.

### 1.1 Analytes. What does this protocol determine?

This protocol measures the engine exhaust gas concentrations of carbon monoxide (CO) and oxygen (O<sub>2</sub>).

Analyte	CAS No.	Sensitivity
Carbon monoxide (CO)	630-08-0	Minimum detectable limit should be 2 percent of the nominal range or 1 ppm, whichever is less restrictive.
Oxygen (O <sub>2</sub> )	7782-44-7	

### 1.2 Applicability. When is this protocol acceptable?

This protocol is applicable to 40 CFR part 63, subpart ZZZZ. Because of inherent cross sensitivities of EC cells, you must not apply this protocol to other emissions sources without specific instruction to that effect.

### 1.3 Data Quality Objectives. How good must my collected data be?

Refer to Section 13 to verify and document acceptable analyzer performance.

### 1.4 Range. What is the targeted analytical range for this protocol?

The measurement system and EC cell design(s) conforming to this protocol will determine the analytical range for each gas component. The nominal ranges are defined by choosing up-scale calibration gas concentrations near the maximum anticipated flue gas concentrations for CO and O<sub>2</sub>, or no more than twice the permitted CO level.

### 1.5 Sensitivity. What minimum detectable limit will this protocol yield for a particular gas component?

The minimum detectable limit depends on the nominal range and resolution of the specific EC cell used, and the signal to noise ratio of the measurement system. The minimum detectable limit should be 2 percent of the nominal range or 1 ppm, whichever is less restrictive.

## 2.0 Summary of Protocol

In this protocol, a gas sample is extracted from an engine exhaust system and then conveyed to a portable EC analyzer for measurement of CO and O<sub>2</sub> gas concentrations. This method provides measurement system performance specifications and sampling protocols to ensure reliable data. You may use additions to, or modifications of vendor supplied measurement systems (e.g., heated or unheated sample lines, thermocouples, flow meters, selective gas scrubbers, etc.) to meet the design specifications of this protocol. Do not make changes to the measurement system from the as-verified configuration (Section 3.12).

## 3.0 Definitions

- 3.1 Measurement System.** The total equipment required for the measurement of CO and O<sub>2</sub> concentrations. The measurement system consists of the following major subsystems:
  - 3.1.1 Data Recorder.** A strip chart recorder, computer or digital recorder for logging measurement data from the analyzer output. You may record measurement data from the digital data display manually or electronically.
  - 3.1.2 Electrochemical (EC) Cell.** A device, similar to a fuel cell, used to sense the presence of a specific analyte and generate an electrical current output proportional to the analyte concentration.
  - 3.1.3 Interference Gas Scrubber.** A device used to remove or neutralize chemical compounds that may interfere with the selective operation of an EC cell.
  - 3.1.4 Moisture Removal System.** Any device used to reduce the concentration of moisture in the sample stream so as to protect the EC cells from the damaging effects of condensation and to minimize errors in measurements caused by the scrubbing of soluble gases.
  - 3.1.5 Sample Interface.** The portion of the system used for one or more of the following: sample acquisition; sample transport; sample conditioning or protection of the EC cell from any degrading effects of the engine exhaust effluent; removal of particulate matter and condensed moisture.
- 3.2 Nominal Range.** The range of analyte concentrations over which each EC cell is operated (normally 25 percent to 150 percent of up-scale calibration gas value). Several nominal ranges can be used for any given cell so long as the calibration and repeatability checks for that range remain within specifications.
- 3.3 Calibration Gas.** A vendor certified concentration of a specific analyte in an appropriate balance gas.
- 3.4 Zero Calibration Error.** The analyte concentration output exhibited by the EC cell in response to zero-level calibration gas.
- 3.5 Up-Scale Calibration Error.** The mean of the difference between the analyte concentration exhibited by the EC cell and the certified concentration of the up-scale calibration gas.

- 3.6 Interference Check.** A procedure for quantifying analytical interference from components in the engine exhaust gas other than the targeted analytes.
- 3.7 Repeatability Check.** A protocol for demonstrating that an EC cell operated over a given nominal analyte concentration range provides a stable and consistent response and is not significantly affected by repeated exposure to that gas.
- 3.8 Sample Flow Rate.** The flow rate of the gas sample as it passes through the EC cell. In some situations, EC cells can experience drift with changes in flow rate. The flow rate must be monitored and documented during all phases of a sampling run.
- 3.9 Sampling Run.** A timed three-phase event whereby an EC cell's response rises and plateaus in a sample conditioning phase, remains relatively constant during a measurement data phase, then declines during a refresh phase. The sample conditioning phase exposes the EC cell to the gas sample for a length of time sufficient to reach a constant response. The measurement data phase is the time interval during which gas sample measurements can be made that meet the acceptance criteria of this protocol. The refresh phase then purges the EC cells with CO-free air. The refresh phase replenishes requisite O<sub>2</sub> and moisture in the electrolyte reserve and provides a mechanism to de-gas or desorb any interference gas scrubbers or filters so as to enable a stable CO EC cell response. There are four primary types of sampling runs: pre-sampling calibrations; stack gas sampling; post-sampling calibration checks; and measurement system repeatability checks. Stack gas sampling runs can be chained together for extended evaluations, providing all other procedural specifications are met.
- 3.10 Sampling Day.** A time not to exceed twelve hours from the time of the pre-sampling calibration to the post-sampling calibration check. During this time, stack gas sampling runs can be repeated without repeated recalibrations, providing all other sampling specifications have been met.
- 3.11 Pre-Sampling Calibration/Post-Sampling Calibration Check.** The protocols executed at the beginning and end of each sampling day to bracket measurement readings with controlled performance checks.
- 3.12 Performance-Established Configuration.** The EC cell and sampling system configuration that existed at the time that it initially met the performance requirements of this protocol.

## 4.0 Interferences.

When present in sufficient concentrations, NO and NO<sub>2</sub> are two gas species that have been reported to interfere with CO concentration measurements. In the likelihood of this occurrence, it is the protocol user's responsibility to employ and properly maintain an appropriate CO EC cell filter or scrubber for removal of these gases, as described in Section 6.2.12.

## 5.0 Safety. [Reserved]

## 6.0 Equipment and Supplies.

### 6.1 What equipment do I need for the measurement system?



The system must maintain the gas sample at conditions that will prevent moisture condensation in the sample transport lines, both before and as the sample gas contacts the EC cells. The essential components of the measurement system are described below.

## 6.2 Measurement System Components.

- 6.2.1 **Sample Probe.** A single extraction-point probe constructed of glass, stainless steel or other non-reactive material, and of length sufficient to reach any designated sampling point. The sample probe must be designed to prevent plugging due to condensation or particulate matter.
- 6.2.2 **Sample Line.** Non-reactive tubing to transport the effluent from the sample probe to the EC cell.
- 6.2.3 **Calibration Assembly (optional).** A three-way valve assembly or equivalent to introduce calibration gases at ambient pressure at the exit end of the sample probe during calibration checks. The assembly must be designed such that only stack gas or calibration gas flows in the sample line and all gases flow through any gas path filters.
- 6.2.4 **Particulate Filter (optional).** Filters before the inlet of the EC cell to prevent accumulation of particulate material in the measurement system and extend the useful life of the components. All filters must be fabricated of materials that are non-reactive to the gas mixtures being sampled.
- 6.2.5 **Sample Pump.** A leak-free pump to provide undiluted sample gas to the system at a flow rate sufficient to minimize the response time of the measurement system. If located upstream of the EC cells, the pump must be constructed of a material that is non-reactive to the gas mixtures being sampled.
- 6.2.8 **Sample Flow Rate Monitoring.** An adjustable rotameter or equivalent device used to adjust and maintain the sample flow rate through the analyzer as prescribed.
- 6.2.9 **Sample Gas Manifold (optional).** A manifold to divert a portion of the sample gas stream to the analyzer and the remainder to a by-pass discharge vent. The sample gas manifold may also include provisions for introducing calibration gases directly to the analyzer. The manifold must be constructed of a material that is non-reactive to the gas mixtures being sampled.
- 6.2.10 **EC cell.** A device containing one or more EC cells to determine the CO and O<sub>2</sub> concentrations in the sample gas stream. The EC cell(s) must meet the applicable performance specifications of Section 13 of this protocol.
- 6.2.11 **Data Recorder.** A strip chart recorder, computer or digital recorder to make a record of analyzer output data. The data recorder resolution (i.e., readability) must be no greater than 1 ppm for CO; 0.1 percent for O<sub>2</sub>; and one degree (either °C or °F) for temperature. Alternatively, you may use a digital or analog meter having the same resolution to observe and manually record the analyzer responses.
- 6.2.12 **Interference Gas Filter or Scrubber.** A device to remove interfering compounds upstream of the CO EC cell. Specific interference gas filters or scrubbers used in the performance-established configuration of the analyzer must continue to be used. Such a filter or scrubber must have a means to determine when the removal agent is exhausted. Periodically replace or replenish it in accordance with the manufacturer's recommendations.

## 7.0 Reagents and Standards. What calibration gases are needed?

- 7.1 Calibration Gases.** CO calibration gases for the EC cell must be CO in nitrogen or CO in a mixture of nitrogen and O<sub>2</sub>. Use CO calibration gases with labeled concentration values certified by the manufacturer to be within  $\pm 5$  percent of the label value. Dry ambient air (20.9 percent O<sub>2</sub>) is acceptable for calibration of the O<sub>2</sub> cell. If needed, any lower percentage O<sub>2</sub> calibration gas must be a mixture of O<sub>2</sub> in nitrogen.
- 7.1.1 Up-Scale CO Calibration Gas Concentration.** Choose one or more up-scale gas concentrations such that the average of the stack gas measurements for each stack gas sampling run are between 25 and 150 percent of those concentrations. Alternatively, choose an up-scale gas that does not exceed twice the concentration of the applicable outlet standard. If a measured gas value exceeds 150 percent of the up-scale CO calibration gas value at any time during the stack gas sampling run, the run must be discarded and repeated.
- 7.1.2 Up-Scale O<sub>2</sub> Calibration Gas Concentration.**
- Select an O<sub>2</sub> gas concentration such that the difference between the gas concentration and the average stack gas measurement or reading for each sample run is less than 15 percent O<sub>2</sub>. When the average exhaust gas O<sub>2</sub> readings are above 6 percent, you may use dry ambient air (20.9 percent O<sub>2</sub>) for the up-scale O<sub>2</sub> calibration gas.
- 7.1.3 Zero Gas.** Use an inert gas that contains less than 0.25 percent of the up-scale CO calibration gas concentration. You may use dry air that is free from ambient CO and other combustion gas products (e.g., CO<sub>2</sub>).

## 8.0 Sample Collection and Analysis

- 8.1 Selection of Sampling Sites.**
- 8.1.1 Control Device Inlet.** Select a sampling site sufficiently downstream of the engine so that the combustion gases should be well mixed. Use a single sampling extraction point near the center of the duct (e.g., within the 10 percent centroidal area), unless instructed otherwise.
- 8.1.2 Exhaust Gas Outlet.** Select a sampling site located at least two stack diameters downstream of any disturbance (e.g., turbocharger exhaust, crossover junction or recirculation take-off) and at least one-half stack diameter upstream of the gas discharge to the atmosphere. Use a single sampling extraction point near the center of the duct (e.g., within the 10 percent centroidal area), unless instructed otherwise.
- 8.2 Stack Gas Collection and Analysis.** Prior to the first stack gas sampling run, conduct that the pre-sampling calibration in accordance with Section 10.1. Use Figure 1 to record all data. Zero the analyzer with zero gas. Confirm and record that the scrubber media color is correct and not exhausted. Then position the probe at the sampling point and begin the sampling run at the same flow rate used during the up-scale calibration. Record the start time. Record all EC cell output responses and the flow rate during the "sample conditioning phase" once per minute until constant readings are obtained. Then begin the "measurement data phase" and record readings every 15 seconds for at least two minutes (or eight readings), or as otherwise required to achieve two continuous minutes of data that meet the specification given in Section 13.1. Finally, perform the

"refresh phase" by introducing dry air, free from CO and other combustion gases, until several minute-to-minute readings of consistent value have been obtained. For each run use the "measurement data phase" readings to calculate the average stack gas CO and O<sub>2</sub> concentrations.

- 8.3 EC Cell Rate.** Maintain the EC cell sample flow rate so that it does not vary by more than  $\pm 10$  percent throughout the pre-sampling calibration, stack gas sampling and post-sampling calibration check. Alternatively, the EC cell sample flow rate can be maintained within a tolerance range that does not affect the gas concentration readings by more than  $\pm 3$  percent, as instructed by the EC cell manufacturer.

## 9.0 Quality Control (Reserved)

## 10.0 Calibration and Standardization

- 10.1 Pre-Sampling Calibration.** Conduct the following protocol once for each nominal range to be used on each EC cell before performing a stack gas sampling run on each field sampling day. Repeat the calibration if you replace an EC cell before completing all of the sampling runs. There is no prescribed order for calibration of the EC cells; however, each cell must complete the measurement data phase during calibration. Assemble the measurement system by following the manufacturer's recommended protocols including for preparing and preconditioning the EC cell. Assure the measurement system has no leaks and verify the gas scrubbing agent is not depleted. Use Figure 1 to record all data.

- 10.1.1 Zero Calibration.** For both the O<sub>2</sub> and CO cells, introduce zero gas to the measurement system (e.g., at the calibration assembly) and record the concentration reading every minute until readings are constant for at least two consecutive minutes. Include the time and sample flow rate. Repeat the steps in this section at least once to verify the zero calibration for each component gas.

- 10.1.2 Zero Calibration Tolerance.** For each zero gas introduction, the zero level output must be less than or equal to  $\pm 3$  percent of the up-scale gas value or  $\pm 1$  ppm, whichever is less restrictive, for the CO channel and less than or equal to  $\pm 0.3$  percent O<sub>2</sub> for the O<sub>2</sub> channel.

- 10.1.3 Up-Scale Calibration.** Individually introduce each calibration gas to the measurement system (e.g., at the calibration assembly) and record the start time. Record all EC cell output responses and the flow rate during this "sample conditioning phase" once per minute until readings are constant for at least two minutes. Then begin the "measurement data phase" and record readings every 15 seconds for a total of two minutes, or as otherwise required. Finally, perform the "refresh phase" by introducing dry air, free from CO and other combustion gases, until readings are constant for at least two consecutive minutes. Then repeat the steps in this section at least once to verify the calibration for each component gas. Introduce all gases to flow through the entire sample handling system (i.e., at the exit end of the sampling probe or the calibration assembly).

- 10.1.4 Up-Scale Calibration Error.** The mean of the difference of the "measurement data phase" readings from the reported standard gas value must be less than or equal to  $\pm 5$  percent or  $\pm 1$  ppm for CO or  $\pm 0.5$  percent O<sub>2</sub>, whichever is less restrictive, respectively. The maximum allowable deviation from the mean measured value of any single "measurement data phase" reading must be less than or equal to  $\pm 2$  percent or  $\pm 1$  ppm for CO or  $\pm 0.5$  percent O<sub>2</sub>, whichever is less restrictive, respectively.

- 10.2 Post-Sampling Calibration Check.** Conduct a stack gas post-sampling calibration check after the stack gas sampling run or set of runs and within 12 hours of the initial calibration. Conduct up-scale and zero calibration checks using the protocol in Section 10.1. Make no changes to the sampling system or EC cell calibration until all post-sampling calibration checks have been recorded. If either the zero or up-scale calibration error exceeds the respective specification in Sections 10.1.2 and 10.1.4 then all measurement data collected since the previous successful calibrations are invalid and re-calibration and re-sampling are required. If the sampling system is disassembled or the EC cell calibration is adjusted, repeat the calibration check before conducting the next analyzer sampling run.

## 11.0 Analytical Procedure

The analytical procedure is fully discussed in Section 8.

## 12.0 Calculations and Data Analysis

Determine the CO and O<sub>2</sub> concentrations for each stack gas sampling run by calculating the mean gas concentrations of the data recorded during the “measurement data phase”.

## 13.0 Protocol Performance

Use the following protocols to verify consistent analyzer performance during each field sampling day.

- 13.1 Measurement Data Phase Performance Check.** Calculate the mean of the readings from the “measurement data phase”. The maximum allowable deviation from the mean for each of the individual readings is  $\pm 2$  percent, or  $\pm 1$  ppm, whichever is less restrictive. Record the mean value and maximum deviation for each gas monitored. Data must conform to Section 10.1.4. The EC cell flow rate must conform to the specification in Section 8.3.

**Example:** A measurement data phase is invalid if the maximum deviation of any single reading comprising that mean is greater than  $\pm 2$  percent or  $\pm 1$  ppm (the default criteria). For example, if the mean = 30 ppm, single readings of below 29 ppm and above 31 ppm are disallowed).

- 13.2 Interference Check.** Before the initial use of the EC cell and interference gas scrubber in the field, and semi-annually thereafter, challenge the interference gas scrubber with NO and NO<sub>2</sub> gas standards that are generally recognized as representative of diesel-fueled engine NO and NO<sub>2</sub> emission values. Record the responses displayed by the CO EC cell and other pertinent data on Figure 1 or a similar form.

**13.2.1 Interference Response.** The combined NO and NO<sub>2</sub> interference response should be less than or equal to  $\pm 5$  percent of the up-scale CO calibration gas concentration.

- 13.3 Repeatability Check.** Conduct the following check once for each nominal range that is to be used on the CO EC cell within 5 days prior to each field sampling program. If a field sampling program lasts longer than 5 days, repeat this check every 5 days. Immediately repeat the check if the EC cell is replaced or if the EC cell is exposed to gas concentrations greater than 150 percent of the highest up-scale gas concentration.

- 13.3.1 **Repeatability Check Procedure.** Perform a complete EC cell sampling run (all three phases) by introducing the CO calibration gas to the measurement system and record the response. Follow Section 10.1.3. Use Figure 1 to record all data. Repeat the run three times for a total of four complete runs. During the four repeatability check runs, do not adjust the system except where necessary to achieve the correct calibration gas flow rate at the analyzer.
- 13.3.2 **Repeatability Check Calculations.** Determine the highest and lowest average “measurement data phase” CO concentrations from the four repeatability check runs and record the results on Figure 1 or a similar form. The absolute value of the difference between the maximum and minimum average values recorded must not vary more than ±3 percent or ±1 ppm of the up-scale gas value, whichever is less restrictive.

14.0 Pollution Prevention (Reserved)

15.0 Waste Management (Reserved)

16.0 Alternative Procedures (Reserved)

17.0 References

- (1) *“Development of an Electrochemical Cell Emission Analyzer Test Protocol”* , Topical Report, Phil Juneau, Emission Monitoring, Inc., July 1997.
- (2) *“Determination of Nitrogen Oxides, Carbon Monoxide, and Oxygen Emissions from Natural Gas-Fired Engines, Boilers, and Process Heaters Using Portable Analyzers”* , EMC Conditional Test Protocol 30 (CTM-30), Gas Research Institute Protocol GRI-96/0008, Revision 7, October 13, 1997.
- (3) *“ICAC Test Protocol for Periodic Monitoring”* , EMC Conditional Test Protocol 34 (CTM-034), The Institute of Clean Air Companies, September 8, 1999.
- (4) *“Code of Federal Regulations”* , Protection of Environment, 40 CFR, Part 60, Appendix A, Methods 1-4; 10.

TABLE 1: APPENDIX A—SAMPLING RUN DATA.

	Facility_____	Engine I.D._____	Date_____	
Run	(-)	(-)	(-)	(-)
Type:				
(X)	Pre-Sample Calibration	Stack Gas Sample	Post-Sample Cal. Check	Repeatability Check

Run #	1	1	2	2	3	3	4	4	Time	Scrub. OK	Flow- Rate
Gas	O <sub>2</sub>	CO	O <sub>2</sub>	CO	O <sub>2</sub>	CO	O <sub>2</sub>	CO			
Sample Cond. Phase											
"											
"											
"											
Measurement Data Phase											
"											
"											
"											
"											
"											
"											
"											
"											
Mean Refresh Phase											
"											
"											
"											
"											

[78 FR 6721, Jan. 30, 2013]