

ADEQ

ARKANSAS
Department of Environmental Quality

March 22, 2016

Greg L. Withrow, General Mgr.
El Dorado Chemical
P.O. Box 231
El Dorado, AR 71730

RE: NPDES Permit Number AR0000752, AFIN 70-00040
NPDES Permit Effluent Violations

Dear Mr. Withrow,

A review of the above referenced facility revealed the following exceedances during 2016:

Monitoring Period End Date	Dsch#	Parameter	Limit Value	DMR Value	Violation Code	% Vio
01/31/2016	006-A	Zinc, total recoverable, MO AVG, ug/L	115.62	895	E90	674%
01/31/2016	006-A	Zinc, total recoverable, DAILY MX, ug/L	231.99	1100	E90	374%
01/31/2016	006-A	Lead, total recoverable, MO AVG, ug/L	3.8	33	E90	768%
01/31/2016	006-A	Lead, total recoverable, DAILY MX, ug/L	7.62	39	E90	412%
01/31/2016	006-A	Solids, total dissolved, MO AVG, mg/L	291	345	E90	19%
01/31/2016	007-A	Solids, total dissolved, MO AVG, mg/L	291	815	E90	180%
01/31/2016	006-A	Solids, total dissolved, DAILY MX, mg/L	436.5	450	E90	3%
01/31/2016	007-A	Solids, total dissolved, DAILY MX, mg/L	436.5	1300	E90	198%

Failure to remain in compliance with the effluent limitations set forth in your permit violates Part I, Section A of your permit, and may result in formal enforcement action that will include the assessment of a civil penalty.

Thank you for your attention to this matter. Should you have any questions, feel free to contact me at 501-682-0664 or you may e-mail me at pemberton@adeq.state.ar.us.

Sincerely,



Layne Pemberton
Enforcement Analyst
NPDES Enforcement Section